



Control Number: 50594



Item Number: 102

Addendum StartPage: 0



Public Utility Commission of Texas

**Five-Year Report
Required by 16 Texas Admin. Code § 25.97(e)**



PROJECT NO. 50594

AFFECTED ENTITY: Guadalupe Valley Electric Cooperative, Inc.

General Information

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

102

1. Historical five-year reporting period: 2015 to 2019

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

During the last five-year reporting period, GVEC has completed comprehensive inspections for clearance and other issues on 80% of our 69 kV and 138 kV transmission system. In addition, we conduct visual inspections of all 69 kV and 138kV transmission lines annually.

2. Future five-year reporting period: 2020 to 2024

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?


GVEC has created and implemented a plan to inspect 100% of its transmission facilities over 60kV in the years 2020 to 2024. All lines will be inspected for compliance with the NESC vertical clearance Standards by December 2024.

Affected Entity: Guadalupe Valley Electric Cooperative, Inc.

PROJECT NO. 50594

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.



Signature

Robert B. Christmas

Printed Name


Senior Executive Manager

Job Title

Guadalupe Valley Electric Cooperative, Inc.

Name of Affected Entity

Sworn and subscribed before me this 12th day of April, 2021
Month



Notary Public in and For the State of TEXAS

My commission expires on 7-22-2024

