



Control Number: 50594



Item Number: 92

Addendum StartPage: 0



Public Utility Commission of Texas  
Five-Year Report  
Required by 16 Texas Admin. Code § 25.97(e)

PROJECT NO. 50594

AFFECTED ENTITY: Western Farmers Electric Cooperative

**General Information**

Pursuant to 16 Texas Admin. Code § 25.97(e)(1), not later than May 1 every five years, each affected entity that owns or operates overhead transmission facilities greater than 60 kilovolts must submit this report. The first report must be submitted not later than May 1, 2020.

**Instructions**

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

**Affidavit**

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

**Filing Instructions**

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk  
Public Utility Commission of Texas  
1701 N. Congress Avenue  
P.O. Box 13326  
Austin, Texas 78711-3326  
Telephone: (512) 936-7180

42

**1. Historical five-year reporting period:** 2015-2019

What percentage of overhead transmission facilities greater than 60 kilovolts did you inspect for compliance with the National Electric Safety Code (NESC) relating to vertical clearance in the historical five-year reporting period?

Western Farmers Electric Cooperative inspected 100% of its overhead transmission lines by means of aerial patrol two (2) times every calendar year and by foot patrol a minimum of once every two (2) years. Notation of any abnormalities in vertical clearances are part of this visual inspection process.

**2. Future five-year reporting period: 2020-2024**

What percentage of overhead transmission facilities greater than 60 kilovolts do you anticipate you will inspect for compliance with the NESC relating to vertical clearance during the future five-year reporting period beginning on January 1 of the year in which this report is submitted?

Western Farmers Electric Cooperative will continue to inspect 100% of its overhead transmission lines by means of aerial patrol two (2) times every calendar year and by foot patrol a minimum of once every two (2) years .

**AFFIDAVIT**

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

*Forrest Brock*  
Signature

Forrest Brock  
Printed Name

Manager, Transmission & Distribution Services  
Job Title

Western Farmers Electric Cooperative  
Name of Affected Entity

Sworn and subscribed before me this 22 day of JUNE, 2020  
Month Year

*[Signature]*  
Notary Public in and For the State of OKLAHOMA

My commission expires on \_\_\_\_\_

