

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
1868	1940	MKNGB	5321	392	26.95
1869	326	BLTON	1801	1464	26.94
1870	1324	LUFKN	1202	1274	26.82
1871	1868	TRLSW	1201	666	26.68
1872	1105	ROSCO	2921	212	26.49
1873	1937	MCDMT	2551	3869	26.46
1874	1706	SHDYG	7812	107	26.39
1875	2198	PCOIT	1004	688	26.17
1876	791	ALPHA	0009	64	26.06
1877	153	LKHLD	0003	1316	26.03
1878	1336	STNVL	1203	1842	26.03
1879	1368	PRKRW	3352	1546	26.01
1880	646	KEENE	1501	1468	25.98
1881	1818	ODESA	0231	1807	25.96
1882	606	CRLJL	1504	1209	25.94
1883	1670	PCUST	2011	2243	25.94
1884	2043	RWDHV	1902	1116	25.93
1885	798	JKREA	1201	28	25.89
1886	1922	PRKWY	1511	1361	25.89
1887	395	IOWPK	0821	748	25.75
1888	2340	MESFR	2104	126	25.72
1889	636	SCHRD	0004	1884	25.65
1890	N/A	MNWLL	1204	739	25.53
1891	1539	CTYVW	2221	1608	25.50
1892	362	GNSVL	1204	1320	25.43
1893	1398	KIMBL	5011	1501	25.43
1894	2028	MDDTN	4321	921	25.41
1895	2378	PRKRW	3311	977	25.37
1896	2167	PCUST	2006	1598	25.33
1897	1198	IRVGS	1902	1477	25.32
1898	1531	WRBND	2312	1505	25.29
1899	627	BNMAG	1202	370	25.24
1900	1371	HKBRY	1109	1357	25.17
1901	876	ALNTH	2853	2315	25.12
1902	1556	MURPH	2751	3530	25.09
1903	1872	CHROW	0003	58	25.09
1904	1487	ALLNC	6411	52	25.06
1905	1299	CRLUD	1303	671	25.04
1906	N/A	ROLTR	2911	3483	25.04
1907	1733	ARTHR	0492	48	25.00
1908	N/A	DFWNW	2602	25	25.00
1909	1161	HORNE	1913	1620	24.98
1910	1437	PPARK	1808	558	24.91
1911	2561	CRLUD	1306	23	24.87
1912	1669	RCHHL	0363	608	24.82
1913	2136	RWDHV	1905	1872	24.73
1914	1809	CPRCV	1402	2192	24.71
1915	205	BDFRD	8821	953	24.68

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
1916	1465	MNHNS	1912	1667	24.61
1917	1598	COLNY	2404	1946	24.58
1918	N/A	BRNSO	1804	11	24.55
1919	1450	IRVND	1206	116	24.52
1920	2392	MAPLE	0001	425	24.50
1921	2359	HMPHL	2721	189	24.44
1922	2223	CDHCR	2050	707	24.32
1923	2067	PALRD	2207	1340	24.22
1924	831	WDGWD	1512	840	24.18
1925	2033	HMTRD	0001	1076	24.13
1926	2413	DFWSW	2204	22	24.05
1927	573	PAYSW	1202	1596	24.04
1928	1154	MNWLW	1401	1601	24.02
1929	1599	BRYAN	0002	318	23.92
1930	1990	WFNTH	0211	878	23.87
1931	2467	WWEST	1216	244	23.86
1932	2244	WNDWD	3611	1035	23.67
1933	2438	RCLNS	1401	85	23.54
1934	901	WEAST	0615	404	23.54
1935	2194	SWDTN	1641	1632	23.54
1936	1365	KLELM	2205	1491	23.43
1937	985	PFLGV	2003	2433	23.43
1938	2390	FRNKF	0008	1149	23.41
1939	1399	MSHLN	0002	658	23.40
1940	1637	CRTLD	4721	3000	23.37
1941	541	MSLSW	0005	754	23.33
1942	508	LKWOD	7421	702	23.21
1943	1644	KILEN	1205	1241	23.18
1944	585	MNWLW	1402	1501	23.02
1945	1483	SHDYG	7831	89	22.88
1946	1920	MNHNS	1911	1176	22.86
1947	1168	TROY	1014	687	22.80
1948	1908	PGSTH	7011	158	22.79
1949	1191	ARTHR	0472	1718	22.75
1950	184	HSKAV	0004	890	22.67
1951	2267	FORSN	5621	50	22.58
1952	1261	MSHLN	0007	712	22.57
1953	1740	CMTSW	0921	1692	22.42
1954	1227	HMTRD	0004	1037	22.38
1955	2454	BRHLW	7631	721	22.38
1956	448	CRLJL	1505	811	22.37
1957	1438	KILEN	1204	961	22.28
1958	1812	MRKLY	0811	146	22.14
1959	1951	PALRD	2201	791	22.14
1960	2093	KILEN	1203	651	22.14
1961	1704	RTHGB	1411	2069	22.10
1962	2007	WINK	0521	55	22.02
1963	1984	BSPRW	2521	1750	22.01

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
1964	682	DCDAM	2001	805	22.00
1965	2398	BSPRG	1904	1263	21.97
1966	1693	RCHRD	1205	1085	21.95
1967	2213	ENSSO	2004	1110	21.95
1968	884	TMPNW	1101	2192	21.83
1969	1793	DUBLN	2214	763	21.74
1970	2042	CHROW	0001	121	21.73
1971	2334	SMOUR	0711	22	21.68
1972	717	DGNST	0005	116	21.67
1973	424	SHNRW	1609	1335	21.64
1974	1709	KFMSSO	1301	887	21.54
1975	1130	ROWLT	1105	1387	21.53
1976	312	PWEST	1303	984	21.53
1977	672	MABNK	2401	1833	21.50
1978	2208	ARTHR	0452	629	21.40
1979	1558	IRVNR	1559	2457	21.38
1980	834	TYOMN	1410	1026	21.30
1981	819	DALRK	1358	2724	21.29
1982	924	LOMAL	0016	649	21.27
1983	2462	WMMMR	2707	1338	21.27
1984	2036	KLNPS	1105	1762	21.14
1985	1574	IRVVV	2801	1348	21.11
1986	2393	BSPSW	0822	277	21.04
1987	771	ALPHA	0011	888	21.00
1988	1999	SHSTH	1303	774	20.95
1989	796	CDHCR	2051	2943	20.94
1990	296	DAVST	0001	859	20.93
1991	889	LKHLN	0001	1392	20.90
1992	2230	ARMST	0003	1234	20.81
1993	1763	ENTOH	0004	1575	20.78
1994	758	PLSTH	1301	601	20.77
1995	1881	CKRHL	0007	195	20.75
1996	N/A	PRNTH	1403	20	20.75
1997	2234	DFWNW	2601	37	20.70
1998	1587	REGST	0002	227	20.63
1999	764	WEAST	0618	933	20.63
2000	1518	TYBLR	2804	1785	20.61
2001	2188	WATSN	5352	1895	20.59
2002	1811	GYVLM	8611	11	20.45
2003	2419	VGCRK	8031	1727	20.37
2004	460	BONHM	1204	884	20.28
2005	2360	WNDWD	3631	312	20.21
2006	1909	LKTMS	2411	153	20.10
2007	2132	NCSFA	1706	595	20.08
2008	1560	PRFTW	4212	1638	20.04
2009	1739	KLNPS	1101	2787	19.97
2010	2084	SMFLD	2322	1267	19.90
2011	1136	JNKNS	0005	546	19.90

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2012	N/A	PEGAS	2321	349	19.88
2013	668	ELKTN	2503	275	19.87
2014	1179	DALWT	2921	285	19.81
2015	2343	COMRC	1204	713	19.75
2016	2242	WRBND	2321	1745	19.67
2017	2375	MDAIR	2911	367	19.57
2018	644	WEAST	0627	102	19.55
2019	236	MDLNE	0141	2398	19.52
2020	1962	SWDTN	1631	1554	19.38
2021	39	GRDPR	0881	1549	19.35
2022	2184	HSKAV	0002	1753	19.35
2023	615	WSOTH	1021	3271	19.33
2024	403	FRMBR	1808	625	19.31
2025	2207	WRBND	2322	937	19.22
2026	1084	BLTLN	0002	856	19.17
2027	1952	ENTOH	0006	1189	19.12
2028	N/A	FRMNT	0005	54	19.00
2029	1917	BRNWD	1201	1518	18.85
2030	2262	CRLJL	1508	136	18.76
2031	1945	HLTOM	2411	1280	18.74
2032	2074	PARIS	1206	991	18.64
2033	1319	WHTRK	0006	1127	18.62
2034	N/A	CRTLD	4722	43	18.60
2035	2522	MDLNW	1552	1081	18.41
2036	191	CRNTH	2404	3818	18.31
2037	2204	HRSMD	1951	4392	18.26
2038	2303	WATSN	5382	634	18.22
2039	2405	ARMST	0008	636	18.21
2040	1056	ARMST	0004	335	18.20
2041	N/A	DFWNW	2606	30	18.20
2042	2346	WFNTH	0221	621	18.17
2043	2202	STNVL	1202	742	18.16
2044	1425	DGNST	0001	71	18.15
2045	2277	GODRD	8122	1005	18.14
2046	2024	KLELM	2201	1868	18.14
2047	722	CHICC	1701	36	18.11
2048	1186	EDGCF	2272	1067	18.07
2049	2174	STNVL	1206	2178	17.94
2050	440	FRMBR	1805	735	17.92
2051	253	HNYGR	2401	504	17.92
2052	60	DNIWS	1603	1253	17.90
2053	1950	WFNTH	0241	796	17.89
2054	2089	ROWLT	1101	737	17.84
2055	2477	LMBLN	0008	183	17.84
2056	2335	COHMA	1132	42	17.83
2057	1782	PCOIT	1024	1590	17.78
2058	1458	CRLFR	2152	3325	17.69
2059	1002	DENDR	0006	42	17.43

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2060	1446	WEAST	0619	1681	17.39
2061	N/A	RECCR	0007	68	17.38
2062	907	CPRCV	1403	1184	17.28
2063	1912	BRNWD	1206	2005	17.25
2064	893	HRSMD	1907	1816	17.19
2065	1916	WNDWD	3621	1908	17.17
2066	380	PLANO	1104	862	17.13
2067	1	CGDEL	5411	44	17.11
2068	N/A	GRPVN	8221	39	17.10
2069	1735	CPRCV	1401	1606	17.06
2070	1322	PCOIT	1008	1376	17.03
2071	1554	HLSBR	1204	549	17.01
2072	2165	INAIR	1421	13	17.00
2073	1553	SPRTN	1801	987	16.98
2074	897	ROWLT	1103	768	16.98
2075	509	THRNE	0004	807	16.91
2076	694	WOVER	6131	2918	16.91
2077	1033	KLNPS	1102	1714	16.88
2078	2403	CRLTR	2007	1220	16.87
2079	2108	BKBNT	1821	1291	16.84
2080	2078	CHALK	0951	84	16.82
2081	1254	ARTHR	0411	700	16.79
2082	1256	WATSN	5342	1888	16.77
2083	715	CHROW	0008	76	16.74
2084	1350	SWDTN	1611	1639	16.73
2085	699	PARIS	1201	1293	16.73
2086	1610	MRVLY	2311	383	16.68
2087	1433	HURST	1831	1365	16.68
2088	2008	SHDYG	7811	382	16.63
2089	1684	WBOSE	1103	800	16.60
2090	1549	ADISN	1603	907	16.51
2091	2139	BSPRG	1902	2492	16.47
2092	1500	SMFLD	2333	1034	16.45
2093	N/A	BRHLW	7641	28	16.39
2094	1612	OKLND	0003	1386	16.28
2095	2541	CRSGL	1306	1702	16.28
2096	2195	ESTLD	3611	1441	16.23
2097	2018	BRKNR	1221	215	16.14
2098	2158	FROKS	0005	1435	16.14
2099	2185	TRLSW	1204	599	16.00
2100	2203	BRYAN	0006	639	15.97
2101	1744	GNSVE	1602	1508	15.96
2102	802	ARLNG	1292	626	15.93
2103	700	HHSTH	1502	2347	15.92
2104	777	LOMAL	0002	603	15.85
2105	2076	ARTHR	0462	979	15.84
2106	549	BRKRG	0221	494	15.83
2107	1111	BRNAV	0711	1100	15.82

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2108	274	ELGIN	1001	473	15.80
2109	2118	RSNHT	1131	2432	15.71
2110	2394	MDDTN	4311	205	15.70
2111	1472	MDWPK	9211	1229	15.70
2112	2021	BLTON	1804	1287	15.69
2113	1498	HHSTH	1501	2541	15.66
2114	1596	PREST	1604	1142	15.64
2115	2197	MESQT	1306	1417	15.62
2116	988	PSHIL	1603	1660	15.54
2117	885	RSPVY	1708	929	15.49
2118	1059	ALPHA	0007	1214	15.47
2119	2495	FROKS	0007	769	15.47
2120	1212	PNTGO	7122	1068	15.41
2121	105	HUBRD	1402	1093	15.40
2122	1000	JKSNR	4109	730	15.36
2123	1913	COHMA	1111	690	15.26
2124	368	PTENN	2352	2408	15.24
2125	1634	PALRD	2206	1424	15.17
2126	916	LKBRN	2401	1650	15.15
2127	2072	CRNRD	0006	369	15.14
2128	810	WFALS	0153	1220	15.14
2129	1344	NPKWY	0011	3945	15.12
2130	2369	MESQN	1508	1790	15.11
2131	251	DENAV	0673	71	15.08
2132	2377	ANDNR	2211	1482	15.08
2133	1860	ENNIS	1903	1252	15.07
2134	185	PRKRW	3321	127	15.06
2135	2283	STNVL	1201	1517	15.03
2136	2439	SACRC	5521	155	14.97
2137	190	GODLY	1601	736	14.96
2138	N/A	TMNTH	1601	27	14.96
2139	1752	WINK	0511	508	14.93
2140	1938	LVBRD	0001	35	14.91
2141	93	POWEL	2706	224	14.89
2142	2073	BRCRK	6512	2255	14.86
2143	1122	BOWEN	3171	1617	14.84
2144	238	MRTSP	1504	728	14.82
2145	1687	TMPNW	1104	1799	14.81
2146	1542	CPRCV	1407	958	14.77
2147	649	GRAHM	0721	1471	14.76
2148	1636	BRNSO	1806	1922	14.74
2149	2435	GSTHW	1613	497	14.71
2150	489	SGOVL	1402	743	14.69
2151	1540	DALRK	1307	1085	14.66
2152	2442	CRNRD	0005	178	14.63
2153	1009	CLBSN	8821	51	14.63
2154	2383	BLKST	1752	1266	14.56
2155	1625	SMFLD	2313	2205	14.54

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2156	2068	FRNKF	0004	861	14.50
2157	386	TRNTY	7521	1165	14.50
2158	854	OKCLS	0008	1191	14.46
2159	2480	DFWSW	2202	33	14.45
2160	2164	COPEL	3053	2017	14.44
2161	2172	MDLNW	1592	1632	14.41
2162	1267	HUDSN	1602	173	14.39
2163	N/A	*MSLMN	4131	104	14.35
2164	2106	SHRSW	6641	669	14.34
2165	1672	WXNTH	2302	1159	14.32
2166	2189	ENNIS	1904	1281	14.28
2167	577	MESTE	1211	938	14.28
2168	1545	ATHNS	1201	843	14.27
2169	1145	PSHIL	1602	3856	14.18
2170	506	CRLTN	1402	530	14.08
2171	75	FARON	4041	886	14.07
2172	1971	GLNHV	3931	1291	13.95
2173	1501	WTAUG	4643	999	13.91
2174	733	LMBLN	0001	2050	13.87
2175	983	HMTRD	0003	403	13.86
2176	2210	HNRTA	0311	1073	13.84
2177	1586	WSANG	2801	1346	13.81
2178	2206	VLYRN	2957	2804	13.80
2179	1742	DESPR	1402	1658	13.80
2180	1597	CTYVW	2212	125	13.75
2181	441	WALST	0010	312	13.74
2182	773	ARMST	0001	801	13.69
2183	1759	PALRD	2208	454	13.69
2184	793	FRMBR	1807	867	13.65
2185	2190	PLANO	1101	376	13.63
2186	2448	CRLTR	2054	369	13.55
2187	829	SADLR	1201	11	13.55
2188	1800	LORAN	9711	407	13.51
2189	2030	MAPLE	0006	413	13.46
2190	1286	ODNTH	2061	610	13.43
2191	1689	BKWST	0004	1238	13.42
2192	678	BDFWD	8921	665	13.31
2193	110	WTAUG	4633	1029	13.29
2194	2323	MKNSW	1603	1181	13.25
2195	1264	LVBRD	0005	1369	13.25
2196	1061	SHAMP	0004	769	13.25
2197	2305	CNTRD	0002	1411	13.24
2198	1663	GRDPR	0891	793	13.20
2199	226	GNSVL	1203	1768	13.18
2200	485	BLTLN	0003	550	13.18
2201	853	CRLTR	2001	2089	13.15
2202	1798	SHNRW	1608	1435	13.10
2203	1233	RCHRD	1204	1025	13.09

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2204	2201	SIKES	2421	1024	13.05
2205	2096	CRLTR	2052	1521	13.02
2206	N/A	LSCOL	2135	31	13.00
2207	1082	MESQW	1808	1420	12.98
2208	1788	EDGCF	2231	753	12.96
2209	2061	MDLNE	0172	1226	12.94
2210	766	ALPHA	0013	448	12.93
2211	281	CDHCR	2053	1385	12.90
2212	2258	ODNTH	2013	1613	12.89
2213	176	SSPNG	1202	1129	12.81
2214	1675	LKWOD	7432	323	12.79
2215	1819	ADISN	1601	249	12.78
2216	2099	MRYNL	2111	22	12.77
2217	2463	EZACH	0004	1011	12.69
2218	815	TYOMN	1402	1627	12.65
2219	1903	PWEST	1307	951	12.65
2220	N/A	LIGSW	1602	1145	12.63
2221	2126	GODRD	8112	1357	12.62
2222	1983	MKNNY	1254	360	12.54
2223	456	ARLNG	1271	1851	12.52
2224	1025	PLSTH	1305	838	12.51
2225	1481	ESTLD	3621	1463	12.49
2226	1802	RWDHV	1901	924	12.49
2227	376	BBTWN	1504	1911	12.47
2228	N/A	EDDY	1301	32	12.34
2229	1308	SWDTN	1621	755	12.33
2230	1460	ADISN	1607	1014	12.31
2231	2302	PPARK	1806	1336	12.25
2232	177	MESQT	1304	456	12.22
2233	2090	SNYDR	1823	1261	12.18
2234	2307	RTHGB	1421	1258	12.09
2235	633	WFALS	0133	1577	12.04
2236	804	TRNTY	7551	374	11.86
2237	1223	BNDRA	0002	560	11.82
2238	1513	KNEDL	6342	1579	11.71
2239	2387	RSPVY	1706	1342	11.61
2240	2397	REAST	1505	1518	11.57
2241	948	SHNRW	1612	256	11.43
2242	1320	CLBRN	1206	1264	11.36
2243	1494	KLNTF	1802	1661	11.33
2244	124	CRLUD	1307	297	11.28
2245	1827	BDFRD	8811	1711	11.28
2246	2034	WWEST	1218	962	11.09
2247	1359	BRKRG	0211	322	11.00
2248	2450	RCHHL	0394	92	10.98
2249	2081	BRNAV	0732	799	10.97
2250	1490	WFNTH	0232	637	10.93
2251	748	MRSES	3019	21	10.90

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2252	2003	HLTOM	2421	1633	10.87
2253	2428	PPARK	1802	1336	10.85
2254	2443	MNHNS	1921	1759	10.77
2255	2009	BRYAN	0001	16	10.75
2256	1314	MESQN	1507	402	10.70
2257	1867	BAKKE	6911	103	10.69
2258	1831	FARON	4031	843	10.68
2259	N/A	MNWLL	1206	1094	10.68
2260	502	FRMBR	1806	100	10.67
2261	1241	CRNRD	0001	665	10.67
2262	2100	MKNNY	1202	1917	10.51
2263	760	SWTWR	1382	451	10.49
2264	1660	ALNTH	2852	3445	10.47
2265	1251	JNKNS	0008	1184	10.44
2266	2425	RGLRW	0004	72	10.42
2267	1604	CMTSW	0915	485	10.42
2268	1980	REAST	1507	103	10.41
2269	N/A	RRNE	2402	2268	10.40
2270	1968	WCOLO	1320	673	10.38
2271	383	KLNTF	1801	1039	10.37
2272	955	KLELM	2203	2761	10.34
2273	544	GLNHV	3911	1135	10.32
2274	1943	FRMNT	0002	104	10.31
2275	2117	ODNTH	2024	2690	10.29
2276	2460	ARTHR	0481	1349	10.29
2277	2347	WFALS	0114	433	10.19
2278	2125	MKNGB	5331	1472	10.18
2279	1683	BLKST	1711	1298	10.14
2280	2027	SNYDR	1852	1330	10.13
2281	1557	WXHCH	1204	1318	10.07
2282	1998	DLEON	0131	727	10.01
2283	N/A	PERIN	1511	560	10.00
2284	881	LTV	5451	1051	9.99
2285	2406	RCLNS	1407	1251	9.96
2286	2456	BSPSW	0841	2132	9.94
2287	1305	IRVNE	1305	184	9.93
2288	2264	PCOIT	1007	1103	9.88
2289	194	SLBLF	1201	127	9.85
2290	1892	HORNE	1942	619	9.79
2291	1605	PRKRW	3362	1072	9.78
2292	N/A	TMPSE	1501	556	9.71
2293	N/A	*RIESL	5010	13	9.69
2294	2085	BSPSW	0812	786	9.64
2295	1856	ABBOT	1901	110	9.64
2296	2298	STNVL	1205	1217	9.57
2297	N/A	PRKWY	1552	490	9.57
2298	944	GORMN	0411	554	9.56
2299	2286	MKNGB	5322	1657	9.56

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2300	1859	PARIS	1204	1711	9.51
2301	406	SHMNE	1409	1234	9.51
2302	1109	SSPNG	1205	1484	9.45
2303	2182	ODESA	0261	1537	9.42
2304	N/A	ROWLT	1107	566	9.32
2305	1439	PALRD	2203	1369	9.32
2306	2209	PSHIL	1606	260	9.27
2307	2310	PRKWY	1521	1685	9.27
2308	2478	CRNRD	0004	467	9.12
2309	2173	MDDTN	4312	1886	9.06
2310	1826	CURIE	7211	310	9.06
2311	1852	NIPAK	1001	121	9.06
2312	1993	WBOSE	1101	338	9.06
2313	2039	BAKKE	6921	1613	9.05
2314	2299	FSTVW	0006	1234	9.04
2315	2391	CLCTY	1031	1431	9.02
2316	2434	MESTE	1205	1587	9.00
2317	757	MESQT	1302	1207	8.93
2318	1131	DNISN	1206	1014	8.88
2319	2145	MDDTN	4322	25	8.88
2320	2322	IRVNR	1506	1393	8.83
2321	2350	RSPCK	2103	194	8.79
2322	2474	ODNTH	2041	2591	8.79
2323	1559	MESQT	1301	1300	8.73
2324	1780	RDRSE	2604	3773	8.72
2325	2331	TRNTY	7511	1681	8.61
2326	1441	SHNRW	1614	414	8.52
2327	2012	PCUST	2005	1724	8.51
2328	264	CRLUD	1301	15	8.47
2329	1805	NPKWY	0014	2997	8.36
2330	2263	MESFR	2105	1053	8.32
2331	2422	ADISN	1604	1154	8.28
2332	2510	MCDMT	2552	643	8.26
2333	1492	RGLRW	0001	35	8.26
2334	1893	BRCRK	6523	846	8.22
2335	N/A	SHDYG	7821	84	8.21
2336	2476	BSPRW	2532	1704	8.20
2337	2070	FARON	4021	283	8.15
2338	2107	MDLNW	1541	2122	8.12
2339	980	GMINI	5811	2522	8.10
2340	1589	FRMBG	1706	53	8.09
2341	2409	GVODS	3011	2280	8.05
2342	1578	WDGWD	1561	1465	7.96
2343	1047	COMRC	1201	999	7.93
2344	217	GRMES	0511	1097	7.89
2345	497	PAYSW	1203	1166	7.87
2346	2327	KLNTF	1805	2664	7.83
2347	2475	IRVND	1208	202	7.79

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2348	1110	SHSTH	1305	419	7.77
2349	2075	ALNSW	2651	3262	7.75
2350	1942	KLNCC	1701	3739	7.74
2351	2063	RANGR	4321	947	7.71
2352	849	GAVSW	0007	1052	7.69
2353	2584	WALST	0007	16	7.69
2354	2472	RGLRW	0006	34	7.68
2355	1878	SCHRD	0008	74	7.68
2356	1853	COMRC	1202	52	7.65
2357	2515	GSTHW	1651	258	7.53
2358	2414	ARTHR	0422	1082	7.48
2359	2066	EDGCF	2221	638	7.45
2360	2148	SNYDR	1822	1598	7.43
2361	1932	MDTHS	1001	695	7.36
2362	2552	ADISN	1606	20	7.35
2363	1685	HMPHL	2752	145	7.32
2364	743	GVODS	3072	2280	7.32
2365	2417	SHNRW	1610	403	7.30
2366	1235	BRNWD	1205	884	7.27
2367	1830	PCOIT	1023	2388	7.24
2368	634	TYSTH	1203	435	7.23
2369	2488	HMPHL	2713	79	7.15
2370	2381	HMPHL	2791	328	7.14
2371	2349	BSPRW	2511	816	7.14
2372	1741	RCHHL	0344	1962	7.13
2373	2506	ALPHA	0010	523	7.09
2374	1861	PROAD	0005	113	7.09
2375	2355	STNVL	1204	756	7.08
2376	776	LMESA	1512	700	7.07
2377	2155	PAYSW	1205	726	7.04
2378	2509	MDLNE	0163	764	7.03
2379	2274	WALNT	0004	1447	7.03
2380	2353	BDFWD	8931	1925	6.99
2381	2320	WWEST	1217	86	6.97
2382	2352	MDLNW	1532	1780	6.96
2383	1475	RECCR	0002	49	6.96
2384	2162	ANDNR	2231	1537	6.94
2385	327	CLLVL	0004	49	6.86
2386	2294	SHAMP	0006	1115	6.83
2387	1114	CHROW	0005	166	6.83
2388	2529	SHDYG	7832	2241	6.81
2389	2433	FRNKF	0005	1832	6.81
2390	2308	ENNIS	1901	366	6.80
2391	564	FROKS	0006	977	6.79
2392	2453	IRVVV	2803	159	6.76
2393	2494	PWEST	1312	1194	6.65
2394	1804	LMESA	1561	2180	6.61
2395	1705	ALNSW	2654	1206	6.58

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2396	1715	ODNTH	2032	2005	6.55
2397	2426	CLCTY	1021	598	6.54
2398	1907	NCSTH	1504	62	6.53
2399	1291	MESTE	1209	1605	6.52
2400	2517	ALLEN	2406	2518	6.47
2401	1986	PGSTH	7021	57	6.42
2402	1410	LMBLN	0003	162	6.37
2403	2199	PWEST	1305	17	6.35
2404	2178	BRHLW	7621	1556	6.25
2405	1786	HKHTS	1605	1681	6.25
2406	1003	PCUST	2012	1736	6.23
2407	2020	JUDCT	0001	1087	6.22
2408	308	BLMED	1618	46	6.20
2409	2288	MDLNW	1521	2471	6.10
2410	116	PCOIT	1022	1588	6.09
2411	969	SHMNE	1403	1016	6.08
2412	1141	DALLW	0002	122	6.01
2413	2459	BKBNT	1842	517	5.99
2414	1310	PLSTH	1303	464	5.97
2415	N/A	WGROB	8411	1629	5.95
2416	1748	MESTE	1215	1392	5.84
2417	30	LOT69	3024	1040	5.83
2418	535	GAVSW	0001	776	5.83
2419	1956	KLNCC	1702	4161	5.83
2420	2196	BSPRW	2552	771	5.82
2421	381	WALNT	0005	1114	5.82
2422	2351	CRLTN	1404	280	5.80
2423	1504	TYOMN	1411	312	5.78
2424	2170	WWEST	1222	142	5.77
2425	594	LIGSW	1603	2501	5.75
2426	2224	ODESW	5211	2042	5.74
2427	2313	MDLNW	1511	2450	5.73
2428	2200	GVODS	3031	1434	5.68
2429	1957	BSPSW	0832	402	5.68
2430	158	WICKT	0411	99	5.67
2431	2412	RSPCK	2106	658	5.66
2432	2054	DGNST	0008	95	5.63
2433	704	TMPNW	1102	78	5.58
2434	2273	BDFWD	8932	1662	5.56
2435	1038	WTAUG	4623	732	5.53
2436	2238	GRMES	0521	491	5.53
2437	2445	PPARK	1807	891	5.44
2438	1345	MSTLT	1011	111	5.38
2439	2326	FSHSW	2111	291	5.36
2440	1380	SHAMP	0007	1157	5.33
2441	2333	MKNSW	1601	1186	5.32
2442	38	SHLMT	1801	310	5.30
2443	1160	CRLTN	1452	181	5.25

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2444	2088	CRLTR	2002	1404	5.24
2445	2410	PCUST	2003	1029	5.22
2446	1899	WXNTH	2301	983	5.21
2447	315	RRSTH	1704	2479	5.21
2448	2553	ARLNG	1291	84	5.12
2449	148	SSPNG	1203	1392	5.11
2450	91	GRLND	1603	312	5.09
2451	118	MDAIR	2921	1089	5.02
2452	675	REAST	1504	1350	5.00
2453	1840	ROSCO	2911	584	4.94
2454	2017	VLARN	2951	4613	4.94
2455	2161	MESTE	1203	90	4.88
2456	1845	SNYDR	1811	1538	4.81
2457	1080	CKRHL	0005	921	4.78
2458	2187	IRVHF	2303	82	4.74
2459	1157	FRMBG	1707	54	4.72
2460	1769	ANDNR	2242	1436	4.67
2461	1135	TERSO	2503	1324	4.66
2462	1222	WWEST	1220	164	4.65
2463	2279	RCHHL	0332	1378	4.64
2464	1621	IRVNR	1510	192	4.60
2465	2469	GVODS	3021	337	4.57
2466	2362	PSHIL	1605	93	4.54
2467	267	PRCTR	1602	204	4.49
2468	2300	PFFRD	3411	305	4.31
2469	880	LWSNR	2241	1028	4.31
2470	1594	TMSTH	1406	2144	4.25
2471	1153	RECCR	0003	245	4.23
2472	2266	MESTE	1207	865	4.12
2473	263	PRKRW	3341	336	4.03
2474	2572	JNKNS	0002	167	3.98
2475	1696	FSTVW	0007	1531	3.97
2476	2002	KNLTR	0005	2375	3.96
2477	2382	BKWST	0006	39	3.90
2478	1335	RGLRW	0005	49	3.82
2479	2504	GODRD	8132	1459	3.78
2480	2444	WWEST	1221	13	3.77
2481	1455	RRSTH	1708	3930	3.65
2482	2222	CTYVW	2211	1578	3.60
2483	2272	MDWCK	0003	1788	3.59
2484	2233	PRKWY	1532	1688	3.57
2485	1245	FSTVW	0004	2054	3.57
2486	2492	PWEST	1306	21	3.57
2487	820	CRLTN	1408	121	3.51
2488	2205	WMMMR	2708	652	3.47
2489	1214	CRLFR	2153	973	3.47
2490	243	MNSTR	1202	262	3.45
2491	2429	CRNRD	0002	271	3.43

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2492	939	WICKT	0431	12	3.42
2493	2049	BLNKT	0701	269	3.40
2494	2530	PLANO	1106	333	3.38
2495	770	SMFLD	2362	560	3.34
2496	2111	MDLNE	0133	258	3.24
2497	N/A	DALRK	1302	826	3.23
2498	2547	CNEXP	0002	844	3.19
2499	2079	SHAMP	0003	1022	3.18
2500	1466	COPEL	3051	2140	3.11
2501	2241	PRCRK	0003	1699	3.08
2502	1588	MESTE	1201	107	3.05
2503	667	MDLNW	1531	1168	3.03
2504	1935	COLNY	2406	2983	2.89
2505	1206	SHMNE	1405	751	2.86
2506	2502	PSHIL	1607	282	2.85
2507	1954	WALNT	0001	1474	2.84
2508	2404	GNSVN	1401	30	2.83
2509	1552	FRMBG	1701	167	2.75
2510	2457	PLANO	1105	74	2.74
2511	669	PAYSW	1213	1176	2.70
2512	1076	SHMNE	1407	801	2.68
2513	1965	SCHRD	0006	368	2.65
2514	N/A	CLBNR	1401	20	2.65
2515	1756	PCOIT	1003	1458	2.60
2516	863	LTV	5461	455	2.57
2517	1373	CKRHL	0006	50	2.54
2518	2010	NMAIN	0241	395	2.49
2519	731	MCGRG	1902	272	2.48
2520	2328	PRKRW	3372	413	2.43
2521	2366	ODESA	0221	277	2.42
2522	894	BNDRA	0005	565	2.41
2523	1653	GRAHM	0713	309	2.24
2524	2105	JKSNR	4107	24	2.21
2525	2293	BRCRK	6533	1317	2.19
2526	2520	LMESA	1531	1301	2.18
2527	558	MSLSW	0008	245	2.08
2528	1333	GNSVL	1213	51	2.06
2529	1987	BKBNT	1811	651	2.06
2530	1351	RRSTH	1707	146	2.00
2531	2484	WFALS	0163	384	1.95
2532	2128	PPARK	1804	233	1.94
2533	1010	SHNRW	1611	897	1.93
2534	N/A	CNI45	2402	1244	1.89
2535	1680	HMPHL	2742	171	1.89
2536	2556	BRYAN	0007	268	1.89
2537	2499	MDLNE	0151	250	1.88
2538	2471	BDFWD	8922	1974	1.83
2539	1910	MCDMT	2554	2169	1.83

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2540	2226	PCUST	2001	542	1.80
2541	1420	INAIR	1423	208	1.75
2542	2577	PLANO	1102	130	1.74
2543	772	AMLIA	0007	125	1.72
2544	2345	PCOIT	1025	2632	1.66
2545	1555	WMMMR	2704	278	1.66
2546	1393	DAVIS	3762	26	1.65
2547	2440	ALLEN	2401	1649	1.65
2548	530	RDRSE	2603	2794	1.62
2549	2176	RCLNS	1404	169	1.60
2550	693	CLLVL	0001	41	1.56
2551	2566	FRMBG	1708	47	1.47
2552	2519	HMPHL	2711	829	1.45
2553	1485	BKWST	0005	1626	1.43
2554	1376	MDLNW	1582	1439	1.29
2555	2579	RCLNS	1403	76	1.28
2556	N/A	RRNE	2407	1072	1.27
2557	2473	WALST	0003	131	1.21
2558	2496	BKWST	0007	1865	1.20
2559	2091	LKMNT	0004	2121	1.19
2560	2513	DNINR	1402	206	1.17
2561	2097	RGLRW	0003	87	1.15
2562	2507	PARIS	1205	35	1.14
2563	2330	TYBLR	2806	256	1.12
2564	2551	KLNTF	1803	1012	1.10
2565	N/A	RSPCK	2101	194	1.06
2566	1876	HMPHL	2792	438	1.06
2567	2421	COTRD	0003	27	1.04
2568	775	HKBRY	1105	136	1.01
2569	2528	ALPHA	0006	378	1.01
2570	902	LIPAN	1303	221	1.00
2571	2532	WFALS	0124	137	0.99
2572	1423	WEAST	0628	210	0.94
2573	590	HKBRY	1103	65	0.85
2574	1844	PROAD	0001	126	0.82
2575	2542	INAIR	1413	939	0.78
2576	2446	WFALS	0143	201	0.78
2577	2045	CURIE	7241	89	0.73
2578	2586	WEAST	0621	130	0.64
2579	2567	GAVSW	0006	72	0.61
2580	767	WEAST	0626	255	0.60
2581	2489	RSNHT	1152	581	0.59
2582	N/A	CRTLD	4733	1423	0.59
2583	N/A	RWDHV	1908	1935	0.58
2584	1137	CKRHL	0003	429	0.56
2585	2514	CRLTR	2004	236	0.56
2586	2581	SHRSW	6631	1320	0.53
2587	1927	BDFWD	8911	1096	0.51

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2588	2212	MDWPK	9221	775	0.43
2589	2540	CNTRD	0001	2021	0.39
2590	850	BNDRA	0006	391	0.38
2591	N/A	ALVRD	1504	124	0.37
2592	1592	MCDMT	2553	1043	0.37
2593	2539	KNLTR	0006	521	0.36
2594	2436	ALNTH	2851	2450	0.31
2595	N/A	FSCRK	6722	172	0.30
2596	2564	FRMBG	1703	25	0.24
2597	1941	PTENN	2355	1225	0.22
2598	2418	GVODS	3041	1370	0.21
2599	N/A	*ESJAX	5030	522	0.17
2600	2548	THRNE	0005	1292	0.16
2601	953	CNTRD	0004	1008	0.14
2602	476	FRMBR	1802	1096	0.14
2603	2501	ALPHA	0016	1724	0.14
2604	2523	LSCOL	2137	947	0.09
2605	2587	WHITE	3542	422	0.08
2606	1152	DAVIS	3743	537	0.07
2607	302	RWALS	1854	1915	0.07
2608	1144	RSPVY	1702	534	0.06
2609	1615	SCHRD	0007	1324	0.05
2610	2535	ALPHA	0002	1220	0.05
2611	2538	ADISN	1602	128	0.00
2612	N/A	AIRPK	8431	24	0.00
2613	N/A	ALEDO	9411	813	0.00
2614	N/A	ALEDO	9421	750	0.00
2615	2451	ALLNC	6422	18	0.00
2616	2297	ALPHA	0001	454	0.00
2617	N/A	ALPHA	0004	20	0.00
2618	1440	ALPHA	0005	147	0.00
2619	209	ARMST	0007	34	0.00
2620	954	CNEXP	0005	757	0.00
2621	2560	COTRD	0005	259	0.00
2622	2546	COTRD	0008	875	0.00
2623	1738	CPSES	9811	18	0.00
2624	N/A	CPSES	9822	23	0.00
2625	N/A	CRLFR	2151	12	0.00
2626	2562	CRNTH	2405	235	0.00
2627	2048	DFWNW	2610	40	0.00
2628	N/A	ELCOR	7411	13	0.00
2629	N/A	FORSW	2004	14	0.00
2630	2481	GAVSW	0008	125	0.00
2631	2568	GAVSW	0011	65	0.00
2632	677	HMPHL	2723	40	0.00
2633	N/A	HORNE	1923	1518	0.00
2634	N/A	IRVNE	2853	20	0.00
2635	N/A	JAREL	1301	13	0.00

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2002 SAIDI Ranking	2001 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2002 SAIDI Value
2636	2465	JEWET	1202	45	0.00
2637	N/A	*JKCTY	5001	20	0.00
2638	20	JNKNS	0001	163	0.00
2639	N/A	KRUM	1201	13	0.00
2640	N/A	LSCOL	2124	13	0.00
2641	N/A	MAYFD	5511	47	0.00
2642	N/A	MKNGB	5311	13	0.00
2643	N/A	MNWLL	1201	18	0.00
2644	271	MRSES	3016	13	0.00
2645	2114	MSTLT	1054	171	0.00
2646	N/A	PRHLL	2402	70	0.00
2647	738	PWEST	1309	56	0.00
2648	N/A	RBNSN	2503	158	0.00
2649	2580	RDRSE	2601	405	0.00
2650	712	REAST	1509	142	0.00
2651	N/A	RECCR	0005	21	0.00
2652	1426	RGFTW	6813	16	0.00
2653	727	RGFTW	6822	28	0.00
2654	2479	RNKSW	5411	35	0.00
2655	N/A	RNKSW	5422	15	0.00
2656	N/A	*RSBUD	5008	15	0.00
2657	1356	RSPCK	2105	24	0.00
2658	2011	RSPCK	2107	113	0.00
2659	2399	SMBMG	1701	28	0.00
2660	N/A	SSPNE	1403	64	0.00
2661	N/A	TDWGL	4811	14	0.00
2662	262	TRLNW	2401	20	0.00
2663	N/A	TYLER	1003	12	0.00
2664	2516	TYLER	1004	106	0.00
2665	2380	WALST	0006	12	0.00
2666	N/A	WBORO	1902	11	0.00
2667	N/A	WKBSN	8511	18	0.00
2668	N/A	WXHNW	2901	230	0.00
2669	2589	WXOCF	1402	14	0.00

ONCOR Electric Delivery Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2002 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	15.00%
Vegetation	10.00%
Animals and Birds	12.00%
People (Including cars and farm equip)	19.00%
Utility-owned Equipment	22.00%
Other	17.00%
Unknown	4.00%