



Control Number: 29165



Item Number: 15

Addendum StartPage: 0

Julie Parsley
Commissioner

Paul Hudson
Chairman



RECEIVED

2004 APR 16 AM 9:06

PUBLIC UTILITY COMMISSION
FILING CLERK

W. Lane Lanford
Executive Director

Public Utility Commission of Texas

April 16, 2004

Mr. Randall Roper
American Electric Power
400 West 15th St., Suite 650
Austin, TX 78701-1662

Re: Substantive Rule §25.52 – Reliability and Continuity of Service
Substantive Rule §25.81 – Service Quality Reports
Project 29165 – 2003 Electric System Service Quality Report

Dear Mr. Roper:

Your company submits three annual Service Quality Reports in accordance with the requirements of the above referenced Substantive Rules. PUC Staff has reviewed your company's three Service Quality Reports for 2003 filed in Project No. 29165 and would like to obtain additional information regarding each of them for further review to ensure compliance with Substantive Rule §25.52.

Attached is a list of nine items for which Staff is requesting your company's responses (a separate response for each of your company's 2003 Service Quality Reports) not later than June 4, 2004. Please file five printed copies and one electronic copy for each separate response in Project No. 29165. If you have questions or need clarification of this request, please contact Mike Lee in the Electric Division at 512-936-7348.

Sincerely,

T. Brian Almon

T. Brian Almon, P.E.
Director of Engineering

Enclosure

Service Quality Information Request
Project 29165 – 2003 Electric System Service Quality Report
April 16, 2004

1. Provide complete records of all sustained interruptions, by interruption class, for the months of April and October, 2003. [Subst. R. §25.52(d)]
2. Provide the number of significant interruptions sustained during 2003 and the number lasting more than 24 hours. [Subst. R. §25.52(c)(5) and §25.52(e)(2)]
3. Provide the number of forced interruptions attributable to each cause shown on the 2003 Service Quality Report.
4. Describe the methodology used to calculate the annual average SAIFI value for each interruption class shown on the 2003 Service Quality Report. Include a description of the data used for the calculations.
5. Describe the methodology used to calculate the annual average SAIDI value for each interruption class shown on the 2003 Service Quality Report. Include a description of the data used for the calculations.
6. Describe the methodology used to calculate the system-wide SAIFI standard for 2003, and include a description of the data used for the calculation. Provide the standard for 2003 and provide the calculation showing how this standard was determined. [Subst. R. §25.52(f)(1)]
7. Describe the methodology used to calculate the system-wide SAIDI standard for 2003, and include a description of the data used for the calculation. Provide the standard for 2003 and provide the calculation showing how this standard was determined. [Subst. R. §25.52(f)(1)]
8. Identify and list the feeders on the 2003 Service Quality Report that did not meet either the SAIDI or SAIFI requirements of Subst. R. §25.52(f)(2)(A). Explain why each feeder did not meet the requirements and what action(s) have been or will be taken to achieve compliance for the feeder (i.e., to prevent the feeder repeating for a third year).
9. Identify and list the feeders on the 2003 Service Quality Report that did not meet either the SAIDI or SAIFI requirements of Subst. R. §25.52(f)(2)(B). Explain why each feeder did not meet the requirements and what action(s) have been or will be taken to achieve compliance for the feeder. Describe the methodology used to calculate the SAIDA and SAIFI system averages of all feeders for purposes of identifying the listed feeders, and provide the calculations.