

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
1820	1099	KLNPS	1104	1440	23.96
1821	185	LUFKN	1204	507	23.95
1822	865	RCHRD	1201	1380	23.93
1823	1643	JSHUA	1301	950	23.91
1824	958	EDGWD	1101	228	23.89
1825	2245	BDFRD	8811	1708	23.86
1826	1326	CLCTY	1011	1179	23.83
1827	2462	WWEST	1220	168	23.83
1828	1017	HURST	1882	1781	23.80
1829	952	PRKRW	3382	208	23.74
1830	2203	RCHRD	1204	1554	23.74
1831	1875	PCOIT	1004	683	23.71
1832	1749	IRVNR	1507	1134	23.69
1833	602	DAVIS	3731	677	23.68
1834	101	NHNSW	0008	564	23.67
1835	951	ITSCA	1702	237	23.56
1836	1788	CRLUD	1304	1205	23.42
1837	1120	BLMND	3241	210	23.41
1838	1111	DEALY	0004	846	23.34
1839	1074	FORSW	2015	1322	23.34
1840	1914	CPRCV	1402	2167	23.33
1841	1919	IRVND	1206	114	23.26
1842	2194	MKNSW	1603	1174	23.24
1843	2324	RDRSE	2604	2996	23.22
1844	2577	WFALS	0143	194	23.07
1845	516	RUSK	5013	155	22.92
1846	1290	IRVNE	1303	1411	22.87
1847	2413	BKBNT	1842	511	22.80
1848	1943	KILEN	1205	1240	22.77
1849	2278	MKNGB	5331	1466	22.74
1850	2485	FSTVW	0004	2072	22.74
1851	1874	SHDYG	7812	109	22.70
1852	454	SHRSW	6622	1221	22.69
1853	2003	VGCRK	8031	1726	22.68
1854	1691	ATHNW	1402	1184	22.65
1855	2533	SHNRW	1611	911	22.59
1856	1628	KLBRG	0004	949	22.58
1857	1782	FSCRK	6711	2798	22.53
1858	2435	WTAUG	4623	718	22.49
1859	758	AMLIA	0008	137	22.47
1860	247	JKSBR	1402	1249	22.43
1861	1718	TAYLR	1201	2018	22.40
1862	1498	MKNNY	1201	1230	22.36
1863	1275	IRVNR	1557	2280	22.36
1864	2220	LIGSW	1602	1145	22.26
1865	2209	MDLNE	0172	1217	22.26
1866	2559	BKWST	0007	1826	22.23
1867	1154	HKHTS	1602	1244	22.20

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
1868	546	CNTRY	2842	2851	22.19
1869	1292	SWAN2	1801	249	22.18
1870	540	DESPR	1408	516	22.18
1871	1470	GRPVN	8213	1436	22.12
1872	2186	CRLTR	2054	373	22.09
1873	1338	KNEDL	6311	1913	22.04
1874	1204	SMPST	0004	1667	22.01
1875	506	CLBNR	1407	270	22.00
1876	1031	HNYGR	2402	106	21.95
1877	714	RRSTH	1706	1240	21.94
1878	864	MSTLT	1073	229	21.93
1879	1444	BRNSO	1808	966	21.90
1880	2084	SWDTN	1611	1626	21.90
1881	1593	KNEDL	6322	3423	21.79
1882	271	ALPHA	0003	697	21.74
1883	647	LFEST	1904	1997	21.71
1884	1046	CLCRK	1011	195	21.70
1885	1429	DALWT	2982	1754	21.70
1886	1865	MNWLL	1202	677	21.68
1887	2240	REAST	1505	1495	21.60
1888	1752	REAST	1506	1201	21.59
1889	1957	KILEN	1204	1059	21.57
1890	1572	IRVNG	1408	1062	21.53
1891	1836	MESFR	2103	996	21.51
1892	2134	PRKRW	3321	128	21.51
1893	2548	RDRSE	2603	3672	21.43
1894	1341	MSLSW	0001	1141	21.42
1895	459	SGOVL	1401	2366	21.38
1896	1263	BNDRA	0001	1003	21.35
1897	1576	WMMMR	2702	1698	21.26
1898	1751	GRSMN	4029	998	21.25
1899	109	WBROK	3021	35	21.20
1900	1302	ANDNR	2222	75	21.17
1901	2289	SLBLF	1201	127	21.09
1902	880	KNEDL	6312	2041	21.05
1903	498	ALLEN	2405	1500	21.00
1904	2077	KLNPS	1102	1386	20.91
1905	1719	BLTON	1805	1162	20.83
1906	1960	KILEN	1203	1788	20.82
1907	1312	SCYEN	0002	1215	20.82
1908	1378	SSPSW	1604	726	20.75
1909	2298	GORMN	0411	556	20.75
1910	2349	ALNSW	2651	1862	20.67
1911	1464	PALMR	2202	887	20.61
1912	2246	WWEST	1218	966	20.55
1913	1738	MESFR	2102	610	20.48
1914	2475	FSTVW	0007	1503	20.43
1915	1830	TYBLR	2805	1988	20.41

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
1916	1965	BSPRG	1904	1274	20.37
1917	475	DAVST	0003	1660	20.25
1918	1249	TMNTH	1605	1650	20.25
1919	1369	HURST	1811	1089	20.19
1920	2226	RWDHV	1901	916	20.17
1921	597	TMPNW	1106	1454	20.11
1922	462	MRSES	4005	819	20.05
1923	1864	BRNAV	0784	2284	20.02
1924	760	CHICW	1301	12	20.00
1925	1963	BSPRW	2521	1747	19.99
1926	580	SCURY	1921	117	19.98
1927	124	IRVND	1205	186	19.98
1928	857	CMBTP	1201	230	19.96
1929	2360	SNYDR	1822	1593	19.91
1930	88	WHTRK	0008	1209	19.86
1931	2663	TRLNW	2401	19	19.84
1932	1500	FRSTN	1602	1088	19.83
1933	1715	CLBRN	1202	960	19.83
1934	1948	PGSTH	7011	158	19.81
1935	2364	GVODS	3072	2278	19.78
1936	304	JUDCT	0008	264	19.76
1937	457	CURIE	7221	660	19.71
1938	2136	SACRC	5521	160	19.70
1939	2361	MDTHS	1001	844	19.68
1940	2500	COPEL	3051	2159	19.66
1941	1529	ALNSW	2652	5180	19.62
1942	1601	MRDCK	0003	1192	19.59
1943	854	MDLNE	0122	204	19.57
1944	542	PRSTN	0002	1299	19.55
1945	2328	CRLUD	1301	15	19.53
1946	1177	ENTOH	0005	963	19.53
1947	2311	NIPAK	1001	123	19.53
1948	685	CLBNR	1404	1179	19.52
1949	1929	BRYAN	0002	341	19.50
1950	1380	SNYDR	1813	287	19.49
1951	2043	STNVL	1202	755	19.48
1952	707	RRSTH	1703	1643	19.43
1953	1981	DALRK	1358	2249	19.40
1954	1192	TYOMN	1405	1489	19.33
1955	1090	WELRD	0008	792	19.31
1956	966	DENDR	0004	2123	19.29
1957	131	MDWCK	0004	1459	19.25
1958	2162	HUDSN	1602	170	19.19
1959	2103	HHSTH	1502	2324	19.19
1960	2054	ROWLT	1101	682	19.17
1961	2025	WRBND	2322	934	19.15
1962	2338	MDLNW	1541	2089	19.04
1963	316	CRNTH	2402	1737	19.03

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
1964	2147	GRAHM	0721	1455	19.02
1965	2358	ARTHR	0422	1072	18.95
1966	2575	PROAD	0001	126	18.94
1967	2178	VLRYN	2957	2812	18.93
1968	2556	RRNE	2407	1136	18.92
1969	1912	RCHHL	0363	582	18.90
1970	909	FROKS	0008	1496	18.85
1971	1780	DLEON	0111	889	18.78
1972	2388	SHDYG	7832	2240	18.66
1973	2581	WEAST	0626	248	18.66
1974	1610	ARLNG	1223	1778	18.65
1975	1489	WFALS	0184	1295	18.62
1976	1285	CKRHL	0002	422	18.60
1977	2368	TYSTH	1203	432	18.59
1978	2492	WICKT	0431	12	18.58
1979	1888	MESFR	2104	130	18.56
1980	2378	MDLNE	0163	793	18.50
1981	379	LKHL	0005	1997	18.46
1982	608	TAYLR	1204	2758	18.46
1983	2427	MDLNW	1511	2441	18.45
1984	2269	RRNE	2402	1576	18.41
1985	1768	CRLTR	2003	1346	18.38
1986	2015	COMRC	1204	702	18.26
1987	1551	ALLEN	2402	2682	18.24
1988	2330	MESFR	2105	1051	18.19
1989	2035	MDLNW	1552	1092	18.13
1990	2276	ARTHR	0481	1328	17.99
1991	481	NHNSW	0005	431	17.97
1992	657	DAVIS	3752	477	17.92
1993	551	RNDRK	1509	2821	17.83
1994	2518	NMAIN	0241	392	17.82
1995	1178	CRLJL	1502	306	17.81
1996	1021	FORSN	5611	229	17.75
1997	2511	PAYSW	1213	1150	17.72
1998	2440	SHAMP	0007	1228	17.71
1999	1886	PRKWY	1511	907	17.62
2000	174	WELRD	0003	829	17.59
2001	585	PCOIT	1006	1069	17.51
2002	630	WOVER	6122	2283	17.44
2003	1968	TMPNW	1101	2197	17.43
2004	1917	COLNY	2404	1928	17.42
2005	1206	MCHSN	1201	253	17.37
2006	1394	IRVGS	1905	832	17.33
2007	1028	ENSSO	2001	213	17.21
2008	997	LKBRN	2402	910	17.20
2009	2119	FROKS	0007	777	17.09
2010	873	SMFLD	2392	923	16.98
2011	2393	PWEST	1312	1193	16.97

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2012	2300	PARIS	1204	1509	16.96
2013	550	RRNE	2401	1616	16.94
2014	2442	SHLMT	1801	305	16.93
2015	1006	GNSVL	1223	1009	16.93
2016	1527	BSPRW	2542	710	16.90
2017	2560	LKMNT	0004	2090	16.86
2018	2271	KLNTF	1801	1023	16.85
2019	2188	LORAN	9711	399	16.83
2020	1067	GLNHV	3922	781	16.81
2021	613	RNDRK	1504	952	16.80
2022	24	TRIRA	6222	609	16.78
2023	223	RCHHL	0384	663	16.76
2024	1679	HUDSN	1601	911	16.75
2025	2063	BRNWD	1206	1978	16.71
2026	140	RRNE	2405	3369	16.68
2027	918	JKSES	3029	406	16.66
2028	2001	WATSN	5352	1857	16.60
2029	2140	LVBRD	0001	35	16.60
2030	827	HKHTS	1604	813	16.53
2031	691	CDCSW	0007	947	16.51
2032	1955	BRHLW	7631	717	16.48
2033	1412	TMSTH	1405	315	16.48
2034	1506	BLMND	3262	98	16.47
2035	235	PSHIL	1601	1453	16.46
2036	NA	HHSTH	1503	258	16.44
2037	1109	KNEDL	6332	2287	16.43
2038	838	ROWLT	1104	1487	16.40
2039	705	CMHBL	8121	60	16.40
2040	1202	DUVAL	0441	1012	16.39
2041	1685	THRNE	0002	1645	16.35
2042	1583	MESQW	1804	1186	16.32
2043	1973	SHNRW	1609	1320	16.22
2044	2481	RRSTH	1708	3935	16.20
2045	1637	SMFLD	2391	276	16.20
2046	1896	PCUST	2006	1597	16.16
2047	442	BOWEN	3122	1200	16.16
2048	1530	WNRTH	1419	324	16.15
2049	257	JUDCT	0007	623	16.14
2050	715	FSCRK	6712	5004	16.13
2051	853	WTAUG	4631	1120	16.12
2052	1547	KERNS	2402	416	16.10
2053	1961	RTHGB	1411	1972	16.09
2054	673	GODRD	8171	812	16.05
2055	1303	BDFRD	8831	820	16.02
2056	2185	PLANO	1101	387	16.02
2057	2124	PTENN	2352	2438	16.01
2058	1908	DFWNW	2602	39	16.00
2059	183	OKLND	0004	1283	15.99

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2060	2327	PCUST	2005	1727	15.95
2061	17	EURKA	2501	119	15.94
2062	926	RKDLE	1302	1505	15.89
2063	1454	DNISN	1201	1353	15.86
2064	1873	MCDMT	2551	2399	15.81
2065	1940	CRTLD	4721	3012	15.77
2066	2156	FRNKF	0004	863	15.77
2067	1494	HMPHL	2781	159	15.73
2068	2000	TYBLR	2804	1789	15.73
2069	1478	FRNKF	0002	842	15.68
2070	2225	ESTLD	3621	1173	15.67
2071	1005	SSPNG	1201	948	15.65
2072	1098	SMFLD	2341	1063	15.63
2073	2198	GRDPR	0891	784	15.61
2074	2139	WINK	0511	502	15.61
2075	1846	RRSTH	1702	1223	15.59
2076	2613	AIRPK	8431	22	15.59
2077	1625	IOWPK	0831	1070	15.58
2078	2242	CLBRN	1206	1275	15.53
2079	2133	ENNIS	1903	1275	15.48
2080	2051	HNYGR	2401	488	15.47
2081	2401	PGSTH	7021	57	15.44
2082	111	MTLDA	0003	1319	15.44
2083	1611	ODNTH	2014	632	15.39
2084	2476	KNLTR	0005	2353	15.21
2085	960	EULES	8731	1409	15.18
2086	1360	PRSTN	0005	1169	15.15
2087	401	FLRTN	3711	97	15.13
2088	2339	GMINI	5811	3254	15.10
2089	2034	CRTLD	4722	23	15.09
2090	1001	NCRST	2202	949	15.04
2091	1997	DFWNW	2601	37	15.03
2092	1675	MESQT	1305	778	15.00
2093	203	CMPST	0004	1660	14.95
2094	1854	KILEN	1201	2205	14.95
2095	1989	CDHCR	2051	2704	14.95
2096	1743	RANGR	4311	881	14.91
2097	1808	ROWLT	1106	1302	14.90
2098	232	STAUG	0008	1739	14.89
2099	414	RCHHL	0342	993	14.88
2100	664	DNINR	1403	1207	14.88
2101	1695	CLBRN	1203	1432	14.88
2102	153	THRDN	1901	1573	14.86
2103	2272	KLELM	2203	3116	14.85
2104	2215	ADISN	1601	250	14.84
2105	513	RECCR	0006	376	14.82
2106	1409	GORMN	0421	381	14.80
2107	2497	DALRK	1302	863	14.79

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2108	2405	HKHTS	1605	938	14.79
2109	2131	DENAV	0673	70	14.74
2110	322	CDCSW	0001	263	14.74
2111	1456	ATHNS	1203	939	14.73
2112	2558	WALST	0003	128	14.73
2113	2347	IRVND	1208	178	14.65
2114	482	MNFLD	2672	1906	14.56
2115	72	SMOUR	0721	27	14.56
2116	1936	KLELM	2205	1438	14.52
2117	2221	GODRD	8112	1365	14.52
2118	1817	OKCLS	0003	1387	14.50
2119	1205	RSNHT	1142	531	14.41
2120	2375	STNVL	1204	763	14.39
2121	NA	HKHTS	1606	2074	14.36
2122	2282	DLEON	0131	714	14.34
2123	449	GRAHM	0711	1597	14.32
2124	636	IRA	3211	245	14.24
2125	105	CLBNR	1402	2147	14.14
2126	1876	ALPHA	0009	60	14.13
2127	1931	WWEST	1216	234	14.11
2128	2502	MESTE	1201	107	14.09
2129	662	BLKRV	8321	44	14.02
2130	486	KLBRG	0002	1389	14.00
2131	1304	LWSNR	2231	551	13.97
2132	346	BRKNR	1211	101	13.95
2133	2096	ESTLD	3611	1578	13.92
2134	1466	BRNSY	1221	77	13.84
2135	1755	PRKWY	1542	1474	13.83
2136	297	PFFRD	3482	1099	13.78
2137	2503	MDLNW	1531	1160	13.78
2138	NA	WEBB	8632	962	13.78
2139	1335	LOMAL	0006	1118	13.76
2140	148	ARMST	0012	553	13.74
2141	2371	BSPRW	2511	800	13.72
2142	1507	CRSCN	1201	816	13.66
2143	1809	MEANS	4421	55	13.65
2144	1671	WRTHM	5004	228	13.58
2145	2299	MKNGB	5322	1769	13.53
2146	563	BRHLW	7651	1139	13.51
2147	1319	BLMND	3211	75	13.51
2148	1288	PTENN	2356	2370	13.50
2149	1432	EGFRD	0001	952	13.47
2150	2053	WFNTH	0241	747	13.46
2151	2341	GVODS	3011	2266	13.40
2152	2205	CRLTR	2052	1522	13.38
2153	1372	RDMLL	2591	1552	13.37
2154	1483	FRMBR	1804	288	13.36
2155	850	IVAN	1621	57	13.33

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2156	2453	ROSCO	2911	579	13.31
2157	1402	EULSO	9122	1044	13.31
2158	682	RNDRK	1506	3644	13.30
2159	1612	TYSTH	1208	289	13.28
2160	100	ALVDO	1901	1220	13.24
2161	2430	WICKT	0411	98	13.20
2162	49	MCKMY	0821	122	13.18
2163	328	WHITE	3531	1891	13.16
2164	1063	HMPHL	2733	74	13.16
2165	1844	TMPTV	2405	469	13.12
2166	2235	WFALS	0133	1547	13.10
2167	1418	LKWOD	7442	786	13.08
2168	2048	EDGCF	2272	1047	13.00
2169	2193	WTAUG	4633	1028	12.95
2170	141	DAVIS	3723	301	12.91
2171	1860	CPRCV	1406	1247	12.87
2172	2307	PRKWY	1521	1706	12.85
2173	2089	WBOSE	1103	805	12.83
2174	886	STAUG	0003	1351	12.81
2175	2610	SCHRD	0007	1299	12.78
2176	2243	KLNTF	1802	1662	12.73
2177	2229	SWDTN	1621	752	12.65
2178	1857	PCUST	2002	839	12.64
2179	2386	SHAMP	0006	1114	12.62
2180	1831	DALWT	2972	193	12.62
2181	835	DUBLN	1360	1106	12.56
2182	2326	SHNRW	1614	407	12.54
2183	1462	CRLJL	1506	1948	12.54
2184	1472	LIPAN	1301	470	12.51
2185	2416	MESTE	1215	1409	12.51
2186	1984	KLNPS	1105	1681	12.50
2187	1694	LUFKN	1207	645	12.48
2188	807	DCDAM	2003	1350	12.48
2189	2277	WFALS	0114	419	12.46
2190	1136	NLNVL	2002	1289	12.45
2191	2520	PRKRW	3372	412	12.42
2192	1703	PCOIT	1001	1211	12.40
2193	1193	BOWEN	3181	814	12.39
2194	2509	FRMBG	1701	164	12.38
2195	2345	PAYSW	1203	1129	12.38
2196	1135	TATSP	4322	1824	12.27
2197	2425	LIGSW	1603	2508	12.26
2198	736	AIRPK	8411	844	12.18
2199	1445	PFFRD	3431	584	12.04
2200	2038	WATSN	5382	665	12.04
2201	2218	TYOMN	1402	1555	12.01
2202	2106	BRKRG	0221	455	11.99
2203	935	CMNCH	1402	1206	11.94

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2204	1829	SHMNE	1401	1187	11.92
2205	2312	WBOSE	1101	326	11.88
2206	1041	RCLNS	1402	74	11.80
2207	1085	LFSTH	1404	273	11.71
2208	2182	ARMST	0001	796	11.68
2209	1096	MRTSP	1501	601	11.67
2210	1642	SHAMP	0002	1175	11.66
2211	1863	CLBWS	8121	1442	11.61
2212	2437	PPARK	1807	881	11.56
2213	1819	ECTHM	3321	1974	11.55
2214	965	BLTON	1806	2048	11.49
2215	810	FRMBG	1753	961	11.48
2216	2373	ALPHA	0010	498	11.48
2217	419	ALLEN	2403	2940	11.45
2218	1656	CHROW	0007	84	11.42
2219	1622	LVBRD	0002	118	11.42
2220	2286	BSPSW	0841	2101	11.39
2221	1680	WBROK	3011	180	11.35
2222	2315	CLCTY	1031	1400	11.34
2223	860	ECTOR	1201	372	11.27
2224	2224	PLSTH	1305	833	11.25
2225	980	DALLW	0001	275	11.23
2226	1653	RWALL	1204	1353	11.22
2227	1772	PPARK	1803	1000	11.21
2228	1122	NPKWY	0010	6552	11.20
2229	NA	HNYGR	0402	499	11.15
2230	258	WDGWD	1513	865	11.14
2231	1648	MESTE	1213	1320	11.14
2232	2637	JEWET	1202	38	11.13
2233	1663	PRNTH	1406	1358	11.06
2234	2602	CNTRD	0004	1008	11.02
2235	683	DALLW	0004	1890	11.02
2236	1910	PPARK	1808	561	10.98
2237	812	MESTE	1206	1172	10.96
2238	2561	DNINR	1402	374	10.88
2239	2377	PAYSW	1205	723	10.88
2240	314	COPER	1202	976	10.86
2241	2078	CRLTR	2007	1286	10.82
2242	2017	MDAIR	2911	374	10.81
2243	1678	MRSES	4012	436	10.76
2244	836	PFFRD	3452	1387	10.75
2245	1649	STERT	2702	15	10.73
2246	333	BRKRG	0213	1474	10.71
2247	1589	KLNTF	1806	1486	10.69
2248	2152	CRNRD	0005	183	10.69
2249	1209	STAUG	0002	1305	10.67
2250	2409	MDLNW	1521	2438	10.65
2251	2447	RRSTH	1704	2476	10.62

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2252	2445	PCUST	2003	1028	10.62
2253	1657	PCUST	2010	2817	10.58
2254	1256	FRMBG	1751	1048	10.54
2255	627	WRTHM	5012	301	10.54
2256	2402	LMBLN	0003	164	10.47
2257	2382	MDLNW	1532	1783	10.39
2258	NA	MNWLE	1701	497	10.37
2259	1142	TMPLE	1206	672	10.35
2260	1282	ODESA	0212	1907	10.35
2261	1855	RNDRK	1505	1043	10.33
2262	1869	BLTON	1801	1440	10.29
2263	2406	PCUST	2012	1733	10.29
2264	2343	COMRC	1201	956	10.26
2265	1517	CRLFR	2154	3642	10.25
2266	2088	SHDYG	7811	377	10.25
2267	1511	GODRD	8131	1628	10.22
2268	1813	ODNTH	2022	602	10.12
2269	NA	AMMFG	5621	549	10.08
2270	2014	DALWT	2921	275	10.08
2271	305	IRVNR	1505	1188	10.07
2272	2336	BSPRW	2532	1677	10.06
2273	2459	FRMBG	1707	56	10.04
2274	2654	RGFTW	6822	28	10.04
2275	2392	IRVVV	2803	150	10.02
2276	949	CHROW	0006	64	10.00
2277	803	TYEST	1511	803	9.96
2278	2291	PRKRW	3362	1064	9.95
2279	2525	BRCRK	6533	1317	9.93
2280	1689	PTENN	2354	3800	9.93
2281	601	MSLSW	0005	689	9.90
2282	2249	BRNAV	0732	779	9.88
2283	2331	ADISN	1604	883	9.87
2284	1316	FSCRK	6713	2701	9.86
2285	2320	IRVNR	1506	1392	9.85
2286	2421	WALNT	0005	1092	9.78
2287	1862	WSOTH	1022	438	9.77
2288	1486	JNKNS	0004	392	9.75
2289	1722	CMPST	0002	887	9.62
2290	1399	ALNTH	2854	3696	9.60
2291	2394	LMESA	1561	2151	9.58
2292	1518	BMTWN	1621	1277	9.55
2293	2214	LKWOD	7432	323	9.53
2294	1996	PRNTH	1403	21	9.52
2295	1381	COPER	0401	151	9.50
2296	809	PLSTH	1304	1347	9.50
2297	1519	PLSTH	1302	1031	9.50
2298	2653	RGFTW	6813	12	9.42
2299	2567	HMPHL	2792	428	9.23

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2300	2195	LVBRD	0005	1372	9.23
2301	1988	SHSTH	1303	752	9.16
2302	1934	WEAST	0615	394	9.15
2303	2539	MCDMT	2554	1500	9.13
2304	2494	PLANO	1106	331	9.12
2305	2110	MDDTN	4311	200	9.07
2306	2301	SHMNE	1409	1203	9.01
2307	938	PFLGV	2002	3935	9.00
2308	2648	PWEST	1309	52	9.00
2309	2155	SMFLD	2313	2200	8.99
2310	1759	DESHR	1206	2005	8.97
2311	2120	PNTGO	7122	1083	8.96
2312	719	ATHNW	1405	901	8.94
2313	2535	HMPHL	2742	170	8.90
2314	1599	KLNCC	1703	2038	8.87
2315	2439	FSHSW	2111	288	8.85
2316	1630	DCATR	1204	449	8.84
2317	2554	MDLNW	1582	1432	8.74
2318	79	POYNR	1201	343	8.74
2319	2169	PSHIL	1602	3368	8.71
2320	2295	ABBOT	1901	112	8.59
2321	1848	DAVIS	3733	550	8.57
2322	424	MTLDA	0005	1534	8.51
2323	182	BLTLN	0005	954	8.51
2324	335	MNFLD	2621	1557	8.48
2325	2052	DNIWS	1603	1247	8.47
2326	2335	SHDYG	7821	83	8.47
2327	2529	BKBNT	1811	659	8.47
2328	1221	ABBOT	1902	110	8.44
2329	1979	IRVNR	1559	2452	8.41
2330	2231	PPARK	1806	1332	8.39
2331	2346	KLNTF	1805	1609	8.36
2332	1953	CMTSW	0921	1679	8.34
2333	382	CLMET	0002	903	8.34
2334	474	TRLNW	1202	60	8.32
2335	471	DALWT	2941	297	8.30
2336	890	BRLSN	2013	1477	8.30
2337	1016	RRSTH	1705	450	8.26
2338	1268	BSPSW	0851	1163	8.17
2339	1985	IRVVV	2801	1345	8.17
2340	130	NSTAR	2011	584	8.16
2341	2491	CRNRD	0002	267	8.12
2342	1455	PCOIT	1005	1104	8.10
2343	2553	BKWST	0005	1606	8.08
2344	1051	WALST	0002	60	8.03
2345	2083	CHROW	0008	78	8.00
2346	2403	PWEST	1305	19	8.00
2347	750	CDHIL	1805	540	7.98

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2348	1867	RWDHV	1904	333	7.91
2349	NA	DFWSW	2207	22	7.91
2350	2389	FRNKF	0005	1684	7.88
2351	2526	LMESA	1531	1285	7.81
2352	1094	FRMNT	0007	91	7.80
2353	1672	SHRSW	6612	1869	7.77
2354	32	PLGRV	0001	1575	7.75
2355	564	WTAUG	4642	1328	7.69
2356	2275	ODNTH	2024	2658	7.68
2357	1377	CMTSW	0941	1056	7.65
2358	200	RNDRK	1508	2834	7.61
2359	2601	THRNE	0005	1293	7.60
2360	2049	STNVL	1206	2053	7.55
2361	2097	BRKNR	1221	210	7.53
2362	2472	MESTE	1207	836	7.49
2363	553	DGNST	0003	267	7.41
2364	1617	VEST	3111	56	7.39
2365	2495	SMFLD	2362	568	7.39
2366	907	DALWT	2992	332	7.38
2367	518	IRVVV	2804	907	7.36
2368	2443	CRLTN	1452	22	7.36
2369	2290	HORNE	1942	1305	7.33
2370	1270	CRLUD	1302	142	7.31
2371	2261	CRNRD	0001	736	7.27
2372	NA	BRCRK	6522	1381	7.27
2373	2458	IRVHF	2303	89	7.22
2374	2132	ANDNR	2211	1471	7.22
2375	808	GSTHW	1662	1136	7.18
2376	1598	PNTGO	7111	671	7.14
2377	880	MSLSW	0006	106	7.06
2378	2523	GRAHM	0713	305	7.04
2379	2351	RANGR	4321	933	7.00
2380	1993	ENTOH	0004	1429	7.00
2381	1723	FRNKF	0001	880	6.98
2382	189	FRNKF	0007	1087	6.95
2383	1641	WXNTH	2305	50	6.90
2384	NA	VENSW	2603	24	6.88
2385	2267	CMTSW	0915	477	6.84
2386	1998	REGST	0002	226	6.65
2387	2069	CPRCV	1401	1588	6.61
2388	1639	MCGHR	2004	17	6.59
2389	NA	RSPCK	2132	98	6.58
2390	2628	DFWNW	2610	42	6.38
2391	97	DNIWS	1601	845	6.37
2392	1687	GAVSW	0002	578	6.31
2393	1476	TMNTH	1604	56	6.23
2394	1143	GAVSW	0010	513	6.21
2395	2042	WFNTH	0221	614	6.17

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2396	2484	PRKWY	1532	1730	6.13
2397	2586	CRLTR	2004	231	6.10
2398	2666	WALST	0006	11	6.09
2399	2207	MESQW	1808	1464	6.06
2400	115	FINK	1802	679	6.05
2401	1461	SMFLD	2372	835	6.04
2402	1765	DAVST	0008	67	6.00
2403	1272	SCHRD	0003	358	5.98
2404	786	FROKS	0002	1252	5.95
2405	2199	GNSVL	1203	1734	5.90
2406	1792	FRMNT	0011	564	5.84
2407	2594	KNLTR	0006	520	5.72
2408	2426	ODESW	5211	2011	5.71
2409	342	GODRD	8161	1727	5.67
2410	2005	WNDWD	3631	335	5.66
2411	1698	MDWCK	0006	906	5.64
2412	451	CRSGL	1301	78	5.62
2413	2222	MKNKY	1254	478	5.60
2414	2102	ARLNG	1292	614	5.60
2415	2356	COMRC	1202	49	5.55
2416	2037	HRSMD	1951	4387	5.52
2417	2044	DGNST	0001	71	5.42
2418	1942	LKWOD	7421	700	5.41
2419	2399	MESTE	1209	1728	5.32
2420	1535	CTYVW	2222	1441	5.17
2421	1708	RNDRK	1501	661	5.11
2422	1990	DAVST	0001	851	5.06
2423	678	TYLGE	1308	1543	5.06
2424	2253	PPARK	1802	1332	5.02
2425	804	WELRD	0002	722	4.96
2426	2112	BLTON	1804	1266	4.91
2427	2180	CTYVW	2212	124	4.88
2428	1398	HKBRY	1113	434	4.87
2429	1773	MDTHN	1703	128	4.83
2430	2396	ODNTH	2032	1975	4.76
2431	2265	JNKNS	0008	1169	4.76
2432	2046	KLELM	2201	1957	4.72
2433	NA	STNVL	1207	946	4.69
2434	2412	DALLW	0002	124	4.64
2435	2547	ALLEN	2401	1754	4.59
2436	2429	BSPSW	0832	406	4.53
2437	444	MESTE	1208	815	4.44
2438	2471	RECCR	0003	241	4.43
2439	1426	FARON	4062	1133	4.42
2440	2355	SCHRD	0008	74	4.38
2441	2260	FRMBR	1806	102	4.37
2442	1537	EMPCT	0001	32	4.31
2443	2460	ANDNR	2242	1259	4.31

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2444	2408	BLMED	1618	44	4.25
2445	2118	ALPHA	0007	1407	4.23
2446	2584	RWDHV	1908	1933	4.22
2447	1970	CHROW	0001	119	4.17
2448	2072	INAIR	1421	13	4.15
2449	1887	IOWPK	0821	723	4.13
2450	1266	ENSSO	2003	471	4.13
2451	2490	MNSTR	1202	263	4.12
2452	2424	WWEST	1222	140	4.10
2453	1410	ODNTH	2053	2231	4.07
2454	1866	BRYAN	0004	910	4.07
2455	2340	FRMBG	1706	56	4.04
2456	2268	REAST	1507	94	4.03
2457	2506	PSHIL	1607	282	4.01
2458	1811	BKWST	0001	377	3.94
2459	1889	SCHRD	0004	1789	3.93
2460	1978	ARTHR	0452	625	3.93
2461	2544	PCOIT	1025	2636	3.92
2462	874	GSTHW	1641	96	3.84
2463	933	FRMBG	1750	233	3.79
2464	2074	ROWLT	1103	420	3.77
2465	2489	CRLFR	2153	971	3.76
2466	110	VANAL	1201	550	3.73
2467	2297	PRKWY	1552	504	3.73
2468	1839	BRNSO	1807	196	3.72
2469	2061	RECCR	0007	67	3.72
2470	2482	CTYVW	2211	1549	3.71
2471	210	WALST	0001	121	3.69
2472	2407	JUDCT	0001	1088	3.68
2473	2563	PARIS	1205	34	3.65
2474	2507	WALNT	0001	1476	3.62
2475	1180	EUSTC	2402	720	3.57
2476	1858	THRNE	0001	1620	3.56
2477	2366	BRNWD	1205	849	3.56
2478	2428	GVODS	3031	1344	3.55
2479	2488	WMMMR	2708	610	3.51
2480	2254	MNHNS	1921	1756	3.41
2481	882	RDRSE	2602	2074	3.37
2482	98	CURIE	7231	1371	3.31
2483	2515	PCOIT	1003	1475	3.30
2484	626	PROAD	0007	241	3.24
2485	2013	ELKTN	2503	279	3.20
2486	173	CHROW	0004	192	3.20
2487	2263	SWTWR	1382	448	3.19
2488	2504	COLNY	2406	3760	3.18
2489	2111	MDWPK	9211	1228	3.10
2490	108	KLBRG	0001	1263	3.08
2491	2501	PRCRK	0003	1652	3.07

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2492	2369	HMPHL	2713	78	3.04
2493	2587	SHRSW	6631	1315	3.03
2494	851	VLARN	2952	1744	2.97
2495	2241	SHNRW	1612	272	2.96
2496	1117	IOWPK	0811	736	2.94
2497	1284	KNLTR	0004	1927	2.90
2498	158	RGLRW	0002	50	2.88
2499	1907	ARTHR	0492	47	2.87
2500	1921	HMPHL	2721	445	2.86
2501	2571	LIPAN	1303	226	2.80
2502	502	MAPLE	0004	147	2.74
2503	2568	COTRD	0003	28	2.71
2504	2531	WFALS	0163	371	2.70
2505	2423	TYOMN	1411	305	2.70
2506	1374	BLTLN	0006	929	2.67
2507	877	SHSTH	1301	1510	2.67
2508	NA	MNWLE	1702	1176	2.63
2509	NA	BBTWN	1501	2307	2.57
2510	1240	ARLNG	1261	1227	2.55
2511	2248	RCHHL	0394	89	2.54
2512	1666	GAVSW	0005	1324	2.52
2513	1181	BLTLN	0001	642	2.51
2514	1295	BAGWL	1202	48	2.48
2515	2603	FRMBR	1802	1092	2.44
2516	507	RCLNS	1405	686	2.40
2517	934	EMPCT	0004	307	2.37
2518	590	KIMBL	5022	801	2.36
2519	1251	SHNRW	1607	663	2.33
2520	2631	GAVSW	0008	123	2.32
2521	2536	BRYAN	0007	264	2.31
2522	261	ARMST	0005	1975	2.27
2523	1228	HSKAV	0003	1302	2.27
2524	623	GSTHW	1682	146	2.26
2525	227	SHAMP	0001	1110	2.24
2526	1166	ALPHA	0015	705	2.22
2527	1485	CRTLD	4712	1125	2.20
2528	2569	HKBRY	1105	140	2.11
2529	2455	MESTE	1203	94	2.09
2530	2524	JKSNR	4107	24	2.08
2531	2149	GSTHW	1613	493	2.07
2532	642	SYCRK	4522	983	2.07
2533	1459	CKRHL	0001	333	2.03
2534	1933	RCLNS	1401	72	2.03
2535	2537	MDLNE	0151	257	2.03
2536	776	BRHLW	7611	1640	1.94
2537	1023	MSTLT	1042	336	1.92
2538	2549	RCLNS	1404	161	1.91
2539	1799	HORNE	1933	1630	1.87

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2540	1859	DENDR	0005	41	1.78
2541	2505	SHMNE	1405	737	1.72
2542	2516	LTV	5461	484	1.69
2543	2354	RGLRW	0006	34	1.68
2544	2543	AMLIA	0007	125	1.67
2545	2468	PFFRD	3411	307	1.64
2546	1986	BSPSW	0822	282	1.64
2547	898	EGFRD	0005	1611	1.63
2548	1670	RNDRK	1507	1037	1.63
2549	2384	ANDNR	2231	1522	1.61
2550	2337	FARON	4021	282	1.56
2551	1062	STAUG	0005	1154	1.56
2552	308	WRTHM	5017	165	1.53
2553	2247	BRKRG	0211	312	1.49
2554	2574	HKBRY	1103	65	1.45
2555	2130	MESQN	1508	1785	1.44
2556	1250	WATSN	5372	1333	1.43
2557	671	JUDCT	0004	92	1.41
2558	956	FROKS	0003	489	1.35
2559	2645	MRSES	3016	39	1.33
2560	983	LMBLN	0004	66	1.30
2561	2236	TRNTY	7551	371	1.30
2562	1370	ENNIS	1905	39	1.28
2563	372	FRMNT	0003	276	1.28
2564	287	MDWCK	0008	901	1.28
2565	2545	WMMMR	2704	278	1.24
2566	1488	BARRY	1801	83	1.20
2567	1640	LENSW	0321	43	1.14
2568	2521	ODESA	0221	265	1.13
2569	2422	CRLTN	1404	274	1.01
2570	NA	BRKTN	1202	111	0.94
2571	788	MSLSW	0007	250	0.89
2572	548	ARMST	0006	822	0.85
2573	NA	RSPCK	2131	44	0.82
2574	2528	GNSVL	1213	54	0.81
2575	2612	ADISN	1602	130	0.80
2576	2039	ARMST	0008	639	0.73
2577	1606	AIRPK	8421	355	0.72
2578	2332	MCDMT	2552	993	0.72
2579	2239	RSPVY	1706	1341	0.66
2580	2189	MAPLE	0006	405	0.62
2581	1145	REGST	0003	1030	0.58
2582	2530	RRSTH	1707	124	0.58
2583	658	WMRLD	0006	163	0.55
2584	2585	CKRHL	0003	458	0.48
2585	2370	HMPHL	2791	55	0.47
2586	1013	EULES	8732	544	0.45
2587	665	JUDCT	0002	1518	0.44

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2588	NA	BRAZE	2404	180	0.38
2589	2316	MESTE	1205	1606	0.38
2590	1562	PROAD	0006	109	0.38
2591	2474	JNKNS	0002	169	0.37
2592	2374	PROAD	0005	110	0.34
2593	2027	ENTOH	0006	1216	0.32
2594	2357	GSTHW	1651	262	0.31
2595	180	FROKS	0004	843	0.31
2596	1002	FRMNT	0004	1036	0.29
2597	2599	GVODS	3041	1325	0.29
2598	1557	BNMNW	1102	192	0.29
2599	1198	CKRHL	0004	316	0.25
2600	2639	JNKNS	0001	163	0.20
2601	2040	ARMST	0004	347	0.19
2602	1669	FRMNT	0001	1373	0.19
2603	2598	PTENN	2355	1175	0.12
2604	2565	KLNTF	1803	1001	0.11
2605	784	PROAD	0008	1193	0.11
2606	2605	LSCOL	2137	986	0.10
2607	2623	COTRD	0008	885	0.10
2608	1987	ALPHA	0011	862	0.08
2609	2618	ALPHA	0004	19	0.00
2610	2619	ALPHA	0005	147	0.00
2611	2570	ALPHA	0006	302	0.00
2612	971	BKWST	0002	1169	0.00
2613	1665	BLMGR	1902	200	0.00
2614	2093	BRHLW	7641	25	0.00
2615	772	BRKRG	0242	21	0.00
2616	NA	CDHIL	1623	369	0.00
2617	2517	CKRHL	0006	48	0.00
2618	2514	CLBNR	1401	18	0.00
2619	2621	CNEXP	0005	750	0.00
2620	2622	COTRD	0005	257	0.00
2621	1911	CRLUD	1306	24	0.00
2622	2059	DENDR	0006	40	0.00
2623	1258	DENDR	0009	57	0.00
2624	2041	DFWNW	2606	28	0.00
2625	2159	DFWSW	2202	35	0.00
2626	1539	ENTOH	0008	84	0.00
2627	2630	FORSW	2004	12	0.00
2628	2597	FRMBG	1703	23	0.00
2629	2596	FSCRK	6722	172	0.00
2630	1315	GSTHW	1672	11	0.00
2631	574	GSTHW	1691	35	0.00
2632	2633	HMPHL	2723	20	0.00
2633	1655	JNKNS	0003	19	0.00
2634	609	JNKNS	0006	486	0.00
2635	2640	KRUM	1201	13	0.00

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

2003 SAIDI Ranking	2002 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2003 SAIDI Value
2636	315	LOMAL	0007	134	0.00
2637	485	LSCOL	2116	27	0.00
2638	2641	LSCOL	2124	13	0.00
2639	2642	MAYFD	5511	165	0.00
2640	NA	MCDMT	2531	2399	0.00
2641	NA	MCDMT	2532	1951	0.00
2642	2319	MDDTN	4322	22	0.00
2643	1646	MESQN	1506	62	0.00
2644	2644	MNWLL	1201	18	0.00
2645	1389	MRSES	4014	21	0.00
2646	2647	PRHLL	2402	69	0.00
2647	2555	RCLNS	1403	82	0.00
2648	1778	REAST	1501	79	0.00
2649	2656	RNKSW	5422	15	0.00
2650	411	RRWES	1603	11	0.00
2651	2582	RSNHT	1152	598	0.00
2652	2659	RSPCK	2107	1410	0.00
2653	NA	RSPCK	2142	478	0.00
2654	2187	SADLR	1201	12	0.00
2655	2660	SMBMG	1701	27	0.00
2656	1356	SORCY	0002	64	0.00
2657	35	SSPNE	1402	65	0.00
2658	2138	TMNTH	1601	28	0.00
2659	1686	TNPON	0001	74	0.00
2660	NA	TYEST	1506	11	0.00
2661	2664	TYLER	1003	12	0.00
2662	2665	TYLER	1004	112	0.00
2663	465	TYLER	1010	60	0.00
2664	495	TYLGE	1311	21	0.00
2665	1161	WALST	0008	18	0.00
2666	2667	WBORO	1902	11	0.00
2667	1712	WWEST	1219	97	0.00
2668	NA	WWEST	1223	12	0.00
2669	2669	WXHNW	2901	165	0.00

Service Quality Report to the Public Utility Commission of Texas

ONCOR Electric Delivery Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2003 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	12.00%
Vegetation	10.00%
Animals and Birds	12.00%
People (Including cars and farm equip)	18.00%
Utility-owned Equipment	22.00%
Other	21.00%
Unknown	5.00%