

Control Number: 30254



Item Number: 47

Addendum StartPage: 0


SOAH NO. 473-05-5790
PUC DOCKET NO. 30254

APPLICATION OF WOOD COUNTY § BEFORE THE
ELECTRIC COOPERATIVE, INC. FOR §
A CERTIFICATE OF CONVENIENCE § PUBLIC UTILITY COMMISSION
AND NECESSITY ("CCN") FOR A §
PROPOSED TRANSMISSION LINE IN § OF TEXAS
WOOD COUNTY, TEXAS §

WOOD COUNTY ELECTRIC COOPERATIVE, INC.'S
SUPPLEMENTAL RESPONSE TO STAFF'S FIRST REQUEST FOR INFORMATION
QUESTION NUMBER ML-1-7

NOW COMES Wood County Electric Cooperative, Inc. ("Wood County") and files its supplemental response to Staff's First Request for Information, Question No. ML-1-7.

Respectfully submitted,


Mark C. Davis

State Bar No. 05525050

Email: mdavis@bbrsaustin.com

Nelson H. Nease

State Bar No. 24008904

Email: nnease@bbrsaustin.com

John T. Wright

State Bar No. 24037747

Email: jwright@bbrsaustin.com

BRICKFIELD BURCHETTE, RITTS & STONE, P.C.

1005 Congress Avenue, Suite 400

Austin, Texas 78701-2415

(512) 472-1081

(512) 472-7473 FAX

ATTORNEYS FOR WOOD COUNTY ELECTRIC
COOPERATIVE, INC.

**SOAH NO. 473-05-5790
PUC DOCKET NO. 30254**

APPLICATION OF WOOD COUNTY ELECTRIC COOPERATIVE, INC. FOR A CERTIFICATE OF CONVENIENCE AND NECESSITY ("CCN") FOR A PROPOSED TRANSMISSION LINE IN WOOD COUNTY, TEXAS	§ § § § § §	BEFORE THE PUBLIC UTILITY COMMISSION OF TEXAS
--	----------------------------	--

**WOOD COUNTY ELECTRIC COOPERATIVE, INC.'S
SUPPLEMENTAL RESPONSE TO STAFF'S FIRST REQUEST FOR INFORMATION
QUESTION NUMBERS ML-1-7**

Question ML-1-7:

Please provide a list of all events resulting in total loss of transmission service during the last five years to the following substations: Cathey, Williamson-Ziegler, Yantis, Brown, and Shaw. For each event, please identify the substation(s), each transmission line that was out, the owner of each line that was out, and the date, duration, and cause(s) (including maintenance) of each transmission line outage.

Response:

Please see chart below for additional information which was not contained in Wood County's original response to this request. This chart now includes the outage data for the Shaw Substation during the past five (5) years.


<u>Date</u>	<u>Substations Out</u>	<u>Line Section Out</u>	<u>Owner</u>	<u>Duration</u>	<u>Cause</u>
1/27/2000	Nichols, Brown, Yantis	Benton to Nichols	WCEC	12:17 - 13:13	Weather
03/28/2000	Brown, Yantis	Nichols to Brown	WCEC	21:17 - 22:07	Weather
12/13/2000	Shaw	Jarred-Williamson to VB Shaw	WCEC	04:25-06:31	Weather
06/14/2001	Brown, Yantis	Nichols to Brown	WCEC	21:00-22:13	Weather

08/16/2001	Benton, Nichols, Brown, Yantis	Quitman to Benton	WCEC	4:04 - 5:03	Weather
08/11/2002	Quitman, Benton, Nichols, Brown, Yantis	AEP Source	AEP	8:25 - 10:05	Unknown Power Supply
08/01/2002	Williamson- Ziegler, Cathey	AEP Source	AEP	8:27 - 9:01	Unknown Power Supply
07/30/2004	Williamson- Ziegler, Cathey	AEP Source	AEP	4:48 - 5:39	Unknown Power Supply

Sponsored By: Robert Norman, P.E.

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of the above and foregoing document was hand delivered and/or mailed this 3rd day of May, 2005 by First Class, U.S. Mail, postage pre-paid to all parties of record.



John T. Wright