



Control Number: 30613



Item Number: 11

Addendum StartPage: 0



RECEIVED
C FEB 16 P. 2:52
PUBLIC UTILITY COMMISSION
FILING CLERK

AEP Texas Central Company
400 West 15th Street, Suite 650
Austin, TX 78701
aep.com

February 16, 2005

Mr. Larry Reed
Electric Division, Commission Staff
Public Utility Commission of Texas
1701 N. Congress
Austin, TX 78711

Dear Mr. Reed,

Attached please find the Reliability and Continuity of Service Report for the reporting year 2004 for AEP Texas Central Company (TCC and formerly known as Central Power and Light Company). This report is filed in accordance with Substantive Rule Section 25.81, Project 30613. I was working on exceptions to the PFD in Docket No. 25157 that relates to the service quality reports for TCC yesterday and failed to get the attached filed before the end of the day. I apologize for the filing being a day late.

Sincerely,

Randal E. Roper
Regulatory Case Manager, AEP Texas Regulatory Services

Attachment

§25.52. -- Reliability and Continuity of Service.

<http://www.puc.state.tx.us/rules/subrules/electric/25.52/25.52.doc>

Application. This section applies to all electric utilities as defined by the Public Utility Regulatory Act (PURA) §31.002(6) and all transmission and distribution utilities as defined by PURA §31.002(19). The term "utility" as used in this section shall mean an electric utility and a transmission and distribution utility.

Public Utility Regulatory Act §31.002

<http://www.puc.state.tx.us/rules/statutes/index.cfm>

DEFINITIONS.

The term "Electric utility" does not include a municipally owned utility or an electric cooperative.

Information typed in highlighted cells will appear on following sheets.

Utility: Type Name of Utility in the Cell Below
AEP Texas Central Company

Feeders: Type Total Number of Distribution Feeders in the Cell Below
689

Due: February 15, 2005

**File: Five Printed Copies and
One Electronic Copy of This Excel File**

Project: 30613

**Address: Attn: Filing Clerk
Public Utility Commission of Texas
P.O. Box 13326
Austin, Texas 78711-3326**

If you have any questions, please contact:

Larry Reed
Electric Division
Commission Staff

Voice: 512 936 7357

Fax: 512 936 7428

E-mail: <mailto:larry.reed@puc.state.tx.us>

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2004 Reporting Year

AEP Texas Central Company

Project 30613

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2004	1.23	0.04	0.06	0.07	0.14	0.16	0.17	0.10	0.12	0.09	0.08	0.12	0.09
Scheduled 2004	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Outside Causes 2004	0.25	0.00	0.01	0.01	0.02	0.01	0.07	0.02	0.02	0.02	0.01	0.01	0.06
Major Events 2004	0.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08
With Storms	1.56												
Without Storms	1.49												

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2004	112.7	2.8	3.9	4.6	14.4	17.6	21.7	6.9	7.5	6.4	7.6	10.8	8.6
Scheduled													
2004	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0
Outside Causes													
2004	13.7	0.3	0.2	0.4	2.2	0.6	4.3	0.7	0.8	1.0	0.1	0.4	2.8
Major Events													
2004	28.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	28.0

With Storms 154.8
Without Storms 126.8

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

689

Add or Delete Rows as Necessary

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
1	11	BRUNI	5440	31.0	9.29
2	7	TATTON	8490	129.0	7.63
3	243	HARLINGEN S.S.	4230	1,607.0	7.11
4	143	ALAZAN	620	220.0	7.06
5	38	NORTH EDINBURG	560	440.0	6.45
6	441	NORTH MCALLEN	2750	1,008.0	5.95
7	431	SOUTH MCALLEN	3790	2,038.0	5.80
8	41	HARLINGEN S.S.	320	552.0	5.56
9	409	PLEASANTON	2080	1,357.0	5.56
10	186	PALMVIEW	9685	772.0	5.51
11	103	BRUNI	1120	89.0	5.47
12	567	CRESTONIO	260	1,507.0	5.42
13	234	LAGUNA	9590	2,134.0	5.32
14	64	SHARYLAND	2020	2,849.0	5.27
15	361	TAFT	1260	109.0	5.00
16	10	NORTH ALAMO	4370	1,979.0	4.88
17	283	PORTLAND	9290	1,186.9	4.76
18	49	LIVE OAK	1080	467.3	4.75
19	447	SAN DIEGO	2880	1,423.0	4.74
20	395	BIG WELLS	1570	497.0	4.69
21	613	SOUTHSIDE	5335	938.0	4.56
22	452	TAFT	1180	1,154.0	4.54
23	84	ELSA	710	599.0	4.47
24	496	SAN DIEGO	1980	643.0	4.45
25	554	GANADO	5795	682.0	4.44
26	203	EAST HARRISON	3950	320.0	4.41
27	63	NORTH ALAMO	3580	316.0	4.36
28	313	WESLACO UNIT	8610	2,364.9	4.35
29	182	SOUTH MCALLEN	3640	1,170.0	4.28
30	274	BRUNI	1100	685.0	4.25
31	268	BAY CITY	6450	1,061.0	4.24
32	139	BAY CITY	1110CN	964.0	4.19
33	51	GREGORY	5920	506.3	4.17
34	138	PALACIOS	6830	894.0	4.11
35	177	GOVERNMENT WELLS	7240	257.0	4.09
36	115	RAYMONDVILLE #2	3250	43.0	4.07
37	89	FREER	1500	209.0	3.98
38	210	FOSTER FIELD	2550	117.0	3.97
39	100	CARRIZO SPRINGS	860	1,427.0	3.94
40	223	LOYOLA	195	655.0	3.84
41	88	FULTON	9050	970.0	3.84
42	501	KENEDY S.S.	6750	495.0	3.71
43	201	HARLINGEN	380	1,293.0	3.68

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
44	98	KINGSVILLE	1130	1,667.0	3.57
45	337	NORTH EDINBURG	3570	465.0	3.55
46	199	PALMVIEW	3930	960.5	3.51
47	291	ARCADIA	6930	1,935.0	3.51
48	190	GREENLAKE	2740CN	20.0	3.50
49	289	NORTH PADRE ISLAND	7900	1,867.0	3.49
50	442	HAMILTON ROAD	9655	680.0	3.47
51	82	ALAZAN	2740CS	40.0	3.45
52	525	TAFT	5230	915.0	3.44
53	43	MATHIS	2870	990.0	3.43
54	224	LOS FRESNOS	3290	1,087.0	3.41
55	25	SANTA ROSA	4040	883.0	3.35
56	634	COLUMBUS	9060	541.0	3.32
57	8	CLARKWOOD	7230	134.0	3.31
58	204	SHARYLAND	2010	1,015.0	3.29
59	52	PLEASANTON	120	1,222.0	3.29
60	618	WESLACO UNIT	8195	2,227.5	3.26
61	90	LIVE OAK	1090CS	179.3	3.26
62	154	PLEASANTON	9475	1,716.0	3.19
63	60	ELSA	3520	1,117.0	3.17
64	36	SKIDMORE	380CS	253.0	3.16
65	579	EL CAMPO	2800	1,369.0	3.14
66	364	WEAVER ROAD	1900	104.0	3.11
67	123	MAVERICK	9680W	603.0	3.10
68	397	BEEVILLE	1760	865.0	3.08
69	175	SOUTH PADRE ISLAND	4695	1,975.0	3.07
70	612	MAGRUDER	6700	1,886.0	3.06
71	433	ARANSAS PASS	590	148.0	3.05
72	97	NORTH MERCEDES	3840	766.0	3.01
73	40	STAFFORD HILL	1550	178.0	2.98
74	37	CASA BLANCA	1300CS	584.0	2.93
75	404	HARLINGEN	660	1,607.0	2.92
76	424	LA PRYOR	2440	585.0	2.91
77	231	WESMER	4050	1,656.0	2.89
78	391	SOUTHSIDE	8025	616.0	2.86
79	403	LIVE OAK	1070	2,233.0	2.85
80	649	SUNCHASE	1155	329.0	2.85
81	500	SEAWALL	9325	1,498.0	2.83
82	237	VICTORIA POWER PLANT	8170	732.0	2.82
83	545	GOODWIN	4625	1,088.7	2.81
84	159	SOUTH MCALLEN	3935	1,166.0	2.71
85	344	MOORE FIELD	3960	1,358.0	2.71
86	400	EL CAMPO	6370	994.0	2.71
87	345	KENEDY	1970	180.6	2.70
88	382	PORT ARANSAS	990CS	559.0	2.69
89	76	CASA BLANCA	55	353.0	2.69
90	574	EDNA	5765	1,134.8	2.69
91	96	GREENLAKE	2750CN	886.0	2.65

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
92	124	PORTLAND	9270	1,737.6	2.60
93	15	RAYMONDVILLE #2	1280	1,521.0	2.60
94	61	EDROY	6990	228.0	2.57
95	421	MOORE FIELD	3110	948.0	2.57
96	432	COLUMBUS	6180	867.0	2.54
97	17	RAYMONDVILLE #1	630	809.0	2.54
98	383	LA PRYOR	570	94.0	2.53
99	408	DILLEY	510	458.0	2.53
100	429	HAMILTON ROAD	9665W	335.0	2.52
101	150	BAY CITY	2700	1,361.0	2.52
102	95	BIG WELLS	2630	243.0	2.51
103	211	WEST MCALLEN	4515	695.0	2.49
104	311	FULTON	2020CS	1,514.0	2.49
105	594	HEARN ROAD	8980	961.0	2.49
106	422	CAUSEWAY	4765	1,170.0	2.48
107	162	UNIVERSITY	920	1,700.0	2.46
108	299	EAGLE PASS CITY	2650	3,199.1	2.45
109	2	CONTINENTAL	4880	57.0	2.44
110	194	LULING - LCRA	10CN	229.0	2.44
111	440	WESLACO UNIT	7630	2,014.3	2.43
112	193	SOUTH EAST EDINBURG	4550	1,830.0	2.41
113	53	BAY CITY	2050	676.0	2.41
114	492	RANGERVILLE	4060	474.0	2.41
115	583	KENEDY S.S.	8340	695.0	2.41
116	132	ZAPATA	8290W	2,095.0	2.41
117	405	PREMONT	2730	222.0	2.41
118	62	PALACIOS	8550	100.0	2.40
119	92	NORTH ALAMO	3610	1,242.0	2.37
120	271	RUNGE	7320	592.0	2.36
121	512	WEST HARLINGEN	3800	2,391.0	2.35
122	414	HEARN ROAD	8990	1,031.0	2.35
123	354	SKIDMORE	600	348.0	2.34
124	669	PHARAOH	1365	470.0	2.34
125	321	RIO RICO	8330	612.0	2.33
126	58	HAINE DRIVE	9690	1,088.0	2.33
127	99	ELSA	700	855.0	2.33
128	102	BRUNI	5160	196.0	2.33
129	117	PORT ARANSAS	1000	888.0	2.33
130	504	EL CAMPO	7710	1,120.0	2.33
131	21	INGLESIDE CITY	8060	1,069.0	2.32
132	27	EDROY	6980	350.0	2.32
133	303	WASHINGTON STREET	6525	2,080.0	2.31
134	108	SAN BENITO	3920	2,145.0	2.31
135	118	SOUTHSIDE	8045	1,025.0	2.30
136	39	WEST MCALLEN	4535	1,925.0	2.30
137	247	FREER	6320	178.0	2.29
138	213	PLEASANTON	9505	1,300.0	2.29
139	170	SOUTH MCALLEN	3850	1,026.0	2.29

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
140	282	HIGHWAY 9	6770	1,589.0	2.29
141	462	YORKTOWN	8380	822.0	2.28
142	30	BANQUETTE	9000	129.0	2.26
143	188	FREER	2900	316.0	2.26
144	540	DEL RIO CITY	9790	2,976.0	2.25
145	534	HARLINGEN	360	1,727.0	2.23
146	34	SANTO NINO	80	520.0	2.23
147	6	CLARKWOOD	5525	465.0	2.22
148	9	RANDADO	8360	78.0	2.21
149	4	POLK AVENUE	4170	1,523.0	2.19
150	244	PETTUS	1020	333.0	2.19
151	659	EAGLE PASS CITY	450	1,832.7	2.18
152	584	SOUTH MISSION	5215	1,060.0	2.16
153	246	PORT ARANSAS	3030CS	594.0	2.16
154	183	EAGLE LAKE	9455	541.0	2.16
155	596	NORTH VICTORIA	7770	989.0	2.14
156	178	SOUTH PADRE ISLAND	6440	1,974.0	2.12
157	489	DEVINE	7100	641.0	2.12
158	446	RANDADO	8350	93.0	2.11
159	105	LOS FRESNOS	3280	1,673.0	2.10
160	379	UNIVERSITY	930	104.0	2.10
161	507	NORTH VICTORIA	7860	1,373.0	2.09
162	302	ROMA	3070	1,656.0	2.09
163	617	LAREDO HEIGHTS	2450	2,080.0	2.09
164	385	PLACEDO	7970	319.0	2.08
165	461	BAY CITY	6670	1,826.0	2.08
166	22	INGLESIDE CITY	6040	1,069.0	2.08
167	563	ROBSTOWN	7120	119.0	2.08
168	281	JOURDANTON	5695	1,071.0	2.07
169	86	ARMSTRONG	6050	48.0	2.06
170	369	SOUTH EAST EDINBURG	4015	1,385.0	2.05
171	665	BROOKHOLLOW	7190	587.0	2.04
172	380	CAVAZOS	3550	1,977.0	2.02
173	359	KLEBERG	8140	170.0	2.02
174	81	SAN YGNACIO	16060	275.7	2.02
175	392	MATTHEWS	1740	39.0	1.97
176	185	ALICE	2540	1,034.0	1.95
177	235	ALICE	2530	891.0	1.93
178	644	BANDERA ELECTRIC (LEAKEY)	L30	388.0	1.93
179	35	ROBSTOWN	1650	548.0	1.92
180	413	BLESSING	8790	634.0	1.91
181	195	CABANISS	80	657.0	1.91
182	263	NORDHEIM	470	242.0	1.90
183	46	TATTON	8200	1,498.0	1.90
184	207	BONNIEVIEW	8020	403.0	1.88
185	80	GREGORY	5900	97.7	1.87
186	31	RAYMONDVILLE #2	3170	578.0	1.87
187	620	ARANSAS PASS	660CS	346.0	1.86

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
188	121	PORT ISABEL S.S.	3820	468.0	1.86
189	470	FULTON	440	1,565.0	1.86
190	451	MARKHAM	5550	84.0	1.86
191	516	EDNA	5785	475.7	1.84
192	3	DEL RIO CITY	420	1,981.0	1.84
193	198	PORT LAVACA	8310	272.9	1.83
194	209	CARRIZO SPRINGS	370W	289.0	1.81
195	430	WADSWORTH	8630	583.0	1.81
196	148	EAST HARRISON	3080	1,136.0	1.80
197	215	SINTON	360CS	274.0	1.79
198	77	REFUGIO	5120	124.0	1.78
199	420	GREGORY	8560	429.0	1.78
200	248	BROWNSVILLE	3050	1,315.0	1.76
201	631	WEST MCALLEN	4965	754.0	1.74
202	435	DARST	800	242.0	1.74
203	258	WEST MCALLEN	4815	840.0	1.73
204	226	ODEM	375	727.0	1.73
205	398	MORRIS STREET	8715	1,645.0	1.71
206	459	NORTH VICTORIA	6390	1,116.0	1.71
207	222	EAST HARRISON	4360	1,349.8	1.71
208	217	SOUTHSIDE	7995	1,468.0	1.70
209	527	GARCENO	2135	1,580.0	1.70
210	221	MCKENZIE ROAD	140	115.0	1.70
211	14	MATHIS	340CS	1,491.0	1.67
212	205	FALFURRIAS	2830	1,398.0	1.66
213	149	RAYMONDVILLE #1	620	607.0	1.65
214	503	NORTH VICTORIA	7440	2,209.0	1.65
215	580	ARANSAS PASS	1250	297.0	1.64
216	487	SOUTHSIDE	7955	969.0	1.64
217	259	JOURDANTON	880	359.0	1.61
218	50	PHARR	1625	548.0	1.60
219	606	SOUTH EAST EDINBURG	6580	1,921.0	1.60
220	241	ARCADIA	1360	1,958.0	1.58
221	588	HARLINGEN S.S.	4110	799.0	1.57
222	465	ARCADIA	1440	1,717.0	1.57
223	151	EAGLE PASS CITY	2745	1,445.3	1.57
224	402	ROCKPORT	5950	430.0	1.56
225	266	STADIUM	8540	1,777.0	1.56
226	225	WESLACO UNIT	9805	1,865.2	1.55
227	480	LA GRULLA	4120	1,759.0	1.55
228	54	PORT ARANSAS	6940	891.0	1.54
229	176	GREENLAKE	2760	668.0	1.54
230	517	LEARY LANE	1890	1,421.3	1.54
231	372	KNIPPA	6535	15.0	1.53
232	547	POINT COMFORT	6060	403.0	1.53
233	497	PORTLAND	6505	1,735.9	1.52
234	526	KLEBERG	1560	903.0	1.51
235	220	GOVERNMENT WELLS	6800	237.0	1.51

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
236	454	ARCADIA	1400	553.0	1.50
237	70	RIO GRANDE CITY	3740	2,976.0	1.50
238	524	ARANSAS PASS	8270	445.0	1.49
239	42	HARLINGEN S.S.	4090	1,077.0	1.49
240	293	VICTORIA POWER PLANT	1390	1,337.0	1.48
241	94	GOVERNMENT WELLS	7250	337.0	1.47
242	510	SABINAL	200	416.0	1.47
243	410	CLARKWOOD	9570	1,175.0	1.47
244	605	RAYMONDVILLE #2	4160	917.0	1.47
245	310	MORRIS STREET	8840	657.0	1.46
246	457	MCCOLL ROAD	4790	1,486.0	1.46
247	473	BERCLAIR	990C	241.0	1.46
248	614	LAREDO HEIGHTS	6820	1,040.0	1.45
249	529	BLESSING	1030	145.0	1.45
250	264	EAST HARRISON	3030	1,037.0	1.44
251	490	RODD FIELD	205	585.0	1.44
252	553	NAVAL BASE	1380CS	1,911.0	1.43
253	341	ANNA STREET	850	1,519.0	1.41
254	297	MCKENZIE ROAD	330	1,708.0	1.40
255	438	O CONNER	390CN	119.0	1.39
256	439	KLEBERG	6000	1,536.0	1.38
257	592	DEVINE	7090	678.0	1.38
258	530	EL CAMPO	5745	914.0	1.37
259	83	PARKER	9260	69.0	1.36
260	552	HIGHWAY 9	6730	376.0	1.35
261	197	ANNA STREET	2250	1,495.0	1.35
262	23	HALL ACRES ROAD	5465	2,731.0	1.34
263	390	PALMHURST	3890	1,120.7	1.33
264	276	BAY CITY	5960	1,897.0	1.32
265	287	RODD FIELD	2190	2,593.0	1.32
266	425	STADIUM	7490	1,336.0	1.32
267	625	DARST	790	121.0	1.31
268	570	SOUTH MISSION	3590	2,441.0	1.30
269	130	SHARYLAND	2150	856.0	1.30
270	572	AIRLINE	8260	1,028.0	1.30
271	418	MCCOLL ROAD	4400	843.0	1.28
272	330	CARANCAHUA	5870CN	274.0	1.27
273	558	SHARYLAND	2035	1,576.0	1.27
274	387	CABANISS	75	970.0	1.27
275	245	NORTH MERCEDES	4860	1,553.0	1.27
276	485	GOODWIN	3530	1,434.5	1.26
277	635	FREER	5200	1,295.0	1.26
278	309	HEARN ROAD	870	972.0	1.26
279	352	JOURDANTON	5685	655.0	1.26
280	651	EAST HARRISON	4620	1,367.0	1.25
281	546	CRYSTAL CITY	140W	1,696.0	1.25
282	564	PHARAOH	1285	1,682.0	1.24
283	168	BEEVILLE	8510CN	969.0	1.24

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
284	522	NAVAL BASE	8440	1,276.0	1.24
285	436	YORKTOWN	8420	908.0	1.24
286	539	RODD FIELD	3010	957.0	1.24
287	68	NORTH MCALLEN	5055	1,704.0	1.23
288	582	ROCKPORT	5940	112.0	1.23
289	356	WASHINGTON STREET	6355	832.0	1.23
290	272	RACHAL	6595	713.0	1.23
291	236	CONTINENTAL	4080	123.0	1.23
292	466	FALFURRIAS	5210	998.0	1.22
293	678	PARKER	9010	14.0	1.21
294	595	CONOCO-CHITTAM RANCH	8580	52.0	1.21
295	290	LEARY LANE	1430	1,296.0	1.21
296	78	HEARN ROAD	9665	820.0	1.21
297	335	BISHOP	7180	995.0	1.21
298	456	FULTON	6070	1,901.0	1.21
299	300	HIDALGO	3680	946.0	1.20
300	365	LAREDO PLANT	8565	874.0	1.20
301	384	HIGHWAY 9	6720	1,393.0	1.19
302	639	SANTO NINO	645	1,560.0	1.19
303	269	CLARKWOOD	7610	224.0	1.19
304	611	NORTH MERCEDES	3770	1,552.0	1.19
305	491	LAGUNA	9065	1,680.0	1.18
306	158	WEAVER ROAD	1910	261.0	1.18
307	308	EAST HARRISON	3190	1,186.0	1.18
308	505	WASHINGTON STREET	2350	1,560.0	1.18
309	75	NIXON	810	537.0	1.18
310	318	GANADO	5815	544.0	1.18
311	627	NORTH MCALLEN	9660	1,419.0	1.18
312	482	ASPHALT MINES	500	24.0	1.17
313	141	REFUGIO	1210	229.0	1.16
314	531	MAGRUDER	6690	538.0	1.16
315	520	HALL ACRES ROAD	3460	2,493.0	1.16
316	180	THREE RIVERS	8430	140.0	1.16
317	26	POLK AVENUE	4600	2,137.0	1.16
318	657	NUECES BAY PLANT	350	782.0	1.15
319	316	PALMHURST	2525	2,269.2	1.14
320	647	PREMONT	2720	965.0	1.14
321	556	KLEBERG	9395	1,096.0	1.14
322	585	MAGRUDER	7690	898.0	1.14
323	406	RIO BRAVO	5	1,040.0	1.14
324	616	HOLLY	1370	2,254.0	1.14
325	602	BLESSING	8780	75.0	1.13
326	652	MCCOLL ROAD	4910	1,444.0	1.13
327	336	RIO GRANDE CITY	3230	1,043.0	1.13
328	339	THREE RIVERS	2580	109.0	1.13
329	640	INGLESIDE CITY	7310	53.0	1.11
330	69	POLK AVENUE	4520	2,100.0	1.11
331	511	AIRLINE	9605	556.0	1.10

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
332	284	HOLLY	1950	1,098.0	1.10
333	286	LA PRYOR	580	159.0	1.09
334	114	UVALDE	6620	1,560.0	1.09
335	381	SOUTH PADRE ISLAND	5850	1,974.0	1.09
336	326	INGLESIDE CITY	8050	1,337.0	1.09
337	368	MORRIS STREET	7465	675.0	1.09
338	122	PHARR	1620	1,725.0	1.09
339	622	COMSTOCK	290	199.0	1.08
340	632	CASA BLANCA	5115	1,155.0	1.07
341	591	SANTO NINO	515	1,560.0	1.07
342	386	GREGORY	420	19.7	1.07
343	179	NORTH VICTORIA	7430	519.0	1.06
344	367	LAREDO PLANT	8505	1,040.0	1.06
345	133	MALONE	7560	227.0	1.06
346	518	ROCKSPRINGS	8040	312.0	1.05
347	590	CAMPWOOD	3430	398.0	1.05
348	109	PLACEDO	7980	403.0	1.05
349	654	CAUSEWAY	4775	1,029.0	1.05
350	101	LOS FRESNOS	3200	1,460.0	1.05
351	630	HIGHWAY 9	7210	1,058.0	1.04
352	191	GOODWIN	4390	855.2	1.03
353	394	COTULLA	90	617.0	1.03
354	135	EAGLE PASS CITY	2770	1,452.0	1.03
355	295	ANNA STREET	780	432.0	1.03
356	20	SANTA ROSA	420	1,546.0	1.02
357	670	ARANSAS PASS	650	247.0	1.02
358	666	WASHINGTON STREET	2470	624.0	1.01
359	169	LAREDO PLANT	9305	1,872.0	1.01
360	673	HAINE DRIVE	9700	495.0	1.00
361	126	KARON HUMBLE PUMP	9895	40.0	1.00
362	677	NORMANNA CST	840	10.0	1.00
363	192	PEARSALL	9905	187.0	1.00
364	new	SANTO NINO	695	50.0	1.00
365	346	BROWNSVILLE	4290	767.0	1.00
366	232	MORRIS STREET	2515	1,167.0	0.97
367	373	PALMHURST	2820	2,270.5	0.97
368	145	ELSA	690	966.0	0.96
369	212	ARANSAS PASS	9130	297.0	0.95
370	256	PORT ISABEL S.S.	3760	851.0	0.94
371	378	LOYOLA	120	691.0	0.93
372	467	HAINE DRIVE	270	740.0	0.92
373	164	CRESTONIO	270W	623.0	0.92
374	275	LEARY LANE	1540	1,503.3	0.90
375	389	WEST OSO	9085	309.0	0.90
376	423	ARCADIA	1460	2,465.0	0.88
377	533	SAN DIEGO	2890	990.0	0.86
378	239	BUENA VISTA	9035	893.0	0.85
379	228	LEARY LANE	7530	1,778.3	0.84

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
380	396	LA GRULLA	5110	1,479.0	0.84
381	285	SOUTH EAST EDINBURG	5045	454.0	0.83
382	216	RIO GRANDE CITY	3220	1,407.0	0.81
383	560	MORRIS STREET	8820	1,212.0	0.81
384	494	HIGHWAY 9	6780	872.0	0.80
385	478	UVALDE	550	385.0	0.79
386	581	WEIL TRACT (138/12KV)	1990	993.0	0.78
387	407	CHARLOTTE	8120	151.0	0.77
388	416	PHARAOH	1185	1,352.0	0.76
389	47	PHARR	1640	213.0	0.76
390	229	HALL ACRES ROAD	5585	1,270.0	0.75
391	1	SANTO NINO	70	1,560.0	0.75
392	18	WEST OSO	9090	1,909.0	0.74
393	261	SINTON	180	1,139.0	0.74
394	577	LEARY LANE	6005	827.0	0.73
395	650	EDNA	5775	832.3	0.72
396	129	PRAIRIE PUMP	1940	38.0	0.71
397	357	SOUTH MISSION	3940	2,326.0	0.71
398	521	ARANSAS PASS	8280	346.0	0.69
399	113	LA GRULLA	5005	1,389.0	0.68
400	44	DEVINE	8100	951.0	0.68
401	448	LYTLE	2850	655.0	0.67
402	144	KINGSVILLE	1670	398.0	0.67
403	79	ARCADIA	8570	1,425.0	0.67
404	377	MINES ROAD	3680	728.0	0.67
405	674	HIGHWAY 9	9830	105.0	0.67
406	598	RIO RICO	5050	1,755.0	0.66
407	267	AIRLINE	9030	325.0	0.65
408	279	SINTON	1750	369.0	0.64
409	277	PHARAOH	5175	1,047.0	0.63
410	479	LAREDO HEIGHTS	2390	777.5	0.63
411	65	ZAPATA	7330	2,225.0	0.62
412	29	NUECES BAY PLANT	7825	397.0	0.61
413	262	ELSA	3500	1,134.0	0.61
414	453	MAGRUDER	7870	1,270.0	0.61
415	298	ODEM	385	259.0	0.61
416	528	KLEBERG	280	1,384.0	0.60
417	13	PUEBLO	130	1,092.0	0.60
418	411	BEEVILLE	8090	1,268.0	0.58
419	455	MUSTANG ISLAND	8510CS	47.0	0.57
420	33	GOLIAD	6540	877.0	0.57
421	233	CAMPWOOD	2610	915.0	0.57
422	19	PUEBLO	95	1,341.0	0.56
423	449	LAREDO HEIGHTS	6810	2,080.0	0.56
424	172	LULING - LCRA	20	267.3	0.56
425	325	MARKHAM	6440CN	455.0	0.56
426	488	MAGRUDER	6680	639.0	0.56
427	333	RIO GRANDE CITY	3210	1,282.0	0.55

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
428	301	MALONE	7550	218.0	0.55
429	87	GATEWAY	380	520.0	0.54
430	240	PORT LAVACA	2480CN	932.9	0.52
431	506	ENCINAL	2160	650.0	0.52
432	471	MAGRUDER	245	1,027.7	0.51
433	619	DEL RIO CITY	1930	1,170.0	0.51
434	548	ROMA	3060	1,738.0	0.51
435	444	BROOKHOLLOW	8950	763.0	0.51
436	93	MINES ROAD	3745	1,821.0	0.50
437	155	PREMONT	6570	1,453.0	0.50
438	315	PALACIOS	6840	1,373.0	0.50
439	147	STADIUM	7810	1,297.0	0.50
440	206	SINTON	6860	1,306.0	0.50
441	550	LAREDO HEIGHTS	9400	1,040.0	0.50
442	434	BEEVILLE	300	1,232.0	0.49
443	200	CRYSTAL CITY	330W	957.0	0.49
444	477	GOODWIN	4380	917.7	0.49
445	257	PEARSALL	7050	1,388.0	0.49
446	331	FALFURRIAS	1080W	436.0	0.48
447	208	WOOLRIDGE	1170CS	527.0	0.48
448	575	HOLLY	5820	1,123.0	0.47
449	543	UVALDE	9770	1,664.0	0.47
450	251	CABANISS	240	1,144.0	0.47
451	219	SAN DIEGO	2930	594.0	0.46
452	85	MATHIS	1410	150.0	0.46
453	460	PALMHURST	1300	1,551.0	0.46
454	486	SOUTHSIDE	7905	2,070.0	0.46
455	427	NIXON	2620	584.0	0.46
456	412	RIO RICO	8290	128.0	0.45
457	578	WEST HARLINGEN	3700	1,348.0	0.45
458	202	ALICE	1770	1,168.0	0.45
459	589	HALL ACRES ROAD	3670	1,043.0	0.45
460	294	NORTH VICTORIA	1580	1,066.0	0.44
461	535	ARCADIA	5020	1,844.0	0.44
462	119	SAN BENITO	3910	2,448.0	0.43
463	468	CARRIZO SPRINGS	910	1,648.0	0.43
464	472	GARCENO	2130	1,326.0	0.43
465	615	BANQUETTE	130	534.0	0.43
466	127	SANTA ROSA	3270	1,111.0	0.42
467	265	SOUTH MISSION	3620	3,217.5	0.42
468	393	PALMHURST	2535	723.0	0.42
469	549	MCKENZIE ROAD	150	12.0	0.42
470	643	ARCADIA	5030	1,873.0	0.42
471	110	NIXON	5990	519.0	0.41
472	214	ARCADIA	1450	2,522.0	0.40
473	24	POLK AVENUE	4190	2,022.0	0.40
474	270	WADSWORTH	7660	1,108.0	0.40
475	475	SEAWALL	9420	1,001.0	0.40

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
476	327	BAY CITY	7480	1,983.0	0.39
477	16	SAN BENITO	4945	2,156.0	0.39
478	515	KINGSVILLE	1660	1,444.0	0.39
479	464	STADIUM	7800	916.0	0.38
480	388	WESLACO UNIT	5970	2,247.4	0.38
481	250	MILO	3065	364.0	0.37
482	181	CHARLOTTE	2790	177.0	0.37
483	610	LEARY LANE	6175	1,160.0	0.37
484	187	LOS FRESNOS	930S	889.0	0.37
485	32	PUEBLO	275	1,144.0	0.37
486	559	EAGLE LAKE	310	820.0	0.36
487	189	GRETA	7890	301.0	0.36
488	153	MCCOLL ROAD	2810	1,539.0	0.36
489	260	SOUTHSIDE	7925	1,183.0	0.36
490	116	SAN BENITO	3860	158.0	0.35
491	514	MATHIS	1420	804.0	0.35
492	71	RODD FIELD	225	1,437.0	0.35
493	587	STADIUM	6950	604.0	0.35
494	306	ASHERTON	2660	658.0	0.34
495	469	HIGHWAY 9	6760	817.0	0.34
496	278	THREE RIVERS	2010CN	745.0	0.34
497	523	DILLEY	6400	1,009.0	0.34
498	218	CHARLOTTE	2780	531.0	0.34
499	67	WEST MCALLEN	4555	1,618.0	0.33
500	474	WOODSBORO	8330CS	1,084.0	0.33
501	338	PEARSALL	5580	1,983.0	0.33
502	484	WESLACO UNIT	7455	1,820.7	0.32
503	443	NORTH MCALLEN	4995	1,369.0	0.32
504	498	SEAWALL	9450	153.0	0.32
505	458	DEL RIO CITY	430	2,334.0	0.32
506	636	WEST OSO	9095	2,551.0	0.31
507	541	ALICE	1790	435.0	0.31
508	305	WEIL TRACT (138/12KV)	2520	291.0	0.30
509	426	WEIL TRACT (138/12KV)	5405	144.0	0.30
510	513	SOUTHSIDE	8035	1,135.0	0.30
511	184	ANNA STREET	900	2,241.0	0.29
512	320	BEEVILLE	2200	794.0	0.29
513	586	MORRIS STREET	8830	1,572.0	0.29
514	238	SOUTHSIDE	8055	1,055.0	0.29
515	196	GATEWAY	390	1,456.0	0.29
516	5	CRYSTAL CITY	190	1,025.0	0.29
517	519	SOUTHSIDE	8005	703.0	0.29
518	165	FANNIN	7940	25.0	0.28
519	48	NORTH WESLACO	4810	1,847.0	0.28
520	603	DEL MAR	490	1,326.0	0.28
521	358	MOORE FIELD	3120	417.0	0.28
522	120	NORTH PADRE ISLAND	5170	2,787.0	0.28
523	508	NORTH MCALLEN	2980	1,626.0	0.28

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
524	375	EAST HARRISON	4310	1,039.0	0.28
525	12	RIO BRAVO	300	897.0	0.27
526	401	NORTH EDINBURG	3810	238.0	0.27
527	304	NORTH MCALLEN	5060	1,818.0	0.27
528	137	SAN BENITO	4030	2,796.0	0.26
529	509	UVALDE	5060	1,664.0	0.26
530	72	HIDALGO	3400	866.0	0.26
531	350	MORRIS STREET	7625	573.0	0.26
532	362	KINGSVILLE	1350	277.0	0.26
533	597	KLEBERG	6410	366.0	0.25
534	317	UVALDE	480	1,675.0	0.25
535	476	ROCKPORT	5930	1,001.0	0.25
536	73	GOLIAD	8220	1,046.0	0.24
537	107	PORT LAVACA	2490	818.0	0.24
538	322	PORT ISABEL S.S.	4070	524.0	0.24
539	173	CRESTONIO	6660	976.0	0.24
540	255	HAMILTON ROAD	9645	316.0	0.24
541	569	CAVAZOS	3560	1,240.0	0.24
542	608	AIRLINE	8890	407.0	0.23
543	648	HALL ACRES ROAD	4895	1,642.0	0.23
544	59	RANGERVILLE	3410	757.0	0.23
545	343	NUECES BAY PLANT	345	52.0	0.23
546	273	AMISTAD DAM	5450	959.0	0.23
547	566	AIRLINE	9390	1,043.0	0.22
548	91	POLK AVENUE	4900	1,557.0	0.22
549	481	WEST HARLINGEN	3720	1,696.0	0.21
550	445	HAINE DRIVE	8065	1,238.0	0.21
551	437	REFUGIO	1040	560.0	0.21
552	499	THREE RIVERS	5190	685.0	0.21
553	288	SUNCHASE	1150	329.0	0.21
554	668	MUSTANG ISLAND	9470	646.0	0.21
555	125	GATEWAY	350	1,560.0	0.21
556	249	NORTH EDINBURG	4240	638.0	0.21
557	142	COTULLA	110	1,399.0	0.20
558	292	BISHOP	2690	771.0	0.20
559	360	ROCKSPRINGS	2600	363.0	0.20
560	642	SOUTH MISSION	4650	1,721.0	0.20
561	551	LAREDO PLANT	8745	1,040.0	0.20
562	593	HIDALGO	4845	466.0	0.20
563	324	VICTORIA POWER PLANT	8070	439.0	0.19
564	562	BROOKHOLLOW	8960	821.0	0.19
565	576	BROOKHOLLOW	7580	645.0	0.19
566	428	GEORGE WEST	1320	587.0	0.19
567	334	GARWOOD CITY	2570	302.0	0.19
568	662	POINT COMFORT	2460	327.0	0.18
569	128	COLUMBUS	930CN	935.0	0.18
570	557	WESMER	4480	2,462.0	0.18
571	66	SAN BENITO	4135	1,801.0	0.18

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
572	329	WASHINGTON STREET	7015	1,040.0	0.18
573	140	CAUSEWAY	4795	1,591.0	0.18
574	623	NORTH MCALLEN	3830	1,427.0	0.18
575	633	HOLLY	7740	2,783.0	0.18
576	104	RAYMONDVILLE #2	3240	1,292.0	0.17
577	254	POLK AVENUE	4610	2,158.0	0.17
578	111	EAGLE LAKE	320CN	685.0	0.17
579	174	KENEDY S.S.	8320	863.0	0.17
580	307	BUENA VISTA	8965	917.0	0.17
581	600	SABINAL	485	496.0	0.17
582	463	UVALDE	540	832.0	0.17
583	661	HOLLY	9675	3,315.0	0.17
584	146	BROWNSVILLE	4280	1,111.0	0.16
585	new	PALMVIEW	9680	352.5	0.16
586	419	NAVAL BASE	6330CS	259.0	0.16
587	561	WOOLRIDGE	1120CS	1,294.0	0.16
588	136	HIGHWAY 9	7200	947.0	0.16
589	363	GARWOOD CITY	2560	202.0	0.16
590	242	AIRLINE	7280	626.0	0.16
591	55	SOUTH MISSION	3980	3,928.5	0.16
592	106	EAGLE PASS CITY	7060	1,521.0	0.15
593	28	POLK AVENUE	4180	2,917.0	0.15
594	565	FULTON	3070	1,782.0	0.15
595	502	THREE RIVERS	5100	40.0	0.15
596	645	WASHINGTON STREET	2360	728.0	0.15
597	399	PETTUS	8210	450.0	0.15
598	374	MORRIS STREET	5655	1,095.0	0.14
599	56	SANTO NINO	75	1,872.0	0.14
600	340	SOUTH EAST EDINBURG	4570	1,636.0	0.14
601	638	THOMASTON	9580	52.0	0.13
602	112	COFFEE PORT	1095	1,170.0	0.13
603	280	HOLLY	1480	2,295.0	0.13
604	253	BUENA VISTA	9385	1,677.0	0.13
605	152	AIRLINE	7390	1,394.0	0.13
606	536	AIRLINE	8370	363.0	0.13
607	493	MILO	3060	1,760.0	0.13
608	624	DEL RIO CITY	9850	798.0	0.13
609	227	ASHERTON	2670	158.0	0.13
610	332	LAREDO HEIGHTS	2100	2,028.0	0.12
611	314	KENEDY	6270	987.7	0.12
612	599	HOLLY	7620	2,499.0	0.12
613	604	NORTH VICTORIA	1470	736.0	0.12
614	532	HALL ACRES ROAD	9595	611.0	0.12
615	45	ZAPATA	2710	43.0	0.12
616	351	FALFURRIAS	1070W	916.0	0.12
617	653	DEL RIO CITY	440	1,686.0	0.11
618	156	SANTA ROSA	3750	295.0	0.11
619	349	ALICE	1780	1,049.0	0.11

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
620	607	NORTH WESLACO	4830	1,322.0	0.11
621	323	BRACKETTVILLE	8460	1,189.0	0.10
622	348	WEST MCALLEN	4595	951.0	0.10
623	415	EL CAMPO	2860	395.0	0.10
624	542	LOLITA	6330CN	29.0	0.10
625	57	PHARR	1645	757.0	0.10
626	353	LAREDO PLANT	8695	457.0	0.10
627	626	PORTLAND	9370	1,386.7	0.10
628	544	AIRLINE	6970	1,055.0	0.10
629	342	WESMER	9705	1,242.0	0.10
630	568	NORTH VICTORIA	2240	806.0	0.10
631	641	MORRIS STREET	8850	446.0	0.10
632	252	PHARAOH	5185	1,796.0	0.10
633	555	BEEVILLE	490CN	1,010.0	0.09
634	355	RODD FIELD	1730	1,546.0	0.09
635	675	MILO	3070LA	1,173.0	0.09
636	601	REFUGIO	1170CN	1,131.0	0.08
637	483	CHASE FIELD	460	12.0	0.08
638	161	PORT LAVACA	6850	783.2	0.08
639	450	KNIPPA	6365	285.0	0.08
640	230	RANGERVILLE	3420	665.0	0.08
641	609	EL CAMPO	7260	578.0	0.08
642	656	DEL MAR	7930	2,601.0	0.08
643	538	COFFEE PORT	1090	1,595.0	0.07
644	157	HARLINGEN	370	1,897.0	0.07
645	629	CLARKWOOD	7220	700.0	0.07
646	537	VICTORIA POWER PLANT	7600	220.0	0.07
647	163	POLK AVENUE	4740	1,364.0	0.07
648	628	HEARN ROAD	2220	1,588.0	0.06
649	134	GEORGE WEST	730	714.0	0.06
650	637	KINGSVILLE	1140	969.0	0.06
651	495	WOOLRIDGE	1110CS	1,191.0	0.05
652	312	WEST MCALLEN	4505	2,006.0	0.05
653	417	DEL MAR	10	3,000.0	0.05
654	658	EAST HARRISON	3000	1,250.0	0.05
655	376	DEL MAR	220	486.0	0.05
656	296	AIRLINE	5870CS	791.0	0.05
657	655	ANNA STREET	5780	706.0	0.05
658	319	WESMER	6900	1,492.0	0.04
659	131	WEST HARLINGEN	4870	2,073.0	0.04
660	366	DEL MAR	3440	2,601.0	0.04
661	646	HOLLY	1220	3,250.0	0.04
662	166	JOURDANTON	250	676.0	0.03
663	573	RAYMONDVILLE #1	3130	96.0	0.03
664	663	KENEDY	1960	224.1	0.03
665	667	SOUTHSIDE	5345	428.0	0.03
666	347	BANQUETTE	740	173.0	0.03
667	370	WEST MCALLEN	6385	1,540.0	0.03

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
668	571	MCCOLL ROAD	4780	1,805.0	0.03
669	660	LAREDO HEIGHTS	9080	1,040.0	0.02
670	371	LAREDO PLANT	8705	884.0	0.02
671	621	AIRLINE	7270	975.0	0.01
672	664	EAGLE PASS CITY	2510	693.3	0.01
673	671	BEEVILLE	2380	940.0	0.00
674	676	MORRIS STREET	NET CC	426.0	0.00
675	167	NORTH MCALLEN	9640	1,715.0	0.00
676	74	HAINE DRIVE	9240	1,372.0	0.00
677	171	AIRLINE	2180	12.0	0.00
678	672	AIRLINE	2210	282.0	0.00
679	328	RACHAL	8145	10.0	0.00
680	679	SOUTHSIDE	7935	43.0	0.00
681	680	STEC (RIVERSIDE)	9101	199.0	0.00
682	680	STEC (RIVERSIDE)	9101	199.0	0.00
683	new	UNIVERSITY	950	150.0	0.00
684	682	VICTORIA POWER PLANT	NET VIC	190.0	0.00
685	683	WASHINGTON STREET	NET LAR	520.0	0.00
686	new	ZACATE CREEK	2635	453.0	0.00
687	new	ZACATE CREEK	2665	442.0	0.00
688	new	ZACATE CREEK	2675	257.5	0.00
689	684	ZAPATA	8300	31.0	0.00

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

689

Add or Delete Rows as Necessary

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1	2	BRUNI	5440	31	1,980.8
2	45	NORTH EDINBURG	560	440	1,894.9
3	14	ALAZAN	620	220	1,504.4
4	46	BRUNI	1120	89	948.0
5	151	BRUNI	1100	685	890.6
6	5	TATTON	8490	129	793.8
7	219	NORTH EDINBURG	3570	465	771.1
8	54	ELSA	710	599	726.9
9	639	COMSTOCK	290	199	711.2
10	22	GREENLAKE	2750CN	886	692.8
11	52	FREER	1500	209	688.0
12	189	EAST HARRISON	3950	320	683.1
13	313	PALMVIEW	9685	772	672.6
14	10	GOVERNMENT WELLS	6800	237	671.4
15	32	NORTH ALAMO	4370	1,979	591.2
16	97	RAYMONDVILLE #2	3250	43	590.3
17	150	FOSTER FIELD	2550	117	567.9
18	433	NORTH PADRE ISLAND	7900	1,867	564.3
19	431	GOODWIN	3530	1,435	548.6
20	134	LULING - LCRA	10CN	229	543.4
21	300	MOORE FIELD	3110	948	526.1
22	6	LIVE OAK	1080	467	524.6
23	9	CLARKWOOD	7230	134	511.8
24	11	EDROY	6990	228	510.0
25	4	ALAZAN	2740CS	40	500.2
26	200	TAFT	1260	109	488.6
27	232	BIG WELLS	1570	497	483.0
28	15	SKIDMORE	380CS	253	476.1
29	1	RANDADO	8360	78	469.8
30	24	BRUNI	5160	196	460.3
31	508	TAFT	1180	1,154	451.9
32	76	GREENLAKE	2740CN	20	441.6
33	342	HARLINGEN S.S.	4230	1,607	439.3
34	434	ARANSAS PASS	590	148	430.7
35	123	WEAVER ROAD	1900	104	421.0
36	506	NORTH MCALLEN	2750	1,008	418.9
37	494	GOODWIN	4625	1,089	416.2
38	278	SKIDMORE	600	348	404.6
39	98	GOVERNMENT WELLS	7240	257	402.2
40	3	CONTINENTAL	4880	57	401.8
41	173	RIO RICO	8330	612	394.7
42	140	SOUTH PADRE ISLAND	4695	1,975	390.3
43	176	MOORE FIELD	3960	1,358	383.7
44	410	CRESTONIO	260	1,507	382.7
45	21	PHARR	1640	213	380.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
46	34	BANQUETTE	9000	129	380.0
47	118	LOS FRESNOS	3290	1,087	378.0
48	604	NORTH MERCEDES	3770	1,552	373.6
49	308	PALMVIEW	3930	961	361.1
50	355	LOYOLA	195	655	359.7
51	591	CONOCO-CHITTAM RANCH	8580	52	358.8
52	571	GANADO	5795	682	353.2
53	93	FREER	2900	316	348.1
54	473	SOUTHSIDE	7955	969	340.2
55	73	MAVERICK	9680W	603	326.2
56	78	STAFFORD HILL	1550	178	325.8
57	310	PLEASANTON	2080	1,357	325.4
58	237	LA PRYOR	570	94	320.8
59	370	LIVE OAK	1070	2,233	318.9
60	246	LAGUNA	9590	2,134	317.6
61	322	SOUTHSIDE	8025	616	317.5
62	26	CLARKWOOD	5525	465	316.4
63	346	ZAPATA	8290W	2,095	314.5
64	228	FULTON	9050	970	312.1
65	86	CABANISS	80	657	309.1
66	576	SOUTHSIDE	5335	938	307.3
67	161	PALMHURST	2820	2,271	305.8
68	202	RAYMONDVILLE #1	620	607	305.1
69	196	SOUTHSIDE	7995	1,468	302.8
70	213	PORT ARANSAS	3030CS	594	300.0
71	154	PALACIOS	6830	894	297.2
72	229	JOURDANTON	5695	1,071	297.0
73	364	MCCOLL ROAD	4400	843	296.5
74	91	CASA BLANCA	1300CS	584	296.2
75	171	CARRIZO SPRINGS	860	1,427	295.1
76	381	RIO GRANDE CITY	3230	1,043	293.6
77	19	ARMSTRONG	6050	48	292.7
78	272	RUNGE	7320	592	291.5
79	108	CONTINENTAL	4080	123	290.7
80	451	AIRLINE	9605	556	287.7
81	223	HARLINGEN	380	1,293	286.4
82	27	ELSA	3520	1,117	281.7
83	583	EL CAMPO	2800	1,369	281.7
84	446	SAN DIEGO	1980	643	279.8
85	412	BAY CITY	6450	1,061	279.0
86	101	NORTH ALAMO	3580	316	277.5
87	144	PALMHURST	3890	1,121	275.0
88	259	WESLACO UNIT	8610	2,365	273.7
89	354	FULTON	2020CS	1,514	271.1
90	417	EL CAMPO	6370	994	268.7
91	484	ASPHALT MINES	500	24	266.3
92	195	FREER	6320	178	262.6
93	7	SANTA ROSA	4040	883	262.0
94	485	EL CAMPO	7710	1,120	261.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
95	490	CAMPWOOD	3430	398	261.3
96	493	LA GRULLA	4120	1,759	261.1
97	409	WESLACO UNIT	7630	2,014	258.0
98	177	PHARR	1625	548	258.0
99	58	PORT ISABEL S.S.	3820	468	257.6
100	438	SAN DIEGO	2880	1,423	256.8
101	391	ARCADIA	1400	553	254.9
102	529	HAMILTON ROAD	9665W	335	254.6
103	75	GREGORY	5920	506	254.4
104	38	MATHIS	340CS	1,491	254.0
105	514	ARANSAS PASS	8270	445	253.6
106	289	PORTLAND	9290	1,187	253.2
107	77	HARLINGEN S.S.	320	552	252.7
108	218	SOUTH EAST EDINBURG	4550	1,830	251.8
109	532	POINT COMFORT	6060	403	251.4
110	191	KENEDY	1970	181	248.9
111	511	DEVINE	7100	641	247.7
112	513	ARCADIA	1440	1,717	247.6
113	383	ARCADIA	6930	1,935	246.5
114	645	BANDERA ELECTRIC (LEAKEY)	L30	388	245.3
115	560	TAFT	5230	915	243.9
116	147	LIVE OAK	1090CS	179	241.2
117	474	MARKHAM	5550	84	241.2
118	48	SHARYLAND	2020	2,849	239.3
119	256	HIGHWAY 9	6770	1,589	236.4
120	379	RANDADO	8350	93	235.6
121	23	SAN YGNACIO	16060	276	235.2
122	396	FULTON	440	1,565	234.9
123	119	NORTH MERCEDES	3840	766	233.3
124	277	WESMER	4050	1,656	233.3
125	115	BIG WELLS	2630	243	232.6
126	501	DARST	800	242	232.4
127	155	ELSA	690	966	231.8
128	247	PALMHURST	2525	2,269	231.8
129	92	EDROY	6980	350	231.8
130	423	SOUTH MCALLEN	3790	2,038	231.0
131	328	HIGHWAY 9	6720	1,393	230.1
132	520	WEIL TRACT (138/12KV)	1990	993	229.4
133	585	ROCKSPRINGS	8040	312	226.4
134	90	MATHIS	2870	990	226.2
135	8	RAYMONDVILLE #2	3170	578	224.1
136	284	ALICE	2530	891	223.5
137	110	HAINE DRIVE	9690	1,088	222.4
138	525	BAY CITY	6670	1,826	219.0
139	402	PLEASANTON	9505	1,300	217.3
140	597	SUNCHASE	1155	329	215.2
141	188	SOUTH MCALLEN	3935	1,166	214.5
142	157	BONNIEVIEW	8020	403	214.3
143	80	ELSA	700	855	212.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
144	40	RAYMONDVILLE #1	630	809	212.1
145	288	PLACEDO	7970	319	209.0
146	13	ROBSTOWN	1650	548	208.6
147	350	PREMONT	2730	222	208.3
148	548	KENEDY S.S.	6750	495	207.2
149	220	GREENLAKE	2760	668	205.7
150	143	BROWNSVILLE	3050	1,315	204.7
151	230	EAGLE PASS CITY	2650	3,199	203.8
152	114	NORTH ALAMO	3610	1,242	203.5
153	384	LA PRYOR	2440	585	201.5
154	425	HAMILTON ROAD	9655	680	200.3
155	241	GREGORY	8560	429	199.5
156	281	VICTORIA POWER PLANT	8170	732	197.6
157	244	RACHAL	6595	713	197.3
158	505	COLUMBUS	6180	867	197.1
159	67	SOUTH PADRE ISLAND	6440	1,974	196.7
160	332	KLEBERG	8140	170	195.4
161	465	LAGUNA	9065	1,680	195.4
162	469	LYTLE	2850	655	195.2
163	28	NIXON	810	537	192.5
164	348	CLARKWOOD	9570	1,175	191.6
165	301	SAN BENITO	3920	2,145	191.4
166	518	CASA BLANCA	5115	1,155	191.3
167	616	WESLACO UNIT	8195	2,228	191.1
168	156	SHARYLAND	2010	1,015	190.6
169	359	BAY CITY	1110CN	964	189.2
170	41	CASA BLANCA	55	353	188.7
171	255	BAY CITY	2700	1,361	187.6
172	538	NORTH VICTORIA	7440	2,209	186.3
173	29	GOVERNMENT WELLS	7250	337	185.8
174	106	PORT ARANSAS	6940	891	185.8
175	612	ARANSAS PASS	660CS	346	183.3
176	595	HEARN ROAD	8980	961	182.1
177	546	ARANSAS PASS	1250	297	181.4
178	209	MCKENZIE ROAD	330	1,708	181.4
179	472	RANGERVILLE	4060	474	180.9
180	269	PORT ARANSAS	990CS	559	180.5
181	443	PORTLAND	6505	1,736	179.8
182	403	BEEVILLE	1760	865	175.5
183	127	BAY CITY	2050	676	174.0
184	120	HEARN ROAD	9665	820	173.9
185	522	BLESSING	1030	145	173.2
186	371	MORRIS STREET	8715	1,645	173.1
187	599	DEL RIO CITY	9790	2,976	169.8
188	418	FALFURRIAS	5210	998	169.2
189	187	MCKENZIE ROAD	140	115	167.6
190	257	PETTUS	1020	333	165.5
191	349	STADIUM	8540	1,777	164.5
192	283	SHARYLAND	2035	1,576	164.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
193	558	LAREDO HEIGHTS	6820	1,040	164.3
194	542	RODD FIELD	205	585	164.1
195	392	WADSWORTH	8630	583	162.9
196	440	INGLESIDE CITY	8050	1,337	162.0
197	82	PORT ARANSAS	1000	888	161.6
198	649	DARST	790	121	160.6
199	627	NORTH VICTORIA	7770	989	160.3
200	393	HEARN ROAD	8990	1,031	159.3
201	552	NORTH VICTORIA	7860	1,373	158.3
202	652	COLUMBUS	9060	541	157.8
203	315	PHARAOH	5175	1,047	157.2
204	594	ROBSTOWN	7120	119	156.2
205	59	ALICE	2540	1,034	156.1
206	545	CABANISS	75	970	153.8
207	56	GREGORY	5900	98	153.2
208	258	ODEM	375	727	152.7
209	436	HAINE DRIVE	270	740	151.7
210	290	PORTLAND	9270	1,738	150.1
211	71	SANTO NINO	80	520	149.9
212	227	SOUTH MCALLEN	3640	1,170	149.7
213	312	BLESSING	8790	634	149.5
214	516	GARCENO	2135	1,580	148.6
215	148	SOUTH EAST EDINBURG	5045	454	148.5
216	66	RAYMONDVILLE #2	1280	1,521	147.9
217	182	NORDHEIM	470	242	147.8
218	287	CAVAZOS	3550	1,977	147.5
219	99	WEST MCALLEN	4515	695	147.3
220	314	MATTHEWS	1740	39	146.0
221	368	ROMA	3070	1,656	145.1
222	527	HARLINGEN	360	1,727	144.8
223	517	WEST HARLINGEN	3800	2,391	143.2
224	670	PHARAOH	1365	470	142.9
225	145	PALACIOS	8550	100	141.8
226	339	CHARLOTTE	8120	151	139.3
227	102	INGLESIDE CITY	8060	1,069	139.2
228	192	KINGSVILLE	1130	1,667	138.3
229	677	NORMANNA CST	840	10	138.0
230	197	CARRIZO SPRINGS	370W	289	137.9
231	336	SINTON	360CS	274	137.0
232	263	ELSA	3500	1,134	137.0
233	380	WEST MCALLEN	4815	840	136.9
234	358	RIO BRAVO	5	1,040	136.9
235	250	ARCADIA	1360	1,958	135.3
236	587	SOUTH EAST EDINBURG	6580	1,921	135.2
237	559	SABINAL	200	416	134.7
238	162	BROWNSVILLE	4290	767	134.6
239	160	GOODWIN	4390	855	134.3
240	265	PLEASANTON	9475	1,716	133.6
241	33	REFUGIO	5120	124	133.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
242	303	CARANCAHUA	5870CN	274	133.1
243	578	EDNA	5765	1,135	132.9
244	496	KLEBERG	1560	903	132.5
245	216	PLEASANTON	120	1,222	132.0
246	592	RAYMONDVILLE #2	4160	917	132.0
247	388	HARLINGEN	660	1,607	131.0
248	422	ARCADIA	1460	2,465	130.8
249	341	WEST OSO	9085	309	130.5
250	72	NORTH MCALLEN	5055	1,704	129.9
251	125	EAGLE LAKE	9455	541	129.9
252	31	TATTON	8200	1,498	129.7
253	320	EAST HARRISON	4360	1,350	129.6
254	36	SANTO NINO	70	1,560	129.3
255	62	DEL RIO CITY	420	1,981	129.2
256	399	MUSTANG ISLAND	8510CS	47	129.2
257	596	LEARY LANE	6005	827	129.1
258	374	CAUSEWAY	4765	1,170	129.1
259	572	RIO RICO	5050	1,755	128.1
260	628	DEVINE	7090	678	128.0
261	458	FULTON	6070	1,901	126.4
262	83	WEAVER ROAD	1910	261	126.4
263	636	WEST MCALLEN	4965	754	125.1
264	526	SEAWALL	9325	1,498	123.8
265	95	PLACEDO	7980	403	122.5
266	421	WASHINGTON STREET	6355	832	122.1
267	69	LA PRYOR	580	159	121.9
268	657	EAGLE PASS CITY	450	1,833	121.6
269	168	FALFURRIAS	2830	1,398	121.1
270	323	RODD FIELD	2190	2,593	121.0
271	146	SOUTH MCALLEN	3850	1,026	120.9
272	536	EDNA	5785	476	120.6
273	362	YORKTOWN	8420	908	119.4
274	573	NAVAL BASE	1380CS	1,911	118.7
275	331	VICTORIA POWER PLANT	1390	1,337	118.3
276	426	DILLEY	510	458	116.1
277	398	PALMHURST	1300	1,551	116.0
278	18	INGLESIDE CITY	6040	1,069	115.7
279	44	ARCADIA	8570	1,425	115.5
280	329	KNIPPA	6535	15	115.5
281	347	CLARKWOOD	7610	224	113.3
282	509	NORTH VICTORIA	6390	1,116	112.7
283	389	ROCKPORT	5950	430	111.6
284	637	PREMONT	2720	965	111.0
285	273	LOYOLA	120	691	110.8
286	344	LEARY LANE	7530	1,778	110.7
287	174	WEST MCALLEN	4535	1,925	110.5
288	295	ARANSAS PASS	9130	297	110.4
289	351	WESLACO UNIT	5970	2,247	110.3
290	279	MORRIS STREET	8840	657	109.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
291	149	LOS FRESNOS	3280	1,673	108.2
292	535	BROOKHOLLOW	8950	763	107.9
293	199	LOS FRESNOS	3200	1,460	107.0
294	624	STADIUM	6950	604	106.1
295	319	SOUTH EAST EDINBURG	4015	1,385	105.9
296	498	MORRIS STREET	8820	1,212	103.6
297	582	BLESSING	8780	75	102.8
298	126	SOUTHSIDE	8045	1,025	102.7
299	113	LULING - LCRA	20	267	102.0
300	386	RIO GRANDE CITY	3220	1,407	100.8
301	179	MINES ROAD	3680	728	100.3
302	252	EAST HARRISON	3080	1,136	100.1
303	390	ANNA STREET	850	1,519	99.4
304	373	ENCINAL	2160	650	99.4
305	556	SOUTH MISSION	5215	1,060	98.4
306	669	WASHINGTON STREET	2470	624	98.0
307	603	KLEBERG	9395	1,096	97.7
308	614	LAREDO HEIGHTS	2450	2,080	97.5
309	540	CRYSTAL CITY	140W	1,696	97.4
310	415	MCCOLL ROAD	4790	1,486	97.2
311	212	PORT LAVACA	8310	273	96.8
312	602	FREER	5200	1,295	96.7
313	333	SOUTH MISSION	3620	3,218	96.2
314	530	SAN DIEGO	2890	990	96.1
315	276	SINTON	180	1,139	96.1
316	35	CRESTONIO	270W	623	96.0
317	233	COTULLA	90	617	95.6
318	487	SOUTH MISSION	3590	2,441	93.1
319	65	LA GRULLA	5005	1,389	91.0
320	330	LA GRULLA	5110	1,479	90.8
321	208	HIDALGO	3680	946	90.6
322	588	MAGRUDER	6700	1,886	90.5
323	444	LEARY LANE	1540	1,503	90.4
324	107	SANTA ROSA	420	1,546	90.2
325	79	MALONE	7560	227	90.1
326	206	PHARR	1620	1,725	90.0
327	563	SANTO NINO	515	1,560	89.7
328	429	BERCLAIR	990C	241	89.1
329	57	RIO GRANDE CITY	3740	2,976	89.0
330	39	ZAPATA	7330	2,225	88.7
331	236	CRYSTAL CITY	330W	957	88.5
332	343	BUENA VISTA	9035	893	87.4
333	268	WESLACO UNIT	9805	1,865	87.3
334	112	HOLLY	1950	1,098	87.1
335	550	KLEBERG	280	1,384	87.0
336	507	LEARY LANE	1890	1,421	86.4
337	480	YORKTOWN	8380	822	86.0
338	285	HALL ACRES ROAD	5585	1,270	85.7
339	286	MCCOLL ROAD	2810	1,539	85.4

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
340	70	HALL ACRES ROAD	5465	2,731	85.2
341	280	NORTH MERCEDES	4860	1,553	85.2
342	650	EAST HARRISON	4620	1,367	85.0
343	662	NUECES BAY PLANT	350	782	85.0
344	243	LEARY LANE	1430	1,296	84.9
345	580	AIRLINE	8260	1,028	84.8
346	489	BISHOP	7180	995	84.3
347	109	PARKER	9260	69	84.3
348	497	ARANSAS PASS	8280	346	82.9
349	673	HAINE DRIVE	9700	495	82.7
350	629	NORTH MCALLEN	9660	1,419	82.5
351	37	PUEBLO	130	1,092	82.3
352	89	GOLIAD	6540	877	81.8
353	49	POLK AVENUE	4170	1,523	81.0
354	316	NIXON	2620	584	80.2
355	564	NAVAL BASE	8440	1,276	79.6
356	166	GANADO	5815	544	79.3
357	240	BAY CITY	5960	1,897	79.0
358	85	RANGERVILLE	3410	757	79.0
359	626	KENEDY S.S.	8340	695	78.7
360	481	HEARN ROAD	870	972	77.2
361	60	KARON HUMBLE PUMP	9895	40	77.0
362	153	PEARSALL	9905	187	76.0
363	663	MUSTANG ISLAND	9470	646	76.0
364	486	PHARAOH	1285	1,682	75.1
365	658	MCCOLL ROAD	4910	1,444	75.0
366	382	UVALDE	6620	1,560	74.3
367	665	BROOKHOLLOW	7190	587	74.3
368	61	MATHIS	1410	150	74.0
369	537	HIGHWAY 9	6730	376	73.7
370	549	RODD FIELD	3010	957	73.5
371	141	WOOLRIDGE	1170CS	527	72.5
372	43	PREMONT	6570	1,453	72.2
373	47	SANTA ROSA	3270	1,111	72.1
374	152	THREE RIVERS	8430	140	72.0
375	678	PARKER	9010	14	70.9
376	193	FALFURRIAS	1080W	436	70.7
377	309	AIRLINE	9030	325	70.3
378	163	RIO GRANDE CITY	3210	1,282	70.3
379	551	HALL ACRES ROAD	3670	1,043	69.8
380	248	REFUGIO	1210	229	69.6
381	569	HIGHWAY 9	6780	872	69.5
382	81	WEST OSO	9090	1,909	69.2
383	282	SHARYLAND	2150	856	69.1
384	172	NORTH VICTORIA	7430	519	68.7
385	376	MAGRUDER	7870	1,270	68.5
386	500	MAGRUDER	6680	639	68.0
387	361	EAGLE PASS CITY	2745	1,445	67.8
388	442	LAREDO HEIGHTS	2390	778	67.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
389	205	THREE RIVERS	2580	109	67.4
390	635	ARCADIA	5030	1,873	66.7
391	111	CHARLOTTE	2780	531	66.1
392	437	SINTON	1750	369	65.0
393	181	GREGORY	420	20	64.8
394	439	HALL ACRES ROAD	3460	2,493	64.7
395	482	HARLINGEN S.S.	4110	799	64.7
396	207	HARLINGEN S.S.	4090	1,077	64.3
397	294	GATEWAY	390	1,456	64.2
398	165	CAMPWOOD	2610	915	63.8
399	455	GARCENO	2130	1,326	63.6
400	566	ARCADIA	5020	1,844	63.6
401	589	EL CAMPO	5745	914	63.6
402	217	MORRIS STREET	2515	1,167	63.4
403	387	MILO	3065	364	63.3
404	640	SANTO NINO	645	1,560	62.4
405	42	DEVINE	8100	951	62.3
406	615	HOLLY	1370	2,254	62.1
407	270	EAST HARRISON	3190	1,186	61.3
408	222	LOS FRESNOS	930S	889	61.2
409	363	SOUTHSIDE	7925	1,183	60.7
410	456	NORTH MCALLEN	4995	1,369	60.5
411	335	MARKHAM	6440CN	455	60.5
412	242	PALMHURST	2535	723	60.5
413	414	SOUTHSIDE	7905	2,070	60.4
414	377	WEIL TRACT (138/12KV)	5405	144	59.3
415	128	NORTH PADRE ISLAND	5170	2,787	58.2
416	430	KLEBERG	6000	1,536	58.1
417	461	JOURDANTON	880	359	58.1
418	406	NORTH MCALLEN	2980	1,626	58.0
419	674	HIGHWAY 9	9830	105	57.9
420	450	LAREDO HEIGHTS	9400	1,040	57.4
421	88	SAN DIEGO	2930	594	56.5
422	17	PUEBLO	95	1,341	56.3
423	50	NUECES BAY PLANT	7825	397	55.9
424	337	MORRIS STREET	7465	675	55.7
425	198	ARCADIA	1450	2,522	55.6
426	293	KINGSVILLE	1670	398	54.4
427	214	MALONE	7550	218	54.3
428	435	O CONNER	390CN	119	53.5
429	201	SINTON	6860	1,306	53.3
430	226	ANNA STREET	2250	1,495	52.4
431	136	UNIVERSITY	920	1,700	52.4
432	467	SOUTHSIDE	8005	703	52.2
433	164	MINES ROAD	3745	1,821	52.2
434	579	JOURDANTON	5685	655	52.1
435	375	MORRIS STREET	7625	573	51.9
436	74	POLK AVENUE	4190	2,022	51.7
437	369	BAY CITY	7480	1,983	51.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
438	528	WESMER	4480	2,462	51.5
439	353	ALICE	1770	1,168	51.3
440	378	STADIUM	7490	1,336	51.1
441	408	ROMA	3060	1,738	51.0
442	64	PRAIRIE PUMP	1940	38	50.8
443	405	CABANISS	240	1,144	50.8
444	463	LAREDO HEIGHTS	6810	2,080	50.3
445	345	WASHINGTON STREET	6525	2,080	50.3
446	454	PHARAOH	1185	1,352	50.2
447	135	PORT ISABEL S.S.	3760	851	50.2
448	261	BROWNSVILLE	4280	1,111	50.0
449	357	WADSWORTH	7660	1,108	50.0
450	338	NORTH VICTORIA	1580	1,066	49.9
451	184	HIDALGO	3400	866	49.8
452	178	POLK AVENUE	4520	2,100	49.5
453	622	MAGRUDER	7690	898	49.2
454	306	AMISTAD DAM	5450	959	49.2
455	510	GOODWIN	4380	918	49.1
456	340	SAN BENITO	3910	2,448	49.0
457	121	GATEWAY	380	520	48.6
458	619	HIGHWAY 9	7210	1,058	47.8
459	661	EDNA	5775	832	47.1
460	499	WESLACO UNIT	7455	1,821	47.1
461	245	BEEVILLE	8510CN	969	46.9
462	623	MORRIS STREET	8830	1,572	46.5
463	260	EAGLE PASS CITY	2770	1,452	46.4
464	360	LAREDO PLANT	8565	874	46.1
465	519	STADIUM	7800	916	45.8
466	544	KINGSVILLE	1350	277	45.3
467	610	INGLESIDE CITY	7310	53	44.3
468	365	RIO RICO	8290	128	44.2
469	367	EAST HARRISON	3030	1,037	43.9
470	231	ASHERTON	2660	658	43.7
471	476	BISHOP	2690	771	43.6
472	87	CHARLOTTE	2790	177	43.6
473	129	UNIVERSITY	930	104	43.3
474	291	PALACIOS	6840	1,373	43.1
475	515	HOLLY	5820	1,123	41.6
476	167	WEST MCALLEN	4555	1,618	41.4
477	105	SOUTH MISSION	3980	3,929	41.3
478	638	SOUTH MISSION	4650	1,721	40.8
479	533	MATHIS	1420	804	40.4
480	452	BEEVILLE	300	1,232	40.0
481	305	SOUTHSIDE	8055	1,055	40.0
482	555	SOUTHSIDE	8035	1,135	39.8
483	117	MOORE FIELD	3120	417	39.8
484	523	UVALDE	550	385	39.6
485	584	ROCKPORT	5940	112	39.2
486	502	CARRIZO SPRINGS	910	1,648	39.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
487	568	MAGRUDER	6690	538	39.1
488	194	RODD FIELD	225	1,437	38.9
489	253	SAN BENITO	3860	158	38.9
490	new	PALMVIEW	9680	353	38.9
491	249	GATEWAY	350	1,560	38.8
492	449	CAVAZOS	3560	1,240	37.9
493	94	SAN BENITO	4945	2,156	37.8
494	299	PORT LAVACA	2480CN	933	37.0
495	225	POLK AVENUE	4600	2,137	36.8
496	432	SOUTH PADRE ISLAND	5850	1,974	36.6
497	238	ODEM	385	259	36.6
498	668	ARANSAS PASS	650	247	36.2
499	547	WEST HARLINGEN	3700	1,348	36.0
500	553	ROCKPORT	5930	1,001	36.0
501	395	BEEVILLE	8090	1,268	36.0
502	646	AIRLINE	8890	407	35.9
503	607	DEL RIO CITY	1930	1,170	35.4
504	20	CRYSTAL CITY	190	1,025	35.2
505	488	DEL MAR	490	1,326	35.2
506	468	HAINE DRIVE	8065	1,238	35.1
507	539	KINGSVILLE	1660	1,444	34.4
508	503	DEL RIO CITY	430	2,334	33.8
509	479	DILLEY	6400	1,009	33.5
510	235	NORTH MCALLEN	5060	1,818	33.3
511	124	NIXON	5990	519	33.1
512	new	SANTO NINO	695	50	33.0
513	25	PUEBLO	275	1,144	32.7
514	641	HALL ACRES ROAD	4895	1,642	32.2
515	394	MCKENZIE ROAD	150	12	32.2
516	447	SEAWALL	9420	1,001	32.0
517	654	CAUSEWAY	4775	1,029	31.9
518	630	WEST OSO	9095	2,551	31.7
519	574	HIDALGO	4845	466	31.7
520	53	RIO BRAVO	300	897	31.6
521	620	AIRLINE	9390	1,043	30.5
522	621	EAST HARRISON	4310	1,039	30.4
523	593	NORTH MCALLEN	3830	1,427	30.3
524	631	BANQUETTE	130	534	29.8
525	296	LAREDO PLANT	8505	1,040	29.2
526	175	PEARSALL	5580	1,983	29.1
527	543	KLEBERG	6410	366	29.0
528	186	STADIUM	7810	1,297	28.8
529	632	HOLLY	7740	2,783	28.6
530	521	WASHINGTON STREET	2350	1,560	28.4
531	130	GRETA	7890	301	28.3
532	586	EAGLE LAKE	310	820	28.1
533	457	ANNA STREET	780	432	28.1
534	51	POLK AVENUE	4900	1,557	27.9
535	448	WEST HARLINGEN	3720	1,696	27.9

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
536	575	FULTON	3070	1,782	27.8
537	210	LAREDO PLANT	9305	1,872	27.7
538	324	ANNA STREET	900	2,241	27.2
539	466	SEAWALL	9450	153	27.2
540	404	CRESTONIO	6660	976	27.1
541	68	NORTH WESLACO	4810	1,847	27.0
542	504	HIGHWAY 9	6760	817	26.7
543	477	MAGRUDER	245	1,028	26.5
544	459	LAREDO PLANT	8745	1,040	25.9
545	600	UVALDE	9770	1,664	25.9
546	16	COTULLA	110	1,399	25.8
547	470	GEORGE WEST	1320	587	25.8
548	385	POLK AVENUE	4610	2,158	25.7
549	462	REFUGIO	1040	560	25.7
550	170	WEIL TRACT (138/12KV)	2520	291	25.4
551	292	EAGLE PASS CITY	7060	1,521	25.0
552	491	ALICE	1790	435	24.7
553	667	POINT COMFORT	2460	327	24.3
554	267	NORTH EDINBURG	3810	238	24.3
555	372	SAN BENITO	4030	2,796	24.2
556	116	SUNCHASE	1150	329	23.7
557	180	THREE RIVERS	2010CN	745	23.4
558	613	THOMASTON	9580	52	22.9
559	139	PEARSALL	7050	1,388	22.4
560	326	SOUTH MISSION	3940	2,326	22.3
561	159	COFFEE PORT	1095	1,170	22.3
562	492	WOODSBORO	8330CS	1,084	21.9
563	264	RANGERVILLE	3420	665	21.9
564	12	FANNIN	7940	25	21.7
565	606	LEARY LANE	6175	1,160	21.7
566	321	ROCKSPRINGS	2600	363	20.8
567	298	PORT ISABEL S.S.	4070	524	20.5
568	251	PORT LAVACA	2490	818	20.2
569	524	COFFEE PORT	1090	1,595	20.1
570	158	NORTH EDINBURG	4240	638	19.9
571	475	ALICE	1780	1,049	19.9
572	307	HAMILTON ROAD	9645	316	19.8
573	642	MORRIS STREET	8850	446	19.5
574	203	COLUMBUS	930CN	935	19.1
575	352	BUENA VISTA	9385	1,677	19.0
576	420	FALFURRIAS	1070W	916	18.9
577	557	WASHINGTON STREET	7015	1,040	18.4
578	366	LAREDO PLANT	8695	457	18.1
579	133	RAYMONDVILLE #2	3240	1,292	18.0
580	416	NAVAL BASE	6330CS	259	17.5
581	625	SABINAL	485	496	17.5
582	419	SOUTH EAST EDINBURG	4570	1,636	17.1
583	304	AIRLINE	7280	626	17.0
584	453	BEEVILLE	2200	794	16.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
585	428	HOLLY	1480	2,295	16.8
586	554	WOOLRIDGE	1120CS	1,294	16.7
587	266	SAN BENITO	4135	1,801	16.5
588	221	POLK AVENUE	4180	2,917	16.3
589	185	SANTO NINO	75	1,872	16.2
590	302	MORRIS STREET	5655	1,095	16.0
591	204	GOLIAD	8220	1,046	15.6
592	570	THREE RIVERS	5190	685	15.6
593	239	CAUSEWAY	4795	1,591	15.6
594	262	AIRLINE	7390	1,394	15.4
595	183	GARWOOD CITY	2570	302	15.3
596	441	HALL ACRES ROAD	9595	611	15.2
597	531	THREE RIVERS	5100	40	15.0
598	142	NUECES BAY PLANT	345	52	15.0
599	541	NORTH WESLACO	4830	1,322	14.6
600	495	UVALDE	480	1,675	14.5
601	471	AIRLINE	6970	1,055	14.5
602	561	UVALDE	5060	1,664	14.4
603	311	BUENA VISTA	8965	917	13.8
604	401	PETTUS	8210	450	13.7
605	100	SANTA ROSA	3750	295	13.7
606	397	KENEDY	6270	988	13.6
607	598	BROOKHOLLOW	8960	821	13.1
608	211	HIGHWAY 9	7200	947	13.0
609	317	PHARAOH	5185	1,796	13.0
610	138	EAGLE LAKE	320CN	685	13.0
611	103	GARWOOD CITY	2560	202	12.9
612	411	LAREDO HEIGHTS	2100	2,028	12.7
613	605	CLARKWOOD	7220	700	12.7
614	648	WASHINGTON STREET	2360	728	12.6
615	659	HOLLY	9675	3,315	12.4
616	84	PHARR	1645	757	11.9
617	63	ZAPATA	2710	43	11.5
618	512	MILO	3060	1,760	11.4
619	567	UVALDE	540	832	11.4
620	131	BRACKETTVILLE	8460	1,189	11.3
621	169	KENEDY S.S.	8320	863	10.7
622	644	DEL RIO CITY	9850	798	10.3
623	132	ASHERTON	2670	158	10.3
624	660	DEL RIO CITY	440	1,686	10.0
625	590	NORTH VICTORIA	2240	806	10.0
626	618	HOLLY	7620	2,499	9.9
627	565	BROOKHOLLOW	7580	645	9.5
628	424	VICTORIA POWER PLANT	8070	439	9.5
629	407	AIRLINE	8370	363	9.5
630	675	MILO	3070LA	1,173	9.2
631	611	PORTLAND	9370	1,387	9.1
632	400	DEL MAR	10	3,000	8.7
633	334	AIRLINE	5870CS	791	8.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
634	325	WESMER	9705	1,242	8.5
635	275	RODD FIELD	1730	1,546	8.5
636	464	LOLITA	6330CN	29	8.3
637	318	WEST MCALLEN	4595	951	8.2
638	633	NORTH VICTORIA	1470	736	8.0
639	271	HARLINGEN	370	1,897	7.8
640	562	BEEVILLE	490CN	1,010	7.7
641	601	EL CAMPO	7260	578	7.6
642	190	POLK AVENUE	4740	1,364	7.2
643	483	VICTORIA POWER PLANT	7600	220	6.9
644	634	DEL MAR	7930	2,601	6.8
645	413	KNIPPA	6365	285	6.6
646	617	REFUGIO	1170CN	1,131	6.4
647	643	ANNA STREET	5780	706	6.4
648	445	WEST MCALLEN	4505	2,006	6.1
649	608	KINGSVILLE	1140	969	6.0
650	274	DEL MAR	3440	2,601	5.8
651	656	HOLLY	1220	3,250	5.3
652	460	EL CAMPO	2860	395	5.3
653	577	HEARN ROAD	2220	1,588	5.3
654	215	WEST HARLINGEN	4870	2,073	5.3
655	96	GEORGE WEST	730	714	5.1
656	254	PORT LAVACA	6850	783	4.9
657	478	RAYMONDVILLE #1	3130	96	4.7
658	356	WEST MCALLEN	6385	1,540	4.5
659	651	EAST HARRISON	3000	1,250	4.4
660	534	WOOLRIDGE	1110CS	1,191	4.3
661	297	DEL MAR	220	486	4.1
662	327	WESMER	6900	1,492	4.0
663	666	SOUTHSIDE	5345	428	2.4
664	676	MORRIS STREET	NET CC	426	2.4
665	609	MCCOLL ROAD	4780	1,805	2.2
666	653	LAREDO HEIGHTS	9080	1,040	2.0
667	55	BANQUETTE	740	173	2.0
668	224	JOURDANTON	250	676	1.8
669	427	CHASE FIELD	460	12	1.6
670	655	KENEDY	1960	224	1.3
671	647	AIRLINE	7270	975	1.2
672	664	EAGLE PASS CITY	2510	693	0.6
673	581	LAREDO PLANT	8705	884	0.5
674	234	NORTH MCALLEN	9640	1,715	0.4
675	137	HAINE DRIVE	9240	1,372	0.2
676	671	BEEVILLE	2380	940	0.2
677	122	AIRLINE	2180	12	0.0
678	672	AIRLINE	2210	282	0.0
679	104	RACHAL	8145	10	0.0
680	679	SOUTHSIDE	7935	43	0.0
681	680	STEC (RIVERSIDE)	9101	199	0.0
682	680	STEC (RIVERSIDE)	9101	199	0.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
683	new	UNIVERSITY	950	150	0.0
684	682	VICTORIA POWER PLANT	NET VIC	190	0.0
685	683	WASHINGTON STREET	NET LAR	520	0.0
686	new	ZACATE CREEK	2635	453	0.0
687	new	ZACATE CREEK	2665	442	0.0
688	new	ZACATE CREEK	2675	258	0.0
689	684	ZAPATA	8300	31	0.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

FORCED INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2004 Reporting Year

Causes of Forced Interruptions	Percentage
Animals and Birds	8.45%
Other	4.34%
People (Including cars and farm equip)	2.31%
Unknown	6.11%
Utility-owned Equipment	40.91%
Vegetation	11.08%
Weather (Including Lightning)	26.80%