

Control Number: 30613



Item Number: 13

Addendum StartPage: 0





Southwestern Electric Power Company 400 West 15th Street, Suite 650 Austin, TX 78701 aen.com

February 16, 2005

Mr. Larry Reed Electric Division, Commission Staff Public Utility Commission of Texas 1701 N. Congress Austin, TX 78711

Dear Mr. Reed,

Attached please find the Reliability and Continuity of Service Report for the reporting year 2004 for Southwestern Electric Power Company (SWEPCO) for its Texas system. This report is filed in accordance with Substantive Rule Section 25.81, Project 30613. It was working on exceptions to the PFD in Docket No. 25157 that relates to the service quality reports for SWEPCO yesterday and failed to get the attached filed before the end of the day. I apologize for the filing being a day late.

Sincerely,

Randal E. Roper

Regulatory Case Manager, AEP Texas Regulatory Services

Attachment

§25.52. -- Reliability and Continuity of Service.

http://www.puc.state.tx.us/rules/subrules/electric/25.52/25.52.doc

Application. This section applies to all electric utilities as defined by the Public Utility Regulatory Act (PURA) §31.002(6) and all transmission and distribution utilities as defined by PURA §31.002(19). The term "utility" as used in this section shall mean an electric utility and a transmission and distribution utility.

Public Utility Regulatory Act §31.002

http://www.puc.state.tx.us/rules/statutes/index.cfm DEFINITIONS.

The term "Electric utility" does not include a municipally owned utility or an electric cooperative.

Information typed in highlighted cells will appear on following sheets.

Type Name of Utility in the Cell Below

Utility:

AEP Southwestern Electric Power

Type Total Number of Distribution Feeders in the Cell Below

Feeders:

252

Due:

February 15, 2004

File:

Five Printed Copies and

One Electronic Copy of This Excel File

Project:

30613

Address:

Attn: Filing Clerk

Public Utility Commission of Texas

P.O. Box 13326

Austin, Texas 78711-3326

If you have any questions, please contact:

Larry Reed

Electric Division Commission Staff

Voice:

512 936 7357

Fax:

512 936 7428

E-mail:

mailto:larry.reed@puc.state.tx.us

Service Quality Report

To The

Public Utility Commission of Texas

In Accordance With

Substantive Rule §25.81

2004 Reporting Year

AEP Southwestern Electric Power

Project 30613

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2004	1.41	0.05	90.0	90.0	0.14	0.14	0.20	90.0	0.14	0.15	0.12	0.13	0.18
Scheduled													
2004	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00
Outside Causes													
2004	0.09	00.00	0.00	0.00	0.00	0.04	0.01	0.01	0.00	0.00	0.00	0.01	0.02
Major Events			:										
2004	0.47	0.00	00.0	00.00	00.00	00.00	0.47	0.00	00.00	0.00	00.00	0.00	00.00
With Storms Without Storms	1.51						-						

System SAIDI	Annual	Jan	Feb	March	April	Мау	June	July	Aug	Sept	Oct	Nov	Dec
Forced							-						
2004	129.3	4.5	2.7	4.7	10.9	17.1	19.3	3.6	10.1	13.3	9.5	18.2	15.6
Scheduled											!		:
2004	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0
Outside Causes													
2004	11.2	0.0	0.0	0.4	0.1	1.0	4.9	2.1	0.0	0.1	0.0	1.5	1.3
Major Events	,												
2004	287.3	0.0	0.0	0.0	0.0	0.2	287.1	0.0	0.0	0.1	0.0	0.0	0.0
With Storms Without Storms	140.7 428.0									-			

Distribution Feeder Indices for <u>Forced Interruptions</u> List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

252

Add or Delete Rows as Necessary

2004 SAIFI	2003 SAIFI		Feeder	Number of	2004 SAIFI
Ranking	Ranking	Substation Identification	Identification	1	Value
1		TURNERTOWN	1B10	33	8.45
2		TEXARKANA PLANT	6570	84	7.38
3	228	HOWELL	2B60	1,042	6.48
4	143	SPRINGHILL	8190	607	5.55
5	83	39TH STREET	1V70	70	5.04
6	57	HARRISON ROAD	11880	3,136	4.73
7		SABINE	5130	1,184	4.58
8		LONDON	5940	297	4.55
9	3	LEVERETTS CHAPEL	5700	125	4.51
10		LAKE LAMOND	4070	1,791	4.32
11		POYNTER	7590	913	4.24
12		HARRISON ROAD	11870	305	3.97
13		MT PLEASANT	5360	1,118	3.83
14		FRIARS SWITCH	1900	163	3.83
15		FRIARS SWITCH	5790	345	3.73
16		12TH STREET	2230	103	3.69
17		LONDON	5950	268	3.69
18		EVENSIDE	1G00	787	3.55
19		GILMER	2450	793	3.46
20		CENTER	2190	979	3.40
21		GRAND SALINE	7120	859	3.35
22		GRAND SALINE	7110	1,432	3.24
23		HAWKINS	2530	85	3.14
24		NORTH MARSHALL	7600	565	3.07
25		PLILER ROAD	10370	2,446	3.01
. 26		POYNTER	7800	142	2.96
27		MT PLEASANT	5370	343	2.94
28		GREGGTON	1F50	251	2.84
29		KILGORE	3090	342	2.78
30		SUGAR HILL	2370	259	2.76
31		HAWKINS	2520	360	2.76
32		LOUISIANA PACIFIC	8030	193	2.73
33		LEVERETTS CHAPEL	10850	303	2.72
34		WASKOM	7900	283	
35		CLARKSVILLE	9210	1,025	2.64
36		KILGORE	7850	99	2.60
37		CENTER	9520	867	2.60
38		MARSHALL	2000	228	2.57
39		NORTH LANEVILLE	10660	410	2.57
40		WASKOM	7890	483	2.53
41		LAKE LAMOND	8570	726	2.49
42		NAPLES	8730	871	2.44
43	202	PILGRIMS PRIDE	6150	831	2.42

	2003 SAIFI	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
Ranking	Ranking				
44		SPRINGHILL	6870	736	2.42
45		DAINGERFIELD	1960	899	2.39 2.38
46		CENTER	8140	913 480	2.36
47		SPRINGHILL	8200		
48		GREGGTON	2A90	513	2.34
49		LONGVIEW	5520	1,156 641	2.33
50		BIG SANDY	7300	678	2.31
51		CLARKSVILLE	9200	141	2.29
52		FRIARS SWITCH	5780	27	2.20
53		SABINE	5120	1	
54		HOOKS	10950	495 525	2.19
55		LOUISIANA PACIFIC	2260		2.10
56		MT VERNON	9140	349	2.10
57		NEW GLADEWATER	11980	1,006	2.09
58		POYNTER	7680	869	2.08 2.07
59		GILMER	2490	1,529	2.07
60		SUGAR HILL	2690	1,459 19	2.03
61		TURNERTOWN	1B00	572	1.99
62		ATLANTA	2150 1780	519	1.99
63		SOUTHEAST LONGVIEW		329	1.96
64		CLARKSVILLE	3660		1.96
65		AIRLINE	1N30	1,489 1,547	1.94
66 67		KINGS HWY HALLSVILLE	9040 5720	1,077	1.88
68		ATLANTA	8070	270	1.86
69		IPC JEFFERSON	8020	882	1.83
70		TURNERTOWN	1B20	348	1.81
70		KILGORE	7860	331	1.80
71		MINEOLA	3680	355	1.74
73		RICHMOND ROAD	6980	977	1.67
74		BIG SANDY	7310	583	1.63
75		CARTHAGE	10240	823	1.61
76		PLILER ROAD	10380	2,894	1.60
77		LONGVIEW HEIGHTS	8430	721	1.56
78		WESTWOOD	3710	44	1.55
78		TAYLOR STREET	7920	396	1.53
		\$ 	8720	208	1.53
80 81		NAPLES	9410	206	1.53
		HAWKINS	1S80	1,005	
82		TEXARKANA OPERATIONS		659	
83		ATLANTA WASKOM	1U80 8180	905	
84 85			5290	1,197	1.50
		RICHMOND ROAD WHITNEY	1480	1,197	1.49
86			4460		1.49
87		ATLANTA		1,057	
88		DAINGERFIELD	1970	666	
89		MARSHALL	4630	495	\$
90		LONDON	5930		
91		NEW BOSTON	5140	1,331	1.4

2004 SAIFI	2003 SAIFI		Feeder	Number of	2004 SAIFI
Ranking	Ranking	Substation Identification	Identification	Customers	Value
92	135	SOUTHEAST MARSHALL	7580	923	1.38
93	176	TATUM	10840	629	1.37
94	216	WINNSBORO	1P00	762	1.37
95	124	SCOTTSVILLE	1J30	412	1.36
96	13	DAINGERFIELD	1950	146	1.36
97	47	PETTY	11460	812	1.33
98	147	KINGS HWY	9030	933	1.33
99	227	TAYLOR STREET	220	1,052	1.32
100		NORTH MARSHALL	9800	1,297	1.32
101	140	HOWELL	2B90	242	1.31
102		HAWKINS	6310	109	1.30
103		MT PLEASANT	5190	609	1.29
104		MT PLEASANT	1920	860	1.28
105		KILGORE	3150	586	1.28
106		PLILER ROAD	12470	1,257	1.27
107		GILMER	2480	596	1.26
108		TEXARKANA OPERATIONS	7240	1,458	1.26
109		SOUTHEAST MARSHALL	10160	1,579	1.19
110		JEFFERSON 69KV	9340	944	1.19
111		LONGVIEW	5530	120	1.18
112		FRIARS SWITCH	5920	203	1.18
113		NEW BOSTON	1620	915	1.18
114		NEW BOSTON	9610	862	1.18
115		GATES STREET	1X70	286	1.17
116		LAKE LAMOND	6850	531	1.17
117		NORTH MARSHALL	8670	811	1.17
118		AIRLINE	1F10	369	1.16
119		NORTH MARSHALL	8660	527	1.16
120		HUGHES SPRINGS	5650	546	1.14
121		NAPLES	3290	511	1.13
122		ATLANTA	2140	1,732	1.13
123		SABINE	5110	72	1.13
124		MINEOLA	9360	512	1.11
124		HOOKS	10960	1,277	1.11
125		ALBA	12400	536	1.10
120		KILGORE	7880	1,006	1.09
127		MT PLEASANT	1930	240	1.03
129		MARSHALL	590	432	1.05
			1G90	78	1.04
130		WEST MT PLEASANT	2180	13	1.04
131		CENTER	1E70	171	0.98
132		COOKVILLE			0.98
133		WHITNEY	4420	489	
134		NORTH MINEOLA	5380	202	0.97
135		LONGVIEW	6770	999	0.97
136		LOGANSPORT	5770	358	0.94
137		POYNTER	9550	342	0.92
138		CARTHAGE	3370	677	0.91
139	132	NEW GLADEWATER	11970	1,527	0.89

2004 SAIFI	2003 SAIFI	Substation Identification	Feeder	Number of	2004 SAIFI
Ranking	Ranking	Substation identification	Identification	Customers	Value
140	175	GREGGTON	1V20	1,473	0.88
141	238	LONGVIEW HEIGHTS	8440	32	0.88
142	99	HALLSVILLE	2380	596	0.87
143	247	KNOX LEE	1U90	146	0.86
144	110	EVENSIDE	1F90	1,095	0.84
145	158	KINGS HWY	9540	1,283	0.83
146	56	NEW HOPE	2120	98	0.83
147	6	RICHMOND ROAD	1L40	648	0.80
148	146	SCOTTSVILLE	1J10	628	0.80
149	177	POYNTER	3270	696	0.78
150	171	SOUTHEAST MARSHALL	10170	1,555	0.77
151	- 88	39TH STREET	2640	556	0.74
152	new	RODESSA	2700	820	0.70
153	4	LONE STAR POWER PLANT	6120	20	0.70
154	84	BECKVILLE	9120	269	0.70
155	125	HOWELL	2B80	1,303	0.69
156	35	CLARKSVILLE	9190	938	0.68
157	206	TENAHA	2510	298	0.67
158	242	WINNSBORO	2040	402	0.67
159		LINDEN	10020	333	0.66
160	166	BECKVILLE	1U50	330	0.65
161	185	CARTHAGE	3350	509	0.65
162	91	HARRISON ROAD	8040	47	0.64
163		AIRLINE	1S30	131	0.63
164		TEXARKANA PLANT	7960	1,525	0.61
165		MINEOLA	7130	1,221	0.60
166		TEXARKANA PLANT	7980	232	0.59
167		DEKALB	3200	342	0.58
168		LIBERTY CITY	7990	742	0.57
169		MARSHALL	580	868	0.56
170		KILGORE	7190	659	0.55
171		NEW HOPE	8000	1,216	0.54
172		WHITNEY	4080	874	0.50
173		CARTHAGE	3360	339	0.50
174		39TH STREET	2630	1,317	0.49
175		DEKALB	2440	546	0.49
176		LAKE LAMOND	4400	662	0.48
177		IPC 69KV	1R60	36	0.47
178		39TH STREET	2610	113	0.47
179	THE RESERVE OF THE PERSON OF T	TAYLOR STREET	9510	1,064	0.47
180		CARTHAGE	5760	797	0.46
181	174	PETTY	11470	1,035	0.45
182	73	SOUTHEAST MARSHALL	10180	1,298	0.43
183	67	TENAHA	2500	380	0.42
184	144	PITTSBURG	5450	992	0.42
185	180	CLARKSVILLE	9180	387	0.42
186	51	TEXARKANA PLANT	6710	1,568	0.42
187	137	DEKALB	2430	865	0.42

2004 SAIFI	2003 SAIFI		Feeder	Number of	2004 SAIFI
Ranking	Ranking	Substation Identification	Identification	Customers	Value
188		GATES STREET	1X40	739	0.41
189		LAKE LAMOND	1380	1,742	0.40
190		WHITNEY	1A00	628	0.40
191		KILGORE	7870	352	0.38
192		WINFIELD	4100	102	0.38
193		KILGORE	4650	516	0.38
194		TAYLOR STREET	4290	946	0.38
195		MONROE CORNERS	6510	48	0.38
196		GREGGTON	1F70	1,684	0.37
197		TAYLOR STREET	6760	1,152	0.36
198		NEW BOSTON	9620	364	0.36
199		TAYLOR STREET	5080	536	0.36
200		TEXARKANA OPERATIONS	7830	891	0.34
201		AIRLINE	1E90	1,159	0.33
202	122	MINEOLA	10990	1,053	0.33
203	214	PITTSBURG	8680	257	0.32
204	40	MT VERNON	12760	859	0.31
205	19	WHITNEY	1490	1,596	0.30
206	20	TEXARKANA OPERATIONS	11630	549	0.29
207		LONGVIEW HEIGHTS	1B40	1,010	0.29
208	93	EVENSIDE	1G10	1,047	0.28
209	189	LAKE LAMOND	9430	527	0.28
210	219	BLOOMBURG	7350	334	0.27
211	86	39TH STREET	1V60	951	0.26
212	182	LONGVIEW HEIGHTS	9240	805	0.26
213	150	RICHMOND ROAD	4020	777	0.26
214	230	AIRLINE	1F00	1,170	0.25
215	14	LEVERETTS CHAPEL	5200	432	0.25
216	236	TEXARKANA OPERATIONS	1S90	500	0.22
217	184	WHITNEY	4090	337	0.22
218	148	SOUTHEAST MARSHALL	10920	718	0.22
219	59	COOKVILLE	1E60	115	0.22
220		PITTSBURG	5460	1,312	0.21
221	71	LINDEN	2540	967	0.20
222	220	LONGVIEW HEIGHTS	9000	509	0.19
223	164	GREGGTON	1F60	83	0.18
224	23	WINFIELD	2B70	500	0.17
225	197	LAKE LAMOND	9770	260	0.17
226	97	WINNSBORO	2050	1,026	0.17
227	234	RICHMOND ROAD	8050	1,051	0.17
228	79	LAKE LAMOND	6860	35	0.14
229	210	PETTY	8370	90	0.13
230	28	CLARKSVILLE	3670	425	0.12
231	209	LONGVIEW	5510	858	0.12
232	52	LONGVIEW	5550	123	0.12
233		HUGHES SPRINGS	1Z00	738	0.12
234		LAKE LAMOND	9440	361	0.12
235	226	MARSHALL UPTOWN	3210	226	0.11

2004 SAIFI Ranking	2003 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIFI Value
236	186	MT VERNON	9130	367	0.10
237	237	BALDWIN	2200	11	0.09
238	90	JEFFERSON 69KV	9350	124	0.09
239	136	WEST MT PLEASANT	1L00	421	0.08
240	new	SUPERIOR	3750	32	0.06
241	170	MONROE CORNERS	6520	152	0.05
242	new	VIVIAN	8990	734	0.04
243	192	PLEASANT HILL	11894	23	0.04
244	217	WEST MT PLEASANT	1G70	95	0.04
245	116	LONGVIEW	5540	105	0.03
246	246	SOUTHEAST LONGVIEW	4190	51	0.02
247	107	GATES STREET	1X60	314	0.02
248	new	VIVIAN	8980	620	0.02
249	240	MARSHALL UPTOWN	3220	98	0.01
250	232	TEXARKANA PLANT	7970	1,669	0.00
251	new	12TH STREET	6180	31	0.00
252	new	NETTLETON	6130	208	0.00

Distribution Feeder Indices for Forced Interruptions
List all Distribution Feeders on Texas System
With 10 or More Customers

Total Number of Feeders

252

Add or Delete Rows as Necessary

2004 SAIDI	2003 SAIDI		Feeder	Number of	2004 SAIDI
Ranking	Ranking	Substation Identification	Identification	Customers	Value
1	218	HOWELL	2B60	1,042	1,448.8
2	16	TURNERTOWN	1B10	33	901.2
3	56	KILGORE	3090	342	653.3
4	135	POYNTER	7800	142	638.5
5	80	SPRINGHILL	8190	607	534.3
6	52	WESTWOOD	3710	44	494.5
7	64	HARRISON ROAD	11880	3,136	488.7
8		SABINE	5120	27	481.0
9		12TH STREET	2230	103	468.8
10		FRIARS SWITCH	1900	163	455.9
11		TEXARKANA PLANT	6570	84	435.5
12		LONDON	5940	297	424.1
13		LEVERETTS CHAPEL	10850	303	413.7
14		GILMER	2450	793	407.3
15		HARRISON ROAD	11870	305	407.0
16		PLILER ROAD	12470	1,257	377.5
17		HOOKS	10950	495	373.7
18		LONDON	5950	268	370.3
19		CENTER	8140	913	368.6
20		BIG SANDY	7300	641	351.7
21		POYNTER	7680	869	350.6
22		KILGORE	7850	99	332.6
23		SABINE	5130	1,184	330.2
24		LAKE LAMOND	6850	531	322.0
25		LEVERETTS CHAPEL	5700	125	318.2
26		FRIARS SWITCH	5920	203	293.3
27		HAWKINS	2530	85	286.2
28		WASKOM	7890	483	284.6
29		MT PLEASANT	5360	1,118	272.4
30		GREGGTON	1F50	251	264.5
31		MINEOLA	9360	512	264.3
32		NORTH MINEOLA	5380	202	258.0
33		GRAND SALINE	7110	1,432	254.5
34		39TH STREET	1V70	70	
35		WASKOM	7900	283	253.1
36		LAKE LAMOND	4070	1,791	252.2
37		NORTH LANEVILLE	10660	410	248.0
38		TURNERTOWN	1B20	348	238.8
39		FRIARS SWITCH	5790	345	238.8
40		CLARKSVILLE	3660	329	237.6
41		LOGANSPORT	5770	358	230.0
42		SUGAR HILL	2370	259	229.3
43	21	MARSHALL	2000	228	223.5

2004 SAIDI	2003 SAIDI)	Feeder	Number of	2004 SAIDI
Ranking	Ranking	Substation Identification	Identification	Customers	Value
44		CLARKSVILLE	9200	678	219.7
45		PLILER ROAD	10370	2,446	215.6
46		CENTER	9520	867	215.0
47		BIG SANDY	7310	583	214.7
48		CENTER	2190	979	212.8
49		GRAND SALINE	7120	859	210.6
50		ATLANTA	2150	572	210.3
51		LOUISIANA PACIFIC	8030	193	206.6
52		RICHMOND ROAD	6980	977	205.1
53		MT PLEASANT	5370	343	203.0
54		NAPLES	8730	871	203.0
55		SUGAR HILL	2690	1,459	202.5
56		HAWKINS	2520	360	201.4
57		POYNTER	3270	696	200.0
58		LOUISIANA PACIFIC	2260	525	195.1
59		DAINGERFIELD	1950	146	191.9
60		GREGGTON	2A90	513	189.3
61		GILMER	2490	1,529	188.2
62		CENTER	2180	13	186.0
63		MT VERNON	9140	349	182.0
64		LAKE LAMOND	8570	726	180.0
65		LONGVIEW	5520	1,156	179.2
66		CLARKSVILLE	9210	1,025	174.7
67		SPRINGHILL	8200	480	174.0
68		PILGRIMS PRIDE	6150	831	171.7
69		DAINGERFIELD	1960	899	171.5
70		SPRINGHILL	6870	736	170.7
71		EVENSIDE	1G00	787	168.7
72		FRIARS SWITCH	5780	141	167.5
73		NEW GLADEWATER	11980	1,006	166.7
74		LONDON	5930	432	166.2
75		SOUTHEAST LONGVIEW	1780	519	166.0
76		LONGVIEW HEIGHTS	8430	721	164.3
77		HALLSVILLE	5720	1,077	160.3
78		PLILER ROAD	10380	2,894	157.0
79	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	LONE STAR POWER PLANT	6120	20	157.0
80		KINGS HWY	9030	933	156.3
81		KILGORE	7860	331	155.6
82		TAYLOR STREET	7920	396	154.5
83		NEW HOPE	2120	98	153.5
84		WINNSBORO	1P00	762	149.6
85		GILMER	2480	596	145.1
86		ALBA	12400	536	143.7
87		POYNTER	7590	913	143.3
88		CARTHAGE	10240	823	137.4
89		AIRLINE	1N30	1,489	135.7
90		ATLANTA	1U80	659	132.4
91		ATLANTA	8070	270	131.3

2004 SAIDI	2003 SAIDI	0.1.4.4	Feeder	Number of	2004 SAIDI
Ranking	Ranking	Substation Identification	Identification	1 t	Value
92		PETTY	11460	812	131.2
93		TURNERTOWN	1B00	19	126.1
94		MT PLEASANT	1920	860	122.3
95		COOKVILLE	1E60	115	122.2
96		RICHMOND ROAD	5290	1,197	121.0
97		KILGORE	7880	1,006	119.3
98		WEST MT PLEASANT	1G90	78	117.5
99		BECKVILLE	9120	269	114.3
100		TEXARKANA PLANT	7960	1,525	111.8
101		NAPLES	8720	208	110.6
102		NORTH MARSHALL	7600	565	108.6
103		NAPLES	3290	511	107.7
104		ATLANTA	4460	1,057	106.8
105		IPC JEFFERSON	8020	882	106.8
106		TATUM	10840	629	106.1
107		SCOTTSVILLE	1J10	628	103.8
108		NEW BOSTON	5140	1,331	102.8
109		MT PLEASANT	5190	609	102.4
110		ATLANTA	2140	1,732	101.7
111		MARSHALL	590	432	100.8
112		KINGS HWY	9040	1,547	97.8
113		WHITNEY	1480	1,651	97.5
114		GATES STREET	1X70	286	97.4
115		COOKVILLE	1E70	171	97.1
116		WHITNEY	4080	874	93.6
- 117		AIRLINE	1F10	369	90.8
118	98	39TH STREET	2640	556	90.4
119		SOUTHEAST MARSHALL	10160	1,579	86.6
120	160	HOOKS	10960	1,277	86.5
121	201	MINEOLA	3680	355	83.9
122		TENAHA	2510	298	83.4
123		KINGS HWY	9540	1,283	82.3
124		LINDEN	10020	333	81.3
125		NEW GLADEWATER	11970	1,527	
126		DAINGERFIELD	1970	666	80.7
127		SUPERIOR	3750	32	80.1
128		RODESSA	2700	820	80.1
129		MT PLEASANT	1930	240	78.2
130		LONGVIEW	6770	999	75.8
131		AIRLINE	1S30	131	74.9
132		HAWKINS	6310	109	74.4
133		NEW BOSTON	9610	862	73.2
134		SCOTTSVILLE	1J30	412	72.8
135		LIBERTY CITY	7990	742	72.6
136		POYNTER	9550	342	72.1
137		EVENSIDE	1F90	1,095	70.5
138		NORTH MARSHALL	9800	1,297	70.1
139		KILGORE	3150	586	69.4

2004 SAIDI	2003 SAIDI		Feeder	Number of	2004 SAIDI
Ranking	Ranking	Substation Identification	Identification	1 1	Value
140		GREGGTON	1V20	1,473	68.2
141		SABINE	5110	72	67.9
142		TAYLOR STREET	220	1,052	67.7
143		CARTHAGE	3370	677	66.5
144		BECKVILLE	1U50	330	65.7
145		MARSHALL	4630	495	64.4
146	10	NEW HOPE	8000	1,216	63.4
147		LONGVIEW	5530	120	63.0
148	8	RICHMOND ROAD	1L40	648	62.7
149		HOWELL	2B80	1,303	62.0
150	170	TEXARKANA OPERATIONS	7830	891	61.6
151		TEXARKANA OPERATIONS	1S80	1,005	61.4
152	171	DEKALB	2440	546	61.3
153	173	SOUTHEAST MARSHALL	10170	1,555	59.4
154	15	JEFFERSON 69KV	9340	944	58.2
155	224	HAWKINS	9410	206	58.2
156	119	HALLSVILLE	2380	596	57.9
157	137	DEKALB	3200	342	57.4
158	34	CLARKSVILLE	9190	938	57.2
159	243	WASKOM	8180	905	55.4
160	141	HUGHES SPRINGS	5650	546	55.1
161	165	SOUTHEAST MARSHALL	7580	923	54.4
162	247	KNOX LEE	1U90	146	52.2
163	106	MARSHALL	580	868	52.1
164		LAKE LAMOND	4400	662	51.4
165	51	MT VERNON	12760	859	51.0
166		GREGGTON	1F60	83	50.7
167		PITTSBURG	5450	992	50.4
168		NEW BOSTON	1620	915	50.4
169		WHITNEY	1490	1,596	49.0
170		CARTHAGE	3350	509	48.0
171		TEXARKANA PLANT	7980	232	46.3
172		GATES STREET	1X40	739	44.3
173		PITTSBURG	8680	257	44.1
174		WHITNEY	4420	489	43.0
175		IPC 69KV	1R60	36	42.8
176		TENAHA	2500	380	41.5
177		PETTY	11470	1,035	40.6
178	229	WINNSBORO	2040	402	40.3
179	143	KILGORE	7190	659	40.0
180		MONROE CORNERS	6510	48	39.6
181		HARRISON ROAD	8040	47	38.2
182		LAKE LAMOND	1380	1,742	37.6
183		TEXARKANA OPERATIONS	7240	1,458	37.1
184		EVENSIDE	1G10	1,047	37.0
185		NEW BOSTON	9620	364	37.0
186		MINEOLA	7130	1,221	36.2
187	107	CARTHAGE	3360	339	34.4

2004 SAIDI	2003 SAIDI		Feeder	Number of	2004 SAIDI
Ranking	Ranking	Substation Identification	Identification	Customers	Value
188	66	GREGGTON	1F70	1,684	34.0
189		LONGVIEW HEIGHTS	9240	805	32.6
190	127	DEKALB	2430	865	32.4
191	53	KILGORE	7870	352	32.0
192	211	WHITNEY	1A00	628	31.6
193	219	CLARKSVILLE	9180	387	31.4
194	108	SOUTHEAST MARSHALL	10180	1,298	31.1
195	57	WINFIELD	4100	102	31.1
196	11	LEVERETTS CHAPEL	5200	432	30.8
197	205	TAYLOR STREET	5080	536	30.2
198	157	NORTH MARSHALL	8670	811	29.9
199	166	AIRLINE	1E90	1,159	29.5
200	222	LONGVIEW HEIGHTS	9000	509	29.4
201		KILGORE	4650	516	29.4
202	117	NORTH MARSHALL	8660	527	26.9
203	152	HOWELL	2B90	242	26.5
204	215	CARTHAGE	5760	797	25.8
205		LINDEN	2540	967	25.4
206	99	39TH STREET	2630	1,317	25.3
207	226	AIRLINE	1F00	1,170	25.0
208	81	TAYLOR STREET	9510	1,064	24.4
209	118	39TH STREET	1V60	951	24.2
210		WINFIELD	2B70	500	24.0
211		LAKE LAMOND	9770	260	22.6
212		RICHMOND ROAD	8050	1,051	22.5
213		TEXARKANA PLANT	6710	1,568	22.1
214		TEXARKANA OPERATIONS	11630	549	21.7
215		LAKE LAMOND	6860	35	19.7
216		BLOOMBURG	7350	334	19.7
217		TAYLOR STREET	4290	946	19.6
218		MINEOLA	10990	1,053	19.1
219		LONGVIEW HEIGHTS	1B40	1,010	18.4
220		39TH STREET	2610	113	17.8
221		WHITNEY	4090	337	17.4
222		MT VERNON	9130	367	17.3
223		LAKE LAMOND	9430	527	16.5
224	167	RICHMOND ROAD	4020	777	14.8
225		TAYLOR STREET	6760	1,152	14.6
226		LONGVIEW	5550	123	14.2
227		JEFFERSON 69KV	9350	124	13.9
228		LONGVIEW	5510	858	13.5
229		TEXARKANA OPERATIONS	1S90	500	13.4
230		CLARKSVILLE	3670	425	13.0
231		PITTSBURG	5460	1,312	12.1
232		MONROE CORNERS	6520	152	11.6
233		SOUTHEAST MARSHALL	10920	718	10.7
234		WINNSBORO	2050	1,026	10.5
235	71	LAKE LAMOND	9440	361	10.5

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
236	144	WEST MT PLEASANT	1L00	421	10.3
237	193	MARSHALL UPTOWN	3210	226	9.3
238	103	PLEASANT HILL	11894	23	6.4
239		BALDWIN	2200	11	5.8
240	244	LONGVIEW HEIGHTS	8440	32	5.3
241	100	HUGHES SPRINGS	1Z00	738	5.2
242	new	VIVIAN	8990	734	4.2
243	236	PETTY	8370	90	3.3
244	136	LONGVIEW	5540	105	2.5
245	234	WEST MT PLEASANT	1G70	95	2.2
246	new	VIVIAN	8980	620	1.0
247	140	GATES STREET	1X60	314	0.7
248	246	SOUTHEAST LONGVIEW	4190	51	0.5
249	240	MARSHALL UPTOWN	3220	98	0.4
250	228	TEXARKANA PLANT	7970	1,669	0.2
251	new	12TH STREET	6180	31	0.0
252	new	NETTLETON	6130	208	0.0

AEP Southwestern Electric Power

FORCED INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2004 Reporting Year

Causes of Forced Interruptions	Percentage	
Animals and Birds	19.73%	
Other	2.13%	
People (Including cars and farm equip)	3.08%	
Unknown	0.86%	
Utility-owned Equipment	9.78%	
Vegetation	36.77%	
Weather (Including Lightning)	27.66%	