

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1772	1740	EMMA	4011	63	25.75
1773	2325	DNIWS	1603	1323	25.72
1774	1670	ROWLT	1107	1181	25.71
1775	1528	SWDTN	1641	1575	25.71
1776	2570	BRKTN	1202	114	25.71
1777	433	WWDWY	2020	1194	25.68
1778	673	LIGSW	1607	1347	25.68
1779	2234	CNTRD	0004	994	25.65
1780	1823	JSHUA	1301	919	25.64
1781	1783	MESQW	1806	1640	25.62
1782	1513	DESPR	1406	909	25.61
1783	N/A	MSLSW	0005	718	25.53
1784	1895	SGOVL	1401	2424	25.53
1785	1444	EZACH	0001	944	25.42
1786	898	ELKTN	2508	1095	25.33
1787	2511	RCHHL	0394	91	25.33
1788	1155	CRSWS	1403	1762	25.30
1789	727	SYCRK	4512	1165	25.29
1790	1400	BONHM	1202	884	25.07
1791	2019	LORAN	9711	389	25.01
1792	862	ADISN	1608	460	24.98
1793	2515	FRMBR	1802	1009	24.91
1794	1908	SSPSW	1604	1285	24.86
1795	2432	KLELM	2201	1973	24.71
1796	2198	AIRPK	8411	736	24.68
1797	770	WALST	0013	321	24.67
1798	1006	LUFKN	1205	1280	24.59
1799	1419	CRLTN	1403	125	24.59
1800	748	SPRDL	4841	906	24.56
1801	1457	CRNRD	0004	463	24.49
1802	2	MKNNY	1253	60	24.48
1803	1653	CNTRD	0003	1217	24.46
1804	2509	BBTWN	1501	2352	24.36
1805	965	TYWST	2004	976	24.34
1806	1128	BLKST	1711	1255	24.34
1807	1470	MTLDA	0004	741	24.31
1808	1983	MDLNW	1511	2426	24.30
1809	1988	MESFR	2105	1033	24.22
1810	2424	PPARK	1802	626	24.21
1811	682	BKBNT	1821	1226	24.18
1812	2292	BMTWN	1621	1273	24.18
1813	N/A	KLELM	2204	2541	24.17
1814	1421	IRVNG	1406	1276	24.14
1815	808	ELGIN	1003	1286	24.07
1816	2023	RCHHL	0384	672	24.00
1817	2530	JKSNR	4107	22	23.91
1818	686	MAYFD	5521	2212	23.91
1819	1595	HORNE	1913	1565	23.87

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1820	877	DESHR	1204	541	23.85
1821	2340	NSTAR	2011	575	23.81
1822	2393	TMNTH	1604	55	23.78
1823	2119	RSNHT	1142	522	23.78
1824	2229	HNYGR	0402	471	23.77
1825	1046	BRLSN	2031	1062	23.70
1826	1481	CRNRD	0007	746	23.64
1827	399	HORNE	1981	1581	23.62
1828	1788	MDLNW	1563	1250	23.59
1829	1348	PFFRD	3472	1280	23.57
1830	450	PRCTR	1602	222	23.57
1831	2602	FRMNT	0001	1406	23.46
1832	236	MRTSP	1504	731	23.40
1833	1930	WHTRK	0008	1258	23.39
1834	434	MESQT	1303	1857	23.37
1835	161	BLSRA	1601	1125	23.36
1836	1940	COPEL	3051	2358	23.32
1837	910	PRFTW	4221	2140	23.31
1838	372	CRSGL	1302	1663	23.30
1839	278	CHICG	1402	543	23.30
1840	630	VENSW	2601	732	23.30
1841	1948	CLBNR	1404	1175	23.29
1842	1843	RDRSE	2604	2402	23.29
1843	1237	SGOVL	1402	715	23.13
1844	2322	MTLDA	0005	1521	23.11
1845	1053	ATHNW	1401	891	23.08
1846	2169	WTAUG	4633	975	23.07
1847	1732	CRSCN	1202	645	23.02
1848	1555	TMPNW	1104	1765	22.98
1849	2122	DLEON	0131	711	22.93
1850	2614	BRHLW	7641	24	22.92
1851	268	BLTLN	0004	669	22.91
1852	1873	KNEDL	6311	1846	22.90
1853	1819	RSNHT	1122	1750	22.89
1854	2097	ROWLT	1106	1294	22.83
1855	1744	HHSTH	1501	2238	22.80
1856	982	MSTLT	1063	927	22.74
1857	566	RTHGB	1421	1267	22.66
1858	1648	RSPCK	2106	482	22.64
1859	1829	PRKRW	3382	170	22.64
1860	2399	MESQW	1808	1465	22.64
1861	998	WEBB	8611	2574	22.58
1862	1210	PLANO	1103	1534	22.55
1863	N/A	CRNTH	2406	1268	22.53
1864	1654	SHRSW	6641	878	22.51
1865	2025	BRNWD	1206	1921	22.44
1866	N/A	PKRVL	1052	2220	22.43
1867	57	PMBRK	1821	69	22.39

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1868	1293	FSTVW	0006	1665	22.39
1869	1588	DUBLN	2214	723	22.39
1870	2191	PRKRW	3372	955	22.35
1871	66	EULSO	9112	1054	22.34
1872	408	FARON	4031	833	22.10
1873	993	ATHNS	1201	809	22.05
1874	2184	LIPAN	1301	469	22.03
1875	596	CURIE	7241	68	22.03
1876	594	MRLNS	4002	540	21.99
1877	622	CRLJL	1504	1218	21.93
1878	973	DALRK	1354	2279	21.75
1879	736	LKBRN	2401	1572	21.75
1880	499	MKNGB	5321	397	21.73
1881	2036	HHSTH	1503	248	21.73
1882	1384	TRLWD	7721	2199	21.66
1883	2104	ADISN	1601	252	21.66
1884	1620	PRKRW	3311	866	21.61
1885	418	SMPST	0001	1795	21.59
1886	2569	CRLTN	1404	274	21.54
1887	2252	PCUST	2003	1024	21.49
1888	2417	DGNST	0001	70	21.47
1889	1099	GLNHV	3953	1383	21.45
1890	2093	CMPST	0004	1583	21.43
1891	1296	CHALK	0951	84	21.42
1892	2264	COMRC	1201	886	21.36
1893	1636	PALRD	2205	289	21.35
1894	2284	FSCRK	6713	2828	21.24
1895	2168	EDGCF	2272	1046	21.23
1896	2158	RNDRK	1506	3690	21.21
1897	979	PRCRK	0001	160	21.17
1898	1385	GRDPR	0862	907	21.14
1899	376	TRLSW	1204	584	21.10
1900	1749	DAVST	0004	1743	21.09
1901	1254	GODRD	8151	1437	21.04
1902	2421	RNDRK	1501	661	21.03
1903	655	VLYRN	2953	2546	21.02
1904	2464	ROWLT	1103	1028	20.99
1905	1929	SNYDR	1822	1574	20.96
1906	1558	RCHRD	1202	784	20.84
1907	1989	MDLNW	1552	2182	20.79
1908	2330	PPARK	1806	814	20.77
1909	777	HORNE	1992	205	20.72
1910	2194	FRMBG	1701	168	20.70
1911	318	MLKF2	1202	463	20.68
1912	1173	RCHHL	0374	1476	20.67
1913	333	WNTHW	1116	624	20.67
1914	1202	WSANG	2801	1315	20.61
1915	1811	FARON	4072	1841	20.58

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1916	1911	PALMR	2202	895	20.52
1917	1614	BRNWD	1203	1221	20.51
1918	1968	RRNE	2407	1172	20.45
1919	2064	MCDMT	2551	2903	20.45
1920	1863	IRVNR	1557	2222	20.45
1921	1376	EULSO	9111	1740	20.45
1922	1042	DNISN	1206	947	20.33
1923	754	TAYLR	1203	1794	20.23
1924	911	LKMNT	0003	451	20.16
1925	1939	MDTHS	1001	1025	20.16
1926	1304	REAST	1502	1255	20.16
1927	787	DAVST	0005	1299	20.11
1928	1487	LVBRD	0008	1598	20.01
1929	2294	PRNTH	1403	21	20.00
1930	2491	PRCRK	0003	1267	19.94
1931	1592	CDCSW	0003	652	19.77
1932	1455	BRIRV	6921	2244	19.70
1933	838	EZACH	0002	1402	19.66
1934	N/A	DENAV	0642	904	19.63
1935	2321	DAVIS	3733	440	19.55
1936	1306	TRPMN	4023	515	19.50
1937	504	LKHLN	0007	1217	19.49
1938	1019	BRCRK	6514	613	19.48
1939	1622	HURST	1831	1353	19.45
1940	1877	RRSTH	1706	2595	19.41
1941	1083	WTAUG	4652	788	19.40
1942	1681	HLTOM	2452	1667	19.36
1943	1649	SNYDR	1823	1271	19.33
1944	1931	TRLSW	2401	19	19.32
1945	1208	WMMMR	2703	1224	19.27
1946	497	BLMGR	1901	263	19.24
1947	1900	ANDNR	2222	71	19.24
1948	1239	HSKAV	0004	797	19.22
1949	2660	TYEST	1506	11	19.18
1950	229	LWSNR	2241	955	19.14
1951	1397	ARLNG	1271	1842	19.12
1952	1598	BSPRG	1903	1451	19.10
1953	1961	WRBND	2322	925	19.08
1954	2040	DUVAL	0441	994	19.07
1955	900	MURPH	2751	3493	19.06
1956	205	ENNIS	1904	1244	19.04
1957	2470	CTYVW	2211	1482	19.03
1958	2523	HSKAV	0003	1278	19.01
1959	1879	BRNSO	1808	958	19.01
1960	2293	LKWOD	7432	993	18.98
1961	2358	RNDRK	1508	2819	18.98
1962	1785	WHITE	3541	808	18.97
1963	1080	DFWSW	2204	26	18.92

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
1964	1241	NCNTH	1804	636	18.90
1965	1627	CNEXP	0002	796	18.90
1966	912	GSTHW	1623	1287	18.87
1967	133	EDDY	0425	229	18.85
1968	1745	GNSVE	1602	1547	18.81
1969	1073	SNYDR	1852	1270	18.81
1970	2135	PRKWY	1542	1504	18.78
1971	2507	SHSTH	1301	1499	18.78
1972	648	REAST	1503	594	18.77
1973	N/A	LKBLT	1001	816	18.70
1974	166	PRSTN	0008	679	18.66
1975	951	SSPNG	1204	931	18.59
1976	2253	PCUST	2010	2818	18.57
1977	1497	BLMED	1621	1473	18.54
1978	746	WWDWY	2022	990	18.53
1979	1619	PFLGV	2003	2389	18.49
1980	2106	GORMN	0421	354	18.42
1981	997	WEAST	0619	1522	18.40
1982	565	DESHR	1203	1324	18.40
1983	1137	MSHLN	0002	655	18.38
1984	2299	HMPHL	2792	425	18.33
1985	1221	DCVSO	1101	1226	18.30
1986	2396	PRKWY	1532	1782	18.28
1987	1129	CNTRY	2851	1538	18.24
1988	660	EZACH	0007	1548	18.21
1989	1549	ALVDO	1902	814	18.21
1990	1563	KFMSSO	1301	877	18.20
1991	1586	PCUST	2011	2240	18.07
1992	867	TYWST	2002	1364	18.06
1993	416	LWSNR	2211	1211	18.06
1994	1656	WDGWD	1552	314	18.03
1995	1009	PWEST	1307	940	17.99
1996	1717	OAKHL	3021	1904	17.97
1997	1691	WNRTH	1416	720	17.96
1998	481	DENAV	0621	1636	17.90
1999	1443	ROWLT	1102	758	17.85
2000	1774	MKNSW	1601	1081	17.83
2001	110	FRMBR	1853	55	17.82
2002	N/A	ZEPHR	2404	181	17.75
2003	2257	MDLNW	1532	1763	17.74
2004	150	OKCLS	0006	1081	17.73
2005	62	VAN	1501	818	17.71
2006	2555	MESQN	1508	1789	17.68
2007	1251	FARON	4011	602	17.67
2008	2376	PNTGO	7111	670	17.63
2009	1920	RWDHV	1901	926	17.61
2010	755	WRBND	2321	1639	17.56
2011	153	PCUST	2004	1101	17.48

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2012	1449	LKHL	0001	1336	17.47
2013	1462	GRLRD	0001	1612	17.42
2014	465	MESQT	1301	1270	17.39
2015	885	MDWCK	0001	765	17.37
2016	270	CMNCH	1401	1164	17.33
2017	2467	PRKWY	1552	452	17.28
2018	2161	WICKT	0411	96	17.24
2019	1944	PRSTN	0002	1298	17.23
2020	1916	BSPRG	1904	1476	17.18
2021	494	VGCRK	8011	1192	17.09
2022	948	IRVVV	2853	3617	17.05
2023	2408	ODESW	5211	1979	17.03
2024	1156	WCOLO	1320	653	17.00
2025	905	DAVIS	3741	1506	16.97
2026	972	NCRST	2203	1190	16.95
2027	2537	MSTLT	1042	332	16.89
2028	2006	IRVGS	1905	835	16.88
2029	2086	PRSTN	0005	1108	16.85
2030	1664	GODRD	8132	1456	16.84
2031	2218	CHROW	0007	83	16.77
2032	1512	WHITE	3532	936	16.74
2033	113	TRNTH	1503	1569	16.67
2034	2098	STAUG	0008	1733	16.65
2035	2108	HKHTS	1605	1251	16.59
2036	142	GDNL	1201	41	16.59
2037	1679	HORNE	1911	840	16.56
2038	2278	PRKRW	3362	1058	16.53
2039	1052	SSPNG	1202	1086	16.41
2040	1979	MESFR	2104	130	16.35
2041	2173	WBOSE	1103	809	16.35
2042	1938	SACRC	5521	162	16.31
2043	893	MTLDA	0001	2028	16.29
2044	544	MSHLN	0005	1272	16.28
2045	2338	BSPSW	0851	1106	16.27
2046	1747	ECTHP	4911	616	16.26
2047	1430	SMFLD	2322	1268	16.15
2048	2219	LVBRD	0002	347	16.08
2049	2195	PAYSW	1203	873	16.07
2050	170	DENAV	0652	39	16.03
2051	2096	RANGR	4311	853	16.02
2052	2300	LVBRD	0005	1320	15.99
2053	1108	JNKNS	0005	525	15.98
2054	1772	CRLJL	1505	805	15.93
2055	1966	PROAD	0001	125	15.84
2056	1728	BNDRA	0006	391	15.80
2057	1390	GSTHW	1622	31	15.74
2058	1837	BLMND	3241	213	15.71
2059	992	HRSMD	1955	1131	15.70

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2060	2367	IRVVV	2804	896	15.67
2061	771	BSPRG	1901	1590	15.60
2062	2237	MESTE	1206	1117	15.51
2063	2317	MDLNW	1582	1407	15.49
2064	842	WALNT	0004	1415	15.45
2065	2099	RCHHL	0342	975	15.36
2066	2009	FROKS	0007	733	15.30
2067	2645	MRSES	4014	21	15.29
2068	401	LKHLD	0006	730	15.24
2069	337	RDLML	2571	361	15.24
2070	1182	IRVGS	1903	789	15.21
2071	2617	CKRHL	0006	50	15.20
2072	1548	TRNTH	1502	529	15.10
2073	1693	MURPH	2753	2340	15.04
2074	1750	STERT	2701	28	15.00
2075	943	DAVST	0002	712	14.99
2076	390	CRLTN	1406	1218	14.97
2077	923	BSPSW	0812	784	14.93
2078	N/A	MSLSW	0004	380	14.93
2079	1007	GRMES	0512	1132	14.91
2080	2167	LKWOD	7442	771	14.83
2081	1329	TMPSE	1503	680	14.83
2082	2490	KLBRG	0001	1337	14.82
2083	2339	IRVVV	2801	1340	14.75
2084	1098	WWDWD	3621	1903	14.74
2085	1020	COLNY	2403	2149	14.69
2086	324	HKBRY	1115	331	14.68
2087	122	BDFRD	8841	810	14.65
2088	2177	SWDTN	1621	726	14.65
2089	696	PCOIT	1022	1584	14.64
2090	1971	DLEON	0111	873	14.60
2091	N/A	WFNTH	0262	258	14.58
2092	2372	BRCRK	6522	1915	14.56
2093	96	TYBLR	2803	759	14.47
2094	1591	PAYSW	1202	1604	14.40
2095	13	CHICC	1701	42	14.38
2096	2187	LUFKN	1207	648	14.38
2097	157	WTAUG	4643	984	14.37
2098	2374	ANDNR	2211	1438	14.32
2099	71	LOMAL	0008	1011	14.30
2100	2276	CHROW	0006	64	14.28
2101	961	SANSM	3921	2890	14.27
2102	2492	HMPHL	2713	67	14.27
2103	359	CRANE	0311	634	14.27
2104	1964	GRAHM	0721	1432	14.26
2105	2051	WTAUG	4631	1110	14.18
2106	2160	ALVDO	1901	1217	14.16
2107	1001	MSTLT	1032	63	14.16

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2108	301	MSHLN	0007	707	14.14
2109	725	ALLEN	2406	2629	14.13
2110	1912	WVWEST	1218	960	14.10
2111	2157	EULSO	9122	1101	14.09
2112	890	MDWCK	0003	1767	14.09
2113	2439	FARON	4062	1136	14.08
2114	2260	ODESA	0212	1977	14.08
2115	1776	TMSTH	1406	2017	14.06
2116	2224	PLSTH	1305	809	14.05
2117	2311	PNTGO	7122	1080	14.03
2118	2633	JNKNS	0003	16	14.00
2119	2052	KERNS	2402	399	13.98
2120	N/A	PJPTR	3211	82	13.93
2121	852	ABRRD	0001	750	13.87
2122	619	LOMAL	0011	1050	13.86
2123	2164	HMPHL	2733	101	13.85
2124	2528	HKBRY	1105	142	13.77
2125	2582	RRSTH	1707	133	13.74
2126	1651	DALRK	1303	1264	13.60
2127	2048	WNRTH	1419	317	13.59
2128	2363	DGNST	0003	261	13.58
2129	2231	MESTE	1213	1323	13.58
2130	1318	MDWCK	0005	1360	13.55
2131	2199	PFFRD	3431	580	13.51
2132	1448	PSHIL	1605	107	13.50
2133	2232	JEWET	1202	40	13.48
2134	1097	MNHNS	1911	1106	13.36
2135	1927	IRVND	1205	183	13.31
2136	2303	MCDMT	2554	1493	13.30
2137	1339	BDFWD	8922	1918	13.29
2138	794	MABNK	2401	1844	13.25
2139	1847	BKBNT	1842	249	13.15
2140	2011	PWEST	1312	1194	13.10
2141	1199	MESFR	2101	1124	13.07
2142	1743	NCSFA	1706	701	12.98
2143	2175	SCHRD	0007	1206	12.93
2144	949	LTV	5451	901	12.89
2145	1368	PALRD	2207	1110	12.83
2146	2454	BRYAN	0004	876	12.81
2147	2239	PAYSW	1205	718	12.80
2148	1189	PWEST	1306	18	12.78
2149	2210	SHAMP	0002	1490	12.74
2150	1946	ENTOH	0005	926	12.66
2151	1742	BONHM	1210	1095	12.65
2152	1956	DENDR	0004	1902	12.60
2153	2331	KLNTF	1805	1568	12.60
2154	2208	ARMST	0001	758	12.59
2155	2212	PPARK	1807	878	12.56

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2156	1479	SIKES	2411	1560	12.55
2157	2310	DESHR	1206	1882	12.53
2158	2061	EURKA	2501	19	12.53
2159	2136	PFFRD	3482	1087	12.47
2160	2133	ESTLD	3611	1569	12.41
2161	1885	DALWT	2982	1468	12.40
2162	850	BLKST	1742	1634	12.39
2163	1697	ROWLT	1105	1415	12.36
2164	795	BRYAN	0001	17	12.35
2165	2360	STNVL	1206	2026	12.35
2166	1767	ADMDS	6511	938	12.26
2167	467	WNRTH	1420	1155	12.26
2168	2371	CRNRD	0001	730	12.20
2169	380	NHNSW	0003	503	12.12
2170	633	GAVSW	0001	764	12.10
2171	1536	GODRD	8122	991	12.08
2172	500	DNCNV	1906	323	12.07
2173	2307	PFLGV	2002	1781	12.06
2174	2573	RSPCK	2131	43	12.00
2175	2486	CHROW	0004	182	11.99
2176	1433	GODRD	8142	795	11.98
2177	431	MNFLD	2611	2044	11.98
2178	1960	ROWLT	1101	672	11.95
2179	2042	MESQW	1804	1282	11.94
2180	916	FSTVW	0008	2255	11.88
2181	1270	PROAD	0003	942	11.79
2182	1607	HMPHL	2752	128	11.75
2183	1923	BRNAV	0784	2237	11.71
2184	2140	ARMST	0012	568	11.71
2185	919	SPRDL	4831	1203	11.70
2186	1262	WOVER	6131	2371	11.65
2187	1307	WATSN	5361	1429	11.61
2188	2265	CRLFR	2154	3429	11.58
2189	109	ALPHA	0013	407	11.58
2190	1822	RCHRD	1201	1324	11.57
2191	2306	SHMNE	1409	1158	11.56
2192	320	PRSTN	0003	2828	11.55
2193	1113	BAKKE	6911	99	11.55
2194	576	LMBLN	0005	671	11.51
2195	2623	DENDR	0009	59	11.51
2196	2005	MCHSN	1201	249	11.49
2197	2431	JNKNS	0008	1107	11.41
2198	2241	CRLTR	2007	1297	11.40
2199	406	CUMBY	1201	677	11.32
2200	959	CRLTR	2005	711	11.29
2201	2389	RSPCK	2132	100	11.26
2202	1814	TRNTY	7511	1484	11.23
2203	2448	INAIR	1421	13	11.23

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2204	2038	ROWLT	1104	1477	11.22
2205	1552	ARMST	0011	568	11.20
2206	1404	DGNST	0007	181	11.19
2207	921	HURST	1852	1388	11.17
2208	816	ALPHA	0016	1715	11.12
2209	650	STHRL	0007	353	11.10
2210	1967	VLYRN	2957	2516	11.08
2211	2113	IRVND	1208	185	11.06
2212	1175	SANSM	3911	731	11.06
2213	2434	DALLW	0002	123	11.00
2214	1486	MRSES	3019	21	11.00
2215	2107	DALRK	1302	862	11.00
2216	1977	TYSTH	1203	436	10.96
2217	1762	ALPHA	0002	1214	10.94
2218	1185	DESHR	1202	1585	10.87
2219	1082	STNVL	1205	687	10.85
2220	2547	EGFRD	0005	1608	10.82
2221	760	CDHCR	2050	563	10.81
2222	1379	GODRD	8141	843	10.81
2223	939	MDDTN	4312	1813	10.77
2224	N/A	PFLGV	2005	3599	10.77
2225	2524	GSTHW	1682	152	10.74
2226	2415	COMRC	1202	48	10.73
2227	2316	DCATR	1204	470	10.71
2228	2352	FRMNT	0007	98	10.67
2229	845	TYSTH	1209	819	10.64
2230	11	MAPLE	0005	1268	10.64
2231	960	VLYRN	2951	4802	10.64
2232	891	HMPHL	2711	429	10.63
2233	1731	RDRSE	2601	920	10.63
2234	813	CLBSN	8821	51	10.61
2235	822	CMPWI	0003	949	10.58
2236	1987	ALLEN	2402	2741	10.52
2237	1407	CNTRY	2833	3021	10.41
2238	1812	THRNE	0004	808	10.40
2239	1030	MDDTN	4321	894	10.39
2240	2127	WVWEST	1216	229	10.39
2241	2285	IRVNR	1506	1373	10.28
2242	2580	MAPLE	0006	400	10.25
2243	2648	REAST	1501	81	10.20
2244	1606	PLSTH	1303	459	10.14
2245	1395	MKNGB	5312	1774	10.13
2246	1445	TYEST	1509	339	10.13
2247	69	ARTHR	0441	1090	10.11
2248	2035	PSHIL	1601	1388	10.10
2249	2593	ENTOH	0006	1211	10.07
2250	2550	FARON	4021	284	9.99
2251	1232	PNTGO	7121	887	9.95

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2252	87	TYSTH	1202	639	9.94
2253	604	WMRLD	0002	1378	9.89
2254	1897	WMMMR	2702	1856	9.85
2255	1676	PWEST	1310	243	9.81
2256	216	PALRD	2208	1001	9.80
2257	620	MSHLN	0008	658	9.78
2258	292	WTAUG	4612	1004	9.75
2259	2564	MDWCK	0008	898	9.72
2260	2444	BLMED	1618	43	9.72
2261	2227	PPARK	1803	991	9.70
2262	33	CHROW	0003	56	9.70
2263	569	WSANG	2802	639	9.69
2264	2274	RGFTW	6822	29	9.69
2265	2495	SHNRW	1612	278	9.68
2266	2514	BAGWL	1202	46	9.61
2267	2112	WALST	0003	126	9.60
2268	2504	WFALS	0163	343	9.52
2269	2661	TYLER	1003	12	9.50
2270	N/A	WEBB	8623	2690	9.47
2271	1065	STNVL	1203	1387	9.44
2272	1844	WFALS	0143	188	9.42
2273	2394	GAVSW	0010	508	9.35
2274	N/A	GDPRW	9611	1143	9.31
2275	764	HSKAV	0005	1365	9.31
2276	1937	CURIE	7221	635	9.29
2277	1435	ODESA	0272	1782	9.24
2278	2438	RECCR	0003	235	9.22
2279	638	WELRD	0007	416	9.18
2280	783	GRMES	0521	490	9.17
2281	2534	RCLNS	1401	71	9.15
2282	1842	MKNSW	1603	1154	9.13
2283	1295	BRYAN	0005	2067	9.12
2284	1831	PCOIT	1004	679	9.06
2285	97	BRGPR	1101	561	9.04
2286	240	MESQT	1306	1409	8.97
2287	2150	WFNTH	0241	716	8.93
2288	899	WALST	0004	54	8.83
2289	1986	COMRC	1204	662	8.83
2290	1518	WALST	0005	223	8.78
2291	1227	HSKAV	0001	1031	8.74
2292	2137	MDLNW	1531	1170	8.73
2293	N/A	ODNTH	2034	2586	8.73
2294	2578	MCDMT	2552	1053	8.69
2295	1708	RCHHL	0344	2217	8.68
2296	1644	PCUST	2001	539	8.64
2297	1990	ARTHR	0481	1308	8.59
2298	2436	BSPSW	0832	398	8.57
2299	22	MURPH	2752	1946	8.51

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2300	1322	OKCLS	0001	680	8.49
2301	2380	ENTOH	0004	1429	8.45
2302	2383	WXNTH	2305	326	8.43
2303	2506	BLTLN	0006	912	8.42
2304	2228	NPKWY	0010	6467	8.40
2305	48	WLWSP	1201	479	8.37
2306	1659	FSTVW	0003	1348	8.37
2307	1519	COMRC	1203	670	8.33
2308	1500	PWEST	1308	617	8.26
2309	562	RGLRW	0004	74	8.24
2310	342	MNWLW	1401	1562	8.23
2311	1949	BRYAN	0002	349	8.22
2312	2044	RRSTH	1708	3826	8.22
2313	2466	VANAL	1201	544	8.20
2314	1568	EDGCF	2252	362	8.20
2315	917	FORSW	2051	246	8.20
2316	79	IRVNE	1304	448	8.19
2317	1109	ARMST	0002	530	8.18
2318	391	PLKST	0005	1386	8.18
2319	506	EZACH	0004	965	8.16
2320	1452	ARCTY	1321	886	8.10
2321	2589	MESTE	1205	1576	8.08
2322	N/A	PJPTR	3221	32	8.03
2323	1101	ARMST	0009	1022	8.01
2324	588	BLSRA	1602	147	7.99
2325	1360	DALWT	2911	286	7.99
2326	2397	CRLTR	2004	236	7.99
2327	1547	ARMST	0010	805	7.90
2328	2568	ODESA	0221	262	7.85
2329	9	BKWST	0006	43	7.84
2330	651	ARLNG	1291	82	7.80
2331	1287	IRVBL	2501	854	7.79
2332	1576	CLLVL	0004	45	7.78
2333	1833	DAVIS	3731	628	7.78
2334	2400	FINK	1802	674	7.76
2335	2549	ANDNR	2231	1482	7.75
2336	541	OKCLS	0007	496	7.73
2337	926	LKHLD	0003	1312	7.72
2338	1403	ABRRD	0003	317	7.69
2339	1437	WXOCF	1402	13	7.69
2340	1127	WFALS	0153	1187	7.67
2341	392	IRVNR	1555	3070	7.67
2342	2343	BKWST	0005	928	7.64
2343	1440	MESTE	1202	723	7.63
2344	1604	GLNHV	3931	1293	7.61
2345	2283	ADISN	1604	893	7.59
2346	2290	ALNTH	2854	2705	7.59
2347	314	PAYSW	1223	110	7.57

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2348	1164	CHROW	0005	157	7.52
2349	17	RDOAK	1302	2015	7.51
2350	2060	PCUST	2005	1722	7.51
2351	2028	WATSN	5352	1760	7.50
2352	1758	PFFRD	3492	707	7.47
2353	99	MDLNW	1573	822	7.47
2354	1405	CRLTR	2006	485	7.46
2355	2478	GVODS	3031	1328	7.46
2356	2030	HKHTS	1604	750	7.40
2357	1850	FSTVW	0004	2014	7.36
2358	55	WALST	0012	228	7.36
2359	N/A	MSLSW	0002	1000	7.35
2360	1698	SSPNG	1203	828	7.35
2361	2179	SHAMP	0006	1097	7.31
2362	846	ELKHR	1201	923	7.29
2363	2176	KLNTF	1802	1658	7.26
2364	1919	HURST	1811	1089	7.25
2365	1574	ACRLY	1711	153	7.25
2366	1575	IRVNE	1309	1172	7.24
2367	1892	PRKRW	3321	134	7.24
2368	1025	PCOIT	1007	680	7.20
2369	213	WFALS	0174	1333	7.20
2370	1114	WRBND	2311	1242	7.17
2371	2565	WMMMR	2704	281	7.13
2372	2433	STNVL	1207	952	7.05
2373	1298	CMTSW	0983	858	7.03
2374	1453	WTAUG	4621	414	7.00
2375	2008	LKBRN	2402	899	6.94
2376	751	ODESA	0231	1953	6.90
2377	2489	MDWPK	9211	1221	6.79
2378	2379	RANGR	4321	903	6.77
2379	2535	MDLNE	0151	253	6.68
2380	266	ARLNG	1212	127	6.63
2381	1391	WXNTH	2302	976	6.62
2382	935	WWEST	1217	93	6.57
2383	2447	CHROW	0001	117	6.55
2384	1973	WEAST	0626	247	6.52
2385	2249	STAUG	0002	1304	6.48
2386	2446	RWDHV	1908	1928	6.48
2387	2334	TRLSW	1202	56	6.45
2388	412	MTLDA	0002	1843	6.44
2389	2250	MDLNW	1521	2392	6.36
2390	2483	PCOIT	1003	1465	6.35
2391	1551	PLANO	1102	123	6.34
2392	1780	STHRL	0004	1197	6.30
2393	1476	SORCY	0001	1582	6.25
2394	2361	BRKNR	1221	196	6.21
2395	2256	LMBLN	0003	163	6.18

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2396	857	FRNKF	0006	2052	6.15
2397	1335	BRCRK	6523	857	6.14
2398	1118	MSTLT	1084	655	6.12
2399	2600	JNKNS	0001	160	6.11
2400	107	ALNTH	2852	2684	6.09
2401	2115	SMOUR	0721	28	6.07
2402	1247	WALST	0014	1012	6.06
2403	2356	ODNTH	2024	2564	6.04
2404	2313	HMPHL	2742	172	6.03
2405	2562	ENNIS	1905	37	6.03
2406	2141	BSPRW	2511	728	5.98
2407	749	RWDHV	1906	645	5.97
2408	N/A	KLNCC	1704	2116	5.96
2409	1550	BBTWN	1502	1538	5.93
2410	1040	TERSO	2503	1610	5.90
2411	2485	ELKTN	2503	691	5.90
2412	2414	ARLNG	1292	607	5.84
2413	1498	PRFTW	4222	1914	5.82
2414	1695	LMESA	1522	1339	5.78
2415	1980	MDLNE	0163	879	5.75
2416	250	CDCSW	0005	1192	5.67
2417	1422	PCOIT	1008	1305	5.66
2418	1211	GRLRD	0002	974	5.60
2419	2017	LKMNT	0004	1911	5.49
2420	2437	MESTE	1208	802	5.49
2421	2539	HORNE	1933	1625	5.46
2422	N/A	MSLSW	0001	1131	5.43
2423	537	MDLNE	0133	182	5.35
2424	1917	DAVST	0003	1602	5.33
2425	2409	GODRD	8161	1548	5.31
2426	762	LGVST	8522	350	5.27
2427	2668	WWEST	1223	11	5.27
2428	2556	WATSN	5372	1335	5.26
2429	2220	BSPSW	0841	2005	5.25
2430	1345	FORSN	5621	47	5.21
2431	1204	MESTE	1211	1327	5.20
2432	2213	ECTHM	3321	1968	5.20
2433	1914	FSTVW	0007	1428	5.17
2434	2341	CRNRD	0002	267	5.03
2435	N/A	ODNTH	2044	1937	5.00
2436	1081	HLTOM	2411	1273	4.85
2437	410	KRGRV	2401	15	4.80
2438	1858	WTAUG	4623	715	4.80
2439	2033	TMSTH	1405	311	4.79
2440	766	CNTRD	0001	1991	4.79
2441	1759	ALPHA	0008	1188	4.77
2442	538	BDFWD	8911	1033	4.76
2443	2382	FRNKF	0007	1140	4.76

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2444	2443	ANDNR	2242	1225	4.75
2445	1775	INAIR	1413	711	4.69
2446	798	NPKWY	0009	5779	4.62
2447	2471	WALST	0001	120	4.59
2448	2031	CDCSW	0007	910	4.58
2449	2251	RRSTH	1704	2473	4.57
2450	1769	PRKRW	3331	79	4.53
2451	2461	PCOIT	1025	2647	4.53
2452	721	CRLTN	1454	204	4.47
2453	2510	ARLNG	1261	1290	4.46
2454	1008	HLSBR	1203	986	4.45
2455	1997	PAYSW	1213	1391	4.43
2456	1872	CRLTR	2054	361	4.43
2457	2667	WWEST	1219	911	4.38
2458	2553	BRKRG	0211	301	4.37
2459	934	BSPRW	2552	753	4.31
2460	1556	GSTHW	1692	731	4.27
2461	621	BRNWD	1201	1397	4.26
2462	2386	REGST	0002	215	4.23
2463	N/A	LAVON	1455	933	4.20
2464	2452	WWEST	1222	142	4.15
2465	1722	MKNYY	1203	982	4.11
2466	1521	IRVVV	2851	2804	4.09
2467	1941	ALNSW	2652	5136	4.06
2468	1460	FRNKF	0008	1129	4.02
2469	1794	CLBWS	8111	1181	3.97
2470	491	MYPRL	1801	107	3.89
2471	2575	ADISN	1602	128	3.88
2472	1542	BNMAG	1201	170	3.88
2473	1859	AMLIA	0008	134	3.88
2474	1094	HLTOM	2461	546	3.86
2475	876	PALRD	2203	979	3.80
2476	1057	WOVER	6142	1373	3.77
2477	2159	TYSTH	1208	294	3.65
2478	2355	WTAUG	4642	1303	3.60
2479	2453	ODNTH	2053	2229	3.50
2480	2494	VLRYN	2952	1802	3.49
2481	570	WTAUG	4632	1174	3.47
2482	1100	PSHIL	1604	1012	3.46
2483	690	CRLTN	1408	124	3.43
2484	388	ROLTR	2911	3097	3.40
2485	896	RNKSW	5411	51	3.37
2486	2604	KLNTF	1803	1002	3.34
2487	2200	WATSN	5382	664	3.33
2488	740	GNSVN	1403	214	3.31
2489	2584	CKRHL	0003	454	3.30
2490	1951	STNVL	1202	758	3.25
2491	2612	BKWST	0002	1071	3.22

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2492	226	PCUST	2008	709	3.21
2493	1363	IRVNR	1552	53	3.19
2494	395	RSPVY	1702	530	3.14
2495	1134	SMFLD	2352	609	3.13
2496	2304	PLANO	1106	330	3.09
2497	2586	EULES	8732	597	3.08
2498	1603	WHTRK	0005	711	3.08
2499	2152	CRLTR	2052	1516	3.04
2500	1816	ADISN	1606	21	3.00
2501	2525	SHAMP	0001	1102	2.99
2502	2151	GVODS	3011	2239	2.95
2503	614	BDFWD	8932	1646	2.93
2504	N/A	PALRD	2204	686	2.91
2505	1022	ROANW	9521	1364	2.91
2506	2596	FRMNT	0004	1036	2.88
2507	2469	RECCR	0007	68	2.88
2508	2480	MNHNS	1921	1721	2.85
2509	289	IRVND	1203	394	2.81
2510	2465	CRLFR	2153	983	2.78
2511	2144	WRTHM	5004	221	2.77
2512	1853	VGCRK	8031	1736	2.76
2513	2346	PWEST	1305	19	2.74
2514	487	BEAST	4088	121	2.73
2515	2641	MCDMT	2532	1955	2.73
2516	1935	GVODS	3072	2165	2.63
2517	706	FSTVW	0001	348	2.56
2518	1597	NCSTH	1504	64	2.55
2519	2378	GRAHM	0713	302	2.54
2520	2435	ALLEN	2401	1781	2.50
2521	1234	PPARK	1804	237	2.49
2522	2595	FROKS	0004	833	2.47
2523	1539	WALST	0007	15	2.47
2524	2561	TRNTY	7551	362	2.46
2525	2426	BLTON	1804	1255	2.43
2526	2640	MCDMT	2531	2396	2.37
2527	2598	BNMNW	1102	192	2.37
2528	N/A	ODNTH	2073	397	2.35
2529	1330	MCDMT	2553	1573	2.32
2530	1625	RSPCK	2103	159	2.31
2531	2351	LMESA	1531	1228	2.18
2532	2541	SHMNE	1405	729	2.17
2533	1222	COPER	0402	168	2.16
2534	2442	EMPCT	0001	33	2.15
2535	1645	MSTLT	1054	175	2.14
2536	1456	GVODS	3062	1834	2.12
2537	2445	ALPHA	0007	1398	2.11
2538	2639	MAYFD	5511	222	2.07
2539	996	FRMBG	1704	35	2.03

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2540	2180	DALWT	2972	177	1.97
2541	1382	TMPSE	1501	537	1.94
2542	2522	ARMST	0005	1719	1.90
2543	2498	RGLRW	0002	48	1.85
2544	N/A	ATNRN	3411	3930	1.81
2545	1484	FSTVW	0002	144	1.80
2546	1709	WALNT	0002	1173	1.78
2547	2370	CRLUD	1302	141	1.77
2548	2401	SMFLD	2372	827	1.77
2549	2653	RSPCK	2142	480	1.76
2550	645	WMRLD	0003	450	1.72
2551	1056	BNMNW	1101	180	1.72
2552	1424	INAIR	1414	814	1.63
2553	2605	PROAD	0008	1180	1.62
2554	2295	COPER	0401	143	1.59
2555	2328	ABBOT	1902	110	1.54
2556	1078	CRNRD	0006	406	1.52
2557	2552	WRTHM	5017	168	1.52
2558	N/A	WTHRF	2002	1389	1.47
2559	790	WEAST	0627	104	1.38
2560	2601	ARMST	0004	345	1.34
2561	1312	BDFWD	8941	306	1.32
2562	1754	WEAST	0620	79	1.32
2563	2238	DNINR	1402	374	1.30
2564	2362	MESTE	1207	835	1.30
2565	1970	FROKS	0008	1458	1.28
2566	259	CNTRY	2862	382	1.24
2567	2126	ALPHA	0009	58	1.21
2568	2275	IRVVV	2803	151	1.19
2569	2153	RDLML	2591	1528	1.18
2570	2576	ARMST	0008	783	1.13
2571	1976	CKRHL	0002	415	1.12
2572	719	SHSTH	1305	390	1.09
2573	797	RGLRW	0003	88	1.08
2574	1526	DEALY	0002	478	1.06
2575	1807	HORNE	1923	1522	1.01
2576	1192	WFALS	0124	126	0.99
2577	2557	JUDCT	0004	91	0.99
2578	267	ARTHR	0431	441	0.99
2579	2029	LVBRD	0001	36	0.97
2580	2131	LWSNR	2231	549	0.95
2581	2473	PARIS	1205	33	0.94
2582	1342	HMPHL	2772	263	0.92
2583	343	MSHLN	0004	829	0.92
2584	788	LOMAL	0004	195	0.88
2585	2335	DALWT	2941	261	0.86
2586	2531	GSTHW	1613	484	0.86
2587	1454	GLNHV	3963	3024	0.83

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2588	2594	GSTHW	1651	250	0.80
2589	2109	DENAV	0673	71	0.80
2590	413	DGNST	0002	233	0.79
2591	1673	FRMBG	1708	46	0.78
2592	2366	DALWT	2992	331	0.78
2593	N/A	MSLSW	0003	207	0.66
2594	1291	PLANO	1105	75	0.65
2595	1729	IRVNR	1510	205	0.65
2596	2657	SSPNE	1402	67	0.63
2597	1034	FRMBG	1752	53	0.62
2598	2411	MDWCK	0006	906	0.61
2599	1217	FSTVW	0005	1676	0.58
2600	2270	DALWT	2921	246	0.58
2601	20	EMPCT	0005	65	0.57
2602	2215	FRMBG	1753	953	0.56
2603	444	HKBRY	1102	1341	0.56
2604	94	BLNKT	0701	264	0.50
2605	1684	SHAMP	0003	1232	0.49
2606	1866	BKWST	0007	1739	0.44
2607	2056	PLANO	1101	372	0.37
2608	2216	ALPHA	0010	490	0.35
2609	2542	LTV	5461	499	0.30
2610	1365	LVBRD	0004	1302	0.30
2611	2513	BLTLN	0001	637	0.30
2612	1936	JUDCT	0008	250	0.27
2613	2441	FRMBR	1806	119	0.24
2614	2518	KIMBL	5022	813	0.21
2615	2320	ABBOT	1901	105	0.21
2616	2521	BRYAN	0007	267	0.17
2617	2428	HKBRY	1113	404	0.16
2618	2422	DAVST	0001	668	0.12
2619	2597	GVODS	3041	1339	0.09
2620	534	GLNHV	3983	884	0.04
2621	N/A	MCWHT	3511	2869	0.04
2622	N/A	MCWHT	3512	1585	0.03
2623	2076	AIRPK	8431	22	0.00
2624	1903	ALLEN	2405	1781	0.00
2625	577	ALLNC	6411	54	0.00
2626	430	ALLNC	6422	20	0.00
2627	2609	ALPHA	0004	21	0.00
2628	2610	ALPHA	0005	137	0.00
2629	1477	AMLIA	0003	24	0.00
2630	2458	BKWST	0001	374	0.00
2631	436	BKWST	0004	1227	0.00
2632	2618	CLBNR	1401	20	0.00
2633	2619	CNEXP	0005	747	0.00
2634	N/A	CNI45	1201	546	0.00
2635	2503	COTRD	0003	26	0.00

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2636	2607	COTRD	0008	877	0.00
2637	2368	CRLTN	1452	22	0.00
2638	2621	CRLUD	1306	25	0.00
2639	641	DAVIS	3762	27	0.00
2640	2402	DAVST	0008	67	0.00
2641	2058	DFWNW	2602	42	0.00
2642	2624	DFWNW	2606	33	0.00
2643	2390	DFWNW	2610	45	0.00
2644	2349	DFWSW	2207	22	0.00
2645	N/A	DFWSW	2208	27	0.00
2646	2626	ENTOH	0008	82	0.00
2647	1715	FHLSW	1382	112	0.00
2648	2628	FRMBG	1703	23	0.00
2649	2455	FRMBG	1706	55	0.00
2650	913	FRMNT	0005	57	0.00
2651	2629	FSCRK	6722	175	0.00
2652	521	GAVSW	0006	64	0.00
2653	1285	GAVSW	0011	57	0.00
2654	2631	GSTHW	1691	32	0.00
2655	713	HKBRY	1111	27	0.00
2656	2632	HMPHL	2723	19	0.00
2657	N/A	HMPHL	2731	14	0.00
2658	894	INAIR	1423	211	0.00
2659	2634	JNKNS	0006	496	0.00
2660	2472	JUDCT	0001	1079	0.00
2661	2049	JUDCT	0007	614	0.00
2662	2407	KNLTR	0006	507	0.00
2663	2560	LMBLN	0004	48	0.00
2664	1176	LSCOL	2114	28	0.00
2665	2638	LSCOL	2124	13	0.00
2666	2606	LSCOL	2137	984	0.00
2667	1727	MAPLE	0002	68	0.00
2668	2642	MDDTN	4322	25	0.00
2669	2529	MESTE	1203	94	0.00
2670	1689	NCSTH	1505	12	0.00
2671	N/A	PJPTR	3212	30	0.00
2672	N/A	PJPTR	3222	173	0.00
2673	2592	PROAD	0005	107	0.00
2674	N/A	PROAD	0009	94	0.00
2675	449	PSHIL	1606	236	0.00
2676	2457	PSHIL	1607	26	0.00
2677	N/A	PTENN	2353	175	0.00
2678	2206	RCLNS	1402	76	0.00
2679	2647	RCLNS	1403	85	0.00
2680	N/A	RCLNS	1408	77	0.00
2681	1112	REAST	1509	58	0.00
2682	608	RECCR	0001	168	0.00
2683	855	RGLRW	0005	48	0.00

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2004 SAIDI Ranking	2003 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2004 SAIDI Value
2684	1015	RGLRW	0008	49	0.00
2685	2649	RNKSW	5422	20	0.00
2686	271	RSPCK	2105	24	0.00
2687	2014	SHLMT	1801	305	0.00
2688	2655	SMBMG	1701	27	0.00
2689	N/A	SNYDR	1831	225	0.00
2690	2656	SORCY	0002	63	0.00
2691	2245	STERT	2702	75	0.00
2692	2659	TNPON	0001	74	0.00
2693	2664	TYLGE	1311	20	0.00
2694	2665	WALST	0008	17	0.00
2695	2666	WBORO	1902	11	0.00
2696	1303	WEAST	0628	198	0.00
2697	N/A	WMMMR	2705	33	0.00
2698	1090	WTAUG	4651	408	0.00

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2004 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13.00%
Vegetation	10.00%
Animals and Birds	11.00%
People (Including cars and farm equip)	18.00%
Utility-owned Equipment	22.00%
Other	21.00%
Unknown	5.00%