

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1772	1914	WSANG	2801	1310	29.60
1773	716	FSCRK	6711	3384	29.59
1774	1446	FHLSW	1351	1203	29.53
1775	2504	PALRD	2204	681	29.50
1776	1693	KILEN	1202	642	29.49
1777	2246	TYEST	1509	366	29.42
1778	1039	SHLMT	1802	688	29.41
1779	1987	CNTRY	2851	1464	29.41
1780	1929	PRNTH	1403	23	29.39
1781	669	TYEST	1508	637	29.35
1782	1426	SYCRK	4531	3339	29.32
1783	304	FSCRK	6712	2481	29.31
1784	N/A	KYSTN	1031	26	29.31
1785	1311	WCOLO	1319	1996	29.26
1786	2363	KLNTF	1802	1694	29.18
1787	101	LIPAN	1303	238	29.14
1788	2370	WRBND	2311	1253	28.99
1789	30	IOWPK	0831	1031	28.95
1790	2255	PWEST	1310	244	28.95
1791	2202	TRNTY	7511	1374	28.93
1792	2051	RANGR	4311	737	28.91
1793	2434	CRNRD	0002	270	28.90
1794	2159	PFFRD	3482	1077	28.87
1795	1656	MDTHN	1703	578	28.79
1796	2453	ARLNG	1261	1338	28.77
1797	1307	FRMBR	1808	205	28.74
1798	1075	AZLE	2111	2013	28.72
1799	1142	WATCO	2603	2715	28.72
1800	1663	EULES	8731	1382	28.69
1801	1899	TRLSW	1204	586	28.64
1802	1566	DESPR	1408	1716	28.49
1803	704	LFSTH	1404	277	28.41
1804	2129	MESTE	1213	1320	28.22
1805	1409	CRLFR	2155	2852	28.19
1806	251	CPRCV	1403	1372	28.12
1807	2606	BKWST	0007	1595	28.12
1808	2384	WEAST	0626	246	28.10
1809	484	RSPVY	1706	1333	28.06
1810	2016	CMNCH	1401	1141	28.00
1811	319	BRLSN	2021	1985	27.98
1812	1612	JSHUA	1302	1236	27.93
1813	1064	MDLNE	0112	529	27.89
1814	397	IRVNE	1305	213	27.88
1815	1090	WCOLO	1318	1502	27.81
1816	1236	DNISN	1201	1366	27.81
1817	735	RSNHT	1131	2543	27.80
1818	963	MNWLL	1205	123	27.78
1819	1717	CDHIL	1804	799	27.77

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1820	2237	CNTRY	2833	2275	27.76
1821	1569	CRNTH	2403	2333	27.71
1822	841	GLNHV	3942	1357	27.70
1823	1520	PRKRW	3392	1109	27.61
1824	1912	RCHHL	0374	1478	27.56
1825	450	HOLDY	0921	516	27.47
1826	900	IRVVV	2802	1045	27.46
1827	98	MAPLE	0003	734	27.42
1828	211	PLSTN	1005	1885	27.37
1829	231	SMPST	0003	892	27.37
1830	1855	HHSTH	1501	2362	27.31
1831	1548	EULES	8711	2036	27.25
1832	835	PRNTH	1401	1419	27.22
1833	1508	RRSTH	1703	1977	27.22
1834	1967	EDDY	0425	220	27.16
1835	571	COPEL	3053	2011	27.16
1836	2578	ARTHR	0431	453	27.13
1837	2365	ACRLY	1711	155	27.12
1838	2089	PCOIT	1022	1590	27.06
1839	526	COLNY	2406	722	27.06
1840	459	LKMNT	0005	561	27.03
1841	2229	TYSTH	1209	823	27.01
1842	351	CHROW	0002	107	26.98
1843	N/A	CRLTR	2051	3307	26.91
1844	1816	RCHHL	0384	677	26.82
1845	2196	MCHSN	1201	243	26.74
1846	617	NMAIN	0231	132	26.68
1847	2293	ODNTH	2034	2596	26.66
1848	1284	LKWOD	7421	43	26.63
1849	1752	OAKHL	3011	1685	26.62
1850	902	CRLTN	1453	285	26.55
1851	2412	ARLNG	1292	1538	26.49
1852	2499	CRLTR	2052	1518	26.45
1853	1528	MESQT	1305	864	26.38
1854	1485	IRVNE	1303	1385	26.37
1855	905	BRNAV	0732	729	26.35
1856	958	HUTCH	1501	798	26.32
1857	N/A	MESWE	3621	707	26.32
1858	2306	FSTVW	0003	1345	26.31
1859	2094	PAYSW	1202	1609	26.05
1860	1639	LMESA	1561	2056	26.02
1861	1413	PCUST	2006	1592	26.02
1862	1263	TMSTH	1401	2170	25.97
1863	790	TAYLR	1201	1585	25.96
1864	627	BDFRD	8842	1402	25.96
1865	1478	PERIN	1511	604	25.95
1866	1061	SALDO	3001	835	25.91
1867	1800	SPRDL	4841	805	25.77

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1868	2105	WTAUG	4631	1112	25.70
1869	2532	SHMNE	1405	729	25.64
1870	154	CPRCV	1405	1519	25.64
1871	657	MNWLL	1203	723	25.63
1872	1651	CHROW	0008	80	25.61
1873	712	PWEST	1304	1306	25.61
1874	433	ADISN	1605	1451	25.58
1875	2331	IRVBL	2501	332	25.57
1876	1626	WDGWD	1512	822	25.57
1877	546	GRDNC	1211	331	25.51
1878	966	BRKRG	0213	1412	25.50
1879	1357	IRVND	1201	1033	25.46
1880	2321	MESTE	1205	1603	25.41
1881	2401	SMOUR	0721	26	25.38
1882	1214	SMFLD	2341	1070	25.36
1883	2191	SHMNE	1409	1161	25.22
1884	1881	HHSTH	1503	610	25.22
1885	1063	DALWT	2962	502	25.21
1886	2004	OKCLS	0006	1094	25.17
1887	887	FRMBG	1705	271	25.00
1888	1664	LOMAL	0014	587	24.99
1889	2050	DENAV	0652	40	24.90
1890	1695	CRLUD	1303	956	24.89
1891	2450	PRKRW	3331	79	24.89
1892	2286	MESQT	1306	1140	24.84
1893	1102	WCOLO	1316	1943	24.81
1894	214	PCUST	2009	2028	24.80
1895	2501	SHAMP	0001	1097	24.78
1896	1575	CMNCH	1402	1183	24.73
1897	2356	HKHTS	1604	808	24.72
1898	483	PROAD	0004	981	24.72
1899	23	RWALL	1201	2177	24.69
1900	997	DESPR	1404	1378	24.67
1901	451	LWRDR	0001	1138	24.65
1902	499	AZLE	2122	1818	24.60
1903	1031	TYLER	1001	242	24.55
1904	1558	RWDHV	1902	912	24.44
1905	533	LKMNT	0008	810	24.42
1906	761	WHTRK	0001	2194	24.41
1907	263	ABRRD	0002	1340	24.41
1908	1741	REAST	1506	1192	24.41
1909	1939	HURST	1831	1340	24.39
1910	1211	ATHNW	1404	1540	24.36
1911	2298	BSPSW	0832	401	24.31
1912	395	SCHRD	0006	358	24.30
1913	1815	ELGIN	1003	1261	24.23
1914	1604	RSNHT	1171	2202	24.20
1915	314	JKSBR	1401	947	24.17

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1916	1066	CMPST	0002	808	24.13
1917	2123	HMPHL	2733	116	24.06
1918	2531	LMESA	1531	1238	24.03
1919	2183	BRNAV	0784	2290	24.02
1920	732	REYST	4051	1084	24.01
1921	463	ENNIS	1901	357	24.00
1922	415	HRSMD	1951	4444	23.97
1923	1655	HORNE	1961	1451	23.73
1924	1454	PFFRD	3421	867	23.71
1925	1883	ADISN	1601	248	23.54
1926	2177	MNFLD	2611	2058	23.46
1927	2536	GVODS	3062	1824	23.27
1928	310	BNDRA	0003	772	23.25
1929	1960	LKWOD	7432	1482	23.24
1930	2546	WALNT	0002	1194	23.21
1931	2624	ALLEN	2405	1926	23.21
1932	1988	EZACH	0007	1540	23.19
1933	462	WFNTH	0221	590	23.09
1934	1140	SIKES	2421	1027	23.03
1935	1806	BLKST	1711	1294	22.99
1936	610	IRVGS	1907	758	22.87
1937	2024	WCOLO	1320	653	22.86
1938	1505	SORCY	0003	826	22.85
1939	1398	SMFLD	2391	293	22.80
1940	558	HDWLK	3003	921	22.79
1941	74	REAST	1505	396	22.75
1942	2535	MSTLT	1054	175	22.70
1943	2257	MSHLN	0008	657	22.68
1944	274	HKBRY	1109	577	22.67
1945	1887	PCUST	2003	1024	22.62
1946	1749	KFMNW	1201	1042	22.61
1947	2189	ALPHA	0013	443	22.61
1948	1998	DENAV	0621	1622	22.56
1949	2538	MAYFD	5511	3615	22.53
1950	1113	KMA	1711	312	22.53
1951	1289	HLTOM	2472	1726	22.46
1952	2261	PPARK	1803	991	22.42
1953	N/A	RRWES	1603	11	22.36
1954	1392	BRLSN	2013	1561	22.35
1955	N/A	STERT	2706	116	22.34
1956	1842	RDRSE	2604	2428	22.29
1957	2137	BDFWD	8922	2090	22.27
1958	2087	BDFRD	8841	810	22.21
1959	2235	CMPWI	0003	953	22.15
1960	1941	WTAUG	4652	787	22.15
1961	343	WTHRE	2101	1038	22.15
1962	1874	LIPAN	1301	472	22.11
1963	2326	CRLTR	2004	237	22.07

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1964	2411	ELKTN	2503	318	22.04
1965	1002	BNTDR	0004	1592	21.97
1966	510	NVARO	1502	556	21.97
1967	1101	PLKST	0001	764	21.95
1968	2445	INAIR	1413	1031	21.91
1969	2172	DNCNV	1906	379	21.89
1970	1984	HMPHL	2792	414	21.80
1971	1256	ODNTH	2014	626	21.72
1972	2014	MESQT	1301	1331	21.67
1973	76	ALPHA	0015	747	21.58
1974	2313	VANAL	1201	552	21.47
1975	2490	STNVL	1202	786	21.46
1976	1287	REAST	1504	1318	21.43
1977	467	MCGHR	2004	19	21.37
1978	1726	CRTLD	4721	3396	21.31
1979	2211	IRVND	1208	178	21.30
1980	N/A	FLINT	3211	1257	21.27
1981	1477	DAVST	0006	1076	21.26
1982	1792	ADISN	1608	464	21.16
1983	903	EDGCF	2282	840	21.13
1984	1335	GVODS	3021	447	21.10
1985	1911	MLKF2	1202	461	21.07
1986	2617	HKBRY	1113	401	21.04
1987	1348	CDHCR	2051	1941	20.96
1988	1747	RCHHL	0353	1642	20.93
1989	1910	FRMBG	1701	166	20.91
1990	1219	PRKWY	1511	913	20.85
1991	1683	DUBLN	1360	1086	20.84
1992	1802	MKNNY	1253	61	20.84
1993	863	PRSTN	0004	640	20.82
1994	1005	TMPNW	1106	354	20.76
1995	1268	ECTHM	3311	848	20.74
1996	881	WDGWD	1522	1458	20.67
1997	1387	HLSES	0561	1448	20.66
1998	N/A	LKBLT	2103	1055	20.65
1999	2143	SCHRD	0007	1222	20.65
2000	1458	FHLSW	1342	1689	20.54
2001	618	QNLAN	1201	817	20.49
2002	2362	ELKHR	1201	914	20.49
2003	185	LOMAL	0003	1117	20.37
2004	1044	EDGCF	2213	2922	20.37
2005	2422	MSLSW	0001	1132	20.36
2006	2436	HLTOM	2411	1309	20.35
2007	1046	MDAIR	2921	1032	20.35
2008	738	CRLUD	1301	15	20.33
2009	2564	MESTE	1207	845	20.31
2010	1621	CNI45	2402	1318	20.29
2011	2218	DESHR	1202	1599	20.21

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2012	1000	WHOUS	4122	1814	20.19
2013	1252	GLNHV	3911	1131	20.17
2014	1830	PRCTR	1602	216	20.15
2015	1089	HLSBR	1202	1214	20.15
2016	1818	MAYFD	5521	2629	20.12
2017	1617	BOWEN	3132	1642	20.09
2018	874	DNISN	1203	1521	19.96
2019	1577	WCOLO	1315	1600	19.89
2020	1853	RSNHT	1122	1739	19.87
2021	303	CNTRY	2824	3120	19.82
2022	1980	GORMN	0421	356	19.80
2023	169	GAVSW	0004	716	19.80
2024	1854	ROWLT	1106	1292	19.79
2025	2516	GVODS	3072	2166	19.79
2026	2281	RCLNS	1401	70	19.79
2027	2342	BKWST	0005	888	19.69
2028	2141	MESFR	2101	1116	19.68
2029	1178	DUVAL	0483	1136	19.67
2030	84	FSHSW	2111	284	19.61
2031	464	PRCRK	0002	1636	19.60
2032	680	SPRTN	1801	1100	19.56
2033	262	THRNE	0002	1705	19.56
2034	708	LAVON	1452	1814	19.51
2035	2179	MESQW	1804	1261	19.49
2036	1825	BRLSN	2031	1072	19.45
2037	859	HLSES	0553	1804	19.33
2038	1159	GODRD	8131	1651	19.33
2039	1589	MESQN	1502	1062	19.24
2040	1316	GRPVN	8211	1759	19.21
2041	1093	MAPLE	0008	28	19.11
2042	1160	FRNKF	0004	948	19.06
2043	1021	SMFLD	2323	525	19.05
2044	2373	CMTSW	0983	846	19.04
2045	1412	BRHLW	7622	1120	19.03
2046	1145	EDGCF	2221	630	18.91
2047	2416	CDCSW	0005	1192	18.90
2048	2503	BDFWD	8932	1624	18.90
2049	1213	PPARK	1801	1184	18.89
2050	1622	HMPHL	2781	121	18.88
2051	109	LOMAL	0016	630	18.88
2052	1190	CRLJL	1502	303	18.87
2053	2426	LGVST	8522	350	18.87
2054	2481	WTAUG	4632	1174	18.86
2055	1706	KLELM	2205	1486	18.79
2056	999	SPRDL	4821	1373	18.75
2057	1361	WBROK	3021	39	18.74
2058	2047	SMFLD	2322	1053	18.72
2059	826	RDRSE	2602	2163	18.72

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2060	2380	ARLNG	1212	131	18.69
2061	2181	PROAD	0003	1013	18.63
2062	838	HKBRY	1104	179	18.58
2063	N/A	CRLFR	2157	786	18.50
2064	530	TLRWT	2203	751	18.45
2065	2457	WWEST	1219	918	18.36
2066	1035	BRHLW	7632	1323	18.31
2067	1442	BOWEN	3142	1423	18.27
2068	1261	GNSVN	1401	25	18.24
2069	1729	GAVSW	0008	121	18.23
2070	1103	PTENN	2356	920	18.15
2071	38	WELRD	0002	717	18.10
2072	1296	BOWEN	3161	1356	17.94
2073	2659	JNKNS	0006	495	17.94
2074	683	GODRD	8112	1387	17.93
2075	1625	BRNAV	0723	1302	17.88
2076	2566	CNTRY	2862	400	17.87
2077	2115	TMSTH	1406	364	17.85
2078	682	MKNSW	2603	2662	17.83
2079	2072	TRNTH	1502	433	17.81
2080	2069	RDLML	2571	353	17.79
2081	2475	PALRD	2203	978	17.75
2082	559	BNBRK	4112	2028	17.69
2083	471	TYBLR	2804	1991	17.65
2084	2059	HRSMD	1955	1314	17.62
2085	2498	WHTRK	0005	714	17.60
2086	293	SANSM	3913	2920	17.54
2087	1015	TYOMN	1410	1107	17.51
2088	481	BRHLW	7612	654	17.46
2089	2292	MDLNW	1531	1174	17.44
2090	809	RENSW	3111	906	17.35
2091	1057	NCDCH	1202	1031	17.33
2092	1869	DUBLN	2214	744	17.32
2093	2157	DESHR	1206	1873	17.31
2094	755	VEST	3111	51	17.29
2095	423	MDLNW	1592	1405	17.25
2096	1407	NYLDV	1202	134	17.25
2097	2341	IRVNR	1555	3239	17.12
2098	108	COHMA	1132	42	17.12
2099	2265	SHNRW	1612	291	17.12
2100	2514	BEAST	4088	115	17.07
2101	1132	ARLNG	1222	93	17.00
2102	2414	LMESA	1522	1348	16.96
2103	2337	LKHLD	0003	1311	16.96
2104	995	MDWPK	9221	407	16.91
2105	1570	BRNWD	1205	804	16.84
2106	2224	PFLGV	2005	3023	16.81
2107	2611	BLTLN	0001	643	16.77

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2108	765	SHSTH	1303	645	16.66
2109	1433	JEWET	1204	1308	16.62
2110	1893	PALRD	2205	302	16.62
2111	1962	WHITE	3541	852	16.60
2112	2549	RSPCK	2142	479	16.50
2113	1701	WRBND	2312	1462	16.46
2114	1901	GODRD	8151	1452	16.38
2115	1314	WNDWD	3631	301	16.37
2116	1309	HMPHL	2721	414	16.35
2117	2239	MDDTN	4321	888	16.27
2118	1255	HLSBR	1204	546	16.27
2119	1395	RCLNS	1407	1598	16.25
2120	752	BNDRA	0002	561	16.19
2121	1100	TYLGE	1308	1510	16.16
2122	1884	PRKRW	3311	967	16.01
2123	2222	GODRD	8141	851	15.95
2124	1715	FROKS	0006	970	15.94
2125	2622	MCWHT	3512	1705	15.89
2126	2156	SIKES	2411	1650	15.86
2127	2291	HSKAV	0001	1021	15.76
2128	1728	HKHTS	1606	1682	15.72
2129	1809	MESFR	2105	1021	15.70
2130	280	WHTRK	0007	1192	15.69
2131	650	HLSES	0533	1230	15.67
2132	2140	PWEST	1312	1194	15.66
2133	259	MESQW	1807	1596	15.64
2134	1986	PRKWY	1532	1815	15.63
2135	1459	RCHHL	0332	1587	15.63
2136	1927	DAVST	0005	1288	15.61
2137	173	BSPRW	2542	692	15.58
2138	2381	WXNTH	2302	928	15.57
2139	970	COMSO	1405	742	15.56
2140	1453	TATSP	4321	1424	15.55
2141	2134	MNHNS	1911	1102	15.54
2142	2258	WTAUG	4612	1043	15.53
2143	47	BLKST	1752	1191	15.53
2144	641	BLMND	3221	76	15.50
2145	1708	CMTSW	0921	1889	15.42
2146	1114	TYBLR	2805	2094	15.42
2147	2378	RANGR	4321	651	15.41
2148	2352	PFFRD	3492	672	15.41
2149	2232	HMPHL	2711	391	15.31
2150	N/A	FORSW	2053	2692	15.31
2151	503	SORCY	0004	589	15.26
2152	1607	PPARK	1805	954	15.26
2153	2369	WFALS	0174	1302	15.24
2154	2167	WNRTH	1420	1152	15.23
2155	2640	DAVST	0008	62	15.23

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2156	2153	KLNTF	1805	1631	15.22
2157	1539	BMTWN	1611	1604	15.22
2158	1790	BONHM	1202	903	15.18
2159	1968	GNSVE	1602	1569	15.18
2160	2249	ENTOH	0006	1489	15.18
2161	1828	MDLNW	1563	1261	15.15
2162	768	GRDPR	0891	750	15.13
2163	1131	DAVIS	3713	863	15.13
2164	482	DCVSO	1107	1011	15.13
2165	1872	FARON	4031	866	15.13
2166	1199	ALNTH	2851	2369	15.12
2167	1418	ALPHA	0014	556	15.10
2168	1069	ARTHR	0462	1002	15.08
2169	1125	ALPHA	0001	453	15.05
2170	1935	DAVIS	3733	454	15.04
2171	N/A	LKBLT	2107	1724	14.98
2172	2010	WRBND	2321	1636	14.91
2173	1836	COPEL	3051	2529	14.90
2174	1611	FARON	4082	1579	14.89
2175	2668	MDDTN	4322	26	14.88
2176	490	PLSTH	1301	575	14.88
2177	2382	WWEST	1217	97	14.82
2178	2377	MDWPK	9211	1217	14.76
2179	1053	KNEDL	6332	2466	14.71
2180	2083	IRVVV	2801	1349	14.68
2181	1504	MTLDA	0003	1412	14.63
2182	2081	TMPSE	1503	642	14.63
2183	2631	BKWST	0004	1225	14.62
2184	1241	CLCRK	1011	189	14.62
2185	2075	DAVST	0002	458	14.60
2186	1320	ODNTH	2013	1129	14.59
2187	2193	BAKKE	6911	104	14.57
2188	2043	MTLDA	0001	2135	14.53
2189	989	MKNGB	5322	616	14.51
2190	839	WATSN	5331	1060	14.50
2191	713	WATSN	5342	1838	14.41
2192	2582	HMPHL	2772	263	14.33
2193	1155	SGOVL	1405	264	14.31
2194	345	PCOIT	1006	847	14.28
2195	2008	PNTGO	7111	665	14.27
2196	242	VALVW	1802	414	14.18
2197	1109	TYLNE	1623	911	14.13
2198	57	CMTSW	0914	84	14.12
2199	2225	GSTHW	1682	152	14.11
2200	2165	STNVL	1206	2047	14.09
2201	901	DENAV	0683	848	13.98
2202	1808	MDLNW	1511	2436	13.97
2203	1321	RRSTH	1702	1584	13.93

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2204	2648	FRMBG	1703	27	13.85
2205	264	BRHLW	7642	781	13.84
2206	208	CRYVE	3011	277	13.82
2207	2629	AMLIA	0003	21	13.81
2208	1591	MKNGB	5331	1554	13.79
2209	700	RWDHV	1905	1139	13.78
2210	1926	REAST	1502	1265	13.68
2211	909	CTYVW	2221	1603	13.66
2212	1596	ECTOR	1201	390	13.62
2213	2508	MNHNS	1921	1713	13.58
2214	2311	BRYAN	0002	374	13.54
2215	1127	BRCRK	6533	1394	13.51
2216	2620	GLNHV	3983	889	13.51
2217	192	MESTE	1201	108	13.48
2218	2472	BNMAG	1201	167	13.44
2219	1609	CRKET	2401	128	13.34
2220	1332	BNDRA	0001	1068	13.25
2221	873	PREST	1604	1307	13.23
2222	2448	CDCSW	0007	907	13.21
2223	2114	ODESA	0212	1953	13.06
2224	515	HSKAV	0006	585	13.06
2225	2287	WFNTH	0241	748	13.04
2226	195	CHICW	1301	12	13.00
2227	2459	BSPRW	2552	819	12.99
2228	2282	MKNSW	1603	1245	12.98
2229	1776	BRKTN	1202	116	12.97
2230	1923	TAYLR	1203	1754	12.89
2231	1559	COHMA	1111	654	12.89
2232	2277	ODESA	0272	1295	12.84
2233	1094	SMFLD	2343	752	12.81
2234	2389	MDLNW	1521	2396	12.79
2235	1803	CNTRD	0003	1201	12.67
2236	1537	SHAMP	0005	1646	12.54
2237	365	WELCH	4911	25	12.52
2238	1924	LKMNT	0003	531	12.48
2239	2182	HMPHL	2752	130	12.48
2240	1981	WEAST	0619	1606	12.45
2241	1849	DLEON	0131	713	12.45
2242	648	CDHIL	1805	556	12.42
2243	2176	GODRD	8142	817	12.36
2244	2423	MDLNE	0133	186	12.35
2245	416	EGFRD	0001	1165	12.34
2246	2460	GSTHW	1692	721	12.32
2247	61	LOMAL	0006	1119	12.31
2248	2223	MDDTN	4312	1802	12.23
2249	1344	SMFLD	2333	733	12.18
2250	940	MRDCK	0002	1373	12.13
2251	698	BARRY	1802	270	12.12

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2252	1953	WRBND	2322	927	12.09
2253	690	CRSGL	1301	72	12.08
2254	602	MTLDA	0007	1136	12.08
2255	1022	BSPRG	1902	2409	12.08
2256	349	BELLS	1201	556	12.04
2257	933	MAYFD	5522	2656	12.00
2258	2409	BBTWN	1502	1647	11.96
2259	1533	BANGS	1201	1453	11.88
2260	2297	ARTHUR	0481	1289	11.81
2261	1684	CLCTY	1031	1217	11.76
2262	1187	MDLNE	0172	1182	11.72
2263	1405	PRNTH	1405	906	11.63
2264	2580	LWSNR	2231	768	11.62
2265	1523	TMPTV	2404	3121	11.55
2266	1375	CNTRY	2814	760	11.55
2267	16	PGSTH	7021	58	11.50
2268	884	PFFRD	3452	1329	11.49
2269	1072	ECTHM	3331	27	11.44
2270	1317	CLCTY	1021	653	11.41
2271	1501	BDFRD	8811	1691	11.24
2272	1795	KLELM	2201	2342	11.19
2273	2314	EDGCF	2252	363	11.16
2274	1930	PRCRK	0003	1309	11.09
2275	1331	LKHLD	0002	1241	11.06
2276	2613	FRMBR	1806	120	10.93
2277	1716	MDDTN	4311	186	10.89
2278	2424	DAVST	0003	1603	10.84
2279	2272	WFALS	0143	184	10.80
2280	2209	STHRL	0007	355	10.79
2281	1943	SNYDR	1823	1346	10.78
2282	1712	PARIS	1204	1184	10.72
2283	2315	FORSW	2051	2349	10.65
2284	1766	MDLNW	1541	2046	10.64
2285	1652	ARTHUR	0411	703	10.63
2286	1545	WDGWD	1513	842	10.63
2287	1641	WHITE	3542	561	10.61
2288	2500	ADISN	1606	49	10.51
2289	1323	PALMR	2201	52	10.50
2290	414	RRNE	2404	4089	10.50
2291	2198	CRLTR	2007	1328	10.49
2292	2477	TYSTH	1208	299	10.34
2293	2474	HLTOM	2461	553	10.31
2294	2407	RWDHV	1906	645	10.28
2295	1060	COMSO	1403	1168	10.27
2296	1889	GLNHV	3953	1575	10.22
2297	1319	SHNRW	1611	858	10.21
2298	2530	RSPCK	2103	159	10.19
2299	1470	MDAIR	2911	359	10.18

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2300	2079	GRMES	0512	1128	10.17
2301	705	SYCRK	4511	1807	10.16
2302	1801	CRNRD	0004	468	10.11
2303	1189	WEAST	0616	489	10.08
2304	2533	COPER	0402	160	10.06
2305	1497	MDLNE	0141	2317	10.03
2306	1359	KLNTF	1806	1162	9.87
2307	1456	LIGSW	1603	2488	9.80
2308	2418	GRLRD	0002	976	9.76
2309	165	ABRRD	0005	1179	9.75
2310	1522	STANT	1311	1178	9.72
2311	2343	MESTE	1202	748	9.61
2312	628	MESTE	1215	1293	9.60
2313	1237	PRCRK	0004	1327	9.59
2314	2003	MDLNW	1532	1709	9.55
2315	2178	ROWLT	1101	743	9.53
2316	1919	MCDMT	2551	3026	9.51
2317	2479	ODNTH	2053	2233	9.50
2318	2125	RRSTH	1707	130	9.48
2319	1623	POYNR	1201	339	9.48
2320	1831	FRMNT	0001	1404	9.46
2321	1088	BLKST	1721	1004	9.45
2322	808	DUVAL	0473	1483	9.43
2323	1449	BOWEN	3112	873	9.42
2324	673	LKMNT	0001	200	9.41
2325	421	CRTL D	4714	1437	9.39
2326	1789	SYCRK	4512	1217	9.38
2327	2139	BKBNT	1842	450	9.35
2328	631	MCKMY	0822	815	9.22
2329	1176	DESPR	1401	2540	9.19
2330	587	ODESA	0261	11	9.09
2331	1993	LWSNR	2211	1639	9.04
2332	2541	TMPSE	1501	537	8.96
2333	524	LNDAL	2202	1044	8.95
2334	2049	PAYSW	1203	846	8.94
2335	2563	DNINR	1402	405	8.93
2336	2626	ALLNC	6422	21	8.86
2337	1804	BBTWN	1501	2359	8.81
2338	309	ODESA	0242	547	8.77
2339	2204	ROWLT	1104	1434	8.73
2340	2058	BLMND	3241	212	8.72
2341	2357	FSTVW	0004	1955	8.72
2342	1905	SNYDR	1822	1588	8.72
2343	1847	CRSCN	1202	640	8.70
2344	689	BRCRK	6512	1107	8.69
2345	1628	DEALY	0001	1019	8.68
2346	2163	ROWLT	1105	1423	8.67
2347	2589	DENAV	0673	77	8.65

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2348	2327	ARMST	0010	806	8.63
2349	92	RSPVY	1708	932	8.63
2350	2520	ALLEN	2401	1875	8.59
2351	2245	MKNGB	5312	1881	8.55
2352	2599	FSTVW	0005	1530	8.52
2353	703	FROKS	0002	1208	8.52
2354	1813	KLELM	2204	2687	8.48
2355	2396	FRNKF	0006	2047	8.41
2356	1811	BKBNT	1821	1215	8.39
2357	1474	CRANE	0331	1056	8.38
2358	2146	BRYAN	0004	1463	8.37
2359	480	SHNRW	1614	396	8.36
2360	620	MLSW	0006	100	8.33
2361	150	CRLTR	2002	1395	8.32
2362	1298	PKRVL	1053	2472	8.20
2363	2203	INAIR	1421	13	8.15
2364	1045	LMESA	1512	643	8.13
2365	2073	MURPH	2753	2616	8.13
2366	2328	ODESA	0221	268	8.08
2367	869	BSPRW	2521	1700	7.98
2368	2432	ECTHM	3321	1980	7.97
2369	2604	BLNKT	0701	52	7.87
2370	2062	MESTE	1206	1192	7.86
2371	542	FRMNT	0008	1003	7.81
2372	1870	PRKRW	3372	1018	7.73
2373	1908	PPARK	1806	1323	7.72
2374	2280	GRMES	0521	488	7.70
2375	1135	ITSCA	1702	228	7.66
2376	754	CNEXP	0006	1050	7.63
2377	2621	MCWHT	3511	2953	7.60
2378	2228	FRMNT	0007	98	7.59
2379	2184	ARMST	0012	578	7.58
2380	409	GRLRD	0003	610	7.51
2381	77	LKHLD	0005	1868	7.51
2382	1416	CRLUD	1307	199	7.44
2383	1244	SHRSW	6612	1831	7.42
2384	2294	MCDMT	2552	1073	7.39
2385	1892	COMRC	1201	968	7.34
2386	1288	BRHLW	7621	2705	7.29
2387	479	LKHLD	0008	1124	7.29
2388	2045	BSPSW	0851	1087	7.24
2389	2097	WTAUG	4643	985	7.21
2390	2366	IRVNE	1309	1083	7.17
2391	1353	GSTHW	1662	1079	7.09
2392	2150	ENTOH	0005	924	7.05
2393	2077	BSPSW	0812	781	7.04
2394	2654	GSTHW	1691	24	6.96
2395	2502	GVODS	3011	2247	6.93

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2396	2683	RGLRW	0005	48	6.92
2397	2435	ODNTH	2044	1931	6.91
2398	472	CMTSW	0915	648	6.90
2399	166	CPRCV	1402	1770	6.87
2400	1360	PRKWY	1521	1762	6.87
2401	1971	SHSTH	1301	1521	6.84
2402	60	NHNSW	0008	547	6.81
2403	2160	ESTLD	3611	1541	6.80
2404	2074	STERT	2701	22	6.73
2405	684	FRMNT	0009	1201	6.72
2406	899	WXHCH	1205	671	6.70
2407	1895	EDGCF	2272	1044	6.68
2408	2612	JUDCT	0008	253	6.68
2409	106	FRMNT	0011	699	6.67
2410	1363	PCOIT	1002	878	6.65
2411	2017	PRKWY	1552	464	6.57
2412	2353	MDLNW	1573	848	6.54
2413	979	HORNE	1942	1287	6.53
2414	2226	COMRC	1202	50	6.52
2415	1434	PTENN	2352	1939	6.52
2416	2360	SSPNG	1203	822	6.42
2417	2519	GRAHM	0713	409	6.37
2418	1858	RSPCK	2106	482	6.37
2419	25	CTYVW	2222	1423	6.31
2420	1464	MESQW	1801	1782	6.31
2421	1163	LOMAL	0005	420	6.30
2422	1755	WSOTH	1022	424	6.28
2423	1940	RRSTH	1706	2597	6.23
2424	762	REGST	0003	909	6.23
2425	1156	JUDCT	0006	1143	6.22
2426	1025	FRMNT	0002	106	6.12
2427	2351	WATSN	5352	1850	6.11
2428	2195	DENDR	0009	59	6.00
2429	2679	RCLNS	1403	85	5.99
2430	2425	GODRD	8161	1548	5.99
2431	2433	FSTVW	0007	1437	5.98
2432	2055	PROAD	0001	125	5.95
2433	2001	FRMBR	1853	55	5.89
2434	1950	LWSNR	2241	1473	5.85
2435	1770	BLTON	1805	1160	5.77
2436	1932	BRIRV	6921	2270	5.74
2437	2495	SMFLD	2352	600	5.72
2438	444	CRTLD	4712	1124	5.71
2439	2262	CHROW	0003	51	5.69
2440	2098	ANDNR	2211	1454	5.66
2441	2201	RSPCK	2132	101	5.63
2442	621	ABRRD	0008	1063	5.63
2443	111	FRMBG	1702	56	5.63

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2444	2110	WWEST	1218	968	5.60
2445	2669	MESTE	1203	97	5.52
2446	1444	ARLNG	1241	579	5.51
2447	780	MSLSW	0007	243	5.46
2448	2271	STNVL	1203	1378	5.42
2449	2680	RCLNS	1408	76	5.39
2450	2585	DALWT	2941	282	5.37
2451	2444	ANDNR	2242	1274	5.32
2452	910	MDLNE	0122	237	5.28
2453	2421	HORNE	1933	1968	5.27
2454	2429	BSPSW	0841	1986	5.21
2455	957	EMPCT	0004	298	5.13
2456	2493	IRVNR	1552	53	5.11
2457	2517	FSTVW	0001	351	5.10
2458	2206	DGNST	0007	184	5.09
2459	1826	CRNRD	0007	746	5.08
2460	2136	MCDMT	2554	1541	5.08
2461	784	GLNHV	3973	1013	5.05
2462	N/A	SNYDR	1833	1309	5.05
2463	1170	BRHLW	7631	713	5.04
2464	18	ABRRD	0006	167	4.97
2465	160	MESFR	2103	1147	4.93
2466	1538	FRNKF	0002	843	4.88
2467	2484	ROLTR	2911	3122	4.83
2468	2431	MESTE	1211	1294	4.82
2469	2244	PLSTH	1303	564	4.79
2470	1997	WNRTH	1416	719	4.77
2471	796	TRNTY	7541	705	4.74
2472	1567	STNVL	1204	881	4.65
2473	2570	ARMST	0008	774	4.62
2474	2518	NCSTH	1504	65	4.62
2475	327	LWRDR	0003	1671	4.60
2476	1703	WFALS	0114	404	4.58
2477	2234	CLBSN	8821	51	4.57
2478	2428	WATSN	5372	1324	4.56
2479	2264	RGFTW	6822	29	4.55
2480	2302	WXNTH	2305	333	4.54
2481	931	WFALS	0193	2327	4.51
2482	860	AMLIA	0007	121	4.46
2483	2329	BKWST	0006	247	4.46
2484	2107	MSTLT	1032	58	4.43
2485	2330	ARLNG	1291	84	4.39
2486	2697	WMMMR	2705	258	4.36
2487	2026	NCRST	2203	1197	4.35
2488	2118	JNKNS	0003	15	4.33
2489	2063	MDLNW	1582	1413	4.27
2490	1783	MSLSW	0005	737	4.25
2491	1312	LENSW	0321	44	4.23

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2492	2404	HMPHL	2742	172	4.23
2493	307	HNYGR	2402	165	4.22
2494	1115	SCHRD	0008	76	4.21
2495	2149	SHAMP	0002	1623	4.21
2496	2386	RWDHV	1908	1930	4.20
2497	2415	MDLNE	0163	970	4.16
2498	1431	BKWST	0003	1858	4.14
2499	2188	CRLFR	2154	3036	4.12
2500	N/A	FLINT	3212	2024	4.04
2501	1969	SNYDR	1852	1306	4.03
2502	203	AIRPK	8421	369	4.03
2503	2528	ODNTH	2073	539	3.99
2504	1017	DALWT	2952	573	3.96
2505	854	BRKRG	0221	714	3.90
2506	2273	GAVSW	0010	504	3.89
2507	2144	LTV	5451	1194	3.86
2508	2335	ANDNR	2231	1516	3.76
2509	2686	RSPCK	2105	24	3.75
2510	675	WALNT	0001	1400	3.65
2511	2471	ADISN	1602	129	3.64
2512	1699	FRNKF	0003	485	3.60
2513	2673	PROAD	0005	111	3.52
2514	1896	RNDRK	1506	3213	3.52
2515	2569	RDLML	2591	1492	3.51
2516	2489	CKRHL	0003	445	3.48
2517	97	CHICW	1302	187	3.48
2518	2113	FARON	4062	1122	3.46
2519	182	THRNE	0008	1807	3.33
2520	1796	AIRPK	8411	737	3.33
2521	1492	PFFRD	3411	303	3.32
2522	2573	RGLRW	0003	89	3.31
2523	2394	BRKNR	1221	199	3.28
2524	1476	BARRY	1801	86	3.27
2525	2560	ARMST	0004	445	3.23
2526	2454	HLSBR	1203	970	3.18
2527	2267	WALST	0003	121	3.17
2528	305	KNLTR	0005	2378	3.11
2529	2544	ATNRN	3411	3010	3.10
2530	2309	RGLRW	0004	74	3.09
2531	1541	MAPLE	0001	651	3.08
2532	2174	RSPCK	2131	42	3.07
2533	2440	CNTRD	0001	2094	3.07
2534	1965	CNEXP	0002	803	3.03
2535	2420	MESTE	1208	803	3.01
2536	1271	JUDCT	0002	1495	3.00
2537	2355	GVODS	3031	1335	2.96
2538	2642	DFWNW	2606	21	2.95
2539	1356	WALNT	0008	928	2.94

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2540	1859	PRKRW	3382	171	2.91
2541	2478	WTAUG	4642	1296	2.86
2542	1355	LOMAL	0012	582	2.77
2543	975	CNEXP	0001	188	2.73
2544	2545	FSTVW	0002	147	2.73
2545	1619	SHNRW	1610	399	2.71
2546	2667	MAPLE	0002	72	2.65
2547	193	WBOSE	1101	332	2.61
2548	1957	CTYVW	2211	1485	2.60
2549	1793	FRMBR	1802	1076	2.60
2550	1149	MSTLT	1073	223	2.60
2551	2652	GAVSW	0006	66	2.53
2552	2507	RECCR	0007	68	2.51
2553	2102	HMPHL	2713	65	2.51
2554	2164	BRYAN	0001	14	2.50
2555	1451	TYBLR	2806	201	2.50
2556	2576	WFALS	0124	117	2.48
2557	2666	LSCOL	2137	982	2.47
2558	2588	GSTHW	1651	264	2.46
2559	325	BSPRW	2532	1571	2.39
2560	2540	DALWT	2972	190	2.35
2561	509	HNYGR	2403	113	2.34
2562	1411	BDFWD	8912	931	2.25
2563	2547	CRLUD	1302	138	2.22
2564	2268	WFALS	0163	337	2.21
2565	724	MKNSW	2602	2592	2.15
2566	2523	WALST	0007	16	2.13
2567	2214	MRSES	3019	21	2.10
2568	1118	LOMAL	0002	617	2.03
2569	487	RGLRW	0006	34	1.97
2570	2663	LMBLN	0004	48	1.94
2571	441	MNWLL	1201	15	1.93
2572	2554	COPER	0401	135	1.93
2573	2529	MCDMT	2553	1640	1.91
2574	1600	BRHLW	7611	1629	1.88
2575	840	DGNST	0006	77	1.82
2576	2655	HKBRY	1111	26	1.77
2577	149	SHDYG	7821	83	1.69
2578	N/A	KLRPR	9011	2589	1.65
2579	842	TMSTH	1407	55	1.60
2580	2132	PSHIL	1605	110	1.59
2581	278	SCHRD	0004	1692	1.55
2582	2400	ALNTH	2852	1866	1.54
2583	2552	INAIR	1414	823	1.50
2584	1864	SHRSW	6641	865	1.46
2585	2609	LTV	5461	649	1.45
2586	2379	MDLNE	0151	253	1.44
2587	1725	REAST	1507	91	1.43

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2588	1019	DGNST	0005	116	1.38
2589	2133	JEWET	1202	39	1.33
2590	176	CRLTN	1451	277	1.30
2591	2241	IRVNR	1506	1355	1.29
2592	2439	TMSTH	1405	314	1.24
2593	2405	ENNIS	1905	39	1.21
2594	697	PROAD	0007	387	1.16
2595	2387	TRLSW	1202	53	1.13
2596	2662	KNLTR	0006	521	1.09
2597	2192	PRSTN	0003	2897	1.08
2598	2442	BDFWD	8911	799	1.07
2599	2592	DALWT	2992	332	1.00
2600	2348	CHROW	0005	154	0.96
2601	2625	ALLNC	6411	54	0.93
2602	2020	BSPRG	1904	1469	0.92
2603	295	CURIE	7231	1332	0.90
2604	2556	CRNRD	0006	389	0.90
2605	1161	RRSTH	1705	447	0.83
2606	2347	PAYSW	1223	114	0.80
2607	253	DGNST	0008	99	0.75
2608	2698	WTAUG	4651	440	0.72
2609	1341	FRMBR	1807	862	0.68
2610	2456	CRLTR	2054	367	0.68
2611	1445	SWAN2	1801	255	0.67
2612	2312	RRSTH	1708	3933	0.64
2613	1400	RECCR	0005	151	0.64
2614	1158	BRIRV	6912	744	0.62
2615	2675	PSHIL	1606	242	0.60
2616	7	SNYDR	1813	275	0.56
2617	276	TYLNE	1613	137	0.52
2618	80	SHDYG	7811	372	0.51
2619	1615	FRMNT	0012	602	0.51
2620	1833	WHTRK	0008	1408	0.48
2621	2180	FSTVW	0008	2254	0.42
2622	709	IRVNR	1553	1344	0.40
2623	1787	RCHHL	0394	230	0.39
2624	1194	RNDRK	1507	1177	0.39
2625	2616	BRYAN	0007	264	0.35
2626	91	SHDYG	7812	112	0.35
2627	2583	MSHLN	0004	862	0.32
2628	2487	WATSN	5382	661	0.31
2629	2066	FROKS	0007	1434	0.31
2630	2486	KLNTF	1803	1018	0.31
2631	1673	WEAST	0621	126	0.25
2632	386	CNEXP	0003	1394	0.23
2633	72	JNKNS	0002	167	0.23
2634	2527	BNMNW	1102	200	0.22
2635	2205	ARMST	0011	570	0.21

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2636	1586	WALNT	0005	1065	0.19
2637	2468	FRNKF	0008	1144	0.17
2638	2317	ARMST	0002	551	0.15
2639	N/A	PTENN	2351	783	0.12
2640	1365	ALPHA	0011	821	0.12
2641	1380	THRNE	0005	1201	0.12
2642	2494	RSPVY	1702	533	0.12
2643	2449	RRSTH	1704	2480	0.10
2644	2561	BDFWD	8941	428	0.04
2645	2623	AIRPK	8431	19	0.00
2646	1576	ANARN	1911	17	0.00
2647	1437	ARTHR	0492	51	0.00
2648	N/A	ATNRN	3412	1898	0.00
2649	147	BLMND	3211	12	0.00
2650	1850	BRHLW	7641	23	0.00
2651	1743	BRNAV	0741	115	0.00
2652	2100	CHROW	0006	63	0.00
2653	2632	CLBNR	1401	18	0.00
2654	2635	COTRD	0003	23	0.00
2655	2638	CRLUD	1306	26	0.00
2656	829	DFWNW	2601	37	0.00
2657	2641	DFWNW	2602	42	0.00
2658	2643	DFWNW	2610	46	0.00
2659	1482	DFWSW	2202	33	0.00
2660	N/A	DFWSW	2203	24	0.00
2661	1963	DFWSW	2204	25	0.00
2662	2644	DFWSW	2207	22	0.00
2663	2645	DFWSW	2208	23	0.00
2664	1888	DGNST	0001	69	0.00
2665	2647	FHLSW	1382	103	0.00
2666	N/A	FLMSO	3711	1378	0.00
2667	2539	FRMBG	1704	36	0.00
2668	2650	FRMNT	0005	61	0.00
2669	2036	GDNVL	1201	41	0.00
2670	1087	GNSVL	1213	53	0.00
2671	2586	GSTHW	1613	433	0.00
2672	2057	GSTHW	1622	31	0.00
2673	1272	GSTHW	1672	12	0.00
2674	2603	HKBRY	1102	1340	0.00
2675	2656	HMPHL	2723	17	0.00
2676	2657	HMPHL	2731	11	0.00
2677	1471	HMPHL	2791	45	0.00
2678	2575	HORNE	1923	1547	0.00
2679	2658	INAIR	1423	165	0.00
2680	1817	JKSNR	4107	22	0.00
2681	2660	JUDCT	0001	1081	0.00
2682	2577	JUDCT	0004	94	0.00
2683	993	LOMAL	0007	133	0.00

Service Quality Report to the Public Utility Commission of Texas

TXU Electric Delivery

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
2684	2242	MAPLE	0006	413	0.00
2685	810	MESQN	1506	59	0.00
2686	125	MRSES	3016	40	0.00
2687	2670	NCSTH	1505	12	0.00
2688	2672	PJPTR	3222	179	0.00
2689	2038	PRKRW	3362	1061	0.00
2690	2676	PSHIL	1607	450	0.00
2691	2677	PTENN	2353	180	0.00
2692	2513	PWEST	1305	19	0.00
2693	2243	REAST	1501	82	0.00
2694	2681	REAST	1509	58	0.00
2695	120	RGFTW	6813	12	0.00
2696	2685	RNKSW	5422	22	0.00
2697	897	RSNHT	1152	598	0.00
2698	N/A	RWALE	3322	128	0.00
2699	2687	SHLMT	1801	305	0.00
2700	1944	TRLSW	2401	18	0.00
2701	1071	TYLER	1004	115	0.00
2702	1527	VENSW	2603	27	0.00
2703	824	WALST	0006	11	0.00
2704	2694	WALST	0008	15	0.00
2705	2562	WEAST	0620	81	0.00
2706	N/A	WMRNR	0001	167	0.00
2707	N/A	WMRNR	0002	265	0.00
2708	N/A	WMRNR	0003	150	0.00
2709	665	WWEST	1221	15	0.00
2710	1216	WXHNW	2901	173	0.00
2711	2339	WXOCF	1402	13	0.00

TXU Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2005 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	12.00%
Vegetation	9.00%
Animals and Birds	15.00%
People (Including cars and farm equip)	18.00%
Utility-owned Equipment	21.00%
Other	21.00%
Unknown	4.00%