

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
736	320	LB	04	417	52.6331
737	231	CB	06	884	52.5679
738	596	SR	04	1,010	52.5366
739	342	DA	06	445	52.3169
740	347	CR	01	2,535	52.2773
741	827	HM	05	3,353	52.1223
742	310	HR	01	2,293	52.0833
743	498	NS	04	1,502	51.9847
744	126	FT	02	1,452	51.9077
745	1151	WZ	47	4,347	51.9050
746	116	NB	44	373	51.8901
747	808	KB	20	742	51.8315
748	826	EC	14	918	51.7233
749	955	BG	06	1,905	51.4903
750	371	RE	05	1,605	51.2411
751	1118	HE	05	1,484	51.2035
752	915	HE	01	1,655	50.9287
753	490	TO	01	1,677	50.6965
754	418	SF	03	604	50.6606
755	637	FM	02	220	50.5864
756	427	AN	06	903	50.5238
757	590	OA	07	603	50.4328
758	1163	MID	01	446	50.4283
759	1084	AF	02	1,570	50.2535
760	549	FT	01	1,467	50.2474
761	1099	ED	07	1,013	50.0721
762	370	MC	02	1,436	50.0223
763	421	WO	05	1,429	49.9762
764	156	GN	06	894	49.9016
765	607	WI	04	2,295	49.6941
766	1249	MY	06	912	49.6820
767	1025	DN	06	988	49.3178
768	905	CD	02	1,640	49.3079
769	1002	TO	06	991	49.2028
770	575	BG	01	394	48.9416
771	935	UW	03	1,183	48.8656
772	424	ES	08	409	48.8533
773	741	EC	03	584	48.7757
774	161	BR	12	687	48.7380
775	627	GV	05	242	48.6322
776	639	EC	06	617	48.6175
777	175	IM	43	4,044	48.5467
778	369	GV	02	1,743	48.5295
779	790	CB	02	1,124	48.4991
780	608	ADK	44	572	48.4108
781	801	IR	02	2,236	48.3864

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
782	990	BG	03	1,765	48.2686
783	475	RU	04	1,650	48.2097
784	1027	CK	05	1,301	48.1837
785	450	CD	03	1,328	48.1687
786	467	BH	07	2,361	48.0928
787	977	CE	02	1,563	47.9469
788	286	HL	06	1,661	47.8784
789	1116	FP	04	267	47.8539
790	563	SA	43	991	47.8103
791	1156	AI	05	87	47.5287
792	454	NM	01	943	47.5005
793	257	HG	02	1,742	47.4237
794	914	RU	05	2,540	47.2445
795	840	MB	07	12	47.1667
796	694	OA	04	1,913	47.0883
797	224	AM	06	1,810	47.0878
798	1143	BI	04	446	46.9305
799	357	UW	02	1,784	46.9243
800	190	GW	01	2,478	46.6033
801	953	FD	13	1,024	46.4658
802	529	DA	04	760	46.3855
803	956	ES	04	321	46.0312
804	536	GG	10	1,790	45.9972
805	412	CD	05	1,863	45.9045
806	198	WV	03	2,605	45.8441
807	568	SE	03	698	45.8381
808	16	SF	47	852	45.7500
809	97	BM	04	1,607	45.6030
810	356	FD	11	1,794	45.5346
811	160	LJ	03	1,469	45.3513
812	1257	WEB	04	626	44.9553
813	704	CA	06	827	44.8077
814	1121	PJ	02	1,245	44.5285
815	616	AD	01	624	44.4663
816	950	BG	02	2,633	44.4588
817	230	UV	07	1,243	44.4586
818	1011	HE	07	1,903	44.3242
819	158	SH	11	1,969	44.3052
820	1229	HY	13	394	44.1929
821	1205	DL	45	3,423	44.1388
822	184	NM	02	3,177	44.0777
823	1093	RE	09	872	43.9461
824	414	WE	02	1,308	43.7339
825	1238	ES	07	302	43.6788
826	870	DE	03	1,139	43.5241
827	545	CD	10	1,165	43.3648

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
828	685	AF	08	1,630	43.1785
829	81	LP	05	1,309	43.0863
830	NEW	KN	06	2,649	42.9706
831	660	MY	05	896	42.9263
832	216	IM	48	1,086	42.8877
833	752	IR	01	1,725	42.8748
834	1247	PO	05	1,307	42.8087
835	322	KW	43	3,078	42.8073
836	1107	BI	11	461	42.6855
837	700	BR	08	1,014	42.6834
838	264	KB	12	1,412	42.6643
839	1013	WO	12	1,539	42.4613
840	390	GA	03	514	42.4455
841	946	NS	06	1,895	42.4412
842	236	UN	11	1,746	41.9725
843	882	UL	47	3,738	41.8475
844	314	HE	03	1,165	41.7854
845	1266	TM	05	33	41.7576
846	1090	DE	06	1,151	41.7159
847	1271	ME	07	1,347	41.4640
848	1285	HT	07	979	41.2615
849	123	BA	42	4,583	41.2444
850	73	CE	08	1,799	41.2357
851	899	GA	04	1,514	41.0865
852	245	LB	07	149	41.0268
853	542	NS	02	1,575	40.8921
854	588	AN	07	813	40.6433
855	76	EU	09	1,433	40.5673
856	769	LY	42	1,646	40.4666
857	776	KN	04	88	40.4205
858	223	RU	02	1,639	40.4045
859	1060	GP	08	1,590	40.3472
860	1061	GA	10	985	40.0650
861	389	KL	46	4,174	40.0194
862	890	BI	07	1,320	39.7462
863	372	LU	01	703	39.7269
864	684	AN	03	1,268	39.6719
865	367	RO	05	1,112	39.5513
866	803	FR	43	4,916	39.4852
867	368	VW	05	3,015	39.4269
868	465	BT	06	1,010	39.3901
869	7	FR	44	5,360	39.2614
870	1262	IND	04	34	39.2353
871	1054	TO	04	492	39.1789
872	1128	FD	08	2,769	39.0932
873	523	CL	06	504	39.0754

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
874	1286	KN	05	1,784	39.0196
875	1292	BI	01	359	39.0000
876	99	ST	08	890	38.9225
877	1242	RO	03	905	38.8221
878	1073	UV	02	1,404	38.7949
879	447	PA	09	1,297	38.7232
880	1259	EU	08	245	38.7102
881	91	MB	04	26	38.5769
882	493	HM	09	2,279	38.5700
883	952	MAR	45	3,071	38.4279
884	911	MP	03	2,443	38.3025
885	1059	MDY	01	1,271	37.8065
886	469	LU	04	1,318	37.7086
887	1240	DL	43	3,042	37.6506
888	1004	DV	06	1,450	37.4710
889	65	MB	03	1,660	37.3620
890	1113	UL	49	2,297	37.3500
891	1172	UV	01	677	37.3397
892	897	CL	03	2,176	37.3097
893	636	HV	06	1,287	37.2774
894	703	RA	01	982	37.2291
895	520	PJ	04	1,601	37.1999
896	294	DH	06	1,339	37.1464
897	839	EU	04	274	37.1058
898	555	HY	12	949	37.0780
899	818	GW	07	882	36.9909
900	964	STF	08	372	36.9543
901	88	AL	10	1,933	36.9291
902	1075	ED	06	2,131	36.8986
903	755	SH	02	1,689	36.8236
904	668	WF	04	587	36.8007
905	266	WE	08	765	36.7660
906	822	RE	07	1,427	36.6321
907	426	ST	13	1,633	36.4930
908	1183	RO	02	2,656	36.4326
909	759	WD	41	487	36.3717
910	98	GV	03	1,257	36.3142
911	976	FD	06	2,446	36.0891
912	153	IM	44	2,812	36.0612
913	489	AF	01	3,522	35.7984
914	1208	HP	02	2,489	35.7742
915	606	ES	03	822	35.6679
916	206	CR	02	72	35.6528
917	422	SR	13	1,087	35.5262
918	113	GP	07	1,091	35.5060
919	183	ST	09	1,124	35.4528

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
920	895	QV	07	1,220	35.3926
921	1162	CB	03	659	35.2777
922	1197	GA	07	1,877	35.2152
923	361	ME	04	1,551	35.0928
924	677	AF	11	2,392	35.0318
925	492	WEB	03	1,871	34.6670
926	57	FD	16	1,242	34.6264
927	353	GG	04	1,727	34.5136
928	848	WO	03	1,862	34.4769
929	505	CB	01	1,554	34.3855
930	851	MY	01	2,179	34.2359
931	667	CB	11	2,310	34.1420
932	1158	HK	41	97	34.0619
933	415	ST	12	1,022	34.0274
934	601	FAN	46	1,845	33.8818
935	154	KL	45	4,880	33.7721
936	584	FD	14	2,877	33.6062
937	388	SP	09	1,953	33.5289
938	1042	DN	03	1,635	33.4061
939	NEW	WI	44	2,817	33.3749
940	5	DH	10	2,835	33.2910
941	595	SB	03	1,524	33.2395
942	1108	DH	03	55	33.1818
943	309	GV	07	677	33.1049
944	919	GT	12	3,126	33.0534
945	229	CS	03	1,820	33.0484
946	654	HOC	07	1,421	32.8044
947	242	WEB	10	672	32.7887
948	34	HB	49	4,485	32.7023
949	1136	GL	10	743	32.6635
950	708	UN	05	1,089	32.6410
951	NEW	KG	41	1,820	32.6099
952	614	CV	11	757	32.4333
953	1207	ED	05	637	32.1334
954	500	KW	45	4,266	32.0813
955	279	ME	10	668	32.0704
956	408	HR	04	1,157	31.9723
957	620	DE	04	1,386	31.8348
958	854	FZ	44	7,355	31.7996
959	892	KB	01	1,020	31.7402
960	1206	MID	03	965	31.7057
961	904	VW	03	3,600	31.6917
962	58	UV	06	1,620	31.6401
963	178	UL	03	1,045	31.4498
964	562	WO	08	814	31.3821
965	715	MY	02	891	31.2020

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
966	86	CB	07	1,995	31.0822
967	1174	DV	02	1,903	30.8508
968	811	RS	03	1,326	30.7919
969	651	WZ	45	2,277	30.7185
970	501	WV	02	672	30.5997
971	272	AF	05	1,732	30.3614
972	439	EL	10	930	30.0860
973	945	CA	01	1,836	30.0757
974	1091	CR	04	2,306	29.9714
975	629	BI	09	1,651	29.8837
976	1078	SB	05	1,462	29.8434
977	1033	DR	05	2,626	29.8142
978	561	SR	11	473	29.8034
979	283	DE	05	1,781	29.7816
980	871	CA	02	1,861	29.7227
981	657	BM	01	611	29.6268
982	658	KT	01	202	29.5990
983	1028	PE	02	2,404	29.4630
984	961	BL	05	1,384	29.2991
985	1015	FP	03	1,149	29.2837
986	991	GA	09	2,700	29.2437
987	551	PA	06	1,654	29.1167
988	672	SR	07	727	29.0261
989	719	PJ	01	214	28.6075
990	1152	NS	03	1,378	28.3716
991	174	PO	02	1,427	28.2446
992	62	LK	10	2,385	28.2205
993	1267	SF	14	2,113	28.2139
994	640	PA	03	2,386	28.1270
995	824	WV	01	108	28.1204
996	1103	WEB	05	480	28.0313
997	1144	ME	09	780	28.0026
998	723	BA	02	1,282	27.9321
999	780	KM	02	1,467	27.8255
1,000	13	SH	09	1,000	27.8070
1,001	587	SA	47	4,278	27.6309
1,002	954	DH	08	2,051	27.5349
1,003	777	BL	06	1,489	27.5077
1,004	132	AI	08	547	27.4607
1,005	1024	CE	03	1,243	27.3057
1,006	986	WO	11	76	27.2237
1,007	485	CD	07	1,516	27.1108
1,008	1083	GA	06	1,204	27.0125
1,009	1264	DN	12	230	26.9087
1,010	470	TV	01	884	26.8484
1,011	613	SB	06	1,680	26.7673

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,012	566	AD	02	2,185	26.6577
1,013	397	VV	08	258	26.3643
1,014	1168	BI	05	1,016	26.3563
1,015	301	KB	05	1,063	26.3330
1,016	726	KM	05	828	26.3237
1,017	443	MY	08	2,002	26.3212
1,018	714	CV	08	2,024	26.2292
1,019	743	BI	03	138	26.2029
1,020	891	PA	07	1,576	26.1180
1,021	1040	KN	02	1,079	26.0936
1,022	1036	HA	08	1,886	26.0573
1,023	556	WEB	02	520	25.9615
1,024	969	ME	02	894	25.7371
1,025	1194	CB	10	1,432	25.6746
1,026	451	WE	03	919	25.5756
1,027	1057	FT	05	1,293	25.5576
1,028	304	LK	05	1,553	25.5344
1,029	980	ME	05	1,593	25.4583
1,030	1074	KB	06	941	25.1530
1,031	664	HA	03	1,985	25.0000
1,032	817	IND	01	23	24.9130
1,033	376	NS	01	1,937	24.9091
1,034	617	CE	01	1,683	24.7908
1,035	463	JN	06	2,852	24.7304
1,036	863	FD	01	1,957	24.7159
1,037	768	PJ	03	1,574	24.6798
1,038	853	RS	05	1,919	24.5904
1,039	690	DE	02	1,386	24.5426
1,040	1150	CL	08	84	24.4762
1,041	1114	SH	07	683	24.4612
1,042	781	MC	04	1,237	24.3711
1,043	1020	SR	02	466	24.3004
1,044	354	TE	05	2,367	24.2214
1,045	413	EL	08	1,203	24.0815
1,046	510	LB	03	394	24.0381
1,047	631	AD	11	1,258	23.9905
1,048	638	FD	07	1,001	23.9820
1,049	511	UV	04	858	23.9172
1,050	998	TE	02	510	23.8745
1,051	25	GT	04	1,083	23.8633
1,052	1034	EL	05	1,316	23.8161
1,053	732	SP	11	1,039	23.8027
1,054	1147	DH	01	2,848	23.7767
1,055	1098	LJ	06	973	23.7595
1,056	228	NM	05	3,160	23.4965
1,057	437	DR	03	2,447	23.3674

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,058	446	BT	03	1,605	23.3333
1,059	NEW	BW	10	12	23.0833
1,060	773	BI	10	18	23.0556
1,061	877	HA	04	2,101	23.0447
1,062	528	GT	08	2,482	23.0222
1,063	NEW	MC	06	778	23.0206
1,064	1180	JP	02	83	22.9759
1,065	428	LP	01	536	22.9683
1,066	576	GE	44	6,650	22.7567
1,067	1056	ES	01	585	22.6889
1,068	874	FZ	41	2,870	22.6223
1,069	1043	GT	01	866	22.5600
1,070	947	SF	05	466	22.4700
1,071	253	FD	05	1,548	22.4432
1,072	122	ST	14	566	22.1802
1,073	1190	ME	06	876	22.1530
1,074	843	IM	47	935	22.0267
1,075	1008	KT	41	4,615	21.8258
1,076	502	BAR	43	3,489	21.7959
1,077	1141	HY	04	1,654	21.6608
1,078	1029	PO	01	889	21.6243
1,079	745	LU	41	5,462	21.5950
1,080	583	BA	43	5,103	21.5726
1,081	903	LK	03	1,138	21.5272
1,082	963	HNY	03	853	21.4549
1,083	1170	FW	04	1,815	21.4463
1,084	722	CG	03	915	21.3333
1,085	1269	RO	01	3,352	21.3225
1,086	444	MY	04	1,142	21.2005
1,087	978	SP	01	1,364	21.1826
1,088	519	UL	46	3,661	21.1603
1,089	237	BR	10	776	21.1211
1,090	805	TV	04	1,652	21.0630
1,091	54	BI	44	1,563	20.9399
1,092	982	DL	44	3,816	20.9361
1,093	933	EL	06	692	20.9350
1,094	1064	UV	05	1,886	20.9327
1,095	785	HP	03	1,586	20.9079
1,096	210	MAR	44	3,454	20.6450
1,097	452	BI	02	1,116	20.6084
1,098	423	SB	02	1,997	20.6024
1,099	1234	AM	07	20	20.6000
1,100	483	CL	05	1,017	20.3048
1,101	254	HOC	06	2,372	20.2374
1,102	931	IM	41	1,423	20.1307
1,103	957	WT	07	1,566	20.0204

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,104	316	CG	02	1,711	19.7440
1,105	366	WEB	06	565	19.5805
1,106	1123	HY	07	1,043	19.5628
1,107	1102	OA	02	224	19.3482
1,108	873	SH	01	1,408	19.1925
1,109	1022	KT	45	3,088	19.1885
1,110	1049	RO	06	995	19.1437
1,111	503	DR	07	1,295	19.0865
1,112	345	CL	09	451	18.9645
1,113	937	CV	03	1,899	18.9336
1,114	1001	RE	01	359	18.8914
1,115	652	ED	04	1,959	18.8754
1,116	1179	MAR	41	3,457	18.8585
1,117	913	RE	08	873	18.8534
1,118	209	ST	03	1,165	18.8094
1,119	NEW	WD	46	2,503	18.7087
1,120	591	RE	06	1,081	18.6846
1,121	687	NS	05	2,839	18.6823
1,122	1182	CK	03	838	18.6456
1,123	1053	KM	01	1,995	18.6030
1,124	923	HR	02	1,132	18.5724
1,125	535	EU	02	141	18.4752
1,126	1215	LK	08	434	18.4124
1,127	1227	GA	05	1,144	18.3243
1,128	867	ED	02	1,442	18.2594
1,129	1216	DV	09	2,222	18.1935
1,130	NEW	FZ	48	4,280	17.8724
1,131	481	JN	05	1,686	17.7390
1,132	203	AR	43	2,772	17.7024
1,133	989	VV	09	1,785	17.6454
1,134	68	SR	15	1,891	17.6388
1,135	1086	EC	10	342	17.2924
1,136	828	HE	09	425	17.2306
1,137	1237	FW	01	1,955	17.2297
1,138	471	AN	05	1,638	17.0311
1,139	1176	ST	15	1,063	17.0028
1,140	1065	FT	03	935	16.8310
1,141	162	LP	06	534	16.7491
1,142	699	EL	09	612	16.7157
1,143	1256	HT	05	866	16.6074
1,144	1223	FAN	45	1,453	16.4370
1,145	295	CV	02	1,656	16.4348
1,146	1214	EU	01	143	16.3077
1,147	204	WO	09	267	16.2509
1,148	NEW	TRN	01	1,141	16.0657
1,149	403	CV	04	284	15.9437

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,150	1283	BR	14	781	15.9052
1,151	479	CB	04	1,666	15.8139
1,152	659	BI	42	1,360	15.7110
1,153	1248	FT	06	795	15.6478
1,154	1026	AF	03	1,960	15.6107
1,155	772	PW	08	1,728	15.4971
1,156	949	IM	45	3,724	15.3848
1,157	343	SR	12	1,697	15.3760
1,158	970	KM	04	1,441	15.3407
1,159	199	UV	03	852	15.3075
1,160	1142	GT	05	1,773	15.2713
1,161	917	DN	04	1,658	15.2027
1,162	1035	SA	45	5,364	15.1734
1,163	754	RS	07	440	15.0932
1,164	987	CR	06	662	15.0634
1,165	541	SP	03	1,624	14.9975
1,166	1186	MY	07	1,038	14.9268
1,167	927	EU	06	307	14.8795
1,168	1072	VW	06	1,505	14.7555
1,169	107	PO	09	1,979	14.6832
1,170	441	KDL	44	3,688	14.5887
1,171	197	CB	09	1,728	14.5457
1,172	951	BM	05	692	14.5376
1,173	797	PE	05	2,001	14.4658
1,174	798	BI	41	1,622	14.2090
1,175	1138	FD	12	1,799	14.1584
1,176	784	TO	03	389	14.1414
1,177	597	HA	07	1,575	14.0432
1,178	1241	OB	43	1,698	14.0053
1,179	1044	EU	10	243	14.0041
1,180	477	SA	50	1,100	13.9045
1,181	43	DE	01	709	13.8886
1,182	232	EU	11	1,665	13.8517
1,183	1218	KB	02	382	13.7592
1,184	1313	PK	47	12	13.6667
1,185	1124	JP	03	28	13.3214
1,186	932	WO	07	790	13.3038
1,187	374	VW	01	703	13.2774
1,188	1046	STF	02	442	13.0837
1,189	1109	JN	10	2,840	12.9056
1,190	910	PZ	44	2,210	12.8643
1,191	378	HG	08	20	12.7000
1,192	1278	HP	05	1,945	12.6231
1,193	624	AI	06	106	12.5849
1,194	866	KT	42	2,336	12.3313
1,195	806	ED	08	1,263	12.3199

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,196	958	SR	09	73	12.1507
1,197	464	RO	07	2,235	12.1356
1,198	725	SP	10	1,118	11.6977
1,199	930	OA	03	29	11.6552
1,200	64	HG	06	856	11.6355
1,201	1230	FL	44	5,926	11.6075
1,202	581	DV	07	786	11.5573
1,203	1021	DN	11	2,408	11.2679
1,204	420	BH	06	163	11.1350
1,205	875	PO	08	1,829	11.1137
1,206	838	BI	08	1,022	10.9951
1,207	1252	CA	05	914	10.9792
1,208	398	GA	08	64	10.9063
1,209	102	BW	07	1,890	10.8550
1,210	235	WF	03	566	10.7951
1,211	1089	GA	02	1,701	10.7831
1,212	1293	BR	06	15	10.7333
1,213	1129	CK	04	1,425	10.7186
1,214	1155	CK	02	1,023	10.5885
1,215	711	CA	04	1,540	10.5773
1,216	844	SR	06	60	10.4500
1,217	70	AF	12	317	10.3186
1,218	1196	GS	29	281	10.2135
1,219	1280	WZ	48	1,164	10.0473
1,220	337	SH	08	1,837	10.0310
1,221	936	MDY	02	381	9.9580
1,222	559	OA	06	1,772	9.8538
1,223	948	THW	47	3,223	9.8231
1,224	365	DR	09	422	9.7156
1,225	744	IND	03	37	9.2973
1,226	1219	GT	10	1,026	9.1774
1,227	1135	WI	01	2,227	9.1459
1,228	829	CG	01	440	9.0932
1,229	1100	DN	08	1,009	9.0248
1,230	77	ST	16	1,380	9.0239
1,231	1300	GP	02	29	9.0000
1,232	1153	BI	45	3,199	8.9834
1,233	1211	SF	01	573	8.8220
1,234	671	HM	01	431	8.8190
1,235	1067	KT	02	666	8.7357
1,236	1201	HM	07	861	8.6179
1,237	1097	HA	06	1,224	8.4910
1,238	1204	EU	07	1,525	8.3921
1,239	486	BW	01	33	7.6667
1,240	1131	CYF	42	5,205	7.6148
1,241	1058	TB	02	829	7.6031

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,242	328	HP	04	668	7.4895
1,243	678	RO	41	1,310	7.4015
1,244	532	BT	02	1,817	7.3709
1,245	1132	BM	02	138	7.2319
1,246	234	SA	42	3,024	7.2199
1,247	1052	FT	08	716	7.1899
1,248	1016	KN	01	937	7.1387
1,249	250	DV	08	977	7.0338
1,250	1225	IND	02	17	7.0000
1,251	835	HT	02	3,571	6.7709
1,252	1106	TV	05	58	6.4310
1,253	1050	MY	03	1,671	6.3668
1,254	736	DV	11	1,089	6.3572
1,255	1312	PK	45	31	6.1935
1,256	1096	CR	07	89	6.1910
1,257	1307	KB	13	30	6.1667
1,258	1031	KB	19	1,094	5.9488
1,259	211	PK	02	19	5.9474
1,260	942	JN	07	1,682	5.9191
1,261	1203	WE	01	217	5.2442
1,262	1173	BG	05	573	5.1204
1,263	1254	MID	02	782	5.0742
1,264	833	WI	03	267	5.0637
1,265	319	WZ	46	191	4.9529
1,266	1245	HL	02	98	4.7551
1,267	709	KB	10	638	4.7022
1,268	462	UL	48	2,044	4.5744
1,269	646	UW	04	669	4.4111
1,270	1226	KN	03	13	4.3077
1,271	1261	KM	03	99	4.2222
1,272	1270	SF	07	878	4.1686
1,273	941	HM	08	1,016	4.1024
1,274	1288	SR	14	185	3.9135
1,275	409	MB	09	1,244	3.8730
1,276	1239	HV	01	1,028	3.8599
1,277	975	BW	03	14	3.4286
1,278	1069	UL	04	1,054	3.0531
1,279	1253	FW	02	1,087	2.9558
1,280	400	JN	01	2,149	2.8348
1,281	1231	HY	02	1,636	2.4187
1,282	1228	CL	04	52	2.1731
1,283	720	PK	42	19	2.1579
1,284	1268	WEB	08	386	2.0648
1,285	730	THW	43	1,914	1.9896
1,286	1277	GN	11	404	1.8936
1,287	1160	WO	10	245	1.6694

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,288	171	SR	01	38	1.6316
1,289	1281	EC	01	574	1.3554
1,290	1284	DV	04	888	1.1261
1,291	809	SF	08	73	1.1096
1,292	1272	HV	05	704	1.0753
1,293	1310	PK	43	64	1.0000
1,294	999	BG	04	1,376	0.8874
1,295	1276	SH	10	1,275	0.8110
1,296	344	SR	03	384	0.5052
1,297	683	HP	01	1,910	0.5042
1,298	686	HT	08	860	0.3430
1,299	823	CK	06	880	0.2864
1,300	1290	KB	18	707	0.0976
1,301	1265	ED	01	1,735	0.0594
1,302	1287	KB	17	991	0.0474
1,303	1282	SF	43	595	0.0420
1,304	83	BI	43	776	0.0000
1,305	1294	DT	19	14	0.0000
1,306	1263	DT	24	24	0.0000
1,307	1295	DT	26	51	0.0000
1,308	1296	DT	32	22	0.0000
1,309	1297	GG	05	11	0.0000
1,310	968	GN	13	14	0.0000
1,311	1298	GN	41	18	0.0000
1,312	534	GN	42	20	0.0000
1,313	1299	GN	45	22	0.0000
1,314	795	GN	48	18	0.0000
1,315	859	GP	09	50	0.0000
1,316	1301	GR	03	34	0.0000
1,317	1255	GR	04	26	0.0000
1,318	1302	GS	02	13	0.0000
1,319	928	GS	06	260	0.0000
1,320	1303	GS	09	105	0.0000
1,321	1304	GS	23	156	0.0000
1,322	1202	GT	02	164	0.0000
1,323	814	IT	01	97	0.0000
1,324	1305	IT	03	11	0.0000
1,325	1175	JP	04	29	0.0000
1,326	1306	KB	08	28	0.0000
1,327	1309	PK	41	457	0.0000
1,328	1311	PK	44	13	0.0000
1,329	1251	PK	46	52	0.0000
1,330	1314	SF	09	216	0.0000
1,331	1315	SF	10	93	0.0000
1,332	1092	SF	11	11	0.0000
1,333	1316	SF	12	50	0.0000

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1,334	544	SF	45	774	0.0000
1,335	1157	UL	14	61	0.0000

Service Quality Report to the Public Utility Commission of Texas

CenterPoint Energy

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2005 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	23.09%
Vegetation	13.12%
Animals and Birds	14.70%
People (Including cars and farm equip)	5.00%
Utility-owned Equipment	22.63%
Other	4.16%
Unknown	17.30%