




Control Number: 32237



Item Number: 15

Addendum StartPage: 0

February 14, 2006

Mr. James Galloway
Filing Clerk
Public Utility Commission of Texas
1701 N. Congress
Austin, TX 78711

RECEIVED
2006 FEB 14 PM 2:55
PUBLIC UTILITY COMMISSION

Dear Mr. Galloway,

Attached please find the Reliability and Continuity of Service Report for the reporting year 2005 for Southwestern Electric Power Company (SWEPCO), for its Texas operations. This report is filed in accordance with Substantive Rule Section 25.81, Project 32237.

Sincerely,



Randal E. Roper
Regulatory Case Manager, AEPSC

Attachment

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2005 Reporting Year

Southwestern Electric Power Company

Project 32237

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2005	1.814	0.05	0.04	0.10	0.17	0.22	0.17	0.20	0.32	0.12	0.11	0.12	0.19
Scheduled 2005	0.018	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Outside Causes 2005	0.143	0.00	0.00	0.05	0.01	0.01	0.00	0.02	0.00	0.00	0.01	0.02	0.03
Major Events 2005	0.610	0.00	0.00	0.00	0.00	0.00	0.00	0.11	0.00	0.50	0.00	0.00	0.00

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2005	156.5	4.7	2.7	6.8	15.2	16.6	11.7	18.0	33.2	8.0	8.2	13.6	17.8
Scheduled													
2005	0.6	0.0	0.0	0.1	0.1	0.0	0.1	0.0	0.0	0.1	0.1	0.0	0.1
Outside Causes													
2005	14.0	0.0	0.0	4.5	0.4	1.2	0.0	0.4	0.1	0.0	3.3	2.2	1.6
Major Events													
2005	591.8	0.0	0.0	0.0	0.0	0.0	0.0	8.1	0.0	583.7	0.0	0.0	0.0

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or More Customers

Total Number of Feeders

251

Add or Delete Rows as Necessary

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
1	51	CLARKSVILLE	9200	621	7.515
2	9	LEVERETTS CHAPEL	5700	129	7.326
3	3	HOWELL	2B60	536	5.959
4	17	LONDON	5950	269	5.190
5	22	GRAND SALINE	7110	1,530	5.175
6	54	HOOKS	10950	495	5.016
7	65	AIRLINE	1N30	1,480	4.795
8	31	HAWKINS	2520	356	4.778
9	81	HAWKINS	9410	206	4.539
10	14	FRIARS SWITCH	1900	151	4.490
11	146	NEW HOPE	2120	100	4.370
12	234	LAKE LAMOND	9440	350	4.211
13	23	HAWKINS	2530	78	4.090
14	202	MINEOLA	10990	1,027	3.929
15	82	TEXARKANA OPERATIONS	1S80	999	3.745
16	84	WASKOM	8180	908	3.653
17	201	AIRLINE	1E90	1,169	3.609
18	240	SUPERIOR	3750	37	3.541
19	212	LONGVIEW HEIGHTS	9240	935	3.536
20	25	PLILER ROAD	10370	2,624	3.521
21	15	FRIARS SWITCH	5790	343	3.478
22	247	GATES STREET	1X60	337	3.418
23	176	LAKE LAMOND	4400	695	3.416
24	174	39TH STREET	2630	1,324	3.382
25	144	EVENSIDE	1F90	1,675	3.377
26	77	LONGVIEW HEIGHTS	8430	721	3.300
27	189	LAKE LAMOND	1380	1,759	3.271
28	133	WHITNEY	4420	497	3.241

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
29	64	CLARKSVILLE	3660	154	3.234
30	206	TEXARKANA OPERATIONS	11630	532	3.207
31	7	SABINE	5130	1,233	3.195
32	115	GATES STREET	1X70	295	3.169
33	2	TEXARKANA PLANT	6570	79	3.152
34	188	GATES STREET	1X40	738	3.125
35	225	LAKE LAMOND	9770	270	3.104
36	139	NEW GLADEWATER	11970	1,617	2.991
37	116	LAKE LAMOND	6850	546	2.984
38	160	BECKVILLE	1U50	348	2.960
39	66	KINGS HWY	9040	1,626	2.940
40	57	NEW GLADEWATER	11980	1,006	2.913
41	101	HOWELL	2B90	256	2.855
42	106	PLILER ROAD	12470	1,322	2.831
43	242	VIVIAN	8990	739	2.824
44	230	CLARKSVILLE	3670	173	2.809
45	21	GRAND SALINE	7120	830	2.749
46	119	NORTH MARSHALL	8660	537	2.745
47	214	AIRLINE	1F00	1,188	2.738
48	61	TURNERTOWN	1B00	19	2.737
49	26	POYNTER	7800	146	2.733
50	228	LAKE LAMOND	6860	39	2.718
51	67	HALLSVILLE	5720	1,078	2.704
52	88	DAINGERFIELD	1970	637	2.694
53	112	FRIARS SWITCH	5920	203	2.675
54	216	TEXARKANA OPERATIONS	1S90	196	2.638
55	248	VIVIAN	8980	625	2.610
56	10	LAKE LAMOND	4070	1,818	2.580
57	41	LAKE LAMOND	8570	725	2.548
58	18	EVENSIDE	1G00	744	2.534
59	208	EVENSIDE	1G10	1,035	2.529
60	45	DAINGERFIELD	1960	1,096	2.510
61	46	CENTER	8140	935	2.493

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
62	126	ALBA	12400	521	2.488
63	239	WEST MT PLEASANT	1L00	437	2.453
64	209	LAKE LAMOND	9430	533	2.452
65	70	TURNERTOWN	1B20	354	2.421
66	29	KILGORE	3090	360	2.417
67	8	LONDON	5940	290	2.376
68	198	NEW BOSTON	9620	361	2.368
69	100	NORTH MARSHALL	9800	1,302	2.356
70	220	PITTSBURG	5460	1,357	2.346
71	142	HALLSVILLE	2380	607	2.344
72	90	LONDON	5930	430	2.344
73	102	HAWKINS	6310	108	2.306
74	117	NORTH MARSHALL	8670	828	2.278
75	163	AIRLINE	1S30	135	2.259
76	20	CENTER	2190	1,014	2.225
77	24	NORTH MARSHALL	7600	549	2.219
78	187	DEKALB	2430	870	2.216
79	40	WASKOM	7890	479	2.215
80	168	LIBERTY CITY	7990	763	2.212
81	62	ATLANTA	2150	587	2.199
82	95	SCOTTSVILLE	1J30	424	2.191
83	113	NEW BOSTON	1620	907	2.190
84	33	LEVERETT'S CHAPEL	10850	303	2.178
85	104	MT PLEASANT	1920	871	2.169
86	83	ATLANTA	1U80	635	2.151
87	73	RICHMOND ROAD	6980	1,048	2.147
88	125	HOOKS	10960	1,362	2.145
89	193	KILGORE	4650	558	2.109
90	211	39TH STREET	1V60	655	2.070
91	58	POYNTER	7680	869	2.067
92	39	NORTH LANEVILLE	10660	418	2.065
93	179	TAYLOR STREET	9510	1,243	2.057
94	135	LONGVIEW	6770	995	2.035

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
95	59	GILMER	2490	1,565	2.011
96	49	LONGVIEW	5520	1,156	1.993
97	68	ATLANTA	8070	265	1.958
98	50	BIG SANDY	7300	635	1.953
99	182	SOUTHEAST MARSHALL	10180	1,265	1.949
100	92	SOUTHEAST MARSHALL	7580	924	1.937
101	165	MINEOLA	7130	1,203	1.883
102	136	LOGANSPOUT	5770	227	1.824
103	86	WHITNEY	1480	1,676	1.800
104	194	TAYLOR STREET	4290	946	1.794
105	140	GREGGTON	1V20	1,526	1.773
106	55	LOUISIANA PACIFIC	2260	560	1.754
107	190	WHITNEY	1A00	628	1.753
108	151	39TH STREET	2640	617	1.746
109	52	FRIARS SWITCH	5780	141	1.738
110	97	PETTY	11460	814	1.736
111	153	LONE STAR POWER PLANT	6120	15	1.733
112	175	DEKALB	2440	528	1.729
113	195	MONROE CORNERS	6510	48	1.688
114	5	39TH STREET	1V70	70	1.686
115	36	KILGORE	7850	95	1.684
116	197	TAYLOR STREET	6760	1,152	1.681
117	200	TEXARKANA OPERATIONS	7830	830	1.646
118	79	TAYLOR STREET	7920	403	1.643
119	122	ATLANTA	2140	1,851	1.641
120	171	NEW HOPE	8000	1,495	1.621
121	96	DAINGERFIELD	1950	150	1.613
122	99	TAYLOR STREET	220	1,178	1.583
123	180	CARTHAGE	5760	891	1.562
124	109	SOUTHEAST MARSHALL	10160	1,552	1.544
125	44	SPRINGHILL	6870	750	1.533
126	129	MARSHALL	590	440	1.530
127	172	WHITNEY	4080	874	1.501

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
128	185	CLARKSVILLE	9180	402	1.493
129	217	WHITNEY	4090	333	1.462
130	35	CLARKSVILLE	9210	937	1.434
131	1	TURNERTOWN	1B10	30	1.433
132	118	AIRLINE	1F10	680	1.419
133	205	WHITNEY	1490	1,596	1.389
134	80	NAPLES	8720	201	1.388
135	154	BECKVILLE	9120	282	1.309
136	87	ATLANTA	4460	1,062	1.305
137	11	POYNTER	7590	941	1.285
138	107	GILMER	2480	585	1.279
139	138	CARTHAGE	3370	705	1.268
140	224	WINFIELD	2B70	504	1.256
141	98	KINGS HWY	9030	905	1.209
142	12	HARRISON ROAD	11870	338	1.204
143	94	WINNSBORO	1P00	730	1.188
144	244	WEST MT PLEASANT	1G70	94	1.170
145	16	12TH STREET	2230	103	1.165
146	169	MARSHALL	580	880	1.157
147	105	KILGORE	3150	581	1.157
148	145	KINGS HWY	9540	1,355	1.152
149	60	SUGAR HILL	2690	1,413	1.134
150	6	HARRISON ROAD	11880	3,628	1.120
151	143	KNOX LEE	1U90	155	1.097
152	235	MARSHALL UPTOWN	3210	231	1.078
153	19	GILMER	2450	778	1.069
154	184	PITTSBURG	5450	991	1.068
155	238	JEFFERSON 69KV	9350	122	1.066
156	75	CARTHAGE	10240	1,007	1.063
157	32	LOUISIANA PACIFIC	8030	329	1.058
158	223	GREGGTON	1F60	84	1.024
159	78	WESTWOOD	3710	46	1.022
160	120	HUGHES SPRINGS	5650	546	1.020

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
161	155	HOWELL	2B80	1,351	1.020
162	192	WINFIELD	4100	102	1.020
163	108	TEXARKANA OPERATIONS	7240	1,469	1.008
164	149	POYNTER	3270	779	1.003
165	249	MARSHALL UPTOWN	3220	103	1.000
166	69	IPC JEFFERSON	8020	839	0.967
167	204	MT VERNON	12760	859	0.962
168	215	LEVERETTS CHAPEL	5200	455	0.934
169	4	SPRINGHILL	8190	664	0.919
170	199	TAYLOR STREET	5080	536	0.916
171	156	CLARKSVILLE	9190	935	0.908
172	85	RICHMOND ROAD	5290	1,212	0.903
173	123	SABINE	5110	75	0.893
174	213	RICHMOND ROAD	4020	802	0.885
175	28	GREGGTON	1F50	265	0.883
176	167	DEKALB	3200	346	0.835
177	170	KILGORE	7190	661	0.834
178	137	POYNTER	9550	311	0.817
179	164	TEXARKANA PLANT	7960	1,436	0.811
180	91	NEW BOSTON	5140	1,347	0.781
181	71	KILGORE	7860	371	0.779
182	121	NAPLES	3290	511	0.763
183	110	JEFFERSON 69KV	9340	944	0.757
184	241	MONROE CORNERS	6520	180	0.728
185	229	PETTY	8370	96	0.719
186	76	PLILER ROAD	10380	3,028	0.647
187	124	MINEOLA	9360	512	0.645
188	251	12TH STREET	6180	49	0.633
189	34	WASKOM	7900	287	0.606
190	173	CARTHAGE	3360	350	0.606
191	63	SOUTHEAST LONGVIEW	1780	502	0.604
192	196	GREGGTON	1F70	1,673	0.592
193	37	CENTER	9520	990	0.585

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
194	114	NEW BOSTON	9610	862	0.582
195	207	LONGVIEW HEIGHTS	1B40	1,095	0.578
196	181	PETTY	11470	1,125	0.575
197	148	SCOTTSVILLE	1J10	758	0.571
198	47	SPRINGHILL	8200	510	0.551
199	132	COOKVILLE	1E70	179	0.547
200	218	SOUTHEAST MARSHALL	10920	718	0.519
201	191	KILGORE	7870	396	0.518
202	232	LONGVIEW	5550	112	0.509
203	210	BLOOMBURG	7350	319	0.505
204	42	NAPLES	8730	873	0.487
205	159	LINDEN	10020	334	0.464
206	233	HUGHES SPRINGS	1Z00	736	0.457
207	161	CARTHAGE	3350	529	0.446
208	221	LINDEN	2540	980	0.442
209	226	WINNSBORO	2050	1,068	0.439
210	56	MT VERNON	9140	343	0.408
211	30	SUGAR HILL	2370	333	0.399
212	183	TENAHA	2500	401	0.389
213	93	TATUM	10840	658	0.388
214	246	SOUTHEAST LONGVIEW	4190	52	0.385
215	157	TENAHA	2510	319	0.382
216	74	BIG SANDY	7310	632	0.380
217	203	PITTSBURG	8680	266	0.376
218	53	SABINE	5120	59	0.373
219	131	CENTER	2180	20	0.350
220	227	RICHMOND ROAD	8050	1,075	0.345
221	147	RICHMOND ROAD	1L40	677	0.341
222	38	MARSHALL	2000	228	0.329
223	43	PILGRIMS PRIDE	6150	827	0.328
224	162	HARRISON ROAD	8040	65	0.323
225	72	MINEOLA	3680	380	0.303
226	177	IPC 69KV	1R60	31	0.290

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or More Customers

Total Number of Feeders

251

Add or Delete Rows as Necessary

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
1	83	NEW HOPE	2120	100	1,198.0
2	215	LAKE LAMOND	6860	39	1,015.1
3	25	LEVERETTS CHAPEL	5700	129	894.6
4	245	WEST MT PLEASANT	1G70	94	855.6
5	1	HOWELL	2B60	536	806.9
6	10	FRIARS SWITCH	1900	151	656.4
7	93	TURNERTOWN	1B00	19	615.0
8	39	FRIARS SWITCH	5790	343	598.9
9	126	DAINGERFIELD	1970	637	589.1
10	17	HOOKS	10950	495	568.8
11	127	SUPERIOR	3750	37	536.4
12	44	CLARKSVILLE	9200	621	526.1
13	69	DAINGERFIELD	1960	1,096	514.1
14	28	WASKOM	7890	479	510.0
15	164	LAKE LAMOND	4400	695	503.4
16	27	HAWKINS	2530	78	477.4
17	229	TEXARKANA OPERATIONS	1S90	196	475.5
18	18	LONDON	5950	269	473.6
19	79	LONE STAR POWER PLANT	6120	15	466.1
20	92	PETTY	11460	814	407.9
21	76	LONGVIEW HEIGHTS	8430	721	401.9
22	144	BECKVILLE	1U50	348	384.8
23	231	PITTSBURG	5460	1,357	378.4
24	207	AIRLINE	1F00	1,188	370.5
25	59	DAINGERFIELD	1950	150	368.0
26	20	BIG SANDY	7300	635	355.9
27	38	TURNERTOWN	1B20	354	354.0
28	242	VIVIAN	8990	739	352.1

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
29	11	TEXARKANA PLANT	6570	79	346.3
30	13	LEVERETTS CHAPEL	10850	303	339.3
31	23	SABINE	5130	1,233	332.3
32	247	GATES STREET	1X60	337	329.9
33	134	SCOTTSVILLE	1J30	424	319.8
34	189	LONGVIEW HEIGHTS	9240	935	308.9
35	236	WEST MT PLEASANT	1L00	437	305.5
36	48	CENTER	2190	1,014	301.4
37	86	ALBA	12400	521	300.7
38	131	AIRLINE	1S30	135	299.7
39	99	BECKVILLE	9120	282	299.3
40	155	HAWKINS	9410	206	298.5
41	71	EVENSIDE	1G00	744	295.9
42	33	GRAND SALINE	7110	1,530	294.6
43	218	MINEOLA	10990	1,027	293.2
44	159	WASKOM	8180	908	274.6
45	3	KILGORE	3090	360	262.3
46	74	LONDON	5930	430	260.3
47	230	CLARKSVILLE	3670	173	260.2
48	125	NEW GLADEWATER	11970	1,617	259.8
49	137	EVENSIDE	1F90	1,675	252.2
50	199	AIRLINE	1E90	1,169	251.5
51	56	HAWKINS	2520	356	249.6
52	114	GATES STREET	1X70	295	245.1
53	16	PLILER ROAD	12470	1,322	242.9
54	34	39TH STREET	1V70	70	242.5
55	91	ATLANTA	8070	265	241.5
56	37	NORTH LANEVILLE	10660	418	240.7
57	227	JEFFERSON 69KV	9350	122	234.8
58	30	GREGGTON	1F50	265	232.3
59	174	WHITNEY	4420	497	230.8
60	72	FRIARS SWITCH	5780	141	227.2
61	94	MT PLEASANT	1920	871	227.2

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
62	184	EVENSIDE	1G10	1,035	224.1
63	19	CENTER	8140	935	222.6
64	45	PLILER ROAD	10370	2,624	221.8
65	221	WHITNEY	4090	333	221.0
66	135	LIBERTY CITY	7990	763	218.3
67	84	WINNSBORO	1P00	730	216.0
68	152	DEKALB	2440	528	214.4
69	182	LAKE LAMOND	1380	1,759	212.3
70	89	AIRLINE	1N30	1,480	212.1
71	52	RICHMOND ROAD	6980	1,048	206.4
72	194	SOUTHEAST MARSHALL	10180	1,265	201.5
73	12	LONDON	5940	290	199.9
74	130	LONGVIEW	6770	995	198.9
75	77	HALLSVILLE	5720	1,078	198.1
76	118	39TH STREET	2640	617	195.4
77	214	TEXARKANA OPERATIONS	11630	532	193.4
78	101	NAPLES	8720	201	192.5
79	73	NEW GLADEWATER	11980	1,006	190.2
80	185	NEW BOSTON	9620	361	188.1
81	196	LEVERETTS CHAPEL	5200	455	182.3
82	65	LONGVIEW	5520	1,156	181.7
83	172	GATES STREET	1X40	738	181.2
84	24	LAKE LAMOND	6850	546	177.5
85	165	MT VERNON	12760	859	176.7
86	203	HOWELL	2B90	256	173.2
87	112	KINGS HWY	9040	1,626	172.6
88	179	KILGORE	7190	661	172.2
89	5	SPRINGHILL	8190	664	172.1
90	201	KILGORE	4650	558	169.7
91	49	GRAND SALINE	7120	830	167.9
92	96	RICHMOND ROAD	5290	1,212	167.1
93	4	POYNTER	7800	146	167.1
94	88	CARTHAGE	10240	1,007	167.0

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
95	198	NORTH MARSHALL	8670	828	164.1
96	66	CLARKSVILLE	9210	937	163.7
97	177	PETTY	11470	1,125	163.6
98	146	NEW HOPE	8000	1,495	161.4
99	243	PETTY	8370	96	159.6
100	41	LOGANSPOUT	5770	227	156.8
101	163	MARSHALL	580	880	156.5
102	120	HOOKS	10960	1,362	155.8
103	40	CLARKSVILLE	3660	154	155.2
104	14	GILMER	2450	778	152.8
105	206	39TH STREET	2630	1,324	152.4
106	151	TEXARKANA OPERATIONS	1580	999	152.3
107	21	POYNTER	7680	869	152.0
108	138	NORTH MARSHALL	9800	1,302	151.5
109	113	WHITNEY	1480	1,676	145.1
110	50	ATLANTA	2150	587	142.7
111	61	GILMER	2490	1,565	141.8
112	235	LAKE LAMOND	9440	350	140.2
113	190	DEKALB	2430	870	137.9
114	102	NORTH MARSHALL	7600	549	136.7
115	35	WASKOM	7900	287	136.5
116	202	NORTH MARSHALL	8660	537	135.0
117	180	MONROE CORNERS	6510	48	131.4
118	75	SOUTHEAST LONGVIEW	1780	502	129.8
119	208	TAYLOR STREET	9510	1,243	129.6
120	58	LOUISIANA PACIFIC	2260	560	128.6
121	161	SOUTHEAST MARSHALL	7580	924	125.9
122	186	MINEOLA	7130	1,203	124.6
123	22	KILGORE	7850	95	123.3
124	7	HARRISON ROAD	11880	3,628	123.2
125	149	HOWELL	2880	1,351	122.9
126	64	LAKE LAMOND	8570	725	122.8
127	26	FRIARS SWITCH	5920	203	122.7

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
128	85	GILMER	2480	585	121.5
129	167	PITTSBURG	5450	991	120.0
130	116	WHITNEY	4080	874	120.0
131	248	SOUTHEAST LONGVIEW	4190	52	119.6
132	36	LAKE LAMOND	4070	1,818	119.2
133	51	LOUISIANA PACIFIC	8030	329	117.3
134	192	WHITNEY	1A00	628	115.9
135	117	AIRLINE	1F10	680	115.7
136	162	KNOX LEE	1U90	155	113.4
137	119	SOUTHEAST MARSHALL	10160	1,552	112.6
138	169	WHITNEY	1490	1,596	108.5
139	188	GREGGTON	1F70	1,673	107.6
140	211	LAKE LAMOND	9770	270	105.4
141	157	DEKALB	3200	346	103.1
142	57	POYNTER	3270	779	100.8
143	140	GREGGTON	1V20	1,526	99.1
144	80	KINGS HWY	9030	905	97.9
145	209	39TH STREET	1V60	655	95.9
146	103	NAPLES	3290	511	93.4
147	156	HALLSVILLE	2380	607	92.9
148	141	SABINE	5110	75	91.2
149	204	CARTHAGE	5760	891	90.0
150	195	WINFIELD	4100	102	89.0
151	223	LAKE LAMOND	9430	533	87.4
152	139	KILGORE	3150	581	87.0
153	160	HUGHES SPRINGS	5650	546	87.0
154	132	HAWKINS	6310	108	85.4
155	183	TEXARKANA OPERATIONS	7240	1,469	85.3
156	2	TURNERTOWN	1B10	30	85.0
157	210	WINFIELD	2B70	504	82.2
158	142	TAYLOR STREET	220	1,178	81.5
159	55	SUGAR HILL	2690	1,413	80.2
160	168	NEW BOSTON	1620	907	78.8

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
161	9	12TH STREET	2230	103	78.1
162	107	SCOTTSVILLE	1J10	758	78.0
163	110	ATLANTA	2140	1,851	77.7
164	100	TEXARKANA PLANT	7960	1,436	77.0
165	6	WESTWOOD	3710	46	77.0
166	90	ATLANTA	1U80	635	75.2
167	217	TAYLOR STREET	4290	946	74.9
168	136	POYNTER	9550	311	72.8
169	158	CLARKSVILLE	9190	935	72.7
170	150	TEXARKANA OPERATIONS	7830	830	72.5
171	241	HUGHES SPRINGS	1Z00	736	72.4
172	219	LONGVIEW HEIGHTS	1B40	1,095	72.3
173	166	GREGGTON	1F60	84	71.8
174	105	IPC JEFFERSON	8020	839	70.9
175	123	KINGS HWY	9540	1,355	70.5
176	78	PLILER ROAD	10380	3,028	70.5
177	81	KILGORE	7860	371	69.9
178	63	MT VERNON	9140	343	69.1
179	193	CLARKSVILLE	9180	402	69.0
180	111	MARSHALL	590	440	65.4
181	70	SPRINGHILL	6870	750	64.7
182	225	TAYLOR STREET	6760	1,152	60.3
183	178	WINNSBORO	2040	405	60.1
184	148	RICHMOND ROAD	1L40	677	59.3
185	67	SPRINGHILL	8200	510	57.9
186	154	JEFFERSON 69KV	9340	944	56.9
187	87	POYNTER	7590	941	52.5
188	104	ATLANTA	4460	1,062	52.0
189	226	LONGVIEW	5550	112	51.8
190	82	TAYLOR STREET	7920	403	50.8
191	115	COOKVILLE	1E70	179	50.6
192	143	CARTHAGE	3370	705	49.8
193	187	CARTHAGE	3360	350	49.7

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
194	233	SOUTHEAST MARSHALL	10920	718	49.5
195	224	RICHMOND ROAD	4020	802	48.2
196	237	MARSHALL UPTOWN	3210	231	47.1
197	68	PILGRIMS PRIDE	6150	827	45.1
198	246	VIVIAN	8980	625	45.1
199	234	WINNSBORO	2050	1,068	44.1
200	216	BLOOMBURG	7350	319	43.8
201	108	NEW BOSTON	5140	1,347	42.6
202	232	MONROE CORNERS	6520	180	42.4
203	46	CENTER	9520	990	41.2
204	249	MARSHALL UPTOWN	3220	103	40.6
205	31	MINEOLA	9360	512	40.4
206	197	TAYLOR STREET	5080	536	39.2
207	176	TENAHA	2500	401	37.3
208	106	TATUM	10840	658	36.9
209	47	BIG SANDY	7310	632	36.6
210	54	NAPLES	8730	873	36.4
211	62	CENTER	2180	20	36.0
212	15	HARRISON ROAD	11870	338	34.2
213	205	LINDEN	2540	980	33.6
214	191	KILGORE	7870	396	33.4
215	228	LONGVIEW	5510	858	31.8
216	121	MINEOLA	3680	380	30.8
217	122	TENAHA	2510	319	30.7
218	8	SABINE	5120	59	30.3
219	170	CARTHAGE	3350	529	29.8
220	173	PITTSBURG	8680	266	27.7
221	124	LINDEN	10020	334	27.0
222	133	NEW BOSTON	9610	862	26.5
223	53	MT PLEASANT	5370	344	26.4
224	181	HARRISON ROAD	8040	65	26.0
225	32	NORTH MINEOLA	5380	206	24.7
226	220	39TH STREET	2610	113	24.4

Service Quality Report to the Public Utility Commission of Texas

Southwestern Electric Power Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2005 Reporting Year

Causes of Forced Interruptions	Percentage
Animals and Birds	29.68%
Vegetation	26.36%
Weather (Including Lightning)	26.31%
Utility-owned Equipment	11.27%
People (Including cars and farm equip)	3.47%
Unknown	1.89%
Other	1.02%