




Control Number: 32237



Item Number: 19

Addendum StartPage: 0



Entergy Texas  
919 Congress Avenue  
Suite 840  
Austin, TX 78701  
Tel 512 487 3999  
Fax 512 487 3998

2006 FEB 15 PM 1:26

PUBLIC UTILITY COMMISSION  
FILING CLERK

February 14, 2006

Mr. T. Brian Almon  
Engineering Specialist  
Electric Division  
Public Utility Commission of Texas  
1701 N. Congress Avenue  
P. O. Box 13326  
Austin, Texas 78711-3326

**Re: PROJECT NO. 32237 - ENTERGY GULF STATES, INC.  
SERVICE QUALITY REPORT TO THE PUBLIC UTILITY COMMISSION OF TEXAS  
IN ACCORDANCE WITH SUBSTANTIVE RULE §25.81**

Dear Mr. Almon,

Attached you will find Entergy Gulf States, Inc. (EGSI) Service Quality Report to the Public Utility Commission of Texas for the annual period between January 1 and December 31, 2005. This report is the seventh filing in compliance with the Commission's Substantive Rule §25.81 of December 1999, using the set of targets established within Substantive Rule §25.52.

The report contains interruption data for all 403 Texas distribution feeders having more than ten (10) customers. The SAIFI and SAIDI distribution feeder lists rank the feeder reliability from worst to best. These distribution reliability indices are based on forced, sustained outages, excluding all major weather events.

This year it must be recognized that the impact of Hurricane Rita, which made landfall on September 24<sup>th</sup>, negatively affected the reliability of the Texas Distribution System through the balance of 2005.

Please feel free to contact me if you have any questions concerning the attached Service Quality Report and the data from this reporting period. You can reach me at (512) 487-3985.

Sincerely,

James M. Glazar  
Staff Engineer  
Regulatory Affairs Texas

Attachment

**Service Quality Report**  
To The  
**Public Utility Commission of Texas**  
In Accordance With  
**Substantive Rule §25.81**  
**2005 Reporting Year**

**Entergy Gulf States, Inc.**

**Project 32237**

Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

<b>System SAIFI</b>	<b>Annual</b>	<b>Jan</b>	<b>Feb</b>	<b>March</b>	<b>April</b>	<b>May</b>	<b>June</b>	<b>July</b>	<b>Aug</b>	<b>Sept</b>	<b>Oct</b>	<b>Nov</b>	<b>Dec</b>
<b>Forced</b>													
<b>2005</b>	1.74	0.09	0.08	0.08	0.14	0.16	0.13	0.25	0.28	0.06	0.12	0.18	0.15
<b>Scheduled</b>													
<b>2005</b>	0.02	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00
<b>Outside Causes</b>													
<b>2005</b>	0.24	0.06	0.03	0.00	0.01	0.00	0.02	0.03	0.02	0.00	0.01	0.01	0.03
<b>Major Events</b>													
<b>2005</b>	3.19	0.00	0.00	0.00	0.00	0.12	0.53	0.00	0.00	2.07	0.47	0.00	0.00

3

Service Quality Report to the Public Utility Commission of Texas

**Energy Gulf States, Inc.**

	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
<b>System SAIDI</b>													
<b>Forced</b>													
2005	154.70	8.66	7.53	6.06	9.97	13.01	11.19	27.89	26.67	2.93	10.23	15.70	14.87
<b>Scheduled</b>													
2005	1.29	0.08	0.21	0.06	0.09	0.30	0.17	0.03	0.09	0.03	0.09	0.08	0.05
<b>Outside Causes</b>													
2005	16.98	6.10	1.54	0.00	0.57	0.28	1.68	1.53	0.99	0.20	0.77	1.19	2.13
<b>Major Events</b>													
2005	7,160.91	0.00	0.00	0.00	0.00	19.76	108.24	0.00	0.00	6,364.99	667.92	0.00	0.00

4

# Service Quality Report to the Public Utility Commission of Texas

## Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

403

Add or Delete Rows as Necessary

### Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
1	13	LAKESIDE	L008F	84	10.55 *
2	27	WARREN	592WR	1,823	9.09 *
3	30	REBEL	119RB	461	8.11 *
4	218	ARCHIE	45ARC	90	7.47
5	188	CALVERT	4CAL	1,375	6.92
6	276	SPLENDORA	308SP	1,298	6.70
7	97	NECHES	194NE	422	6.63
8	15	CLEVELAND	425CV	1,382	6.46 *
9	106	LOVELLS LAKE	142LV	306	6.28
10	116	NECHES	193NE	595	6.25
11	274	SOUR LAKE	104SL	289	6.02
12	61	PARKDALE	176PR	508	5.94
13	103	CALVERT	6CAL	835	5.67
14	186	RIVTRIN	268RV	1,655	5.65
15	46	DOUCETTE	570DC	1,100	5.57
16	347	LAWSON	102LA	266	5.40
17	24	CROCKETT	198CR	48	5.19 *
18	393	ARCHIE	46ARC	21	5.10
19	29	DOUCETTE	568DC	563	4.96 *
20	21	PLEASURE	77PLS	146	4.95 *
21	43	LAKESIDE	L009F	75	4.79
22	99	LAKESIDE	5LAS	91	4.52
23	75	CROCKETT	65CRK	470	4.51
24	384	DE QUEEN	86DQN	272	4.50
25	207	BRIARCLIFF	30BRC	2,147	4.40
26	262	CORDREY	327CO	1,045	4.36
27	119	LUMBERTON	441LU	2,873	4.27
28	20	MAGNOLIA AMES	711MG	798	4.27 *
29	77	WARREN	506WR	1,539	4.25
30	93	DAYTON BULK	726DY	1,499	4.21
31	85	HEARNE	29HRN	305	4.13
32	307	FRANKLIN	7FKL	666	4.12
33	48	NAVASOTA	902NA	607	4.11
34	56	TYRRELL	37TYR	511	4.11
35	295	CONROE BULK	505CN	657	4.06
36	23	BEVIL	155BE	2,971	4.01 *
37	28	MAYHAW	671MA	1,722	3.96 *
38	4	WOODVILLE	594WD	1,119	3.93 *
39	247	ECHO	70ECH	1,476	3.83
40	100	HUMPHREY	107HM	1,367	3.80
41	54	DAYTON BULK	723DY	835	3.80
42	199	SPLENDORA	309SP	2,009	3.77
43	172	APOLLO	321AP	1,039	3.71

5

## Service Quality Report to the Public Utility Commission of Texas

### Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
44	133	HARDIN	35HDN	685	3.71
45	90	TAMINA	316TA	294	3.70
46	202	ELIZABETH	121EL	1,252	3.63
47	38	DAYTON BULK	724DY	2,055	3.62
48	18	RIVTRIN	269RV	2,942	3.61
49	360	FORT WORTH	54FTW	136	3.58
50	44	PORT NECHES	46PTN	1,270	3.47
51	193	BATSON	53BAT	860	3.43
52	60	HEARNE	25HRN	218	3.42
53	101	LAKESIDE	8LAS	36	3.42
54	64	TRINITY	261TR	585	3.41
55	19	OAK RIDGE	743OK	1,634	3.31
56	6	CRYSTAL	566CR	2,912	3.24
57	198	CLEVELAND	406CV	1,427	3.22
58		MEMORIAL	280ML	229	3.22
59	151	BRIDGE CITY	361BD	1,052	3.21
60	206	FLETCHER	456FL	708	3.20
61	132	DE QUEEN	84DQN	318	3.16
62	352	CROWDER	103CD	1,381	3.07
63	376	PORT ARTHUR WW	17WWK	409	3.06
64	286	HANKAMER	206HA	633	3.04
65	252	CHINA	92CHI	564	3.03
66	137	APOLLO	320AP	1,055	2.92
67	17	PEE DEE	809PD	1,481	2.87
68	117	ELIZABETH	120EL	1,321	2.86
69	37	GRIMES	982GR	669	2.82
70	179	OAK RIDGE	744OK	3,118	2.77
71	250	KOLBS	36KOL	1,301	2.77
72	3	KICKAPOO	251KP	1,090	2.73
73	264	BRIARCLIFF	32BRC	1,171	2.71
74	154	CLEVELAND	426CV	2,059	2.69
75	115	BRIARCLIFF	31BRC	867	2.68
76	57	DOUCETTE	569DC	165	2.67
77	177	MCHALE	112MC	659	2.66
78	240	SILSBEE	462SI	756	2.64
79	187	KOUNTZE BULK	435KT	41	2.59
80	196	AMELIA BULK	182AM	662	2.57
81	118	BEVIL	156BE	673	2.54
82	313	LONGMIRE	584LM	881	2.53
83	95	LINDBERGH	42LNB	1,680	2.53
84	144	LINDBERGH	40LNB	1,195	2.51
85	168	HICKORY RIDGE	341HI	1,355	2.48
86	166	LINDBERGH	41LNB	307	2.46
87	35	ROSEDALE	153RS	831	2.44
88	41	PEE DEE	808PD	2,186	2.44
89	96	CONAIR	514CN	1,358	2.43
90	271	GRIMES	883GR	807	2.41
91	2	ALDEN BRIDGE	762AL	1,848	2.40

6

# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
92	239	CALDWELL INDUSTRIAL	138CI	645	2.39
93	94	HUNTSVILLE	611HU	1,122	2.34
94	387	CROCKETT	60CRK	262	2.34
95	301	VIRGINIA	130VI	835	2.32
96	162	CONROE BULK	507CN	2,164	2.32
97	68	MCLEWIS	382MC	638	2.31
98	332	METRO	719ME	629	2.28
99	34	KOUNTZE BULK	432KT	801	2.27
100	221	OAK RIDGE	745OK	139	2.24
101	255	HAMPTON	158HA	1,146	2.24
102	152	NECHES	197NE	174	2.24
103	78	NAVASOTA	905NA	1,916	2.21
104	104	GROVES	59GRO	1,262	2.20
105	226	LACON	537LA	632	2.20
106	232	ROSEDALE	152RS	348	2.19
107	329	ORANGE	351ON	385	2.19
108	88	SPLENDORA	307SP	1,485	2.19
109	50	NEW CANEY	333NC	3,659	2.19
110	176	PORT ACRES SUB	68PTA	1,126	2.17
111	190	TEMCO	627TE	959	2.15
112	355	CORRIGAN BULK	239CR	510	2.13
113	91	CLEVELAND	405CV	1,542	2.11
114	167	MCDONALD	477MD	1,293	2.08
115	136	MCLEWIS	381MC	1,113	2.07
116	346	HIMEX	222HI	292	2.07
117	235	NEW CANEY	304NC	1,162	2.04
118	209	LAKESIDE	4LAS	61	2.02
119	1	EASTGATE	781EG	923	2.02
120	123	GOREE	682GR	1,516	2.01
121	36	SARATOGA	761SA	428	2.00
122	8	OAK RIDGE	742OK	2,073	2.00
123	243	HANKS	23HKS	1,292	1.95
124	7	GOSLIN	707GL	764	1.93
125	157	ORANGE	350ON	840	1.93
126	14	SILSBEE	463SI	587	1.92
127	149	WALDEN	564WD	4,066	1.90
128	259	ROSEDALE	151RS	1,141	1.90
129	74	MCDONALD	478MD	624	1.89
130	72	LILLARD	490LI	281	1.88
131	238	DAISETTA	743DA	341	1.87
132	308	NAVASOTA	904NA	1,180	1.86
133	299	GOSLIN	702GL	1,724	1.83
134	138	ALDEN BRIDGE	765AL	1,163	1.83
135	257	TESCO	36TSC	76	1.83
136	45	DAYTON BULK	727DY	775	1.82
137	284	SOUTH LIBERTY	714SL	152	1.82
138	268	CROWDER	104CD	1,561	1.81
139	59	HUNTSVILLE	607HU	2,911	1.79

7



# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
140	297	CONAIR	515CN	1,416	1.76
141	323	ORANGE	352ON	917	1.76
142	121	WEST END	85WED	507	1.75
143	287	CENTRAL	131CE	878	1.74
144	242	MILLEDGE	407MI	725	1.73
145	159	LINDBERGH	43LNB	721	1.72
146	129	TAMINA	317TA	1,258	1.72
147	58	ELIZABETH	122EL	963	1.72
148	269	TRANSCO	48TCO	175	1.70
149	98	LONGMIRE	580LM	287	1.70
150	194	FLETCHER	457FL	1,521	1.67
151	102	CRYSTAL	570CR	1,360	1.66
152	12	TEMCO	628TE	332	1.65
153	244	NEW CANEY	336NC	3,250	1.65
154	324	STONEGATE	93STG	2,062	1.64
155	32	DAYTON BULK	725DY	1,062	1.64
156	197	DOBBIN	519DO	1,671	1.63
157	53	PEE DEE	811PD	881	1.63
158	261	BLUE WATER	101BL	1,687	1.63
159	285	MCDONALD	476MD	1,008	1.62
160	114	MCDONALD	479MD	949	1.61
161	160	VIWAY	681VI	932	1.60
162	156	DOBBIN	920DO	1,317	1.59
163	31	NEW CANEY	337NC	2,202	1.55
164	69	OILLA	345OI	889	1.53
165	5	CHINA	93CHI	1,277	1.53
166	292	AMELIA BULK	180AM	1,188	1.53
167	273	KOUNTZE	452KT	390	1.52
168	354	TRAVIS	14TRV	16	1.50
169	67	TRINITY	262TR	110	1.50
170	141	CONAIR	512CN	1,829	1.50
171	311	WEST END	86WED	946	1.49
172	315	PANORAMA	525PA	1,120	1.49
173	260	CLEVELAND	403CV	1,821	1.49
174	373	METRO	716ME	1,846	1.47
175	339	GOSLIN	708GL	2,187	1.45
176	171	VIRGINIA	132VI	498	1.44
177	312	WINFREE	342WN	336	1.44
178	109	LOEB	17LOB	1,036	1.44
179	183	FRONT STREET	307FR	488	1.43
180	26	HANKS	25HKS	915	1.43
181	40	MANCHESTER	66MAN	1,542	1.42
182	303	SILSBEE	461SI	484	1.41
183	134	NORTH END	21NOE	1,759	1.39
184	25	NEW CANEY	335NC	2,545	1.38
185	22	TANGLEWOOD	134TG	2,290	1.36
186	11	ALDEN BRIDGE	763AL	1,053	1.36
187	143	TANGLEWOOD	137TG	1,375	1.36

8

# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
188	254	CRYSTAL	567CR	1,196	1.36
189	337	GROVES	61GRO	912	1.35
190	148	HUNTSVILLE	610HU	1,590	1.34
191	126	KOUNTZE	453KT	658	1.33
192	212	LACON	538LA	1,767	1.30
193	9	LOEB	18LOB	548	1.29
194	47	MCHALE	110MC	864	1.29
195	319	SPURLOCK	99SPU	533	1.29
196	333	CHEEK	166CH	23	1.26
197	178	RAYWOOD	74RAY	1,131	1.26
198	135	CENTRAL	133CE	1,556	1.26
199	320	YANKEE DOODLE	23YAN	608	1.25
200	192	ECHO	72ECH	506	1.24
201	234	WYNTEX	632WT	866	1.23
202	291	SOMERVILLE	126SO	846	1.22
203	326	PLANTATION	546PL	793	1.22
204	83	RAYWOOD	73RAY	487	1.21
205	163	CONAIR	516CN	254	1.21
206	203	MCLEWIS	380MC	2,133	1.19
207	181	STOWELL	231ST	792	1.18
208	367	LONGMIRE	581LM	1,007	1.17
209	210	JIROU	77JRU	325	1.17
210	371	LINCOLN	15LCN	283	1.15
211	340	CHEEK	165CH	97	1.14
212	356	WEST END	88WED	758	1.14
213	330	PRAIRIE	147PR	277	1.13
214	231	KOLBS	37KOL	1,061	1.13
215	223	GEORGIA	670GE	299	1.12
216	201	NEW CANEY	334NC	2,401	1.12
217	182	MIDWAY	819MD	73	1.11
218	80	OAK RIDGE	740OK	818	1.10
219	237	CHEEK	160CH	1,375	1.09
220	125	PLANTATION	545PL	1,013	1.09
221	105	HUNTSVILLE	600HU	1,638	1.09
222	396	FORT WORTH	55FTW	142	1.07
223	309	LINCOLN	16LCN	380	1.06
224	200	BAYOU FANNETT	250BY	33	1.06
225	229	BLUE BONNET	73BLB	283	1.06
226	131	VIDOR	163VD	2,845	1.05
227	145	WINSHIRE	240WS	1,141	1.05
228	153	ECHO	71ECH	645	1.04
229	217	CONROE BULK	574CN	821	1.04
230	165	FRONT STREET	308FR	404	1.03
231	322	SOMERVILLE	127SO	406	1.03
232	70	HANKS	22HKS	1,144	1.02
233	392	ALDEN BRIDGE	769AL	710	1.02
234	139	PORT ACRES SUB	69PTA	1,045	1.01
235	71	ALDEN BRIDGE	764AL	1,351	1.01

9

## Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
236	191	HEARNE	28HRN	23	1.00
237	381	TRAVIS	11TRV	26	1.00
238	124	WESTSIDE	112WS	469	1.00
239	81	BAYSHORE	213BA	1,700	0.93
240	230	VIRGINIA	129VI	672	0.92
241	302	BRIDGE CITY	362BD	1,190	0.92
242	110	NORTH END	27NOE	226	0.92
243	180	VIWAY	682VI	1,849	0.91
244	107	LACON	539LA	1,038	0.91
245	51	WINFREE	341WN	678	0.90
246	185	STOWELL	233ST	654	0.90
247	150	WINSHIRE	241WS	974	0.89
248	258	PANSY	184PS	374	0.88
249	249	CLEVELAND	404CV	1,621	0.87
250	84	TAMINA	599TA	437	0.87
251	55	CORDREY	324CO	1,467	0.87
252	277	CHEEK	159CH	547	0.86
253	127	NAVASOTA	969NA	760	0.83
254	79	VIRGINIA	131VI	1,249	0.82
255	222	CORDREY	326CO	1,135	0.81
256	147	WINFREE	340WN	857	0.81
257	331	STONEGATE	91STG	1,132	0.79
258	338	FRONT STREET	309FR	469	0.78
259	189	BRIDGE CITY	363BD	1,848	0.78
260	86	HANKAMER	207HA	660	0.77
261	205	ECHO	73ECH	777	0.77
262	169	BRIDGE CITY	360BD	967	0.76
263	170	SPURLOCK	98SPU	508	0.76
264	16	GRIMES	981GR	297	0.73
265	246	NORTH SILSBEE	472NS	321	0.72
266	281	ELIZABETH	123EL	2,277	0.72
267	361	CEDAR	698CE	21	0.71
268	62	STOWELL	232ST	1,031	0.71
269	89	LAKEVIEW	81LAV	1,280	0.70
270	65	CONAIR	513CN	1,086	0.69
271	142	APRIL	590AP	1,409	0.67
272	314	BAYSHORE	211BA	997	0.67
273	219	SOUR LAKE	105SL	1,195	0.67
274	305	ADAMS BAYOU	332AD	629	0.66
275	294	OAK RIDGE	741OK	762	0.64
276	368	PANSY	185PS	591	0.64
277	111	BEVIL	154BE	1,673	0.63
278	215	HUNTSVILLE	608HU	2,724	0.63
279	278	GROVES	62GRO	1,483	0.63
280	343	CORDREY	320CO	236	0.62
281	164	NORTH SILSBEE	471NS	1,071	0.62
282	377	ADAMS BAYOU	331AD	201	0.62
283	161	MCHALE	111MC	543	0.60

# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
284	272	CONROE BULK	506CN	2,088	0.59
285	304	VIDOR	164VD	873	0.59
286	266	CROWDER	105CD	836	0.59
287	213	TYRRELL	38TYR	33	0.58
288	214	VIDOR	162VD	1,734	0.57
289	128	HUMPHREY	106HM	1,058	0.57
290	92	CONROE BULK	577CN	584	0.56
291	155	TANGLEWOOD	135TG	496	0.56
292	267	WEST ORANGE	392WO	669	0.55
293	336	WEST ORANGE	393WO	761	0.55
294	300	CENTRAL	132CE	1,574	0.55
295	108	TAMINA	598TA	606	0.54
296	82	GROVES	63GRO	1,239	0.53
297	73	GOSLIN	706GL	1,416	0.52
298	248	PORT ACRES BULK	70PAS	834	0.52
299	66	CORDREY	325CO	1,420	0.51
300	253	VIDOR	161VD	611	0.51
301	236	GOSLIN	703GL	2,396	0.49
302	289	CONAIR	511CN	1,264	0.48
303	245	LACON	540LA	1,346	0.48
304	220	METRO	718ME	1,145	0.48
305	130	CORRIGAN BULK	238CR	586	0.47
306	113	WALDEN	563WD	1,289	0.47
307	76	KOLBS	34KOL	1,005	0.46
308	184	DAISETTA	744DA	773	0.45
309	10	CROCKETT	64CRK	982	0.44
310	318	WEST END	80WED	271	0.43
311	158	YANKEE DOODLE	22YAN	1,971	0.42
312	296	APRIL	591AP	1,400	0.42
313	283	APRIL	592AP	909	0.40
314	349	YANKEE DOODLE	25YAN	171	0.39
315	298	ADAMS BAYOU	330AD	130	0.38
316	87	CONROE BULK	576CN	253	0.38
317	225	HUMPHREY	108HM	39	0.36
318	140	MANCHESTER	67MAN	959	0.36
319	265	KOLBS	35KOL	1,111	0.35
320	288	ROSEDALE	150RS	106	0.33
321	241	FEDERAL	801FE	205	0.32
322	317	DE QUEEN	87DQN	203	0.32
323	228	SANDY SHORES	201SD	1,425	0.31
324	263	PORT NECHES	45PTN	924	0.31
325	345	GOSLIN	709GL	3,505	0.31
326	224	WYNTEX	634WT	1,201	0.30
327	310	AVERILL	56AVR	233	0.30
328	279	LONGMIRE	582LM	2,892	0.29
329	174	LAKEVIEW	80LAV	689	0.29
330	227	MCHALE	113MC	633	0.28
331	327	CROWDER	102CD	1,817	0.28

//

# Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
332	175	WOODVILLE	593WD	616	0.27
333	321	BLUE WATER	100BL	1,688	0.26
334	256	GOREE	681GR	196	0.24
335	208	YANKEE DOODLE	24YAN	448	0.24
336	290	STONEGATE	92STG	1,938	0.24
337	293	LONGMIRE	583LM	1,219	0.24
338	366	NORTH END	28NOE	208	0.24
339	120	CONROE BULK	572CN	1,281	0.23
340	282	LOVELLS LAKE	141LV	750	0.23
341	357	JIROU	76JRU	221	0.23
342	195	TANGLEWOOD	136TG	612	0.23
343	362	CENTRAL	130CE	663	0.23
344	344	BLUE BONNET	72BLB	31	0.23
345	275	MAPLE	91MPL	334	0.22
346	379	LAMAR	95LAM	540	0.22
347	52	BAYSHORE	212BA	44	0.20
348	42	BREKOS	13BEK	661	0.20
349	251	HANKS	24HKS	855	0.19
350	364	AMELIA BULK	181AM	1,037	0.19
351	353	WALDEN	560WD	546	0.18
352	375	NORTH END	26NOE	470	0.18
353	146	GROVETON	257GV	136	0.18
354	335	PORT ARTHUR WW	15WWK	426	0.17
355	280	BRIARCLIFF	33BRC	297	0.16
356	348	JIROU	75JRU	81	0.15
357	372	PRAIRIE	148PR	323	0.15
358	270	SHEAWILL	536SH	1,406	0.14
359	378	METRO	721ME	215	0.14
360	306	NORTH END	29NOE	387	0.14
361	39	HIMEX	221HI	382	0.14
362	325	LAMAR	97LAM	550	0.13
363	369	WESTSIDE	111WS	500	0.11
364	350	MANCHESTER	65MAN	343	0.11
365	388	GOSLIN	710GL	1,352	0.11
366	49	WEST END	82WED	450	0.11
367	63	SANDY SHORES	202SD	525	0.10
368	363	DAISETTA	741DA	174	0.10
369	173	MAPLE	90MPL	404	0.10
370	370	CROCKETT	61CRK	115	0.10
371	395	DE QUEEN	85DQN	99	0.09
372	342	AVERILL	55AVR	172	0.09
373	403	WEST END	87WED	26	0.08
374	358	FORT WORTH	51FTW	335	0.07
375	341	SHEAWILL	535SH	338	0.07
376	316	FORT WORTH	52FTW	39	0.05
377	389	STONEGATE	90STG	867	0.05
378	374	JIROU	78JRU	288	0.05
379	383	GOSLIN	704GL	1,673	0.05

# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIFI Ranking	2004 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIFI Value
380	216	WEST END	83WED	191	0.05
381	397	MANCHESTER	64MAN	129	0.05
382	334	PORT ARTHUR WW	18WWK	289	0.04
383	211	WESTSIDE	113WS	329	0.04
384	122	WYNTEX	633WT	481	0.04
385	204	PRAIRIE	149PR	319	0.03
386	382	FORT WORTH	50FTW	235	0.02
387	33	GOSLIN	705GL	858	0.01
388	380	ALDEN BRIDGE	766AL	1,638	0.01
389	386	AVERILL	57AVR	106	0.01
390	398	METRO	720ME	494	0.01
391	328	PARKDALE	171PR	592	0.00
392	390	ALDEN BRIDGE	767AL	1,610	-
393	391	ALDEN BRIDGE	768AL	1,838	-
394	233	CONROE BULK	575CN	367	-
395	359	CORDREY	321CO	72	-
396	394	CROCKETT	63CRK	36	-
397	365	FORT WORTH	53FTW	12	-
398	385	METRO	717ME	105	-
399	400	METRO	723ME	62	-
400	351	SPEEDWAY	917SW	23	-
401	112	TRAVIS	13TRV	44	-
402	401	TRAVIS	4TRV	12	-
403	402	TRAVIS	9TRV	25	-

# Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

403

Add or Delete Rows as Necessary

**Entergy Gulf States, Inc.**

\* Feeder among top 10% for two (2) years

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value	
1	1	LAKESIDE	L008F	84	1,935.19	*
2	4	PLEASURE	77PLS	146	1,207.45	*
3	23	REBEL	119RB	461	921.19	*
4	8	CLEVELAND	425CV	1,382	914.68	*
5	37	WARREN	592WR	1,823	876.52	*
6	5	HEARNE	25HRN	218	810.88	*
7	38	LOVELLS LAKE	142LV	306	794.71	*
8	9	DOUCETTE	569DC	165	707.26	*
9	230	BLUE WATER	101BL	1,687	672.76	
10	25	LAKESIDE	4LAS	61	659.57	*
11	367	FORT WORTH	54FTW	136	658.06	
12	246	NECHES	193NE	595	649.26	
13	28	LAKESIDE	5LAS	91	643.21	*
14	266	SPLENDORA	308SP	1,298	629.51	
15	51	CALVERT	6CAL	835	615.32	
16	329	FRANKLIN	7FKL	666	590.20	
17	146	NECHES	194NE	422	589.03	
18	10	HEARNE	29HRN	305	545.77	*
19	40	GRIMES	982GR	669	536.24	*
20	2	MAGNOLIA AMES	711MG	798	525.42	*
21	46	ARCHIE	45ARC	90	525.32	
22	39	DOUCETTE	570DC	1,100	520.85	*
23	132	BATSON	53BAT	860	511.91	
24	24	DOUCETTE	568DC	563	501.63	*
25	61	ALDEN BRIDGE	763AL	1,053	499.61	
26	35	DAYTON BULK	726DY	1,499	492.95	*
27	43	WARREN	506WR	1,539	483.06	
28	103	FLETCHER	456FL	708	460.34	
29	34	LAKESIDE	L009F	75	454.62	*
30	191	RIVTRIN	268RV	1,655	453.43	
31	188	CALVERT	4CAL	1,375	435.11	
32	325	LAWSON	102LA	266	422.34	
33	33	SARATOGA	761SA	428	401.77	*
34	393	ARCHIE	46ARC	21	395.59	
35	186	CHINA	92CHI	564	383.07	
36	363	CROWDER	103CD	1,381	377.13	
37	22	BEVIL	155BE	2,971	358.53	*
38	130	HARDIN	35HDN	685	357.78	
39	134	CLEVELAND	406CV	1,427	355.72	
40	291	LUMBERTON	441LU	2,873	355.40	
41	143	CROCKETT	65CRK	470	343.37	
42	15	RIVTRIN	269RV	2,942	339.02	
43		MEMORIAL	280ML	229	338.83	

14

# Service Quality Report to the Public Utility Commission of Texas

## Entergy Gulf States, Inc.

\* Feeder among top 10% for two (2) years

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
44	382	DE QUEEN	86DQN	272	334.40
45	169	APOLLO	320AP	1,055	334.28
46	126	CROCKETT	198CR	48	332.38
47	221	APOLLO	321AP	1,039	332.18
48	11	KICKAPOO	251KP	1,090	330.37
49	259	GRIMES	883GR	807	328.35
50	54	TRINITY	261TR	585	328.13
51	309	METRO	719ME	629	325.33
52	245	CALDWELL INDUSTRIAL	138CI	645	325.21
53	149	SPLENDORA	307SP	1,485	323.45
54	52	TYRRELL	37TYR	511	317.31
55	280	HANKAMER	206HA	633	316.69
56	257	SOUR LAKE	104SL	289	308.93
57	48	PEE DEE	808PD	2,186	307.58
58	18	DAYTON BULK	725DY	1,062	304.83
59	87	AMELIA BULK	182AM	662	298.87
60	168	PARKDALE	176PR	508	296.61
61	260	TESCO	36TSC	76	294.55
62	267	CROWDER	104CD	1,561	286.90
63	151	CLEVELAND	426CV	2,059	286.06
64	109	MCHALE	112MC	659	285.52
65	50	MAYHAW	671MA	1,722	285.39
66	174	HICKORY RIDGE	341HI	1,355	282.70
67	311	CONROE BULK	505CN	657	282.18
68	44	LAKESIDE	8LAS	36	281.61
69	302	MCDONALD	476MD	1,008	275.32
70	62	PORT NECHES	46PTN	1,270	270.00
71	59	DAYTON BULK	724DY	2,055	266.60
72	195	SPLENDORA	309SP	2,009	263.23
73	197	BRIARCLIFF	30BRC	2,147	260.76
74	31	OAK RIDGE	743OK	1,634	259.76
75	20	CRYSTAL	566CR	2,912	258.37
76	82	DE QUEEN	84DQN	318	257.51
77	144	LINDBERGH	41LNB	307	251.04
78	115	HEARNE	28HRN	23	250.00
79	327	PANORAMA	525PA	1,120	249.83
80	273	SOUTH LIBERTY	714SL	152	248.74
81	294	CENTRAL	131CE	878	245.88
82	29	PEE DEE	809PD	1,481	243.18
83	95	NEW CANEY	333NC	3,659	239.51
84	114	LINDBERGH	40LNB	1,195	238.09
85	236	BRIARCLIFF	32BRC	1,171	237.19
86	94	HUMPHREY	107HM	1,367	235.58
87	45	TAMINA	316TA	294	233.57
88	330	CORRIGAN BULK	239CR	510	226.24
89	268	NEW CANEY	304NC	1,162	225.28
90	313	VIRGINIA	130VI	835	224.56

15



# Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
91	30	WOODVILLE	594WD	1,119	223.82
92	253	LACON	537LA	632	223.41
93	297	TRANSCO	48TCO	175	223.36
94	157	MCLEWIS	381MC	1,113	223.21
95	251	ROSEDALE	152RS	348	221.65
96	372	TRAVIS	14TRV	16	221.13
97	176	KOUNTZE BULK	435KT	41	218.59
98	79	MIDWAY	819MD	73	217.84
99	189	DOBBIN	519DO	1,671	212.33
100	244	SILSBEE	462SI	756	211.64
101	196	ROSEDALE	151RS	1,141	209.94
102	199	NAVASOTA	902NA	607	208.07
103	13	KOUNTZE BULK	432KT	801	206.65
104	55	SILSBEE	463SI	587	202.71
105	49	MCLEWIS	382MC	638	199.66
106	74	DAYTON BULK	723DY	835	199.59
107	193	WYNTEX	632WT	866	199.57
108	361	PORT ARTHUR WW	17WWK	409	199.47
109	124	BEVIL	156BE	673	199.19
110	164	CONAIR	514CN	1,358	198.87
111	91	BRIARCLIFF	31BRC	867	197.62
112	27	HANKS	25HKS	915	193.54
113	272	CORDREY	327CO	1,045	192.90
114	198	FRONT STREET	307FR	488	192.15
115	75	OAK RIDGE	740OK	818	191.05
116	250	ECHO	70ECH	1,476	189.82
117	303	WINFREE	342WN	336	189.33
118	88	PORT ACRES SUB	68PTA	1,126	187.26
119	254	OAK RIDGE	745OK	139	184.22
120	3	EASTGATE	781EG	923	183.47
121	163	BAYOU FANNETT	250BY	33	183.27
122	14	TEMCO	628TE	332	177.58
123	131	DOBBIN	920DO	1,317	175.27
124	201	ELIZABETH	121EL	1,252	173.30
125	133	DAYTON BULK	727DY	775	172.68
126	58	ROSEDALE	153RS	831	171.29
127	135	CLEVELAND	405CV	1,542	170.71
128	315	STONEGATE	93STG	2,062	170.44
129	140	GOREE	682GR	1,516	168.97
130	141	LILLARD	490LI	281	167.22
131	67	PLANTATION	545PL	1,013	166.58
132	180	KOLBS	36KOL	1,301	166.32
133	288	LINCOLN	16LCN	380	164.69
134	68	NAVASOTA	905NA	1,916	159.13
135	346	ORANGE	352ON	917	158.22
136	328	NAVASOTA	904NA	1,180	156.93
137	234	YANKEE DOODLE	23YAN	608	156.66

16

# Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
138	60	WEST END	85WED	507	155.97
139	207	TEMCO	627TE	959	155.38
140	161	HANKS	23HKS	1,292	155.16
141	89	HUNTSVILLE	611HU	1,122	154.14
142	42	RAYWOOD	73RAY	487	154.14
143	228	NEW CANEY	334NC	2,401	153.69
144	264	LINDBERGH	43LNB	721	153.45
145	113	MANCHESTER	66MAN	1,542	151.56
146	107	RAYWOOD	74RAY	1,131	150.61
147	345	SPURLOCK	99SPU	533	148.00
148	338	HIMEX	222HI	292	146.60
149	119	CRYSTAL	570CR	1,360	145.36
150	36	ALDEN BRIDGE	762AL	1,848	140.65
151	117	PORT ACRES SUB	69PTA	1,045	138.93
152	233	CONROE BULK	507CN	2,164	138.91
153	16	CHINA	93CHI	1,277	137.97
154	263	SOMERVILLE	126SO	846	135.68
155	177	CENTRAL	133CE	1,556	131.22
156	105	ALDEN BRIDGE	765AL	1,163	130.35
157	150	GROVES	59GRO	1,262	129.53
158	66	NEW CANEY	337NC	2,202	129.33
159	138	OAK RIDGE	744OK	3,118	128.77
160	222	HAMPTON	158HA	1,146	127.46
161	336	CONAIR	515CN	1,416	126.33
162	249	CONROE BULK	574CN	821	126.20
163	86	PEE DEE	811PD	881	125.92
164	339	GROVES	61GRO	912	125.22
165	304	CHEEK	166CH	23	123.12
166	65	LOEB	17LOB	1,036	121.95
167	57	NEW CANEY	335NC	2,545	119.38
168	98	TRINITY	262TR	110	119.03
169	278	PLANTATION	546PL	793	118.26
170	185	MCDONALD	477MD	1,293	116.89
171	314	PRAIRIE	147PR	277	116.79
172	80	ELIZABETH	122EL	963	114.82
173	299	GROVES	62GRO	1,483	113.94
174	41	LOEB	18LOB	548	113.89
175	53	MCHALE	110MC	864	113.71
176	84	OILLA	345OI	889	113.67
177	370	METRO	716ME	1,846	112.55
178	12	GRIMES	981GR	297	112.34
179	333	SILSBEE	461SI	484	111.50
180	165	MILLEDGE	407MI	725	111.25
181	173	SOUR LAKE	105SL	1,195	111.04
182	118	TAMINA	317TA	1,258	111.02
183	335	GOSLIN	708GL	2,187	110.55
184	71	LONGMIRE	580LM	287	110.26

17

## Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
185	123	ELIZABETH	120EL	1,321	108.98
186	69	GOSLIN	707GL	764	108.53
187	227	CHEEK	160CH	1,375	105.80
188	127	MANCHESTER	67MAN	959	105.23
189	125	WINFREE	341WN	678	104.57
190	166	NORTH SILSBEE	471NS	1,071	104.49
191	388	CROCKETT	60CRK	262	104.20
192	235	STOWELL	231ST	792	103.81
193	355	FRONT STREET	309FR	469	103.54
194	81	BAYSHORE	213BA	1,700	102.44
195	32	NORTH END	21NOE	1,759	101.92
196	396	FORT WORTH	55FTW	142	101.89
197	83	HANKS	22HKS	1,144	101.02
198	217	DAISETTA	743DA	341	100.73
199	238	METRO	718ME	1,145	100.52
200	203	NEW CANEY	336NC	3,250	100.50
201	270	CRYSTAL	567CR	1,196	100.15
202	192	MCLEWIS	380MC	2,133	99.65
203	252	BRIDGE CITY	361BD	1,052	98.80
204	17	OAK RIDGE	742OK	2,073	98.35
205	104	WINSHIRE	240WS	1,141	96.65
206	281	GOSLIN	702GL	1,724	96.15
207	258	ORANGE	350ON	840	95.93
208	90	LINDBERGH	42LNB	1,680	95.44
209	172	ECHO	72ECH	506	95.15
210	376	LONGMIRE	581LM	1,007	93.76
211	102	HUNTSVILLE	600HU	1,638	93.67
212	317	WEST END	86WED	946	93.41
213	111	WALDEN	564WD	4,066	92.78
214	277	LONGMIRE	584LM	881	92.75
215	205	FLETCHER	457FL	1,521	91.24
216	216	VIDOR	163VD	2,845	89.49
217	293	KOUNTZE	452KT	390	89.21
218	248	CLEVELAND	403CV	1,821	88.69
219	331	ORANGE	351ON	385	88.36
220	255	NAVASOTA	969NA	760	88.19
221	137	VIRGINIA	131VI	1,249	87.89
222	99	LACON	539LA	1,038	87.57
223	85	HUNTSVILLE	607HU	2,911	87.15
224	148	MCDONALD	479MD	949	85.67
225	220	VIRGINIA	129VI	672	85.44
226	212	MCDONALD	478MD	624	85.01
227	239	NECHES	197NE	174	84.87
228	276	AMELIA BULK	180AM	1,188	82.56
229	289	WEST ORANGE	392WO	669	82.32
230	170	LAKEVIEW	81LAV	1,280	82.13
231	210	VIWAY	682VI	1,849	82.11

## Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
232	64	TANGLEWOOD	137TG	1,375	81.87
233	194	BRIDGE CITY	360BD	967	81.24
234	93	CORRIGAN BULK	238CR	586	78.94
235	269	ECHO	71ECH	645	77.00
236	326	SOMERVILLE	127SO	406	76.29
237	229	KOLBS	37KOL	1,061	75.98
238	261	TYRRELL	38TYR	33	75.12
239	7	CONROE BULK	577CN	584	74.91
240	175	VIDOR	162VD	1,734	73.92
241	72	TAMINA	599TA	437	72.79
242	224	VIWAY	681VI	932	72.19
243	353	WEST END	80WED	271	72.13
244	223	CHEEK	159CH	547	70.86
245	265	BLUE BONNET	73BLB	283	70.18
246	282	CONAIR	516CN	254	69.61
247	284	OAK RIDGE	741OK	762	69.41
248	283	BRIDGE CITY	362BD	1,190	69.18
249	377	APRIL	592AP	909	68.96
250	301	DE QUEEN	87DQN	203	68.25
251	375	WEST END	88WED	758	67.65
252	275	CROWDER	105CD	836	67.04
253	181	WINSHIRE	241WS	974	66.69
254	47	TANGLEWOOD	134TG	2,290	66.36
255	256	CORDREY	326CO	1,135	66.18
256	145	CORDREY	324CO	1,467	66.17
257	368	CEDAR	698CE	21	65.71
258	295	ELIZABETH	123EL	2,277	64.47
259	214	STOWELL	233ST	654	63.94
260	70	CORDREY	325CO	1,420	63.91
261	362	LINCOLN	15LCN	283	63.55
262	213	PANSY	184PS	374	63.14
263	208	BRIDGE CITY	363BD	1,848	62.88
264	200	APRIL	590AP	1,409	62.76
265	78	TAMINA	598TA	606	62.63
266	167	KOLBS	34KOL	1,005	61.88
267	332	CHEEK	165CH	97	61.80
268	219	CLEVELAND	404CV	1,621	61.35
269	179	LACON	538LA	1,767	60.59
270	77	HANKAMER	207HA	660	60.24
271	142	CONAIR	513CN	1,086	59.86
272	312	CENTRAL	132CE	1,574	59.79
273	305	STONEGATE	91STG	1,132	58.90
274	122	DAISETTA	744DA	773	58.80
275	116	JIROU	77JRU	325	58.69
276	158	KOUNTZE	453KT	658	56.72
277	110	VIRGINIA	132VI	498	54.63
278	21	STOWELL	232ST	1,031	53.68

# Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
279	206	NORTH SILSBEE	472NS	321	53.67
280	379	METRO	721ME	215	53.39
281	232	SPURLOCK	98SPU	508	53.17
282	204	PORT ACRES BULK	70PAS	834	52.47
283	121	CONAIR	512CN	1,829	52.07
284	190	VIDOR	161VD	611	51.80
285	296	APRIL	591AP	1,400	51.08
286	306	BAYSHORE	211BA	997	49.87
287	139	WINFREE	340WN	857	49.48
288	183	HUNTSVILLE	608HU	2,724	49.23
289	162	HUNTSVILLE	610HU	1,590	47.76
290	285	VIDOR	164VD	873	47.24
291	187	CONROE BULK	506CN	2,088	46.96
292	366	PANSY	185PS	591	46.90
293	354	WEST ORANGE	393WO	761	45.80
294	202	GOSLIN	706GL	1,416	44.54
295	159	ALDEN BRIDGE	764AL	1,351	44.50
296	378	LAMAR	95LAM	540	43.29
297	96	GROVES	63GRO	1,239	43.07
298	100	WALDEN	563WD	1,289	41.69
299	120	YANKEE DOODLE	22YAN	1,971	41.37
300	97	CONROE BULK	572CN	1,281	41.18
301	392	ALDEN BRIDGE	769AL	710	40.73
302	310	ADAMS BAYOU	332AD	629	39.62
303	287	PORT NECHES	45PTN	924	39.36
304	292	CONAIR	511CN	1,264	39.34
305	63	MCHALE	111MC	543	37.83
306	101	HUMPHREY	106HM	1,058	37.33
307	242	ECHO	73ECH	777	36.87
308	348	JIROU	76JRU	221	36.64
309	209	MCHALE	113MC	633	36.53
310	318	AVERILL	56AVR	233	33.96
311	262	LAKEVIEW	80LAV	689	32.56
312	160	WYNTEX	634WT	1,201	32.55
313	381	ADAMS BAYOU	331AD	201	32.49
314	320	NORTH END	26NOE	470	31.56
315	243	LACON	540LA	1,346	31.32
316	147	BEVIL	154BE	1,673	31.25
317	231	GOSLIN	703GL	2,396	30.85
318	218	TANGLEWOOD	135TG	496	30.28
319	365	CENTRAL	130CE	663	30.23
320	307	ADAMS BAYOU	330AD	130	29.45
321	337	YANKEE DOODLE	25YAN	171	29.32
322	182	FEDERAL	801FE	205	29.31
323	344	GOSLIN	709GL	3,505	29.12
324	129	WOODVILLE	593WD	616	28.76
325	403	WEST END	87WED	26	28.62

## Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**\* Feeder among top 10% for two (2) years**

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
326	319	CROWDER	102CD	1,817	28.49
327	178	GEORGIA	670GE	299	28.25
328	341	MANCHESTER	65MAN	343	27.30
329	383	TRAVIS	11TRV	26	27.08
330	171	GOREE	681GR	196	26.51
331	226	KOLBS	35KOL	1,111	26.45
332	334	PORT ARTHUR WW	15WWK	426	25.39
333	300	LONGMIRE	582LM	2,892	24.28
334	108	CONROE BULK	576CN	253	23.79
335	152	YANKEE DOODLE	24YAN	448	23.31
336	290	STONEGATE	92STG	1,938	23.11
337	271	LOVELLS LAKE	141LV	750	22.81
338	240	HANKS	24HKS	855	22.27
339	324	BLUE WATER	100BL	1,688	22.22
340	347	JIROU	75JRU	81	22.12
341	184	MAPLE	91MPL	334	21.46
342	350	WESTSIDE	111WS	500	21.05
343	128	NORTH END	27NOE	226	20.60
344	215	SANDY SHORES	201SD	1,425	20.52
345	136	GROVETON	257GV	136	20.29
346	298	LONGMIRE	583LM	1,219	19.96
347	340	WALDEN	560WD	546	19.18
348	342	CORDREY	320CO	236	19.11
349	19	BAYSHORE	212BA	44	18.82
350	322	TANGLEWOOD	136TG	612	18.44
351	26	CROCKETT	64CRK	982	17.25
352	73	WESTSIDE	112WS	469	14.97
353	76	BREKOS	13BEK	661	14.12
354	356	NORTH END	28NOE	208	13.70
355	316	HUMPHREY	108HM	39	13.18
356	156	MAPLE	90MPL	404	12.89
357	241	FRONT STREET	308FR	404	12.80
358	373	PRAIRIE	148PR	323	11.59
359	358	AMELIA BULK	181AM	1,037	11.51
360	237	ROSEDALE	150RS	106	10.78
361	385	GOSLIN	704GL	1,673	10.64
362	225	BRIARCLIFF	33BRC	297	10.61
363	364	CROCKETT	61CRK	115	10.45
364	6	HIMEX	221HI	382	9.87
365	359	BLUE BONNET	72BLB	31	9.71
366	395	DE QUEEN	85DQN	99	9.52
367	286	NORTH END	29NOE	387	9.17
368	274	SHEAWILL	536SH	1,406	9.00
369	153	SANDY SHORES	202SD	525	8.98
370	360	SHEAWILL	535SH	338	8.47
371	386	GOSLIN	710GL	1,352	8.16
372	371	DAISETTA	741DA	174	7.55

## Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

\* Feeder among top 10% for two (2) years

2005 SAIDI Ranking	2004 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2005 SAIDI Value
373	323	AVERILL	55AVR	172	6.39
374	106	WEST END	83WED	191	6.17
375	349	LAMAR	97LAM	550	4.47
376	352	PORT ARTHUR WW	18WWK	289	4.14
377	374	JIROU	78JRU	288	4.07
378	384	FORT WORTH	50FTW	235	3.85
379	357	FORT WORTH	51FTW	335	3.34
380	211	WESTSIDE	113WS	329	2.43
381	155	WYNTEX	633WT	481	2.42
382	112	WEST END	82WED	450	2.40
383	308	FORT WORTH	52FTW	39	2.31
384	369	ALDEN BRIDGE	766AL	1,638	1.88
385	397	MANCHESTER	64MAN	129	1.86
386	154	GOSLIN	705GL	858	1.50
387	389	STONEGATE	90STG	867	1.25
388	56	PRAIRIE	149PR	319	1.21
389	398	METRO	720ME	494	0.30
390	387	AVERILL	57AVR	106	0.22
391	279	PARKDALE	171PR	592	0.11
392	390	ALDEN BRIDGE	767AL	1,610	-
393	391	ALDEN BRIDGE	768AL	1,838	-
394	247	CONROE BULK	575CN	367	-
395	321	CORDREY	321CO	72	-
396	394	CROCKETT	63CRK	36	-
397	343	FORT WORTH	53FTW	12	-
398	380	METRO	717ME	105	-
399	400	METRO	723ME	62	-
400	351	SPEEDWAY	917SW	23	-
401	92	TRAVIS	13TRV	44	-
402	401	TRAVIS	4TRV	12	-
403	402	TRAVIS	9TRV	25	-

Service Quality Report to the Public Utility Commission of Texas

**Entergy Gulf States, Inc.**

**INTERRUPTION CAUSES**

Provide the percentage of interruptions attributable to each cause.

2005 Reporting Year

<b>Causes of Forced Interruptions</b>	<b>Percentage</b>
Weather (Including Lightning)	19.89%
Vegetation	18.00%
Animals and Birds	7.56%
People (Including cars and farm equip)	16.34%
Utility-owned Equipment	28.45%
Other	3.41%
Unknown	6.35%
	100.00%