



Control Number: 33629



Item Number: 15

Addendum StartPage: 0



A unit of American Electric Power

AEP Texas
AEP Texas Central Company
400 West 15th Street, Suite 1520
Austin, TX 78701
AEPTexas.com

August 24, 2007

Mr. James Galloway
Filing Clerk
Public Utility Commission of Texas
1701 N. Congress
Austin, TX 78711

RECEIVED
2007 AUG 24 PM 2:46
PUBLIC UTILITY COMMISSION
FILING CLERK

RE: Project No. 33629, Revised Reliability and Continuity of Service Report for 2006

Dear Mr. Galloway,


Please find attached a revised Reliability and Continuity of Service Report (Report) for the reporting year 2006 for AEP Texas Central Company (TCC and formerly known as Central Power and Light Company). The revisions do not adversely impact the ranking of the ten percent worst performing repeat feeders for either SAIDI or SAIFI for the 689 TCC feeders. The following describes the revisions made to the original filing.

- In 2006, AEP Texas initiated an equipment identification process that tracked breakers at the substation attached to a feeder by the specific feeder number. This caused a problem when a breaker was moved to another feeder and the outage data for that prior breaker operation on the old feeder was moved to the new feeder. It was determined after the original filing of the Report that before this problem was corrected two breakers at North Alamo had been switched between two feeders in the substation to address a loading issue on one of the feeders. This switching of breakers affected the outage information associated with these two feeders. Once corrected this changed the SAIFI ranking for North Alamo Feeder 94SB4370 from 9 to 137 and for North Alamo Feeder 94SB3610 from 5 to 3. This correction changed the SAIDI ranking from 24 to 43 for feeder 94SB4370 and 17 to 15 for feeder 94SB3610.
- Sharyland feeder 94SB2035 had a large number of customers moved to Sharyland feeder 94SB2150 in September 2006. This change in customer count was not reflected correctly in the files used for the calculation of the annual SAIFI and SAIDI in the original filing of the Report. Once corrected this changed the SAIFI ranking for Sharyland Feeder 94SB2035 from 639 to 680 and for Sharyland Feeder 94SB2150

from 642 to 633. This correction changed the SAIDI ranking from 633 to 675 for feeder 94SB2035 and from 615 to 599 for feeder 94SB2150.

- During 2006, Airline Feeder 94CS2210 and Banquette Feeder 94CS740 had the customer counts drop below 10. This information was not reflected in the files used for the original Report filing. These changes remove these two feeders from the revised Report. Airline 94CS2210 was ranked 684 (SAIFI and SAIDI) and Banquette 94CS740 was ranked 337 (SAIFI) and 49 (SAIDI).
- It was determined after the filing of the original Report that a programming change to the annual SAIDI and SAIFI calculations was in error. The annual customer count has historically been rounded to the nearest integer value in the calculation of the annual SAIDI and SAIFI. In the original Report this rounding did not take place. The revised report has corrected the calculation and as such there has been minor shifting in rankings.
- In the original Report filed the new feeders added during 2006 had the annual average customer count in the SAIDI and SAIFI calculation divided by 12 months regardless of the in-service date of the new feeder. This has been corrected to reflect a dividend consistent with the number of months the feeder was in service during 2006. The new feeders in the Report were impacted as followed by this correction.
 - Palmhurst 94SB2530 – SAIFI (600 to 635) SAIDI (567 to 628)
 - N. Padre Island 94CS1010 – SAIFI (558 to 638) SAIDI (620 to 660)
 - Goodwin 94SB3530 – SAIFI (619 to 643) SAIDI (604 to 643)
 - N. Padre Island 94CS720 – SAIFI (685 to 683) SAIDI (685 to 683)
 - Haine Drive 94SB3490 – SAIFI (691 to 689) SAIDI (691 to 689)

Sincerely,



Randal E. Roper
Regulatory Case Manager, AEPSC

Attachment

§25.52. -- Reliability and Continuity of Service.

<http://www.puc.state.tx.us/rules/subrules/electric/25.52/25.52.doc>

Application. This section applies to all electric utilities as defined by the Public Utility Regulatory Act (PURA) §31.002(6) and all transmission and distribution utilities as defined by PURA §31.002(19). The term "utility" as used in this section shall mean an electric utility and a transmission and distribution utility.

Public Utility Regulatory Act §31.002

<http://www.puc.state.tx.us/rules/statutes/index.cfm>

DEFINITIONS.

The term "Electric utility" does not include a municipally owned utility or an electric cooperative.

Information typed in highlighted cells will appear on following sheets.

Utility:	Type Name of Utility in the Cell Below AEP Texas Central Company
Feeders:	Type Total Number of Distribution Feeders in the Cell Below 689
Due:	February 14, 2007
File:	Five Printed Copies and One Electronic Copy of This Excel File
Project:	33629
Address:	Attn: Filing Clerk Public Utility Commission of Texas P.O. Box 13326 Austin, Texas 78711-3326

If you have any questions, please contact:

Larry Reed
Electric Division
Commission Staff
Voice: 512 936 7357
Fax: 512 936 7328
E-mail: <mailto:larry.reed@puc.state.tx.us>

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2006 Reporting Year

AEP Texas Central Company

Project 33629

REVISED 8/24/2007

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2006	1.47	0.08	0.11	0.13	0.10	0.15	0.13	0.14	0.11	0.15	0.15	0.12	0.12
Scheduled 2006	0.02	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00	0.00	0.00
Outside Causes 2006	0.34	0.04	0.02	0.04	0.08	0.02	0.02	0.01	0.00	0.03	0.03	0.01	0.03
Major Events 2006	0.17	0.00	0.00	0.04	0.01	0.08	0.00	0.04	0.00	0.00	0.00	0.00	0.00

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
System SAIDI													
Forced 2006	123.0	6.3	7.7	9.7	9.3	13.2	10.7	12.1	7.0	15.4	10.6	9.3	11.5
Scheduled 2006	1.5	0.1	0.0	0.0	0.1	0.0	0.9	0.1	0.1	0.1	0.1	0.0	0.1
Outside Causes 2006	16.1	1.9	0.7	2.3	3.7	1.4	1.4	0.7	0.0	0.9	1.4	0.2	1.6
Major Events 2006	24.4	0.0	0.0	5.8	1.4	14.2	0.0	3.0	0.0	0.0	0.0	0.0	0.0

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or More Customers

Add or Delete Rows as Necessary

AEP Texas Central Company

Total Number of Feeders

689

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
1	230	Moore Field	94SB3960	3,131	9.701	Was 3960 last year
2	261	Raymondville #1	94SB620	656	8.634	Was 620 last year
3	23	North Alamo	94SB3610	3,643	8.277	Was 4370 last year
4	613	Blessing	94CN8780	68	7.971	Was 8780 last year
5	640	Pharr	94SB1645	1,669	7.294	Was 1645 last year
6	259	Rangerville	94SB3420	757	7.141	Was 3420 last year
7	64	Bruni	94LA5440	31	6.742	Was 5440 last year
8	58	McKenzie Road	94CS140	150	6.260	Was 140 last year
9	487	Milo	94LA3060	2,252	6.128	Was 3060 last year
10	3	Raymondville #1	94SB630	794	6.110	Was 630 last year
11	486	Randado	94LA8350	39	5.974	Was 8350 last year
12	387	Airline	94CS8260	862	5.785	Was 8260 last year
13	238	Government Wells	94LA7250	363	5.777	Was 7250 last year
14	9	Alazan	94CS620	207	5.575	Was 620 last year
15	52	Laguna	94CS9590	2,134	5.512	Was 9590 last year
16	517	South Santa Rosa	94SB1225	328	5.424	Was 1225 last year
17	114	Elsa	94SB710	1,225	5.251	Was 710 last year
18	597	Columbus	94CN930	935	5.214	Was 930CN last year
19	236	Port Isabel S.S.	94SB3820	452	5.027	Was 3820 last year
20	69	South East Edinburg	94SB6580	2,142	5.000	Was 6580 last year
21	558	Milo	94LA3065	216	4.722	Was 3065 last year
22	89	Odem	94CS375	750	4.709	Was 375 last year
23	432	Gregory	94CS5900	80	4.700	Was 5900 last year
24	449	Zapata	94LA8290	2,009	4.637	Was 8290W last year
25	200	Moore Field	94SB3120	114	4.614	Was 3120 last year
26	342	Kleberg	94CS6410	366	4.607	Was 6410 last year
27	92	Mines Road	94LA3745	1,160	4.564	Was 3745 last year
28	178	Clarkwood	94CS7610	185	4.535	Was 7610 last year
29	532	Carancahua	94CN5870	341	4.481	Was 5870CN last year
30	460	North Alamo	94SB3580	2,193	4.463	Was 3580 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
31	455	Rachal	94LA6595	580	4.457	Was 6595 last year
32	567	Morris Street	94CS8830	1,572	4.402	Was 8830 last year
33	2	Hidalgo	94SB3680	848	4.392	Was 3680 last year
34	11	East Harrison	94SB3950	519	4.353	Was 3950 last year
35	548	Hearn Road	94CS8980	961	4.284	Was 8980 last year
36	224	Rio Bravo	94LA300	897	4.225	Was 300 last year
37	596	Greenlake	94CN2750	993	4.194	Was 2750CN last year
38	36	Rio Rico	94SB8330	521	4.190	Was 8330 last year
39	447	Falfurrias	94LA2830	1,398	4.126	Was 2830 last year
40	368	Premont	94LA6570	579	4.079	Was 6570 last year
41	586	Zapata	94LA2710	44	4.068	Was 2710 last year
42	265	Eagle Pass City	94LA2745	1,303	4.059	Was 2745 last year
43	374	Rachal	94LA8145	10	4.000	Was 8145 last year
44	278	Markham	94CN5550	84	3.976	Was 5550 last year
45	428	Palmhurst	94SB2535	911	3.966	Was 2535 last year
46	182	Cavazos	94SB3550	1,887	3.919	Was 3550 last year
47	193	Port Aransas	94CS6940	1,493	3.841	Was 6940 last year
48	110	Devine	94LA7090	803	3.737	Was 7090 last year
49	383	Taft	94CS1260	109	3.734	Was 1260 last year
50	210	Causeway	94SB4765	1,152	3.729	Was 4765 last year
51	190	South Santa Rosa	94SB1215	1,686	3.696	Was 1215 last year
52	223	McKenzie Road	94CS330	1,969	3.680	Was 330 last year
53	489	West McAllen	94SB4505	1,964	3.641	Was 4505 last year
54	40	North McAllen	94SB2750	2,591	3.639	Was 2750 last year
55	394	Bonnieview	94CS8020	444	3.619	Was 8020 last year
56	507	Casa Blanca	94CS1300	584	3.570	Was 1300CS last year
57	369	La Pryor	94LA2440	585	3.526	Was 2440 last year
58	344	Rodd Field	94CS205	1,016	3.522	Was 205 last year
59	20	Gregory	94CS5920	539	3.506	Was 5920 last year
60	577	South Mission	94SB3980	1,080	3.478	Was 3980 last year
61	228	Phair	94SB1640	901	3.461	Was 1640 last year
62	260	Weil Tract (138/12kV)	94CS2520	291	3.460	Was 2520 last year
63	573	McColl Road	94SB2810	1,737	3.436	Was 2810 last year
64	251	Rio Rico	94SB5050	1,413	3.436	Was 5050 last year
65	504	Harlingen S.S.	94SB4230	1,840	3.402	Was 4230 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
66	379	Harlingen	94SB660	2,141	3.391	Was 660 last year
67	244	Weil Tract (138/12kV)	94CS5405	144	3.382	Was 5405 last year
68	606	Ingleside City	94CS6040	203	3.355	Was 6040 last year
69	15	Brownsville	94SB4290	1,663	3.354	Was 4290 last year
70	413	Aransas Pass	94CS8270	445	3.348	Was 8270 last year
71	113	South McAllen	94SB5065	114	3.316	Was HIDALGO COLISEUM last year
72	427	Hidalgo	94SB4845	537	3.302	Was 4845 last year
73	448	Stadium	94CS6950	562	3.294	Was 6950 last year
74	208	Blessing	94CN8790	661	3.289	Was 8790 last year
75	104	Naval Base	94CS8440	1,276	3.241	Was 8440 last year
76	405	Stadium	94CS7810	1,627	3.237	Was 7810 last year
77	215	Rangerville	94SB4060	714	3.178	Was 4060 last year
78	101	Maverick	94LA9680	603	3.151	Was 9680W last year
79	38	South McAllen	94SB3790	1,353	3.132	Was 3790 last year
80	499	Bay City	94CN6450	1,042	3.123	Was 6450 last year
81	8	Los Fresnos	94SB3200	2,564	3.115	Was 3200 last year
82	475	Mathis	94CS340	1,540	3.057	Was 340CS last year
83	550	Highway 9	94CS6730	376	3.056	Was 6730 last year
84	154	Uvalde	94LA480	1,242	3.036	Was 480 last year
85	184	Randado	94LA8360	117	3.017	Was 8360 last year
86	248	Cabaniss	94CS75	1,326	2.999	Was 75 last year
87	294	Refugio	94CN5120	124	2.984	Was 5120 last year
88	189	Pearsall	94LA7050	1,388	2.976	Was 7050 last year
89	315	Mines Road	94LA3680	533	2.972	Was 3680 last year
90	399	Palmhurst	94SB3890	1,844	2.960	Was 3890 last year
91	362	University	94LA950	1,800	2.921	Was 950 last year
92	393	Live Oak	94CS1080	646	2.861	Was 1080 last year
93	175	Mathis	94CS1410	222	2.824	Was 1410 last year
94	583	Government Wells	94LA6800	221	2.801	Was 6800 last year
95	97	Tatton	94CS8200	1,426	2.786	Was 8200 last year
96	35	Uvalde	94LA6620	2,605	2.774	Was 6620 last year
97	138	Rio Rico	94SB8290	79	2.747	Was 8290 last year
98	271	Edroy	94CS6990	232	2.741	Was 6990 last year
99	568	Sinton	94CS360	276	2.674	Was 360CS last year
100	65	Weaver Road	94CN1900	54	2.667	Was 1900 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
101	352	Ganado	94CN5795	682	2.660	Was 5795 last year
102	511	Conoco-Chittam Ranch	94LA8580	64	2.656	Was 8580 last year
103	117	Palmhurst	94SB2525	2,029	2.652	Was 2525 last year
104	37	North Edinburg	94SB560	875	2.648	Was 560 last year
105	99	Encinal	94LA2160	650	2.642	Was 2160 last year
106	73	Weil Tract (138/12kV)	94CS1990	993	2.633	Was 1990 last year
107	88	Palmhurst	94SB1300	1,688	2.605	Was 1300 last year
108	198	Luling - LCRA	94CN10	261	2.602	Was 10CN last year
109	289	Laguna	94CS9065	1,680	2.595	Was 9065 last year
110	288	Hall Acres Road	94SB3460	2,939	2.588	Was 3460 last year
111	347	Three Rivers	94CN2580	109	2.587	Was 2580 last year
112	60	La Pryor	94LA570	94	2.585	Was 570 last year
113	376	Odem	94CS385	273	2.579	Was 385 last year
114	262	Anna Street	94LA900	2,993	2.572	Was 900 last year
115	607	Parker	94CN9010	14	2.571	Was 9010 last year
116	66	Elsa	94SB690	2,038	2.554	Was 690 last year
117	284	Arcadia	94CS1440	1,549	2.551	Was 1440 last year
118	13	Raymondville #2	94SB3250	41	2.537	Was 3250 last year
119	105	Naval Base	94CS6330	259	2.537	Was 6330CS last year
120	54	West Harlingen	94SB3700	1,508	2.533	Was 3700 last year
121	496	East Harrison	94SB4360	1,465	2.517	Was 4360 last year
122	107	Elsa	94SB700	1,348	2.512	Was 700 last year
123	206	Morris Street	94CS8715	1,645	2.498	Was 8715 last year
124	319	Falfurrias	94LA5210	998	2.496	Was 5210 last year
125	467	Taft	94CS1180	1,154	2.491	Was 1180 last year
126	250	West Oso	94CS9095	1,656	2.477	Was 9095 last year
127	207	Lytte	94LA2850	655	2.476	Was 2850 last year
128	255	Pearsall	94LA9905	187	2.476	Was 9905 last year
129	280	Sunchase	94SB1150	975	2.475	Was 1150 last year
130	411	Live Oak	94CS1090	214	2.467	Was 1090CS last year
131	430	Hearn Road	94CS870	972	2.453	Was 870 last year
132	429	Placedo	94CN7970	386	2.438	Was 7970 last year
133	176	Gregory	94CS8560	606	2.434	Was 8560 last year
134	525	Goodwin	94SB4390	599	2.427	Was 4390 last year
135	75	McColl Road	94SB4400	1,269	2.418	Was 4400 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
136	314	Morris Street	94CS5655	1,095	2.416	Was 5655 last year
137	522	North Alamo	94SB4370	1,071	2.408	Was 3610 last year
138	103	Bishop	94CS2690	579	2.408	Was 2690 last year
139	205	Malone	94CN7550	218	2.404	Was 7550 last year
140	164	Kieberg	94CS8140	170	2.394	Was 8140 last year
141	25	Clarkwood	94CS5525	698	2.388	Was 5525 last year
142	29	West McAllen	94SB4965	922	2.385	Was 4965 last year
143	229	Rodd Field	94CS225	1,973	2.382	Was 225 last year
144	202	Kingsville	94CS1130	1,667	2.381	Was 1130 last year
145	419	Seawall	94CS9450	241	2.378	Was 9450 last year
146	209	Hall Acres Road	94SB5585	949	2.375	Was 5585 last year
147	334	Victoria Power Plant	94CN7600	168	2.369	Was 7600 last year
148	142	East Harrison	94SB4310	1,139	2.342	Was 4310 last year
149	414	Greenlake	94CN2760	469	2.284	Was 2760 last year
150	547	Amistad Dam	94LA5450	959	2.277	Was 5450 last year
151	632	Polk Avenue	94SB4740	1,170	2.277	Was 4740 last year
152	440	Pueblo	94LA130	1,132	2.266	Was 130 last year
153	626	Haine Drive	94SB8065	1,234	2.262	Was 8065 last year
154	599	Wesmer	94SB6900	1,492	2.261	Was 6900 last year
155	663	Highway 9	94CS7210	1,058	2.255	Was 7210 last year
156	384	Hamilton Road	94LA9665	718	2.251	Was 9665W last year
157	31	Tatton	94CN8490	160	2.250	Was 8490 last year
158	320	Eagle Lake	94CN9455	581	2.250	Was 9455 last year
159	562	Weslaco Unit	94SB8195	2,332	2.238	Was 8195 last year
160	479	Government Wells	94LA7240	229	2.231	Was 7240 last year
161	166	Gateway	94LA390	2123	2.228	Was 390 last year
162	485	San Benito	94SB4030	2,356	2.218	Was 4030 last year
163	218	Columbus	94CN6180	867	2.205	Was 6180 last year
164	408	Goodwin	94SB4625	711	2.195	Was 4625, but reconfig since last year
165	620	Highway 9	94CS7200	947	2.195	Was 7200 last year
166	94	Holly	94CS7620	2,190	2.165	Was 7620 last year
167	373	Falfurrias	94LA1080	436	2.165	Was 1080W last year
168	610	Milo	94LA6940	1,357	2.160	Was 3070 last year
169	192	Crestonio	94LA270	623	2.156	Was 270W last year
170	287	Uvalde	94LA5060	1,281	2.156	Was 5060 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
171	651	Falfurrias	94LA1070	916	2.155	Was 1070W last year
172	553	Malone	94CN7560	227	2.154	Was 7560 last year
173	439	Crystal City	94LA330	957	2.149	Was 330W last year
174	246	Rio Grande City	94SB3740	2,108	2.100	Was 3740 last year
175	140	Devine	94LA7100	831	2.097	Was 7100 last year
176	623	Edna	94CN5765	1,638	2.096	Was 5765 last year
177	72	Nueces Bay Plant	94CS350	782	2.095	Was 350 last year
178	463	Stadium	94CS8540	1,640	2.091	Was 8540 last year
179	240	Palmhurst	94SB2820	3,393	2.089	Was 2820 last year
180	392	Port Isabel S.S.	94SB4070	297	2.084	Was 4070 last year
181	5	Nueces Bay Plant	94CS7830	148	2.081	Was 7830 last year
182	4	Los Fresnos	94SB3290	928	2.081	Was 3290 last year
183	426	University	94LA920	200	2.080	Was 920 last year
184	16	Bruni	94LA1120	89	2.079	Was 1120 last year
185	310	Rocksprings	94LA2600	363	2.066	Was 2600 last year
186	180	South Santa Rosa	94SB1240	1,221	2.056	Was 1240 last year
187	488	Eagle Pass City	94LA2650	3,329	2.054	Was 2650 last year
188	512	Edroy	94CS6980	326	2.037	Was 6980 last year
189	165	Port Aransas	94CS1000	1,086	2.034	Was 1000 last year
190	217	Sinton	94CS180	1,122	2.030	Was 180 last year
191	655	Rocksprings	94LA8040	312	2.029	Was 8040 last year
192	51	Karon Humble Pump	94CN9895	40	2.025	Was 9895 last year
193	643	Rodd Field	94CS3010	1,298	2.024	Was 3010 last year
194	435	Goodwin	94SB4380	1,248	2.020	Was 4380 last year
195	169	Robstown	94CS7120	57	2.018	Was 7120 last year
196	263	South East Edinburg	94SB5045	1,031	2.018	Was 5045 last year
197	375	Pleasanton	94LA9505	1,300	2.017	Was 9505 last year
198	356	Brownsville	94SB4280	302	1.993	Was 4280 last year
199	537	Highway 9	94CS6760	817	1.987	Was 6760 last year
200	241	Hearn Road	94CS8990	1,031	1.984	Was 8990 last year
201	296	Bruni	94LA5160	196	1.980	Was 5160 last year
202	100	Polk Avenue	94SB4170	1,372	1.974	Was 4170 last year
203	211	La Grulla	94SB4120	1,539	1.966	Was 4120 last year
204	237	Foster Field	94CN2550	248	1.964	Was 2550 last year
205	39	Carrizo Springs	94LA370	289	1.962	Was 370W last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
206	358	Stafford Hill	94CN1550	178	1.961	Was 1550 last year
207	348	Rockport	94CS5940	64	1.953	Was 5940 last year
208	33	Goliad	94CN6540	877	1.949	Was 6540 last year
209	389	Live Oak	94CS1070	2,512	1.947	Was 1070 last year
210	253	Bay City	94CN2700	1,314	1.946	Was 2700 last year
211	24	Southside	94CS8005	493	1.941	Was 8005 last year
212	268	Raymondville #2	94SB4160	889	1.930	Was 4160 last year
213	204	Southside	94CS5335	1,093	1.930	Was 5335 last year
214	147	Garwood City	94CN2560	202	1.911	Was 2560 last year
215	639	Zapata	94LA7330	2,271	1.911	Was 7330 last year
216	503	Pueblo	94LA95	1,413	1.892	Was 95 last year
217	212	Sharyland	94SB2020	2,880	1.891	Was 2020 last year
218	126	Armstrong	94CS6050	48	1.875	Was 6050 last year
219	402	Fulton	94CS9050	1,436	1.872	Was 9050 last year
220	380	Highway 9	94CS6720	1,393	1.852	Was 6720 last year
221	612	Polk Avenue	94SB4520	1,309	1.842	Was 4520 last year
222	516	Clarkwood	94CS9570	1,215	1.823	Was 9570 last year
223	545	Brackettville	94LA8460	1,189	1.812	Was 8460 last year
224	186	Palmview	94SB9685	3,075	1.790	Was 9685 last year
225	129	South Santa Rosa	94SB1235	774	1.784	Was 1235 last year
226	120	Wadsworth	94CN8630	583	1.782	Was 8630 last year
227	386	Airline	94CS9605	693	1.779	Was 9605 last year
228	282	Causeway	94SB4795	1,449	1.770	Was 4795 last year
229	366	La Pryor	94LA580	159	1.767	Was 580 last year
230	401	O'Conner	94CN390	201	1.766	Was 390CN last year
231	420	Aransas Pass	94CS9130	297	1.758	Was 9130 last year
232	641	San Benito	94SB4135	778	1.757	Was 4135 last year
233	431	Kenedy	94CN1970	638	1.757	Was 1970 last year
234	203	Brookhollow	94CN8950	799	1.726	Was 8950 last year
235	372	Holly	94CS5820	892	1.716	Was 5820 last year
236	569	Port Lavaca	94CN8310	305	1.715	Was 8310 last year
237	498	Beeville	94CN300	1,288	1.699	Was 300 last year
238	57	North Edinburg	94SB3570	843	1.699	Was 3570 last year
239	281	Arcadia	94CS1460	2,072	1.693	Was 1460 last year
240	108	North McAllen	94SB9660	1,912	1.677	Was 9660 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
241	173	Carrizo Springs	94LA860	1,427	1.671	Was 860 last year
242	84	Jourdanton	94LA880	381	1.656	Was 880 last year
243	473	Weslaco Unit	94SB8610	2,441	1.643	Was 8610 last year
244	398	Harlingen S.S.	94SB320	1,736	1.641	Was 320 last year
245	514	San Diego	94CS2930	594	1.635	Was 2930 last year
246	19	San Benito	94SB3920	2,010	1.633	Was 3920 last year
247	660	Harlingen	94SB370	1,047	1.630	Was 370 last year
248	458	Del Rio City	94LA1930	1,077	1.618	Was 1930 last year
249	41	La Grulla	94SB5110	908	1.612	Was 5110 last year
250	82	West McAllen	94SB4555	1,584	1.611	Was 4555 last year
251	672	Hamilton Road	94LA9645	291	1.608	Was 9645 last year
252	416	Garceno	94SB2135	1,615	1.604	Was 2135 last year
253	359	Arcadia	94CS1450	1,942	1.604	Was 1450 last year
254	494	Pharaoh	94CS5175	1,047	1.594	Was 5175 last year
255	627	Wesmer	94SB4480	2,462	1.576	Was 4480 last year
256	46	Palmview	94SB3930	2,001	1.571	Was 3930 last year
257	234	Alice	94CS1790	354	1.571	Was 1790 last year
258	437	North Victoria	94CN7860	1,354	1.566	Was 7860 last year
259	177	Luling - LCRA	94CN20	226	1.562	Was 20 last year
260	444	Banquette	94CS130	255	1.553	Was 130 last year
261	17	El Campo	94CN6370	994	1.553	Was 6370 last year
262	116	Campwood	94LA2610	924	1.553	Was 2610 last year
263	254	Woolridge	94CS1170	1,120	1.523	Was 1170CS last year
264	12	Los Fresnos	94SB3280	1,764	1.522	Was 3280 last year
265	181	Pleasanton	94LA9475	1,716	1.519	Was 9475 last year
266	418	Kingsville	94CS1660	1,444	1.518	Was 1660 last year
267	318	San Diego	94CS1980	643	1.516	Was 1980 last year
268	335	Kingsville	94CS1350	277	1.513	Was 1350 last year
269	451	La Grulla	94SB5005	217	1.512	Was 5005 last year
270	86	Sharyland	94SB2010	1,065	1.508	Was 2010 last year
271	185	Holly	94CS7740	1,787	1.506	Was 7740 last year
272	303	Fulton	94CS3070	1,443	1.503	Was 3070 last year
273	422	Bay City	94CN6670	1,817	1.502	Was 6670 last year
274	277	Morris Street	94CS8840	657	1.501	Was 8840 last year
275	264	Beeville	94CN2200	781	1.501	Was 2200 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
276	513	Weaver Road	94CN1910	373	1.499	Was 1910 last year
277	400	North Victoria	94CN1470	405	1.499	Was 1470 last year
278	44	Buena Vista	94LA9035	1,201	1.498	Was 9035 last year
279	300	Elsa	94SB3520	444	1.498	Was 3520 last year
280	521	North Victoria	94CN1580	975	1.488	Was 1580 last year
281	119	Alazan	94CS2740	41	1.488	Was 2740CS last year
282	71	Rio Bravo	94LA5	1,040	1.485	Was 5 last year
283	536	Beeville	94CN490	994	1.484	Was 490CN last year
284	127	Parker	94CN9260	69	1.478	Was 9260 last year
285	476	Mathis	94CS2870	955	1.476	Was 2870 last year
286	160	Woolridge	94CS1120	1,880	1.474	Was 1120CS last year
287	559	Harrington S.S.	94SB4090	2,351	1.466	Was 4090 last year
288	123	San Ygnacio	94LA16060	410	1.461	Was 16060 last year
289	50	Port Isabel S.S.	94SB3760	1,536	1.460	Was 3760 last year
290	484	San Benito	94SB3910	1,709	1.457	Was 3910 last year
291	47	Southside	94CS7955	1,079	1.456	Was 7955 last year
292	645	Premont	94LA6610	865	1.452	Was 6610 last year
293	213	Fulton	94CS6070	2,579	1.449	Was 6070 last year
294	139	Naval Base	94CS1380	1,911	1.445	Was 1380CS last year
295	493	Kleberg	94CS6000	1,536	1.436	Was 6000 last year
296	70	Gateway	94LA350	1,359	1.430	Was 350 last year
297	351	Laredo Plant	94LA8565	999	1.425	Was 8565 last year
298	390	West Oso	94CS9090	1,812	1.424	Was 9090 last year
299	406	West McAllen	94SB4515	822	1.415	Was 4515 last year
300	63	North McAllen	94SB5055	2,323	1.411	Was 5055 last year
301	128	Eagle Pass City	94LA450	1,390	1.410	Was 450 last year
302	528	Palacios	94CN8550	100	1.410	Was 8550 last year
303	478	North Victoria	94CN7770	927	1.406	Was 7770 last year
304	149	West McAllen	94SB4595	965	1.405	Was 4595 last year
305	21	Nueces Bay Plant	94CS345	52	1.404	Was 345 last year
306	90	Runge	94CN7320	592	1.400	Was 7320 last year
307	555	East Harrison	94SB3190	1,194	1.399	Was 3190 last year
308	326	North McAllen	94SB3830	1,391	1.390	Was 3830 last year
309	552	Mathis	94CS1420	840	1.386	Was 1420 last year
310	286	Crestonio	94LA260	1,507	1.382	Was 260 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
311	93	North Mercedes	94SB3770	1,156	1.381	Was 3770 last year
312	410	Greta	94CN7890	301	1.379	Was 7890 last year
313	290	Taft	94CS5230	915	1.378	Was 5230 last year
314	77	South Padre Island	94SB4695	1,143	1.378	Was 4695 last year
315	1	Hidalgo	94SB3400	474	1.376	Was 3400 last year
316	403	Arcadia	94CS1400	445	1.371	Was 1400 last year
317	676	West McAllen	94SB6385	1,305	1.370	Was 6385 last year
318	132	Woodsboro	94CS8330	1,084	1.367	Was 8330CS last year
319	560	Aransas Pass	94CS1250	297	1.367	Was 1250 last year
320	659	Laredo Plant	94LA8745	1,040	1.366	Was 8745 last year
321	135	Pharaoh	94CS1285	1,682	1.353	Was 1285 last year
322	122	Jourdanton	94LA5695	1,219	1.348	Was 5695 last year
323	130	Goliad	94CN8220	1,046	1.347	Was 8220 last year
324	619	Aransas Pass	94CS650	247	1.344	Was 650 last year
325	134	Carrizo Springs	94LA910	1,648	1.332	Was 910 last year
326	81	Southside	94CS7925	1,331	1.331	Was 7925 last year
327	141	Goodwin	94SB7380	1,969	1.321	Was 3530 last year
328	490	Holly	94CS1370	1,816	1.318	Was 1370 last year
329	608	Polk Avenue	94SB4600	2,761	1.312	Was 4600 last year
330	409	Elsa	94SB3500	1,091	1.308	Was 3500 last year
331	510	North Victoria	94CN7430	1,706	1.304	Was 7430 last year
332	48	Brownsville	94SB3050	1,958	1.303	Was 3050 last year
333	331	Bishop	94CS7180	928	1.300	Was 7180 last year
334	153	Del Rio City	94LA420	2,083	1.295	Was 420 last year
335	381	Harlingen S.S.	94SB4110	696	1.290	Was 4110 last year
336	593	Port Lavaca	94CN6850	620	1.287	Was 6850 last year
337	592	Laredo Heights	94LA2450	2,166	1.283	Was 2450 last year
338	83	Three Rivers	94CN8430	140	1.279	Was 8430 last year
339	42	North Mercedes	94SB4860	1,388	1.272	Was 4860 last year
340	194	Bay City	94CN2050	645	1.270	Was 2050 last year
341	80	Blessing	94CN1030	191	1.267	Was 1030 last year
342	276	Santo Nino	94LA80	1,492	1.265	Was 80 last year
343	59	South Padre Island	94SB6440	1,882	1.257	Was 6440 last year
344	225	West McAllen	94SB4535	1,921	1.255	Was 4535 last year
345	27	Wadsworth	94CN7660	1,108	1.254	Was 7660 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
346	306	Holly	94CS1950	792	1.245	Was 1950 last year
347	456	Placedo	94CN7980	395	1.233	Was 7980 last year
348	270	Polk Avenue	94SB4190	2,222	1.222	Was 4190 last year
349	157	Raymondville #2	94SB3170	584	1.221	Was 3170 last year
350	136	Moore Field	94SB3110	407	1.221	Was 3110 last year
351	557	Airline	94CS8890	519	1.216	Was 8890 last year
352	365	Santo Nino	94LA75	1,432	1.216	Was 75 last year
353	131	Bay City	94CN1110	1,013	1.215	Was 1110CN last year
354	600	Laredo Heights	94LA9400	1,565	1.213	Was 9400 last year
355	49	Rio Grande City	94SB3230	1,102	1.212	Was 3230 last year
356	529	Port Aransas	94CS3030	671	1.210	Was 3030CS last year
357	329	Anna Street	94LA850	1,670	1.206	Was 850 last year
358	214	Arcadia	94CS8570	1,337	1.200	Was 8570 last year
359	216	North Padre Island	94CS7900	2,385	1.200	Was 7900 last year
360	143	Fulton	94CS2020	1,681	1.189	Was 2020CS last year
361	506	Morris Street	94CS7625	573	1.187	Was 7625 last year
362	624	Coffee Port	94SB1095	1,030	1.183	Was 1095 last year
363	274	Victoria Power Plant	94CN1390	1,233	1.181	Was 1390 last year
364	349	Edna	94CN5775	517	1.170	Was 5775 last year
365	540	Seawall	94CS9420	872	1.170	Was 9420 last year
366	576	San Benito	94SB4945	1,694	1.168	Was 4945 last year
367	336	Del Rio City	94LA9850	846	1.167	Was 9850 last year
368	353	South East Edinburg	94SB4015	875	1.166	Was 4015 last year
369	233	Premont	94LA2730	208	1.163	Was 2730 last year
370	317	Airline	94CS9030	432	1.162	Was 9030 last year
371	323	Pharaoh	94CS1185	1,352	1.160	Was 1185 last year
372	616	Airline	94CS9390	1,654	1.160	Was 9390 last year
373	542	Washington Street	94LA2350	2,974	1.159	Was 2350 last year
374	74	Banquette	94CS9000	536	1.159	Was 9000 last year
375	161	McKenzie Road	94CS150	19	1.158	Was 150 last year
376	505	Cavazos	94SB3560	932	1.152	Was 3560 last year
377	311	Bay City	94CN7480	1,959	1.151	Was 7480 last year
378	658	Eagle Pass City	94LA2770	2,172	1.150	Was 2770 last year
379	179	South Padre Island	94SB5850	1,275	1.147	Was 5850 last year
380	565	Airline	94CS6970	1,096	1.144	Was 6970 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
381	520	Edna	94CN5785	736	1.144	Was 5785 last year
382	145	Columbus	94CN9060	541	1.140	Was 9060 last year
383	421	Fulton	94CS440	1,968	1.135	Was 440 last year
384	653	Casa Blanca	94CS5115	1,155	1.121	Was 5115 last year
385	556	Fannin	94CN7940	25	1.120	Was 7940 last year
386	657	East Harrison	94SB3080	495	1.113	Was 3080 last year
387	312	Rodd Field	94CS1730	1,809	1.109	Was 1730 last year
388	346	Southside	94CS5345	396	1.109	Was 5345 last year
389	462	South McAllen	94SB3850	196	1.102	Was 3850 last year
390	630	Magruder	94CN6700	1,886	1.096	Was 6700 last year
391	85	Asherton	94LA2670	158	1.095	Was 2670 last year
392	603	Hearn Road	94CS2220	1,588	1.091	Was 2220 last year
393	313	Rodd Field	94CS2190	2,821	1.091	Was 2190 last year
394	292	Victoria Power Plant	94CN8070	616	1.086	Was 8070 last year
395	341	North McAllen	94SB9640	824	1.081	Was 9640 last year
396	112	Kleberg	94CS1560	903	1.078	Was 1560 last year
397	649	Airline	94CS7270	951	1.077	Was 7270 last year
398	480	Airline	94CS7280	606	1.073	Was 7280 last year
399	337	Continental	94SB4880	57	1.070	Was 4880 last year
400	454	Morris Street	94CS8850	446	1.067	Was 8850 last year
401	275	North Victoria	94CN6390	1,370	1.065	Was 6390 last year
402	572	Pharaoh	94CS5185	1,796	1.062	Was 5185 last year
403	121	Causeway	94SB4775	1,044	1.057	Was 4775 last year
404	509	Brookhollow	94CN7580	510	1.055	Was 7580 last year
405	443	Wesmer	94SB4050	1,656	1.042	Was 4050 last year
406	611	Eagle Pass City	94LA2510	640	1.038	Was 2510 last year
407	669	Washington Street	94LA2360	747	1.036	Was 2360 last year
408	67	Hearn Road	94CS9665	570	1.032	Was 9665 last year
409	412	Raymondville #1	94SB3130	95	1.021	Was 3130 last year
410	598	Pettus	94CN1020	383	1.021	Was 1020 last year
411	644	Pharaoh	94CS1365	470	1.019	Was 1365 last year
412	601	Del Mar	94LA490	1,092	1.018	Was 490 last year
413	321	El Campo	94CN5745	914	1.014	Was 5745 last year
414	295	Bruni	94LA1100	685	1.013	Was 1100 last year
415	364	Jourdanton	94LA250	676	1.004	Was 250 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
416	666	Washington Street	94LA2470	275	1.004	Was 2470 last year
417	688	Washington Street	94LANETLAR	520	1.000	Was NET LAR last year
418	638	Coffee Port	94SB1090	1,307	0.985	Was 1090 last year
419	76	Haine Drive	94SB9690	926	0.973	Was 9690 last year
420	397	Cabaniss	94CS80	784	0.964	Was 80 last year
421	316	Point Comfort	94CN2460	145	0.952	Was 2460 last year
422	345	North McAllen	94SB5060	1,760	0.942	Was 5060 last year
423	633	Lolita	94CN6330	29	0.931	Was 6330CN last year
424	269	Beeville	94CN8090	1,256	0.924	Was 8090 last year
425	523	Rio Grande City	94SB3210	1,470	0.913	Was 3210 last year
426	219	Continental	94SB4080	123	0.911	Was 4080 last year
427	222	South East Edinburg	94SB4570	1,269	0.901	Was 4570 last year
428	170	Haine Drive	94SB270	805	0.889	Was 270 last year
429	343	Santo Nino	94LA70	3,004	0.879	Was 70 last year
430	492	Charlotte	94LA8120	151	0.868	Was 8120 last year
431	497	Bandera Electric (Leakey)	94LAL30	388	0.858	Was L30 last year
432	137	Southside	94CS8045	1,065	0.852	Was 8045 last year
433	474	Garceno	94SB2130	1,326	0.848	Was 2130 last year
434	396	Alice	94CS1770	1,503	0.840	Was 1770 last year
435	221	Freer	94LA1500	209	0.837	Was 1500 last year
436	355	Pleasanton	94LA2080	1,357	0.837	Was 2080 last year
437	158	Pueblo	94LA275	1,365	0.824	Was 275 last year
438	242	Alice	94CS2530	1,322	0.818	Was 2530 last year
439	404	Beeville	94CN1760	1,011	0.814	Was 1760 last year
440	188	Matthews	94CN1740	154	0.805	Was 1740 last year
441	332	Thomaston	94CN9580	51	0.804	Was 9580 last year
442	667	Brookhollow	94CN7190	383	0.802	Was 7190 last year
443	26	Hall Acres Road	94SB5465	3,856	0.769	Was 5465 last year
444	299	Darst	94CN790	89	0.764	Was 790 last year
445	155	Sinton	94CS1750	378	0.749	Was 1750 last year
446	7	Casa Blanca	94CS55	353	0.745	Was 55 last year
447	6	West Harlingen	94SB4870	544	0.728	Was 4870 last year
448	459	Beeville	94CN8510	946	0.714	Was 8510CN last year
449	470	South East Edinburg	94SB4550	1,798	0.711	Was 4550 last year
450	195	Palmview	94SB9680	1,773	0.711	Was 9680 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
451	257	Ingleside City	94CS8050	1,718	0.710	Was 8050 last year
452	168	Raymondville #2	94SB3240	1,231	0.705	Was 3240 last year
453	468	Southside	94CS7905	1,760	0.701	Was 7905 last year
454	518	Nixon	94CN2620	584	0.692	Was 2620 last year
455	452	Raymondville #2	94SB1280	1,496	0.680	Was 1280 last year
456	543	Darst	94CN800	211	0.673	Was 800 last year
457	106	Stadium	94CS7490	1,180	0.669	Was 7490 last year
458	183	Rockport	94CS5950	532	0.656	Was 5950 last year
459	252	Highway 9	94CS6780	872	0.646	Was 6780 last year
460	227	Weslaco Unit	94SB9805	2,065	0.645	Was 9805 last year
461	350	Freer	94LA2900	316	0.636	Was 2900 last year
462	538	South Mission	94SB3620	1,066	0.624	Was 3620 last year
463	267	Palacios	94CN6840	1,373	0.623	Was 6840 last year
464	30	Los Fresnos	94SB930	1,775	0.623	Was 930S last year
465	551	Dilley	94LA510	458	0.614	Was 510 last year
466	22	Stadium	94CS7800	641	0.613	Was 7800 last year
467	98	Portland	94CS9290	1,626	0.602	Was 9290 last year
468	245	West McAllen	94SB4815	844	0.598	Was 4815 last year
469	249	Southside	94CS8055	1,055	0.596	Was 8055 last year
470	471	San Diego	94CS2890	990	0.594	Was 2890 last year
471	156	Devine	94LA8100	1,220	0.580	Was 8100 last year
472	167	Clarkwood	94CS7230	671	0.577	Was 7230 last year
473	32	Alice	94CS2540	1,591	0.565	Was 2540 last year
474	231	Crystal City	94LA190	1,025	0.563	Was 190 last year
475	333	North Edinburg	94SB4240	710	0.559	Was 4240 last year
476	239	Arcadia	94CS6930	1,564	0.555	Was 6930 last year
477	322	Premont	94LA2720	901	0.554	Was 2720 last year
478	425	Skidmore	94CS600	350	0.551	Was 600 last year
479	477	George West	94CN730	714	0.550	Was 730 last year
480	68	Hall Acres Road	94SB9595	428	0.542	Was 9595 last year
481	423	Arcadia	94CS5030	1,543	0.542	Was 5030 last year
482	272	Leary Lane	94CN6005	796	0.541	Was 6005 last year
483	434	Zacate Creek	94LA2675	515	0.540	Was 2675 last year
484	385	Laredo Plant	94LA8695	332	0.533	Was 8695 last year
485	407	Port Lavaca	94CN2480	1,504	0.529	Was 2480CN last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
486	79	Pharr	94SB1625	1,715	0.526	Was 1625 last year
487	481	Greenlake	94CN2740	23	0.522	Was 2740CN last year
488	534	Weslaco Unit	94SB5970	2,571	0.507	Was 5970 last year
489	196	North McAllen	94SB2980	2,001	0.505	Was 2980 last year
490	118	Morris Street	94CS8820	1,212	0.499	Was 8820 last year
491	469	Alice	94CS1780	278	0.493	Was 1780 last year
492	220	Nixon	94CN5990	519	0.491	Was 5990 last year
493	445	Cotulla	94LA90	617	0.491	Was 90 last year
494	109	North Victoria	94CN7440	1,525	0.490	Was 7440 last year
495	563	George West	94CN1320	587	0.489	Was 1320 last year
496	308	Anna Street	94LA2250	1,684	0.485	Was 2250 last year
497	604	Polk Avenue	94SB4610	1,617	0.484	Was 4610 last year
498	617	North Padre Island	94CS5170	2,236	0.483	Was 5170 last year
499	363	Campwood	94LA3430	58	0.483	Was 3430 last year
500	446	Sinton	94CS6860	1,326	0.468	Was 6860 last year
501	150	Pearsall	94LA5580	1,983	0.454	Was 5580 last year
502	266	Rangerville	94SB3410	726	0.452	Was 3410 last year
503	650	North Edinburg	94SB3810	639	0.446	Was 3810 last year
504	18	Portland	94CS9270	1,755	0.444	Was 9270 last year
505	304	Asherton	94LA2660	658	0.442	Was 2660 last year
506	328	East Harrison	94SB3030	824	0.442	Was 3030 last year
507	302	Pharr	94SB1620	2,578	0.436	Was 1620 last year
508	580	Del Rio City	94LA9790	2,826	0.435	Was 9790 last year
509	111	Hall Acres Road	94SB3670	928	0.435	Was 3670 last year
510	285	Kenedy	94CN6270	467	0.435	Was 6270 last year
511	95	Gateway	94LA380	679	0.429	Was 380 last year
512	442	Hamilton Road	94LA9655	951	0.428	Was 9655 last year
513	614	Polk Avenue	94SB4180	1,716	0.425	Was 4180 last year
514	618	Crystal City	94LA140	1,696	0.423	Was 140W last year
515	677	McColl Road	94SB4910	869	0.419	Was 4910 last year
516	163	West Harlingen	94SB3720	1,915	0.412	Was 3720 last year
517	472	Kleberg	94CS9395	1,096	0.408	Was 9395 last year
518	124	North Mercedes	94SB3840	655	0.408	Was 3840 last year
519	500	Lealy Lane	94CN1890	1,441	0.406	Was 1890 last year
520	357	Roma	94SB3070	1,656	0.405	Was 3070 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
521	464	Charlotte	94LA2790	177	0.395	Was 2790 last year
522	571	Nordheim	94CN470	242	0.388	Was 470 last year
523	665	Clarkwood	94CS7220	115	0.383	Was 7220 last year
524	526	Del Rio City	94LA430	2,327	0.380	Was 430 last year
525	647	Port Lavaca	94CN2490	1,093	0.379	Was 2490 last year
526	461	Sharyland	94SB5635	1,174	0.377	Was 2150 last year
527	102	Portland	94CS6505	1,603	0.377	Was 6505 last year
528	45	Rockport	94CS5930	970	0.376	Was 5930 last year
529	235	Yorktown	94CN8420	908	0.372	Was 8420 last year
530	533	Leary Lane	94CN1540	1,707	0.367	Was 1540 last year
531	247	Leary Lane	94CN7530	1,899	0.364	Was 7530 last year
532	14	Prairie Pump	94CN1940	61	0.361	Was 1940 last year
533	370	Uvalde	94LA9770	1,226	0.358	Was 9770 last year
534	162	Uvalde	94LA550	639	0.355	Was 550 last year
535	133	San Diego	94CS2880	1,423	0.354	Was 2880 last year
536	197	Southside	94CS8025	1,168	0.352	Was 8025 last year
537	436	Aransas Pass	94CS590	148	0.345	Was 590 last year
538	450	Pleasanton	94LA120	1,222	0.345	Was 120 last year
539	307	Southside	94CS8035	1,069	0.342	Was 8035 last year
540	544	Harlingen	94SB360	2,519	0.341	Was 360 last year
541	279	Haine Drive	94SB9700	640	0.339	Was 9700 last year
542	191	Seawall	94CS9325	1,864	0.335	Was 9325 last year
543	226	Highway 9	94CS6770	1,589	0.334	Was 6770 last year
544	515	Kingsville	94CS1140	969	0.331	Was 1140 last year
545	595	Kenedy S.S.	94CN8340	695	0.328	Was 8340 last year
546	151	Holly	94CS1480	1,687	0.328	Was 1480 last year
547	519	Weslaco Unit	94SB7455	1,531	0.327	Was 7455 last year
548	674	South McAllen	94SB3640	259	0.317	Was 3640 last year
549	327	Kleberg	94CS280	1,384	0.313	Was 280 last year
550	602	Eagle Lake	94CN320	665	0.313	Was 320CN last year
551	508	Harlingen	94SB380	2,137	0.312	Was 380 last year
552	382	Three Rivers	94CN2010	745	0.311	Was 2010CN last year
553	201	North Weslaco	94SB4830	423	0.307	Was 4830 last year
554	56	Buena Vista	94LA8965	931	0.302	Was 8965 last year
555	457	Ingleside City	94CS8060	1,932	0.300	Was 8060 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
556	388	Aransas Pass	94CS8280	346	0.298	Was 8280 last year
557	671	Airline	94CS5870	830	0.294	Was 5870CS last year
558	561	Palacios	94CN6830	894	0.277	Was 6830 last year
559	415	Kingsville	94CS1670	398	0.274	Was 1670 last year
560	501	South Mission	94SB5215	1,206	0.272	Was 5215 last year
561	283	Morris Street	94CS7465	675	0.271	Was 7465 last year
562	125	Rio Grande City	94SB3220	1,409	0.269	Was 3220 last year
563	546	Port Aransas	94CS990	1,046	0.267	Was 990CS last year
564	668	Highway 9	94CS9830	105	0.267	Was 9830 last year
565	539	Knippa	94LA6535	15	0.267	Was 6535 last year
566	581	Brookhollow	94CN8960	651	0.264	Was 8960 last year
567	55	Buena Vista	94LA9385	1,702	0.259	Was 9385 last year
568	10	West Harlingen	94SB3800	1,346	0.259	Was 3800 last year
569	378	South Mission	94SB3590	864	0.258	Was 3590 last year
570	243	Hall Acres Road	94SB4895	1,235	0.256	Was 4895 last year
571	622	Roma	94SB3060	1,738	0.254	Was 3060 last year
572	635	Refugio	94CN1040	560	0.254	Was 1040 last year
573	298	North McAllen	94SB4995	2,070	0.252	Was 4995 last year
574	325	Zacate Creek	94LA2665	884	0.251	Was 2665 last year
575	297	Magruder	94CN6690	538	0.251	Was 6690 last year
576	53	Southside	94CS7995	1,542	0.247	Was 7995 last year
577	258	Dilley	94LA6400	1,009	0.246	Was 6400 last year
578	395	Morris Street	94CS2515	1,167	0.245	Was 2515 last year
579	625	North Victoria	94CN2240	784	0.242	Was 2240 last year
580	232	Victoria Power Plant	94CN8170	747	0.242	Was 8170 last year
581	152	Cabaniss	94CS240	1,206	0.242	Was 240 last year
582	438	Knippa	94LA6365	285	0.239	Was 6365 last year
583	588	Polk Avenue	94SB4900	2,338	0.234	Was 4900 last year
584	453	Arcadia	94CS1360	1,570	0.234	Was 1360 last year
585	441	Leary Lane	94CN6175	1,220	0.234	Was 6175 last year
586	554	Aransas Pass	94CS660	346	0.231	Was 660CS last year
587	662	Gregory	94CS420	26	0.231	Was 420 last year
588	43	Uvalde	94LA540	1,209	0.231	Was 540 last year
589	502	Berclair	94CN990	241	0.228	Was 990C last year
590	115	El Campo	94CN7710	1,120	0.228	Was 7710 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
591	648	Crestonio	94LA6660	976	0.225	Was 6660 last year
592	535	McColl Road	94SB4790	1,968	0.224	Was 4790 last year
593	564	Bay City	94CN5960	1,890	0.221	Was 5960 last year
594	330	East Harrison	94SB4620	967	0.220	Was 4620 last year
595	62	Point Comfort	94CN6060	260	0.219	Was 6060 last year
596	466	Laredo Plant	94LA8505	1,040	0.219	Was 8505 last year
597	549	Magruder	94CN6680	639	0.219	Was 6680 last year
598	656	McColl Road	94SB4780	1,691	0.218	Was 4780 last year
599	96	Santo Nino	94LA695	787	0.216	Was 695 last year
600	673	Del Mar	94LA7930	2,601	0.216	Was 7930 last year
601	78	South McAllen	94SB3935	956	0.214	Was 3935 last year
602	28	West Oso	94CS9085	711	0.210	Was 9085 last year
603	591	Del Mar	94LA10	3,000	0.210	Was 10 last year
604	61	Portland	94CS9370	1,020	0.208	Was 9370 last year
605	354	Sabinal	94LA200	416	0.207	Was 200 last year
606	661	Del Mar	94LA3440	2,601	0.206	Was 3440 last year
607	144	Eagle Lake	94CN310	767	0.205	Was 310 last year
608	377	South Mission	94SB3940	833	0.204	Was 3940 last year
609	482	Three Rivers	94CN5100	40	0.200	Was 5100 last year
610	578	Magruder	94CN245	1,225	0.198	Was 245 last year
611	589	El Campo	94CN2800	1,369	0.196	Was 2800 last year
612	495	Markham	94CN6440	455	0.193	Was 6440CN last year
613	273	Sunchase	94SB1155	1,102	0.193	Was 1155 last year
614	199	Big Wells	94LA1570	497	0.193	Was 1570 last year
615	171	Arcadia	94CS5020	1,531	0.189	Was 5020 last year
616	483	Yorktown	94CN8380	822	0.179	Was 8380 last year
617	637	Del Rio City	94LA440	1,405	0.167	Was 440 last year
618	291	Leary Lane	94CN1430	1,358	0.167	Was 1430 last year
619	305	Freer	94LA5200	1,295	0.161	Was 5200 last year
620	582	Laredo Heights	94LA6820	1,532	0.160	Was 6820 last year
621	172	Robstown	94CS1650	418	0.153	Was 1650 last year
622	590	Anna Street	94LA780	495	0.152	Was 780 last year
623	527	Charlotte	94LA2780	531	0.151	Was 2780 last year
624	87	Holly	94CS1220	2,028	0.149	Was 1220 last year
625	579	Laredo Heights	94LA2390	769	0.144	Was 2390 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
626	609	Wesmer	94SB9705	1,242	0.142	Was 9705 last year
627	367	Laredo Heights	94LA2100	1,769	0.139	Was 2100 last year
628	636	Pettus	94CN8210	352	0.134	Was 8210 last year
629	309	Weslaco Unit	94SB7630	2,501	0.132	Was 7630 last year
630	594	Washington Street	94LA6355	1,162	0.130	Was 6355 last year
631	340	Kenedy S.S.	94CN8320	863	0.127	Was 8320 last year
632	524	Ganado	94CN5815	544	0.127	Was 5815 last year
633	615	Asphalt Mines	94LA500	24	0.125	Was 500 last year
634	654	Sharyland	94SB2150	1,413	0.124	Was 2035 last year
635	146	Jourdanton	94LA5685	563	0.112	Was 5685 last year
636	new	Palmhurst	94SB2530	1,764	0.109	New, much from 3890
637	531	Magruder	94CN7870	1,270	0.102	Was 7870 last year
638	371	Mustang Island	94CS9470	646	0.101	Was 9470 last year
639	new	North Padre Island	94CS1010	1,087	0.098	New
640	585	South Mission	94SB4650	1,081	0.098	Was 4650 last year
641	324	Washington Street	94LA6525	2,367	0.097	Was 6525 last year
642	491	Refugio	94CN1210	229	0.096	Was 1210 last year
643	642	Three Rivers	94CN5190	685	0.092	Was 5190 last year
644	new	Goodwin	94SB3530	1,012	0.090	Partial customers from last year's 4625
645	541	Skidmore	94CS380	278	0.090	Was 380CS last year
646	634	Laredo Heights	94LA6810	1,863	0.090	Was 6810 last year
647	566	Anna Street	94LA5780	828	0.089	Was 5780 last year
648	574	Magruder	94CN7690	898	0.089	Was 7690 last year
649	293	Kenedy S.S.	94CN6750	495	0.089	Was 6750 last year
650	670	Santo Nino	94LA645	1,850	0.088	Was 645 last year
651	187	University	94LA930	104	0.087	Was 930 last year
652	575	Cotulla	94LA110	1,399	0.086	Was 110 last year
653	34	Comstock	94LA290	199	0.085	Was 290 last year
654	629	Airline	94CS7390	1,581	0.083	Was 7390 last year
655	91	Holly	94CS9675	1,734	0.082	Was 9675 last year
656	605	Eagle Pass City	94LA7060	1,314	0.082	Was 7060 last year
657	256	Sabinal	94LA485	496	0.081	Was 485 last year
658	584	Refugio	94CN1170	1,131	0.073	Was 1170CN last year
659	587	Garwood City	94CN2570	302	0.073	Was 2570 last year
660	148	Nixon	94CN810	537	0.071	Was 810 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
661	621	Del Mar	94LA220	486	0.070	Was 220 last year
662	301	Mustang Island	94CS8510	47	0.064	Was 8510CS last year
663	417	Freer	94LA6320	178	0.062	Was 6320 last year
664	631	Big Wells	94LA2630	243	0.062	Was 2630 last year
665	652	El Campo	94CN7260	578	0.054	Was 7260 last year
666	465	Laredo Heights	94LA9080	427	0.052	Was 9080 last year
667	361	Kenedy	94CN1960	60	0.050	Was 1960 last year
668	433	San Benito	94SB3860	250	0.048	Was 3860 last year
669	628	Woolridge	94CS1110	1,352	0.047	Was 1110CS last year
670	338	North Weslaco	94SB4810	1,215	0.044	Was 4810 last year
671	339	Laredo Plant	94LA8705	728	0.041	Was 8705 last year
672	391	Washington Street	94LA7015	1,985	0.034	Was 7015 last year
673	570	El Campo	94CN2860	395	0.030	Was 2860 last year
674	360	Santo Nino	94LA515	1,283	0.023	Was 515 last year
675	530	Airline	94CS8370	312	0.016	Was 8370 last year
676	686	Zacate Creek	94LA2635	906	0.011	Was 2635 last year
677	174	Haine Drive	94SB9240	649	0.011	Was 9240 last year
678	675	Beeville	94CN2380	817	0.010	Was 2380 last year
679	424	Laredo Plant	94LA9305	1,872	0.010	Was 9305 last year
680	664	East Harrison	94SB3000	900	0.009	Was 3000 last year
681	new	Sharyland	94SB2035	1,714	0.006	New feeder, not 2035 last year
682	680	Victoria Power Plant	94CNNETVIC	190	-	Was NET VIC last year
683	new	North Padre Island	94CS720	278	-	New
684	646	Ingleside City	94CS7310	40	-	Was 7310 last year
685	683	Southside	94CS7935	35	-	Was 7935 last year
686	684	STEC (Riverside)	94CS9101	199	-	Was 9101 last year
687	685	Morris Street	94CSNET CC	426	-	Was NET CC last year
688	687	Zapata	94LA8300	340	-	Was 8300 last year
689	new	Haine Drive	94SB3490	663	-	New, piece from 270

Feeders from last year that do not appear this year:

159	BANQUETTE	740	Serves <10 customers
678	CHASE FIELD	460	Serves <10 customers
679	NORMANNA CST	840	Serves <10 customers
681	AIRLINE	2180	Serves <10 customers

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIFI Ranking	2005 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIFI Value	Notes
	682	AIRLINE	2210			Serves <10 customers

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or More Customers

Total Number of Feeders

689

Add or Delete Rows as Necessary

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
1	50	Bruni	94LA5440	31	1,444.9	Was 5440 last year
2	1	Alazan	94CS620	207	888.2	Was 620 last year
3	131	Moore Field	94SB3960	3,131	862.2	Was 3960 last year
4	495	Conoco-Chittam Ranch	94LA8580	64	838.6	Was 8580 last year
5	62	Nueces Bay Plant	94CS350	782	830.3	Was 350 last year
6	95	Raymondville #1	94SB620	656	804.3	Was 620 last year
7	581	Blessing	94CN8780	68	773.9	Was 8780 last year
8	364	Rachal	94LA6595	580	766.3	Was 6595 last year
9	76	Elsa	94SB710	1,225	764.3	Was 710 last year
10	399	Rachal	94LA8145	10	721.0	Was 8145 last year
11	389	Randado	94LA8350	39	711.4	Was 8350 last year
12	461	Malone	94CN7560	227	708.5	Was 7560 last year
13	591	Greenlake	94CN2750	993	690.5	Was 2750CN last year
14	217	Premont	94LA6570	579	647.5	Was 6570 last year
15	42	North Alamo	94SB3610	3,643	638.3	Was 4370 last year
16	269	Rangerville	94SB3420	757	611.2	Was 3420 last year
17	179	Moore Field	94SB3120	114	602.3	Was 3120 last year
18	93	Armstrong	94CS6050	48	583.0	Was 6050 last year
19	623	Phair	94SB1645	1,669	573.2	Was 1645 last year
20	414	Zapata	94LA8290	2,009	566.8	Was 8290W last year
21	316	Airline	94CS8260	862	553.5	Was 8260 last year
22	292	Taft	94CS1260	109	538.7	Was 1260 last year
23	511	Carancahua	94CN5870	341	534.3	Was 5870CN last year
24	53	Luling - LCRA	94CN10	261	525.3	Was 10CN last year
25	26	Elsa	94SB700	1,348	523.0	Was 700 last year
26	137	Government Wells	94LA7250	363	514.5	Was 7250 last year
27	532	Brackettville	94LA8460	1,189	510.4	Was 8460 last year
28	216	Malone	94CN7550	218	499.8	Was 7550 last year
29	158	Rio Bravo	94LA300	897	486.5	Was 300 last year
30	117	Laguna	94CS9590	2,134	485.7	Was 9590 last year
31	266	Blessing	94CN8790	661	466.6	Was 8790 last year
32	7	Bruni	94LA1120	89	466.4	Was 1120 last year
33	46	Blessing	94CN1030	191	461.7	Was 1030 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
34	565	Milo	94LA3065	216	451.9	Was 3065 last year
35	64	Odem	94CS375	750	442.6	Was 375 last year
36	81	Port Isabel S.S.	94SB3820	452	442.3	Was 3820 last year
37	34	Rio Rico	94SB8330	521	436.5	Was 8330 last year
38	345	Palmhurst	94SB2535	911	436.5	Was 2535 last year
39	265	Gregory	94CS5900	80	421.5	Was 5900 last year
40	172	Tatton	94CS8200	1,426	409.4	Was 8200 last year
41	483	Parker	94CN9010	14	409.3	Was 9010 last year
42	49	McKenzie Road	94CS140	150	405.2	Was 140 last year
43	434	North Alamo	94SB4370	1,071	397.1	Was 3610 last year
44	295	Government Wells	94LA7240	229	396.7	Was 7240 last year
45	35	Encinal	94LA2160	650	392.0	Was 2160 last year
46	558	South Mission	94SB3980	1,080	391.3	Was 3980 last year
47	349	Weil Tract (138/12KV)	94CS2520	291	390.6	Was 2520 last year
48	256	Stadium	94CS7810	1,627	386.9	Was 7810 last year
49	3	Hidalgo	94SB3680	848	383.0	Was 3680 last year
50	360	Government Wells	94LA6800	221	370.0	Was 6800 last year
51	156	North McAllen	94SB2750	2,591	365.6	Was 2750 last year
52	23	North Edinburg	94SB560	875	364.6	Was 560 last year
53	164	Palmhurst	94SB2525	2,029	359.3	Was 2525 last year
54	12	Asherton	94LA2670	158	356.5	Was 2670 last year
55	175	Clarkwood	94CS7610	185	351.5	Was 7610 last year
56	551	Zapata	94LA2710	44	350.0	Was 2710 last year
57	385	Causeway	94SB4765	1,152	349.7	Was 4765 last year
58	132	Moore Field	94SB3110	407	347.9	Was 3110 last year
59	66	Polk Avenue	94SB4170	1,372	347.7	Was 4170 last year
60	262	Falfurrias	94LA1080	436	346.3	Was 1080W last year
61	429	Aransas Pass	94CS8270	445	342.2	Was 8270 last year
62	373	Refugio	94CN5120	124	340.8	Was 5120 last year
63	220	Uvalde	94LA6620	2,605	338.8	Was 6620 last year
64	489	South Santa Rosa	94SB1225	328	337.0	Was 1225 last year
65	333	North Alamo	94SB3580	2,193	334.5	Was 3580 last year
66	100	South East Edinburg	94SB6580	2,142	333.7	Was 6580 last year
67	350	Mines Road	94LA3745	1,160	333.4	Was 3745 last year
68	462	Mathis	94CS340	1,540	324.0	Was 340CS last year
69	13	Elsa	94SB3520	444	322.1	Was 3520 last year
70	85	Randado	94LA8360	117	321.3	Was 8360 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
71	186	Sharyland	94SB2010	1,065	319.4	Was 2010 last year
72	478	Hearn Road	94CS8980	961	319.0	Was 8980 last year
73	17	Raymondville #1	94SB630	794	313.1	Was 630 last year
74	245	Mines Road	94LA3680	533	308.5	Was 3680 last year
75	141	Falfurrias	94LA5210	998	307.7	Was 5210 last year
76	154	Highway 9	94CS6720	1,393	305.2	Was 6720 last year
77	104	Edroy	94CS6990	232	305.1	Was 6990 last year
78	330	Rangerville	94SB4060	714	303.8	Was 4060 last year
79	69	Crestonio	94LA270	623	302.3	Was 270W last year
80	18	La Pryor	94LA570	94	302.1	Was 570 last year
81	9	Tatton	94CN8490	160	300.3	Was 8490 last year
82	357	Bonnieview	94CS8020	444	297.5	Was 8020 last year
83	415	Falfurrias	94LA2830	1,398	296.9	Was 2830 last year
84	80	Port Isabel S.S.	94SB3760	1,536	293.0	Was 3760 last year
85	145	Cavazos	94SB3550	1,887	289.4	Was 3550 last year
86	479	East Harrison	94SB4360	1,465	288.9	Was 4360 last year
87	585	Wesmer	94SB6900	1,492	285.9	Was 6900 last year
88	70	McColl Road	94SB4400	1,269	285.6	Was 4400 last year
89	281	Weil Tract (138/12kV)	94CS5405	144	284.7	Was 5405 last year
90	170	Bruni	94LA5160	196	284.6	Was 5160 last year
91	311	Ganado	94CN5795	682	284.4	Was 5795 last year
92	174	Port Aransas	94CS6940	1,493	277.5	Was 6940 last year
93	6	East Harrison	94SB3950	519	276.3	Was 3950 last year
94	428	Kieberg	94CS6410	366	272.5	Was 6410 last year
95	63	Maverick	94LA9680	603	268.6	Was 9680W last year
96	559	Harlingen	94SB660	2,141	268.2	Was 660 last year
97	190	Pharr	94SB1640	901	265.7	Was 1640 last year
98	574	McColl Road	94SB2810	1,737	264.6	Was 2810 last year
99	313	La Pryor	94LA2440	585	263.2	Was 2440 last year
100	136	McKenzie Road	94CS150	19	261.7	Was 150 last year
101	608	Rocksprings	94LA8040	312	260.4	Was 8040 last year
102	31	North Edinburg	94SB3570	843	259.7	Was 3570 last year
103	97	South McAllen	94SB3790	1,353	256.6	Was 3790 last year
104	101	South Santa Rosa	94SB1235	774	254.3	Was 1235 last year
105	10	Los Fresnos	94SB3290	928	254.2	Was 3290 last year
106	22	Weaver Road	94CN1900	54	253.1	Was 1900 last year
107	165	Lytle	94LA2850	655	249.2	Was 2850 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
108	148	Goliad	94CN8220	1,046	247.7	Was 8220 last year
109	32	Los Fresnos	94SB3200	2,564	247.5	Was 3200 last year
110	528	Kenedy	94CN1970	638	244.6	Was 1970 last year
111	506	Highway 9	94CS6730	376	243.9	Was 6730 last year
112	355	Eagle Pass City	94LA2745	1,303	243.8	Was 2745 last year
113	404	Casa Blanca	94CS1300	584	243.5	Was 1300CS last year
114	94	Palmhurst	94SB1300	1,688	243.4	Was 1300 last year
115	92	Markham	94CN5550	84	240.5	Was 5550 last year
116	51	Brownsville	94SB4290	1,663	240.2	Was 4290 last year
117	469	West McAllen	94SB4505	1,964	238.6	Was 4505 last year
118	334	McKenzie Road	94CS330	1,969	235.3	Was 330 last year
119	19	Raymondville #2	94SB3250	41	234.0	Was 3250 last year
120	20	Alazan	94CS2740	41	233.3	Was 2740CS last year
121	403	Live Oak	94CS1080	646	232.8	Was 1080 last year
122	27	Clarkwood	94CS5525	698	232.8	Was 5525 last year
123	106	Elsa	94SB690	2,038	232.4	Was 690 last year
124	98	Port Aransas	94CS1000	1,086	230.5	Was 1000 last year
125	91	Devine	94LA7090	803	230.4	Was 7090 last year
126	312	Fulton	94CS9050	1,436	230.3	Was 9050 last year
127	628	Port Lavaca	94CN8310	305	230.0	Was 8310 last year
128	24	Mathis	94CS1410	222	229.0	Was 1410 last year
129	622	Ingleside City	94CS6040	203	226.9	Was 6040 last year
130	206	Holly	94CS5820	892	225.5	Was 5820 last year
131	38	Freer	94LA1500	209	224.2	Was 1500 last year
132	503	Milo	94LA3060	2,252	224.0	Was 3060 last year
133	87	Raymondville #2	94SB3170	584	221.9	Was 3170 last year
134	380	West McAllen	94SB4515	822	219.4	Was 4515 last year
135	109	Kleberg	94CS8140	170	216.6	Was 8140 last year
136	407	Placedo	94CN7970	386	216.0	Was 7970 last year
137	637	Premont	94LA6610	865	215.9	Was 6610 last year
138	242	Victoria Power Plant	94CN7600	168	214.3	Was 7600 last year
139	263	Rocksprings	94LA2600	363	213.2	Was 2600 last year
140	475	Taft	94CS1180	1,154	210.9	Was 1180 last year
141	160	Weil Tract (138/12kV)	94CS1990	993	210.8	Was 1990 last year
142	524	Goodwin	94SB4390	599	210.7	Was 4390 last year
143	465	Hamilton Road	94LA9665	718	209.9	Was 9665W last year
144	566	Morris Street	94CS8830	1,572	209.6	Was 8830 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
145	374	Stadium	94CS8540	1,640	209.2	Was 8540 last year
146	168	South East Edinburg	94SB5045	1,031	207.9	Was 5045 last year
147	193	Goodwin	94SB4625	711	207.3	Was 4625, but reconfig since last year
148	36	Karon Humble Pump	94CN9895	40	205.0	Was 9895 last year
149	259	Arcadia	94CS1400	445	204.0	Was 1400 last year
150	133	West McAllen	94SB4965	922	202.0	Was 4965 last year
151	527	Edroy	94CS6980	326	201.6	Was 6980 last year
152	614	Coffee Port	94SB1095	1,030	200.8	Was 1095 last year
153	171	North McAllen	94SB9660	1,912	197.2	Was 9660 last year
154	386	Sunchase	94SB1150	975	197.2	Was 1150 last year
155	497	San Benito	94SB4030	2,356	192.1	Was 4030 last year
156	315	South Santa Rosa	94SB1215	1,686	191.6	Was 1215 last year
157	126	Rio Rico	94SB8290	79	191.5	Was 8290 last year
158	505	Causeway	94SB4795	1,449	191.3	Was 4795 last year
159	514	Pueblo	94LA95	1,413	191.2	Was 95 last year
160	239	Bishop	94CS7180	928	190.0	Was 7180 last year
161	223	Eagle Lake	94CN9455	581	189.8	Was 9455 last year
162	203	Naval Base	94CS8440	1,276	187.5	Was 8440 last year
163	369	North McAllen	94SB3830	1,391	187.5	Was 3830 last year
164	606	Columbus	94CN930	935	187.4	Was 930CN last year
165	74	Gregory	94CS5920	539	186.2	Was 5920 last year
166	303	Wesmer	94SB4050	1,656	183.9	Was 4050 last year
167	341	Live Oak	94CS1070	2,512	180.4	Was 1070 last year
168	118	West Harlingen	94SB3700	1,508	180.1	Was 3700 last year
169	296	Rodd Field	94CS225	1,973	179.2	Was 225 last year
170	523	Harlingen S.S.	94SB4230	1,840	179.0	Was 4230 last year
171	422	Atansas Pass	94CS9130	297	179.0	Was 9130 last year
172	196	Stadium	94CS6950	562	178.5	Was 6950 last year
173	214	Uvalde	94LA480	1,242	178.2	Was 480 last year
174	664	Highway 9	94CS7210	1,058	178.2	Was 7210 last year
175	121	Bishop	94CS2690	579	176.9	Was 2690 last year
176	59	South McAllen	94SB5065	114	176.0	Was HIDALGO COLISEUM last year
177	221	Raymondville #2	94SB4160	889	174.9	Was 4160 last year
178	135	Devine	94LA7100	831	174.8	Was 7100 last year
179	28	Southside	94CS8005	493	173.8	Was 8005 last year
180	21	Wadsworth	94CN8630	583	173.7	Was 8630 last year
181	631	Coffee Port	94SB1090	1,307	173.5	Was 1090 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
182	604	San Benito	94SB4135	778	173.3	Was 4135 last year
183	284	Woolridge	94CS1170	1,120	173.1	Was 1170CS last year
184	288	Rodd Field	94CS205	1,016	172.4	Was 205 last year
185	569	Wesmer	94SB4480	2,462	172.2	Was 4480 last year
186	152	Holly	94CS7620	2,190	171.1	Was 7620 last year
187	209	West Oso	94CS9095	1,656	169.3	Was 9095 last year
188	390	Cabaniss	94CS75	1,326	168.9	Was 75 last year
189	547	Darst	94CN800	211	168.8	Was 800 last year
190	446	Goodwin	94SB4380	1,248	168.8	Was 4380 last year
191	232	Foster Field	94CN2550	248	168.8	Was 2550 last year
192	86	La Grulla	94SB5110	908	168.0	Was 5110 last year
193	526	Brownsville	94SB4280	302	167.4	Was 4280 last year
194	177	San Diego	94CS1980	643	167.0	Was 1980 last year
195	142	Alice	94CS1790	354	166.9	Was 1790 last year
196	159	Hall Acres Road	94SB5585	949	166.2	Was 5585 last year
197	370	La Grulla	94SB5005	217	164.1	Was 5005 last year
198	340	Brookhollow	94CN8950	799	163.0	Was 8950 last year
199	649	Zapata	94LA7330	2,271	162.7	Was 7330 last year
200	199	Rio Grande City	94SB3740	2,108	162.0	Was 3740 last year
201	250	East Harrison	94SB4310	1,139	161.9	Was 4310 last year
202	195	Gregory	94CS8560	606	161.4	Was 8560 last year
203	123	La Grulla	94SB4120	1,539	160.9	Was 4120 last year
204	105	La Pryor	94LA580	159	159.3	Was 580 last year
205	488	University	94LA950	1,800	158.5	Was 950 last year
206	204	Elsa	94SB3500	1,091	156.3	Was 3500 last year
207	201	Morris Street	94CS8715	1,645	154.0	Was 8715 last year
208	348	Darst	94CN790	89	153.4	Was 790 last year
209	672	Hamilton Road	94LA9645	291	153.2	Was 9645 last year
210	384	Greenlake	94CN2760	469	151.8	Was 2760 last year
211	372	Crystal City	94LA330	957	151.8	Was 330W last year
212	251	Columbus	94CN6180	867	151.1	Was 6180 last year
213	402	Greta	94CN7890	301	149.4	Was 7890 last year
214	270	Palmhurst	94SB2820	3,393	147.0	Was 2820 last year
215	166	Jourdanton	94LA880	381	146.8	Was 880 last year
216	230	Laguna	94CS9065	1,680	145.1	Was 9065 last year
217	589	Highway 9	94CS7200	947	144.8	Was 7200 last year
218	114	Rio Bravo	94LA5	1,040	143.3	Was 5 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
219	433	Santo Nino	94LA70	3,004	142.3	Was 70 last year
220	453	Stafford Hill	94CN1550	178	141.1	Was 1550 last year
221	492	Live Oak	94CS1090	214	139.3	Was 1090CS last year
222	255	Seawall	94CS9450	241	139.2	Was 9450 last year
223	382	Hearn Road	94CS8990	1,031	139.1	Was 8990 last year
224	363	Arcadia	94CS1440	1,549	139.0	Was 1440 last year
225	218	Pharaoh	94CS1285	1,682	138.7	Was 1285 last year
226	582	Del Rio City	94LA1930	1,077	138.5	Was 1930 last year
227	280	Hearn Road	94CS870	972	137.8	Was 870 last year
228	243	Pearsall	94LA9905	187	137.3	Was 9905 last year
229	424	Hidalgo	94SB4845	537	136.2	Was 4845 last year
230	149	Southside	94CS7955	1,079	135.1	Was 7955 last year
231	549	North Victoria	94CN1580	975	135.0	Was 1580 last year
232	222	Victoria Power Plant	94CN1390	1,233	134.9	Was 1390 last year
233	260	South Santa Rosa	94SB1240	1,221	134.8	Was 1240 last year
234	279	Odem	94CS385	273	134.6	Was 385 last year
235	240	Goodwin	94SB7380	1,969	133.2	Was 3530 last year
236	530	Eagle Pass City	94LA2650	3,329	132.9	Was 2650 last year
237	464	Palacios	94CN8550	100	132.9	Was 8550 last year
238	629	Lolita	94CN6330	29	132.8	Was 6330CN last year
239	487	South McAllen	94SB3850	196	132.5	Was 3850 last year
240	252	Harlingen S.S.	94SB4110	696	132.1	Was 4110 last year
241	673	West McAllen	94SB6385	1,305	131.7	Was 6385 last year
242	8	Causeway	94SB4775	1,044	131.5	Was 4775 last year
243	103	Luling - LCRA	94CN20	226	131.3	Was 20 last year
244	536	North Victoria	94CN7430	1,706	131.3	Was 7430 last year
245	361	Anna Street	94LA900	2,993	131.0	Was 900 last year
246	587	Port Lavaca	94CN6850	620	130.7	Was 6850 last year
247	294	West McAllen	94SB4555	1,584	130.2	Was 4555 last year
248	518	Bay City	94CN6450	1,042	129.3	Was 6450 last year
249	60	Continental	94SB4080	123	129.2	Was 4080 last year
250	343	Sharyland	94SB2020	2,880	128.9	Was 2020 last year
251	52	Palmview	94SB3930	2,001	128.4	Was 3930 last year
252	612	Edna	94CN5765	1,638	127.5	Was 5765 last year
253	238	Port Isabel S.S.	94SB4070	297	127.3	Was 4070 last year
254	521	Weaver Road	94CN1910	373	127.2	Was 1910 last year
255	391	Beeville	94CN2200	781	127.1	Was 2200 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
256	427	Pharaoh	94CS5175	1,047	125.4	Was 5175 last year
257	71	Buena Vista	94LA9035	1,201	124.5	Was 9035 last year
258	516	Highway 9	94CS6760	817	124.3	Was 6760 last year
259	276	Three Rivers	94CN2580	109	124.2	Was 2580 last year
260	362	Hall Acres Road	94SB3460	2,939	123.7	Was 3460 last year
261	485	Garceno	94SB2130	1,326	122.7	Was 2130 last year
262	183	Pearsall	94LA7050	1,388	122.4	Was 7050 last year
263	354	Sinton	94CS180	1,122	122.4	Was 180 last year
264	55	Banquette	94CS9000	536	121.7	Was 9000 last year
265	130	Hall Acres Road	94SB3670	928	121.0	Was 3670 last year
266	653	Polk Avenue	94SB4520	1,309	120.9	Was 4520 last year
267	519	East Harrison	94SB3190	1,194	120.6	Was 3190 last year
268	358	Arcadia	94CS1460	2,072	119.8	Was 1460 last year
269	447	Pleasanton	94LA9505	1,300	119.7	Was 9505 last year
270	308	Bay City	94CN6670	1,817	119.1	Was 6670 last year
271	277	Garwood City	94CN2560	202	118.5	Was 2560 last year
272	219	Palmview	94SB9685	3,075	118.5	Was 9685 last year
273	146	Arcadia	94CS1450	1,942	118.5	Was 1450 last year
274	332	Kingsville	94CS1350	277	118.1	Was 1350 last year
275	359	Premont	94LA2720	901	118.1	Was 2720 last year
276	567	Weslaco Unit	94SB8195	2,332	118.0	Was 8195 last year
277	125	Campwood	94LA2610	924	118.0	Was 2610 last year
278	185	Airline	94CS9605	693	117.6	Was 9605 last year
279	244	Pleasanton	94LA2080	1,357	117.5	Was 2080 last year
280	96	North McAllen	94SB5055	2,323	117.3	Was 5055 last year
281	325	North Victoria	94CN6390	1,370	117.3	Was 6390 last year
282	198	Del Rio City	94LA420	2,083	116.9	Was 420 last year
283	502	North Victoria	94CN1470	405	116.7	Was 1470 last year
284	258	North McAllen	94SB2980	2,001	116.0	Was 2980 last year
285	520	Cavazos	94SB3560	932	115.9	Was 3560 last year
286	413	Woolridge	94CS1120	1,880	115.1	Was 1120CS last year
287	552	Port Aransas	94CS3030	671	115.0	Was 3030CS last year
288	588	Laredo Heights	94LA9400	1,565	114.4	Was 9400 last year
289	557	Harlingen S.S.	94SB4090	2,351	113.5	Was 4090 last year
290	467	San Diego	94CS2930	594	113.1	Was 2930 last year
291	416	North Victoria	94CN7860	1,354	113.1	Was 7860 last year
292	454	San Benito	94SB3910	1,709	112.8	Was 3910 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
293	237	West McAllen	94SB4595	965	112.7	Was 4595 last year
294	61	Premont	94LA2730	208	112.3	Was 2730 last year
295	320	West Oso	94CS9090	1,812	111.9	Was 9090 last year
296	319	Charlotte	94LA2790	177	111.4	Was 2790 last year
297	613	Sinton	94CS360	276	111.3	Was 360CS last year
298	377	O'Conner	94CN390	201	110.7	Was 390CN last year
299	449	Garceno	94SB2135	1,615	110.7	Was 2135 last year
300	68	Naval Base	94CS6330	259	109.5	Was 6330CS last year
301	367	Weslaco Unit	94SB8610	2,441	109.5	Was 8610 last year
302	143	Morris Street	94CS8840	657	108.8	Was 8840 last year
303	430	Southside	94CS7905	1,760	108.2	Was 7905 last year
304	4	Casa Blanca	94CS55	353	107.9	Was 55 last year
305	466	Bandera Electric (Leakey)	94LAL30	388	106.4	Was L30 last year
306	110	Brownsville	94SB3050	1,958	106.3	Was 3050 last year
307	122	North Mercedes	94SB4860	1,388	105.2	Was 4860 last year
308	155	Rockport	94CS5950	532	104.8	Was 5950 last year
309	173	Woodsboro	94CS8330	1,084	103.8	Was 8330CS last year
310	652	Falfurrias	94LA1070	916	103.3	Was 1070W last year
311	25	Continental	94SB4880	57	103.1	Was 4880 last year
312	554	Haine Drive	94SB8065	1,234	102.9	Was 8065 last year
313	30	Carrizo Springs	94LA370	289	102.7	Was 370W last year
314	45	Wadsworth	94CN7660	1,108	102.7	Was 7660 last year
315	618	Pettus	94CN1020	383	102.1	Was 1020 last year
316	491	West McAllen	94SB4815	844	101.6	Was 4815 last year
317	490	Clarkwood	94CS9570	1,215	101.3	Was 9570 last year
318	215	Palmview	94SB9680	1,773	101.3	Was 9680 last year
319	84	Goliad	94CN6540	877	101.1	Was 6540 last year
320	431	Fulton	94CS440	1,968	100.4	Was 440 last year
321	181	North Edinburg	94SB4240	710	100.1	Was 4240 last year
322	212	Pleasanton	94LA9475	1,716	99.9	Was 9475 last year
323	40	Robstown	94CS7120	57	99.8	Was 7120 last year
324	645	Casa Blanca	94CS5115	1,155	99.7	Was 5115 last year
325	337	Banquette	94CS130	255	99.6	Was 130 last year
326	388	Southside	94CS5345	396	98.3	Was 5345 last year
327	99	San Ygnacio	94LA16060	410	98.2	Was 16060 last year
328	616	Aransas Pass	94CS1250	297	98.2	Was 1250 last year
329	309	Cabaniss	94CS80	784	97.5	Was 80 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
330	2	Nueces Bay Plant	94CS7830	148	97.4	Was 7830 last year
331	107	Freer	94LA2900	316	96.5	Was 2900 last year
332	248	Jourdanton	94LA5695	1,219	95.8	Was 5695 last year
333	150	Raymondville #2	94SB3240	1,231	95.5	Was 3240 last year
334	307	Alice	94CS1780	278	95.4	Was 1780 last year
335	366	Ingleside City	94CS8050	1,718	95.3	Was 8050 last year
336	302	Naval Base	94CS1380	1,911	95.1	Was 1380CS last year
337	205	Rio Rico	94SB5050	1,413	94.3	Was 5050 last year
338	583	North Padre Island	94CS5170	2,236	94.3	Was 5170 last year
339	400	Morris Street	94CS5655	1,095	94.2	Was 5655 last year
340	592	Amistad Dam	94LA5450	959	94.1	Was 5450 last year
341	194	Alice	94CS2530	1,322	93.8	Was 2530 last year
342	274	Gateway	94LA390	2,123	93.6	Was 390 last year
343	44	Southside	94CS7925	1,331	92.5	Was 7925 last year
344	134	Carrizo Springs	94LA910	1,648	92.3	Was 910 last year
345	43	West Harlingen	94SB4870	544	92.3	Was 4870 last year
346	234	Carrizo Springs	94LA860	1,427	92.2	Was 860 last year
347	556	San Benito	94SB4945	1,694	91.5	Was 4945 last year
348	47	Kleberg	94CS1560	903	90.7	Was 1560 last year
349	293	Fulton	94CS3070	1,443	90.6	Was 3070 last year
350	426	Placedo	94CN7980	395	90.3	Was 7980 last year
351	499	Charlotte	94LA8120	151	90.3	Was 8120 last year
352	285	Fulton	94CS6070	2,579	89.9	Was 6070 last year
353	236	Three Rivers	94CN8430	140	88.4	Was 8430 last year
354	597	Polk Avenue	94SB4740	1,170	88.3	Was 4740 last year
355	128	Airline	94CS9030	432	88.2	Was 9030 last year
356	660	Harlingen	94SB370	1,047	88.0	Was 370 last year
357	328	Polk Avenue	94SB4190	2,222	87.6	Was 4190 last year
358	297	Bruni	94LA1100	685	87.6	Was 1100 last year
359	392	Alice	94CS1770	1,503	86.8	Was 1770 last year
360	207	Pharr	94SB1620	2,578	86.5	Was 1620 last year
361	83	Haine Drive	94SB270	805	86.3	Was 270 last year
362	14	Nueces Bay Plant	94CS345	52	84.8	Was 345 last year
363	290	Harlingen S.S.	94SB320	1,736	84.6	Was 320 last year
364	278	Parker	94CN9260	69	84.6	Was 9260 last year
365	406	Santo Nino	94LA80	1,492	84.6	Was 80 last year
366	457	Mathis	94CS2870	955	84.5	Was 2870 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
367	376	Raymondville #2	94SB1280	1,496	84.1	Was 1280 last year
368	124	Southside	94CS8045	1,065	82.7	Was 8045 last year
369	378	Kingsville	94CS1660	1,444	82.3	Was 1660 last year
370	188	Haine Drive	94SB9690	926	82.0	Was 9690 last year
371	509	Rio Grande City	94SB3210	1,470	81.9	Was 3210 last year
372	615	Milo	94LA6940	1,357	80.7	Was 3070 last year
373	451	Weslaco Unit	94SB9805	2,065	80.5	Was 9805 last year
374	418	Beeville	94CN8090	1,256	80.3	Was 8090 last year
375	39	Hall Acres Road	94SB5465	3,856	80.3	Was 5465 last year
376	371	Bay City	94CN2700	1,314	80.0	Was 2700 last year
377	191	North Mercedes	94SB3770	1,156	79.6	Was 3770 last year
378	75	West McAllen	94SB4535	1,921	79.6	Was 4535 last year
379	594	Fannin	94CN7940	25	79.6	Was 7940 last year
380	129	Pharr	94SB1625	1,715	78.4	Was 1625 last year
381	381	Raymondville #1	94SB3130	95	78.3	Was 3130 last year
382	572	Polk Avenue	94SB4600	2,761	78.3	Was 4600 last year
383	444	Holly	94CS7740	1,787	77.6	Was 7740 last year
384	339	Rodd Field	94CS1730	1,809	76.6	Was 1730 last year
385	544	Airline	94CS6970	1,096	76.4	Was 6970 last year
386	229	Kingsville	94CS1130	1,667	76.3	Was 1130 last year
387	387	Palmhurst	94SB3890	1,844	75.9	Was 3890 last year
388	498	North Victoria	94CN7770	927	75.8	Was 7770 last year
389	77	Hall Acres Road	94SB9595	428	75.7	Was 9595 last year
390	661	Laredo Plant	94LA8745	1,040	75.4	Was 8745 last year
391	264	Crestonio	94LA260	1,507	74.7	Was 260 last year
392	410	South East Edinburg	94SB4570	1,269	74.7	Was 4570 last year
393	501	Uvalde	94LA5060	1,281	73.8	Was 5060 last year
394	383	Sinton	94CS6860	1,326	73.7	Was 6860 last year
395	48	Los Fresnos	94SB3280	1,764	73.6	Was 3280 last year
396	595	Mathis	94CS1420	840	73.4	Was 1420 last year
397	246	West Harlingen	94SB3720	1,915	73.1	Was 3720 last year
398	318	Holly	94CS1950	792	72.8	Was 1950 last year
399	356	South East Edinburg	94SB4015	875	72.5	Was 4015 last year
400	460	South East Edinburg	94SB4550	1,798	72.3	Was 4550 last year
401	515	Morris Street	94CS8850	446	71.6	Was 8850 last year
402	119	Southside	94CS8055	1,055	71.0	Was 8055 last year
403	560	Polk Avenue	94SB4610	1,617	70.4	Was 4610 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
404	65	Devine	94LA8100	1,220	70.1	Was 8100 last year
405	508	Edna	94CN5785	736	69.7	Was 5785 last year
406	56	Stadium	94CS7800	641	68.9	Was 7800 last year
407	323	Arcadia	94CS5030	1,543	68.9	Was 5030 last year
408	663	East Harrison	94SB3080	495	68.7	Was 3080 last year
409	178	Matthews	94CN1740	154	68.2	Was 1740 last year
410	306	Portland	94CS9290	1,626	68.0	Was 9290 last year
411	254	Victoria Power Plant	94CN8070	616	67.9	Was 8070 last year
412	15	Runge	94CN7320	592	67.6	Was 7320 last year
413	33	Alice	94CS2540	1,591	67.3	Was 2540 last year
414	351	Palacios	94CN6840	1,373	67.2	Was 6840 last year
415	493	Pueblo	94LA1130	1,132	66.9	Was 130 last year
416	299	Edna	94CN5775	517	66.9	Was 5775 last year
417	625	Eagle Pass City	94LA2510	640	66.9	Was 2510 last year
418	224	Thomaston	94CN9580	51	66.8	Was 9580 last year
419	5	Hidalgo	94SB3400	474	66.3	Was 3400 last year
420	310	Laredo Plant	94LA8695	332	66.2	Was 8695 last year
421	287	Zacate Creek	94LA2675	515	66.0	Was 2675 last year
422	116	Los Fresnos	94SB930	1,775	65.1	Was 930S last year
423	261	Crystal City	94LA190	1,025	64.5	Was 190 last year
424	79	San Benito	94SB3920	2,010	64.4	Was 3920 last year
425	455	Skidmore	94CS600	350	64.1	Was 600 last year
426	438	Del Rio City	94LA9850	846	64.0	Was 9850 last year
427	394	University	94LA920	200	63.8	Was 920 last year
428	432	East Harrison	94SB3030	824	63.7	Was 3030 last year
429	639	North Edinburg	94SB3810	639	63.5	Was 3810 last year
430	182	Gateway	94LA350	1,359	63.3	Was 350 last year
431	228	Mustang Island	94CS9470	646	63.2	Was 9470 last year
432	522	Kleberg	94CS6000	1,536	63.1	Was 6000 last year
433	570	Laredo Heights	94LA2450	2,166	63.1	Was 2450 last year
434	448	Beeville	94CN1760	1,011	62.8	Was 1760 last year
435	180	Highway 9	94CS6780	872	62.6	Was 6780 last year
436	72	Stadium	94CS7490	1,180	61.8	Was 7490 last year
437	626	Magruder	94CN6700	1,886	61.3	Was 6700 last year
438	37	El Campo	94CN6370	994	61.1	Was 6370 last year
439	525	Weslaco Unit	94SB5970	2,571	61.1	Was 5970 last year
440	210	Bay City	94CN2050	645	60.8	Was 2050 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
441	112	Clarkwood	94CS7230	671	60.8	Was 7230 last year
442	226	Nixon	94CN2620	584	60.3	Was 2620 last year
443	408	San Diego	94CS2890	990	60.2	Was 2890 last year
444	563	Dilley	94LA510	458	60.0	Was 510 last year
445	459	Santo Nino	94LA75	1,432	59.7	Was 75 last year
446	225	Rangerville	94SB3410	726	59.6	Was 3410 last year
447	445	North McAllen	94SB9640	824	59.4	Was 9640 last year
448	120	Arcadia	94CS6930	1,564	59.4	Was 6930 last year
449	600	Airline	94CS8890	519	59.0	Was 8890 last year
450	609	Aransas Pass	94CS650	247	57.9	Was 650 last year
451	335	Pharaoh	94CS1185	1,352	57.7	Was 1185 last year
452	273	Pueblo	94LA275	1,365	57.4	Was 275 last year
453	41	Robstown	94CS1650	418	57.2	Was 1650 last year
454	420	North Padre Island	94CS7900	2,385	57.0	Was 7900 last year
455	161	Point Comfort	94CN2460	145	57.0	Was 2460 last year
456	648	Rodd Field	94CS3010	1,298	56.9	Was 3010 last year
457	405	Rockport	94CS5940	64	55.9	Was 5940 last year
458	58	Portland	94CS9270	1,755	55.6	Was 9270 last year
459	474	South Mission	94SB3620	1,066	55.3	Was 3620 last year
460	605	Roma	94SB3060	1,738	54.6	Was 3060 last year
461	658	Eagle Pass City	94LA2770	2,172	54.4	Was 2770 last year
462	537	Beeville	94CN300	1,288	54.2	Was 300 last year
463	283	Rodd Field	94CS2190	2,821	53.4	Was 2190 last year
464	458	Beeville	94CN8510	946	52.7	Was 8510CN last year
465	211	Southside	94CS8025	1,168	52.5	Was 8025 last year
466	247	Southside	94CS5335	1,093	52.4	Was 5335 last year
467	417	Zacate Creek	94LA2665	884	52.3	Was 2665 last year
468	657	McColl Road	94SB4780	1,691	52.0	Was 4780 last year
469	546	Beeville	94CN490	994	51.6	Was 490CN last year
470	395	Bay City	94CN7480	1,959	51.5	Was 7480 last year
471	163	North Mercedes	94SB3840	655	51.5	Was 3840 last year
472	89	Arcadia	94CS8570	1,337	51.1	Was 8570 last year
473	436	Greenlake	94CN2740	23	50.7	Was 2740CN last year
474	396	Holly	94CS1370	1,816	50.6	Was 1370 last year
475	535	Hamilton Road	94LA9655	951	50.0	Was 9655 last year
476	327	Anna Street	94LA2250	1,684	49.4	Was 2250 last year
477	187	Eagle Pass City	94LA450	1,390	49.2	Was 450 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
478	496	Harlingen	94SB380	2,137	49.2	Was 380 last year
479	140	South McAllen	94SB3935	956	49.1	Was 3935 last year
480	463	Anna Street	94LA850	1,670	48.9	Was 850 last year
481	675	South McAllen	94SB3640	259	48.4	Was 3640 last year
482	257	Nixon	94CN5990	519	47.8	Was 5990 last year
483	353	North McAllen	94SB4995	2,070	47.2	Was 4995 last year
484	584	Pharaoh	94CS5185	1,796	47.2	Was 5185 last year
485	253	Bay City	94CN1110	1,013	47.1	Was 1110CN last year
486	127	Morris Street	94CS8820	1,212	47.1	Was 8820 last year
487	593	Wesmer	94SB9705	1,242	47.1	Was 9705 last year
488	419	Port Lavaca	94CN2480	1,504	46.7	Was 2480CN last year
489	482	Kieberg	94CS9395	1,096	46.4	Was 9395 last year
490	322	Morris Street	94CS7625	573	46.3	Was 7625 last year
491	347	South Padre Island	94SB4695	1,143	46.2	Was 4695 last year
492	472	Washington Street	94LA2350	2,974	46.1	Was 2350 last year
493	208	Columbus	94CN9060	541	45.9	Was 9060 last year
494	298	Hall Acres Road	94SB4895	1,235	45.8	Was 4895 last year
495	401	Cotulla	94LA90	617	45.3	Was 90 last year
496	533	Roma	94SB3070	1,656	45.3	Was 3070 last year
497	512	George West	94CN730	714	45.2	Was 730 last year
498	601	Crystal City	94LA140	1,696	44.6	Was 140W last year
499	539	Harlingen	94SB360	2,519	44.6	Was 360 last year
500	624	Airline	94CS7270	951	43.9	Was 7270 last year
501	654	Pharaoh	94CS1365	470	43.8	Was 1365 last year
502	108	North Victoria	94CN7440	1,525	43.5	Was 7440 last year
503	314	Fulton	94CS2020	1,681	43.0	Was 2020CS last year
504	611	George West	94CN1320	587	42.4	Was 1320 last year
505	610	Kenedy S.S.	94CN8340	695	42.4	Was 8340 last year
506	397	Asherton	94LA2660	658	41.8	Was 2660 last year
507	641	Del Mar	94LA3440	2,601	41.8	Was 3440 last year
508	437	Leary Lane	94CN6005	796	41.6	Was 6005 last year
509	235	Gateway	94LA380	679	40.7	Was 380 last year
510	192	Highway 9	94CS6770	1,589	40.7	Was 6770 last year
511	90	Cabaniss	94CS240	1,206	39.8	Was 240 last year
512	555	Airline	94CS7280	606	39.7	Was 7280 last year
513	671	Brookhollow	94CN7190	383	39.5	Was 7190 last year
514	393	North McAllen	94SB5060	1,760	39.4	Was 5060 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
515	632	Hearn Road	94CS2220	1,588	38.5	Was 2220 last year
516	421	South Mission	94SB3940	833	38.4	Was 3940 last year
517	603	Seawall	94CS9420	872	38.0	Was 9420 last year
518	139	Santo Nino	94LA695	787	38.0	Was 695 last year
519	409	Taft	94CS5230	915	37.4	Was 5230 last year
520	599	Polk Avenue	94SB4180	1,716	37.1	Was 4180 last year
521	450	Leary Lane	94CN1890	1,441	36.9	Was 1890 last year
522	538	Weslaco Unit	94SB7455	1,531	36.9	Was 7455 last year
523	619	Polk Avenue	94SB4900	2,338	36.4	Was 4900 last year
524	151	South Padre Island	94SB6440	1,882	36.1	Was 6440 last year
525	398	Campwood	94LA3430	58	36.1	Was 3430 last year
526	54	Buena Vista	94LA8965	931	36.0	Was 8965 last year
527	304	Haine Drive	94SB9700	640	35.7	Was 9700 last year
528	202	Yorktown	94CN8420	908	35.6	Was 8420 last year
529	531	Del Mar	94LA490	1,092	35.0	Was 490 last year
530	529	Brookhollow	94CN7580	510	34.9	Was 7580 last year
531	147	Morris Street	94CS2515	1,167	34.9	Was 2515 last year
532	586	Palacios	94CN6830	894	34.8	Was 6830 last year
533	368	Southside	94CS8035	1,069	34.7	Was 8035 last year
534	545	Leary Lane	94CN1540	1,707	34.6	Was 1540 last year
535	78	Buena Vista	94LA9385	1,702	34.3	Was 9385 last year
536	477	Sharyland	94SB5635	1,174	34.2	Was 2150 last year
537	111	Rio Grande City	94SB3230	1,102	33.9	Was 3230 last year
538	144	Hearn Road	94CS9665	570	33.9	Was 9665 last year
539	282	Portland	94CS6505	1,603	33.9	Was 6505 last year
540	441	Sunchase	94SB1155	1,102	33.3	Was 1155 last year
541	668	Clarkwood	94CS7220	115	33.2	Was 7220 last year
542	643	Del Rio City	94LA9790	2,826	32.7	Was 9790 last year
543	197	San Diego	94CS2880	1,423	32.3	Was 2880 last year
544	480	McColl Road	94SB4790	1,968	32.3	Was 4790 last year
545	73	Rockport	94CS5930	970	32.2	Was 5930 last year
546	267	Leary Lane	94CN7530	1,899	32.2	Was 7530 last year
547	686	Washington Street	94LANETLAR	520	32.0	Was NET LAR last year
548	577	Airline	94CS9390	1,654	31.7	Was 9390 last year
549	646	Eagle Lake	94CN320	665	31.6	Was 320CN last year
550	510	Kingsville	94CS1670	398	31.3	Was 1670 last year
551	317	Kenedy	94CN6270	467	31.0	Was 6270 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
552	670	Washington Street	94LA2360	747	30.8	Was 2360 last year
553	602	Del Rio City	94LA430	2,327	30.7	Was 430 last year
554	617	Brookhollow	94CN8960	651	30.4	Was 8960 last year
555	305	Three Rivers	94CN2010	745	29.0	Was 2010CN last year
556	504	Port Aransas	94CS990	1,046	28.8	Was 990CS last year
557	666	Highway 9	94CS9830	105	28.7	Was 9830 last year
558	513	Kingsville	94CS1140	969	28.6	Was 1140 last year
559	375	Holly	94CS1480	1,687	28.1	Was 1480 last year
560	656	Airline	94CS5870	830	27.5	Was 5870CS last year
561	662	Washington Street	94LA2470	275	27.3	Was 2470 last year
562	321	Morris Street	94CS7465	675	27.3	Was 7465 last year
563	638	Gregory	94CS420	26	27.3	Was 420 last year
564	338	Laredo Plant	94LA8565	999	26.7	Was 8565 last year
565	138	Pearsall	94LA5580	1,983	26.7	Was 5580 last year
566	113	North Weslaco	94SB4830	423	26.5	Was 4830 last year
567	346	South Padre Island	94SB5850	1,275	26.4	Was 5850 last year
568	542	Nordheim	94CN470	242	26.4	Was 470 last year
569	176	Victoria Power Plant	94CN8170	747	26.4	Was 8170 last year
570	423	South Mission	94SB3590	864	26.3	Was 3590 last year
571	435	Ingleside City	94CS8060	1,932	26.2	Was 8060 last year
572	326	Arcadia	94CS1360	1,570	26.0	Was 1360 last year
573	324	Magruder	94CN6690	538	25.9	Was 6690 last year
574	227	Sinton	94CS1750	378	24.8	Was 1750 last year
575	200	Rio Grande City	94SB3220	1,409	24.7	Was 3220 last year
576	157	Seawall	94CS9325	1,864	24.5	Was 9325 last year
577	29	Prairie Pump	94CN1940	61	24.3	Was 1940 last year
578	471	Leary Lane	94CN6175	1,220	24.1	Was 6175 last year
579	189	El Campo	94CN5745	914	23.4	Was 5745 last year
580	596	Del Mar	94LA10	3,000	23.4	Was 10 last year
581	470	Uvalde	94LA9770	1,226	23.2	Was 9770 last year
582	352	Kleberg	94CS280	1,384	22.7	Was 280 last year
583	88	Sabinal	94LA200	416	22.7	Was 200 last year
584	184	Big Wells	94LA1570	497	22.7	Was 1570 last year
585	167	Southside	94CS7995	1,542	22.6	Was 7995 last year
586	11	West Oso	94CS9085	711	22.2	Was 9085 last year
587	153	Arcadia	94CS5020	1,531	22.1	Was 5020 last year
588	677	McColl Road	94SB4910	869	22.0	Was 4910 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
589	651	North Victoria	94CN2240	784	21.8	Was 2240 last year
590	553	Aransas Pass	94CS660	346	21.7	Was 660CS last year
591	476	Laredo Plant	94LA8505	1,040	21.6	Was 8505 last year
592	300	Three Rivers	94CN5100	40	21.4	Was 5100 last year
593	440	Aransas Pass	94CS590	148	21.3	Was 590 last year
594	571	South Mission	94SB5215	1,206	21.3	Was 5215 last year
595	233	Pleasanton	94LA120	1,222	20.8	Was 120 last year
596	336	Uvalde	94LA550	639	20.5	Was 550 last year
597	115	West Harlingen	94SB3800	1,346	20.5	Was 3800 last year
598	517	Charlotte	94LA2780	531	20.4	Was 2780 last year
599	286	Portland	94CS9370	1,020	20.3	Was 9370 last year
600	627	Sharyland	94SB2150	1,413	19.7	Was 2035 last year
601	365	Dilley	94LA6400	1,009	19.5	Was 6400 last year
602	425	Berclair	94CN990	241	19.0	Was 990C last year
603	578	Laredo Heights	94LA6820	1,532	18.7	Was 6820 last year
604	268	Freer	94LA5200	1,295	18.3	Was 5200 last year
605	379	East Harrison	94SB4620	967	18.2	Was 4620 last year
606	647	Refugio	94CN1040	560	18.1	Was 1040 last year
607	655	Port Lavaca	94CN2490	1,093	18.0	Was 2490 last year
608	241	El Campo	94CN7710	1,120	18.0	Was 7710 last year
609	650	Crestonio	94LA6660	976	17.8	Was 6660 last year
610	57	Point Comfort	94CN6060	260	17.8	Was 6060 last year
611	562	Magruder	94CN6680	639	17.7	Was 6680 last year
612	272	Jourdanton	94LA250	676	17.3	Was 250 last year
613	636	Knippa	94LA6535	15	16.8	Was 6535 last year
614	344	Eagle Lake	94CN310	767	16.6	Was 310 last year
615	561	Laredo Heights	94LA2100	1,769	16.5	Was 2100 last year
616	659	Pettus	94CN8210	352	16.5	Was 8210 last year
617	213	Weslaco Unit	94SB7630	2,501	16.2	Was 7630 last year
618	82	University	94LA930	104	16.1	Was 930 last year
619	486	Markham	94CN6440	455	15.9	Was 6440CN last year
620	329	Aransas Pass	94CS8280	346	15.6	Was 8280 last year
621	667	Del Rio City	94LA440	1,405	15.2	Was 440 last year
622	289	Leary Lane	94CN1430	1,358	14.7	Was 1430 last year
623	271	Holly	94CS1220	2,028	14.6	Was 1220 last year
624	275	Uvalde	94LA540	1,209	14.4	Was 540 last year
625	674	Del Mar	94LA7930	2,601	13.9	Was 7930 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
626	640	Asphalt Mines	94LA500	24	13.8	Was 500 last year
627	580	Eagle Pass City	94LA7060	1,314	13.8	Was 7060 last year
628	484	Ganado	94CN5815	544	13.7	Was 5815 last year
629	new	Palmhurst	94SB2530	1,764	13.3	New, much from 3890
630	494	South Mission	94SB4650	1,081	12.7	Was 4650 last year
631	541	Bay City	94CN5960	1,890	12.6	Was 5960 last year
632	473	Kenedy S.S.	94CN8320	863	12.6	Was 8320 last year
633	579	El Campo	94CN2800	1,369	12.5	Was 2800 last year
634	568	Anna Street	94LA5780	828	12.4	Was 5780 last year
635	468	Washington Street	94LA6525	2,367	11.4	Was 6525 last year
636	607	Del Mar	94LA220	486	11.4	Was 220 last year
637	621	Airline	94CS7390	1,581	11.0	Was 7390 last year
638	231	Mustang Island	94CS8510	47	11.0	Was 8510CS last year
639	534	Anna Street	94LA780	495	10.6	Was 780 last year
640	16	Comstock	94LA290	199	10.4	Was 290 last year
641	507	Yorktown	94CN8380	822	10.2	Was 8380 last year
642	564	Laredo Heights	94LA2390	769	10.2	Was 2390 last year
643	500	Washington Street	94LA6355	1,162	9.5	Was 6355 last year
644	new	Goodwin	94SB3530	1,012	9.4	New, partial customers from last year's 4625
645	573	Magruder	94CN245	1,225	9.4	Was 245 last year
646	634	Laredo Heights	94LA6810	1,863	9.4	Was 6810 last year
647	249	Kenedy S.S.	94CN6750	495	8.8	Was 6750 last year
648	481	Knippa	94LA6365	285	8.7	Was 6365 last year
649	550	Cotulla	94LA110	1,399	8.7	Was 110 last year
650	669	Santo Nino	94LA645	1,850	8.6	Was 645 last year
651	162	Nixon	94CN810	537	8.3	Was 810 last year
652	548	Magruder	94CN7870	1,270	7.8	Was 7870 last year
653	575	Magruder	94CN7690	898	7.8	Was 7690 last year
654	590	Refugio	94CN1210	229	7.4	Was 1210 last year
655	301	Jourdanton	94LA5685	563	7.3	Was 5685 last year
656	412	San Benito	94SB3860	250	7.2	Was 3860 last year
657	342	Freer	94LA6320	178	6.5	Was 6320 last year
658	635	Three Rivers	94CN5190	685	5.6	Was 5190 last year
659	67	Sabinal	94LA485	496	5.6	Was 485 last year
660	633	Big Wells	94LA2630	243	5.6	Was 2630 last year
661	new	North Padre Island	94CS1010	1,087	5.4	New
662	331	Holly	94CS9675	1,734	5.4	Was 9675 last year

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2006 SAIDI Ranking	2005 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2006 SAIDI Value	Notes
663	456	Skidmore	94CS380	278	4.9	Was 380CS last year
664	576	Garwood City	94CN2570	302	4.9	Was 2570 last year
665	442	Laredo Heights	94LA9080	427	3.9	Was 9080 last year
666	169	North Westlaco	94SB4810	1,215	3.9	Was 4810 last year
667	642	Woolridge	94CS1110	1,352	3.7	Was 1110CS last year
668	543	El Campo	94CN7260	578	3.5	Was 7260 last year
669	443	Laredo Plant	94LA8705	728	3.3	Was 8705 last year
670	452	Kenedy	94CN1960	60	3.0	Was 1960 last year
671	620	El Campo	94CN2860	395	3.0	Was 2860 last year
672	439	Washington Street	94LA7015	1,985	2.8	Was 7015 last year
673	644	Refugio	94CN1170	1,131	1.9	Was 1170CN last year
674	411	Santo Nino	94LA515	1,283	1.6	Was 515 last year
675	598	Laredo Plant	94LA9305	1,872	1.2	Was 9305 last year
676	new	Sharyland	94SB2035	1,714	1.1	New feeder, not 2035 last year
677	540	Airline	94CS8370	312	1.0	Was 8370 last year
678	291	Haine Drive	94SB9240	649	0.7	Was 9240 last year
679	687	Zacate Creek	94LA2635	906	0.5	Was 2635 last year
680	676	Beeville	94CN2380	817	0.3	Was 2380 last year
681	665	East Harrison	94SB3000	900	0.3	Was 3000 last year
682	685	Victoria Power Plant	94CNNETVIC	190	-	Was NET VIC last year
683	new	North Padre Island	94CS720	278	-	New
684	630	Ingleside City	94CS7310	40	-	Was 7310 last year
685	683	Southside	94CS7935	35	-	Was 7935 last year
686	684	STEC (Riverside)	94CS9101	199	-	Was 9101 last year
687	681	Morris Street	94CSNET CC	426	-	Was NET CC last year
688	688	Zapata	94LA8300	340	-	Was 8300 last year
689	new	Haine Drive	94SB3490	663	-	New, piece from 270

Feeders from last year that do not appear this year:

102	BANQUETTE	740	Serves <10 customers
678	AIRLINE	2180	Serves <10 customers
679	AIRLINE	2210	Serves <10 customers
680	CHASE FIELD	460	Serves <10 customers
682	NORMANNA CST	840	Serves <10 customers

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2006 Reporting Year

Causes of Forced Interruptions	Percentage
Animals and Birds	10.0%
People (including cars and farm eqpt)	2.7%
Unknown	5.3%
Utility-Owned Equipment	44.3%
Vegetation	17.5%
Weather (including lightning)	19.5%
Other	0.7%