

SPP- ETI QPR Study Report

	• Market Operations Testing support for certification – \$10,920. • Data Integrity and Analysis ongoing support for ESI ID account registration, extracts, and training - \$9,750
Estimated Project Time Requirements* *Unless otherwise indicated, project time requirements begin upon project initiation.	Approximately twenty-nine (29) months
ERCOT Staffing Impacts (across all areas)	No long term impact for Energy Analysis and Aggregation No long term impact for Retail Customer Choice No long term impact for Market Operations Testing No long term impact for Data Integrity & Administration
ERCOT Computer System Impacts	Impact to the following systems for the addition of ~ 425,000 more ESI IDs, the associated increase in volume for retail transactions on those ESI IDs to support Retail Open Access, including monthly usage data that would be forwarded to REPs. Inovis database Siebel database Lodestar database Paperfree database and file system TIBCO database ETS database ISM database Storage Limited Data Center Capacity • Already at full capacity • No relief until MET Center Disposition Project delivers more capacity • Potentially not until 4Q2010 or 1Q2011 • Means we potentially can't "plug-in" another server until relief is realized
ERCOT Business Function Impacts	No long term impact for Energy Analysis and Aggregation No long term impact for Retail Customer Choice No long term impact for Market Operations Testing

SPP- ETI QPR Study Report

	No long term impact for Data Integrity & Administration
Grid Operations & Practices Impacts	None known

Alternatives for a More Efficient Implementation <i>(include explanation of impacts)</i>

Evaluation of Interim Solutions <i>(e.g., manual workarounds)</i>

Feasibility of Implementation
Impact on Resource Availability: Impact on Other Projects:

Comments
This High Level Impact Analysis Report does NOT include the following aspects for wholesale or grid/network that were provided in 2006 as part of the Entergy Integration Report (Project No. 32217, <i>Entergy Gulf States Inc.'s Plan for Identifying Applicable Power Region Pursuant to PURA § 39.452(f)</i>) Transmission and Distribution Service Provider – wholesale power transmission connectivity, communication, network modeling, settlement metering and data aggregation.

SPP- ETI QPR Study Report

Resources – registration, setup in ERCOT's network model and data aggregation systems.

Qualified Scheduling Entities – registration, telemetry testing, telecommunications, credit, network modeling, scheduling, bidding and deployments.

Municipal Electric Utilities and Electric Cooperatives – registration, testing and integration of meter points into ERCOT's metering, data aggregation and settlement systems.

October 20, 2008 DRAFT

**Cleco Power - Lafayette Utilities System-
SPP/SPPICT-Entergy
Joint Transmission Planning Study**

**RELIABILITY AND ECONOMIC STUDY FOR
THE 2008 TRANSMISSION EXPANSION PLAN
OF THE ACADIANA AREA LOAD POCKET**

October, 2008

JOINT STUDY GROUP

<u>Company</u>	<u>Study Representative</u>
Cleco Power	Terry Whitmore
Cleco Power	Chris Thibodeaux
Entergy	Doug Powell
Entergy	Joe Payne
Entergy	Edin Habibovich
LUS	Mike Boustany
LUS	Scotty Touchet
LUS	Jeff Stewart
GDS Associates	John Childes
SPPICT	Ben Roubique
SPPICT	Jody Holland
SPPICT	Bruce Rew

Table of Contents

I. EXECUTIVE SUMMARY	4
II. OVERVIEW	6
III. STUDY OBJECTIVE & ASSUMPTIONS	7
IV. POWERFLOW RESULTS	8
VI. RECOMMENDATION	11
VII. CONCLUSIONS.....	11
Attachment A. Model Generation Dispatch.....	12
Attachment B. Reliability Project detail.....	13
Attachment C. Reliability & Economic Project detail.....	15
Attachment D. ICT Option Project detail	17
Attachment E. Webre – Richard Project detail	19
Attachment F. Powerflow Results	21

I. EXECUTIVE SUMMARY

Study Purpose

This study examines the reliability issues in the Acadiana Load Pocket and develops a long-term transmission expansion plan for the Acadiana Load Pocket that will benefit all parties in the local area including potential economic benefits. The economic benefits would be in terms of fuel cost savings by providing flexibility of generation within the Acadiana Area Load Pocket. The proposed solutions are designed to bring the load pocket to the point where the area could sustain the loss of a major generating facility and a transmission line.

This study is intended to be a starting point for discussion amongst the affected parties for the expansion of transmission in the Acadiana Load Pocket. The upgrades discussed herein have not been approved, nor is there commitment from any parties to construct these upgrades. The study has not been reviewed or approved by the affected parties.

This study was considered to be a continuation of prior studies including the 2005 Wells Substation addition and evaluate options that will fortify area reliability under N-1 conditions beyond summer 2017. Studies have identified criteria violations within the Acadiana Load Pocket (ALP) in years 2012 and 2017. These criteria violations require some level of Transmission investment within the ALP by 2012. In an effort to eliminate the criteria violations and increase generation flexibility within the load pocket several transmission expansion projects were looked at. This study compares three options which were evaluated in detail and provides the most relief to the ALP. This study used NERC Planning Standard I.A as a criterion for evaluating numerous analyses and alternative solutions.

Background Information

The Acadiana load pocket area encompasses customers of Cleco Power, Lafayette Utilities System (LUS), Entergy Gulf States Louisiana (EGSL), Louisiana Generating (LaGen), and Louisiana Energy and Power Authority (LEPA). The area's total load-serving requirement for 2007 was approximately 1,720 MW. This load-serving requirement is met by local area generation (LUS' Bonin, Hargis, Labbe generating facilities and Cleco's Teche generating facilities) and transmission line thermal capability. This area's projected load in 2017 is approximately 2000 MW.

In 2005 Cleco and Entergy combined to finance the construction of Wells Substation which has provided much relief in the form of increasing the import capability into the ALP. Several long term studies have been performed since the incorporation of Wells substation in which the goal of the study was to evaluate both reliability and economics.

The ICT called 125 TLRs in the Acadiana Load Pocket between November, 2006 and November, 2007, 66 of which were called in June and July of 2007. These TLRs were primarily issued on EGSL Cecelia – Moril 138 kV line for the loss of Cleco Power's Flanders – Hopkins 138 kV line and EGSL Scott – Bonin 138 kV line for the loss of LUS Labbe – Bonin 230 kV line. There were 8 TLR Level 5 (firm curtailments) and 43 TLR Level 4 (redispatch generation prior to firm curtailments) events. These TLR events resulted in curtailment of both firm and non-firm transactions, and required redispatch of Cleco Power and LUS generation units in the ALP.

Cleco Power and LUS entered into an agreement in July 27th, 2007 to monitor and adhere to a company specific import limit. By re-dispatching generation to adhere to the import limit has resulted in a reduction of TLR events on the Scott – Bonin 138 kV line. This agreement originally expired on October 31st, 2007, but was extended through December 31st, 2007. Currently the Agreement has been agreed upon for the summer of 2008. This procedure appears to have had a positive effect since to date there have been no TLR Level 5 events issued on Scott – Bonin, and only 3 TLR Level 4 events were called after this agreement was in place. By 2013, this agreement will no longer be able to provide relief as a result of forecasted load growth in the area.

Transmission line maintenance outages have been difficult to obtain, in part due to concerns over the potential for overloads or TLRs on the transmission system with lines out of service. Under certain conditions, it may be necessary for generation to be run in order to grant outages. These concerns can prevent maintenance of

transmission equipment, or cause other parties to bear the cost of running generation in order to support transmission outages.

Solutions (Options Evaluated)

There were three (3) options which were given serious consideration as a solution to load pocket issues.

Option I ("Reliability & Economic")

(Reliability Portion)

- Construction of new 230 kV line from Labbe – Bonin (LUS)
- Installation of 500/230 kV auto transformer at Wells (Cleco Power)
- Construction of new 230 kV line from Wells - Labbe (Cleco Power /LUS)
- Construction of new 230 kV line from Labbe - Meaux (EGSL)
- Installation of 230/138 kV auto transformer at Meaux (EGSL)

Attachment B shows Phase I transmission system enhancements proposed in the Acadiana Load Pocket.

(Economic Portion)

- Installation of 500/230 kV auto transformer at Richard (Cleco Power /EGSL)
- Construction of new 230 kV line from Richard – Sellers Road (Cleco Power)
- Construction of new 230 kV substation at Sellers Road to connect Labbe – Meaux and Richard – Sellers Road (Cleco Power)
- Construction of new 230 kV substation at Segura near Moril (Cleco Power)
- Construction of new 230 kV line from Sellers Road – Segura (Cleco Power)
- Installation of 230/138 kV auto transformer at Segura (Cleco Power)
- Construction of new 138 kV line from Segura – Moril (Cleco Power)
- Construction of new 138 kV line terminal at Moril 138 kV substation (EGSL)

Attachment C shows Phases I and II of proposed transmission system enhancements in the Acadiana Load Pocket. The estimated direct total estimated cost of Option I is approximately \$200.0 million.

Option II ("ICT Option")

- Construction of new 230 kV transmission line from EGSL's Webre substation - Cecelia
- Construction of new 230 kV substation at Cecelia with a new 230 kV line from Cecelia - Wells and Cecelia - Moril
- Construction of new 230 kV line from Moril - LeBlanc
- Rehabilitating the existing Bonin – Cecelia 138 kV line, Cecelia – Moril 138 kV line, and Moril – Dubois 138 kV line with a new bundled conductor

Attachment D shows the transmission system enhancements in Acadiana Load Pocket for Option II. The estimated direct total cost of Option II is \$299 million.

Option III ("Webre & Richard")

- Construction of new 230 kV line from EGSL's Webre substation - Moril
- Construction of new 230 kV station at Richard with a new 230 kV line from Richard - Moril
- Construction of new 230 kV line from Bonin - Meaux
- Construction of new 230 kV sub-station at Sellers Road and tying the 230 kV lines from Moril – Richard and Bonin – Meaux into Sellers Road.

Attachment E shows the transmission system enhancements in the Acadiana Load Pocket for Option III. The estimated direct total cost of Option III is \$319 million.

Recommendation and Conclusion

Based on the results comparing the three options presented in this report, the best solution for the Acadiana Area is Option I ("Reliability and Economic"). This option is the most cost effective solution, improves reliability beyond 2017, as well as provides generation flexibility within the ALP allowing the system to be operated to N-1, G-1 criteria. More importantly this option provides a way for Cleco Power LLC, Entergy, and Lafayette Utility Services to agree on project responsibilities & ownership while improving reliability & generator flexibility in south Louisiana.

It should be noted that financial investment in this project does not guarantee transmission service or allow for de-commissioning of and generation facilities in the ALP. Additional studies would need to be run with specific source & sink generation dispatch to accommodate such transfers.

II. OVERVIEW

The Acadiana load pocket area encompasses load served by Cleco Power, Lafayette Utilities System (LUS), Entergy Gulf States, Inc. (EGSI), Louisiana Generating (LaGen), and Louisiana Energy and Power Authority (LEPA). The projected load serving requirements for 2013 for each of these entities are as follows:

Cleco Power:	457 MW plus 246 MW of firm point-to-point
LUS:	523 MW
EGSI:	477 MW plus LaGen's 413 MW (890 MW total)
LEPA:	62 MW

The total load-serving requirement for this area for 2007 was approximately 1,720 MW. This load-serving requirement is met by local area generation (LUS' Bonin units 1, 2, & 3, Hargis units 1 & 2, Labbe units 1 & 2 and Cleco's Teche units 1, 2, & 3) and transmission line thermal capability (1,429 MVA for Entergy and 1,125 MVA for Cleco). Entergy's transmission tie lines into the load pocket include one 115 kV line and four 138 kV lines. Cleco's transmission tie lines include one 138 kV line and one 230 kV line.

A meeting was held on March 2nd, 2007 in Lafayette with Cleco, Entergy, LEPA, LUS and SPP (representing both the RTO and the ICT) to discuss operational issues in the Acadiana Load Pocket. At this meeting, the ICT presented a prototype expansion plan for the Acadiana Load Pocket. The ICT committed to further develop this plan and present results to the group. The ICT became involved in the planning effort so that an independent entity could review and propose plans, and provide mediation between the parties involved.

The ICT presented its Preliminary Acadiana Load Pocket Reliability Study Report on September 3rd, 2007. In this report, the ICT proposed a transmission expansion plan that involves creating a source on the east side of the load pocket by creating a 230 kV line from the Webre station to Cecelia, and south to Moril. This project was designed to provide for a transmission system that could sustain the loss of a generator and transmission line (Option II "ICT Option"). The estimated cost for this project is \$298.6 million.

Following the ICT's report, several follow-up meetings were held to discuss the ICT's plan, and alternative options. At meetings with Cleco, Entergy, LUS and the ICT, additional plans were discussed and three options came out of these discussions. One of the alternatives presented was designed to address N-1 reliability issues on the system. This plan has been termed the "Reliability Option", and consists of a new 230 kV line from Wells to Meaux. In order to address potential savings in fuel cost, the Reliability Option was modified to include an additional 230 kV transmission source which has been named (Option I) "Reliability & Economics Option" to provide better generation flexibility within the ALP. The third option (Option III) that was considered is the "Webre and Richard Option" which was a combination of the "ICT Option" and the "Reliability & Economic Option". This option like the ICT option provided generation flexibility in the ALP and increased the Webre to Wells operating limit.

Based on the results comparing the three options presented in this report, the best solution for the Acadiana Area is Option I ("Reliability and Economic"). This option is the most cost effective solution, improves reliability beyond 2017, as well as provides generation flexibility within the ALP allowing the system to be operated to N-1, G-1 criteria. More importantly this option provides a way for Cleco Power LLC, Entergy, and Lafayette Utility Services to agree on project responsibilities & ownership while improving reliability & generator flexibility in south Louisiana.

III. STUDY OBJECTIVE & ASSUMPTIONS

A. Objective

This study identifies the minimum reliability requirements to be built by the 2012 and 2017 Summer Peak. This study also compares the Options described above for the ALP under different levels of reduced generation within the load pocket. In order to allow for the reduction in generation within the ALP, power transfers from areas far away from the load pocket were performed. This study only monitored elements in or near the ALP and ignored all loading or voltage violations outside of this area. In addition, overloads or voltage violations on 69 kV and below were ignored for the purpose of this study.

Current Reliability Criteria

The performance criteria used in this study are consistent with NERC Reliability Standards and are listed below:

- All lines in service
 - Voltage must remain between 0.95 and 1.05 pu. Voltage deviation greater than or equal to 0.03 pu between base case and study model requires an upgrade.
 - MVA flow should not exceed Rate A (Normal rating). Flow increase greater than or equal to 3% between base case and study model requires an upgrade.
- Under contingencies (N-1)
 - Voltage must remain between 0.92 and 1.05 pu. Voltage deviation greater than or equal to 0.03 pu between base case and study model requires an upgrade.
 - MVA flow should not exceed Rate B (Emergency rating). Flow increase greater than or equal to 3% between base case and study model requires an upgrade.

Future Reliability Criteria

Due to the limited amount of generation in the load pocket and the potential of wide spread power outages in the Acadiana Load Pocket for loss of a line and a generator, N-1, G-1 criteria was studied. Currently this is above and beyond NERC planning criteria, however in the future this could become standard. Below is the proposed future criteria:

- All lines in service
 - Voltage must remain between 0.95 and 1.05 pu. Voltage deviation greater than or equal to 0.03 pu between base case and study model requires an upgrade.
 - MVA flow should not exceed Rate A (Normal rating). Flow increase greater than or equal to 3% between base case and study model requires an upgrade.
- Under contingencies (N-1, G-1)
 - Voltage must remain between 0.92 and 1.05 pu. Voltage deviation greater than or equal to 0.03 pu between base case and study model requires an upgrade.
 - MVA flow should not exceed Rate B (Emergency rating). Flow increase greater than or equal to 3% between base case and study model requires an upgrade.

B. Model Details

All results in this analysis are based off of the 2007 set of SPP models. The 2017 summer Peak model has the load within the Acadiana Load Pocket scaled up to 2000 MW. It should be noted that the analysis within this report is only a fraction of the studies simulated and each party has been given all supporting documentation, load flow cases for which these results are based on. These results are intended to demonstrate to all parties involved which overloads/violations are fixed by the different projects and which overload/violations remain problems under different generation dispatch scenarios (ALP generation dispatch can be found in the Index for each case)

IV. POWERFLOW RESULTS

A. 2012 Summer Peak N-1 Criteria Violations

The following elements were loaded over 100%:

Moril to Bayou Warehouse 138 kV line for loss of the Moril to Hopkins 138 kV line
Wells 230/500 kV Auto for loss of the Richard to Wells 500 kV line
Scott to Judice 138 kV line for loss of the Moril to Leblanc 138 kV line
Judice to Meaux 138 kV line for loss of the Moril to Leblanc 138 kV line
Semere to Scott bypass 138 kV line for loss of the Labbe to Bonin 230 kV line
Terrebonne to Greenwood 115 kV line for loss of Webre Wells 500 kV line
Liviona to Wilbert 138 kV line for loss of Webre Wells 500 kV line
N. Crowley to Scott 138 kV line for loss of the Labbe to Bonin 230 kV line

The following substations were flagged as having voltage below 0.92 pu.:

Col. Academy, Acadia(GSU) and Scanlin for loss of the Richard – Col. Academy 138 kV line
Beadle for loss of Flanders to Beadle 230 kV line
Leroy, Meaux, Delcamb and Abbeville for loss of the Moril to Duboin 138 kV line
Bonin, Semere, Cecelia, Acadiana Mall, Flanders for loss of Labbe to Bonin 230 kV line

B. 2017 Summer Peak N-1 Criteria Violations

The following elements were loaded over 100%:

Scott to Judice 138 kV line for loss of the Moril to Leblanc 138 kV line
Judice to Meaux 138 kV line for loss of the Moril to Leblanc 138 kV line
Semere to Scott bypass 138 kV line for loss of the Wells to Bonin 230 kV line
Bonin 230/138 kV Auto for loss of the Flanders to Acadiana Mall 230 kV line
Wells 230/500 kV Auto for loss of the Richard to Wells 500 kV line
Terrebonne to Greenwood 115 kV line for loss of Webre Wells 500 kV line
Scott 138/69 kV Auto #1 for loss of the Scott 138/69 kV Auto #2
Duboin to Bayou Warehouse 138 kV line for loss of the Moril to Hopkins 138 kV line
Bonin 138/69 kV Auto #2 for loss of the Bonin 138/69 kV Auto #1
Scott to Bonin 138 kV line for loss of the Labbe to Bonin 230 kV line
North Crowley to Scott 138 kV line for loss of the Wells to Bonin 230 kV line
Moril to Delcamb 138 kV line for loss of the Scott to Judice 138 kV line
Bonin to Cecelia 138 kV line for loss of the Richard to Col. Academy 138 kV line
Greenwood to Humphrey 115 kV line for loss of Webre Wells 500 kV line
Bonin to Cecelia 138 kV line for loss of the Richard to Col. Academy 138 kV line

The following substations were flagged as having voltage below 0.92 pu.:

Col. Academy, Acadia(GSU) and Scanlin for loss of the Richard – Col. Academy 138 kV line
Beadle for loss of Flanders to Beadle 230 kV line
Leroy, Meaux, Delcamb and Abbeville for loss of the Moril to Duboin 138 kV line

C. Option I (Reliability Portion)

2017 Summer Peak N-1 Criteria Violations

The following elements were loaded over 100%:

Wells 230/500 kV Auto for loss of the Richard to Wells 500 kV line
Terrebonne to Greenwood 115 kV line for loss of Webre to Wells 500 kV line
Scott 138/69 kV Auto #1 for loss of the Scott 138/69 kV Auto #2

The following substations were flagged as having voltage below 0.92 pu.:

None

D. Option I (Reliability & Economic Portion)

2017 Summer Peak N-1 G-1 Criteria Violations (Teche Unit 3 Off)

The following elements were loaded over 100%:

Terrebonne to Greenwood 115 kV line for loss of Webre to Wells 500 kV line
Greenwood to Humphry 115 kV line for loss of Webre to Wells 500 kV line
Humphry to Gibson 115 kV line for loss of Webre to Wells 500 kV line
Liviona to Wilbert 138 kV line for loss of Webre to Wells 500 kV line
Gibson to Ramos 138kV line for loss of Webre to Wells 500 kV line
*Scott 138/69 kV Auto #1 for loss of the Scott 138/69 kV Auto #2
*Bonin to Cecelia 138 kV line for loss of the Richard to Col. Academy 138 kV line

The following substations were flagged as having voltage below 0.92 pu.:

None

*Local Area Problem

E. Option I (Reliability & Economic Portion)

2017 Summer Peak N-1, G-2 Criteria Violations (Teche & Bonin Off)

The following elements were loaded over 100%:

Terrebonne to Greenwood 115 kV line for loss of Webre to Wells 500 kV line
Greenwood to Humphry 115 kV line for loss of Webre to Wells 500 kV line
Humphry to Gibson 115 kV line for loss of Webre to Wells 500 kV line
Gibson to Ramos 138kV line for loss of Webre to Wells 500 kV line
Liviona to Wilbert 138 kV line for loss of Webre to Wells 500 kV line
Scott 138/69 kV Auto #1 for loss of the Scott 138/69 kV Auto #2

The following substations were flagged as having voltage below 0.92 pu.:

Teche 138 kV bus with all lines in service
Teche 138 kV bus for an outage on the Webre to Wells 500 kV line

F. Option I (Reliability & Economic Portion)

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off)

The following elements were loaded over 100%:

Terrebonne to Greenwood 115 kV line for loss of Webre to Wells 500 kV line
Greenwood to Humphry 115 kV line for loss of Webre to Wells 500 kV line
Humphry to Gibson 115 kV line for loss of Webre to Wells 500 kV line
Liviona to Wilbert 138 kV line for loss of Webre to Wells 500 kV line
Gibson to Ramos 138kV line for loss of Webre to Wells 500 kV line
Scott 138/69 kV Auto #1 for loss of the Scott 138/69 kV Auto #2
Cocodrie to Ville Platte 230 kV line for loss of Webre to Wells 500 kV line
Acadiana Mall to Bonin 230 kV line for loss of Webre to Wells 500 kV line

The following substations were flagged as having voltage below 0.92 pu.:

Greenwood, Ramos, Semere, Judice, Leblanc, Scott, Leroy, Meaux, Moril, Delcambre, Abbeville, Duboin, Bayou Warehouse, Cecelia, Humphry, Gibson, BelPlace, Bayou Sale, Bayou Vista, Berwick, El Paso, Flanders, Hopkins, Ivanhoe, Julien, Meaux, Morbihan, North Bend, Patoutville, Segura, Sellers Rd, Teche, Wax Lake, Acadiana Mall, Bonin, Elks, Labbe, Beadle for loss of the Webre to Wells 500 kV line
Beadle for loss of Flanders to Beadle 230 kV line

G. Option II (ICT Option)

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off)

The following elements were loaded over 100%:

Scott to Bonin 138 kV line for loss of Wells to Pont Des Mouton 230 kV line
Webre to Cecelia 230 kV line for loss of Webre to Wells 500 kV line
Bonin 230/69 kV Auto for loss of Acadiana to Bonin 230 kV line

The following substations were flagged as having voltage below 0.92 pu.:

Col. Academy, Acadia(GSU) and Scanlin for loss of the Richard – Col. Academy 138 kV line
Champagne for loss of the Coughlin to Plaisance 138 kV line
Leroy, Meaux, Delcambre and Abbeville for loss of the Scott to Judice 138 kV line
Cecelia for loss of the Cecelia 230/138 kV Auto
Breux Bridge for loss of the Flanders to Beadle 230 kV line
Habetz for loss of the Richard to Habetz 138 kV line
Flanders for loss of the Wells to Pont Des Mouton 230 kV line
Moril with all lines in service

H. Option III (Webre & Richard)

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off)

The following elements were loaded over 100%:

Terrebonne to Greenwood 115 kV line for loss of Webre Wells 500 kV line
Webre 500/230 kV Auto for loss of the Webre to Wells 500 kV line
Bonin 230/69 kV Auto for loss of Bonin 230/138 kV Auto

The following substations were flagged as having voltage below 0.92 pu.:

Col. Academy, Acadia(GSU) and Scanlin for loss of the Richard – Col. Academy 138 kV line
Champagne for loss of the Coughlin to Plaisance 138 kV line
Leroy, Meaux, Delcambre and Abbeville for loss of the Wells to Pont Des Mouton 230 kV line
Duboin, Cecelia, Breux Bridge for loss of the Wells to Pont Des Mouton 230 kV line
Habetz for loss of the Richard to Habetz 138 kV line
Hopkins, Flanders, Nickerson for loss of the Wells to Pont Des Mouton 230 kV line
Sellers Rd. and BoninByPass for loss of the Wells to Pont Des Mouton 230 kV line

VIII. RECOMMENDATION

Currently the Acadiana Load Pocket depends on transmission system and 30 to 40 year old natural gas fired local generation to provide reliability for the load pocket year round. It is the recommendation of this group that a transmission project be constructed to improve import capability into the Acadiana Load Pocket in order to reduce the dependence on local generation within the load pocket and furthermore plan the ALP to a higher criteria standard on N-1, G-1 to insure reliability for the foreseeable future. The "Reliability & Economic", "ICT", and "Webre & Richard" options all meet the recommended standard of planning the system to N-1, G-1. Only the "Reliability and Economic" option provides an agreeable way to split up the project responsibilities in an equitable manner among Cleco Power LLC, Entergy, and Lafayette Utility Services. So it is the recommendation of this study for the "Reliability and Economic" option to be built.

Due to the dynamic nature of this industry and uncertainty of future generation dispatch this area will continue to need to be planned jointly with close interaction among transmission owners in the ALP.

IX. CONCLUSION

The recommendation of this study is to construct the "Reliability and Economic" project among Cleco Power, Entergy, and Lafayette. This report is final and a Memorandum of Understanding has been signed by all parties.

Attachment A. Model Generation Dispatch

Bus Number	Id	Bus Name	A		B		C		D		E		F		G		H	
			12SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)	17SP	Pgen (MW)
501812	1	G2RODEMR 22.000	525	525	525	525	525	525	525	525	525	525	525	525	525	525	525	525
501821	1	G1TECHE 13.800	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23	23
501822	1	G2TECHE 13.200	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48	48
501823	1	G3TECHE 24.000	318	318	325	325	325	325	325	325	325	325	325	325	325	325	325	325
501910	1	G1ACAD 18.000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
501911	1	G1-1ACAD 18.000	125	125	0	0	0	0	0	0	0	0	0	0	0	0	0	0
501912	1	G1-2ACAD 18.000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
501920	1	G2ACAD 18.000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
501921	1	G2-1ACAD 18.000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
501922	1	G2-2ACAD 18.000	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
502433	1	LABBE1 13.800	21	21	50	50	50	50	50	50	50	50	50	50	50	50	50	50
502434	1	LABBE2 13.800	48	48	50	50	50	50	50	50	50	50	50	50	50	50	50	50
502435	1	HARGIS1 13.800	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
502436	1	HARGIS2 13.800	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50	50
502437	1	BONIN3 20.000	0	0	127	127	127	127	127	127	127	127	127	127	127	127	127	127
502438	1	BONIN2 13.800	31	31	0	0	0	0	0	0	0	0	0	0	0	0	0	0
502439	1	BONIN1 13.800	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
503301	1	MRGNCTY4 138.00	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
503301	2	MRGNCTY4 138.00	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0
503301	3	MRGNCTY4 138.00	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17	17
503301	4	MRGNCTY4 138.00	36	36	31	31	31	31	31	31	31	31	31	31	31	31	31	31

EGSI-LA Breaker Upgrades

Scenario:

- Based on asymmetrical fault current analysis, various circuit breakers have been identified as underrated.

Recommended Solution:

- Replace the identified underrated circuit breakers with appropriately sized breakers.
(List in order of priority)

- Mossville 138kV # 17970
- Scott 138kV #'s 8820, 17100 & 8825
- Carlyss 69kV #'s 7840 & 8775
- Nelson 138kV # 7990
- Coly 69kV #'s 20375, 20365 & 20370
- Esso 230kV #'s 20080, 20085, 20090
- Nelson 230kV # 27105
- Scott 69kV # 8860




Descriptions: This project eliminates the ALP's N-1 criteria violations in 2017.

Construction:

- Build a New Meaux 230 kV Substation with a 230/138 kV Auto connected to the Meaux 138 kV station
 - Build a New 230 kV line from Wells to Meaux using mostly existing ROW
 - Build a New 230 kV line from Labbe to Bonin using existing ROW
- Add new Capacitor Banks at Meaux(36 MVAR), Leblanc(72 MVAR), and Acadia(GSU)(36 MVAR).

Estimated Cost: \$71,891,000

Attachment C. Reliability & Economic Project detail



Option Participants
 ENTERGY
 LAFAYETTE UTILITES
 CLECO

Descriptions: This project eliminates the ALP's N-1, G-1 criteria violations in 2017 which are not local area problems. This project also gives Cleco and LUS more generation flexibility in the ALP.

Construction:

- Build a New Meaux 230 kV Substation with a 230/138 kV Auto connected to the Meaux 138 kV station
- Build a New Richard 230 kV Substation with a 500/230 kV Auto connected to the Richard 500 kV station
- Build a New Segura 230 kV Substation with a 230/138 kV Auto connected to the Moril 138 kV station
- Build a New Sellers Rd. 230 kV Substation where the Wells to Meaux 230 kV line crosses the Habetz to Flanders 138 kV line
- Build a New 230 kV line from Wells to Labbe using mostly existing ROW
- Build a New 230 kV line from Labbe to Sellers Rd using existing ROW
- Build a New 230 kV line from Sellers Rd to Meaux using existing ROW
- Build a New 230 kV line from Sellers Rd to Segura using existing ROW
- Build a New 230 kV line from Richard to Sellers Rd using existing ROW
- Build a New 230 kV line from Labbe to Bonin using existing ROW
- Add a Second Wells 500/230 kV Auto
- Add a New 230/138 kV Auto and 138/69 kV Auto at Bonin
- Add Capacitor Banks at Acadia(GSU)(36), Cecelia(36), Scott(36), Meaux(18), Ramos(36), Beadle(36) and Leblanc(36) MVARs*

Estimated Cost: \$200,000,000

Option Participants

- ENERGY
- LAFAYETTE UTILITES
- CLECO

ENERGY
LAFAYETTE UTILITIES
CLECO

Descriptions: This project eliminates the ALP's N-1, G-1 criteria violations in 2017. This project also gives Cleco and LUS more generation flexibility in the ALP. This project also increases the amount of power that can be generated East of the Atchafalaya basin and/or reduces the must run requirements on Entergy generation West of the Atchafalaya basin. This provides more flexibility for Entergy and Entergy customers by greatly reducing the Webre to Wells operating limit on the Webre to Wells line.

Construction:

- Build a New Webre 230 kV Substation with a 500/230 kV Auto connected to the Webre 500 kV station
- Build a New Cecelia 230 kV Substation with a 230/138 kV Auto connected to the Cecelia 138 kV station
- Build a New Moril 230 kV Substation with a 230/138 kV Auto connected to the Moril 138 kV station
- Build a New 230 kV line from Webre to Cecelia using existing ROW
- Build a New 230 kV line from Cecelia to Wells using existing ROW
- Build a New 230 kV line from Cecelia to Moril using existing ROW
- Build a New 138 kV line from Moril to Leblanc using existing ROW
- Re-conductor the existing 138 kV line from Cecelia to Moril
- Re-conductor the existing 138 kV line from Cecelia to Bonin
- Re-conductor the existing 138 kV line from Moril to Duboin
- Add Capacitor Banks at Col. Academy(36), Meaux(36), Ramos(36) and Leblanc(72) MVARs*
- New Bonin 230/69 kV Auto**
- 2nd Wells 500/230 kV Auto**
- 2nd Webre 500/230 kV Auto**
- New Cecelia 230/69 kV Auto**

Estimated Cost: \$299,000,000

*More Capacitor banks could be needed to fix other violations in the Powerflow results.

** Projects are not included in the price estimate

Option Participants
ENERGY
LAFAYETTE UTILITES
CLECO

ENERGY
LAFAYETTE UTILITIES
CLECO

Descriptions: This project eliminates the ALP's N-1, G-1 criteria violations in 2017. This project also gives Cleco and LUS more generation flexibility in the ALP. This project also increases the amount of power that can be generated East of the Atchafalaya basin and/or reduces the must run requirements on Entergy generation West of the Atchafalaya basin. This provides more flexibility for Entergy and Entergy customers by greatly reducing the Webre to Wells operating limit on the Webre to Wells line.

Construction:

- Build a New Webre 230 kV Substation with a 500/230 kV Auto connected to the Webre 500 kV station
- Build a New Cecelia 230 kV Substation (optional)
- Build a New Scott 230 kV Substation with a 230/69 kV Auto connected to the Scott 69 kV station
- Build a New Meaux 230 kV Substation with a 230/138 kV Auto connected to the Meaux 138 kV station
- Build a New Richard 230 kV Substation with a 500/230 kV Auto connected to the Richard 500 kV station
- Build a New Segura 230 kV Substation with a 230/138 kV Auto connected to the Moril 138 kV station
- Build a New Sellers Rd. 230 kV Substation where the Scott to Meaux 230 kV line crosses the Habetz to Flanders 138 kV line
- Build a New 230 kV line from Webre to Cecelia using existing ROW
- Build a New 230 kV line from Cecelia to Segura using existing ROW
- Build a New 230 kV line from Scott to Sellers Rd using existing ROW
- Build a New 230 kV line from Sellers Rd to Meaux using existing ROW
- Build a New 230 kV line from Sellers Rd to Segura using existing ROW
- Build a New 230 kV line from Richard to Sellers Rd using existing ROW
- Build a New switching station where the Scott to Bonin and the Bonin to Cecelia 138 kV lines turn south near Labbe. Eliminate one of the 138 kV lines between this new switching station and Bonin to make room for a new 230 kV line into Bonin.
- Build a New 230 kV line from Scott to Bonin using existing ROW
- Add a New 230/69 kV Auto at Bonin
- Add Capacitor Banks at Col. Academy(36), Cecelia(36), Scott(36), Meaux(36), Ramos(36) and Leblanc(72) MVARs

Estimated Cost: \$319,000,000

*More Capacitor banks could be needed to fix other violations in the Powerflow results.

Attachment F. Powerflow Results

2012 Summer Peak N-1 Criteria Violations

** From bus	** ** To bus	** CKT	Contingency	Loading %
98184 4DUBOIN 138	98185 4BUWHSE 138	1	98177 4MORIL 138 500410 HOPKINS4 138	123.3
98109 8WELLS 500	500950 WELSRCT6 230	1	98107 8RICHARD 500 98109 8WELLS 500	120
97324 4JUDICE 138	98130 4SCOTT 138	1	98177 4MORIL 138 98178 4DELCAMB 138	111.5
97324 4JUDICE 138	98160 4MEAUX 138	1	98177 4MORIL 138 98178 4DELCAMB 138	109.4
97324 4JUDICE 138	98130 4SCOTT 138	1	97330 4LEBLAN 138 98178 4DELCAMB 138	103.7
97323 4SEMERE 138	98113 4SCOTT2 138	1	502403 BONIN 6 230 502421 LABBE 230	102.9
98410 4LIVON 138	98411 4WILBT 138	1	98109 8WELLS 500 98430 8WEBRE 500	102.9
97309 3GRENWD 115	98522 3TEREBN 115	1	98109 8WELLS 500 98430 8WEBRE 500	101
97329 4NCROWL 138	98130 4SCOTT 138	1	502403 BONIN 6 230 502421 LABBE 230	100.8
98177 4MORIL 138	98184 4DUBOIN 138	1	98177 4MORIL 138 500410 HOPKINS4 138	100.7
98130 4SCOTT 138	502404 BONIN 4	138 1	502403 BONIN 6 230 502421 LABBE 230	99.8
97324 4JUDICE 138	98160 4MEAUX 138	1	97330 4LEBLAN 138 98178 4DELCAMB 138	99.6
98185 4BUWHSE 138	500440 IVANHOE4 138	1	98177 4MORIL 138 500410 HOPKINS4 138	99.4
98177 4MORIL 138	98178 4DELCAMB 138	1	97324 4JUDICE 138 98130 4SCOTT 138	98.5
502403 BONIN 6 230	502404 BONIN 4	138 1	502402 ACADIAN6 230 502403 BONIN 6 230	98.1
98130 4SCOTT 138	98131 2SCOTT 69.0	2	98130 4SCOTT 138 98131 2SCOTT 69.0	95.7
98130 4SCOTT 138	98131 2SCOTT 69.0	1	98130 4SCOTT 138 98131 2SCOTT 69.0	95.7
97323 4SEMERE 138	98113 4SCOTT2 138	1	500940 WELLS 230 502410 PMOUTON6 230	95.5

2017 Summer Peak N-1 Criteria Violations

** From bus	** ** To bus	** CKT	Contingency	Loading %
97324 4JUDICE 138	98130 4SCOTT 138	1	98177 4MORIL 138 98178 4DELCAMB 138	125
97324 4JUDICE 138	98160 4MEAUX 138	1	98177 4MORIL 138 98178 4DELCAMB 138	123.6
97323 4SEMERE 138	98113 4SCOTT2 138	1	502403 BONIN 6 230 502421 LABBE 230	118.5
500190 COCODR 6 230	500230 COUGH 4	138 1	500190 COCODR 6 230 500880 VILPLT 6 230	117.1
97324 4JUDICE 138	98130 4SCOTT 138	1	97330 4LEBLAN 138 98178 4DELCAMB 138	115.5
502403 BONIN 6 230	502404 BONIN 4	138 1	502402 ACADIAN6 230 502403 BONIN 6 230	114.9
98109 8WELLS 500	500950 WELSRCT6 230	1	98107 8RICHARD 500 98109 8WELLS 500	114.8
97309 3GRENWD 115	98522 3TEREBN 115	1	98109 8WELLS 500 98430 8WEBRE 500	114
98130 4SCOTT 138	98131 2SCOTT 69.0	2	98130 4SCOTT 138 98131 2SCOTT 69.0	113
98130 4SCOTT 138	98131 2SCOTT 69.0	1	98130 4SCOTT 138 98131 2SCOTT 69.0	113
97324 4JUDICE 138	98160 4MEAUX 138	1	97330 4LEBLAN 138 98178 4DELCAMB 138	112.9
97323 4SEMERE 138	98113 4SCOTT2 138	1	500940 WELLS 230 502410 PMOUTON6 230	112.2
98184 4DUBOIN 138	98185 4BUWHSE 138	1	98177 4MORIL 138 500410 HOPKINS4 138	112
502404 BONIN 4 138	502405 BONIN 2	69.0 2	502401 FLANDER6 230 502425 BEADLE 6 230	111
98130 4SCOTT 138	502404 BONIN 4	138 1	502403 BONIN 6 230 502421 LABBE 230	110.9
500190 COCODR 6 230	500230 COUGH 4	138 1	500880 VILPLT 6 230 500920 WSTFORK6 230	110.3
97329 4NCROWL 138	98130 4SCOTT 138	1	502403 BONIN 6 230 502421 LABBE 230	110
97323 4SEMERE 138	98113 4SCOTT2 138	1	502410 PMOUTON6 230 502421 LABBE 230	108.3
98177 4MORIL 138	98178 4DELCAMB 138	1	97324 4JUDICE 138 98130 4SCOTT 138	107.9
98190 4CECELIA 138	502404 BONIN 4	138 1	98108 4RICHARD 138 98110 4COLACDY 138	106.9
502404 BONIN 4 138	502405 BONIN 2	69.0 1	502401 FLANDER6 230 502425 BEADLE 6 230	106.6

502404 BONIN 4	138	502405 BONIN 2	69.0	2	502404 BONIN 4	138	502405 BONIN 2	69.0	1	105.9
502404 BONIN 4	138	502405 BONIN 2	69.0	1	502404 BONIN 4	138	502405 BONIN 2	69.0	2	105.3
97329 4NCROWL	138	98130 4SCOTT	138	1	500940 WELLS	230	502410 PMOUTON6	230	1	104.6
502403 BONIN 6	230	502404 BONIN 4	138	1	502401 FLANDER6	230	502402 ACADIAN6	230	1	104.6
98190 4CECELIA	138	502404 BONIN 4	138	1	98110 4COLACDY	138	98111 4ACADGSU	138	1	102.4
97324 4JUDICE	138	98130 4SCOTT	138	1	500820 TECHE 4	138	501823 G3TECHE	24.0	1	101.5
97329 4NCROWL	138	98130 4SCOTT	138	1	502410 PMOUTON6	230	502421 LABBE	230	1	101
97309 3GRENWD	115	98520 3HUMPHY	115	1	98109 8WELLS	500	98430 8WEBRE	500	1	100.5
98190 4CECELIA	138	502404 BONIN 4	138	1	98111 4ACADGSU	138	98112 4SCANLN	138	1	100.1
500190 COCODR 6	230	500230 COUGH 4	138	1	500920 WSTFORK6	230	500940 WELLS	230	1	100
500820 TECHE 4	138	500830 TECHE 1	34.5	1	500820 TECHE 4	138	500830 TECHE 1	34.5	2	99.7
502404 BONIN 4	138	502405 BONIN 2	69.0	2	502402 ACADIAN6	230	502403 BONIN 6	230	1	99.6
98520 3HUMPHY	115	98521 3GIBSON	115	1	98109 8WELLS	500	98430 8WEBRE	500	1	99.4
98410 4LIVON	138	98411 4WILBT	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	98.7
98130 4SCOTT	138	98131 2SCOTT	69.0	1	97324 4JUDICE	138	98130 4SCOTT	138	1	98.7
98130 4SCOTT	138	98131 2SCOTT	69.0	2	97324 4JUDICE	138	98130 4SCOTT	138	1	98.7
97330 4LEBLAN	138	98178 4DELCAMB	138	1	97324 4JUDICE	138	98130 4SCOTT	138	1	98.2
98108 4RICHARD	138	98110 4COLACDY	138	1	502403 BONIN 6	230	502421 LABBE	230	1	98.1
98130 4SCOTT	138	502404 BONIN 4	138	1	500940 WELLS	230	502410 PMOUTON6	230	1	97.1
502403 BONIN 6	230	502421 LABBE	230	1	98107 8RICHARD	500	98109 8WELLS	500	1	96.9
98108 4RICHARD	138	500400 HABETZ 4	138	1	502403 BONIN 6	230	502421 LABBE	230	1	96.7
502404 BONIN 4	138	502405 BONIN 2	69.0	2	502413 ELKS 2	69.0	502417 ELKS 6	230	1	96.5
502404 BONIN 4	138	502405 BONIN 2	69.0	2	502417 ELKS 6	230	502425 BEADLE 6	230	1	96.5
502404 BONIN 4	138	502405 BONIN 2	69.0	1	502402 ACADIAN6	230	502403 BONIN 6	230	1	96
500190 COCODR 6	230	500230 COUGH 4	138	1	98107 8RICHARD	500	98109 8WELLS	500	1	95.8
502401 FLANDER6	230	502402 ACADIAN6	230	1	98107 8RICHARD	500	98109 8WELLS	500	1	95.8
502401 FLANDER6	230	502402 ACADIAN6	230	1	502403 BONIN 6	230	502404 BONIN 4	138	1	95.6
97324 4JUDICE	138	98160 4MEAUX	138	1	500820 TECHE 4	138	501823 G3TECHE	24.0	1	95.4
98108 4RICHARD	138	98130 4SCOTT	138	1	502403 BONIN 6	230	502421 LABBE	230	1	95.4
98176 2MORIL	69.0	98177 4MORIL	138	1	98177 4MORIL	138	98178 4DELCAMB	138	1	95.1

2017 Summer Peak N-1 Criteria Violations (Reliability Upgrade)

** From bus	** ** To bus	** CKT	Contingency	Loading %
98109 8WELLS	500 500950 WELSRCT6	230 1	98107 8RICHARD 500 98109 8WELLS 500 1	127.3
500190 COCODR 6	230 500230 COUGH 4	138 1	500190 COCODR 6 230 500880 VILPLT 6 230 1	115.7
500190 COCODR 6	230 500230 COUGH 4	138 1	500880 VILPLT 6 230 500920 WSTFORK6 230 1	108.9
97309 3GRENWD	115 98522 3TEREBN	115 1	98109 8WELLS 500 98430 8WEBRE 500 1	107.9
98109 8WELLS	500 500950 WELSRCT6	230 1	500190 COCODR 6 230 500880 VILPLT 6 230 1	102
98130 4SCOTT	138 98131 2SCOTT	69.0 2	98130 4SCOTT 138 98131 2SCOTT 69.0 1	101.4
98130 4SCOTT	138 98131 2SCOTT	69.0 1	98130 4SCOTT 138 98131 2SCOTT 69.0 2	101.4
500820 TECHE 4	138 500830 TECHE 1	34.5 1	500820 TECHE 4 138 500830 TECHE 1 34.5 2	99.7
500190 COCODR 6	230 500230 COUGH 4	138 1	500920 WSTFORK6 230 500940 WELLS 230 1	98.6
98109 8WELLS	500 500950 WELSRCT6	230 1	500880 VILPLT 6 230 500920 WSTFORK6 230 1	96.9
98410 4LIVON	138 98411 4WILBT	138 1	98109 8WELLS 500 98430 8WEBRE 500 1	96.6

2017 Summer Peak N-1 G-1Criteria Violations (Teche Unit 3) (Reliability & Economic Upgrade)

** From bus	** **	To bus	** CKT	Contingency				Loading %
97309 3GRENWD	115	98522 3TEREBN	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	141.9
97309 3GRENWD	115	98520 3HUMPHY	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	127.6
98520 3HUMPHY	115	98521 3GIBSON	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	126.5
98410 4LIVON	138	98411 4WILBT	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	109.3
98572 4GIBSON	138	500740 RAMOS 4	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	108.5
98130 4SCOTT	138	98131 2SCOTT	69.0 1	98130 4SCOTT	138	98131 2SCOTT	69.0 2	104.8
98130 4SCOTT	138	98131 2SCOTT	69.0 2	98130 4SCOTT	138	98131 2SCOTT	69.0 1	104.8
98190 4CECELIA	138	502404 BONIN 4	138 1	98108 4RICHARD	138	98110 4COLACDY	138 1	100.1
98147 4L-642TP	138	98410 4LIVON	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	97.2
98190 4CECELIA	138	502404 BONIN 4	138 1	98110 4COLACDY	138	98111 4ACADGSU	138 1	96.7
98521 3GIBSON	115	98572 4GIBSON	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	95.8
97318 4KSPRGS	138	98147 4L-642TP	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	95.5
98190 4CECELIA	138	502404 BONIN 4	138 1	98111 4ACADGSU	138	98112 4SCANLN	138 1	95.1

2017 Summer Peak N-1 G-2Criteria Violations (Teche & Bonin) (Reliability & Economic Upgrade)

** From bus	** **	To bus	** CKT	Contingency				Loading %
97309 3GRENWD	115	98522 3TEREBN	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	159.7
97309 3GRENWD	115	98520 3HUMPHY	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	144.4
98520 3HUMPHY	115	98521 3GIBSON	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	143.5
98572 4GIBSON	138	500740 RAMOS 4	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	123.4
98410 4LIVON	138	98411 4WILBT	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	120.8
98147 4L-642TP	138	98410 4LIVON	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	108.2
97318 4KSPRGS	138	98147 4L-642TP	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	106.5
97340 4EOPLOUS	138	98141 4CHAMPNE	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	104.7
98521 3GIBSON	115	98572 4GIBSON	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	104.4
98130 4SCOTT	138	98131 2SCOTT	69.0 1	98130 4SCOTT	138	98131 2SCOTT	69.0 2	103.7
98130 4SCOTT	138	98131 2SCOTT	69.0 2	98130 4SCOTT	138	98131 2SCOTT	69.0 1	103.7
500940 WELLS	230	500950 WELSRCT6	230 1	98107 8RICHARD	500	98109 8WELLS	500 1	102.9
97319 4VATCAN	138	97340 4EOPLOUS	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	100.6
98190 4CECELIA	138	502404 BONIN 4	138 1	98108 4RICHARD	138	98110 4COLACDY	138 1	99
98177 4MORIL	138	98184 4DUBOIN	138 1	97309 3GRENWD	115	98522 3TEREBN	115 1	98.5
98190 4CECELIA	138	502404 BONIN 4	138 1	98110 4COLACDY	138	98111 4ACADGSU	138 1	95.5
97318 4KSPRGS	138	98141 4CHAMPNE	138 1	98109 8WELLS	500	98430 8WEBRE	500 1	95.2
98177 4MORIL	138	98184 4DUBOIN	138 1	98177 4MORIL	138	500410 HOPKINS4	138 1	95

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off) (Reliability & Economic Upgrade)

** From bus	** **	To bus	** CKT	Contingency				Loading %
97309 3GRENWD	115	98522 3TEREBN	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	191.4
500820 TECHE 4	138	500830 TECHE 1	34.5 1	500820 TECHE 4	138	500830 TECHE 1	34.5 2	176.2
97309 3GRENWD	115	98520 3HUMPHY	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	169.2

98520 3HUMPHY	115	98521 3GIBSON	115	1	98109 8WELLS	500	98430 8WEBRE	500	1	167.9
500820 TECHE 4	138	500830 TECHE 1	34.5	2	500820 TECHE 4	138	500830 TECHE 1	34.5	1	152.2
98410 4LIVON	138	98411 4WILBT	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	143
98572 4GIBSON	138	500740 RAMOS 4	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	139.5
97340 4EOPLOUS	138	98141 4CHAMPNE	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	135.6
97319 4VATCAN	138	97340 4EOPLOUS	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	128.4
98147 4L-642TP	138	98410 4LIVON	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	126.2
97318 4KSPRGS	138	98147 4L-642TP	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	123.5
500620 NICKTAP	69.0	502413 ELKS 2	69.0	1	98109 8WELLS	500	98430 8WEBRE	500	1	119.8
500940 WELLS	230	500950 WELSRCT6	230	1	98107 8RICHARD	500	98109 8WELLS	500	1	111
500100 BERWKTP4	138	500740 RAMOS 4	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	109
500060 BVISTA 4	138	500100 BERWKTP4	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	107.8
98161 2MEAUX	69.0	98162 2HUNTER	69.0	1	98109 8WELLS	500	98430 8WEBRE	500	1	106.4
500190 COCODR 6	230	500880 VILPLT 6	230	1	98109 8WELLS	500	98430 8WEBRE	500	1	106.4
97318 4KSPRGS	138	98141 4CHAMPNE	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	103.7
98130 4SCOTT	138	98131 2SCOTT	69.0	1	98130 4SCOTT	138	98131 2SCOTT	69.0	2	103.4
98130 4SCOTT	138	98131 2SCOTT	69.0	2	98130 4SCOTT	138	98131 2SCOTT	69.0	1	103.4
502402 ACADIAN6	230	502403 BONIN 6	230	1	98109 8WELLS	500	98430 8WEBRE	500	1	101
500880 VILPLT 6	230	500920 WSTFORK6	230	1	98109 8WELLS	500	98430 8WEBRE	500	1	100.1
98177 4MORIL	138	98184 4DUBOIN	138	1	97309 3GRENWD	115	98522 3TEREBN	115	1	98.5
98109 8WELLS	500	500950 WELSRCT6	230	1	98107 8RICHARD	500	98109 8WELLS	500	1	97.8
98109 8WELLS	500	500950 WELSRCT6	230	2	98107 8RICHARD	500	98109 8WELLS	500	1	97.8
98190 4CECELIA	138	502404 BONIN 4	138	1	98108 4RICHARD	138	98110 4COLACDY	138	1	96.7
502401 FLANDER6	230	502402 ACADIAN6	230	1	98109 8WELLS	500	98430 8WEBRE	500	1	96
97323 4SEMERE	138	98113 4SCOTT2	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	95.8
502401 FLANDER6	230	502402 ACADIAN6	230	1	98108 4RICHARD	138	500400 HABETZ 4	138	1	95.8
98108 4RICHARD	138	98110 4COLACDY	138	1	98109 8WELLS	500	98430 8WEBRE	500	1	95.6

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off) (ICT option)

** From bus	** **	To bus	** CKT	Contingency				Loading %
98130 4SCOTT	138	502404 BONIN 4	138 1	500940 WELLS	230	502410 PMOUTON6	230 1	104.9
99905 WEBRE 6	230	99906 6CECELIA	230 1	98109 8WELLS	500	98430 8WEBRE	500 1	103.0

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off) (Webre & Richard Upgrade)

** From bus	** **	To bus	** CKT	Contingency				Loading %
97309 3GRENWD	115	98522 3TEREBN	115 1	98109 8WELLS	500	98430 8WEBRE	500 1	110.4
98109 8WELLS	500	500950 WELSRCT6	230 1	98107 8RICHARD	500	98109 8WELLS	500 1	116.3
98430 8WEBRE	500	99905 WEBRE 6	230 1	98109 8WELLS	500	98430 8WEBRE	500 1	102.6

Attachment G. Powerflow Voltage Report

2012 Summer Peak N-1 Criteria Violations

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description			
98159	4LEROY	0.9425	0.9425	**	Base Case	**	
98160	4MEAUX	0.9496	0.9496	**	Base Case	**	
98178	4DELCAMB	0.8372	0.9602	98177 4MORIL	138	98178 4DELCAMB	138 1
97330	4LEBLAN	0.8379	0.9567	98177 4MORIL	138	98178 4DELCAMB	138 1
98179	4ABBVIL	0.8543	0.9543	98177 4MORIL	138	98178 4DELCAMB	138 1
97330	4LEBLAN	0.8592	0.9567	97330 4LEBLAN	138	98178 4DELCAMB	138 1
98159	4LEROY	0.8637	0.9425	98177 4MORIL	138	98178 4DELCAMB	138 1
98160	4MEAUX	0.8715	0.9496	98177 4MORIL	138	98178 4DELCAMB	138 1
98179	4ABBVIL	0.8723	0.9543	97330 4LEBLAN	138	98178 4DELCAMB	138 1
98159	4LEROY	0.8776	0.9425	97330 4LEBLAN	138	98178 4DELCAMB	138 1
97324	4JUDICE	0.8851	0.9504	97324 4JUDICE	138	98130 4SCOTT	138 1
98160	4MEAUX	0.8853	0.9496	97330 4LEBLAN	138	98178 4DELCAMB	138 1
98159	4LEROY	0.8896	0.9425	97324 4JUDICE	138	98130 4SCOTT	138 1
97319	4VATCAN	0.8958	0.9567	97319 4VATCAN	138	98130 4SCOTT	138 1
98110	4COLACDY	0.8962	0.9872	98108 4RICHARD	138	98110 4COLACDY	138 1
98160	4MEAUX	0.8972	0.9496	97324 4JUDICE	138	98130 4SCOTT	138 1
98111	4ACADGSU	0.8979	0.9765	98108 4RICHARD	138	98110 4COLACDY	138 1
98112	4SCANLN	0.8982	0.9752	98108 4RICHARD	138	98110 4COLACDY	138 1
502425	BEADLE 6	0.8996	0.9672	502401 FLANDER6	230	502425 BEADLE 6	230 1
98410	4LIVON	0.9020	0.9637	98410 4LIVON	138	98411 4WILBT	138 1
97324	4JUDICE	0.9041	0.9504	98177 4MORIL	138	98178 4DELCAMB	138 1
97330	4LEBLAN	0.9048	0.9567	98177 4MORIL	138	500410 HOPKINS4	138 1
97328	4VEAZIE	0.9048	0.9682	500230 COUGH 4	138	500720 PLAISAN4	138 1
98159	4LEROY	0.9052	0.9425	502403 BONIN 6	230	502421 LABBE	230 1
98159	4LEROY	0.9056	0.9425	98177 4MORIL	138	500410 HOPKINS4	138 1
98178	4DELCAMB	0.9067	0.9602	98177 4MORIL	138	500410 HOPKINS4	138 1
97311	4PLAISN	0.9079	0.9712	500230 COUGH 4	138	500720 PLAISAN4	138 1
500720	PLAISAN4	0.9080	0.9712	500230 COUGH 4	138	500720 PLAISAN4	138 1
98148	4COLSPRG	0.9082	0.9568	98410 4LIVON	138	98411 4WILBT	138 1
97318	4KSPRGS	0.9083	0.9568	98410 4LIVON	138	98411 4WILBT	138 1
98147	4L-642TP	0.9083	0.9568	98410 4LIVON	138	98411 4WILBT	138 1
98111	4ACADGSU	0.9096	0.9765	98110 4COLACDY	138	98111 4ACADGSU	138 1
98112	4SCANLN	0.9097	0.9752	98110 4COLACDY	138	98111 4ACADGSU	138 1
98179	4ABBVIL	0.9097	0.9543	98177 4MORIL	138	500410 HOPKINS4	138 1
98179	4ABBVIL	0.9103	0.9543	97324 4JUDICE	138	98130 4SCOTT	138 1
98159	4LEROY	0.9116	0.9425	500820 TECHE 4	138	501823 G3TECHE	24.0 1
97324	4JUDICE	0.9119	0.9504	502403 BONIN 6	230	502421 LABBE	230 1
98160	4MEAUX	0.9126	0.9496	502403 BONIN 6	230	502421 LABBE	230 1
98160	4MEAUX	0.9130	0.9496	98177 4MORIL	138	500410 HOPKINS4	138 1
97324	4JUDICE	0.9136	0.9504	97330 4LEBLAN	138	98178 4DELCAMB	138 1
97318	4KSPRGS	0.9138	0.9568	98109 8WELLS	500	98430 8WEBRE	500 1

98147	4L-642TP	0.9138	0.9568	98109 8WELLS	500	98430 8WEBRE	500 1
98148	4COLSPRG	0.9138	0.9568	98109 8WELLS	500	98430 8WEBRE	500 1
502404	BONIN 4	0.9139	0.9641	502403 BONIN 6	230	502421 LABBE	230 1
98410	4LIVON	0.9141	0.9637	98109 8WELLS	500	98430 8WEBRE	500 1
98112	4SCANLN	0.9148	0.9752	98111 4ACADGSU	138	98112 4SCANLN	138 1
97323	4SEMERE	0.9170	0.9549	502403 BONIN 6	230	502421 LABBE	230 1
98190	4CECELIA	0.9170	0.9550	502403 BONIN 6	230	502421 LABBE	230 1
502425	BEADLE 6	0.9175	0.9672	502403 BONIN 6	230	502421 LABBE	230 1
98177	4MORIL	0.9177	0.9782	98177 4MORIL	138	500410 HOPKINS4	138 1
502403	BONIN 6	0.9177	0.9744	502403 BONIN 6	230	502421 LABBE	230 1
97340	4EOPLOUS	0.9179	0.9576	97319 4VATCAN	138	98130 4SCOTT	138 1
502402	ACADIAN6	0.9183	0.9707	502403 BONIN 6	230	502421 LABBE	230 1
98141	4CHAMPNE	0.9187	0.9590	500230 COUGH 4	138	500720 PLAISAN4	138 1
502401	FLANDER6	0.9187	0.9694	502403 BONIN 6	230	502421 LABBE	230 1
98160	4MEAUX	0.9190	0.9496	500820 TECHE 4	138	501823 G3TECHE	24.0 1
97319	4VATCAN	0.9190	0.9567	502403 BONIN 6	230	502421 LABBE	230 1
98159	4LEROY	0.9192	0.9425	500940 WELLS	230	502410 PMOUTON6	230 1
98179	4ABBVIL	0.9199	0.9543	502403 BONIN 6	230	502421 LABBE	230 1

2017 Summer Peak N-1 Criteria Violations

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description			
97324	4JUDICE	0.8840	0.9591	97324 4JUDICE	138	98130 4SCOTT	138 1
98159	4LEROY	0.8898	0.9525	97324 4JUDICE	138	98130 4SCOTT	138 1
502425	BEADLE 6	0.8944	0.9718	502401 FLANDER6	230	502425 BEADLE 6	230 1
98110	4COLACDY	0.8950	0.9843	98108 4RICHARD	138	98110 4COLACDY	138 1
98111	4ACADGSU	0.8969	0.9741	98108 4RICHARD	138	98110 4COLACDY	138 1
98112	4SCANLN	0.8973	0.9729	98108 4RICHARD	138	98110 4COLACDY	138 1
98160	4MEAUX	0.8976	0.9598	97324 4JUDICE	138	98130 4SCOTT	138 1
97328	4VEAZIE	0.8994	0.9873	500230 COUGH 4	138	500720 PLAISAN4	138 1
98159	4LEROY	0.9001	0.9525	98177 4MORIL	138	98178 4DELCAMB	138 1
97311	4PLAISN	0.9027	0.9903	500230 COUGH 4	138	500720 PLAISAN4	138 1
500720	PLAISAN4	0.9028	0.9903	500230 COUGH 4	138	500720 PLAISAN4	138 1
98178	4DELCAMB	0.9056	0.9700	98177 4MORIL	138	98178 4DELCAMB	138 1
97330	4LEBLAN	0.9063	0.9682	98177 4MORIL	138	98178 4DELCAMB	138 1
98179	4ABBVIL	0.9063	0.9647	98177 4MORIL	138	98178 4DELCAMB	138 1
97319	4VATCAN	0.9070	0.9659	97319 4VATCAN	138	98130 4SCOTT	138 1
98160	4MEAUX	0.9078	0.9598	98177 4MORIL	138	98178 4DELCAMB	138 1
98111	4ACADGSU	0.9099	0.9741	98110 4COLACDY	138	98111 4ACADGSU	138 1
98112	4SCANLN	0.9100	0.9729	98110 4COLACDY	138	98111 4ACADGSU	138 1
98179	4ABBVIL	0.9114	0.9647	97324 4JUDICE	138	98130 4SCOTT	138 1
98141	4CHAMPNE	0.9149	0.9709	500230 COUGH 4	138	500720 PLAISAN4	138 1
98112	4SCANLN	0.9157	0.9729	98111 4ACADGSU	138	98112 4SCANLN	138 1
98159	4LEROY	0.9169	0.9525	500940 WELLS	230	502410 PMOUTON6	230 1
97318	4KSPRG	0.9195	0.9654	500230 COUGH 4	138	500720 PLAISAN4	138 1

98147	4L-642TP	0.9196	0.9654	500230 COUGH 4	138 500720 PLAISAN4	138 1
98148	4COLSPRG	0.9196	0.9653	500230 COUGH 4	138 500720 PLAISAN4	138 1

2017 Summer Peak N-1 Criteria Violations (Reliability Upgrade)

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description		
502425	BEADLE 6	0.8975	0.9765	502401 FLANDER6	230 502425 BEADLE 6	230 1
97319	4VATCAN	0.9082	0.9756	97319 4VATCAN	138 98130 4SCOTT	138 1
97328	4VEAZIE	0.9110	0.9913	500230 COUGH 4	138 500720 PLAISAN4	138 1
97311	4PLAISN	0.9142	0.9942	500230 COUGH 4	138 500720 PLAISAN4	138 1
500720	PLAISAN4	0.9143	0.9943	500230 COUGH 4	138 500720 PLAISAN4	138 1

2017 Summer Peak N-1 G-1Criteria Violations (Teche Unit 3) (Reliability & Economic Upgrade)

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description		
97319	4VATCAN	0.9079	0.9770	97319 4VATCAN	138 98130 4SCOTT	138 1
98410	4LIVON	0.9104	0.9740	98109 8WELLS	500 98430 8WEBRE	500 1
97328	4VEAZIE	0.9137	0.9915	500230 COUGH 4	138 500720 PLAISAN4	138 1
97318	4KSPRGS	0.9158	0.9709	98109 8WELLS	500 98430 8WEBRE	500 1
98147	4L-642TP	0.9158	0.9709	98109 8WELLS	500 98430 8WEBRE	500 1
98148	4COLSPRG	0.9158	0.9708	98109 8WELLS	500 98430 8WEBRE	500 1
97311	4PLAISN	0.9170	0.9945	500230 COUGH 4	138 500720 PLAISAN4	138 1
500720	PLAISAN4	0.9171	0.9946	500230 COUGH 4	138 500720 PLAISAN4	138 1

2017 Summer Peak N-1 G-2Criteria Violations (Teche & Bonin) (Reliability & Economic Upgrade)

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description		
98410	4LIVON	0.8823	0.9696	98109 8WELLS	500 98430 8WEBRE	500 1
98148	4COLSPRG	0.8849	0.9654	98109 8WELLS	500 98430 8WEBRE	500 1
97318	4KSPRGS	0.8850	0.9654	98109 8WELLS	500 98430 8WEBRE	500 1
98147	4L-642TP	0.8850	0.9654	98109 8WELLS	500 98430 8WEBRE	500 1
97328	4VEAZIE	0.9025	0.9875	500230 COUGH 4	138 500720 PLAISAN4	138 1
98141	4CHAMPNE	0.9050	0.9711	98109 8WELLS	500 98430 8WEBRE	500 1
97340	4EOPLIOUS	0.9051	0.9684	98109 8WELLS	500 98430 8WEBRE	500 1
97311	4PLAISN	0.9058	0.9905	500230 COUGH 4	138 500720 PLAISAN4	138 1
500720	PLAISAN4	0.9059	0.9906	500230 COUGH 4	138 500720 PLAISAN4	138 1
97319	4VATCAN	0.9070	0.9648	97319 4VATCAN	138 98130 4SCOTT	138 1
98521	3GIBSON	0.9128	0.9934	98109 8WELLS	500 98430 8WEBRE	500 1
98520	3HUMPHY	0.9155	0.9874	98109 8WELLS	500 98430 8WEBRE	500 1
97309	3GRENWD	0.9167	0.9874	98109 8WELLS	500 98430 8WEBRE	500 1
97319	4VATCAN	0.9179	0.9648	98109 8WELLS	500 98430 8WEBRE	500 1
98410	4LIVON	0.9180	0.9696	98410 4LIVON	138 98411 4WILBT	138 1
98141	4CHAMPNE	0.9180	0.9711	500230 COUGH 4	138 500720 PLAISAN4	138 1

**2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off)
(Reliability & Economic Upgrade)**

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description			
98521	3GIBSON	0.8762	0.9917	98109 8WELLS	500	98430 8WEBRE	500 1
98520	3HUMPHY	0.8871	0.9858	98109 8WELLS	500	98430 8WEBRE	500 1
97309	3GRENWD	0.8888	0.9858	98109 8WELLS	500	98430 8WEBRE	500 1
97328	4VEAZIE	0.8981	0.9838	500230 COUGH 4	138	500720 PLAISAN4	138 1
97324	4JUDICE	0.8991	0.9586	98109 8WELLS	500	98430 8WEBRE	500 1
98572	4GIBSON	0.8992	0.9917	98109 8WELLS	500	98430 8WEBRE	500 1
502425	BEADLE 6	0.9003	0.9633	502401 FLANDER6	230	502425 BEADLE 6	230 1
98159	4LEROY	0.9007	0.9580	98109 8WELLS	500	98430 8WEBRE	500 1
97311	4PLAISN	0.9014	0.9868	500230 COUGH 4	138	500720 PLAISAN4	138 1
500720	PLAISAN4	0.9015	0.9869	500230 COUGH 4	138	500720 PLAISAN4	138 1
97323	4SEMERE	0.9025	0.9588	98109 8WELLS	500	98430 8WEBRE	500 1
98190	4CECELIA	0.9025	0.9591	98109 8WELLS	500	98430 8WEBRE	500 1
98130	4SCOTT	0.9027	0.9632	98109 8WELLS	500	98430 8WEBRE	500 1
97319	4VATCAN	0.9047	0.9590	97319 4VATCAN	138	98130 4SCOTT	138 1
502404	BONIN 4	0.9068	0.9677	98109 8WELLS	500	98430 8WEBRE	500 1
500090	BERWIC 4	0.9081	1.0057	98109 8WELLS	500	98430 8WEBRE	500 1
500100	BERWKTP4	0.9081	1.0057	98109 8WELLS	500	98430 8WEBRE	500 1
98160	4MEAUX	0.9084	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
500060	BVISTA 4	0.9091	1.0040	98109 8WELLS	500	98430 8WEBRE	500 1
98179	4ABBVIL	0.9102	0.9691	98109 8WELLS	500	98430 8WEBRE	500 1
503306	ABBVILL4	0.9102	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
500630	N.BEND 4	0.9106	0.9970	98109 8WELLS	500	98430 8WEBRE	500 1
98184	4DUBOIN	0.9113	0.9718	98109 8WELLS	500	98430 8WEBRE	500 1
500290	ELPTAP 4	0.9115	1.0020	98109 8WELLS	500	98430 8WEBRE	500 1
98178	4DELCAMB	0.9116	0.9715	98109 8WELLS	500	98430 8WEBRE	500 1
97310	4BAYRAM	0.9120	1.0104	98109 8WELLS	500	98430 8WEBRE	500 1
97330	4LEBLAN	0.9120	0.9721	98109 8WELLS	500	98430 8WEBRE	500 1
500740	RAMOS 4	0.9120	1.0105	98109 8WELLS	500	98430 8WEBRE	500 1
500775	SEGURA6	0.9125	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
500050	BSALES 4	0.9129	1.0040	98109 8WELLS	500	98430 8WEBRE	500 1
98177	4MORIL	0.9131	0.9719	98109 8WELLS	500	98430 8WEBRE	500 1
500890	WAXLAKE4	0.9131	1.0017	98109 8WELLS	500	98430 8WEBRE	500 1
98410	4LIVON	0.9132	0.9665	98410 4LIVON	138	98411 4WILBT	138 1
500565	MEAUX 6	0.9133	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
502417	ELKS 6	0.9135	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
98141	4CHAMPNE	0.9137	0.9667	500230 COUGH 4	138	500720 PLAISAN4	138 1
502425	BEADLE 6	0.9146	0.9633	98109 8WELLS	500	98430 8WEBRE	500 1
502401	FLANDER6	0.9151	0.9647	98109 8WELLS	500	98430 8WEBRE	500 1
500660	PATOUT 4	0.9154	0.9810	98109 8WELLS	500	98430 8WEBRE	500 1
98112	4SCANLN	0.9154	0.9759	98111 4ACADGSU	138	98112 4SCANLN	138 1
500410	HOPKINS4	0.9156	0.9755	98109 8WELLS	500	98430 8WEBRE	500 1
502402	ACADIAN6	0.9158	0.9658	98109 8WELLS	500	98430 8WEBRE	500 1

98185	4BUWHSE	0.9162	0.9819	98109 8WELLS	500	98430 8WEBRE	500 1
500820	TECHE 4	0.9165	0.9897	98109 8WELLS	500	98430 8WEBRE	500 1
500776	SELLRD6	0.9169	0.9653	98109 8WELLS	500	98430 8WEBRE	500 1
502403	BONIN 6	0.9179	0.9694	98109 8WELLS	500	98430 8WEBRE	500 1
97318	4KSPRGS	0.9180	0.9618	500230 COUGH 4	138	500720 PLAISAN4	138 1
98148	4COLSPRG	0.9180	0.9618	500230 COUGH 4	138	500720 PLAISAN4	138 1
500030	BELPLA 4	0.9180	0.9771	98109 8WELLS	500	98430 8WEBRE	500 1
500580	MORBHAN4	0.9180	0.9772	98109 8WELLS	500	98430 8WEBRE	500 1
98147	4L-642TP	0.9181	0.9618	500230 COUGH 4	138	500720 PLAISAN4	138 1
500330	FLANDR 4	0.9182	1.0020	98109 8WELLS	500	98430 8WEBRE	500 1
500450	JULIEN 4	0.9187	0.9886	98109 8WELLS	500	98430 8WEBRE	500 1
502421	LABBE	0.9187	0.9702	98109 8WELLS	500	98430 8WEBRE	500 1
98148	4COLSPRG	0.9194	0.9618	98410 4LIVON	138	98411 4WILBT	138 1
97318	4KSPRGS	0.9195	0.9618	98410 4LIVON	138	98411 4WILBT	138 1
98147	4L-642TP	0.9195	0.9618	98410 4LIVON	138	98411 4WILBT	138 1
500440	IVANHOE4	0.9198	0.9878	98109 8WELLS	500	98430 8WEBRE	500 1

2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off) (ICT option)

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description			
98130	4SCOTT	0.9367	0.9367	**	Base Case	**	
98159	4LEROY	0.9085	0.9085	**	Base Case	**	
98160	4MEAUX	0.9162	0.9162	**	Base Case	**	
98177	4MORIL	0.9465	0.9465	**	Base Case	**	
98178	4DELCAMB	0.9367	0.9367	**	Base Case	**	
98179	4ABBVIL	0.926	0.926	**	Base Case	**	
98184	4DUBOIN	0.9493	0.9493	**	Base Case	**	
98190	4CECELIA	0.9496	0.9496	**	Base Case	**	
500330	FLANDR 4	0.9497	0.9497	**	Base Case	**	
500944	6 MORIL	0.9466	0.9466	**	Base Case	**	
98130	4SCOTT	0.9174	0.9367	500230 COUGH 4	138	500720 PLAISAN4	138 1
98159	4LEROY	0.8812	0.9085	97324 4JUDICE	138	98130 4SCOTT	138 1
98159	4LEROY	0.8812	0.9085	97330 4LEBLAN	138	98179 4ABBVIL	138 1
98159	4LEROY	0.8871	0.9085	98160 4MEAUX	138	98179 4ABBVIL	138 1
98160	4MEAUX	0.8879	0.9162	97513 7GRIMES	345	97554 GRMXF	345 1
98160	4MEAUX	0.8891	0.9162	97324 4JUDICE	138	98130 4SCOTT	138 1
98160	4MEAUX	0.8891	0.9162	97330 4LEBLAN	138	98179 4ABBVIL	138 1
98179	4ABBVIL	0.8891	0.926	97330 4LEBLAN	138	98179 4ABBVIL	138 1
98159	4LEROY	0.8913	0.9085	500940 WELLS	230	502410 PMOUTON6	230 1
98141	4CHAMPNE	0.8916	0.9532	500230 COUGH 4	138	500720 PLAISAN4	138 1
98159	4LEROY	0.8932	0.9085	500920 WSTFORK6	230	500940 WELLS	230 1
98159	4LEROY	0.8932	0.9085	97324 4JUDICE	138	98160 4MEAUX	138 1
98159	4LEROY	0.8947	0.9085	97329 4NCROWL	138	98108 4RICHARD	138 1
98160	4MEAUX	0.895	0.9162	98160 4MEAUX	138	98179 4ABBVIL	138 1
98159	4LEROY	0.8952	0.9085	500940 WELLS	230	500950 WELSRCT6	230 1
98159	4LEROY	0.8952	0.9085	98190 4CECELIA	138	99906 6CECELIA	230 1

98130	4SCOTT	0.8955	0.9367	500940 WELLS	230	502410 PMOUTON6	230	1
98159	4LEROY	0.8968	0.9085	97329 4NCROWL	138	98130 4SCOTT	138	1
98159	4LEROY	0.8969	0.9085	98108 4RICHARD	138	98130 4SCOTT	138	1
98179	4ABBVIL	0.8976	0.926	97513 7GRIMES	345	97554 GRMXF	345	1
98147	4L-642TP	0.8976	0.9519	98410 4LIVON	138	98411 4WILBT	138	1
98160	4MEAUX	0.8992	0.9162	500940 WELLS	230	502410 PMOUTON6	230	1
98160	4MEAUX	0.901	0.9162	500920 WSTFORK6	230	500940 WELLS	230	1
98160	4MEAUX	0.901	0.9162	97324 4JUDICE	138	98160 4MEAUX	138	1
98160	4MEAUX	0.9025	0.9162	97329 4NCROWL	138	98108 4RICHARD	138	1
500330	FLANDR 4	0.9027	0.9497	500940 WELLS	230	502410 PMOUTON6	230	1
98160	4MEAUX	0.9029	0.9162	500940 WELLS	230	500950 WELSRCT6	230	1
98160	4MEAUX	0.903	0.9162	98190 4CECELIA	138	99906 6CECELIA	230	1
98130	4SCOTT	0.9032	0.9367	502410 PMOUTON6	230	502421 LABBE	230	1
98160	4MEAUX	0.9046	0.9162	97329 4NCROWL	138	98130 4SCOTT	138	1
98160	4MEAUX	0.9047	0.9162	98108 4RICHARD	138	98130 4SCOTT	138	1
98160	4MEAUX	0.9048	0.9162	97916 8NELSON	500	98107 8RICHARD	500	1
98130	4SCOTT	0.9049	0.9367	502403 BONIN 6	230	502421 LABBE	230	1
98130	4SCOTT	0.9074	0.9367	97513 7GRIMES	345	97554 GRMXF	345	1
98179	4ABBVIL	0.9081	0.926	97324 4JUDICE	138	98130 4SCOTT	138	1
98190	4CECELIA	0.9084	0.9496	98190 4CECELIA	138	99906 6CECELIA	230	1
98178	4DELCAMB	0.9087	0.9367	97513 7GRIMES	345	97554 GRMXF	345	1
98179	4ABBVIL	0.911	0.926	500920 WSTFORK6	230	500940 WELLS	230	1
98179	4ABBVIL	0.9112	0.926	500940 WELLS	230	502410 PMOUTON6	230	1
500330	FLANDR 4	0.9118	0.9497	502410 PMOUTON6	230	502421 LABBE	230	1
98141	4CHAMPNE	0.9121	0.9532	98141 4CHAMPNE	138	500720 PLAISAN4	138	1
98179	4ABBVIL	0.9124	0.926	97324 4JUDICE	138	98160 4MEAUX	138	1
98179	4ABBVIL	0.9127	0.926	500940 WELLS	230	500950 WELSRCT6	230	1
98179	4ABBVIL	0.913	0.926	98190 4CECELIA	138	99906 6CECELIA	230	1
500400	HABETZ 4	0.9132	0.9656	98108 4RICHARD	138	500400 HABETZ 4	138	1
98179	4ABBVIL	0.9136	0.926	97329 4NCROWL	138	98108 4RICHARD	138	1
500330	FLANDR 4	0.9139	0.9497	502403 BONIN 6	230	502421 LABBE	230	1
500330	FLANDR 4	0.9145	0.9497	502402 ACADIAN6	230	502403 BONIN 6	230	1
98111	4ACADGSU	0.9156	0.9643	98110 4COLADY	138	98111 4ACADGSU	138	1
98112	4SCANLN	0.9158	0.9632	98110 4COLADY	138	98111 4ACADGSU	138	1
98130	4SCOTT	0.9161	0.9367	97329 4NCROWL	138	98108 4RICHARD	138	1
500330	FLANDR 4	0.917	0.9497	502401 FLANDER6	230	502402 ACADIAN6	230	1
98130	4SCOTT	0.917	0.9367	98109 8WELLS	500	98430 8WEBRE	500	1
98130	4SCOTT	0.9184	0.9367	500920 WSTFORK6	230	500940 WELLS	230	1
98130	4SCOTT	0.9187	0.9367	97329 4NCROWL	138	98130 4SCOTT	138	1
98130	4SCOTT	0.919	0.9367	99905 WEBRE 6	230	99906 6CECELIA	230	1
98177	4MORIL	0.9191	0.9465	97513 7GRIMES	345	97554 GRMXF	345	1
500944	6 MORIL	0.9198	0.9466	97513 7GRIMES	345	97554 GRMXF	345	1
98113	4SCOTT2	0.9442	0.9594	99905 WEBRE 6	230	99906 6CECELIA	230	1

**2017 Summer Peak N-1, G-All Criteria Violations (All ALP gen off)
(Webre & Richard Upgrade)**

Bus #	Bus Name	Cont-Volt	Base-Volt	Contingency Description			
98159	4LEROY	0.9429	0.9429	**	Base Case	**	
98190	4CECELIA	0.9483	0.9483	**	Base Case	**	
98111	4ACADGSU	0.8933	0.9636	98110 4COLACDY	138	98111 4ACADGSU	138 1
98112	4SCANLN	0.8934	0.9624	98110 4COLACDY	138	98111 4ACADGSU	138 1
98112	4SCANLN	0.9009	0.9624	98111 4ACADGSU	138	98112 4SCANLN	138 1
98113	4SCOTT2	0.9015	0.9584	98110 4COLACDY	138	98111 4ACADGSU	138 1
98113	4SCOTT2	0.9078	0.9584	98111 4ACADGSU	138	98112 4SCANLN	138 1
98130	4SCOTT	0.9174	0.9563	500940 WELLS	230	502410 PMOUTON6	230 1
98130	4SCOTT	0.9185	0.9563	502410 PMOUTON6	230	502421 LABBE	230 1
98141	4CHAMPNE	0.8995	0.9626	500230 COUGH 4	138	500720 PLAISAN4	138 1
98159	4LEROY	0.9176	0.9429	500190 COCODR 6	230	500880 VILPLT 6	230 1
98159	4LEROY	0.8905	0.9429	500940 WELLS	230	502410 PMOUTON6	230 1
98159	4LEROY	0.8946	0.9429	502410 PMOUTON6	230	502421 LABBE	230 1
98159	4LEROY	0.8969	0.9429	502403 BONIN 6	230	502421 LABBE	230 1
98159	4LEROY	0.9089	0.9429	500942 MEAUX 6	230	500948 SELRSRD6	230 1
98159	4LEROY	0.9094	0.9429	98160 4MEAUX	138	500942 MEAUX 6	230 1
98159	4LEROY	0.9106	0.9429	97513 7GRIMES	345	97554 GRMXF	345 1
98159	4LEROY	0.9149	0.9429	98109 8WELLS	500	98430 8WEBRE	500 1
98159	4LEROY	0.9186	0.9429	500880 VILPLT 6	230	500920 WSTFORK6	230 1
98159	4LEROY	0.9187	0.9429	98158 6RICHARD	230	500948 SELRSRD6	230 1
98160	4MEAUX	0.8984	0.9503	500940 WELLS	230	502410 PMOUTON6	230 1
98160	4MEAUX	0.9024	0.9503	502410 PMOUTON6	230	502421 LABBE	230 1
98160	4MEAUX	0.9047	0.9503	502403 BONIN 6	230	502421 LABBE	230 1
98160	4MEAUX	0.9166	0.9503	500942 MEAUX 6	230	500948 SELRSRD6	230 1
98160	4MEAUX	0.9171	0.9503	98160 4MEAUX	138	500942 MEAUX 6	230 1
98160	4MEAUX	0.9181	0.9503	97513 7GRIMES	345	97554 GRMXF	345 1
98177	4MORIL	0.9127	0.9616	500940 WELLS	230	502410 PMOUTON6	230 1
98177	4MORIL	0.9171	0.9616	502410 PMOUTON6	230	502421 LABBE	230 1
98177	4MORIL	0.9195	0.9616	502403 BONIN 6	230	502421 LABBE	230 1
98178	4DELCAMB	0.908	0.9594	500940 WELLS	230	502410 PMOUTON6	230 1
98178	4DELCAMB	0.9124	0.9594	502410 PMOUTON6	230	502421 LABBE	230 1
98178	4DELCAMB	0.9148	0.9594	502403 BONIN 6	230	502421 LABBE	230 1
98179	4ABBVIL	0.9029	0.9554	500940 WELLS	230	502410 PMOUTON6	230 1
98179	4ABBVIL	0.9072	0.9554	502410 PMOUTON6	230	502421 LABBE	230 1
98179	4ABBVIL	0.9096	0.9554	502403 BONIN 6	230	502421 LABBE	230 1
98184	4DUBOIN	0.9133	0.9609	500940 WELLS	230	502410 PMOUTON6	230 1
98184	4DUBOIN	0.9177	0.9609	502410 PMOUTON6	230	502421 LABBE	230 1
98190	4CECELIA	0.9047	0.9483	500940 WELLS	230	502410 PMOUTON6	230 1
98190	4CECELIA	0.9072	0.9483	502410 PMOUTON6	230	502421 LABBE	230 1
98190	4CECELIA	0.9092	0.9483	502403 BONIN 6	230	502421 LABBE	230 1
98190	4CECELIA	0.9175	0.9483	97513 7GRIMES	345	97554 GRMXF	345 1
500330	FLANDR 4	0.8799	0.9522	500940 WELLS	230	502410 PMOUTON6	230 1
500330	FLANDR 4	0.8855	0.9522	502410 PMOUTON6	230	502421 LABBE	230 1

500330	FLANDR 4	0.8883	0.9522	502403 BONIN 6	230 502421 LABBE	230 1
500330	FLANDR 4	0.9126	0.9522	502402 ACADIAN6	230 502403 BONIN 6	230 1
500400	HABETZ 4	0.912	0.968	98108 4RICHARD	138 500400 HABETZ 4	138 1
500410	HOPKINS4	0.9147	0.9632	500940 WELLS	230 502410 PMOUTON6	230 1
500410	HOPKINS4	0.9192	0.9632	502410 PMOUTON6	230 502421 LABBE	230 1
500720	PLAISAN4	0.8871	0.9836	500230 COUGH 4	138 500720 PLAISAN4	138 1
500942	MEAUX 6	0.8936	0.9531	500940 WELLS	230 502410 PMOUTON6	230 1
500942	MEAUX 6	0.8984	0.9531	502410 PMOUTON6	230 502421 LABBE	230 1
500942	MEAUX 6	0.9008	0.9531	502403 BONIN 6	230 502421 LABBE	230 1
500942	MEAUX 6	0.9166	0.9531	500942 MEAUX 6	230 500948 SELRSRD6	230 1
500944	MORIL 6	0.9048	0.9578	500940 WELLS	230 502410 PMOUTON6	230 1
500944	MORIL 6	0.9092	0.9578	98109 8WELLS	500 98430 8WEBRE	500 1
500944	MORIL 6	0.9093	0.9578	502410 PMOUTON6	230 502421 LABBE	230 1
500944	MORIL 6	0.9115	0.9578	502403 BONIN 6	230 502421 LABBE	230 1
500948	SELRSRD6	0.8927	0.9562	500940 WELLS	230 502410 PMOUTON6	230 1
500948	SELRSRD6	0.8978	0.9562	502410 PMOUTON6	230 502421 LABBE	230 1
500948	SELRSRD6	0.9004	0.9562	502403 BONIN 6	230 502421 LABBE	230 1
502415	BONINBYPS	0.9157	0.9554	500940 WELLS	230 502410 PMOUTON6	230 1
502415	BONINBYPS	0.9171	0.9554	502410 PMOUTON6	230 502421 LABBE	230 1
502415	BONINBYPS	0.9189	0.9554	502403 BONIN 6	230 502421 LABBE	230 1

Entergy Gulf States, Inc. (Louisiana)

Proposed Transmission Reliability Projects

Entergy Transmission Planning Summit

New Orleans, LA


July 13, 2006



Entergy



Proposed 2006-10 EGSi-LA Transmission Reliability Projects



Lawtag-Jennings: 69 kV line Upgrade

Scenario:

- The 69kV transmission system between Jennings and Chlomal substations serves approximately 90 MW of load including the radial transmission system from Lawtag substation. The main "trunk" of these systems is the contiguous segments comprised of Line 13 (Jennings-Compton-Elton), Line 16 (Elton-Tupper-Serpent-Carter), and Line 11 (Carter-Lacassine-Chlomal).
- For the loss of 69kV line Lawtag to Jennings, the Chlomal to lowa line overloads in summer 2007. For the loss of 500kV line Nelson to Richard, both the Lawtag to Jennings line and the Welsh to Lawtag line overload in summer 2007.

Recommended solution:

To reliably serve the load in this area, the following portfolios of projects are proposed:

Phase I (2007):

- Upgrade 4.78 miles of 4/0 CU from Jennings to Lawtag with a conductor rated at least 106 MVA of capacity.
- Install a 15 MVAr capacitor bank at Winn Substation.
- Upgrade about 8 miles of 4/0 CU from Chlomal to lowa with a conductor rated at least 106 MVA of capacity.
- **Estimated cost: \$8 MM**

Phase II (2008):


- Upgrade 12.36 miles of 1/0 ACSR from Chlomal to Lacassine with a conductor rated at least 106MVA of capacity.
- Install a circuit breaker at Lacassine.
- **Estimated cost: \$7.8 MM**

Phase III (2009):

- Upgrade about 6 miles of 4/0 CU from Welsh to Lawtag with a conductor rated at least 106 MVA of capacity.
- Upgrade 3.07 miles of 795 AA from Lake Charles Bulk to Chlomal with a conductor rated at least 133 MVA of capacity.
- **Estimated cost: \$5.4 MM**



JEFFERSON DAVIS



Lafayette-Holiday: Upgrade 69 kV Line

Scenario:

- There is approximately 141 MW of load in the area between Scott and New Iberia. The Lafayette-Holiday-Billeaud line is currently rated at 39 MVA.
- Loss of the Moril 138/69 kV auto or loss of Moril-New Iberia 69 kV line causes an overload on the Lafayette-Holiday line under expected summer 2007 load levels.



Recommended Solution:

- Replace 4.89 miles of 1- 4/0 Cu on the Lafayette-Holiday 69 kV line with a conductor rated at least 106 MVA of capacity.
- Proposed In-Service Date: 2008

Estimated Cost: \$3.9 MM



69 kV Lafayette-Holiday Line Upgrade



Nesser Substation: Install 69kV 15 MVAr capacitor bank

Scenario:

- Nesser is on a long radial tap on the Harelson-Jones Creek 69kV line. Nesser substation is experiencing rapid growth of over 6%/year. Peak loading is over 45 MVA.
- For the loss of Harelson-Nesser tap, voltage at Nesser drops below acceptable level.

Recommended Solution:



- Install a 15 MVAr capacitor bank at the Nesser Substation. The capacitor platform should be expandable for future growth.
- Proposed In-Service Date: 2007

Estimated cost: \$510 k



Entergy

Nesser Substation: Install 69kV 15 MVAr capacitor bank



69 kV Jackson-Marydale Line Upgrade

Scenario:

- The 69 kV transmission system radiating north of Port Hudson substation serves 12 substations.
- Loss of Port Hudson to Sandy Creek to Jackson or Francis to Grant to Port Hudson will overload Jackson-Marydale.

Recommended Solution:


- Replace 5.89 miles of existing 1/0 ACSR conductor with 336 ACSR. Replace all structures and conductor as needed. The reconductor will increase line capacity from 33 MVA to 69 MVA.
- Proposed In-Service Date: 2008

Estimated cost: \$3.6 MM



Entergy

69 kV Jackson-Marydale Line Upgrade



69 kV McManus Capacitor Bank Expansion

Scenario:

- The 69 kV transmission system radiating north of Port Hudson substation serves 12 substations including McManus.
- Loss of Port Hudson to Jackson 69kV line will cause low voltages at multiple substations.


Recommended Solution:

- Install a 6 MVAr capacitor bank at McManus substation for contingencies only. The existing 18 MVAR bank at McManus should be on-line during summer peak.
- Proposed In-Service Date: 2008

Estimated cost: \$510 k



69 kV McManus Capacitor Bank Expansion



Alchem - Monochem: Upgrade 138 kV Line

Scenario:

- Alchem to Monochem 138kV line overloads for the loss of any segment of the 230kV line Vulchlor-Woodstock-Belle Helene-Licar-Polscar-Willow Glen.


Recommended Solution:

- Replace 6.76 miles of 336 ACSR with a conductor rated at least 380 MVA of capacity.
- Proposed In-Service Date: 2009

Estimated cost: \$4.5 MM



Alchem - Monochem: Upgrade 138 kV Line



EGSI-LA Breaker Upgrades

Scenario:

- Based on asymmetrical fault current analysis, various circuit breakers have been identified as underrated.

Recommended Solution:

- Replace the identified underrated circuit breakers with appropriately sized breakers.
(List in order of priority)

- Mossville 138kV # 17970
- Scott 138kV #'s 8820, 17100 & 8825
- Carlyss 69kV #'s 7840 & 8775
- Nelson 138kV # 7990
- Coly 69kV #'s 20375, 20365 & 20370
- Esso 230kV #'s 20080, 20085, 20090
- Nelson 230kV # 27105
- Scott 69kV # 8860

