



Control Number: 35077



Item Number: 132

Addendum StartPage: 0

PUC Project No. 35077

INTERCONNECTION AGREEMENT

Between

Kerrville Public Utility Board

and

LCRA Transmission Services Corporation

March 10, 2009

RECEIVED
2009 JUN 22 PM 3:49
PUBLIC UTILITY BOARD
KERRVILLE, TEXAS

INTERCONNECTION AGREEMENT
BETWEEN
KERRVILLE PUBLIC UTILITY BOARD
AND
LCRA TRANSMISSION SERVICES CORPORATION

DATED: March 10, 2009

**INTERCONNECTION AGREEMENT
BETWEEN
KERRVILLE PUBLIC UTILITY BOARD
AND
LCRA TRANSMISSION SERVICES CORPORATION**

This Interconnection Agreement ("Agreement") is made and entered into this 10th day of March, 2009, by the LCRA Transmission Services Corporation ("LCRA TSC"), a nonprofit affiliated company of the Lower Colorado River Authority ("LCRA"), a conservation and reclamation district of the State of Texas, and Kerrville Public Utility Board ("KPUB") each hereinafter sometimes referred to individually as "Party" or both referred to collectively as the "Parties". In consideration of the mutual covenants set forth herein, the Parties agree as follows:

WITNESSETH

WHEREAS, each Party is the owner and operator of transmission and/or distribution facilities and is engaged in the business of transmitting electric energy to the general public within the Electric Reliability Council of Texas; and

WHEREAS, the Parties desire to interconnect their respective transmission and/or distribution systems in the respects, and under the terms and conditions set forth below.

NOW, THEREFORE, in consideration of the premises and of the mutual covenants and conditions herein set forth, the Parties agree as follows:

ARTICLE I – EFFECTIVE DATE AND TERM

1.1 This Agreement and any subsequent addendum to this Agreement shall become effective on the date of execution by both Parties. Unless otherwise mutually agreed, this Agreement shall remain in effect initially for a period of thirty (30) years from the effective date, and shall continue in effect thereafter for periods of five (5) years each unless canceled after such initial period or any subsequent period either by mutual agreement or by either Party upon at least 36 months written notice to the other party.

ARTICLE II – OBJECTIVE AND SCOPE

2.1 It is the intent of the Parties, by this Agreement, to state the terms and conditions under which the Parties' transmission and/or distribution systems will be interconnected and to identify the facilities and equipment provided by each Party at the points of interconnection between their systems.

2.2 This Agreement shall apply to the ownership, construction, operation and maintenance of those facilities which are specifically identified and described in the Facility Schedules which are attached hereto and incorporated herein.

2.3 This Agreement, including all attached Facility Schedules, constitutes the entire agreement and understanding between the Parties with regard to the interconnection of the facilities of the Parties at the Points of Interconnection expressly provided for in this Agreement. The Parties are not bound by or liable for any statement, representation, promise, inducement, understanding, or undertaking of any kind or nature (whether written or oral) with regard to the subject matter hereof if not set forth or provided for herein. This Agreement replaces all other agreements and undertakings, oral and written, between the Parties with regard to the subject matter hereof. It is expressly acknowledged that the Parties may have other agreements covering other services not expressly provided for herein; such agreements are unaffected by this Agreement.

2.4 If KPUB also takes Transformation Service from LCRA TSC, KPUB shall execute a separate agreement for Transformation Service, which shall be attached hereto.

ARTICLE III – DEFINITIONS

For purposes of this Agreement, the following definitions shall apply:

3.1 Agreement shall mean this Agreement with all schedules and attachments applying hereto, including any schedules and attachments hereafter made and any amendments hereafter made.

3.2 ERCOT shall mean the Electric Reliability Council of Texas, Inc or its successor in function.

3.3 ERCOT Protocols shall mean the documents adopted by ERCOT, and approved by the PUCT, including any attachments or exhibits referenced in the ERCOT Protocols, as amended from time to time, that contain the scheduling, operating, planning, reliability, and settlement (including customer registration) policies, rules, guidelines, procedures, standards, and criteria of ERCOT.

3.4 ERCOT Transmission Operator shall mean the subset of transmission service providers or transmission and/or distribution service providers (TDSPs) that is charged with continuous communication (7 days per week and 24 hours per day basis) with ERCOT operations and carrying out dispatch instructions directly or on behalf of represented TDSPs and carrying out other functions as described in the ERCOT Protocols.

3.5 Facility Schedule(s) shall mean the addendum(s) to this Agreement that describe the agreement on ownership, control, operation, and maintenance responsibilities of the Parties at the Point(s) of Interconnection.

3.6 Good Utility Practice shall mean any of the practices, methods and acts engaged in or approved by a significant portion of the electric utility industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety, and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather to be acceptable practices, methods, or acts generally accepted in the region. Good Utility Practice may include, but not be limited to, conformance with the applicable and consistently applied reliability criteria, standards and operating guides of ERCOT and the NERC, or successor organization(s).

3.7 Independent System Operator shall mean the ERCOT Independent System Operator as defined in the PUCT Substantive Rules.

3.8 NERC shall mean the North American Electric Reliability Corporation or its successor in function.

3.9 NERC Reliability Standards shall mean the mandatory electric reliability standards enforced by NERC.

3.10 Point(s) of Interconnection shall mean the points where the electrical systems of the Parties are connected or may, by the closure of normally open switches, be connected.

3.11 PUCT shall mean the Public Utility Commission of Texas or its successor in function.

ARTICLE IV – ESTABLISHMENT AND TERMINATION OF POINTS OF INTERCONNECTION

4.1 The Parties agree to comply with NERC Reliability Standards as they relate to the interconnection of their facilities at the locations identified and described in the Facility Schedules which are attached hereto and incorporated herein.

4.2 The Parties agree to interconnect their facilities at the locations, and in accordance with the terms and conditions, specified in the attached Facility Schedule(s). All Points of Interconnection shall be specified in Exhibit "A" and the Facility Schedule(s) attached hereto and made a part hereof. The Facility Schedule(s) shall specify the responsibilities of the Parties with respect to ownership, control, operation, and maintenance of the interconnection facilities.

4.3 Unless otherwise provided in a Facility Schedule, each Party shall, at each Point of Interconnection, at its own risk and expense, design, install, or cause the design and installation of the transmission or distribution equipment, apparatus, devices, or facilities on its side of the Point of Interconnection, so as to reasonably minimize the likelihood of voltage and frequency abnormalities, originating in the system of one Party, from affecting or impairing the system of the other Party, or other systems to which the system of such Party is interconnected. The Parties agree that all Points of Interconnection will be established in conformance with

operating guidelines of ERCOT and the ERCOT Protocols, as the same may be amended hereafter. The Parties agree to cause their systems to be constructed in accordance with specifications at least equal to those provided by the National Electrical Safety Code (NESC), approved by the American National Standards Institute (ANSI), in effect at the time of construction. Except as otherwise provided in the Facility Schedules, each Party will be responsible for the equipment and facilities it owns on its side of the Point of Interconnection.

4.4 From time to time, a Point of Interconnection may be added, changed, or deleted from this Agreement as mutually agreed by the Parties and/or as ordered by a regulatory authority having jurisdiction thereof. Any such change, addition, or deletion shall be recorded in Exhibit A and a Facility Schedule in such a way that the numbering of the other Facility Schedules is not changed.

4.5 Subject to regulatory approval, if required, unless mutually agreed, neither Party shall have the right to disconnect from the other Party at any Point of Interconnection specified on Exhibit A and a Facility Schedule, originally attached to this Agreement or added subsequent to the execution of this Agreement, except for reason of a material violation of the terms of this Agreement, for which opportunity to correct such violation was given under Paragraph 15.1 of this Agreement and such violation was not corrected in accordance with said Paragraph 15.1.

4.6 For facilities not specified in the Facility Schedules, or if either Party makes equipment changes or additions to the equipment at a Point of Interconnection, which may affect the operation or performance of the other Party's interconnection facilities, the Parties agree to notify the other Party, in writing, of such changes. Such changes shall be made in accordance with Good Utility Practice, ERCOT requirements, the NESC, other applicable codes, and standards in effect at the time of construction, and coordinated between the Parties.

4.7 Each Party agrees to provide current as-built drawings to the other Party of the facilities owned by that Party at each Point of Interconnection.

4.8 The Parties agree to coordinate and cooperate on assessments of the reliability impacts to the interconnected transmission system for new facilities requesting connection to their distribution or transmission facilities, in accordance with the NERC Reliability Standards.

4.9 KPUB is responsible for reporting annual load data requests to ERCOT as required by the ERCOT Protocols and the Parties agree to coordinate and cooperate on submitting this report.

ARTICLE V - OTHER SERVICES

5.1 This Agreement is applicable only to the interconnection of the facilities of the Parties at the Points of Interconnection and does not obligate either Party to provide, or entitle either Party to receive, any service not expressly provided for herein. Each Party is responsible for making the arrangements necessary to receive any other service that either Party may desire from the other Party or any third party.

5.2 All transmission, transformation, distribution, metering, operations and maintenance, engineering, billing or other miscellaneous services will be provided and charged under agreements separate from this Agreement.

5.3 Each Facility Schedule shall indicate whether transformation and/or metering services apply at each Point of Interconnection. Parties agree that the name and location of the Points of Interconnection in the Exhibit "A" and the Facilities Schedules attached to this Agreement, will be identical to the name used and the location of the corresponding facilities in the Transformation Service Agreement.

ARTICLE VI - SYSTEM OPERATION AND MAINTENANCE

6.1 Unless otherwise provided by the Facility Schedules, each Party shall, at each Point of Interconnection, at its own risk and expense, operate and maintain the equipment, apparatus, devices, or facilities it owns, or hereafter may own, so as to reasonably minimize the likelihood of voltage and frequency abnormalities, originating in the system of one Party, from affecting or impairing the system of the other Party, or other systems to which the Party is interconnected. The Parties agree that all Points of Interconnection will be operated and maintained in conformance with operating guidelines of ERCOT and the ERCOT Protocols, as the same may be amended hereafter.

6.2 Operational responsibility for facilities owned by one Party, but installed in another Party's substation or transmission line will be identified in the Facility Schedule for that particular Point of Interconnection.

6.3 During the term of this Agreement, the Parties will, consistent with maintaining good operating practices, coordinate their operations to maintain continuity of services to their respective customers to the extent practicable. Planned facility maintenance by either Party that will cause a deviation from the normal power and energy flow at a Point of Interconnection will be scheduled at a mutually agreeable time. No changes will be made in the normal operation of a Point of Interconnection without the mutual agreement of the Parties. The Parties will, to the extent necessary to support continuity of operations, coordinate the operation of protective devices on the facilities they operate in the proximity of the Points of Interconnection which might reasonably be expected to affect the operation of facilities on the other Party's system.

6.4 Each Party will provide the reactive requirements for its own system in accordance with the operating guides as established from time to time by ERCOT. Each Party will provide the reactive requirements for its own system so as not to impose a burden on the other system.

6.5 KPUB designates LCRA TSC to perform the functions of an "ERCOT Transmission Operator" on KPUB's behalf as described in the ERCOT Protocols. As the ERCOT Transmission Operator acting on behalf of KPUB, LCRA TSC shall have full authority to perform any necessary load shedding, switching, and other transmission activities that are deemed necessary to reliably maintain the electric system.

6.6 KPUB shall ensure that its operators designated to carry out dispatch instructions from LCRA TSC are properly authorized and trained to comply with all reliability directives issued by LCRA TSC, including shedding firm load, unless such actions would violate safety, equipment, regulatory or statutory requirements. Under these circumstances, KPUB's operators shall immediately inform LCRA TSC of the inability to perform the directive so that LCRA TSC can implement alternate remedial actions.

6.7 During periods of emergency conditions declared by the ERCOT Independent System Operator, or its successor, or as necessary to restore customer service, either Party may operate equipment that is normally operated by the other Party, provided that authorization to do so must first be received from the Party that normally operates the equipment, such authorization not to be unreasonably withheld or delayed. It shall be considered reasonable for the Party that normally operates such equipment to deny such a request by the other Party if the withholding Party will provide such operation within the time frame called for in the circumstances. Such operations by the other Party will be at no cost to the owner or normal operator of the equipment.

6.8 Each Party will determine the operating limits of the facilities that it owns and make such limits known to the Party operating those facilities. The operating Party of those facilities will not exceed those limits without prior approval of the Party owning the facilities.

6.9 KPUB's requirement for under-frequency relaying, as described in the ERCOT Protocols, is accomplished through its participation within the LCRA TSC under-frequency load shed (UFLS) program, however, each Party that owns UFLS equipment must individually comply with ERCOT requirements and NERC Reliability Standards pertaining to UFLS equipment ownership, including but not limited to relay testing and maintenance documentation.

ARTICLE VII - RIGHTS OF ACCESS, EQUIPMENT INSTALLATION, AND REMOVAL

7.1 Each Party shall permit duly authorized representatives and employees of the other Party to enter upon its premises for the purpose of inspecting, testing, repairing, renewing, or exchanging any or all of the equipment owned by such other Party that is located on such premises or for the purpose of performing any work necessary in the performance of this Agreement.

7.2 Each Party grants to the other Party permission to install, maintain, and/or operate, or cause to be installed, maintained, and/or operated, on its premises, the necessary equipment, apparatus, devices, or facilities required for the performance of this Agreement. Any such installation, maintenance, and operation to be performed, except in the case of emergencies, shall be performed only after a schedule of such activity has been submitted and agreed upon by the Parties.

7.3 Any and all equipment, apparatus, devices, or facilities placed or installed, or caused to be placed or installed by one Party on, or in, the premises of the other Party, shall be and remain the property of the Party owning and installing such equipment, apparatus, devices,

or facilities, regardless of the mode and manner of annexation or attachment to real property. Upon the termination of any Point of Interconnection under this Agreement, the Party owning and installing such equipment, apparatus, devices, or facilities on the property of the other Party, shall 1) have the right to sell such equipment, apparatus, devices, or facilities to the other Party if the other Party wishes to purchase such equipment, apparatus, devices, or facilities or 2) to enter the premises of the other Party and, within a reasonable time, remove such equipment, apparatus, devices, or facilities, at no cost to the owner of the premises. If, upon the termination of any Point of Interconnection under this Agreement, equipment of a Party that is installed on the premises of the other Party is either not sold to the other Party or removed by the owning Party within a reasonable time, it shall be considered abandoned by the owning Party and may be disposed of by the other Party in the manner it shall determine appropriate; provided, however, that any net cost incurred by the disposing Party shall be reimbursed by the abandoning party.

7.4 Each Party shall clearly mark their respective equipment, apparatus, devices, or facilities with appropriate ownership identification.

7.5 Either Party may request the other Party to upgrade or modify its terminal facilities at a Point of Interconnection in accordance with the other Party's standard design of equipment. Such request shall not be unreasonably denied.

ARTICLE VIII – METERING AND RECORDS

8.1 All metering equipment required herein shall be selected, installed, tested, operated, and maintained by the Party owning such metering equipment in accordance with Good Utility Practice, applicable ERCOT operating and metering guidelines, and the ERCOT Protocols.

8.2 The Party that does not own the metering equipment shall be permitted to witness any testing, inspection, maintenance, or alteration of such metering equipment owned by the other Party. The owner of such equipment shall give reasonable advance notice of all tests and inspections so that representatives of the other Party may be present. After proper notification to the other Party, the owner may proceed with the scheduled tests or inspections regardless of whether a witness is present.

8.3 If any test or inspection of metering equipment shows that it does not meet the accuracy requirements established by ERCOT operating or metering guidelines, whichever is applicable, the meter or other equipment found to be inaccurate or defective shall be promptly repaired, adjusted, or replaced by the owner. Should metering equipment fail to register, the power and energy delivered and received shall be determined in accordance with ERCOT operating or metering guidelines, and ERCOT Protocols.

ARTICLE IX – COMMUNICATION AND TELEMETERING FACILITIES

9.1 Each Party shall provide, at its own expense, the necessary communication and telemetering facilities needed for the control and operation of its transmission and/or distribution system.

9.2 All communication and telemetering facilities required herein shall be selected, installed, tested, operated, and maintained by the Party owning such equipment in accordance with Good Utility Practice, applicable ERCOT operating and metering guidelines, and the ERCOT Protocols.

9.3 KPUB's requirement (if any) to supply real-time telemetry data to ERCOT, as described in the ERCOT Protocols and referred to in the NERC Reliability Standards, is accomplished through the LCRA TSC as it performs the functions of KPUB's ERCOT Transmission Operator.

ARTICLE X - INDEMNIFICATION

10.1 EACH PARTY SHALL INDEMNIFY, DEFEND, AND SAVE HARMLESS THE OTHER PARTY, ITS DIRECTORS, OFFICERS, AND AGENTS (INCLUDING, BUT NOT LIMITED TO, DIRECTORS, OFFICERS, AND EMPLOYEES OF ITS AFFILIATES AND CONTRACTORS) FROM ANY AND ALL DAMAGES, LOSSES, CLAIMS, INCLUDING CLAIMS AND ACTIONS RELATING TO INJURY TO OR DEATH OF ANY PERSON OR DAMAGE TO PROPERTY, DEMANDS, SUITS, RECOVERIES, COSTS AND EXPENSES, COURT COSTS, ATTORNEY FEES, AND ALL OTHER OBLIGATIONS BY OR TO THIRD PARTIES, ARISING OUT OF OR RESULTING FROM GROSS NEGLIGENCE OR OTHER FAULT IN THE DESIGN, CONSTRUCTION, OR OPERATION OF THEIR RESPECTIVE EQUIPMENT, APPARATUS, DEVICES, OR FACILITIES, DURING THE PERFORMANCE OF THIS AGREEMENT AND TO THE EXTENT PERMITTED BY LAW, EXCEPT IN CASES OF GROSS NEGLIGENCE OR INTENTIONAL WRONGDOING BY THE OTHER PARTY.

ARTICLE XI -NOTICES

11.1 Notices of an administrative nature, including but not limited to a notice of termination, a request for amendment, a change to a Point of Interconnection, or a request for a new Point of Interconnection, shall be forwarded to the designees listed below for each Party and shall be deemed properly given if delivered in writing to the following:

- (a) KERRVILLE PUBLIC UTILITY BOARD
P.O. Box 294999
2250 Memorial Blvd.
Kerrville, TX 78029-4999
- (b) LCRA TRANSMISSION SERVICES CORPORATION
Manager, Transmission Engineering
LCRA
P.O. Box 220
Austin, TX 78767-0220

11.2 The above listed names, titles, and addresses of either Party may be changed upon written notification to the other Party.

ARTICLE XII - SUCCESSORS AND ASSIGNS

12.1 Subject to the provisions of Section 12.2 below, this Agreement shall be binding upon and inure to the benefit of the permitted successors and assigns of the respective Parties.

12.2 Neither Party shall assign its interest in this Agreement in whole or in part without the prior written consent of the other Party. Such consent shall not be unreasonably withheld, provided that neither Party will be required to consent to any assignment which would, in its sole judgment and among other reasons, subject it to additional federal or state regulation, result in the imposition of additional costs of administration which the Party requesting assignments does not agree to reimburse, or in any way diminish the reliability of its system, enlarge its obligations or otherwise create or maintain an unacceptable condition. The respective obligations of the Parties under this Agreement may not be changed, modified, amended, or enlarged, in whole or in part, by reason of the sale, merger, or other business combination of either Party with any other person or entity. Notwithstanding the foregoing, a Party may assign, without the consent of the other Party, its interest in this Agreement, in whole or in part (1) to a successor that has an interest to all or a substantial portion of the Party's transmission and distribution business; or (2) in connection with any financing or financial arrangements.

12.3 The several provisions of this Agreement are not intended to and shall not create rights of any character whatsoever in favor of any persons, corporations, or associations other than the Parties to this Agreement, and the obligations herein assumed are solely for the use and benefit of the Parties to this Agreement.

ARTICLE XIII – GOVERNING LAW AND REGULATION

13.1 This Agreement was executed in the State of Texas and must in all respects be governed by, interpreted, construed, and enforced in accordance with the laws thereof except as to matters exclusively controlled by the Constitution and statutes of the United States of America. This Agreement is subject to all valid applicable federal, state, and local laws, ordinances, rules and regulations of duly constituted regulatory authorities having jurisdiction.

13.2 This Agreement and all obligations hereunder, are expressly conditioned upon obtaining approval or authorization or acceptance for filing by any regulatory body, whose approval, authorization or acceptance for filing is required by law. Both Parties hereby agree to support the approval of this Agreement before such regulatory authority and to provide such documents, information, and opinions as may be reasonably required or requested by either Party in the course of approval proceedings.

13.3 In the event that a regulatory authority having jurisdiction over the Parties orders a change in the terms of this Agreement, the Parties agree to negotiate in good faith a replacement term that will most nearly accomplish the purpose and intent of the original term consistent with the regulatory order. If the Parties cannot reach an agreement over the new term

and if the old term is an essential provision of this Agreement, either Party may elect to terminate this Agreement, by providing notice of such election to the other upon sixty (60) days prior written notice to the other Party. An election to terminate under this provision shall not affect either Party's duty to perform prior to the effective date of termination.

13.4 In the event any part of this Agreement is declared invalid by a court of competent jurisdiction, the remainder of said Agreement shall remain in full force and effect and shall constitute a binding agreement between the Parties provided, however, that if either Party determines, in its sole discretion, that there is a material change in this Agreement by reason of any provision or application being finally determined to be invalid, illegal, or unenforceable, that Party may terminate this Agreement upon sixty (60) days prior written notice to the other Party. An election to terminate under this provision shall not affect either Party's duty to perform prior to the effective date of termination.

ARTICLE XIV – DEFAULT AND FORCE MAJEURE

14.1 Neither Party shall be considered in default with respect to any obligation hereunder, other than the payment of money, if prevented from fulfilling such obligations by reason of any cause beyond its reasonable control, including, but not limited to, outages or interruptions due to weather, accidents, equipment failures or threat of failure, strikes, civil unrest, injunctions or order of governmental authority having jurisdiction. If performance by either Party has been prevented by such event, the affected Party shall promptly and diligently attempt to remove the cause of its failure to perform, except that neither Party shall be obligated to agree to any quick settlement of any strike or labor disturbance, which, in the affected Party's opinion, may be inadvisable or detrimental, or to appeal from any administrative or judicial ruling.

ARTICLE XV - TERMINATION ON DEFAULT

15.1 Should either of the Parties hereto violate any material provisions of this Agreement, the other Party shall give written notice to the violating Party specifying the violation. Upon actual receipt of such notice, the Party shall have one hundred eighty (180) days to correct such violation. In the event such violation of this Agreement is not corrected by the expiration of said one hundred eighty (180) days, this Agreement, subject to the applicable regulations of any jurisdictional regulatory authority, may be terminated by giving no less than sixty (60) days written notice, but no other remedy or remedies, available under the law, for such violation shall be limited in any way because of this provision or the exercise of the right conferred hereunder.

15.2 The failure of a Party to this Agreement to insist, on any occasion, upon strict performance of this Agreement will not be considered to waive the obligations, rights, or duties imposed upon the Parties by this Agreement.

ARTICLE XVI- MISCELLANEOUS PROVISIONS

16.1 Any undertaking by a Party to the other Party under this Agreement shall not constitute the dedication of the electrical system or any portion thereof of that Party to the public or to the other Party, and it is understood and agreed that any such undertaking shall cease upon the termination of this Agreement.

16.2 The several provisions of this Agreement are not intended to and shall not create rights of any character in, nor be enforceable by, parties other than the signatories to this Agreement and their assigns.

16.3 Neither Party shall be liable to the other for any indirect, consequential, incidental, punitive, or exemplary damages.

16.4 This Agreement shall not affect the obligations or rights of either Party with respect to other agreements. Both Parties to this Agreement represent that there is no agreement or other obligation binding upon it, which, as such Party is presently aware, would limit the effectiveness or frustrate the purpose of this Agreement.

16.5 This Agreement may be amended only upon mutual agreement of the Parties, which amendment will not be effective until reduced in writing and executed by the Parties.

16.6 The descriptive headings of the various sections of this Agreement have been inserted for convenience of reference only and are to be afforded no significance in the interpretation or construction of this Agreement.

16.7 The invalidity of one or more phrases, sentences, clauses, Sections or Articles contained in this Agreement shall not affect the validity of the remaining portions of this Agreement so long as the material purposes of this Agreement can be determined and carried out.

16.8 This Agreement will be executed in two or more counterparts, each of which is deemed an original, but all constitute one and the same instrument.

- Remainder of page has intentionally been left blank. -

IN WITNESS WHEREOF, the Parties have caused this Interconnection Agreement between LCRA Transmission Services Corporation and Kerrville Public Utility Board to be executed in two (2) counterparts, each of which shall constitute an original, on the day and year first written above.

KERRVILLE PUBLIC UTILITY BOARD

By: *L. L. McL*
(Name)

Title: General Manager and CEO

Date: 2-27-09

LCRA TRANSMISSION SERVICES CORPORATION

By: *Ray Pfefferkorn*
Ray Pfefferkorn, P.E.

Title: LCRA Transmission Engineering Manager

Date: 3/10/09



EXHIBIT A

FACILITY SCHEDULE NO.	LOCATION OF POINT(S) OF INTERCONNECTION (# of Points)	INTERCONNECTION VOLTAGE (KV)	EFFECTIVE DATE OF INTERCONNECTION
1	Harper Road (2)	138 kV	
2	Hunt (2)	138 kV	
3	Ingram (1)	138 kV	
4	Kerrville Stadium (2)	138 kV	
5	Kerrville Legion (1)	69 kV	
6	Raymond F. Barker (1)	138 kV	
7	Rim Rock (12)	12.5 kV	
8	Kerrville Travis (1)	69 kV	
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			
26			
27			
28			
29			
30			
31			
32			
33			
34			
35			

FACILITY SCHEDULE NO. 1

1. **Name:** Harper Road Substation
2. **Facility Location:** The Harper Road Substation is located at 729 Harper Rd., Kerrville, Kerr County, Texas 78028.
3. **Points of Interconnection:** There are two (2) Points of Interconnection in the Harper Road Substation generally described as:
 - where the 138 kV operating bus terminal connector bolts to the four hole pad on switch 9274.
 - where the 138 kV operating bus terminal connector bolts to the four hole pad on switch 5094.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 138 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformers are located in the PWT-1, T-1 total bay #2 and inside PWT-2 T-2. The bus potential transformers are located on both 12.5 kV operating buses.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - Two (2) circuit switchers CS-9275 and CS-5095, associated disconnect switches 9274 and 5094, bypass switch 9277
 - Two (2) power transformers PWT-1, T-1 and PWT-2, T-2 with associated surge arresters
 - All distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - All distribution circuit breakers/reclosers including jumpers, protective relay packages and foundations
 - All distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, bus potential transformers and associated cabling
 - Control house (10' X 20')
 - Two (2) station service SS-1 and SS-2
 - Two(2) load management systems LM-1 and LM-2


LCRA TSC owns:

The Harper Road Substation including, but not limited to, the following items:

- Two (2) 138 kV dead-end structures, foundations, insulators and jumpers
- 138 kV operating bus including structures, insulators, foundations and jumpers
- Two (2) 138 kV circuit breakers 9250 and 9260 including foundation, jumpers and protective relay packages
- Eight (8) 138 kV switches 9249, 9251, 9253, 9256, 9259, 9261, 9263 and 9269
- One (1) motor operated switch 9258
- Three (3) 138 kV surge arresters SA-8, SA-18 and SA-19
- Two (2) wave traps and tuners WT-1 and WT-2
- Two (2) coupling capacitors CC-1 and CC-2
- One (1) 138 kV bus potential transformer PT-2
- Two (2) metering current transformers CT-1 and CT-2
- Control house (24' X 39') and battery bank

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement"
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

HARPER ROAD ONE-LINE DIAGRAM



HARPER ROAD SUBSTATION

FACILITY SCHEDULE NO. 2

1. **Name:** Hunt Substation
2. **Facility Location:** The Hunt Substation is located at 300 River Road West, Hunt, Kerr County, Texas 78024.
3. **Points of Interconnection:** There are two (2) Points of Interconnection in the Hunt Substation generally described as:
 - where the jumper from the 138 kV operating bus bolts to the four hole pad on switch 1954.
 - where the jumper from the 138 kV transfer bus bolts to the four hole pad on switch 1953.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 138 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformer is located inside PWT-1, T-1. The bus potential transformer is located on the 12.5 kV operating bus.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - One (1) circuit switcher CS-1955 and associated disconnect switches 1953 and 1954
 - One (1) power transformer PWT-1, T-1 with associated surge arresters
 - All distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - All distribution circuit breakers/reclosers including jumpers, protective relay packages and foundations
 - All distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, bus potential transformer and associated cabling
 - Station Service


LCRA TSC owns:

The Hunt Substation including, but not limited to, the following items:

- 138 kV operating and transfer bus including structures, insulators, foundations and jumpers
- One (1) circuit switcher CS-2455 and associated disconnect switch 2456
- One (1) current transformer CT-4
- One (1) single phase current transformer CT-5
- One (1) 138 kV bus potential transformer PT-1
- One (1) 138 kV surge arrester SA-1
- One (1) 69 kV capacitor bank potential transformer PT-4
- One (1) capacitor bank CP-1
- Control house and battery bank
- Underfrequency relay panel

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

HUNT ONE-LINE DIAGRAM



HUNT SUBSTATION
THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
FOR A COMPLETE ONE-LINE DIAGRAM OF THIS
SUBSTATION, REFER TO DRAWINGS 144-E-0012

FACILITY SCHEDULE NO. 3

1. **Name:** Ingram Substation
2. **Facility Location:** The Ingram Substation is located at 3482 Junction Hwy., Ingram, Kerr County, Texas 78025.
3. **Points of Interconnection:** There are one (1) Point of Interconnection in the Ingram Substation generally described as:
 - where the jumper from switch 12994 bolts to the four hole pad on circuit switcher CS-12995.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 138 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformers are located in the total bay and in each distribution bay. The bus potential transformer is located on the 12.5 kV operating bus.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - One (1) circuit switcher CS-12995
 - One (1) power transformer PWT-1, T-1 with associated surge arresters
 - Two (2) distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - Two (2) distribution circuit breakers/reclosers IN-20 and IN-40 including jumpers and protective relay packages
 - All distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, bus potential transformer and associated cabling
 - Station Service


LCRA TSC owns:

The Ingram Substation including, but not limited to, the following items:

- 138 kV dead-end structures, foundations, insulators and jumpers
- Two (2) 138 kV surge arresters SA-9 and SA-10
- Two (2) CCVTs, CCVT-1 and CCVT-2
- Two (2) wave traps and line tuners WT-1 and WT-2
- Seven (7) 138 kV switches 12989, 12991, 12993, 12994, 12999, 13001 and 13003
- Two (2) 138 kV circuit breakers 12990 and 13000 including foundations, jumpers and protective relay packages
- One (1) 138 kV current transformer CT-9
- Five (5) metering current transformers CT-2, CT-3, CT-4 CT-5 and CT-6
- Control house and battery

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

INGRAM ONE-LINE DIAGRAM



INGRAM SUBSTATION

FACILITY SCHEDULE NO. 4

1. **Name:** Kerrville Stadium Substation
2. **Facility Location:** The Kerrville Stadium Substation is located at 400 Holdsworth Dr., Kerrville, Kerr County, Texas 78028.
3. **Points of Interconnection:** There are two (2) Points of Interconnection in the Kerrville Stadium Substation generally described as:
 - where the jumper from the 138 kV operating bus bolts to the four hole pad on switch 3689.
 - where the jumper from the 138 kV transfer bus bolts to the four hole pad on switch 3693.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 138 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformer for PWT-2, T-3 is located in the PWT-2, T-3 total bay. The metering current transformer for PWT-1, T-2 is located in the PWT-1, T-2 total bay. The bus potential transformers are located on 12.5 kV operating bus #1 and 12.5 kV operating bus #2.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - 138 kV lower yard bay #3 including foundations; structures; 138 kV switches 3689, 3691 and 3693; jumpers and insulators
 - Two (2) circuit switchers CS-2845 and CS-2855 with associated disconnect switches 2844 and 2854
 - Two (2) power transformers PWT-1, T-2 and PWT-2, T-3 with associated surge arresters
 - One (1) 138 kV current transformer CT-4
 - All distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - All distribution circuit breakers/reclosers including jumpers, protective relay packages and foundations
 - All distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer buses #1 and #2, bus potential transformers and associated cabling

- ♦ Two (2) station service SS-1 and SS-2


LCRA TSC owns:

The Kerrville Stadium Substation including, but not limited to, the following items:

- ♦ 138 kV operating and transfer bus including structures, insulators, foundations and jumpers (except for KPUB ownership in lower yard bay #3)
- ♦ One (1) 138 kV bus potential transformer PT-4
- ♦ Two (2) metering current transformers CT-2 and CT-3
- ♦ Control house
- ♦ Battery house with batteries
- ♦ Station service SS-4 (not shown on one-line)
- ♦ Underfrequency relay panel

- 10. Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
- 11. Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
- 12. Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

KERRVILLE STADIUM ONE-LINE DIAGRAM



KERRVILLE STADIUM SUBSTATION
THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
THESE CONNECTIONS ARE FOR INFORMATION ONLY
SUBSTATION, REFER TO DRAWING S147-E-0089

FACILITY SCHEDULE NO. 5

1. **Name:** Kerrville Legion Substation
2. **Facility Location:** The Kerrville Legion Substation is located at 108 N. Peterson Farm Rd., Kerrville, Kerr County, Texas 78028.
3. **Points of Interconnection:** There is one (1) Point of Interconnection in the Kerrville Legion Substation generally described as:
 - where the jumper from the 69 kV operating bus dead end insulator bolts to the four hole pad on switch 424.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 69 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformer is located in the PWT-1, T-1; 12.5 kV transformer bus. The bus potential transformer is located on the 12.5 kV operating bus.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - One (1) circuit switcher CS-425 and associated disconnect switch 424
 - One (1) power transformer PWT-1, T-1 with associated surge arresters
 - Two (2) transformer bus towers including foundations, insulators and jumpers
 - All distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - All distribution circuit breakers/reclosers including jumpers, protective relay packages and foundations
 - All distribution and total bays including structures, insulators, disconnect switches, surge arresters, 12.5 kV bus, bus potential transformer and associated cabling
 - Station service SS-2


LCRA TSC owns:

The Kerrville Legion Substation including, but not limited to, the following items:

- One (1) 69 kV box structure including foundations, jumpers, insulators and surge arresters
- Two (2) 69 kV circuit breakers 370 and 410 including foundation, jumpers and protective relay packages
- Two (2) 69 kV surge arresters SA-8 and SA-9
- Six (6) 69 kV switches 369, 371, 373, 409, 411 and 413
- 69 kV bus including structures, insulators, foundations and jumpers
- One (1) 69 kV bus potential transformer PT-1
- One (1) metering current transformer CT-1
- Control house and battery
- Station service SS-1

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

KERRVILLE LEGION ONE-LINE DIAGRAM



KERRVILLE LEGION SUBSTATION

THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
FOR A COMPLETE ONE-LINE DIAGRAM OF THIS
SUBSTATION, REFER TO DRAWING S-51E-0001

FACILITY SCHEDULE NO. 6

1. **Name:** Raymond F. Barker Substation
2. **Facility Location:** The Raymond F. Barker Substation is located at 194 Willow Bend Dr. N., Center Point, Kerr County, Texas 78010.
3. **Points of Interconnection:** There is one (1) Point of Interconnection in the Raymond F. Barker Substation generally described as:
 - where the 138 kV transformer bus #1 jumper bolts to the four hole pad on switch 11284.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 138 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformers are located in the PWT-1, T-1 total bay and in each distribution bay. The bus potential transformer is located on the 12.5 kV operating bus.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - One (1) circuit switcher CS-11285 and associated disconnect switch 11284
 - One (1) power transformer PWT-1, T-1 with associated surge arresters
 - One (1) current transformer CT-7
 - Two (2) distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - Two (2) distribution circuit breakers/reclosers RB-20 and RB-40 including jumpers and protective relay packages
 - Four (4) distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, bus potential transformer and associated cabling
 - Three (3) single phase voltage regulators REG-1 and associated disconnect and bypass switches
 - One (1) load management system LM-1
 - Station Service SS-1


LCRA TSC owns:

The Raymond F. Barker Substation including, but not limited to, the following items:

- 138 kV operating bus #1 and #2 including structures, insulators, foundations and jumpers
- 138 kV transformer bus #1 including structures, insulators, foundations and jumpers
- Two (2) 138 kV circuit breakers 11280 and 11290 including foundation, jumpers and protective relay packages
- Six (6) 138 kV switches 11271, 11272, 11279, 11281, 11289 and 11291
- Four (4) metering current transformers CT-1, CT-2, CT-3 and CT-4
- Control house and battery
- Station Service SS-2 (not shown on one-line)

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

RAYMOND F. BARKER ONE-LINE DIAGRAM



RAYMOND F. BARKER SUBSTATION

THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
FOR A COMPLETE ONE-LINE DIAGRAM OF THIS
SUBSTATION, REFER TO DRAWING S483-E-0001.

FACILITY SCHEDULE NO. 7

1. **Name:** Rim Rock Substation
2. **Facility Location:** The Rim Rock Substation is located at 190 Catalina Ct. S., Kerrville, Kerr County, Texas 78028.
3. **Points of Interconnection:** There are nine (12) Points of Interconnection in the Rim Rock Substation generally described as:
 - where the incoming distribution line connects to the tubular bus between switches RR-11 and RR-13 at breaker RR-10.
 - where the jumper from breaker RR-10, passing through CT-2, connects to the 4 hole pad on switch RR-9.
 - where the jumper from breaker RR-10 connects to the 4 hole pad on switch RR-11.
 - where the incoming distribution line connects to the tubular bus between switches RR-41 and RR-43 at breaker RR-40.
 - where the jumper from breaker RR-40, passing through CT-4, connects to the 4 hole pad on switch RR-39.
 - where the jumper from breaker RR-40 connects to the 4 hole pad on switch RR-41.
 - where the incoming distribution line connects to the tubular bus between switches RR-51 and RR-53 at breaker RR-50.
 - where the jumper from breaker RR-50, passing through CT-5, connects to the 4 hole pad on switch RR-49.
 - where the jumper from breaker RR-50 connects to the 4 hole pad on switch RR-51.
 - where the incoming distribution line connects to the tubular bus between switches RR-101 and RR-103 at breaker RR-60.
 - where the jumper from breaker RR-60, passing through CT-8, connects to the 4 hole pad on switch RR-99.
 - where the jumper from breaker RR-60 connects to the 4 hole pad on switch RR-101.
4. **Transformation Services Provided by LCRA TSC:** Yes
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 12.5 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformers are located in PWT-1, T-1 total bay; inside PWT-2, T-2 and in each distribution bay. The bus potential transformers are on the 12.5 kV operating buses.

8. **One Line Diagram Attached:** Yes

9. **Description of Facilities Owned by Each Party:**

KPUB owns:

- Four (4) distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
- Four (4) distribution circuit breakers/reclosers RR-10, RR-40, RR-50, RR-60 including jumpers and protective relay packages
- Four (4) distribution circuit breaker foundations in bays 1,4, 5 and 9

LCRA TSC owns:


The Rim Rock Substation is leased from the University of Texas.

- Two (2) circuit switchers CS-8855 and CS-8865 with associated bypass switches 8857 and 8867
- Two (2) power transformers T-1 and T-2 and associated surge arresters
- All distribution and total bays including A-frames, trusses, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, metering current transformers, bus potential transformers and associated cabling
- Two (2) station service SS-1 and SS-2
- Control house and battery

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".

11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".

12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.



THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
FOR A COMPLETE ONE-LINE DIAGRAM OF THIS
SUBSTATION, REFER TO DRAWING S406-E-00003.

FACILITY SCHEDULE NO. 8

1. **Name:** Kerrville Travis Substation
2. **Facility Location:** The Kerrville Travis Substation is located at 718 Travis St., Kerrville, Kerr County, Texas 78028.
3. **Points of Interconnection:** There is one (1) Point of Interconnection in the Kerrville Travis Substation generally described as:
 - where the jumper from the 69 kV operating bus dead end insulator bolts to the four hole pad on circuit switcher CS-665.
4. **Transformation Services Provided by LCRA TSC:** No
5. **Metering Services Provided by LCRA TSC:** Yes
6. **Delivery Voltage:** 69 kV
7. **Metered Voltage and Location:** The metering voltage is 12.5 kV. The metering current transformer is located in the PWT-1, T-1; 12.5 kV transformer bus. The bus potential transformer is located on the 12.5 kV operating bus.
8. **One Line Diagram Attached:** Yes
9. **Description of Facilities Owned by Each Party:**

KPUB owns:

 - One (1) circuit switcher CS-665
 - One (1) power transformer PWT-1, T-1 with associated surge arresters
 - All distribution circuits including dead end insulators that attach to the dead end structure, conductors, and hardware
 - All distribution circuit breakers/reclosers including jumpers, protective relay packages and foundations
 - All distribution and total bays including box structure, insulators, disconnect switches, surge arresters, 12.5 kV operating and transfer bus, bus potential transformer and associated cabling
 - Station Service
 - Control house and battery


LCRA TSC owns:

The Kerrville Travis Substation including, but not limited to, the following items:

- 69 kV box structures, foundations, insulators and jumpers
- 69 kV operating bus, located on 69 kV box structure, including insulators and jumpers
- Three (3) 69 kV switches 626, 694 and 1033
- One (1) 69 kV surge arrester SA-1
- One (1) Metering current transformer CT-1
- Underfrequency relay panel

10. **Operational Responsibilities of Each Party:** Each Party will be responsible for the operation of the equipment it owns. The responsibility for the operation of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
11. **Maintenance Responsibilities of Each Party:** Each Party will be fully responsible for the maintenance of the equipment it owns. The responsibility for the maintenance of leased equipment will be according to the "Facilities and Premises Lease and Operating Agreement".
12. **Other Terms and Conditions:** KPUB and LCRA TSC are to share access to the substation and control house.

KERRVILLE TRAVIS ONE-LINE DIAGRAM



KERRVILLE TRAVIS SUBSTATION
 THIS IS NOT A COMPLETE ONE-LINE DIAGRAM
 FOR A COMPLETE ONE-LINE DIAGRAM OF THIS
 SUBSTATION, REFER TO DRAWING S148-E-0028