



Filing Receipt

Filing Date - 2024-05-29 02:14:23 PM

Control Number - 35077

Item Number - 1842



Thomas J. Yamin, P.E.
Director
Regulatory Transmission and Planning

May 29, 2024

Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, TX 78711-3326

**RE: Subject: Project No. 35077–Oncor Electric Delivery Company’s Transmission
Contract Filing Pursuant to Subst. Rule 25.195(h)**

Find attached the Third Amendment to the Standard Generation Interconnection Agreement between Oncor Electric Delivery Company LLC and BT Connolly Storage, LLC (Denton Creek Switch) (23INR0403), dated May 20, 2024, for filing at the Public Utility Commission pursuant to Substantive Rule 25.195(h).

Oncor Electric Delivery has redacted station location information located in Exhibit C which contains CEII information.

Sincerely,

A handwritten signature in black ink, reading "Thomas J. Yamin".

Thomas J. Yamin, P.E.
Director

**ERCOT STANDARD GENERATION
INTERCONNECTION AGREEMENT
BT CONNOLLY STORAGE, LLC**

**GINR 23INR0403
Connolly Storage**

Amendment No. 3

AMENDMENT NO. 3

ERCOT STANDARD GENERATION INTERCONNECTION AGREEMENT

23INR0403 - BT CONNOLLY STORAGE, LLC (DENTON CREEK SWITCH)


This Amendment No. 3 to the ERCOT Standard Generation Interconnection Agreement dated as of February 27, 2023 ("Agreement") by and between Oncor Electric Delivery Company, LLC ("Transmission Service Provider"), and Power Resources, LTD ("Generator"), is made this 20 day of May 2024.

In consideration of the mutual promises and undertakings herein set forth and other good and valuable consideration, the parties hereby agree to amend the Agreement as follows:

1. Item 2 of Exhibit "C" attached to the Agreement are deleted in their entirety, and the Item 2 of Exhibit "C" attached to this Amendment are hereby added to the Agreement in lieu thereof.
2. Except as provided above, the Agreement will remain in effect in accordance with its terms.

IN WITNESS WHEREOF, the Parties have caused this Amendment to be signed by their duly authorized representatives, in duplicate originals, each of which shall constitute and be an original effective amendment to the Agreement.

ONCOR ELECTRIC DELIVERY COMPANY LLC


By: 
DocuSigned by:
1A4F380A21AA462...

Name: Robert Holt

Title: Director, Transmission Services

Date: 5/20/2024 | 5:53:59 PM PDT

BT CONNOLLY STORAGE, LLC

By: 
DocuSigned by:
534DC81F60U44F1...

Name: JT Boone

Title: President

Date: 5/20/2024 | 12:14:53 PM PDT

Exhibit "C"

Interconnection Details

1. Name: BT Connolly Storage, LLC
2. Point of Interconnection location: The Point of Interconnection is located in Wise County, Texas, at the Denton Creek Switch within the between the Allison to Flatwood section ([REDACTED]) of the Bennett Road Switch to Krum Tap Switch 138kV line. Specifically, the Point of Interconnection shall be defined as the points where the Generator shall connect at a delivery voltage of 138 kV with the change of ownership of facilities to be designated at the points where TSP's jumpers, connected to TSP's 138 kV switch, connect to the Generator-owned 4 hole pad connections at the end of Generator's bus, located near the common fence separating TSP's Denton Creek Switch from the Generator's 138 kV Plant Switchyard. TSP will install and own the jumpers from TSP's switch to the Generator-owned 4 hole pad connections. The Generator Project will be located approximately 9.8 miles east southeast of Decatur in Wise County, Texas. (See attached one-line diagram.)