



## **Filing Receipt**

**Filing Date - 2024-08-23 03:51:35 PM**

**Control Number - 35077**

**Item Number - 1910**



Thomas J. Yamin, P.E.  
Director  
Regulatory Transmission and Planning

August 23, 2024

Filing Clerk  
Public Utility Commission of Texas  
1701 N. Congress Avenue  
P.O. Box 13326  
Austin, TX 78711-3326

**RE: Subject: Project No. 35077—Oncor Electric Delivery Company's Transmission  
Contract Filing Pursuant to Subst. Rule 25.195(h)**

Find attached the First Amendment to the Standard Generation Interconnection Agreement between Oncor Electric Delivery Company LLC and Blevins Solar, LLC (23INR0118 and 23INR0119), dated July 31, 2024, for filing at the Public Utility Commission pursuant to Substantive Rule 25.195(h).

Oncor Electric Delivery has redacted certain financial information located in Exhibit D.

Sincerely,

A handwritten signature in black ink that reads "Thomas J. Yamin". The signature is written in a cursive, flowing style.

Thomas J. Yamin, P.E.  
Director

**AMENDMENT NO. 1 TO  
ERCOT STANDARD GENERATION INTERCONNECTION AGREEMENT  
BLEVINS SOLAR, LLC  
GINR 23INR0118 and 23INR0119**

This Amendment No. 1 (“Amendment”) to the ERCOT Standard Generation Interconnection Agreement by and between Oncor Electric Delivery Company LLC (“Transmission Service Provider” or “TSP”) and Blevins Solar, LLC (“Generator”), dated June 17, 2023 (“Agreement”) is made and entered into this 31 day of July, 2024 between Transmission Service Provider and Generator, each hereinafter sometimes referred to individually as a “Party” or both referred to collectively as the “Parties.”

In consideration of the mutual promises and undertaking herein set forth and other good and valuable consideration, the Parties hereby agree to amend the Agreement as follows:

1. This Amendment shall be effective upon execution by both Parties.
2. Sections 4 and 5 of Exhibit “C” attached to the Agreement are hereby deleted and replaced with the following Sections 4 and 5.

**4. Number and size of Generating Units:**

23INR0118 - Solar: Seventy-two (72) Sungrow SG4400UD inverters each rated at 4.4 MVA with a total gross capacity of 316.8 MVA, dispatched at 275 MW, measured at the generator terminals, and 271.58 MW, measured at the 34.5 kV bus.

23INR0119 - Battery: Fifty-six (56) Sungrow SC4000D inverters each rated at 4 MVA with a total gross capacity of 220 MVA, dispatched at 183 MW, measured at the generator terminals, and 181.33 MW, measured at the 34.5 kV bus.

The Parties will amend this Exhibit “C” as necessary to reflect any changes Generator makes to the number and size of generating units.

**5. Type of Generating Unit:**

23INR0118 - Solar: Sungrow SG4400UD  
23INR0119 - Battery: Sungrow SC4000D

The Parties will amend this Exhibit “C” as necessary to reflect any changes Generator makes to the manufacturer, model, or type of generating units.


3. Exhibit “D” to the Agreement is hereby deleted and replaced with the Exhibit “D” attached to this Amendment.

4. Except as otherwise expressly provided for herein, the Agreement shall continue in full force and effect in accordance with its terms.

IN WITNESS WHEREOF, the Parties have caused this Amendment No. 1 to be signed by their respective duly authorized representatives

ONCOR ELECTRIC DELIVERY COMPANY  
LLC

BLEVINS SOLAR, LLC

BY:   
DocuSigned by:  
1A4F386A21AA402...  
Signature

BY:   
Signed by:  
4B09EB68046841D...  
Signature

NAME: Robert Holt

NAME: Jeff Ringblom

TITLE: Director, Transmission Services

TITLE: Chief Development Officer

DATE: 7/31/2024 | 6:49:12 AM PDT

DATE: 7/31/2024 | 6:48:24 AM PDT

**Exhibit "D"**  
**Notice and Electronic Funds Transfer Information of the**  
**ERCOT Standard Generation Interconnection Agreement**

(a) Dispatch Center Communications:

If to Transmission Service Provider:	If to Generator (see the provisions of Exhibit C, section 12(b))
Fax number at TSP control center: (214) 743-6884	Off Premise Exchange Number for Generator Control Center:
	Off Premise Exchange Email for Generator Control Center:
24/7 Telephone at TSP control center: (214) 743-6897	Other Generator Control Center 24/7 Number: 610-880-7493
	Other Generator Control Center Email: mbsoperators@millerbros.us

(b) Notices of an administrative nature:

If to Transmission Service Provider:	If to Generator:
Oncor Electric Delivery Company LLC	Blevins Solar, LLC
Attn: Robert Holt	Attn: Richard McMichael
777 Main Street, Suite 707	8400 Normandale Lake Blvd, Suite 1200
Ft. Worth, Texas 76102	Bloomington, MN 55437
Phone: (817)-215-5812	Phone: (561)-339-1395
E-mail: Robert.Holt@oncor.com	E-mail: <a href="mailto:rncmichael@nationalgridrenewables.com">rncmichael@nationalgridrenewables.com</a>

(c) Notice for statement and billing purposes:

If to: Transmission Service Provider	If to Generator:
Oncor Electric Delivery Company LLC	Blevins Solar, LLC
Attn: Robert Holt	Attn: Jake Schroeder
777 Main Street, Suite 707	8400 Normandale Lake Blvd, Suite 1200
Ft. Worth, Texas 76102	Bloomington, MN 55437
Phone: (817)-215-5812	Phone: (952)-988-9000
E-mail: Robert.Holt@oncor.com	E-mail: <a href="mailto:accounting@nationalgridrenewables.com">accounting@nationalgridrenewables.com</a>

(d) Information concerning Electronic Funds Transfers:

If to: Transmission Service Provider	If to Generator:
JPMorgan Chase Bank	Wells Fargo Bank N.A.
Houston, Texas	
ABA No. [REDACTED]	ABA No. [REDACTED]
For credit to:	For credit to: Blevins Solar, LLC
Oncor Electric Delivery Company LLC	
Account No. [REDACTED]	Account No. [REDACTED]