



Filing Receipt

Filing Date - 2025-03-25 09:56:49 AM

Control Number - 35077

Item Number - 2096



Thomas J. Yamin, P.E.
Director
Regulatory Transmission and Planning

March 25, 2025

Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, TX 78711-3326

**RE: Subject: Project No. 35077–Oncor Electric Delivery Company’s Transmission
Contract Filing Pursuant to Subst. Rule 25.195(h)**

Find attached the Second Amendment to the Standard Generation Interconnection Agreement between Oncor Electric Delivery Company LLC and Limewood Bell Renewables, LLC (Limewood Solar) (23INR0249), dated March 22, 2025 for filing at the Public Utility Commission pursuant to Substantive Rule 25.195(h).

Sincerely,

A handwritten signature in black ink that reads "Thomas J. Yamin". The signature is written in a cursive, flowing style.

Thomas J. Yamin, P.E.
Director

**AMENDMENT NO. 2 TO
ERCOT STANDARD GENERATION INTERCONNECTION AGREEMENT
LIMEWOOD BELL RENEWABLES, LLC – GINR 23INR0249
Limewood Solar**

This Amendment No. 2 (“Amendment”) to the ERCOT Standard Generation Interconnection Agreement by and between Oncor Electric Delivery Company LLC (“Transmission Service Provider” or “TSP”) and Limewood Bell Renewables, LLC (“Generator”), dated February 22, 2023 (“Agreement”) is made and entered into this 22 day of March, 2025 between Transmission Service Provider and Generator, each hereinafter sometimes referred to individually as a “Party” or both referred to collectively as the “Parties.”

In consideration of the mutual promises and undertaking herein set forth and other good and valuable consideration, the Parties hereby agree to amend the Agreement as follows:

1. This Amendment shall be effective upon execution by both Parties.
2. Sections 4 and 5 of Exhibit “C” to the Agreement are hereby deleted and replaced with the following Sections 4 and 5.

4. Number and size of Generating Units:

Fifty-two (52) Sungrow SG4400UD-MV-US inverters each rated at 4.4 MVA with a total gross capacity of 228.8 MVA. The plant will be dispatched at 206.15 MW, measured at the generator terminals, and 204.6 MW, measured at the 34.5 kV bus.

The Parties will amend this Exhibit “C” as necessary to reflect any changes Generator makes to the number and size of generating units.

5. Type of Generating Unit:

Sungrow SG4400UD-MV-US

The Parties will amend this Exhibit "C" as necessary to reflect any changes Generator makes to the manufacturer, model, or type of generating units.

3. Except as otherwise expressly provided for herein, the Agreement shall continue in full force and effect in accordance with its terms.

IN WITNESS WHEREOF, the Parties have caused this Amendment No. 2 to be signed by their respective duly authorized representatives

ONCOR ELECTRIC DELIVERY COMPANY
LLC

LIMEWOOD BELL RENEWABLES, LLC

BY: ^{DocuSigned by:}
Robert Holt
1A4F398A21AA462...
Signature

BY: ^{Signed by:}
Jon Saxon
5B20D70782454E9...
Signature

NAME: Robert Holt

NAME: Jon Saxon

TITLE: Director, Transmission Services

TITLE: Chief Development Officer*

DATE: 3/22/2025 | 10:42:57 AM PDT

DATE: 3/22/2025 | 9:49:07 AM PDT

***of Pine Gate Renewables, LLC, Manager of Pine Gate Development, LLC, Manager of FP 2021 Dev Holdco, LLC, Manager of Limewood Bell Renewables, LLC**