



## **Filing Receipt**

**Filed Date - 2025-08-01 01:48:41 PM**

**Control Number - 35077**

**Item Number - 2211**



Thomas J. Yamin, P.E.  
Director  
Regulatory Transmission and Planning

August 1, 2025

Filing Clerk  
Public Utility Commission of Texas  
1701 N. Congress Avenue  
P.O. Box 13326  
Austin, TX 78711-3326

**RE: Subject: Project No. 35077—Oncor Electric Delivery Company's Transmission  
Contract Filing Pursuant to Subst. Rule 25.195(h)**

Find attached the Third Amendment to the Standard Generation Interconnection Agreement between Oncor Electric Delivery Company LLC and Gaia Solar, LLC (24INR0141 & 24INR0140), dated July 25, 2025, for filing at the Public Utility Commission pursuant to Substantive Rule 25.195(h).

Sincerely,

A handwritten signature in black ink that reads "Thomas J. Yamin".

Thomas J. Yamin, P.E.  
Director

## AMENDMENT NO. 3 TO ERCOT STANDARD GENERATION INTERCONNECTION AGREEMENT

This Amendment No. 3 to the ERCOT Standard Generation Interconnection Agreement dated as of November 8, 2023 (“Agreement”) by and between Oncor Electric Delivery Company, LLC (“Transmission Service Provider”), and **Gaia Solar, LLC** (“Generator”), is made this 25 day of July 2025.


In consideration of the mutual promises and undertakings herein set forth and other good and valuable consideration, the parties hereby agree to amend the Agreement as follows:

The Exhibit “C” Interconnection Details section 4 and 5 to the Agreement are deleted in their entirety and replaced with the Exhibit “C” Interconnection Details section 4 and 5 attached hereto and made a part hereof.

Except as provided above, the Agreement will remain in effect in accordance with its terms.

IN WITNESS WHEREOF, the Parties have caused this Amendment No. 3 to be signed by their duly authorized representatives, in duplicate originals, each of which shall constitute and be an original effective amendment to the Agreement.

ONCOR ELECTRIC DELIVERY COMPANY  
LLC

By:   
1A4F388A21AA462...

Name: Robert Holt

Title: Director, Transmission Services

Date: 7/25/2025 | 6:20:09 PM PDT

GAIA SOLAR, LLC

By:   
5480CFBA2E4C480...

Name: Nathan Krieger

Title: SVP - Commercial

Date: 7/25/2025 | 9:42:40 AM PDT

## **Exhibit “C” Interconnection Details**

4. Number and size of Generating Units:

Solar – thirty-five (35) inverters rated at 4.0 MVA each, for a total gross capacity of 154 MVA. The net output for the Plant will be 144.02 MW, measured at the 34.5kV bus (145.8 MW at the generator terminals)

BESS – twenty-five (25) inverters rated at 3.61 MVA each, for a total gross capacity of 90.25 MVA. The net output for the Plant will be +78.81/-74.8 MW, measured at the 34.5kV bus (+79.35/-74.36 MW at the generator terminals)

The Parties will amend this Exhibit “C” as necessary to reflect any changes Generator makes to the number and size of generating units.

5. Type of Generating Unit:

Solar – Sungrow SG4400 inverters

BESS – SMA 3950UP-US inverters

The Parties will amend this Exhibit “C” as necessary to reflect any changes Generator makes to the manufacturer, model, or type of generating units.