

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
1773	1474	PSHIL	1602	1006	32.36
1774	2	BKBNT	1832	190	32.21
1775	763	MRSES	4005	756	32.18
1776	604	CRLJL	1504	883	32.16
1777	2129	ALNTH	2853	3398	32.12
1778	1605	HORNE	1981	1579	32.11
1779	1346	KNEDL	6322	3505	32.09
1780	1699	KILEN	1204	1497	32.07
1781	2572	GODRD	8141	856	32.04
1782	57	PFFRD	3452	1190	32.03
1783	317	CRTLD	4732	3732	31.98
1784	1945	ARTHR	0441	1662	31.91
1785	2346	CRLCC	2703	702	31.86
1786	1200	SPRDL	4831	1209	31.83
1787	2361	CMTSW	0941	746	31.82
1788	2026	BOWEN	3171	1356	31.76
1789	2004	CNTRY	2824	3061	31.69
1790	2312	MSTLT	1084	638	31.68
1791	2192	PRCRK	0003	1597	31.65
1792	822	WCOLO	1320	628	31.57
1793	N/A	DALRK	1309	392	31.57
1794	2265	MESQN	1507	616	31.54
1795	2388	BRNWD	1206	1839	31.49
1796	2244	DCVSO	1103	1112	31.49
1797	532	MESQN	1505	1212	31.44
1798	752	CRNRD	0007	744	31.29
1799	1862	PLSTH	1302	1034	31.24
1800	1892	VLRYN	2957	3043	31.24
1801	923	PLANO	1103	1513	31.22
1802	2184	WSOTH	1021	3110	31.20
1803	1942	DALWT	2931	1352	31.03
1804	2627	DFWSW	2202	31	30.90
1805	1632	EULES	8712	1003	30.82
1806	116	GRDPR	0852	1214	30.81
1807	2210	EULSO	9131	1908	30.80
1808	1424	HSKAV	0003	1320	30.76
1809	234	BLTON	1805	1193	30.75
1810	1195	FARON	4082	1598	30.62
1811	995	TRSES	1201	509	30.61
1812	1065	CNTRY	2814	834	30.60
1813	1425	PCUST	2009	2228	30.59
1814	1308	DEALY	0001	1018	30.59
1815	2352	SHDYG	7841	373	30.59
1816	818	KNEDL	6342	527	30.58
1817	219	MSLMN	4009	208	30.45
1818	1826	RNDRK	1504	936	30.43
1819	2357	BRNSO	1806	2018	30.31
1820	1456	WRBND	2322	895	30.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
1821	1747	OKLND	0003	1237	30.25
1822	700	PCUST	2011	2210	30.22
1823	772	DAVIS	3743	506	30.17
1824	1397	BRNSO	1807	210	30.15
1825	8	JDKNS	0821	35	30.14
1826	1884	CRLTR	2007	1361	30.12
1827	2651	JNKNS	0004	123	30.03
1828	2283	CMTSW	0915	677	29.93
1829	1720	SGOVL	1404	2023	29.92
1830	874	MKNNY	1202	1800	29.91
1831	2591	NCSFA	1706	862	29.90
1832	631	HSKAV	0001	1022	29.88
1833	1403	PREST	1602	1277	29.86
1834	374	HMPHL	2781	219	29.84
1835	1983	PCUST	2001	479	29.84
1836	1667	MESTE	1211	2680	29.82
1837	1258	WCOLO	1319	1903	29.79
1838	1215	STAUG	0002	1290	29.79
1839	1773	TYWST	2013	1485	29.76
1840	872	KLBRG	0002	1511	29.70
1841	2614	JNKNS	0003	1037	29.67
1842	980	REAST	1502	1260	29.65
1843	389	CRSCN	1204	572	29.61
1844	436	BLMED	1620	1840	29.53
1845	375	GRDPR	0862	935	29.41
1846	1234	BSPRW	2542	710	29.41
1847	1608	HNRTA	0311	895	29.39
1848	1221	VANSB	1501	837	29.38
1849	1334	RCLNS	1406	636	29.31
1850	2301	GSTHW	1692	712	29.29
1851	2417	REGST	0003	880	29.29
1852	2349	ARLNG	1251	480	29.24
1853	1841	WATSN	5361	1437	29.23
1854	1795	PWEST	1301	1092	29.18
1855	1194	NCSTH	1504	64	29.14
1856	2206	SHRSW	6621	1587	29.09
1857	68	MESQN	1506	51	29.06
1858	189	BNDRA	0005	768	29.04
1859	1696	FORSN	5611	116	29.01
1860	2442	HNYGR	2403	118	29.01
1861	2559	ALPHA	0014	558	28.90
1862	1210	IOWPK	0811	708	28.86
1863	1013	DALRK	1305	1209	28.83
1864	2197	ENSSO	2001	221	28.75
1865	138	REYST	4118	647	28.67
1866	848	CURIE	7211	357	28.67
1867	419	PRKRW	3362	1066	28.52
1868	2404	HSKAV	0004	859	28.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
1869	2131	PCOIT	1003	1479	28.41
1870	2111	BSPSW	0832	731	28.37
1871	1828	BRNSO	1805	646	28.33
1872	97	WMMMR	2707	1511	28.25
1873	807	CLBNR	1402	1798	28.21
1874	1517	ADISN	1605	1390	28.17
1875	N/A	RCHRD	1206	667	28.12
1876	1949	WFALS	0143	191	28.10
1877	1560	DESPR	1408	406	28.06
1878	718	LAVON	1452	1707	27.89
1879	1847	ARCTY	1321	891	27.84
1880	207	MKNNY	1251	1294	27.75
1881	1881	GRAHM	0721	1247	27.72
1882	907	RSPCK	2108	966	27.70
1883	2230	WTAUG	4652	778	27.63
1884	78	RBNSN	2501	1699	27.63
1885	N/A	CPLSO	4321	16	27.63
1886	670	KLNPS	1104	1282	27.62
1887	270	AMMFG	5611	784	27.61
1888	2389	LNCST	1603	2414	27.61
1889	2051	DESPR	1402	1495	27.59
1890	188	CRLJL	1503	660	27.56
1891	1635	TRNTY	7541	693	27.55
1892	942	LWSNR	2221	985	27.52
1893	2653	CNTRY	2833	2300	27.42
1894	1832	CRLJL	1501	1462	27.40
1895	2381	ALPHA	0003	684	27.37
1896	854	FSCRK	6723	2886	27.30
1897	1503	CLBWS	8111	1308	27.28
1898	2639	WMMMR	2704	28	27.25
1899	1092	HLSES	0533	1231	27.23
1900	1237	WATSN	5372	1339	27.15
1901	1937	CDHCR	2050	737	27.11
1902	358	MKNSW	2604	2191	27.09
1903	33	BLTON	1804	829	27.09
1904	1954	DESPR	1404	528	27.05
1905	1624	JUDCT	0007	633	27.05
1906	2148	WSOTH	1017	1662	27.04
1907	698	LKWOD	7411	597	27.02
1908	835	ARMST	0010	827	27.01
1909	212	GRLWS	1706	269	26.88
1910	2687	DFWSW	2208	23	26.87
1911	452	WFALS	0133	1646	26.86
1912	1328	KLNPS	1105	1523	26.82
1913	301	KRUMS	1203	1503	26.80
1914	1327	PCOIT	1004	689	26.65
1915	1730	KLELM	2205	2732	26.62
1916	662	SMFLD	2343	760	26.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
1917	2180	PLSTN	1005	1918	26.57
1918	1497	CRANE	0331	1084	26.51
1919	45	GVODS	3021	528	26.49
1920	2168	WDGWD	1522	1462	26.45
1921	2185	MESFR	2101	1918	26.42
1922	2446	LMESA	1531	1215	26.27
1923	469	RECCR	0003	241	26.26
1924	2279	GODRD	8151	415	26.22
1925	606	MDLNE	0112	574	26.17
1926	2110	GRAHM	0713	403	26.13
1927	2581	WEBBS	8621	2007	26.11
1928	1905	WLSPT	1002	597	26.06
1929	1014	PWEST	1311	764	25.91
1930	1335	COLNY	2403	2318	25.88
1931	2047	PLGRV	0001	1143	25.74
1932	1214	MDLNW	1511	2469	25.72
1933	690	PLDAV	4211	38	25.68
1934	865	CRLFR	2155	1334	25.63
1935	1483	PSHIL	1603	1466	25.61
1936	1410	JSHUA	1302	1254	25.60
1937	1316	GMINI	5811	2893	25.57
1938	1118	HRSMD	1905	2756	25.56
1939	444	FSCRK	6711	3448	25.55
1940	266	STAUG	0005	1130	25.36
1941	1636	WVWEST	1218	991	25.35
1942	615	NCSTH	1501	800	25.35
1943	1075	RWDHV	1907	753	25.29
1944	2193	LORAN	9711	391	25.25
1945	2259	DALRK	1301	928	25.25
1946	2203	FRMBG	1701	158	25.01
1947	2556	ARMST	0006	876	24.94
1948	1484	WEAST	0619	1922	24.94
1949	1578	RKDLE	1302	1186	24.91
1950	1670	BNDRA	0003	788	24.87
1951	964	PRKRW	3372	1038	24.69
1952	2036	ABBOT	1901	118	24.67
1953	2001	IRVVV	2803	150	24.60
1954	561	OKLND	0001	831	24.56
1955	2059	RTHGB	1421	1560	24.56
1956	172	CMPWI	0002	1712	24.41
1957	1256	MEXIA	4012	978	24.39
1958	989	STAUG	0006	1878	24.32
1959	2517	CKRHL	0007	218	24.32
1960	433	CLYVL	9322	2127	24.32
1961	1899	WALST	0004	52	24.27
1962	1242	CNSES	0750	1134	24.21
1963	2501	IRVVV	2851	2779	24.21
1964	2413	IRVVV	2804	906	24.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
1965	334	ODESA	0212	1647	24.06
1966	119	WDGWD	1523	285	24.01
1967	4	BLKRV	8321	53	23.96
1968	2463	WXNTH	2301	1145	23.94
1969	2654	MESQW	1805	73	23.89
1970	971	OKCLS	0008	1459	23.85
1971	1775	WFALS	0193	2241	23.85
1972	2406	LFEST	1901	999	23.80
1973	1818	BEAST	4088	123	23.80
1974	1315	BONHM	1204	889	23.65
1975	2377	PWEST	1312	1194	23.61
1976	890	CRTLD	4724	2665	23.55
1977	120	MDWCK	0003	1855	23.53
1978	1631	KLNCC	1701	3356	23.47
1979	2530	PRFTW	4212	2347	23.46
1980	435	ADISN	1603	157	23.30
1981	1936	DENAV	0683	853	23.28
1982	106	BRTLTL	1402	109	23.26
1983	1109	WDGWD	1541	1126	23.23
1984	917	HSKAV	0002	1443	23.22
1985	644	MKNSW	2601	2731	23.17
1986	1908	CLYVL	9321	775	23.16
1987	1104	MESQW	1803	1593	23.11
1988	2441	DWSON	3121	25	23.08
1989	1612	CDHIL	1613	1363	23.08
1990	1047	WHTRK	0006	1274	23.01
1991	235	BNTDR	0001	1053	22.95
1992	1223	MEXIA	3016	177	22.94
1993	152	PCOIT	1006	999	22.94
1994	877	RWDHV	1904	87	22.90
1995	563	NLNVL	2001	71	22.87
1996	2268	PRCTR	1602	220	22.87
1997	1005	WSOTH	1020	1132	22.87
1998	2115	BLMED	1622	975	22.86
1999	2315	HORNE	1911	959	22.83
2000	1051	PPARK	1808	584	22.70
2001	2334	SHNRW	1610	382	22.66
2002	159	TMNTH	1605	1704	22.66
2003	1586	ARMST	0009	1025	22.56
2004	2596	WFNTH	0241	746	22.53
2005	2375	MESQT	1302	1303	22.53
2006	1041	GODRD	8112	1397	22.52
2007	2422	PRKRW	3341	357	22.50
2008	143	COTRD	0005	220	22.50
2009	976	GSTHW	1691	25	22.40
2010	2090	OKLND	0004	1736	22.39
2011	2068	WOVER	6111	1957	22.39
2012	262	PLKST	0002	1513	22.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2013	2118	INAIR	1432	2797	22.29
2014	940	HLTOM	2461	586	22.26
2015	728	WDGWD	1572	1474	22.24
2016	326	PARIS	1206	993	22.20
2017	1472	VLRYN	2951	4728	22.06
2018	2136	GRDPR	0892	1262	22.06
2019	425	PCOIT	1007	682	22.06
2020	534	WCOLO	1317	1237	22.02
2021	1203	BKWST	0001	383	22.00
2022	2358	STNVL	1203	1399	21.95
2023	1250	ROLTR	2921	2082	21.94
2024	6	WATCO	2602	1695	21.88
2025	2644	PWEST	1305	21	21.86
2026	1220	GLNHV	3931	1303	21.83
2027	2623	HKHTS	1607	1289	21.82
2028	129	DENAV	0662	534	21.76
2029	1408	BSPRG	1901	532	21.74
2030	2371	GODRD	8122	872	21.67
2031	1777	ROWLT	1102	622	21.62
2032	1932	ATHNW	1402	1164	21.54
2033	2294	FRMBR	1805	743	21.53
2034	2436	CTYVW	2221	1811	21.52
2035	744	MDLNW	1592	1422	21.51
2036	447	LOMAL	0009	990	21.49
2037	1923	CHROW	0005	165	21.47
2038	413	COHMA	1111	651	21.47
2039	602	NMAIN	0231	283	21.43
2040	506	ALPHA	0002	1225	21.43
2041	957	CRLUD	1301	15	21.40
2042	793	DALLW	0004	1586	21.38
2043	1532	HMPHL	2711	437	21.36
2044	253	DAVIS	3762	27	21.26
2045	1875	ENNIS	1904	1211	21.25
2046	594	BOWEN	3132	1684	21.21
2047	2306	CLCRK	1011	192	21.20
2048	282	WSTHL	3652	3032	21.10
2049	2108	CMPWI	0004	1560	21.05
2050	725	WALST	0002	46	20.89
2051	2587	LWSNR	2231	767	20.83
2052	705	WALST	0014	803	20.80
2053	1968	MNSTR	1201	686	20.77
2054	827	LKHLD	0002	1249	20.68
2055	2278	ARTHR	0411	718	20.65
2056	722	DNIWS	1603	1345	20.63
2057	2662	CLBSN	8821	51	20.63
2058	633	PREST	1601	1014	20.62
2059	676	SLBLF	1201	119	20.61
2060	2589	GAVSW	0008	122	20.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2061	285	CHICG	1402	543	20.55
2062	2392	GSTHW	1611	1251	20.50
2063	349	PFFRD	3431	581	20.46
2064	2300	CRLJL	1502	321	20.41
2065	2347	MESTE	1204	1566	20.41
2066	126	ROGRS	1301	710	20.39
2067	2565	REAST	1501	295	20.37
2068	1717	RWDHV	1903	592	20.35
2069	264	LOMAL	0013	1058	20.30
2070	175	CRNRD	0004	484	20.25
2071	400	HMPHL	2762	1039	20.20
2072	139	RBNSN	2504	1936	20.14
2073	2385	KLELM	2204	2862	20.13
2074	2151	FRNKS	1202	84	20.12
2075	2029	BSPRG	1904	1631	20.05
2076	618	BNDRA	0006	478	19.94
2077	823	AMMFG	5631	1399	19.93
2078	1023	IRVND	1205	184	19.92
2079	1500	GRDNC	1211	324	19.91
2080	477	EDGCF	2211	1977	19.91
2081	659	WVWEST	1219	919	19.88
2082	201	MCGRG	0775	359	19.86
2083	1370	KNLTR	0008	833	19.84
2084	N/A	CPLSO	4322	179	19.82
2085	1741	SWTWR	1341	362	19.81
2086	1885	BDFRD	8841	812	19.80
2087	1585	BDFRD	8811	1698	19.78
2088	2236	WDGWD	1531	1430	19.78
2089	1159	BNBRK	4121	3922	19.77
2090	1175	DCVSO	1107	1033	19.72
2091	84	BKBNT	1821	1212	19.70
2092	2224	PNTGO	7111	679	19.70
2093	1955	CDCSW	0006	1287	19.69
2094	1052	TMNTH	1606	214	19.61
2095	2037	ENTOH	0007	789	19.55
2096	920	PRKRW	3392	1390	19.54
2097	N/A	NCRST	2202	21	19.52
2098	1815	IRVHF	2301	1185	19.46
2099	454	MESQW	1802	858	19.46
2100	2409	ARTHR	0481	1281	19.46
2101	1143	GRLND	1603	303	19.45
2102	2052	FROKS	0003	489	19.45
2103	577	LKHLD	0008	1131	19.32
2104	2298	MESTE	1205	1608	19.31
2105	2078	IRVNR	1559	2558	19.27
2106	458	GPLND	1202	397	19.27
2107	1377	SHDYG	7821	86	19.26
2108	409	ODESA	0251	1375	19.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2109	107	BRHLW	7642	652	19.22
2110	2335	GRMES	0521	504	19.22
2111	448	BSPRW	2521	1739	19.21
2112	2000	ALNTH	2854	2561	19.18
2113	2064	HUTTO	2711	1560	19.16
2114	2200	MESQT	1301	1097	19.16
2115	1094	BLTLN	0005	825	19.12
2116	804	IRVNR	1553	1267	18.96
2117	268	LOMAL	0016	634	18.88
2118	1755	BSPRG	1905	1461	18.85
2119	1100	PRCRK	0004	1325	18.85
2120	730	ELKTN	2501	1568	18.85
2121	592	FINKS	1803	1118	18.81
2122	1733	DAVST	0002	616	18.76
2123	414	CRTLD	4711	2695	18.66
2124	2049	AIRPK	8411	716	18.66
2125	1406	OKLND	0002	1217	18.56
2126	927	LKHLD	0004	1242	18.55
2127	1549	KLNTF	1806	1147	18.48
2128	2341	LKMNT	0008	804	18.46
2129	1380	MDLNW	1541	2068	18.43
2130	2188	STNVL	1205	1032	18.35
2131	2046	CLCTY	1011	1095	18.35
2132	2363	LFSTH	1405	1166	18.30
2133	1776	PRNTH	1401	1361	18.25
2134	156	PFLGV	2001	4116	18.18
2135	1025	PRCRK	0002	2029	18.16
2136	1423	TMSTH	1405	321	18.14
2137	2269	MKNSW	1601	1632	18.07
2138	1446	PKRVL	1053	2871	17.96
2139	1748	BRNAV	0784	2275	17.90
2140	319	DENDR	0006	51	17.90
2141	855	MSHLN	0003	858	17.90
2142	966	CRNTH	2402	3594	17.87
2143	2483	MTLDA	0007	1156	17.75
2144	778	ATHNW	1405	892	17.74
2145	248	CRLTR	2052	1560	17.70
2146	2247	TMPNW	1101	2175	17.64
2147	475	BRGPR	1103	820	17.58
2148	1871	GODRD	8142	879	17.55
2149	303	PRSTN	0002	1298	17.54
2150	2084	CRLTR	2005	709	17.53
2151	479	MKNGB	5321	390	17.50
2152	2285	WTAUG	4643	979	17.50
2153	1622	CDMIL	1201	605	17.38
2154	468	MCDMT	2554	2228	17.33
2155	1787	ODNTH	2034	2619	17.29
2156	693	MESTE	1215	1294	17.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2157	831	NHNSW	0003	513	17.22
2158	1113	ADMDS	6521	1388	17.19
2159	1644	NMAIN	0272	449	17.11
2160	1746	EZACH	0005	533	17.02
2161	2383	MKNSW	2602	2887	17.01
2162	834	DGNST	0003	259	17.00
2163	1756	FHLSW	1342	1631	16.99
2164	2219	FRNKF	0003	495	16.98
2165	1367	ARTHR	0431	451	16.96
2166	593	RSNHT	1122	1751	16.87
2167	1640	FRMBG	1703	29	16.83
2168	2178	ALLEN	2401	2138	16.81
2169	1864	ROWLT	1107	1156	16.80
2170	463	COMSO	1405	738	16.72
2171	2402	BSPRW	2532	1587	16.66
2172	2072	TYBLR	2806	200	16.66
2173	1691	GRLRD	0004	1539	16.63
2174	1972	LGVST	8522	355	16.61
2175	1288	WNRTH	1419	314	16.60
2176	2515	LMESA	2833	25	16.60
2177	1791	PARIS	1203	1005	16.53
2178	1789	HLSBR	1202	1216	16.51
2179	1975	SHMNE	1409	918	16.49
2180	1695	WNRTH	1416	717	16.47
2181	541	LWSNR	2232	2221	16.37
2182	2028	TYSTH	1203	426	16.33
2183	2647	GSTHW	1613	338	16.31
2184	2636	SHNRW	1614	402	16.31
2185	1317	LNCST	1602	2094	16.30
2186	1311	MESQN	1502	1049	16.23
2187	2488	PRKWY	1542	1532	16.23
2188	1569	MDWCK	0005	1376	16.21
2189	2070	ROWLT	1103	1064	16.14
2190	1611	ALNSW	2651	1447	16.09
2191	638	CNEXP	0004	883	16.07
2192	1870	EULSO	9121	1239	16.00
2193	1169	FSTVW	0008	2150	15.79
2194	1437	GLNHV	3953	1353	15.75
2195	1646	HKHTS	1605	1362	15.72
2196	568	BRYAN	0006	673	15.67
2197	1148	CTYVW	2222	1429	15.65
2198	632	VWDWY	2015	1095	15.56
2199	1863	BLMED	1619	918	15.53
2200	2289	SMPST	0004	1604	15.48
2201	2202	KFMNW	1201	906	15.42
2202	1721	MDDTN	4321	897	15.38
2203	2332	BLMED	1621	1467	15.35
2204	699	IRVND	1204	1195	15.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2205	914	LFSTH	1404	465	15.28
2206	572	MDWCK	0001	850	15.25
2207	490	WEAST	0617	868	15.25
2208	384	SANSM	3922	1477	15.18
2209	2166	TMNTH	1601	29	15.17
2210	1228	FRNKF	0006	2128	15.15
2211	519	FRMBR	1808	205	15.13
2212	1898	RANGR	4321	784	15.05
2213	1986	CANTN	1302	1301	15.03
2214	2360	MDAIR	2911	383	15.02
2215	1811	WFALS	0184	1346	14.99
2216	612	SHNRW	1612	558	14.95
2217	1736	PLANO	1104	842	14.95
2218	14	SGOVL	1403	1800	14.86
2219	2533	ARLNG	1222	102	14.82
2220	642	PALRD	2208	1014	14.80
2221	323	JKSES	3029	386	14.79
2222	1178	SCYEN	0001	1875	14.74
2223	516	BSPRG	1903	1570	14.74
2224	2284	PRKWY	1521	1826	14.73
2225	1433	HUBRD	1401	913	14.73
2226	2516	ROLTR	2912	2272	14.71
2227	909	BDFWD	8931	1718	14.68
2228	1982	RCLNS	1407	1664	14.68
2229	2103	JKSBR	1401	954	14.68
2230	1291	JKSNR	4105	332	14.68
2231	738	HNYGR	2401	476	14.67
2232	760	HORNE	1932	1063	14.61
2233	180	ALLEN	2403	1700	14.60
2234	1167	CRLTN	1453	295	14.53
2235	2518	WITTS	1701	1549	14.50
2236	2612	NPKWY	0011	2142	14.48
2237	N/A	LWSNR	2242	1289	14.35
2238	2440	ANDNR	2231	1410	14.33
2239	2403	PRKWY	1532	1943	14.32
2240	588	PWEST	1303	907	14.30
2241	811	BRKRG	0213	1422	14.21
2242	626	CDHIL	1805	596	14.21
2243	2370	RWDHV	1906	626	14.14
2244	1750	FINKS	1801	1353	14.12
2245	2139	PNTGO	7121	823	14.10
2246	N/A	RICES	0208	472	14.01
2247	2685	DENAV	0673	60	14.00
2248	1703	KRGRV	2401	14	14.00
2249	2434	MSTLT	1032	62	13.94
2250	1639	PFLGV	2005	3223	13.93
2251	1616	CRLFR	2157	2394	13.78
2252	2606	JUDCT	0006	1099	13.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2253	1521	MESQN	1504	646	13.74
2254	1076	KERNS	2401	509	13.74
2255	2464	MNWLW	1402	1562	13.72
2256	109	BRHLW	7622	1336	13.66
2257	1134	HMPHL	2721	445	13.63
2258	1988	TATSP	4321	1438	13.54
2259	579	LOMAL	0008	1006	13.48
2260	2430	WALST	0013	337	13.47
2261	357	MESFR	2102	609	13.44
2262	1641	CNEXP	0007	450	13.35
2263	2511	PALRD	2207	1103	13.34
2264	1001	FROKS	0001	1330	13.32
2265	2344	CRTLD	4712	1123	13.32
2266	2692	FRMNT	0002	796	13.25
2267	1176	GNSVL	1223	1021	13.24
2268	1526	DNINR	1403	1170	13.24
2269	2290	GVOVS	3031	1349	13.23
2270	2648	LVBRD	0005	1230	13.23
2271	2030	BDFWD	8932	1642	13.22
2272	548	ENNIS	1901	344	13.11
2273	N/A	WMRLD	0009	11	13.09
2274	1187	FHLSW	1321	84	13.05
2275	610	GRDPR	0822	599	13.02
2276	2470	PJPTR	3211	101	12.87
2277	1212	MDTHS	1002	921	12.83
2278	2250	ACRLY	1711	156	12.82
2279	896	MDLNW	1532	1797	12.77
2280	1448	FROKS	0002	1239	12.71
2281	826	NHNSW	0005	427	12.68
2282	1061	TMNTH	1602	491	12.66
2283	2625	MTLDA	0005	1508	12.65
2284	473	DAVIS	3752	520	12.63
2285	2667	WMMMR	2705	267	12.54
2286	2274	ADISN	1604	1151	12.47
2287	1420	ABRRD	0001	706	12.47
2288	418	WDGWD	1513	835	12.47
2289	2545	RGLRW	0008	54	12.44
2290	2473	BSPRW	2552	828	12.37
2291	193	CNSES	3054	1686	12.35
2292	2450	BLMND	3221	82	12.35
2293	2339	FRMNT	0010	1613	12.34
2294	1347	MCKMY	0811	1878	12.33
2295	2225	BLMND	3262	97	12.32
2296	2400	MSHLN	0004	908	12.26
2297	1772	RNDRK	1506	1626	12.22
2298	2212	BRKRG	0221	724	12.20
2299	1411	BOWEN	3122	1200	12.12
2300	2458	WTAUG	4642	1294	12.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2301	1610	WTAUG	4623	668	12.07
2302	1480	BLMGR	1902	196	12.00
2303	2429	TNSCL	1104	173	12.00
2304	508	PWEST	1310	218	12.00
2305	2382	SNYDR	1822	1617	11.97
2306	1989	ECTOR	1201	386	11.92
2307	1045	WWEST	1216	241	11.91
2308	2728	SORCY	0002	64	11.80
2309	1909	COTRD	0003	30	11.77
2310	952	RRSTH	1703	3055	11.76
2311	1683	MAPLE	0005	1219	11.75
2312	1711	WWEST	1217	94	11.65
2313	1320	CRNTH	2403	1869	11.58
2314	2707	MRSES	3016	40	11.58
2315	N/A	PPARK	1806	1284	11.57
2316	1725	MRLNS	4002	397	11.55
2317	449	SHRSW	6641	866	11.53
2318	N/A	WGROB	8412	1316	11.52
2319	2462	PLKST	0005	1370	11.46
2320	2423	SHDYG	7811	194	11.39
2321	2469	WTAUG	4621	420	11.29
2322	2220	WRBND	2321	1609	11.27
2323	2310	CPRCV	1402	1954	11.24
2324	737	CMTSW	0952	560	11.18
2325	2472	RGLRW	0004	75	11.16
2326	2649	SWTWR	1382	430	11.14
2327	2505	PROAD	0008	1124	11.08
2328	947	WEBBS	8612	4357	11.06
2329	2121	DNIWS	1602	1392	11.06
2330	2239	MDLNW	1573	905	11.03
2331	1201	LNCST	1601	655	11.03
2332	2058	MDLNW	1563	1264	11.02
2333	882	STAUG	0003	1658	11.00
2334	2366	PCOIT	1022	2035	10.99
2335	965	CMTSW	0973	1161	10.97
2336	1283	GSTHW	1662	1011	10.97
2337	244	SORCY	0001	2347	10.95
2338	892	CRKET	2401	141	10.91
2339	1531	MURPH	2752	2060	10.85
2340	1674	STERT	2701	12	10.83
2341	2722	RNKSW	5411	31	10.81
2342	1783	LOMAL	0002	619	10.77
2343	442	ARLNG	1271	1937	10.77
2344	2227	WEAST	0628	211	10.74
2345	2097	OKCLS	0006	1093	10.68
2346	937	VLRYN	2955	5208	10.62
2347	2303	HLSBR	1203	1149	10.46
2348	2330	SNYDR	1833	1392	10.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2349	2531	ABRRD	0003	324	10.39
2350	2319	EMPCT	0003	1424	10.35
2351	1927	WDGWD	1581	688	10.34
2352	1933	ARTHR	0452	625	10.33
2353	679	WALST	0009	767	10.26
2354	673	BDFWD	8912	928	10.22
2355	52	RYSSW	2802	2759	10.20
2356	2089	DNISN	1204	1285	10.19
2357	415	PLGRV	0004	1251	10.19
2358	781	WMRLD	0003	462	10.17
2359	2091	WBOSE	1101	365	10.08
2360	992	FSTVW	0003	1315	10.05
2361	2538	PAYSW	1203	838	10.03
2362	768	TMSTH	1401	1833	9.97
2363	2719	RECCR	0002	100	9.92
2364	889	LKHLA	0005	1751	9.89
2365	58	FLRTN	3721	28	9.86
2366	260	LOT69	3024	980	9.85
2367	2597	JNKNS	0005	527	9.84
2368	N/A	PTENN	2355	93	9.83
2369	2689	EMPCT	0001	31	9.81
2370	N/A	TMSTH	1406	1749	9.75
2371	1103	CRYVE	3011	279	9.75
2372	2561	NPKWY	0010	5925	9.65
2373	2214	WFNTH	0221	575	9.63
2374	28	RBNSN	2503	848	9.61
2375	2368	SHAMP	0005	1586	9.59
2376	1843	WFNTH	0262	249	9.57
2377	661	PWEST	1308	604	9.55
2378	1132	IRVND	1208	186	9.48
2379	2579	WBROK	3011	180	9.48
2380	719	DESPR	1401	2085	9.48
2381	1544	MESTE	1208	807	9.41
2382	806	WTHRF	2001	594	9.39
2383	2457	WALST	0003	129	9.37
2384	327	HKBRY	1109	144	9.32
2385	1345	ODESA	0221	260	9.28
2386	1739	CMBTP	1201	243	9.28
2387	1913	ANDNR	2242	1281	9.21
2388	1825	MESQW	1804	1218	9.18
2389	1482	SIKES	2411	1548	9.15
2390	765	DENAV	0652	43	9.14
2391	1389	DENDR	0004	1892	9.10
2392	2408	ECTHM	3321	1965	9.08
2393	1036	MESQW	1808	1309	9.08
2394	1277	TRLSW	1204	592	9.02
2395	2359	MNWLL	1202	681	9.02
2396	2514	TYEST	1506	12	9.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2397	496	GAVSW	0010	1112	8.95
2398	915	RCLNS	1405	630	8.86
2399	551	RGLRW	0003	87	8.85
2400	168	CNEXP	0002	828	8.82
2401	2017	WATCO	2603	2998	8.80
2402	784	CKRHL	0008	1503	8.78
2403	1992	WTAUG	4632	1142	8.75
2404	1922	ENNIS	1906	1813	8.73
2405	2124	MESTE	1202	774	8.71
2406	2626	WFALS	0174	1295	8.64
2407	616	ABRRD	0006	170	8.64
2408	1436	RSPCK	2132	96	8.55
2409	153	BMTWN	1621	1228	8.52
2410	1928	WNRTH	1418	1708	8.48
2411	1282	ARLNG	1223	1600	8.44
2412	1469	BLSRA	1602	149	8.40
2413	2331	MNHNS	1921	1743	8.26
2414	732	BKWST	0007	1567	8.25
2415	1193	MCWHT	3512	1462	8.24
2416	2187	CRSGL	1301	75	8.20
2417	2709	ODESA	0261	896	8.11
2418	2127	SHSTH	1301	1925	8.10
2419	481	CRLUD	1307	198	8.09
2420	2427	RDRSE	2603	3569	8.06
2421	1155	MNWLE	1702	1229	8.02
2422	2277	RSPCK	2106	481	8.01
2423	800	MSLSW	0005	485	7.97
2424	1619	WCOLO	1316	1920	7.95
2425	2671	SMPST	0006	1237	7.93
2426	931	WSANG	2801	1277	7.92
2427	320	BRKRG	0242	21	7.90
2428	2217	MKNGB	5331	1572	7.85
2429	446	SCYEN	0002	1823	7.84
2430	2453	BARRY	1801	88	7.84
2431	7	LMBLN	0001	1953	7.76
2432	1977	RRWES	1603	11	7.73
2433	2307	MNWLW	1401	1557	7.73
2434	2228	ESTLD	3611	1545	7.64
2435	N/A	LFSTH	1402	1122	7.61
2436	1156	WSANG	2802	609	7.58
2437	1198	SWDTN	1641	1586	7.56
2438	1780	CKRHL	0001	401	7.54
2439	749	JNKNS	0008	19	7.53
2440	598	TYOMN	1411	298	7.49
2441	2682	CKRHL	0004	322	7.49
2442	1046	MDLNW	1521	2459	7.46
2443	1267	WSTHL	3631	1991	7.39
2444	1660	WSOTH	1022	421	7.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2445	1464	FSCRK	6721	3184	7.35
2446	174	FSTVW	0004	1915	7.32
2447	2176	GODRD	8131	1647	7.31
2448	1318	MNWLL	1203	785	7.28
2449	227	CMTSW	0921	1812	7.25
2450	2549	BRYAN	0001	13	7.15
2451	2175	NPKWY	0012	1828	7.09
2452	2527	DNISN	1206	892	7.01
2453	2013	MCGRG	1902	443	6.96
2454	N/A	RSPCK	2103	1202	6.95
2455	1801	VLYRN	2952	3749	6.95
2456	2490	THRNE	0008	2053	6.94
2457	1969	KNLTR	0005	2408	6.92
2458	2020	CRSWS	1403	1761	6.91
2459	675	NAVCO	0001	26	6.88
2460	916	SNYDR	1823	1345	6.84
2461	688	GVGLF	9601	50	6.80
2462	2494	MAPLE	0008	190	6.78
2463	2670	VLYRN	2954	1017	6.73
2464	1211	DGNST	0008	312	6.66
2465	256	BKBNT	1842	484	6.65
2466	2231	STNVL	1202	466	6.55
2467	2419	WMMMR	2702	1964	6.54
2468	1912	MLKF2	1202	454	6.52
2469	2539	DALWT	2941	285	6.51
2470	1516	DAVIS	3723	333	6.49
2471	393	DALLW	0001	457	6.46
2472	2041	HURST	1841	168	6.45
2473	2617	THRNE	0004	784	6.43
2474	2412	PFLGV	2002	1903	6.33
2475	870	RENSW	3121	2296	6.26
2476	2655	PRKRW	3331	101	6.20
2477	2432	WMMMR	2708	669	6.17
2478	2023	RSNHT	1152	976	6.15
2479	1597	ARMST	0001	766	6.10
2480	2248	SWDTN	1611	1014	6.10
2481	1889	SHMNE	1407	771	6.00
2482	2323	BLMGR	1901	264	6.00
2483	1663	MNWLL	1205	438	6.00
2484	590	PRSTN	0001	863	5.94
2485	2452	CRTLD	4722	4282	5.92
2486	2714	PRNTH	1403	23	5.91
2487	2609	WALST	0001	181	5.91
2488	63	CNEXP	0005	31	5.90
2489	79	LOMAL	0010	1552	5.88
2490	660	WMRNR	0002	265	5.86
2491	2372	PRSTN	0003	2884	5.84
2492	2474	HMPHL	2791	42	5.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2493	2590	BRNWD	1205	1374	5.83
2494	2640	EMPCT	0004	345	5.81
2495	1231	HURST	1852	1162	5.79
2496	1708	BLKST	1762	1034	5.76
2497	2426	TRLSW	2401	17	5.76
2498	2438	BRYAN	0005	2058	5.76
2499	390	MRSES	4012	359	5.75
2500	2031	WTAUG	4633	978	5.75
2501	2348	BRKRG	0211	294	5.74
2502	2218	WFALS	0114	395	5.74
2503	1594	LVBRD	0001	35	5.74
2504	1466	DALWT	2991	858	5.73
2505	417	MESQN	1508	1780	5.67
2506	2232	HKBRY	1107	27	5.59
2507	2725	RSPCK	2105	25	5.52
2508	546	PWEST	1307	937	5.45
2509	2732	WEAST	0627	96	5.28
2510	362	MCKMY	0821	2127	5.28
2511	1405	FORSW	2015	912	5.23
2512	2420	CNEXP	0003	1407	5.23
2513	N/A	HKBRY	1105	25	5.20
2514	2555	CURIE	7231	1361	5.15
2515	1145	IRVNE	1305	224	5.09
2516	2521	BRIRV	6922	2987	5.05
2517	2630	MESFR	2103	331	5.05
2518	1294	CRLTR	2054	355	5.04
2519	2174	MURPH	2753	2734	5.00
2520	880	BOWEN	3142	822	5.00
2521	2365	MDWPK	9221	499	5.00
2522	1757	TRLSW	1202	56	4.98
2523	2619	CLBNR	1407	276	4.97
2524	776	WFALS	0163	352	4.95
2525	2571	MCDMT	2552	1742	4.95
2526	1848	SHRSW	6612	1786	4.94
2527	636	CLLVL	0004	48	4.90
2528	1701	JNKNS	0002	164	4.88
2529	2040	PCOIT	1002	1106	4.87
2530	288	MDWCK	0008	882	4.86
2531	443	GSTHW	1682	153	4.84
2532	2550	ADISN	1602	185	4.84
2533	2632	WTAUG	4651	501	4.83
2534	1745	PROAD	0003	973	4.72
2535	1493	ALPHA	0011	947	4.69
2536	1758	ODESA	0231	2011	4.67
2537	1378	GAVSW	0002	580	4.64
2538	684	WOVER	6142	1442	4.64
2539	1854	MKNGB	5312	2083	4.64
2540	2506	PROAD	0006	121	4.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2541	297	TNPON	0001	73	4.53
2542	2369	ROLTR	2911	2407	4.48
2543	2460	CTYVW	2211	1462	4.41
2544	1833	CRSCN	1201	795	4.41
2545	2633	LUFKN	1207	786	4.41
2546	N/A	COPEL	3056	2317	4.40
2547	1379	DFWSW	2207	22	4.23
2548	2088	JUDCT	0002	1318	4.21
2549	2287	RWDHV	1908	1818	4.13
2550	2229	NCRST	2203	1099	4.08
2551	2691	FRMBG	1706	58	4.00
2552	1508	MDLNW	1531	1163	3.96
2553	286	CRLFR	2154	3075	3.96
2554	547	FRMBG	1752	162	3.93
2555	810	DAVST	0001	514	3.86
2556	466	INAIR	1414	816	3.85
2557	1468	PCOIT	1025	2897	3.83
2558	2407	LAVON	1404	858	3.83
2559	1637	CNEXP	0008	419	3.71
2560	1026	LWSNR	2212	1263	3.69
2561	1404	WATSN	5352	1806	3.66
2562	1876	TRLSW	1201	584	3.59
2563	1119	GAVSW	0004	667	3.54
2564	2087	WFALS	0153	1164	3.54
2565	1460	FRMBG	1708	44	3.50
2566	2065	ADISN	1601	546	3.49
2567	711	MCHSN	1201	182	3.45
2568	1443	ENTOH	0005	1020	3.43
2569	2699	JNKNS	0006	494	3.39
2570	2554	IRVHF	2303	87	3.39
2571	1115	STNVL	1204	889	3.38
2572	2542	LWSNR	2241	1126	3.37
2573	1571	PLSTH	1303	540	3.35
2574	742	DALWT	2911	300	3.33
2575	1392	WALST	0011	1168	3.33
2576	71	NPKWY	0013	5681	3.30
2577	1999	GODRD	8132	2013	3.29
2578	2138	TYSTH	1208	302	3.25
2579	1664	GODRD	8161	1217	3.24
2580	2524	HRSMD	1953	306	3.23
2581	1821	MDLNE	0151	254	3.22
2582	861	CHROW	0008	81	3.19
2583	1307	SHAMP	0003	1711	3.18
2584	2600	MAPLE	0006	428	3.15
2585	2433	DFWSW	2204	24	3.08
2586	2608	JUDCT	0008	131	3.05
2587	2395	REGST	0004	407	3.05
2588	2659	GRLRD	0002	975	3.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2589	1753	PRCTR	1601	204	3.02
2590	1606	CNTRY	2862	398	2.99
2591	2421	GRLRD	0001	1731	2.92
2592	2386	REAST	1507	110	2.91
2593	1926	THRNE	0005	1187	2.91
2594	1326	GSTHW	1651	254	2.87
2595	2562	DALWT	2972	198	2.87
2596	2526	BLNKT	0701	253	2.87
2597	1761	SWDTN	1621	725	2.80
2598	1251	RNDRK	1502	145	2.80
2599	2710	PARIS	1205	28	2.79
2600	950	NMAIN	0241	645	2.78
2601	150	RRSTH	1704	2484	2.76
2602	1868	KLNTF	1803	1011	2.71
2603	2162	BKBNT	1811	681	2.70
2604	2484	RCLNS	1401	89	2.70
2605	2238	WFNTH	0211	777	2.69
2606	2712	PLANO	1102	118	2.68
2607	1166	CRLUD	1302	139	2.65
2608	2715	PSHIL	1605	116	2.56
2609	2105	FROKS	0005	1326	2.52
2610	624	EDGCF	2272	1045	2.47
2611	1851	CURIE	7221	645	2.44
2612	1415	HMPHL	2792	401	2.44
2613	2391	MSLSW	0004	386	2.44
2614	2634	HORNE	1923	1553	2.40
2615	2641	TYLER	1004	112	2.32
2616	1122	COLNY	2406	729	2.31
2617	2485	CLCTY	1031	1235	2.27
2618	2353	TYBLR	2802	968	2.11
2619	2449	WALNT	0004	1423	2.04
2620	1738	HMPHL	2742	414	2.04
2621	N/A	WXNTH	2308	433	1.97
2622	N/A	WEBBS	8634	515	1.95
2623	1943	RDRSE	2604	2814	1.91
2624	953	BKWST	0005	813	1.88
2625	1399	MCDMT	2551	2879	1.87
2626	2280	PSHIL	1606	245	1.86
2627	N/A	NMAIN	0262	163	1.74
2628	2628	WMRNR	0001	174	1.71
2629	830	MCDMT	2531	2001	1.70
2630	2380	PSHIL	1607	448	1.68
2631	1960	CHICC	1701	48	1.58
2632	N/A	COPEL	3055	1944	1.56
2633	2586	WXHNW	2901	174	1.53
2634	1830	HLTOM	2411	1330	1.51
2635	2116	LOMAL	0004	167	1.46
2636	2043	WWEST	1222	125	1.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2637	1530	BNMNW	1102	194	1.37
2638	2548	GSTHW	1622	30	1.37
2639	1085	SCHRD	0006	359	1.34
2640	2673	LEMON	0009	2019	1.32
2641	2713	PLANO	1106	410	1.31
2642	2329	ATNRN	3411	3423	1.30
2643	1792	ALPHA	0009	58	1.28
2644	42	DGNST	0006	151	1.26
2645	167	CHROW	0001	122	1.23
2646	2646	RECCR	0005	157	1.23
2647	1381	ENTOH	0006	1509	1.20
2648	1778	MDDTN	4311	186	1.19
2649	2321	FROKS	0004	120	1.17
2650	1572	JUDCT	0001	1118	1.16
2651	2733	WHITE	3542	603	1.14
2652	2411	ALPHA	0016	1721	1.09
2653	1984	WHITE	3532	1177	1.07
2654	2677	ARMST	0007	92	1.07
2655	556	ARMST	0005	1416	1.04
2656	2570	MESTE	1203	92	1.03
2657	2700	JUDCT	0004	96	1.03
2658	1993	FRMBG	1702	57	0.98
2659	557	LKMNT	0001	191	0.93
2660	2631	ENTOH	0008	84	0.87
2661	229	DGNST	0007	185	0.77
2662	2540	MSLSW	0006	100	0.76
2663	2537	LAVON	1402	65	0.75
2664	2480	WDGWD	1561	1458	0.71
2665	1742	HLTOM	2442	1048	0.70
2666	2094	RRSTH	1705	431	0.64
2667	2697	INAIR	1442	96	0.61
2668	949	MKNNY	1253	86	0.57
2669	1290	FHLSW	1382	103	0.53
2670	1835	BKWST	0006	620	0.52
2671	2672	FRNKF	0008	1161	0.50
2672	N/A	MCWHT	3522	3212	0.48
2673	1906	LVBRD	0004	972	0.48
2674	428	WALNT	0001	1419	0.46
2675	2637	PLANO	1105	101	0.46
2676	2262	WATSN	5382	644	0.43
2677	2564	BDFWD	8911	809	0.42
2678	2558	FRNKF	0007	1158	0.40
2679	388	MKNNY	1205	471	0.39
2680	1918	LMBLN	0003	169	0.38
2681	1332	SCHRD	0004	1805	0.34
2682	2320	SHDYG	7812	114	0.33
2683	683	AMLIA	0008	139	0.32
2684	1280	ALPHA	0010	491	0.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2685	1477	ALPHA	0001	443	0.30
2686	1310	NPKWY	0009	3969	0.27
2687	1590	FRMNT	0011	706	0.25
2688	338	FRMNT	0005	143	0.25
2689	309	WFALS	0124	131	0.24
2690	1114	BKWST	0004	1256	0.24
2691	2669	ATNRN	3412	2332	0.24
2692	2257	ARMST	0002	829	0.22
2693	733	WXNTH	2305	431	0.22
2694	N/A	KLELM	2202	2004	0.21
2695	2487	BRYAN	0002	316	0.19
2696	1764	RDRSE	2601	975	0.17
2697	2703	LSCOL	2148	347	0.16
2698	1718	BDFWD	8941	560	0.15
2699	2601	MNSTR	1202	262	0.14
2700	2666	SHDYG	7832	1821	0.14
2701	1219	KNLTR	0004	1927	0.11
2702	N/A	BLTSW	3203	1041	0.10
2703	829	FRMNT	0004	1413	0.10
2704	2302	WALNT	0008	855	0.08
2705	756	SORCY	0003	810	0.07
2706	2125	MDWCK	0006	824	0.07
2707	N/A	BLTSW	3201	1544	0.05
2708	2451	HORNE	1933	1935	0.02
2709	2656	BRHLW	7611	1629	0.01
2710	2077	ABBOT	1902	112	0.00
2711	2674	AIRPK	8431	21	0.00
2712	2652	ALLEN	2405	134	0.00
2713	2551	ALPHA	0005	123	0.00
2714	2676	ALPHA	0006	295	0.00
2715	2351	AMLIA	0003	21	0.00
2716	N/A	ANARN	1911	13	0.00
2717	1289	ARMST	0008	238	0.00
2718	2035	BLMED	1618	40	0.00
2719	2679	BRHLW	7641	19	0.00
2720	N/A	BRNLK	2401	68	0.00
2721	77	CHICW	1301	11	0.00
2722	459	CLBNR	1401	19	0.00
2723	N/A	CLLVL	0003	18	0.00
2724	N/A	CPLSW	3051	16	0.00
2725	2683	CRLUD	1306	26	0.00
2726	795	DFWNW	2601	51	0.00
2727	1557	DFWNW	2602	42	0.00
2728	2569	DFWNW	2606	16	0.00
2729	2199	DFWNW	2610	48	0.00
2730	2686	DFWSW	2203	24	0.00
2731	2635	DGNST	0001	71	0.00
2732	1525	ECTHM	3331	27	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2007 SAIDI Ranking	2006 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2007 SAIDI Value
2733	2164	EMPCT	0005	64	0.00
2734	2513	ENNIS	1905	42	0.00
2735	2663	FRMNT	0012	635	0.00
2736	1959	GAVSW	0006	516	0.00
2737	1238	GNSVL	1213	52	0.00
2738	1087	GNSVN	1401	20	0.00
2739	1276	GSTHW	1672	12	0.00
2740	1067	HKBRY	1102	1355	0.00
2741	2694	HKBRY	1111	28	0.00
2742	2695	HMPHL	2723	20	0.00
2743	2696	HMPHL	2731	12	0.00
2744	2512	INAIR	1421	13	0.00
2745	1434	INAIR	1423	165	0.00
2746	2534	JKSNR	4107	21	0.00
2747	678	LKWOD	7421	42	0.00
2748	2308	LOMAL	0007	134	0.00
2749	1421	LSCOL	2114	28	0.00
2750	2701	LSCOL	2135	611	0.00
2751	1427	LSCOL	2137	683	0.00
2752	N/A	LSCOL	2140	291	0.00
2753	2702	LSCOL	2142	14	0.00
2754	2704	MDDTN	4322	26	0.00
2755	N/A	MKNNY	1204	11	0.00
2756	2706	MNWLL	1201	14	0.00
2757	2708	MRSES	4014	22	0.00
2758	1133	PJPTR	3222	202	0.00
2759	1374	PROAD	0001	125	0.00
2760	1390	PROAD	0009	93	0.00
2761	2717	PTENN	2353	275	0.00
2762	1858	PWEST	1306	22	0.00
2763	2718	PWEST	1309	343	0.00
2764	2661	RCLNS	1403	78	0.00
2765	2665	RGLRW	0002	207	0.00
2766	1162	RGLRW	0006	33	0.00
2767	2724	ROANW	9522	24	0.00
2768	2447	RSPCK	2131	41	0.00
2769	1824	SMFLD	2362	57	0.00
2770	N/A	TMNTH	1603	122	0.00
2771	1888	TYLGE	1311	27	0.00
2772	2730	WALST	0008	16	0.00
2773	2731	WEAST	0620	78	0.00
2774	181	WEAST	0621	77	0.00
2775	2536	WVWEST	1221	15	0.00
2776	656	WVWEST	1223	11	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2007 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	14.00%
Vegetation	10.00%
Animals and Birds	9.00%
People (Including cars and farm equip)	19.00%
Utility-owned Equipment	22.00%
Other	23.00%
Unknown	3.00%