

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2110	1030	FRMBG	1701	64	0.19
2111	2592	PLANO	1102	123	0.19
2112	1990	TRNTY	7521	917	0.19
2113	587	SMFLD	2392	907	0.19
2114	721	KLNCC	1702	4151	0.19
2115	827	ESKSW	2711	108	0.19
2116	1906	ARMST	0010	900	0.18
2117	2110	WTAUG	4622	884	0.18
2118	2395	SHMNE	1407	775	0.18
2119	1933	HUTTO	2711	1704	0.18
2120	603	NMAIN	0211	1925	0.18
2121	971	SCYEN	0004	1177	0.18
2122	2448	SHDYG	7821	88	0.18
2123	478	VLYRN	2957	490	0.18
2124	2442	MKNGB	5312	2185	0.18
2125	1018	FRNKF	0005	1561	0.18
2126	2434	LKHLA	0005	1102	0.18
2127	586	FRMBG	1707	412	0.18
2128	2457	RCLNS	1401	56	0.18
2129	1888	RCHRD	1206	678	0.18
2130	1155	ALLEN	2402	3536	0.18
2131	2707	BRHLW	7611	1607	0.18
2132	2407	ODESA	0231	2108	0.18
2133	2105	ODNTH	2024	2637	0.18
2134	249	SMFLD	2391	271	0.18
2135	2058	WFNTH	0221	576	0.18
2136	1401	HLTOM	2482	1023	0.18
2137	703	DENAV	0621	1635	0.18
2138	2094	BRCRK	6533	1720	0.18
2139	710	RGLRW	0001	34	0.18
2140	1943	CNTRY	2824	3092	0.18
2141	1773	SPRDL	4822	1105	0.18
2142	1939	NSTAR	2011	564	0.18
2144	225	MKNGB	5322	743	0.18
2143	2685	SCHRD	0004	1823	0.18
2145	2513	MCDMT	2552	1745	0.17
2146	2496	SHDYG	7811	378	0.17
2147	1849	MSLMN	4009	212	0.17
2148	1589	BRHLW	7612	688	0.17
2149	2179	NCRST	2202	23	0.17
2150	470	OAKHL	3041	794	0.17
2151	914	FARON	4011	612	0.17
2152	739	RSNHT	1142	689	0.17
2153	2026	EULES	8731	1435	0.17
2155	1966	DAVIS	3743	498	0.17
2156	2261	SHMNE	1409	920	0.17
2154	592	SMFLD	2323	533	0.17
2157	2441	NCRST	2203	1079	0.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2158	1426	RDOAK	1303	695	0.17
2159	2600	NMAIN	0241	325	0.17
2160	189	RWDHV	1902	973	0.17
2161	2509	BDFWD	8912	944	0.17
2162	935	SHNRW	1611	897	0.17
2163	1830	CURIE	7211	329	0.17
2164	2569	PWEST	1308	1395	0.17
2165	2478	PRCRK	0004	1283	0.17
2166	1428	EDGCF	2213	2999	0.17
2167	2201	MTLDA	0005	1517	0.17
2168	853	PTENN	2351	1142	0.17
2169	117	AMLIA	0007	121	0.17
2170	2573	SHRSW	6612	1725	0.16
2171	885	SMFLD	2372	717	0.16
2172	2122	PCOIT	1003	1490	0.16
2173	2071	PCOIT	1005	1108	0.16
2174	1842	PCOIT	1008	1244	0.16
2175	928	GVODS	3072	2176	0.16
2176	2054	CTYVW	2222	1429	0.16
2177	2445	EMPCT	0003	1429	0.16
2178	1879	GRDPR	0892	1295	0.16
2179	1633	PALMR	2202	918	0.16
2180	2339	SMPST	0004	1596	0.16
2183	1257	ANDNR	2222	74	0.16
2181	2529	LWSNR	2241	1128	0.16
2182	2086	NMAIN	0272	450	0.16
2184	2703	MDWCK	0006	859	0.16
2185	922	DAVST	0005	1754	0.16
2186	2365	WALST	0013	367	0.16
2187	1921	PNTGO	7111	681	0.16
2188	1874	DENAV	0673	50	0.16
2189	1978	MKNSW	1601	1650	0.16
2190	2458	MDLNE	0151	270	0.16
2191	187	DUVAL	0483	1128	0.16
2192	851	BRNAV	0762	2244	0.16
2193	956	LKHLD	0002	1251	0.16
2194	2214	CRSGL	1301	83	0.16
2195	926	ITSCA	1702	174	0.16
2196	934	TMPLE	1204	1122	0.16
2197	356	ALPHA	0007	1432	0.16
2198	167	BBTWN	1502	1679	0.15
2199	1329	IRASB	3211	239	0.15
2200	1133	ELKTN	2503	660	0.15
2201	656	ODNTH	2033	603	0.15
2202	2648	DGNST	0007	183	0.15
2203	677	FRNKF	0001	497	0.15
2204	1699	KLNPS	1102	1748	0.15
2206	1973	HORNE	1961	1340	0.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2205	1330	IRVND	1206	99	0.15
2207	248	KLELM	2201	2444	0.15
2208	883	BDFWD	8921	683	0.15
2209	2742	HMPHL	2723	20	0.15
2210	2196	ADMDS	6521	1441	0.15
2211	2216	WALST	0002	47	0.15
2212	1465	BRLSN	2062	3108	0.15
2213	844	CRNTH	2404	2212	0.15
2215	779	MTLDA	0003	1457	0.15
2214	799	PCUST	2006	1586	0.15
2216	2436	FSCRK	6711	3461	0.15
2217	232	CRLJL	1506	1937	0.15
2218	2391	WCOLO	1316	1925	0.15
2219	850	KNEDL	6332	3854	0.15
2220	1703	PALRD	2205	302	0.15
2221	2397	HORNE	1981	1580	0.14
2222	2301	ARLNG	1251	499	0.14
2223	620	WEBBS	8611	2870	0.14
2224	2034	LOMAL	0009	995	0.14
2225	2522	CTYVW	2211	1435	0.14
2226	954	THRNE	0002	1538	0.14
2227	2081	PNTGO	7121	833	0.14
2228	2388	PRNTH	1403	21	0.14
2229	2112	TRLWD	7711	2559	0.14
2230	1995	LOT69	3024	988	0.14
2231	2153	FARON	4082	1579	0.14
2232	N/A	ROLTR	2922	818	0.14
2234	2485	IRVND	1208	171	0.14
2233	1847	RCHHL	0344	712	0.14
2235	2379	CRLTR	2005	672	0.14
2236	2039	GODRD	8122	852	0.14
2237	2649	MDDTN	4311	179	0.14
2238	1336	DESHR	1203	1504	0.14
2239	825	ODNTH	2044	2037	0.14
2240	2427	WMMMR	2702	1984	0.14
2241	1387	BRKNR	1221	209	0.14
2242	758	GORMN	0421	303	0.14
2243	843	CRLFR	2152	3318	0.14
2244	795	DLEON	0131	703	0.14
2245	927	ENNIS	1901	349	0.14
2246	10	EZACH	0002	1397	0.14
2247	2079	IRVVV	2851	2785	0.14
2248	2350	SHAMP	0003	1480	0.14
2249	1792	GODRD	8112	1395	0.14
2251	1787	BLMED	1617	943	0.14
2250	N/A	BLTON	1802	1228	0.14
2253	341	ECTHM	3311	930	0.14
2252	1463	PFFRD	3492	637	0.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2254	230	MDLNW	1522	1449	0.14
2255	2114	LOMAL	0013	1063	0.14
2256	1686	MEXIA	3016	207	0.14
2257	738	HRSMD	1957	2350	0.13
2259	2429	LOMAL	0002	628	0.13
2258	1863	PCUST	2005	1786	0.13
2260	2383	WBOSE	1101	345	0.13
2261	2269	CMTSW	0914	83	0.13
2262	2271	MCKMY	0811	1624	0.13
2263	2472	MESTE	1208	796	0.13
2264	2276	CMBTP	1201	243	0.13
2265	1594	CLCTY	1011	1117	0.13
2266	2186	MNHNS	1921	1748	0.13
2267	2333	WRBND	2321	1605	0.13
2268	783	FSTVW	0006	1609	0.13
2269	2155	GVODS	3011	2299	0.13
2270	1055	PPARK	1808	581	0.13
2271	2613	HMPHL	2742	436	0.13
2272	1366	WLWSP	1201	460	0.13
2273	2174	TRNTY	7541	638	0.13
2274	2527	PCOIT	1025	2913	0.13
2275	1443	PJPTR	3221	31	0.13
2276	2032	PRKWY	1552	523	0.13
2277	846	RWALS	1852	1785	0.13
2278	2020	WEAST	0615	353	0.13
2279	2247	PRKWY	1521	1834	0.13
2280	2375	MDWCK	0005	1380	0.13
2281	565	NCDCH	1202	1000	0.13
2282	2286	CRSCN	1201	802	0.13
2283	769	FRFWS	3004	812	0.13
2284	1065	FSTVW	0007	1362	0.13
2285	1824	IRVVV	2802	2151	0.13
2286	2208	BLMND	3221	88	0.13
2287	1619	BSPRG	1901	544	0.13
2288	2512	MRSES	3016	40	0.13
2289	1991	PJPTR	3211	104	0.13
2290	1050	TRNTY	7511	1065	0.12
2291	332	RDRSE	2602	2502	0.12
2293	2615	HLTOM	2442	1055	0.12
2292	237	LTVSB	5461	765	0.12
2294	2595	WWEST	1222	137	0.12
2295	2546	PROAD	0003	929	0.12
2297	1078	ARMST	0004	526	0.12
2296	1373	EULES	8724	2944	0.12
2298	2606	RDRSE	2604	2118	0.12
2299	N/A	TMPTV	2402	2266	0.12
2300	712	ABRRD	0005	1177	0.12
2301	1504	RWDHV	1901	910	0.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2302	2380	WFNTH	0262	247	0.12
2303	1033	FSTVW	0005	1592	0.12
2304	376	COPER	0402	166	0.12
2305	1977	LWSNR	2221	1038	0.12
2306	2123	LMESA	2833	25	0.12
2307	2300	CRTLD	4711	2960	0.12
2308	891	ARTHR	0481	1274	0.12
2309	1754	ARLNG	1232	1238	0.12
2310	2495	BLMGR	1901	430	0.12
2311	2202	ANDNR	2242	1603	0.12
2312	255	LKHLD	0006	738	0.12
2314	1188	COTRD	0008	1046	0.12
2313	2653	MSLSW	0006	102	0.12
2316	2211	BSPRW	2542	715	0.12
2315	1947	STNVL	1203	1404	0.12
2317	94	WHITE	3541	937	0.12
2318	2253	WMMMR	2708	224	0.12
2319	2290	PAYSW	1203	819	0.12
2320	2732	ECTHM	3331	26	0.12
2321	1531	DAVST	0003	1415	0.12
2322	206	ARTHR	0472	1646	0.11
2323	1655	GAVSW	0012	1121	0.11
2324	2060	PFFRD	3421	852	0.11
2326	1837	CNTRD	0003	1355	0.11
2325	1176	FRMNT	0008	1504	0.11
2327	1313	PALRD	2203	961	0.11
2328	130	BNMAG	1202	383	0.11
2329	2368	RSPCK	2106	481	0.11
2330	920	EDGCF	2252	384	0.11
2331	2695	KLELM	2202	2177	0.11
2332	2715	AMLIA	0003	18	0.11
2333	1944	GVODS	3062	1890	0.11
2334	2183	ABRRD	0006	190	0.11
2335	2167	CRTLD	4724	2682	0.11
2336	2317	LKMNT	0008	997	0.11
2337	2446	BKBNT	1842	499	0.11
2338	2069	ECTOR	1201	374	0.11
2339	754	BANGS	1201	1470	0.11
2340	2572	PCOIT	1002	879	0.11
2341	1852	IRVNR	1552	55	0.11
2342	2294	ARTHR	0431	450	0.11
2343	358	LKMNT	0004	2036	0.11
2344	2017	CNTRY	2814	859	0.11
2345	N/A	FSCRK	6724	4003	0.11
2346	2632	JUDCT	0001	1159	0.11
2347	2144	LKHLD	0008	1136	0.11
2348	2447	TRLSW	1202	56	0.11
2349	994	MESFR	2105	981	0.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2350	2505	LAVON	1404	857	0.11
2351	1922	DNINR	1401	85	0.11
2352	1456	CRTLD	4734	1798	0.11
2353	2617	CNTRY	2862	398	0.11
2354	2764	RCLNS	1403	19	0.11
2355	834	HORNE	1921	776	0.10
2356	2228	BLMGR	1902	163	0.10
2357	1007	CNEXP	0007	452	0.10
2358	1027	MDLNE	0122	202	0.10
2359	1240	SNYDR	1852	1330	0.10
2360	1854	COPEL	3052	1304	0.10
2361	2250	ROWLT	1107	1106	0.10
2363	2699	BKWST	0004	720	0.10
2362	1811	MDLNE	0112	574	0.10
2364	2409	GSTHW	1662	1392	0.10
2365	2490	RENSW	3121	2305	0.10
2366	2521	SHRSW	6641	864	0.10
2367	1522	MESQW	1806	1623	0.10
2369	173	CNTRD	0004	1017	0.10
2368	905	DGNST	0002	227	0.10
2370	1736	STANT	1322	79	0.10
2371	1079	CNEXP	0003	1393	0.10
2372	317	WELRD	0007	435	0.10
2373	2342	PALRD	2208	1020	0.10
2374	2523	CURIE	7231	1379	0.10
2375	902	CRLTN	1451	290	0.10
2376	1710	CMPWI	0003	941	0.10
2377	906	WRTHM	5004	241	0.10
2378	2614	MSLSW	0004	392	0.10
2379	1611	EULSO	9141	181	0.10
2380	998	PFLGV	2007	1268	0.10
2381	864	REAST	1502	1264	0.10
2382	2688	BKWST	0006	648	0.10
2383	571	INDIA	2501	350	0.10
2384	1029	CKRHL	0006	62	0.10
2386	856	COLNY	2405	1984	0.10
2385	791	WELRD	0008	1117	0.10
2387	38	CRTLD	4731	3222	0.10
2388	2392	ALNSW	2651	1566	0.10
2389	2484	WATSN	5361	1810	0.09
2390	2525	VLYRN	2952	3758	0.09
2391	2463	MLKF2	1202	456	0.09
2392	2647	MESTE	1203	172	0.09
2393	N/A	CRLCC	2704	464	0.09
2394	2075	HMPHL	2713	54	0.09
2395	14	LMESA	1512	622	0.09
2396	2334	MDWCK	0001	844	0.09
2397	405	BRHLW	7632	1339	0.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2398	2554	EDGCF	2272	1020	0.09
2399	949	ARMST	0012	489	0.09
2400	2252	CMTSW	0915	678	0.09
2401	2278	GVODS	3031	1347	0.09
2402	1047	WALNT	0002	1124	0.09
2403	2444	NPKWY	0011	2139	0.09
2404	2405	WEBBS	8612	2934	0.09
2405	2755	MKNNY	1204	34	0.09
2406	2157	BKBNT	1821	1214	0.09
2407	287	BLKST	1752	1161	0.09
2408	801	ODNTH	2073	559	0.09
2409	1128	FLMSO	3711	2022	0.09
2410	2504	FSTVW	0004	1833	0.09
2411	2482	SORCY	0001	2411	0.09
2412	306	GMINI	5812	722	0.09
2413	1056	MESTE	1207	877	0.09
2414	907	BSPSW	0841	2020	0.09
2415	2347	BRHLW	7622	1352	0.08
2416	2538	FROKS	0001	1318	0.08
2417	1622	ODESA	0251	1393	0.08
2418	2000	TMPNW	1101	2206	0.08
2419	2519	MDWCK	0008	886	0.08
2420	329	TMPNW	1102	528	0.08
2421	2643	LOMAL	0004	148	0.08
2422	2471	RSNHT	1152	987	0.08
2423	372	DESHR	1206	1941	0.08
2424	2118	PWEST	1310	223	0.08
2425	1228	LAVON	1454	2671	0.08
2426	860	TMNTH	1604	50	0.08
2427	790	KLNCC	1704	1556	0.08
2428	221	GRLRD	0003	604	0.08
2429	679	LIGSW	1603	2499	0.08
2430	2718	BLMED	1618	38	0.08
2431	383	FRMBG	1750	801	0.08
2432	1021	GODRD	8141	858	0.08
2433	N/A	ROBNW	1501	258	0.08
2434	2514	NMAIN	0262	168	0.08
2435	2415	BRKRG	0211	299	0.08
2436	660	LIPAN	1303	260	0.08
2437	1881	SMPST	0003	962	0.08
2438	12	GAVSW	0007	1095	0.08
2439	1101	FARON	4021	291	0.08
2440	2117	CKRHL	0007	226	0.08
2441	449	ROWLT	1106	1296	0.07
2442	1591	SHDYG	7831	95	0.07
2443	N/A	MYPTX	2401	259	0.07
2444	1737	RECCR	0003	246	0.07
2445	2376	TATSP	4321	1437	0.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2446	284	BDFWD	8922	2163	0.07
2447	1200	LKTMS	2411	745	0.07
2448	1629	EDGCF	2221	706	0.07
2449	2694	ALPHA	0010	517	0.07
2450	1111	SMFLD	2322	42	0.07
2451	2280	WEAST	0627	98	0.07
2452	2106	PRCRK	0003	1572	0.07
2453	2063	NHNSW	0004	555	0.07
2454	2633	COLNY	2406	743	0.07
2455	1926	EGFRD	0005	1790	0.07
2456	943	MSTLT	1054	231	0.07
2457	2244	CMTSW	0941	854	0.07
2458	1057	KLELM	2204	2689	0.07
2459	300	DLEON	0111	641	0.07
2460	1035	WRTHM	5017	175	0.07
2461	639	TMSTH	1407	59	0.07
2463	418	ADMDS	6511	725	0.07
2462	2751	LSCOL	2137	680	0.07
2464	859	BSPRG	1904	1632	0.07
2465	966	HRSMD	1951	3887	0.07
2466	2744	INAIR	1421	15	0.07
2467	583	REAST	1509	60	0.07
2469	334	FORSW	2053	2916	0.07
2468	972	LOMAL	0005	511	0.07
2470	1576	WTAUG	4641	557	0.07
2471	2517	TRLSW	1201	591	0.07
2472	2113	WWEST	1216	244	0.07
2473	2016	GRLRD	0004	1542	0.07
2475	2162	MCDMT	2532	1967	0.06
2474	2473	MDLNW	1531	1270	0.06
2476	1613	GSTHW	1613	124	0.06
2477	1885	BSPRW	2532	1591	0.06
2478	2173	CRLTR	2007	1356	0.06
2479	2698	BDFWD	8941	601	0.06
2480	1512	IRVGS	1907	761	0.06
2481	942	MDWCK	0003	1863	0.06
2482	1117	RNDRK	1507	1465	0.06
2483	2352	PWEST	1305	16	0.06
2484	1950	BNDRA	0005	786	0.06
2485	426	MDLNE	0163	997	0.06
2486	2066	CHROW	0007	82	0.06
2487	1909	IRVNR	1555	3372	0.06
2488	2080	CRNTH	2403	1853	0.06
2489	1001	RRSTH	1701	2791	0.06
2490	961	WALST	0004	50	0.06
2491	818	MAYFD	5511	4048	0.06
2492	N/A	HKHTS	1608	1279	0.06
2494	2103	ARTHR	0411	708	0.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2493	1799	PWEST	1302	337	0.06
2495	2749	LSCOL	2114	34	0.06
2496	2487	TRLSW	2401	17	0.06
2497	1876	MESTE	1211	2682	0.06
2498	1994	PPARK	1802	1427	0.06
2499	1914	CLBSN	8821	52	0.06
2500	889	IRVNR	1506	1343	0.06
2501	119	MSLSW	0007	384	0.06
2503	193	BRHLW	7631	684	0.06
2502	678	FRMBG	1705	263	0.06
2504	1013	BRIRV	6912	762	0.06
2505	2588	CLCTY	1031	1206	0.06
2506	1602	MCGHR	2004	18	0.06
2507	2768	RSPCK	2131	36	0.06
2508	976	PCUST	2002	1785	0.06
2510	1137	GAVSW	0001	1071	0.06
2509	2154	SHNRW	1610	381	0.06
2512	2373	BDFWD	8932	1657	0.05
2511	1123	CURIE	7241	91	0.05
2513	948	PRKRW	3372	1075	0.05
2514	1557	KLNTF	1802	766	0.05
2515	2681	WXNTH	2305	442	0.05
2516	2530	GSTHW	1682	148	0.05
2517	2325	TMNTH	1606	223	0.05
2518	874	VGCRK	8011	1571	0.05
2519	2680	WATSN	5382	636	0.05
2520	2363	ECTHM	3321	2040	0.05
2521	462	LIGSW	1607	1390	0.05
2522	2042	WWEST	1217	94	0.05
2523	2189	MDAIR	2911	382	0.05
2524	1588	CNTRY	2842	1112	0.05
2525	1076	ALPHA	0008	1212	0.05
2526	N/A	RDRSE	2607	2803	0.05
2527	1669	TYLER	1001	155	0.05
2528	2670	ATNRN	3411	3455	0.05
2529	1071	WATSN	5372	1326	0.05
2530	2584	HRSMD	1953	319	0.05
2531	2260	HMPHL	2791	40	0.05
2532	2225	MSTLT	1032	60	0.05
2533	2582	PRSTN	0003	2911	0.05
2534	2479	WFALS	0114	402	0.05
2535	1368	RWALL	1201	1046	0.05
2536	1785	HMPHL	2772	242	0.05
2537	919	BSPSW	0812	810	0.05
2538	1454	WMRLD	0005	1567	0.05
2539	2193	LAVON	1452	2428	0.05
2540	2360	DENAV	0652	41	0.05
2541	897	PRKRW	3321	144	0.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2542	2190	JNKNS	0004	124	0.05
2543	1174	RENSW	3111	1307	0.05
2544	2637	LEMON	0009	2041	0.05
2546	1069	DAVST	0002	607	0.05
2545	369	ENTOH	0002	795	0.05
2547	848	SCHRD	0003	357	0.05
2548	N/A	ELZCK	4921	1121	0.05
2549	1866	DAVIS	3733	382	0.05
2550	84	MSLSW	0002	1012	0.05
2551	1802	WEBBS	8621	2118	0.05
2553	348	PRHLL	2402	65	0.05
2552	1984	WFNTH	0241	736	0.05
2554	2501	JNKNS	0005	525	0.05
2555	1813	DALWT	2921	263	0.05
2556	2560	IRVHF	2303	88	0.05
2557	2143	CRLTR	2052	1564	0.05
2558	1868	DAVST	0007	994	0.05
2559	2586	WATSN	5352	1793	0.05
2560	2555	REAST	1507	111	0.05
2561	2024	MDLNW	1573	915	0.04
2562	2515	DGNST	0008	161	0.04
2563	2735	FRMNT	0012	369	0.04
2564	479	FRMBR	1806	165	0.04
2565	174	COPEL	3051	189	0.04
2566	1323	NLNVL	2003	593	0.04
2567	2725	CRLUD	1306	24	0.04
2568	2218	IRVVV	2804	917	0.04
2569	2679	ARMST	0002	1085	0.04
2570	890	WALNT	0005	1094	0.04
2571	1110	COMRC	1202	50	0.04
2572	2486	MESQN	1506	50	0.04
2573	1163	PJPTR	3212	75	0.04
2574	257	CNEXP	0006	1127	0.04
2575	2675	FRNKF	0007	1159	0.04
2577	2318	IRVNR	1559	2254	0.04
2576	863	SYCRK	4531	4175	0.04
2578	1044	FRMBR	1802	1101	0.04
2579	1620	BRCRK	6523	879	0.04
2580	1085	DENDR	0009	52	0.04
2581	2737	GNSVL	1213	52	0.04
2582	1090	STERT	2703	78	0.04
2583	2389	TMSTH	1406	2188	0.04
2584	2544	ROLTR	2912	2352	0.04
2585	1851	DAVIS	3762	27	0.04
2586	2754	MDDTN	4322	27	0.04
2587	2557	PARIS	1205	27	0.04
2588	1385	SMBMG	1701	27	0.04
2589	2585	COPEL	3056	2206	0.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2590	78	PLKST	0004	1050	0.04
2591	2644	ENTOH	0008	83	0.04
2592	2609	ROLTR	2911	2318	0.04
2593	1981	RCLNS	1408	170	0.04
2594	740	WEBBS	8623	3059	0.03
2595	2437	JNKNS	0003	1038	0.03
2596	875	PPARK	1804	238	0.03
2597	1026	RNKSW	5422	30	0.03
2598	2655	FHLSW	1382	92	0.03
2599	2268	ALLEN	2401	2202	0.03
2600	2561	WTAUG	4651	499	0.03
2601	923	TRNTY	7551	1286	0.03
2602	140	CRLFR	2153	1018	0.03
2603	1204	HHSTH	1501	1643	0.03
2604	406	MNFLD	2621	2071	0.03
2605	1080	BKWST	0002	1850	0.03
2606	2677	BDFWD	8911	911	0.03
2607	351	GRLWS	1704	169	0.03
2608	2658	SCHRD	0006	102	0.03
2610	2465	CRLUD	1307	205	0.03
2609	304	RWDHV	1905	1195	0.03
2611	1119	JUDCT	0003	1540	0.03
2612	1052	GODRD	8142	913	0.03
2613	325	ARMST	0003	636	0.03
2614	983	CHROW	0002	107	0.03
2616	2233	ANDNR	2231	1447	0.03
2615	792	WBROK	3021	741	0.03
2617	2577	DALWT	2941	271	0.03
2618	1042	PROAD	0005	117	0.03
2619	1326	PRKRW	3382	197	0.03
2620	908	PRSTN	0005	1183	0.03
2621	2234	ABRRD	0001	716	0.03
2623	2528	BOWEN	3142	1040	0.03
2622	343	FRMBR	1807	1318	0.03
2624	2296	LWSNR	2231	767	0.02
2625	2602	FRMBG	1708	41	0.02
2626	2548	KLNTF	1803	1025	0.02
2627	2691	FRMNT	0011	711	0.02
2628	1068	DGNST	0004	1067	0.02
2629	991	SHAMP	0006	1101	0.02
2630	N/A	RSPCK	2133	134	0.02
2631	55	CHYNE	9121	90	0.02
2632	355	FRMNT	0003	274	0.02
2633	2541	CLLVL	0004	48	0.02
2634	909	HNYGR	0402	398	0.02
2635	2401	HKBRY	1109	51	0.02
2636	2413	LVBRD	0005	1194	0.02
2637	931	ARTHR	0492	52	0.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2639	2316	RDRSE	2603	3281	0.02
2638	2765	RGLRW	0002	208	0.02
2641	1046	IRLBJ	3222	1305	0.02
2640	2502	JNKNS	0002	163	0.02
2642	2467	ODESA	0221	273	0.02
2643	415	RECCR	0001	164	0.02
2644	1151	RCLNS	1402	339	0.02
2645	2618	FRMBG	1702	59	0.02
2648	2612	PLANO	1106	414	0.02
2646	2657	PSHIL	1605	118	0.02
2647	2139	SHRSW	6631	1240	0.02
2649	2526	RSPCK	2103	1791	0.02
2650	2045	ALNTH	2854	1913	0.02
2651	2550	RWDHV	1908	1859	0.02
2652	992	CKRHL	0002	370	0.02
2653	2520	MAPLE	0008	185	0.02
2654	2693	RDRSE	2601	1226	0.02
2655	1075	MCDMT	2553	937	0.01
2656	1034	RECCR	0007	67	0.01
2657	N/A	WEBBS	8631	2762	0.01
2658	1074	DAVIS	3731	750	0.01
2659	2664	AMLIA	0008	140	0.01
2660	2272	HKBRY	1103	71	0.01
2661	1953	FRMBR	1808	596	0.01
2662	1005	NHNSW	0001	447	0.01
2663	2668	DGNST	0006	150	0.01
2664	2640	PSHIL	1607	450	0.01
2665	1962	ALPHA	0003	683	0.01
2666	1215	BLMND	3282	76	0.01
2667	2481	IRVVV	2803	152	0.01
2668	950	CKRHL	0003	233	0.01
2669	1054	PROAD	0007	393	0.01
2670	1288	HNYGR	2402	161	0.01
2671	1070	DALWT	2992	328	0.01
2672	1402	IRLBJ	3211	2385	0.01
2673	2421	CKRHL	0001	413	0.01
2674	387	CNTRD	0001	1966	0.01
2675	953	TMSTH	1405	269	0.01
2676	1972	RRSTH	1707	274	0.01
2677	1067	STNVL	1202	94	0.01
2678	1073	MSLSW	0003	202	0.01
2679	985	LWSNR	2211	815	0.01
2680	1063	RECCR	0002	103	0.01
2683	2562	HURST	1852	1175	0.01
2682	2708	KNLTR	0004	1917	0.01
2681	2567	WEAST	0628	212	0.01
2684	2651	INAIR	1442	109	0.01
2685	2641	MCDMT	2551	3409	0.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2686	988	RRSTH	1708	3854	0.01
2687	2146	ABBOT	1901	113	0.01
2688	2598	CRLFR	2154	3088	0.01
2689	390	RSPVY	1702	474	0.01
2690	2219	LWSNR	2212	1339	0.01
2691	N/A	LSCOL	2138	619	0.01
2692	328	GVODS	3041	1368	0.01
2693	2558	GSTHW	1651	261	0.01
2695	986	MAPLE	0004	132	0.01
2696	2386	PROAD	0008	1058	0.01
2694	2761	PTENN	2353	394	0.01
2697	1459	CPLSO	4321	135	0.01
2698	N/A	BRNSO	1801	1095	0.01
2699	2684	ALPHA	0016	1712	0.01
2701	2714	ALPHA	0006	296	0.01
2700	1041	BRIRV	6921	2062	0.01
2702	1092	WMMMR	2705	318	0.01
2703	2098	PRFTW	4212	2258	0.01
2704	2623	BKWST	0005	814	0.01
2705	323	CNEXP	0001	192	0.01
2707	2581	DALWT	2972	198	0.01
2706	2659	WHITE	3542	590	0.01
2708	683	BLTLN	0001	647	0.00
2709	2607	MAPLE	0006	438	0.00
2710	1344	RCHHL	0394	229	0.00
2711	1865	HMPHL	2711	461	0.00
2713	2229	KLNCC	1701	2317	0.00
2712	N/A	NPKWY	0008	508	0.00
2714	2102	CKRHL	0004	289	0.00
2715	2510	MCKMY	0821	2322	0.00
2716	1554	FRMBR	1804	300	0.00
2718	2422	BKWST	0007	1559	0.00
2717	2004	BRKRG	0242	623	0.00
2719	377	HKBRY	1115	383	0.00
2720	2564	CNEXP	0008	428	0.00
2721	2461	ALPHA	0011	889	0.00
2722	430	CLLVL	0002	482	0.00
2723	1010	MAPLE	0001	569	0.00
2724	1037	PWEST	1312	1173	0.00
2725	2305	ALPHA	0002	1216	0.00
2726	1160	FRMNT	0002	786	0.00
2727	2705	SHDYG	7832	1817	0.00
2728	2701	FRMNT	0004	1584	0.00
2729	2711	AIRPK	8431	19	0.00
2730	359	ALLNC	6422	20	0.00
2731	1083	ALPHA	0004	20	0.00
2732	2713	ALPHA	0005	132	0.00
2733	2646	ARMST	0007	94	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2734	2717	ARMST	0008	238	0.00
2735	N/A	ATNRN	3421	995	0.00
2736	733	BLMND	3211	15	0.00
2737	1061	BRYAN	0007	263	0.00
2738	380	CHROW	0006	66	0.00
2739	2722	CLBNR	1401	18	0.00
2740	N/A	CLBWS	8112	1233	0.00
2741	2723	CLLVL	0003	18	0.00
2742	2345	CNEXP	0005	26	0.00
2743	2565	COTRD	0003	29	0.00
2744	2460	CRLUD	1301	14	0.00
2745	951	CURIE	7212	11	0.00
2746	2728	DFWNW	2606	23	0.00
2747	2730	DFWSW	2203	22	0.00
2748	2400	DFWSW	2204	19	0.00
2749	2531	DFWSW	2207	22	0.00
2750	1086	DFWSW	2208	20	0.00
2751	N/A	DFWSW	2209	11	0.00
2752	2224	EMPCT	0001	31	0.00
2753	2733	EMPCT	0005	66	0.00
2754	2734	ENNIS	1905	43	0.00
2755	2559	FRMBG	1703	28	0.00
2756	360	FRMBG	1704	36	0.00
2757	2621	FRMBG	1706	58	0.00
2758	1053	FRMNT	0001	952	0.00
2759	2665	FRMNT	0005	143	0.00
2760	1124	FRMNT	0007	93	0.00
2761	2738	GNSVN	1401	21	0.00
2762	2566	GSTHW	1622	29	0.00
2763	2438	HKBRY	1107	35	0.00
2764	2741	HKBRY	1111	29	0.00
2765	2746	JKSNR	4107	18	0.00
2766	N/A	JNKNS	0001	11	0.00
2767	2671	JNKNS	0006	497	0.00
2768	2552	JUDCT	0008	131	0.00
2769	2178	KRGRV	2401	14	0.00
2770	2748	LOMAL	0007	134	0.00
2771	46	LSCOL	2116	28	0.00
2772	2750	LSCOL	2135	612	0.00
2773	2752	LSCOL	2140	281	0.00
2774	2753	LSCOL	2142	13	0.00
2775	2690	LSCOL	2148	643	0.00
2776	2587	LVBRD	0001	31	0.00
2777	1690	MAPLE	0002	76	0.00
2778	1696	MESTE	1201	22	0.00
2779	2756	MNWLL	1201	15	0.00
2780	2757	MRSES	4014	20	0.00
2781	952	NCSTH	1505	13	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
2782	1081	NMAIN	0252	254	0.00
2783	N/A	PJPTR	3231	24	0.00
2784	2654	PLANO	1105	101	0.00
2785	2763	PWEST	1309	50	0.00
2786	2346	RNKSW	5411	31	0.00
2787	2767	ROANW	9522	27	0.00
2788	2372	RRWES	1603	11	0.00
2789	1040	RSPCK	2142	927	0.00
2790	2769	SMFLD	2362	57	0.00
2791	2630	SORCY	0002	63	0.00
2792	2402	STERT	2701	13	0.00
2793	2627	TYBLR	2802	976	0.00
2794	2704	WALNT	0008	854	0.00
2795	1091	WALST	0007	18	0.00
2796	2773	WEAST	0620	78	0.00
2797	2774	WEAST	0621	77	0.00
2798	2605	WEBBS	8634	262	0.00
2799	2662	WFALS	0124	128	0.00
2800	1422	WICKT	0431	13	0.00
2801	2775	WWEST	1221	16	0.00
2802	2776	WWEST	1223	11	0.00
2803	1093	WXOCF	1402	11	0.00

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

2803

Add or Delete Rows as Necessary

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1	100	LOVNG	2511	174	1826.90
2	2074	FRNKS	1202	85	1624.00
3	155	SBEND	0611	150	1471.40
4	38	MSTNG	2611	134	1296.70
5	776	EMMAS	4011	70	941.14
6	125	BNBOR	1202	1011	846.10
7	113	CHRNO	1203	892	823.48
8	1487	MRTNS	1502	511	810.93
9	1136	COPER	1201	332	768.94
10	89	MEXIA	3015	88	754.97
11	23	CLKVL	1201	457	740.70
12	557	HNTNG	1301	1255	732.07
13	66	DGLAS	2401	708	718.96
14	576	THSES	2402	1162	699.93
15	7	DHIDE	2821	115	695.13
16	329	WCITY	2402	703	683.57
17	30	FKLCY	5111	80	675.13
18	N/A	CSHNG	1204	323	674.14
19	309	JKREA	1201	29	631.52
20	562	COPER	1202	930	625.84
21	1301	CHALK	0911	121	621.13
22	1276	ALPHA	0015	819	613.31
23	1676	BNTDR	0003	402	607.61
24	368	TRPMN	4001	787	604.52
25	2577	GODRD	8132	2040	588.24
26	145	REYST	4129	469	566.65
27	3	HNTNG	1307	1365	564.18
28	282	TSLVL	4001	935	549.52
29	2	BRNSY	1211	121	548.41
30	1967	BLKRV	8321	53	545.25
31	267	DIALV	3911	1044	542.27
32	49	TYLNE	1605	1080	541.37
33	520	CSHNG	1201	920	524.92
34	45	ARPMN	4149	299	521.35
35	1909	GRLWS	1706	270	505.64
36	491	MIDWY	0612	33	497.27
37	492	CDCSW	0007	884	494.15
38	201	EDWDS	5921	573	488.01
39	531	DIBOL	1505	1403	484.80
40	310	ALEDO	9411	1928	482.38
41	115	SCURY	1921	91	478.84
42	8	PMBRK	1811	22	478.36
43	517	MRDCK	0001	722	476.17
44	1711	CRWLY	7011	400	458.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
45	478	CGDEL	5411	26	458.19
46	181	BRGPR	1102	1139	456.76
47	16	DHIDE	2811	107	450.57
48	19	GSMTH	1732	68	447.50
49	257	HOWRD	3921	67	446.97
50	909	DNISN	1205	1445	446.57
51	1669	BNBOR	1201	675	435.35
52	1053	BLPOD	1201	94	433.96
53	136	TYLNE	1624	475	433.53
54	56	CLKVL	1203	603	429.52
55	331	UPTON	0721	83	429.47
56	1433	DNISN	1203	1647	425.53
57	157	KYSTN	1021	44	419.61
58	417	FRFWS	3001	1927	417.38
59	1226	HNTNG	1305	1173	411.10
60	248	BRIRV	6911	2782	410.61
61	815	HNRTA	0321	859	409.15
62	2459	NAVCO	0001	25	408.12
63	1308	IVANS	1621	56	406.80
64	418	SSPNE	1403	1658	404.98
65	398	WINKS	0521	51	386.98
66	537	CNI45	2401	521	381.45
67	1	CRSSN	7911	644	380.45
68	95	RYLTY	1431	73	379.49
69	195	DCDAM	2003	1380	378.82
70	1099	LUFKN	1208	2030	374.10
71	2471	DALLW	0001	573	373.98
72	29	MIDWY	0621	155	373.08
73	203	NCNTH	1806	856	372.78
74	44	ANDRD	0921	140	372.26
75	1143	BRNAV	0741	127	370.93
76	545	RYSSW	2801	1718	370.82
77	761	SWAN2	1801	343	370.69
78	661	AZLES	2121	2608	369.84
79	36	COYAN	6321	254	368.26
80	64	PLDAV	4221	166	367.22
81	666	DNISN	1201	1176	364.69
82	1042	FORSW	2025	712	362.38
83	2490	WMRNR	0002	267	360.97
84	32	EDGWD	1101	581	360.49
85	473	PEGAS	2311	107	356.85
86	670	SPRTN	1801	1690	356.56
87	321	TYWST	2002	404	353.63
88	111	CMPST	0004	1502	350.75
89	360	BAGWL	1202	46	350.09
90	2132	LFSTH	1405	211	349.75
91	1582	EULES	8711	2069	348.20
92	319	FRNKS	4168	972	348.14
93	375	LUFKN	1206	1304	346.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
94	1306	FRFWS	3002	511	346.06
95	442	LGVST	8511	723	344.28
96	2372	NPKWY	0010	5953	343.47
97	1985	MKNSW	2601	2775	336.37
98	188	BRHLW	7651	1115	329.35
99	868	KRUMS	1201	787	328.43
100	207	WELRD	0001	1217	327.78
101	70	COYAN	6311	94	326.67
102	2240	PWEST	1303	927	324.60
103	11	SCSES	1201	196	324.29
104	1033	RDOAK	1302	1193	323.98
105	1848	VANSB	1501	839	322.29
106	1001	MEXIA	4011	904	319.76
107	2461	GVGLF	9601	51	318.59
108	34	SNYDR	1813	271	318.46
109	57	BLTON	1806	549	318.37
110	414	LUFKN	1201	1279	317.38
111	2631	CHICC	1701	48	316.08
112	167	HOLDY	0921	564	314.96
113	1847	HNRTA	0311	1068	313.93
114	2371	CRYVE	3011	281	313.58
115	48	MDFRM	2111	53	312.49
116	214	DEALY	0002	1224	311.35
117	1686	DAVST	0004	1734	308.82
118	2042	DALLW	0004	1636	307.07
119	1125	CMTSW	0983	894	306.90
120	1736	SMFLD	2311	958	306.87
121	330	CHALK	0951	81	303.95
122	120	RDLML	2552	281	303.43
123	2221	JKSES	3029	1170	302.97
124	17	PEGAS	2321	407	302.74
125	1501	ALVRD	1504	125	301.08
126	33	CDCRK	1201	1192	299.47
127	1385	RDLML	2581	1212	299.22
128	402	JDKNS	0811	55	294.73
129	367	DALRK	1302	16	293.44
130	585	ECTHP	4911	718	293.27
131	91	SCURY	1911	182	292.88
132	1079	DNCNV	1902	1029	291.86
133	1678	KMPSO	2400	912	291.29
134	1022	JKWST	4178	315	289.63
135	391	LKMNT	0007	1537	288.57
136	2579	GODRD	8161	2104	287.54
137	164	LMBLN	0005	671	287.33
138	811	CRLTR	2004	192	285.43
139	840	MNFLD	2672	1965	285.35
140	376	CRLTR	2003	1347	285.20
141	232	TRPMN	4023	427	284.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
142	63	KRGRV	2403	2965	284.05
143	2096	PRKRW	3392	1433	283.74
144	986	BDFRD	8831	703	282.92
145	347	LUFKN	1204	610	282.51
146	311	DALLW	0003	767	280.16
147	2628	WMRNR	0001	519	278.24
148	870	MRSES	3015	1248	278.22
149	2301	WTAUG	4623	717	277.44
150	501	LFSTH	1406	1797	277.38
151	1839	TYWST	2013	1501	277.35
152	1212	MDWCK	0004	1682	275.93
153	1438	MSLMN	4007	129	275.42
154	653	CRKET	2403	2690	274.49
155	13	PLDAV	4231	113	274.27
156	101	GRSMN	3071	234	273.96
157	2090	DCVSO	1107	1034	273.29
158	511	ELMAR	3211	112	271.16
159	1045	LWRDR	0001	1143	270.17
160	1257	WEBBS	8613	2666	269.63
161	744	TYLNW	1910	1473	269.58
162	2391	DENDR	0004	1881	269.36
163	2141	MSHLN	0003	873	269.34
164	1139	PLGRV	0002	2134	268.78
165	90	COPER	0401	135	268.19
166	2447	GODRD	8131	1657	266.97
167	1378	UPTON	0711	92	266.68
168	826	MCGHR	2003	1276	265.94
169	1283	GVFTW	1801	594	265.13
170	2061	CHICG	1402	541	263.59
171	1965	ODESA	0212	1664	262.92
172	1376	CRLTN	1406	1206	262.68
173	522	IRLBJ	3212	3592	262.49
174	1368	SPRDL	4812	1208	262.34
175	1704	MAYFD	5522	2842	261.95
176	60	TSLVL	4008	1883	261.93
177	873	MEXIA	4040	881	257.67
178	2101	GRLND	1603	306	257.42
179	1206	PRNTH	1404	1446	256.94
180	250	CNANG	1806	2193	256.77
181	26	CSHNG	1202	67	256.30
182	1703	OTTOJ	3060	12	255.25
183	1883	WTAUG	4652	787	254.56
184	1649	WSTHL	3621	4092	254.33
185	4	BRNSY	1221	81	254.07
186	1028	CMEXP	1601	218	253.00
187	1401	MKNNY	1254	789	252.89
188	94	FHLSW	1332	283	251.28
189	410	EZACH	0008	1488	250.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
190	785	JREST	2101	1091	250.76
191	968	WHTRK	0005	717	249.61
192	1937	GMINI	5811	2777	249.22
193	1421	LUFKN	1203	1414	248.56
194	1181	FRSTN	1602	1067	247.71
195	193	HLTOM	2452	1786	246.70
196	373	HLSES	0511	1248	246.14
197	223	FRNKS	1201	354	245.34
198	554	RKDLN	1401	928	245.29
199	624	PAYSW	1223	112	245.27
200	1338	PALMR	2201	52	245.17
201	1094	CRLTN	1407	1515	243.99
202	1334	FLMSO	3712	2524	243.55
203	144	CNSES	3056	1251	243.15
204	1776	CRLJL	1504	909	242.31
205	1509	RENSW	3122	84	241.30
206	37	OVRTN	4019	701	241.00
207	1333	HSKAV	0006	600	239.90
208	1265	SSPNG	1202	1172	239.70
209	123	DESPR	1405	515	239.19
210	640	DCVSO	1105	2138	238.63
211	1587	MSHLN	0008	684	237.50
212	283	GSMTH	1711	51	235.84
213	1081	PRNTH	1405	935	235.83
214	460	CNTRD	0002	1434	235.38
215	607	RSNHT	1181	1648	235.00
216	2084	CPLSO	4322	179	234.35
217	1441	CDCSW	0003	664	234.15
218	1832	HSKAV	0001	1029	233.51
219	416	CANTN	1301	2032	233.44
220	180	BEAST	4090	932	233.37
221	288	LFSTH	1407	1056	233.09
222	1055	PGSTH	7021	63	232.51
223	1457	WELCH	4911	24	232.29
224	633	CDCSW	0001	255	231.37
225	446	DENDR	0005	397	230.96
226	461	TYWST	2012	1748	229.71
227	781	BRCRK	6512	1753	229.12
228	2059	SLBLF	1201	120	229.09
229	2230	JKSNR	4105	323	228.70
230	81	RSPVY	1708	923	228.45
231	53	GRSMN	3027	312	228.23
232	784	CRSWS	1402	861	227.53
233	149	RWALE	3322	635	226.69
234	119	MRYNL	2111	11	226.45
235	560	DCATR	1201	1303	225.97
236	290	NYLDV	1201	180	225.46
237	1270	TYLNE	1623	432	225.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
238	1645	MKNNY	1252	1894	225.15
239	861	OAKHL	3021	1773	225.11
240	1761	SHSTH	1305	425	225.01
241	469	MEANS	4411	129	224.98
242	2225	HUBRD	1401	911	224.53
243	516	FKLCY	5121	113	223.39
244	1860	HNYGR	2403	116	223.00
245	301	EZACH	0001	1482	222.83
246	1700	TYWST	2004	1020	222.30
247	2282	TMNTH	1602	482	221.26
248	62	BKWWF	0521	438	221.16
249	804	HKBRY	1101	158	220.27
250	1942	NCSTH	1501	784	219.84
251	345	TAYLR	1202	1337	219.13
252	2566	ADISN	1601	553	218.97
253	76	TYEST	1503	1432	218.81
254	2649	FROKS	0004	119	218.53
255	2135	PRCRK	0002	2059	217.99
256	1186	TYWST	2003	1336	217.78
257	1585	CHNDL	1201	1749	217.74
258	760	RSKMN	3046	1080	216.37
259	2259	LOMAL	0008	1009	215.85
260	1117	PPARK	1807	883	215.40
261	1153	IRVNE	1310	1287	214.73
262	841	IRVGS	1908	768	213.76
263	1840	KLBRG	0002	1554	213.45
264	1561	ALLEN	2406	3827	212.52
265	1684	ATHNW	1401	896	212.44
266	2024	WATCO	2602	1887	210.57
267	775	CDCSW	0002	2239	210.35
268	189	POWEL	2706	239	210.00
269	1179	EULSO	9122	1170	209.41
270	1381	CDHCR	2055	2235	209.19
271	20	NCWDN	1121	55	209.02
272	687	RRNES	2401	2749	208.51
273	1973	BEAST	4088	125	208.14
274	2161	MKNSW	2602	2886	207.79
275	1680	MABNK	2401	1910	207.29
276	2289	RGLRW	0008	51	207.27
277	1302	DEALY	0003	1039	206.90
278	2365	FLRTN	3721	28	206.29
279	851	WMMMR	2703	1486	206.02
280	2011	WOVER	6111	2210	205.86
281	172	CDCSW	0004	1291	205.28
282	587	CPLND	1101	934	205.20
283	867	SYCRK	4522	1875	204.67
284	2358	WMRLD	0003	463	204.59
285	1279	KNAPP	4021	39	204.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
286	260	EZACH	0006	1100	204.39
287	1498	GLNHV	3942	1415	204.32
288	1719	LUFKN	1202	1141	204.08
289	2760	PROAD	0009	102	203.88
290	1393	PMBRK	1821	66	203.85
291	2500	WTAUG	4633	986	203.83
292	892	MSLSW	0008	199	203.39
293	827	MTLDA	0002	1905	203.05
294	2172	TYBLR	2806	200	203.04
295	2280	FROKS	0002	1247	202.27
296	1280	FHLSW	1351	1262	201.60
297	2567	MCHSN	1201	267	201.01
298	244	COLDG	4047	446	200.58
299	114	BNBRK	4122	1939	200.23
300	828	NHNSW	0006	588	200.18
301	1786	SPRDL	4831	1226	199.88
302	734	FORSN	5621	46	199.04
303	112	WTHRF	2002	1568	198.88
304	2318	WGROB	8412	1756	198.70
305	983	ODESA	0272	1309	198.53
306	110	QNLAN	1201	836	198.40
307	1282	MTLDA	0004	722	198.18
308	1940	STAUG	0005	1137	197.89
309	135	MEXIA	4024	365	197.68
310	467	MYPRL	1801	115	197.37
311	586	MYPRL	1803	733	197.34
312	1067	MNWLE	1701	641	197.29
313	184	JKSES	3028	377	196.98
314	1469	CMPST	0002	1105	196.94
315	1109	SHDYG	7842	633	195.79
316	573	FLINT	3211	1572	194.27
317	2300	WTAUG	4642	1300	194.05
318	2274	FHLSW	1321	319	192.23
319	1131	GNSVE	1603	1560	192.14
320	1160	CDHIL	1801	723	190.87
321	447	MEXIA	4007	517	190.74
322	1087	WDGWD	1591	1145	190.63
323	328	PFLGV	2004	2679	190.33
324	1597	HRSMD	1907	2234	189.39
325	1920	WDGWD	1522	1465	188.25
326	622	WHITE	3521	1012	187.93
327	165	COMRC	1203	639	187.80
328	211	TMPLE	1203	1190	187.46
329	2402	CKRHL	0008	1603	187.32
330	655	MLKF2	1201	1651	187.10
331	N/A	SMBSN	8811	15	187.00
332	806	NHNSW	0007	920	186.88
333	2048	WSTHL	3652	2854	185.62

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
334	1524	HURST	1822	1285	185.44
335	1516	HOLDY	0911	1120	185.09
336	2015	WDGWD	1572	1478	184.88
337	1814	DEALY	0001	1021	184.14
338	1074	EULES	8732	1408	184.11
339	419	EUSTC	2401	1717	183.38
340	802	LNCST	1604	536	183.30
341	2032	ATHNW	1402	1193	183.30
342	583	KIMBL	5012	1569	183.19
343	152	KNEDL	6312	2745	182.79
344	852	MDAIR	2921	1333	182.68
345	86	WICKT	0421	207	182.62
346	277	WTAUG	4613	1858	182.36
347	2028	DENAV	0662	537	181.67
348	1287	BRKRG	0223	253	180.85
349	161	MAPLE	0003	703	179.95
350	153	HDWLK	3003	932	179.60
351	604	BRKNR	1211	107	179.15
352	1286	KNLTR	0003	599	179.13
353	860	KILEN	1203	1588	179.05
354	808	CMHBL	8121	54	178.09
355	1990	WHTRK	0006	1268	177.81
356	1135	GVFTW	1802	758	177.39
357	1284	WDGWD	1552	308	177.30
358	1695	PCUST	2010	2247	175.94
359	1751	CHROW	0003	53	175.26
360	75	TYLGE	1314	829	175.13
361	581	RRNES	2405	2852	174.90
362	523	LFEST	1905	1688	174.60
363	271	TATSP	4312	2440	174.43
364	536	DALLW	0002	132	174.40
365	2134	PFLGV	2001	4542	174.25
366	2388	MESQW	1804	1189	173.84
367	2189	ROWLT	1103	1076	173.40
368	1249	BNTDR	0004	1551	173.07
369	965	GRPVN	8222	536	172.24
370	1624	BLKST	1711	1885	172.11
371	1638	CRSGL	1303	82	172.04
372	296	RCHHL	0321	507	171.60
373	1564	MEXIA	4023	601	171.58
374	1494	VANAL	2412	2638	171.13
375	1162	IOWPK	0821	746	171.11
376	1220	EZACH	0003	1277	170.97
377	987	CRLTR	2006	487	170.96
378	506	HOLND	1901	914	170.88
379	1803	DALWT	2931	1414	170.84
380	1275	WNTHW	1118	1499	169.99
381	270	LNCST	1605	627	169.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
382	795	HNTNG	1306	995	169.37
383	602	TRIRA	6221	898	169.21
384	611	ODNTH	2053	2383	169.10
385	1416	LAVON	1453	2225	169.07
386	779	RSKMN	3053	486	168.74
387	2352	ARTHR	0452	626	168.46
388	798	WESTS	1601	1086	167.76
389	897	DUVAL	0434	2287	167.37
390	241	MNWLW	1403	902	167.35
391	534	EDGWD	1102	1086	167.04
392	2319	PLKST	0005	1391	167.03
393	104	EZACH	0007	1566	167.03
394	1141	CLBRN	1202	969	167.01
395	618	FRMBG	1751	754	166.93
396	704	PCOIT	1024	2168	166.25
397	2609	FROKS	0005	1318	165.99
398	77	PRKRW	3311	854	164.83
399	1981	DENAV	0683	846	164.68
400	2396	TYEST	1506	429	164.63
401	1495	BRNAV	0774	1432	164.48
402	126	LWRDR	0004	790	164.44
403	458	LKMNT	0002	1076	164.26
404	2695	BRYAN	0002	448	164.21
405	2185	LNCST	1602	2083	164.13
406	344	ACRLY	1721	56	163.54
407	620	MRDCK	0004	793	163.33
408	218	TYBLR	2811	1013	162.03
409	1475	KILEN	1201	1532	161.98
410	2554	FRMBG	1752	191	160.62
411	231	CRNAT	4121	53	160.57
412	960	IRVNE	1306	1500	160.43
413	185	RDLML	2521	993	160.33
414	2380	DESPR	1401	2129	159.92
415	724	LVBRD	0002	377	159.86
416	648	CRTLD	4742	1607	159.53
417	224	LKWOD	7432	1399	159.26
418	2398	RCLNS	1405	636	159.15
419	286	SPRDL	4821	1369	159.01
420	433	BLTLN	0007	761	158.97
421	616	CRSGL	1302	705	158.96
422	1085	KLRPR	9021	1953	158.52
423	593	SANSM	3913	2729	158.47
424	1112	PGSTH	7011	107	158.36
425	1539	ROANW	9521	1448	158.29
426	566	TYSTH	1201	1357	158.21
427	2180	WNRTH	1416	722	158.12
428	N/A	TYRSW	1703	1307	158.07
429	46	WFNTH	0252	890	157.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
430	1773	PSHIL	1602	1006	157.83
431	572	WESTS	1602	888	157.24
432	684	PLKST	0003	1912	157.17
433	1151	NCSFA	1704	1419	157.12
434	751	CNSES	0370	1216	157.00
435	954	OAKCK	2211	40	156.93
436	714	SWAN2	1803	959	156.66
437	1913	KRUMS	1203	1563	156.52
438	790	EMMAS	4012	14	156.36
439	59	RCHLD	2101	532	156.30
440	1403	EULES	8713	1492	155.80
441	1996	PRCTR	1602	225	155.55
442	1072	CRSCN	1202	624	155.54
443	1251	DUVAL	0452	1785	155.50
444	665	CTYVW	2212	140	155.49
445	1644	CLMET	0003	891	155.37
446	2321	WTAUG	4621	421	155.30
447	896	CDCSW	0008	681	155.23
448	915	LIGSW	1602	1140	155.09
449	568	ODESW	5221	1124	154.98
450	486	PFFRD	3441	1100	154.92
451	863	MLDR2	1605	712	154.47
452	2120	ELKTN	2501	1406	154.34
453	2079	GRDNC	1211	325	153.65
454	2463	VLYRN	2954	1027	153.54
455	678	BLKST	1771	1163	153.30
456	1071	PFFRD	3462	1592	153.29
457	1505	MSHLN	0007	715	153.28
458	2155	ODNTH	2034	2678	153.23
459	18	LENSW	0321	15	152.80
460	2747	LKWOD	7421	43	152.49
461	2053	MNSTR	1201	692	152.47
462	264	HUTCH	1503	519	152.25
463	1201	PTENN	2358	1460	152.15
464	88	TYBLR	2803	772	152.00
465	740	FLINT	3212	2236	151.83
466	1508	OKCLS	0007	494	151.83
467	2399	RGLRW	0003	91	151.74
468	729	QNLAN	1202	383	151.33
469	1726	TYOMN	1401	1506	151.32
470	479	RSNHT	1171	2222	151.25
471	660	CRLTN	1454	291	151.22
472	698	SMFLD	2341	1067	151.05
473	967	GRPVN	8213	1590	150.88
474	1918	CRANE	0331	1221	150.14
475	528	DNCNV	1905	1292	150.05
476	280	PROAD	0004	979	149.88
477	667	NECSP	2401	528	149.80

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
478	276	HORNE	1913	1627	149.38
479	2303	TNSCL	1104	177	149.35
480	2657	JUDCT	0004	67	149.33
481	2672	MCWHT	3522	3249	149.11
482	2545	LUFKN	1207	790	149.10
483	2576	NPKWY	0013	5556	149.01
484	320	TYBLR	2808	840	148.99
485	160	SYCRK	4532	3658	148.95
486	453	DUVAL	0441	969	148.91
487	693	FARON	4062	1121	148.67
488	312	TRNTH	1502	450	148.38
489	712	CNI45	2402	1240	148.27
490	1242	MRSES	4006	575	148.11
491	857	OTTOJ	3059	643	147.78
492	1036	RSKMN	3078	137	147.74
493	988	JKWST	4035	159	146.71
494	405	HUDSN	1603	2011	146.34
495	599	THRDN	1901	1422	146.28
496	638	RGLRW	0005	49	146.00
497	274	COMRC	1201	948	145.92
498	354	DUVAL	0421	1108	145.68
499	1187	BRLSN	2013	1108	145.65
500	71	RSKMN	3057	1190	145.36
501	369	GRPVN	8231	343	145.04
502	1928	WLSPT	1002	601	145.01
503	1314	WCOLO	1315	1621	144.70
504	2504	DALWT	2991	1210	144.25
505	1950	BNDRA	0003	801	143.85
506	1822	PCUST	2011	2211	143.85
507	2144	ATHNW	1405	957	143.84
508	379	WEBBS	8622	1806	143.77
509	1317	FRMBR	1853	265	143.67
510	1309	FERIS	1103	838	143.51
511	1237	MDLNE	0172	1219	143.48
512	351	TRPMN	4094	639	143.30
513	2033	FRMBR	1805	743	143.10
514	2140	DENDR	0006	48	143.08
515	1689	BRHLW	7621	2237	143.06
516	1422	BRLSN	2051	1208	142.84
517	204	IVANS	1612	966	142.81
518	2368	PTENN	2355	97	142.66
519	246	GNSVL	1203	1620	142.50
520	1563	KLNPS	1101	2250	142.46
521	2405	MESTE	1202	778	142.36
522	1997	WSOTH	1020	1137	142.31
523	1025	ITSCA	1701	735	142.17
524	1687	ARTHR	0462	1050	141.76
525	1833	PREST	1602	1283	141.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
526	869	WMRLD	0006	555	141.69
527	976	AMMFG	5621	541	141.31
528	1954	OKLND	0001	829	141.27
529	2355	RYSSW	2802	3145	141.27
530	598	TYEST	1501	1597	141.01
531	2125	OKLND	0002	1180	140.90
532	450	STHRL	0001	704	140.82
533	177	KRUMS	1202	191	140.74
534	47	TYLNE	1607	647	140.66
535	658	ABRRD	0004	733	140.28
536	917	MEXIA	4008	744	139.52
537	72	HURST	1831	1333	139.44
538	1259	TYBLR	2805	1912	139.16
539	2516	BRIRV	6922	3138	139.08
540	381	FERIS	1101	1065	139.06
541	695	OVRTN	4037	116	138.97
542	1701	GRMES	0511	1201	138.56
543	422	LFEST	1902	1506	138.55
544	2671	FRNKF	0008	1160	138.47
545	619	LOMAL	0006	1123	138.34
546	138	ELKTN	2508	1224	138.22
547	409	GLNHV	3973	1232	138.20
548	1983	WDGWD	1541	1124	137.87
549	107	BLVUE	1111	379	137.54
550	1130	PLSTH	1304	1275	137.54
551	1363	BSPRW	2511	717	137.50
552	1991	BNTDR	0001	1180	137.16
553	1639	CUMBY	1201	716	136.86
554	163	GSTHW	1631	1591	136.70
555	951	WFNTH	0232	573	136.70
556	306	STHRL	0004	1203	136.67
557	894	WHOUS	4128	330	136.12
558	1462	WNRTH	1421	1416	135.71
559	2117	LOMAL	0016	643	135.68
560	338	MSHLN	0001	1037	135.36
561	1647	TRSES	1202	511	135.31
562	121	PLSTN	1001	1668	135.31
563	1253	PCUST	2007	1444	135.30
564	1161	IRVGS	1901	1367	135.12
565	932	TERSO	2501	146	134.49
566	2002	TMNTH	1605	1679	134.48
567	1560	MRDCK	0003	1203	134.36
568	2568	ENTOH	0005	1031	134.04
569	1040	BRNAV	0723	1318	133.98
570	880	NCSFA	1702	851	133.96
571	849	RWALL	1202	2237	133.76
572	1989	CDHIL	1613	1449	133.58
573	187	ELCTR	1211	263	133.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
574	359	BLTON	1803	403	132.80
575	1244	CRLTN	1401	803	132.79
576	1386	LOMAL	0001	673	132.61
577	1410	KLNCC	1703	4255	132.01
578	1548	GNSVN	1403	275	131.96
579	334	CMTSW	0934	1482	131.78
580	739	WHITE	3512	1246	131.66
581	1523	DCDAM	2001	1083	131.58
582	613	IRVNG	1403	528	131.55
583	721	PSHIL	1604	1122	131.13
584	1805	EULES	8712	1002	131.11
585	1305	RWALS	1851	2287	130.95
586	2099	MESQW	1802	777	130.76
587	307	GRDPR	0811	1174	130.60
588	1063	VENSW	2603	26	130.46
589	2095	ENTOH	0007	804	130.37
590	2093	CDCSW	0006	1278	130.34
591	920	CPRCV	1406	1305	130.20
592	1907	LKWOD	7411	596	130.12
593	1899	HLSES	0533	1228	130.04
594	2513	HKBRY	1105	168	130.04
595	235	LWRDR	0003	1692	130.00
596	128	CLBNR	1404	1177	129.83
597	1580	TYLGE	1308	1542	129.82
598	552	HUDSN	1605	1682	129.82
599	1362	ALVDO	1902	1059	129.69
600	743	HDWLK	3001	929	129.54
601	580	CRNDL	2403	835	129.36
602	98	SSPNE	1401	1188	129.30
603	192	LMESA	2813	116	129.17
604	2685	ALPHA	0001	417	129.03
605	124	SYCRK	4512	1807	128.86
606	2068	RWDHV	1903	595	128.82
607	2408	RSPCK	2132	125	128.58
608	2118	BSPRG	1905	1474	128.50
609	818	FSCRK	6713	2908	128.45
610	737	AYERS	4411	1124	128.36
611	2335	CMTSW	0973	1140	128.36
612	1864	ENSSO	2001	219	127.97
613	2193	FSTVW	0008	2079	127.61
614	759	NCDCH	1203	1563	126.89
615	380	SCHRD	0007	1309	126.59
616	1538	BLMND	3241	217	126.38
617	383	WDGWD	1512	827	126.34
618	1329	CDHIL	1623	1608	126.32
619	468	JREST	2102	953	126.04
620	1324	HORNE	1972	713	125.79
621	592	JKWST	4033	748	125.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
622	2231	HNYGR	2401	548	125.27
623	1456	MESFR	2104	148	125.26
624	456	CRLTR	2002	2438	124.75
625	1770	TYLER	1012	1727	124.65
626	147	NCDCH	1205	1017	124.52
627	335	EZACH	0004	1044	124.36
628	227	RWALL	1203	3032	123.85
629	300	TATSP	4322	2225	123.77
630	2234	CRLTN	1453	299	123.67
631	1542	ARLNG	1261	1369	123.66
632	1591	BOWEN	3181	820	123.40
633	783	GMINI	5821	2997	123.38
634	2691	ATNRN	3412	2535	123.32
635	1844	BLMED	1620	1855	123.23
636	990	RCHRD	1205	873	122.97
637	394	TEGMN	3038	1722	122.86
638	258	TROYS	1013	1029	122.74
639	2345	OKCLS	0006	1070	122.70
640	1998	BLMED	1622	974	122.69
641	117	TYEST	1507	1183	122.54
642	441	STHRL	0007	327	122.48
643	1605	BLKST	1732	1290	122.29
644	1420	ESTLD	3621	1439	122.18
645	1097	MTLDA	0001	2241	121.51
646	1069	CLBWS	8121	1234	121.42
647	2440	TYOMN	1411	296	121.42
648	2357	PLGRV	0004	1588	121.31
649	96	RECCR	0006	377	121.21
650	389	BEAST	4084	1597	121.14
651	108	GRDPR	0842	1210	121.13
652	308	RSNHT	1131	2683	121.08
653	668	LIGSW	1604	618	121.07
654	54	SHSTH	1303	679	121.03
655	2479	ARMST	0001	784	121.02
656	610	BDFRD	8822	1051	120.88
657	1073	COLNY	2401	727	120.56
658	609	JKSNR	4111	414	120.56
659	1485	BLTLN	0003	496	120.51
660	591	FHLSW	1372	1006	120.32
661	1180	VGCRK	8031	1748	119.85
662	1646	DESHR	1204	591	119.57
663	1972	LFEST	1901	1008	119.51
664	701	EDGCF	2223	2861	119.48
665	158	TXHRV	1621	128	119.14
666	122	LGVST	8521	1624	119.06
667	999	SGOVL	1402	861	118.85
668	233	IRVHF	2305	1411	118.61
669	134	CRNTH	2401	2873	118.51

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
670	249	LKMNT	0003	546	118.48
671	1609	HUTCH	1501	811	118.44
672	1240	FSTVW	0001	368	118.21
673	1549	PPARK	1801	1264	118.18
674	137	SBEAN	6011	97	118.06
675	2102	FROKS	0003	486	118.05
676	1355	ELKTN	2506	1713	117.99
677	1650	TATSP	4323	2477	117.55
678	927	CRANE	0321	11	117.55
679	963	RNRDK	1508	3803	117.48
680	2353	WALST	0009	720	117.43
681	420	LFEST	1904	1288	117.03
682	1154	CRANE	0311	693	116.92
683	741	PLKST	0001	725	116.89
684	1196	LVOAK	1601	736	116.70
685	574	TYOMN	1409	1459	116.52
686	874	ATHNS	1203	970	116.35
687	1177	PPARK	1803	993	116.23
688	1654	LVOAK	1602	791	116.16
689	2316	MRLNS	4002	332	116.14
690	2241	BRKRG	0213	1433	116.08
691	12	ALEDO	9421	1128	115.72
692	1159	IRVNG	1408	1036	115.62
693	421	CLLVL	0001	54	115.59
694	2360	FSTVW	0003	1806	115.06
695	981	HUDSN	1604	991	114.89
696	532	CNTRY	2831	525	114.79
697	68	BONHM	1202	888	114.73
698	2026	GLNHV	3931	1303	114.67
699	52	BNDRA	0007	604	114.51
700	1809	BLTON	1805	1199	114.47
701	799	BLKST	1781	1912	114.33
702	109	CRNTH	2405	2778	114.26
703	1850	GSTHW	1692	704	114.24
704	255	WHTRK	0004	1127	114.05
705	800	KLRPR	9011	2550	113.92
706	2152	WTAUG	4643	1201	113.90
707	1521	DCATR	1202	1804	113.84
708	2071	HMPHL	2762	1032	113.63
709	430	LNDAL	2203	1962	113.38
710	269	LIPAN	1301	500	113.09
711	1619	WLSPT	1001	1814	113.03
712	1292	SCHRD	0001	1382	113.00
713	2431	LMBLN	0001	1953	112.85
714	767	SHNRW	1607	423	112.85
715	2686	NPKWY	0009	3956	112.83
716	1696	FRNKF	0002	867	112.81
717	1503	GLNHV	3963	1892	112.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
718	69	TMPTV	2405	467	112.78
719	1943	RWDHV	1907	760	112.67
720	462	REGST	0002	227	112.65
721	1945	DALRK	1301	686	112.54
722	1019	VLYRN	2953	2993	112.08
723	512	PKRVL	1052	2080	111.93
724	1780	KILEN	1204	1497	111.86
725	2601	RRSTH	1704	2494	111.62
726	1436	PRSTN	0004	649	111.54
727	1635	TLRWT	2201	1177	111.46
728	1312	KMASB	1721	110	111.05
729	1957	MEXIA	4012	1110	110.93
730	1880	MKNNY	1251	1316	110.83
731	692	MAYFD	5521	3044	110.63
732	103	SMFLD	2381	843	110.62
733	812	PERIN	1511	609	110.61
734	43	RYLTY	1421	435	110.28
735	1304	NCDSW	3813	375	110.28
736	139	SNDHL	3821	66	110.02
737	889	HLTOM	2472	1759	109.70
738	1110	WITTS	1705	392	109.55
739	980	PAYSW	1213	1428	109.36
740	78	ARPMN	4147	598	109.34
741	918	DEALY	0004	1283	109.27
742	1459	RWALL	1204	1007	109.09
743	2485	CRTLD	4722	2878	109.01
744	2296	MSHLN	0004	1244	108.93
745	415	ABRRD	0002	1293	108.82
746	2121	FINKS	1803	1184	108.54
747	1088	RDOAK	1304	2294	108.51
748	732	ALNTH	2832	882	108.50
749	2655	ARMST	0005	1475	108.17
750	1750	PLANO	1101	388	108.16
751	200	TYSTH	1206	1264	107.84
752	1474	CLYVL	9312	968	107.74
753	1032	SYCRK	4521	3182	107.67
754	824	NCSTH	1503	891	107.59
755	436	WEBBS	8614	1086	107.59
756	680	WALST	0010	324	107.53
757	1417	MRTSP	1501	1124	107.44
758	1245	WHOUS	4122	2052	107.44
759	1479	NCRST	2201	1775	107.36
760	2194	GLNHV	3953	1794	107.23
761	652	CPLSO	4312	1456	107.07
762	2246	RICES	0208	636	106.83
763	912	SSPNE	1402	66	106.70
764	1100	WNRTH	1417	1363	106.48
765	1263	LNGLK	1602	426	106.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
766	1031	FORSW	2051	2266	106.27
767	1623	PLSTH	1305	837	106.19
768	1573	LOMAL	0011	1113	105.78
769	1142	KEENE	1503	813	105.76
770	170	WELRD	0002	724	105.52
771	1124	SMPST	0002	643	105.31
772	1134	HORNE	1991	1324	105.29
773	1043	LUFKN	1205	1304	105.28
774	578	SHAMP	0004	781	105.26
775	1199	DESPR	1403	1755	105.24
776	1821	OKLND	0003	1199	104.91
777	2518	CRLTR	2054	360	104.81
778	1405	DUVAL	0462	884	104.78
779	226	SMFLD	2352	611	104.65
780	600	DUBLN	2214	712	104.54
781	2005	MESQT	1302	1323	104.25
782	688	RCHHL	0374	1611	104.25
783	1759	NCWDN	1111	643	104.12
784	713	WICKT	0411	113	104.12
785	1936	JSHUA	1302	1200	103.98
786	2082	MCGRG	0775	400	103.74
787	966	BARRY	1802	271	103.66
788	150	CLBNR	1406	94	103.63
789	2334	PCOIT	1022	2056	103.58
790	959	EULES	8722	2034	103.36
791	396	PRSTN	0008	732	103.35
792	2021	BKWST	0001	383	103.28
793	596	CDCSW	0005	1725	103.19
794	340	MABNK	2402	948	102.99
795	2085	SWTWR	1341	372	102.97
796	1460	PLSTH	1301	694	102.95
797	771	ARLNG	1241	589	102.94
798	2443	WSTHL	3631	1993	102.51
799	1838	STAUG	0002	1287	102.46
800	27	BONHM	1206	2084	102.36
801	2162	DGNST	0003	262	102.32
802	1527	RSPVY	1704	1265	102.14
803	452	SMOUR	0721	24	102.13
804	1628	CLKVL	1202	1146	101.98
805	1775	MRSES	4005	774	101.83
806	2588	GRLRD	0002	987	101.81
807	946	MRTNS	1501	469	101.79
808	302	PRSTN	0006	667	101.58
809	191	IRVVV	2853	4148	101.36
810	1535	SANSM	3911	1191	101.29
811	2489	LOMAL	0010	1553	101.26
812	525	CRSCN	1205	803	101.25
813	747	AZLES	2111	1576	101.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
814	1361	IRVGS	1903	610	101.01
815	1984	HSKAV	0002	1609	100.85
816	448	TSLVL	4002	2198	100.72
817	1536	DALRK	1326	3967	100.48
818	1030	WHTRK	0001	2192	100.04
819	2383	WALST	0003	129	100.02
820	2596	BLNKT	0701	248	100.00
821	835	FARON	4041	1018	99.94
822	178	REAST	1505	342	99.77
823	617	CNI45	1202	778	99.75
824	466	PCOIT	1001	1220	99.63
825	1995	NLNVL	2001	103	99.28
826	1566	FSHSW	2121	1166	99.23
827	31	VALVW	1802	404	99.17
828	1105	CNTRY	2851	1410	99.12
829	475	MRTSP	1504	664	99.02
830	848	CRLJL	1508	285	98.58
831	1868	HSKAV	0004	1079	98.37
832	2541	TNPON	0001	75	98.29
833	265	TYLER	1005	1957	98.12
834	1497	GLSCK	2411	128	97.98
835	445	GODLY	1601	1023	97.86
836	627	ODNTH	2014	674	97.70
837	222	TERSO	2503	1612	97.64
838	2078	IRVND	1205	190	97.64
839	637	NCSTH	1506	86	97.40
840	753	TMPNW	1105	1010	97.34
841	937	PLSTN	1002	1192	97.28
842	1576	SORCY	0004	583	97.20
843	1004	ATHNW	1404	1586	97.19
844	1037	IRVBL	2505	482	97.15
845	2198	WWDWY	2015	1113	96.88
846	304	ABRRD	0008	770	96.60
847	1396	SSPNG	1203	793	96.45
848	540	KLBRG	0004	939	96.44
849	1171	RCHHL	0384	680	96.36
850	2647	ENTOH	0006	1511	96.25
851	1048	PCUST	2004	1056	96.15
852	1425	CRLTN	1402	507	96.00
853	973	AYERS	4431	1473	95.96
854	1632	PREST	1603	1496	95.86
855	1845	GRDPR	0862	948	95.80
856	2291	CNSES	3054	1548	95.73
857	143	CLINA	4201	897	95.69
858	728	VANSB	1502	1609	95.61
859	1337	TATSP	4313	1351	95.56
860	217	CDMIL	2401	550	95.55
861	1473	GRNGR	1801	880	95.54

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
862	694	GODRD	8171	818	95.52
863	1090	KILEN	1202	625	95.13
864	1349	KFMNW	1202	777	95.08
865	1610	RNDRK	1501	570	95.01
866	1553	EULSO	9112	1092	94.94
867	252	NCRST	2204	921	94.84
868	1679	HSKAV	0008	776	94.65
869	22	BRKTN	1201	501	94.47
870	1488	ATHNS	1201	940	94.24
871	1557	EUSTC	2402	666	94.08
872	1709	GRDPR	0871	1445	94.02
873	754	BRCRK	6514	1333	93.96
874	1331	ODESW	5211	2136	93.63
875	485	NCNTH	1804	689	93.42
876	1740	ALVDO	1901	1006	93.41
877	1148	MNWLL	1206	1089	93.28
878	1581	MESWE	3611	1667	92.93
879	556	AZLES	2112	1288	92.93
880	2458	CRSWS	1403	1775	92.86
881	952	ATHNW	1403	2164	92.67
882	2228	RCLNS	1407	1684	92.50
883	500	GRDPR	0831	1187	92.07
884	1511	DCATR	1204	605	91.93
885	1215	PSHIL	1608	1858	91.92
886	1281	CRTLD	4721	3414	91.75
887	9	ROANW	9511	1357	91.68
888	1080	RSPCK	2104	1792	91.62
889	464	GLNHV	3911	1337	91.62
890	2593	THRNE	0005	1162	91.48
891	539	CHICW	1302	193	91.09
892	2494	EMPCT	0004	349	90.78
893	563	WMRLD	0001	470	90.64
894	935	HKBRY	1104	176	90.55
895	1078	HLSBR	1204	542	90.31
896	1931	PLGRV	0001	1148	90.17
897	225	ARCTY	1311	447	89.97
898	1178	TMPNW	1103	248	89.95
899	1024	BRGPR	1101	650	89.92
900	162	CNTRY	2811	2447	89.33
901	1896	FSCRK	6723	2896	89.33
902	746	BNTDR	0002	1613	89.16
903	349	ROANW	9512	1789	89.16
904	61	CLMET	0004	1576	89.13
905	2727	DFWNW	2602	42	89.02
906	1348	HLSES	0553	1793	89.00
907	1318	SSPNG	1204	906	88.98
908	377	MAYFD	5524	3024	88.93
909	1607	KLBRG	0001	1518	88.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
910	1829	SGOVL	1404	2072	88.89
911	996	CNTRY	2823	1777	88.70
912	1865	REYST	4118	724	88.70
913	2473	THRNE	0004	790	88.69
914	1783	CRTLD	4732	3747	88.64
915	1095	KILEN	1205	1259	88.56
916	2589	PRCTR	1601	201	88.51
917	495	NCNTH	1802	1218	88.33
918	199	TYOMN	1405	1544	88.31
919	1256	COLNY	2402	2379	88.24
920	888	EULES	8714	3232	88.21
921	2067	REAST	1501	301	88.17
922	2081	WWEST	1219	924	88.05
923	1452	IRVNE	1303	1386	87.95
924	899	NCNTH	1801	2073	87.92
925	1615	WATSN	5342	1626	87.84
926	1510	CRNRD	0002	312	87.44
927	1450	WSTHL	3613	2739	87.39
928	219	NCDSW	3811	1390	87.37
929	N/A	RNKSW	5412	25	87.00
930	313	TXHRV	1611	155	86.99
931	706	GAVSW	0009	1050	86.98
932	1011	NYLDV	1202	136	86.83
933	1529	BEAST	4082	515	86.82
934	494	NWARD	3511	53	86.81
935	2452	DNISN	1206	899	86.79
936	850	KIMBL	5021	2330	86.53
937	247	OAKHL	3052	752	86.26
938	2712	ALLEN	2405	138	86.24
939	237	CHSPR	2401	2504	86.04
940	1722	BRCRK	6543	1441	85.97
941	1872	WMMMR	2707	1511	85.86
942	2315	PPARK	1806	23	85.83
943	1016	MABNK	2403	1551	85.80
944	92	MCGRG	0776	207	85.66
945	1664	NMAIN	0282	600	85.24
946	2281	NHNSW	0005	441	85.13
947	1451	EULSO	9132	1705	84.67
948	2037	CHROW	0005	164	84.55
949	N/A	CLNSE	4201	914	84.50
950	1465	EGFRD	0001	1668	84.07
951	544	CMPST	0003	225	84.02
952	2708	HORNE	1933	1979	83.96
953	1915	KLELM	2205	2755	83.71
954	1065	RICES	0206	580	83.68
955	1774	BKBNT	1832	184	83.65
956	924	LKWOD	7442	856	83.61
957	905	SPRTN	1802	870	83.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
958	1454	MAPLE	0007	95	83.51
959	10	CRNTH	2406	1279	83.45
960	1093	NPKWY	0014	2998	83.42
961	768	WDGWD	1592	1170	83.37
962	1369	MCWHT	3511	2880	83.10
963	2261	MESFR	2102	599	83.01
964	1345	WHTRK	0003	1179	83.00
965	975	CMTSW	0925	1317	82.96
966	273	POYNR	1201	340	82.91
967	1643	TRLWD	7712	3650	82.82
968	1785	CRLCC	2703	703	82.77
969	357	HSKAV	0005	1359	82.69
970	169	KNEDL	6311	2162	82.48
971	2772	WALST	0008	16	82.44
972	2445	FSCRK	6721	3189	82.37
973	1327	ALLEN	2404	2052	82.31
974	1784	ARTHR	0441	1671	82.30
975	859	PARIS	1202	1191	82.22
976	890	CMNCH	1402	1193	82.13
977	2088	WDGWD	1531	1634	82.13
978	654	CRLUD	1305	1326	82.00
979	196	MNFLD	2682	1931	81.85
980	173	RWALE	3321	2869	81.74
981	955	RDLML	2542	1304	81.67
982	1207	TRNTH	1503	1689	81.43
983	2239	PRKWY	1532	1949	81.14
984	2086	BDFRD	8841	816	81.13
985	742	MASON	3421	201	80.96
986	1406	OAKHL	3062	2079	80.83
987	2634	HLTOM	2411	1337	80.66
988	325	FRMNT	0009	1630	80.63
989	1882	RSPCK	2108	966	80.41
990	105	HMTRD	0002	1700	80.38
991	352	WELRD	0003	484	80.37
992	1922	LMESA	1531	1222	80.34
993	1262	CAMRN	1201	1010	80.28
994	1504	CNTRY	2813	2986	80.17
995	1379	LKHLD	0001	1482	80.06
996	362	KYSTN	1011	57	79.89
997	85	PLSTN	1004	1537	79.86
998	132	SACRC	5521	96	79.83
999	1075	DAVIS	3741	1191	79.81
1000	1442	KMASB	1711	315	79.73
1001	1825	JDKNS	0821	37	79.65
1002	657	HURST	1882	1843	79.36
1003	1046	WMRLD	0004	1467	79.18
1004	2160	EZACH	0005	554	79.17
1005	2104	MESTE	1205	1611	79.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1006	2646	RECCR	0005	154	78.98
1007	561	PRFTW	4221	2427	78.89
1008	400	RHOME	2402	1194	78.86
1009	1533	MRKLY	0811	133	78.83
1010	1743	WEAST	0616	473	78.80
1011	1128	GSTHW	1641	83	78.73
1012	1667	TMPLE	1205	2409	78.73
1013	386	AYERS	4421	1446	78.60
1014	1641	TYLNE	1613	139	78.42
1015	437	IRVNE	1302	411	78.39
1016	1389	GLNHV	3983	1112	78.19
1017	843	NHNSW	0002	645	77.98
1018	549	LOMAL	0015	340	77.91
1019	646	TYWST	2001	2001	77.89
1020	1121	HMPHL	2733	95	77.88
1021	1210	PFFRD	3472	1272	77.88
1022	564	SALDO	3003	513	77.56
1023	877	CAMRN	1202	1494	77.54
1024	675	IRVNR	1501	861	77.54
1025	2470	DAVIS	3723	330	77.47
1026	2154	MCDMT	2554	2239	77.31
1027	2284	DAVIS	3752	523	77.30
1028	80	HDWLK	3005	905	77.29
1029	229	STAUG	0004	1087	77.25
1030	93	CRSWS	1401	1216	77.23
1031	854	PALRD	2206	1472	77.23
1032	1492	HUTCH	1505	1632	76.96
1033	1816	KNEDL	6342	532	76.95
1034	1901	CDHCR	2050	736	76.87
1035	671	DNCNV	1903	1155	76.70
1036	2664	WDGWD	1561	1460	76.68
1037	2663	LAVON	1402	63	76.67
1038	1002	IRVNG	1405	1119	76.63
1039	716	SSPNG	1205	899	76.61
1040	1173	SMFLD	2313	2160	76.58
1041	1089	RRSTH	1706	2866	76.48
1042	256	ALLNC	6412	2248	76.33
1043	213	EDDYS	0712	1259	76.32
1044	1806	GRDPR	0852	1240	76.17
1045	1603	MESTE	1206	1239	76.09
1046	142	LKHLD	0003	1339	75.86
1047	682	BLKST	1721	996	75.73
1048	2715	AMLIA	0003	18	75.67
1049	2175	WNRTH	1419	310	75.64
1050	2643	ALPHA	0009	61	75.48
1051	1307	SHMNE	1405	785	75.36
1052	1424	RNDRK	1509	3970	75.23
1053	1467	INAIR	1413	1078	75.08

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1054	254	KERNS	2402	326	74.91
1055	579	HMTRD	0004	1019	74.91
1056	2448	MNWLL	1203	782	74.89
1057	361	TYSTH	1209	819	74.89
1058	766	HHSTH	1503	1527	74.87
1059	521	BNBRK	4111	2847	74.82
1060	1658	MESTE	1213	1390	74.61
1061	1625	MESQT	1305	1137	74.58
1062	5	RYLTY	1411	134	74.54
1063	198	WINKS	0531	88	74.33
1064	314	WXNTH	2306	1248	74.31
1065	116	ELMAR	3221	104	74.30
1066	272	CLBRN	1206	1373	74.24
1067	2213	CANTN	1302	1305	74.08
1068	1926	GRAHM	0713	409	74.03
1069	1266	DALWT	2962	427	74.01
1070	168	CRSGL	1306	1345	74.00
1071	597	ELGIN	1002	1950	73.95
1072	1962	CNSES	0750	1109	73.94
1073	220	ARMST	0011	563	73.87
1074	548	ENNIS	1902	1200	73.85
1075	518	IRVGS	1905	686	73.82
1076	1640	MESTE	1209	548	73.79
1077	1365	PPARK	1805	491	73.52
1078	2612	HMPHL	2792	411	73.43
1079	1397	EULSO	9111	1664	73.37
1080	496	DCVSO	1101	1445	73.36
1081	1114	DALWT	2982	974	73.25
1082	318	CRLUD	1304	1112	73.23
1083	1887	AMMFG	5611	786	73.18
1084	884	LMBLN	0008	111	73.17
1085	1517	LAVON	1401	1616	73.16
1086	605	IRVBL	2504	1566	73.10
1087	1815	SHDYG	7841	376	73.05
1088	N/A	ROBNW	1503	1486	72.87
1089	1694	CRNES	2711	133	72.82
1090	384	DESHR	1202	1452	72.67
1091	1116	COMSO	1401	582	72.58
1092	1545	TYBLR	2801	1280	72.44
1093	364	BRCRK	6521	1425	72.44
1094	2702	BLTSW	3203	1052	72.31
1095	821	JKSNR	4109	696	72.29
1096	1734	BOWEN	3112	895	72.18
1097	1811	TRSES	1201	497	72.14
1098	2126	LKHLN	0004	1245	72.10
1099	651	MSLMN	4131	112	72.07
1100	1384	PCOIT	1023	1991	72.01
1101	1291	CRLTN	1452	308	72.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1102	336	CNTRY	2822	2749	71.89
1103	106	PSHIL	1601	1854	71.86
1104	303	IRVNR	1508	1927	71.84
1105	1622	ARLNG	1212	129	71.80
1106	836	NCDCH	1206	1078	71.79
1107	2295	BLMND	3262	123	71.76
1108	2339	MURPH	2752	2079	71.61
1109	2659	LKMNT	0001	197	71.53
1110	243	TYEST	1509	378	71.53
1111	2498	BRYAN	0005	2700	71.50
1112	2349	ABRRD	0003	331	71.44
1113	1554	TRIRA	6222	619	71.42
1114	1748	WRBND	2312	1462	71.41
1115	1673	MNHNS	1912	1648	71.40
1116	2329	DNIWS	1602	1364	71.37
1117	2252	JUDCT	0006	1083	71.31
1118	1525	CDHCR	2052	1190	71.18
1119	769	CRISP	1501	679	71.13
1120	205	WMMMR	2706	77	70.90
1121	844	MRVLY	2311	380	70.88
1122	159	WELRD	0006	682	70.83
1123	2338	CRKET	2401	143	70.80
1124	2487	WALST	0001	189	70.68
1125	1047	ALNSW	2654	2418	70.67
1126	994	WITTS	1703	1510	70.67
1127	1076	GRFRD	1002	375	70.63
1128	1934	CRLFR	2155	1096	70.55
1129	1699	MESQT	1307	514	70.32
1130	686	TAYLR	1204	1659	70.25
1131	615	CDHCR	2053	1414	70.23
1132	2114	MESQT	1301	1097	70.19
1133	923	BDFRD	8812	778	70.19
1134	763	MKNNY	1201	1255	70.18
1135	1107	INAIR	1411	1972	70.09
1136	502	TYBLR	2804	2364	70.08
1137	589	BRNAV	0711	1235	69.94
1138	621	PLSTN	1003	1372	69.85
1139	1411	BNDRA	0004	716	69.81
1140	245	DAVIS	3713	867	69.79
1141	289	KNLTR	0001	2098	69.68
1142	2035	MDLNW	1592	1426	69.61
1143	474	BLTLN	0002	875	69.59
1144	1808	HSKAV	0003	1317	69.53
1145	2325	RGLRW	0004	74	69.50
1146	689	HMTRD	0003	395	69.25
1147	1859	FORSN	5611	215	69.25
1148	1691	BRNAV	0732	741	69.22
1149	1795	BRNWD	1206	1847	69.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1150	910	EDGCF	2231	748	69.17
1151	1120	WXHCH	1204	1479	69.14
1152	942	ALNTH	2851	1944	69.11
1153	395	FSCRK	6732	2188	69.07
1154	565	RCHHL	0342	977	68.86
1155	206	WSTHL	3642	3365	68.82
1156	1540	MESQW	1801	2073	68.82
1157	2736	GAVSW	0006	516	68.73
1158	1326	TAYLR	1201	1451	68.73
1159	1782	PFFRD	3452	638	68.65
1160	1006	WHOUS	4121	1083	68.48
1161	2591	GRLRD	0001	1750	68.46
1162	2403	WTAUG	4632	1145	68.39
1163	1082	WHITE	3522	1628	68.21
1164	872	OAKHL	3082	1396	68.17
1165	971	GRDPR	0881	1964	68.15
1166	444	WSOTH	1018	1260	68.10
1167	830	DALWT	2952	600	68.10
1168	2111	BSPRW	2521	1748	68.03
1169	626	TLRWT	2203	766	67.99
1170	756	NCDCH	1201	661	67.93
1171	816	IRVNG	1407	1437	67.91
1172	440	OKCLS	0004	1426	67.89
1173	1448	STNVL	1206	2155	67.88
1174	1911	WFALS	0133	1656	67.85
1175	339	VGCRK	8021	206	67.83
1176	1608	HLSES	0542	1106	67.77
1177	1685	SSPNG	1201	1080	67.69
1178	731	MABNK	2404	2389	67.55
1179	1234	PRCRK	0001	171	67.37
1180	911	MESQN	1503	1857	67.34
1181	1034	ALLNC	6421	15	67.33
1182	862	CMPST	0001	444	67.30
1183	2574	DALWT	2911	301	67.26
1184	1879	ARCTY	1321	894	66.99
1185	154	SHMNE	1401	1223	66.85
1186	1236	HLSES	0522	1191	66.65
1187	782	LNDAL	2202	1042	66.59
1188	2324	CMTSW	0952	560	66.59
1189	2653	WHITE	3532	1173	66.53
1190	1214	SANSM	3921	3698	66.49
1191	428	WWDWY	2022	981	66.43
1192	174	BRNAV	0753	1280	66.38
1193	2411	ARLNG	1223	1513	66.32
1194	317	LOT69	3023	862	66.31
1195	327	AZLES	2122	1984	66.10
1196	527	MDWCK	0007	1059	66.09
1197	1118	WMRLD	0008	1531	65.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1198	371	WNDWD	3641	1435	65.91
1199	1867	PRKRW	3362	1061	65.87
1200	2109	BRHLW	7642	880	65.83
1201	925	RDOAK	1301	3415	65.76
1202	1547	WHTRK	0007	1226	65.75
1203	1250	CAMRN	1203	1173	65.64
1204	2521	MDWPK	9221	497	65.62
1205	845	CPLSO	4311	125	65.59
1206	1921	MESFR	2101	1864	65.57
1207	2524	WFALS	0163	352	65.56
1208	N/A	SHLMT	1801	313	65.50
1209	567	MRLNS	4003	976	65.49
1210	1532	DAVST	0006	1092	65.49
1211	982	KIMBL	5011	1155	65.45
1212	1541	GRAHM	0711	1630	65.38
1213	1565	CRSCN	1206	1646	65.37
1214	883	WHTRK	0002	1393	65.26
1215	1765	MESQT	1303	1809	65.23
1216	305	LMESA	1561	2053	65.21
1217	2436	WSANG	2802	626	65.20
1218	683	THRNE	0001	1327	65.19
1219	1295	LKHLD	0007	1208	65.14
1220	151	MDTHN	1703	979	64.92
1221	240	TROYS	1014	703	64.86
1222	1904	DESPR	1404	553	64.79
1223	1205	MNWLL	1204	274	64.51
1224	803	SCYEN	0003	1209	64.49
1225	842	HORNE	1992	209	64.49
1226	2058	PREST	1601	1029	64.39
1227	2314	MRSES	3016	40	64.38
1228	929	IRVBL	2501	487	64.22
1229	261	LWRDR	0002	981	64.22
1230	632	TMSTH	1408	746	64.15
1231	950	NIPAK	1001	126	64.14
1232	985	ROSCO	2921	219	63.92
1233	730	SMFLD	2333	1009	63.91
1234	614	LMBLN	0004	45	63.91
1235	630	OAKHL	3072	2279	63.85
1236	1278	TMSTH	1402	2188	63.84
1237	2060	GAVSW	0008	121	63.80
1238	2229	JKSBR	1401	909	63.80
1239	745	REYST	4051	1095	63.71
1240	372	WSOTH	1019	727	63.68
1241	2010	OKLND	0004	1736	63.61
1242	1897	CLBWS	8111	1278	63.50
1243	998	DNCNV	1901	879	63.48
1244	2139	BRNAV	0784	2281	63.39
1245	385	CHROW	0004	186	63.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1246	1399	SHDYG	7822	495	63.25
1247	1721	GRPVN	8223	1971	63.22
1248	2192	EULSO	9121	1296	63.22
1249	1982	BRTL	1402	109	63.21
1250	2519	MURPH	2753	2786	63.20
1251	588	GSTHW	1623	717	63.17
1252	1367	PRKWY	1511	927	63.06
1253	2288	WDGWD	1513	837	63.04
1254	1723	PREST	1604	1206	62.93
1255	1813	PCUST	2009	2258	62.92
1256	2690	BKWST	0004	720	62.90
1257	1807	EULSO	9131	1926	62.83
1258	2008	COTRD	0005	220	62.80
1259	1350	DAVIS	3711	658	62.75
1260	864	GRPVN	8212	3849	62.74
1261	1407	BRLSN	2052	2576	62.65
1262	773	IRVNG	1404	1386	62.45
1263	2739	GSTHW	1672	12	62.42
1264	1008	DIBOL	1506	618	62.34
1265	2083	KNLTR	0008	904	62.29
1266	2110	GRMES	0521	506	62.29
1267	978	SHNRW	1609	1412	62.07
1268	1185	SIKES	2421	1100	62.04
1269	715	NCDCH	1204	1138	61.96
1270	407	BOWEN	3161	1455	61.94
1271	285	MURPH	2751	2522	61.89
1272	411	RBNSN	2502	1160	61.77
1273	1325	RKDLE	1301	1204	61.76
1274	2472	HURST	1841	162	61.56
1275	2210	FRNKF	0006	2141	61.52
1276	2540	PROAD	0006	120	61.48
1277	2404	ENNIS	1906	1992	61.38
1278	1277	IRVNE	1309	1124	61.28
1279	298	EULES	8723	3292	61.22
1280	2237	LWSNR	2242	1295	61.15
1281	2457	KNLTR	0005	2416	61.08
1282	497	WMRLD	0002	1889	60.97
1283	2009	GSTHW	1691	22	60.95
1284	2203	BLMED	1621	1466	60.89
1285	2199	BLMED	1619	946	60.83
1286	1929	PWEST	1311	763	60.78
1287	727	MSTLT	1073	217	60.71
1288	1589	TYOMN	1408	1321	60.68
1289	708	MSHLN	0002	656	60.58
1290	1394	PJPTR	3221	31	60.58
1291	426	ELCTR	1221	136	60.40
1292	2182	TYSTH	1203	422	60.37
1293	1430	LOMAL	0012	663	60.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1294	2218	SGOVL	1403	1876	60.33
1295	1472	DCVSO	1104	1309	60.31
1296	535	WBOSE	1103	817	60.28
1297	853	TATSP	4311	1835	60.22
1298	1360	FRMBR	1801	1237	60.19
1299	1230	BRCRK	6513	1154	60.14
1300	2614	HORNE	1923	1529	60.11
1301	454	IRVGS	1902	1513	60.07
1302	723	HOWRD	3911	34	60.03
1303	1373	HUTCH	1502	215	60.00
1304	236	GDNVL	1201	43	59.86
1305	2065	MESTE	1204	1702	59.85
1306	2582	CHROW	0008	84	59.82
1307	1851	REGST	0003	918	59.76
1308	2389	SIKES	2411	1826	59.74
1309	788	VANAL	1201	559	59.66
1310	902	CKRHL	0005	1198	59.46
1311	551	GRLND	1605	1380	59.37
1312	1010	ALPHA	0013	449	59.29
1313	1999	HORNE	1911	950	59.21
1314	809	HLTOM	2431	1274	59.13
1315	2013	INAIR	1432	2811	59.11
1316	2016	PARIS	1206	991	59.10
1317	358	GRPVN	8211	1823	58.97
1318	2428	MKNGB	5331	1641	58.84
1319	1057	GPLND	1201	679	58.75
1320	1271	SCYEN	0004	1177	58.65
1321	1189	BRLSN	2023	1806	58.62
1322	263	WOVER	6122	3050	58.51
1323	1437	COPEL	3054	1267	58.35
1324	1906	WSOTH	1017	1675	58.30
1325	1799	PLSTH	1302	1030	58.25
1326	796	WHTRK	0008	1458	58.19
1327	1017	DENDR	0008	79	58.00
1328	1551	FINKS	1804	2179	57.95
1329	N/A	LEMON	0002	686	57.92
1330	2046	BOWEN	3132	1719	57.88
1331	1518	IRVNR	1505	1222	57.86
1332	1526	ENSSO	2003	462	57.83
1333	2511	FORSW	2015	1764	57.63
1334	1344	MNFLD	2611	2214	57.61
1335	1413	WTAUG	4611	1360	57.52
1336	1392	JKSBR	1402	1206	57.49
1337	2418	SHSTH	1301	1918	57.47
1338	315	REAST	1503	813	57.46
1339	N/A	RWALS	1853	2650	57.43
1340	1423	ENTOH	0004	1588	57.35
1341	2484	PRSTN	0001	868	57.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1342	2449	CMTSW	0921	1801	57.24
1343	42	FRMBR	1803	1218	57.24
1344	1296	WXHCH	1202	1570	57.22
1345	365	IRVBL	2502	169	57.22
1346	2346	VLYRN	2955	5129	57.17
1347	2227	BDFWD	8931	1735	57.15
1348	1728	DNINR	1402	441	57.12
1349	1980	ADISN	1603	152	57.05
1350	2233	ALLEN	2403	1711	56.77
1351	2507	RSPCK	2105	316	56.64
1352	1468	DAVIS	3782	927	56.29
1353	146	MNRVA	1301	558	56.20
1354	1113	BNDRA	0002	564	56.18
1355	938	WNTHW	1119	1304	56.15
1356	1419	HUDSN	1602	162	56.15
1357	907	JEWET	1202	43	55.95
1358	1593	RRSTH	1702	2908	55.66
1359	953	WNTHW	1121	737	55.57
1360	2379	WBROK	3011	185	55.56
1361	2023	ROLTR	2921	2339	55.40
1362	79	WEAST	0629	1420	55.28
1363	1745	CDHCR	2051	2007	55.22
1364	558	PARIS	1201	1225	55.19
1365	1938	HRSMD	1905	2768	54.98
1366	916	HLSES	0561	1449	54.93
1367	324	SALDO	3001	1580	54.88
1368	833	NLNVL	2002	3027	54.79
1369	2556	INAIR	1414	821	54.77
1370	623	IOWPK	0831	912	54.74
1371	2142	CRNTH	2402	3171	54.71
1372	2707	BLTSW	3201	2373	54.71
1373	1157	MKNSW	1603	1296	54.66
1374	964	CRTLD	4714	1457	54.64
1375	179	RHOME	2401	1056	54.63
1376	876	TMSTH	1404	1327	54.53
1377	1730	WGROB	8421	3047	54.51
1378	350	OAKHL	3011	1843	54.47
1379	1889	DESPR	1402	1611	54.40
1380	439	IRVND	1201	1023	54.36
1381	1248	SCHRD	0008	71	54.31
1382	2157	NHNSW	0003	514	54.31
1383	1316	PTENN	2357	373	54.30
1384	1182	FROKS	0008	1364	54.05
1385	2412	BLSRA	1602	145	54.02
1386	807	RRNES	2407	1224	53.99
1387	2208	SANSM	3922	1604	53.99
1388	672	WATSN	5331	777	53.95
1389	1830	MKNNY	1202	1808	53.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1390	1175	KIMBL	5022	819	53.93
1391	1599	WCOLO	1318	1498	53.84
1392	413	ECTHP	4921	721	53.80
1393	480	MSHLN	0006	1093	53.69
1394	726	EDGCF	2282	888	53.57
1395	1572	WNRTH	1420	1141	53.49
1396	1594	DNCNV	1904	1427	53.40
1397	443	TYEST	1508	625	53.34
1398	878	ENSSO	2002	980	53.32
1399	1652	MSLSW	0001	1132	53.14
1400	1793	DALRK	1309	451	53.02
1401	1336	COHMA	1132	46	53.00
1402	644	DESHR	1201	1262	52.90
1403	1543	MSTLT	1021	1157	52.89
1404	2143	MTLDA	0007	1163	52.89
1405	1415	REYST	4040	560	52.84
1406	1146	HURST	1811	1094	52.76
1407	297	JEWET	1204	1308	52.74
1408	2578	TYSTH	1208	300	52.64
1409	1145	TMPNW	1104	1793	52.63
1410	2017	VLRYN	2951	4644	52.59
1411	895	ADISN	1608	388	52.49
1412	1562	HURST	1872	2176	52.48
1413	1893	CNTRY	2833	2315	52.42
1414	1303	BSPRG	1902	2040	52.36
1415	2429	SCYEN	0002	1799	52.33
1416	928	MKNSW	1602	675	52.28
1417	1881	GRAHM	0721	1228	52.28
1418	1824	BRNSO	1807	215	52.16
1419	2235	WITTS	1701	1798	52.16
1420	1225	CPRCV	1403	1404	52.13
1421	1347	RRWES	1601	500	52.10
1422	1596	THRNE	0003	1219	51.95
1423	429	BAKKE	6921	1717	51.85
1424	764	WXNTH	2303	1523	51.70
1425	194	RCHRD	1207	1230	51.66
1426	1917	PLSTN	1005	1887	51.63
1427	1612	WALST	0012	330	51.62
1428	696	WINKS	0511	429	51.28
1429	709	RRNES	2404	3301	51.25
1430	719	LKBRN	2402	193	51.07
1431	2607	CRLUD	1302	140	51.01
1432	2451	NPKWY	0012	1834	50.90
1433	1352	BLSRA	1601	1031	50.83
1434	1322	HKBRY	1113	403	50.77
1435	1831	NCSFA	1706	970	50.61
1436	1356	HMPHL	2752	135	50.59
1437	1733	IRVNR	1551	1325	50.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1438	2587	REGST	0004	384	50.53
1439	1371	MESQT	1304	813	50.32
1440	2267	GNSVL	1223	1021	50.31
1441	190	IRVGS	1904	732	50.28
1442	1520	CRNRD	0006	380	50.26
1443	2178	HLSBR	1202	1181	50.17
1444	343	HSKAV	0007	1865	49.99
1445	707	ELGIN	1001	273	49.97
1446	212	LAVON	1406	1355	49.96
1447	355	SMFLD	2372	717	49.93
1448	1754	MESQT	1306	1190	49.93
1449	829	IRVNG	1406	1165	49.91
1450	957	CRLJL	1505	416	49.87
1451	1578	MSTLT	1011	99	49.84
1452	1617	HLSBR	1201	1618	49.84
1453	752	RGFTW	6822	22	49.82
1454	524	PRFTW	4211	3231	49.81
1455	234	BNMNW	1101	187	49.81
1456	595	CLYVL	9311	1358	49.81
1457	1223	WOVER	6131	2131	49.80
1458	958	BELLS	1201	627	49.76
1459	1871	BRNSO	1805	662	49.73
1460	901	TYOMN	1410	1647	49.63
1461	2047	CLCRK	1011	200	49.50
1462	378	CLYVL	9323	2237	49.49
1463	392	WNDWD	3611	1033	49.39
1464	538	RRNES	2402	3577	49.37
1465	505	BLMND	3231	1151	49.37
1466	2163	FHLSW	1342	1767	49.31
1467	1382	MDLNE	0141	1354	49.19
1468	1092	MDLNW	1552	2424	49.17
1469	2575	WALST	0011	639	49.13
1470	2393	MESQW	1808	1304	48.96
1471	941	CRLUD	1303	921	48.89
1472	1119	OVRTN	4015	617	48.74
1473	2098	IRVHF	2301	1164	48.71
1474	425	IRVBL	2507	850	48.68
1475	1797	MESQN	1505	1231	48.65
1476	242	PNTGO	7112	1271	48.56
1477	2673	LVBRD	0004	983	48.52
1478	1264	ELKHR	1201	915	48.49
1479	1873	CLBNR	1402	2404	48.44
1480	1478	WHITE	3531	1852	48.44
1481	1217	PARIS	1204	1167	48.33
1482	1051	TRLWD	7721	1311	48.31
1483	2069	LOMAL	0013	1063	48.27
1484	1675	CLBRN	1204	1109	48.21
1485	424	CANTN	1303	677	48.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1486	2072	RBNSN	2504	1393	48.15
1487	332	BRLSN	2033	1654	48.06
1488	1428	VENSW	2601	1150	48.06
1489	612	RNDRK	1505	1132	47.98
1490	1449	DENAV	0642	851	47.93
1491	702	PNTGO	7122	1061	47.86
1492	209	RCHHL	0353	1661	47.70
1493	819	WTAUG	4612	1190	47.67
1494	1310	RCHRD	1203	886	47.62
1495	514	HORNE	1921	776	47.59
1496	1905	JUDCT	0007	637	47.58
1497	1924	GODRD	8151	431	47.51
1498	1335	RCLNS	1404	289	47.47
1499	1339	SHAMP	0007	1315	47.39
1500	1966	WDGWD	1523	291	47.38
1501	1802	WSOTH	1021	3126	47.33
1502	1000	DCVSO	1106	1189	47.27
1503	2293	FRMNT	0010	1601	47.26
1504	2421	MNWLE	1702	1229	47.25
1505	2052	WALST	0014	803	47.17
1506	2394	TRLSW	1204	575	47.17
1507	1688	HUDSN	1601	922	47.02
1508	805	WWDWY	2020	1181	46.94
1509	2196	BRYAN	0006	692	46.88
1510	1613	HKHTS	1602	1067	46.81
1511	2320	SHDYG	7811	378	46.76
1512	131	BRCRK	6511	1195	46.67
1513	822	LKBLT	2105	981	46.65
1514	2262	CNEXP	0007	452	46.42
1515	1163	RDLML	2591	1415	46.42
1516	2444	WSOTH	1022	412	46.41
1517	2299	BOWEN	3122	1204	46.35
1518	1604	AIRPK	8421	399	46.34
1519	2674	WALNT	0001	1423	46.33
1520	490	RCHRD	1208	1035	46.31
1521	625	EDDYS	0710	664	46.30
1522	2680	LMBLN	0003	168	46.16
1523	1958	STAUG	0006	1861	46.11
1524	423	FARON	4031	1142	45.96
1525	926	FSHSW	2111	290	45.87
1526	1500	LKMNT	0005	583	45.83
1527	2242	CDHIL	1805	597	45.82
1528	65	LRENA	2901	818	45.77
1529	1779	KNEDL	6322	3520	45.75
1530	1737	WKATY	1718	2096	45.70
1531	601	FRMBG	1707	412	45.55
1532	2548	JUDCT	0002	1297	45.55
1533	1960	CLYVL	9322	2132	45.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1534	99	STAUG	0001	681	45.52
1535	1209	RSPVY	1706	1309	45.51
1536	2207	WEAST	0617	961	45.50
1537	1671	PROAD	0002	822	45.42
1538	2156	MESTE	1215	1464	45.25
1539	1127	WALST	0005	216	45.24
1540	1408	ALNSW	2652	4238	45.20
1541	634	IRVNE	1304	3371	45.18
1542	1035	GSTHW	1633	868	45.05
1543	239	BRKTN	1202	122	44.94
1544	259	SMPST	0001	2165	44.94
1545	664	CRLTN	1404	286	44.93
1546	691	SLAKE	8321	2516	44.88
1547	1986	CLYVL	9321	785	44.82
1548	2115	BLTLN	0005	817	44.82
1549	58	PRFTW	4222	3066	44.80
1550	2375	SHAMP	0005	1559	44.80
1551	1400	ZEPHR	2404	180	44.79
1552	2770	TMNTH	1603	119	44.77
1553	1732	MNHNS	1911	1221	44.66
1554	434	CADDO	0911	438	44.59
1555	1166	HORNE	1952	985	44.58
1556	1341	WEBBS	8624	3425	44.54
1557	102	WNTHW	1120	1007	44.42
1558	1574	SGOVL	1401	1666	44.29
1559	341	DCATR	1203	498	44.22
1560	1629	DALRK	1354	2487	44.09
1561	530	LFSTH	1408	5978	44.09
1562	2532	ADISN	1602	189	44.08
1563	956	MDTHN	1701	1366	44.06
1564	1724	ARLNG	1291	82	44.02
1565	2215	WFALS	0184	1352	43.99
1566	1066	BSPSW	0822	309	43.89
1567	736	BLTON	1801	888	43.88
1568	2679	MKNNY	1205	473	43.68
1569	834	ADISN	1607	1260	43.62
1570	846	FROKS	0007	1294	43.60
1571	2415	MCWHT	3512	1504	43.59
1572	780	RSNHT	1162	1373	43.55
1573	1229	LAVON	1451	706	43.51
1574	1340	SHAMP	0002	1869	43.44
1575	838	MRDCK	0002	1345	43.42
1576	2668	MKNNY	1253	91	43.38
1577	582	CRKET	2402	1423	43.29
1578	2705	SORCY	0003	815	43.27
1579	463	HMTRD	0001	946	43.19
1580	370	CDHIL	1804	718	43.14
1581	705	RRNES	2403	4586	43.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1582	1507	CLBRN	1203	1499	43.06
1583	1014	DENAV	0611	830	43.03
1584	2076	BNDRA	0006	480	43.01
1585	2056	DNIWS	1603	1346	42.98
1586	608	SANSM	3912	4552	42.97
1587	333	PRKRW	3352	1385	42.93
1588	2014	HLTOM	2461	590	42.93
1589	1665	EDGCF	2241	910	42.90
1590	2311	MAPLE	0005	1223	42.87
1591	1493	WGROB	8411	2749	42.84
1592	2483	MNWLL	1205	443	42.77
1593	711	WRTHM	5012	320	42.71
1594	750	GRDPR	0891	831	42.62
1595	1391	CLMET	0001	1210	42.61
1596	N/A	TYRSW	1701	2007	42.58
1597	1203	FRNKF	0005	1561	42.50
1598	989	ROWLT	1104	1372	42.42
1599	2062	GSTHW	1611	1506	42.42
1600	1238	CRLTR	2001	2440	42.36
1601	553	VGCRK	8041	1032	42.35
1602	1969	MESQW	1805	84	42.30
1603	2077	AMMFG	5631	1414	42.28
1604	1890	CRLJL	1503	742	42.18
1605	2740	HKBRY	1102	1360	42.15
1606	1197	HUBRD	1402	993	42.15
1607	73	OKCLS	0003	1459	42.09
1608	1224	ALNSW	2653	3307	41.92
1609	1213	FARON	4072	1475	41.92
1610	735	TRLSW	1203	670	41.89
1611	275	RSPCK	2102	1268	41.86
1612	1834	HMPHL	2781	212	41.84
1613	1846	BSPRW	2542	715	41.84
1614	725	GLNHV	3922	694	41.76
1615	1971	WFALS	0193	2241	41.68
1616	1003	BRNAV	0762	2244	41.66
1617	21	TYSTH	1202	628	41.63
1618	39	MEANS	4421	129	41.57
1619	393	PALRD	2204	681	41.57
1620	2257	HMPHL	2721	466	41.50
1621	1101	ARLNG	1213	1305	41.45
1622	397	FROKS	0006	994	41.42
1623	1642	BRCRK	6533	1720	41.41
1624	2217	PLANO	1104	837	41.37
1625	1735	BNDRA	0001	1193	41.33
1626	1792	WCOLO	1320	629	41.30
1627	82	PLKST	0006	792	41.27
1628	1949	RKDLE	1302	971	41.26
1629	2277	MDTHS	1002	940	41.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1630	1790	MSTLT	1084	627	41.15
1631	230	PRNTH	1406	1109	41.05
1632	1630	WWDWY	2024	1403	41.04
1633	944	BRNWD	1203	1074	41.02
1634	2007	PRKRW	3341	333	40.91
1635	1519	FSTVW	0002	147	40.90
1636	1552	TMPLE	1202	1393	40.84
1637	2496	BLKST	1762	905	40.71
1638	1796	DCVSO	1103	1108	40.69
1639	1546	MDWPK	9231	2360	40.43
1640	2006	GODRD	8112	1395	40.43
1641	1741	LKBLT	2101	1498	40.38
1642	1555	DALRK	1303	1233	40.30
1643	1874	ADISN	1605	1056	40.30
1644	1044	JSHUA	1301	896	40.29
1645	1372	ENTOH	0001	745	40.26
1646	2039	NMAIN	0231	320	40.22
1647	1239	IRVNR	1510	270	40.19
1648	197	MRSES	3019	20	40.00
1649	1353	VESTS	3111	49	39.98
1650	1531	PTENN	2352	1620	39.97
1651	1662	SHMNE	1403	962	39.97
1652	865	LMESA	1522	1363	39.92
1653	2706	MDWCK	0006	859	39.91
1654	1752	ARMST	0004	526	39.81
1655	1522	CRNRD	0001	731	39.76
1656	1725	FHLSW	1311	1101	39.71
1657	2129	MDLNW	1541	1745	39.68
1658	2177	PARIS	1203	1003	39.48
1659	1015	PLKST	0007	2228	39.44
1660	84	NHNSW	0008	553	39.32
1661	2508	PWEST	1307	936	39.28
1662	972	BLTLN	0006	896	39.22
1663	519	COMRC	1204	625	39.21
1664	1898	WMMMR	2704	22	39.18
1665	1398	TMPLE	1201	369	39.18
1666	459	CRKET	1201	312	39.17
1667	2027	HKHTS	1607	781	39.16
1668	1837	WCOLO	1319	1965	39.16
1669	1955	RTHGB	1421	1583	38.99
1670	1414	CMTSW	0962	612	38.87
1671	1894	CRLJL	1501	1467	38.84
1672	900	EMPCT	0008	31	38.77
1673	210	ARLNG	1292	1546	38.76
1674	2395	MNWLL	1202	680	38.70
1675	2244	FINKS	1801	1431	38.66
1676	348	TYEST	1511	858	38.60
1677	2232	HORNE	1932	1006	38.58