



Control Number: 36484



Item Number: 16

Addendum StartPage: 0

RECEIVED
10/11/14 11:33:37
PUBLIC UTILITIES COMMISSION

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2008 Reporting Year
Amended 5/14/10

Entergy Texas, Inc.

Project 36484

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2008	1.736	0.091	0.116	0.120	0.087	0.186	0.278	0.131	0.158	0.072	0.194	0.154	0.151
Scheduled 2008	0.033	0.002	0.003	0.001	0.001	0.003	0.002	0.007	0.004	0.000	0.002	0.004	0.004
Outside Causes 2008	0.398	0.023	0.039	0.028	0.002	0.034	0.070	0.022	0.026	0.008	0.088	0.040	0.019
Major Events 2008	2.242	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.329	1.892	0.022	0.000	0.000

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced	149.7	7.1	7.5	9.2	7.6	20.6	24.0	10.8	12.0	7.0	17.2	13.7	12.9
2008													
Scheduled	2.5	0.1	0.2	0.0	0.0	0.4	0.1	0.4	0.2	0.0	0.2	0.3	0.5
2008													
Outside Causes	25.0	1.8	2.9	2.6	0.2	2.2	4.3	2.5	1.2	0.4	4.0	2.7	0.4
2008													
Major Events	10,303.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	83.1	10,218.1	1.9	0.0	0.0
2008													

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

376

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
1	20	LAKESIDE	L009F	560	7.8214
2	39	EGYPT	552EP	185	7.3730
3	302	NORTH SILSBEE	471NS	1,079	6.2447
4	94	CLEVELAND	425CV	1,796	6.2439
5	13	NEW CANEY	335NC	2,720	5.6515
6	6	PEE DEE	809PD	1,531	5.6486
7	21	DOUCETTE	570DC	1,099	5.5323
8	198	GOSLIN	708GL	2,202	5.4746
9	62	RIVTRIN	268RV	2,481	5.4337
10	100	CHEEK	160CH	1,159	5.0587
11	176	SPLENDORA	309SP	1,200	5.0300
12	95	BEVIL	155BE	3,510	4.8436
13	107	TRANSCO	48TCO	180	4.7333
14	50	CRYSTAL	570CR	1,426	4.7258
15	68	LOVELLS LAKE	141LV	771	4.6939
16	127	WINFREE	341WN	691	4.6903
17	74	HARDIN	35HDN	748	4.5094
18	10	TAMINA	316TA	308	4.4513
19	92	DOUCETTE	568DC	483	4.4472
20	60	DOUCETTE	569DC	180	4.4333
21	22	MAGNOLIA AMES	711MG	779	4.4275
22	26	OAK RIDGE	745OK	228	4.4254
23	205	MCDONALD	477MD	1,312	4.4207
24	99	BRIDGE CITY	363BD	1,900	4.3958
25	24	LAKESIDE	L008F	167	4.3713
26	30	NECHES	197NE	150	4.0400
27	77	SPLENDORA	307SP	1,553	4.0064
28	215	CONROE BULK	572CN	1,264	3.9668
29	266	CHINA	93CHI	1,214	3.9440
30	5	CLEVELAND	426CV	2,913	3.8122
31	300	LILLARD	490LI	290	3.6759
32	41	HEARNE	29HRN	314	3.6115
33	16	DAYTON BULK	725DY	1,183	3.5968
34	46	CORDREY	324CO	1,517	3.5676
35	115	ELIZABETH	120EL	1,344	3.5640
36	156	METRO	719ME	2,209	3.5410
37	166	FORT WORTH	12FTW	1,563	3.4664
38	162	SARATOGA	761SA	421	3.4608
39	293	MCDONALD	479MD	943	3.4008
40	222	NEW CANEY	334NC	4,327	3.3725
41	37	CHEEK	166CH	327	3.3058
42	189	LAKESIDE	4LAS	51	3.2941
43	11	GRIMES	982GR	697	3.2353
44	12	NEW CANEY	333NC	4,952	3.2274

4

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
45	239	WINSHIRE	241WS	970	3.2134
46	201	LAKESIDE	8LAS	34	3.2059
47	116	ORANGE	352ON	924	3.1981
48	341	METRO	716ME	1,087	3.1196
49	203	MAYHAW	671MA	1,712	3.1162
50	338	LAMAR	95LAM	531	3.0998
51	43	WARREN	592WR	2,003	3.0879
52	363	Alden Bridge	763AL	2,061	2.9418
53	236	BRIARCLIFF	32BRC	1,291	2.9411
54	142	RAYWOOD	74RAY	1,132	2.9231
55	129	LAKESIDE	5LAS	93	2.8602
56	144	DAYTON BULK	724DY	2,133	2.8467
57	8	CORRIGAN BULK	238CR	597	2.8392
58	54	APOLLO	321AP	846	2.7577
59	1	NORTH END	21NOE	1,817	2.7545
60	76	FLETCHER	456FL	791	2.7497
61	63	CALDWELL INDUSTRIAL	138CI	661	2.7458
62	78	EASTGATE	781EG	1,068	2.7406
63	263	ELIZABETH	121EL	1,147	2.7341
64	260	VIRGINIA	130VI	758	2.7282
65	108	NECHES	193NE	1,033	2.7193
66	56	MCLEWIS	382MC	732	2.7036
67	194	CALVERT	4CAL	1,794	2.7007
68	132	LONGMIRE	582LM	1,089	2.6896
69	251	LACON	540LA	1,463	2.6705
70	229	SHEAWILL	536SH	1,176	2.6480
71	362	CONROE BULK	577CN	196	2.6378
72	4	TEMCO	628TE	342	2.5965
73	15	TAMINA	317TA	1,341	2.5772
74	28	VIDOR	163VD	2,898	2.5752
75	75	HANKS	23HKS	1,288	2.4922
76	311	KOLBS	35KOL	1,104	2.4746
77	131	KICKAPOO	251KP	1,225	2.4710
78	164	BRIARCLIFF	31BRC	867	2.4648
79	259	PANSY	185PS	624	2.4615
80	193	DAISETTA	743DA	336	2.4464
81	282	CENTRAL	132CE	1,748	2.4405
82	212	LOVELLS LAKE	142LV	320	2.4313
83	181	MCLEWIS	381MC	1,151	2.4292
84	313	WINSHIRE	240WS	1,086	2.4236
85	70	HANKS	25HKS	901	2.3396
86	161	WEST END	85WED	513	2.3372
87	93	LACON	537LA	1,746	2.3362
88	36	DOBBIN	920DO	1,505	2.2970
89	47	NEW CANEY	337NC	2,261	2.2932
90	105	HUNTSVILLE	611HU	1,170	2.2897
91	79	WALDEN	564WD	5,183	2.2790
92	143	HICKORY RIDGE	341HI	1,486	2.2732

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
93	18	BATSON	53BAT	859	2.2689
94	17	NORTH SILSBEE	472NS	308	2.2630
95	34	CLEVELAND	404CV	1,640	2.2579
96	135	WARREN	506WR	1,380	2.2391
97	359	GOSLIN	703GL	1,662	2.2232
98	267	MANCHESTER	66MAN	1,921	2.1640
99	268	LONGMIRE	580LM	1,145	2.1397
100	187	AVERILL	57AVR	98	2.1327
101	192	CROCKETT	61CRK	109	2.1193
102	65	KOUNTZE BULK	435KT	47	2.1064
103	55	TEMCO	627TE	992	2.1018
104	133	CONAIR	512CN	1,241	2.0943
105	365	AVERILL	55AVR	174	2.0862
106	49	CONROE BULK	507CN	2,022	2.0727
107	71	CLEVELAND	406CV	1,398	2.0436
108	80	GOSLIN	706GL	1,444	2.0346
109	40	BAYSHORE	213BA	1,536	2.0286
110	111	LINDBERGH	42LNB	1,686	2.0231
111	152	HAMPTON	158HA	1,096	1.9991
112	335	ADAMS BAYOU	331AD	200	1.9950
113	321	SOUTH LIBERTY	714SL	127	1.9843
114	177	STONEGATE	91STG	1,249	1.9744
115	124	VIRGINIA	131VI	1,192	1.9606
116	284	CONROE BULK	505CN	790	1.9354
117	245	FLETCHER	457FL	1,457	1.9101
118	146	KOUNTZE BULK	432KT	797	1.8745
119	48	HUNTSVILLE	600HU	1,737	1.8497
120	202	BEVIL	156BE	666	1.8363
121	179	LINDBERGH	40LNB	1,150	1.8322
122	175	HANKAMER	207HA	683	1.8302
123	247	CROWDER	105CD	886	1.7912
124	31	RAYWOOD	73RAY	497	1.7726
125	183	CHINA	92CHI	589	1.7725
126	283	BAYSHORE	211BA	963	1.7601
127	150	TAMINA	599TA	381	1.7533
128	218	GROVES	63GRO	1,361	1.7436
129	298	LACON	539LA	1,101	1.7402
130	304	ECHO	71ECH	673	1.7340
131	9	RIVTRIN	269RV	2,873	1.7247
132	82	TANGLEWOOD	137TG	1,515	1.6818
133	232	WINFREE	342WN	357	1.6807
134	29	SILSBEE	462SI	750	1.6773
135	285	PORT ACRES SUB	69PTA	458	1.6725
136	221	CORDREY	325CO	1,340	1.6373
137	261	ROSEDALE	151RS	1,102	1.6352
138	134	WYNTEX	632WT	851	1.6134
139	167	OILLA	345OI	1,261	1.6090
140	349	CONROE BULK	574CN	1,341	1.6063

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
141	208	STOWELL	232ST	1,004	1.5996
142	25	CALVERT	6CAL	1,261	1.5845
143	295	LOEB	18LOB	545	1.5523
144	230	BRIARCLIFF	30BRC	2,352	1.5459
145	296	APRIL	590AP	1,501	1.5237
146	314	NAVASOTA	904NA	1,209	1.5161
147	58	CLEVELAND	405CV	1,666	1.4934
148	159	CROWDER	103CD	1,379	1.4801
149	14	PEE DEE	808PD	2,221	1.4782
150	106	LONGMIRE	581LM	1,497	1.4770
151	32	STONEGATE	93STG	1,647	1.4645
152	145	SPLENDORA	308SP	2,224	1.4618
153	91	NAVASOTA	905NA	2,272	1.4529
154	33	ADAMS BAYOU	332AD	592	1.4409
155	182	AMELIA BULK	180AM	1,306	1.4326
156	57	MCLEWIS	380MC	2,236	1.4275
157	119	CONAIR	513CN	1,350	1.4222
158	96	HUMPHREY	107HM	1,861	1.4170
159	306	YANKEE DOODLE	23YAN	592	1.4155
160	278	HEARNE	25HRN	227	1.4097
161	333	VIDOR	161VD	605	1.4083
162	88	MANCHESTER	67MAN	1,000	1.4060
163	353	WOODVILLE	593WD	722	1.3947
164	286	ELIZABETH	122EL	973	1.3936
165	160	VIWAY	681VI	942	1.3769
166	73	WEST END	88WED	768	1.3737
167	138	MCDONALD	476MD	987	1.3718
168	45	WINFREE	340WN	1,017	1.3717
169	130	BRIDGE CITY	361BD	1,060	1.3689
170	NA	NAVASOTA	901NA	324	1.3673
171	344	LAKEVIEW	80LAV	711	1.3629
172	265	MCHALE	113MC	625	1.3616
173	151	MCDONALD	478MD	606	1.3597
174	219	WEST END	86WED	961	1.3548
175	220	CORDREY	320CO	81	1.3457
176	290	PANORAMA	525PA	1,305	1.3418
177	NA	FRONT STREET	310FR	512	1.3398
178	69	NEW CANEY	304NC	1,186	1.3027
179	128	TANGLEWOOD	135TG	504	1.2976
180	147	YANKEE DOODLE	22YAN	2,065	1.2949
181	340	Alden Bridge	766AL	1,638	1.2747
182	87	FRONT STREET	307FR	486	1.2572
183	231	NEW CANEY	336NC	3,497	1.2514
184	240	GRIMES	883GR	829	1.2449
185	66	TANGLEWOOD	134TG	2,319	1.2432
186	330	DAISETTA	744DA	761	1.2405
187	275	LINDBERGH	41LNB	305	1.2295
188	334	TANGLEWOOD	136TG	613	1.2284

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
189	200	SPURLOCK	99SPU	608	1.2188
190	357	LAMAR	97LAM	343	1.2070
191	44	CONAIR	514CN	1,956	1.2065
192	358	DAISETTA	741DA	160	1.2000
193	352	HUMPHREY	108HM	42	1.1905
194	324	AMELIA BULK	181AM	1,616	1.1708
195	86	LINDBERGH	43LNB	739	1.1637
196	312	WEST ORANGE	393WO	729	1.1550
197	42	GOREE	681GR	209	1.1531
198	97	STOWELL	233ST	500	1.1440
199	243	LUMBERTON	441LU	3,491	1.1389
200	336	LINCOLN	16LCN	331	1.1329
201	168	TYRRELL	37TYR	486	1.1317
202	171	BAYSHORE	212BA	38	1.1316
203	329	VIDOR	164VD	852	1.1256
204	59	DAYTON BULK	726DY	1,471	1.1013
205	242	KOUNTZE BULK	451KT	1057	1.0965
206	61	GROVES	59GRO	1,656	1.0912
207	307	CONROE BULK	575CN	577	1.0728
208	169	JIROU	78JRU	256	1.0703
209	51	VIDOR	162VD	1,819	1.0676
210	195	LACON	538LA	1,247	1.0650
211	351	JIROU	75JRU	80	1.0625
212	279	CONAIR	516CN	380	1.0553
213	292	WYNTEX	633WT	572	1.0490
214	310	AVERILL	56AVR	217	1.0461
215	297	CORDREY	326CO	1,133	1.0459
216	271	SOUR LAKE	105SL	1,204	1.0349
217	323	TYRRELL	38TYR	36	1.0278
218	72	HANKAMER	206HA	573	1.0244
219	186	NORTH END	26NOE	337	1.0030
220	319	TRAVIS	11TRV	20	1.0000
221	289	ROSEDALE	153RS	880	0.9830
222	136	SILSBEE	463SI	632	0.9794
223	366	Alden Bridge	767AL	2,388	0.9757
224	102	WYNTEX	634WT	1,212	0.9596
225	125	LOEB	17LOB	844	0.9585
226	155	WALDEN	563WD	1,599	0.9468
227	101	KOLBS	34KOL	1,218	0.9401
228	210	MCHALE	112MC	659	0.9074
229	2	GOREE	682GR	1,615	0.9009
230	308	CROCKETT	198CR	209	0.8995
231	117	OAK RIDGE	743OK	1,653	0.8953
232	83	APOLLO	320AP	1,375	0.8916
233	19	CRYSTAL	566CR	3,152	0.8905
234	35	HUNTSVILLE	607HU	3,247	0.8848
235	315	GOSLIN	702GL	1,700	0.8782
236	81	PORT ACRES SUB	68PTA	1,142	0.8695

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
237	23	DOBBIN	519DO	2,037	0.8694
238	253	ELIZABETH	123EL	2,355	0.8484
239	103	OAK RIDGE	744OK	2,403	0.8390
240	249	LONGMIRE	583LM	1,295	0.8293
241	223	VIWAY	682VI	1,815	0.8171
242	123	EGYPT	550EP	2,099	0.8094
243	273	KOLBS	36KOL	1,261	0.7986
244	226	GOSLIN	709GL	3,569	0.7868
245	118	Alden Bridge	765AL	735	0.7850
246	207	HANKS	22HKS	1,153	0.7788
247	288	YANKEE DOODLE	25YAN	176	0.7784
248	257	LAKEVIEW	81LAV	1,270	0.7677
249	90	TAMINA	598TA	671	0.7601
250	214	CORDREY	327CO	1,017	0.7581
251	238	ECHO	72ECH	500	0.7460
252	234	AMELIA BULK	182AM	793	0.7327
253	112	Alden Bridge	762AL	3,803	0.7213
254	272	CROCKETT	195CR	958	0.6994
255	199	ORANGE	351ON	380	0.6974
256	217	HUNTSVILLE	608HU	3,134	0.6803
257	277	CHEEK	159CH	532	0.6748
258	140	DAYTON BULK	723DY	878	0.6697
259	52	PLANTATION	546PL	817	0.6695
260	254	PORT ACRES BULK	70PAS	788	0.6688
261	121	ECHO	70ECH	1,497	0.6466
262	216	SOMERVILLE	127SO	414	0.6401
263	196	ROSEDALE	152RS	558	0.6272
264	204	DAYTON BULK	727DY	744	0.6183
265	262	BEVIL	154BE	2,093	0.6111
266	64	ADAMS BAYOU	330AD	140	0.6071
267	225	WOODVILLE	594WD	1,187	0.6049
268	190	CONAIR	511CN	1,340	0.5993
269	191	CLEVELAND	403CV	1,481	0.5922
270	213	CEDAR	698CE	26	0.5769
271	148	PEE DEE	806PD	1332	0.5601
272	294	ORANGE	350ON	863	0.5516
273	67	GEORGIA	670GE	321	0.5483
274	158	CROCKETT	60CRK	259	0.5483
275	157	FORT WORTH	7FTW	1,317	0.5368
276	237	HUNTSVILLE	610HU	1,845	0.5344
277	255	VIRGINIA	129VI	619	0.5234
278	276	PORT NECHES	46PTN	1,260	0.5230
279	316	STONEGATE	92STG	1,983	0.5194
280	53	CRYSTAL	567CR	1,240	0.5185
281	113	KOLBS	37KOL	694	0.5159
282	7	OAK RIDGE	742OK	2,443	0.5100
283	233	BRIDGE CITY	362BD	1,248	0.5040
284	209	PORT ACRES SUB	67PTA	577	0.4939

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
285	120	NAVASOTA	969NA	819	0.4799
286	269	CROWDER	102CD	2,217	0.4781
287	174	ECHO	73ECH	789	0.4715
288	126	CONAIR	515CN	2,036	0.4661
289	153	STOWELL	231ST	875	0.4617
290	305	MCHALE	110MC	992	0.4446
291	149	PLANTATION	545PL	1,039	0.4408
292	274	BRIARCLIFF	33BRC	301	0.4319
293	320	SHEAWILL	535SH	655	0.4260
294	137	CROWDER	104CD	1,571	0.4176
295	345	CROCKETT	64CRK	744	0.4113
296	104	NORTH END	28NOE	205	0.3902
297	339	CONROE BULK	506CN	2,093	0.3884
298	206	STONEGATE	90STG	1,027	0.3768
299	180	MAPLE	90MPL	368	0.3750
300	346	CHEEK	165CH	99	0.3737
301	NA	STOWELL	234ST	5572	0.3460
302	173	JIROU	76JRU	235	0.3447
303	27	HIMEX	221HI	402	0.3408
304	342	CENTRAL	131CE	929	0.3402
305	252	METRO	718ME	1,552	0.3396
306	360	CROCKETT	63CRK	30	0.3333
307	248	BRIDGE CITY	360BD	1,044	0.3324
308	354	PARKDALE	176PR	525	0.3295
309	3	CROCKETT	65CRK	502	0.3267
310	235	GROVES	61GRO	932	0.3262
311	38	METRO	723ME	394	0.3122
312	244	SOMERVILLE	126SO	824	0.3095
313	197	WEST END	80WED	270	0.3074
314	NA	BROOKS CREEK	270BC	47	0.2979
315	98	GRIMES	981GR	309	0.2751
316	172	CENTRAL	133CE	1,579	0.2654
317	264	OAK RIDGE	740OK	1,148	0.2605
318	258	GROVES	62GRO	1,486	0.2544
319	170	PANSY	184PS	415	0.2530
320	139	SOUR LAKE	104SL	309	0.2492
321	270	FEDERAL	801FE	224	0.2277
322	227	MCHALE	111MC	570	0.2246
323	188	NORTH END	29NOE	361	0.2216
324	332	HUMPHREY	106HM	1,103	0.2167
325	309	HANKS	24HKS	841	0.2128
326	89	OAK RIDGE	741OK	726	0.2121
327	328	WESTSIDE	111WS	428	0.2103
328	317	LONGMIRE	584LM	1,321	0.1991
329	165	MAPLE	91MPL	294	0.1973
330	299	WEST ORANGE	392WO	661	0.1906
331	185	FRONT STREET	308FR	374	0.1872
332	280	SILSBEE	461SI	507	0.1834

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIFI Ranking	2007SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
333	325	WALDEN	560WD	606	0.1782
334	361	BAYOU FANNETT	250BY	34	0.1765
335	370	GOSLIN	704GL	1,669	0.1762
336	141	VIRGINIA	132VI	527	0.1727
337	343	PARKDALE	171PR	678	0.1652
338	303	GOSLIN	705GL	864	0.1563
339	350	CORDREY	321CO	52	0.1538
340	322	YANKEE DOODLE	24YAN	335	0.1522
341	84	HIMEX	222HI	280	0.1286
342	287	TESCO	36TSC	81	0.1235
343	154	SPURLOCK	98SPU	509	0.1198
344	318	PORT NECHES	45PTN	914	0.1127
345	256	GOSLIN	707GL	708	0.1088
346	371	GOSLIN	710GL	840	0.0952
347	163	APRIL	592AP	1,041	0.0932
348	355	WEST END	82WED	354	0.0791
349	348	LINCOLN	15LCN	272	0.0772
350	372	SPEEDWAY	917SW	27	0.0741
351	364	METRO	720ME	523	0.0612
352	184	JIROU	77JRU	303	0.0594
353	281	WESTSIDE	112WS	423	0.0591
354	301	APRIL	591AP	1,492	0.0583
355	85	CORRIGAN BULK	239CR	498	0.0582
356	114	WESTSIDE	113WS	310	0.0581
357	178	MEMORIAL	281ML	22	0.0455
358	347	CENTRAL	130CE	684	0.0380
359	291	CONROE BULK	576CN	836	0.0287
360	368	NORTH END	27NOE	162	0.0247
361	369	MEMORIAL	280ML	325	0.0185
362	224	Alden Bridge	768AL	3,074	0.0049
363	110	Alden Bridge	764AL	1,428	0.0000
364	228	Alden Bridge	769AL	957	0.0000
365	NA	GOSLIN	701GL	1126	0.0000
366	356	HEARNE	28HRN	25	0.0000
367	109	METRO	717ME	125	0.0000
368	331	METRO	721ME	467	0.0000
369	367	METRO	722ME	120	0.0000
370	211	ROSEDALE	150RS	97	0.0000
371	373	TRAVIS	13TRV	42	0.0000
372	374	TRAVIS	14TRV	16	0.0000
373	NA	Travis	6TRV	29	0.0000
374	375	TRAVIS	9TRV	26	0.0000
375	376	WEST END	83WED	178	0.0000
376	377	WEST END	87WED	19	0.0000

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

376

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1	6	LAKESIDE	L009F	560	1,499.6000
2	79	EGYPT	552EP	185	1,068.5892
3	160	WINFREE	341WN	691	1,004.0897
4	80	CLEVELAND	425CV	1,796	685.7912
5	14	PEE DEE	809PD	1,531	677.9327
6	306	NORTH SILSBEE	471NS	1,079	578.8443
7	61	CRYSTAL	570CR	1,426	569.1802
8	4	MAGNOLIA AMES	711MG	779	545.5302
9	57	TRANSCO	48TCO	180	534.5556
10	3	DOUCETTE	569DC	180	524.4444
11	108	FLETCHER	456FL	791	495.6599
12	70	LONGMIRE	582LM	1,089	481.8026
13	74	RMTRIN	268RV	2,481	453.2813
14	9	NEW CANEY	335NC	2,720	425.3382
15	126	KOUNTZE BULK	432KT	797	393.0226
16	330	CONROE BULK	577CN	196	389.9133
17	25	HEARNE	29HRN	314	386.7325
18	100	NECHES	197NE	150	384.1733
19	142	BRIDGE CITY	363BD	1,900	372.1732
20	90	BEVIL	155BE	3,510	371.0732
21	129	LOVELLS LAKE	141LV	771	370.1258
22	21	DOUCETTE	570DC	1,099	362.6460
23	75	SPLENDORA	307SP	1,553	359.1423
24	5	TAMINA	316TA	308	357.6786
25	280	MCDONALD	479MD	943	354.9629
26	15	TEMCO	628TE	342	354.4386
27	186	CONROE BULK	572CN	1,264	348.0934
28	45	HARDIN	35HDN	748	347.9773
29	116	SARATOGA	761SA	421	344.4466
30	22	LAKESIDE	L008F	167	342.3234
31	40	DAYTON BULK	725DY	1,183	338.5757
32	11	CLEVELAND	426CV	2,913	336.4195
33	206	SHEAWILL	536SH	1,176	334.2245
34	106	FORT WORTH	12FTW	1,563	333.3826
35	125	CHEEK	160CH	1,159	330.9707
36	297	LILLARD	490LI	290	327.7586
37	120	ORANGE	352ON	924	324.4102
38	341	LAMAR	95LAM	531	323.5424
39	220	GRIMES	883GR	829	298.9759
40	268	GOSLIN	708GL	2,202	297.6208
41	58	BATSON	53BAT	859	292.6775
42	37	LACON	537LA	1,746	292.0979
43	16	VIDOR	163VD	2,898	289.5542
44	23	DOBBIN	92ODO	1,505	286.2379
45	26	NEW CANEY	333NC	4,952	280.0687
46	55	OAK RIDGE	745OK	228	273.4605
47	121	NEW CANEY	334NC	4,327	272.7046
48	102	RAYWOOD	74RAY	1,132	268.6546
49	270	BEVIL	156BE	666	266.7763
50	67	CHEEK	166CH	327	263.0183
51	200	CROCKETT	61CRK	109	260.5872
52	135	KOUNTZE BULK	435KT	47	255.6596
53	192	STOWELL	232ST	1,004	253.8835
54	24	NEW CANEY	337NC	2,261	252.6108

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
55	209	SPLENDORA	309SP	1,200	251.5058
56	112	CHINA	92CHI	589	251.4177
57	336	METRO	716ME	1,087	250.5262
58	29	NORTH END	21NOE	1,817	249.8134
59	132	WALDEN	563WD	1,599	248.7198
60	64	CLEVELAND	404CV	1,640	248.4756
61	114	EASTGATE	781EG	1,068	246.6320
62	10	WINFREE	340WN	1,017	243.0649
63	28	CALDWELL INDUSTRIAL	138CI	661	241.1967
64	13	RIVTRIN	269RV	2,873	240.4654
65	321	WINSHIRE	240WS	1,086	235.0120
66	137	HANKS	23HKS	1,288	233.1576
67	101	HICKORY RIDGE	341HI	1,486	229.2981
68	78	OILLA	345OI	1,261	229.0555
69	316	NAVASOTA	904NA	1,209	227.4177
70	366	AVERILL	55AVR	174	225.1897
71	281	LAKESIDE	8LAS	34	225.1176
72	50	WALDEN	564WD	5,183	224.3027
73	243	CHINA	93CHI	1,214	224.0923
74	176	CALVERT	4CAL	1,794	222.9532
75	275	LAKESIDE	4LAS	51	220.0980
76	353	Alden Bridge	763AL	2,061	214.8331
77	156	WEST END	85WED	513	213.0663
78	124	ADAMS BAYOU	332AD	592	212.0524
79	199	MCDONALD	477MD	1,312	211.5282
80	263	LACON	540LA	1,463	210.8804
81	261	BRIARCLIFF	32BRC	1,291	210.7397
82	157	METRO	719ME	2,209	206.1313
83	167	BRIARCLIFF	31BRC	867	205.0681
84	2	GOREE	681GR	209	199.4163
85	35	WARREN	592WR	2,003	197.6775
86	127	LINDBERGH	42LNB	1,686	196.8233
87	27	GRIMES	982GR	697	195.3960
88	138	DOUCETTE	568DC	483	191.5362
89	144	NECHES	193NE	1,033	187.8093
90	319	TANGLEWOOD	136TG	613	187.1599
91	128	WARREN	506WR	1,380	187.0355
92	290	LONGMIRE	580LM	1,145	185.0131
93	245	WINFREE	342WN	357	184.5042
94	32	BAYSHORE	213BA	1,536	184.0618
95	150	LAKESIDE	5LAS	93	181.5914
96	292	KOLBS	35KOL	1,104	177.3361
97	201	MCLEWIS	381MC	1,151	176.1990
98	222	HANKS	25HKS	901	174.1876
99	NA	FRONT STREET	310FR	512	174.0469
100	83	WEST END	86WED	961	172.7763
101	41	TAMINA	317TA	1,341	169.4974
102	109	VIRGINIA	131VI	1,192	168.1351
103	85	CLEVELAND	405CV	1,666	168.1164
104	33	CALVERT	6CAL	1,261	167.7034
105	231	MANCHESTER	66MAN	1,921	167.0708
106	82	NAVASOTA	905NA	2,272	166.8041
107	7	TEMCO	627TE	992	166.3246
108	66	RAYWOOD	73RAY	497	165.7767
109	36	CORRIGAN BULK	238CR	597	163.9933
110	207	AVERILL	57AVR	98	163.9286
111	277	PORT ACRES SUB	69PTA	458	163.5197
112	31	HANKAMER	206HA	573	160.7574
113	249	AMELIA BULK	180AM	1,306	159.5544

13

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
114	323	SOUTH LIBERTY	714SL	127	159.5039
115	349	CONROE BULK	574CN	1,341	158.8285
116	56	NEW CANEY	304NC	1,186	157.8356
117	169	HUNTSVILLE	611HU	1,170	157.6872
118	304	LACON	539LA	1,101	157.2071
119	283	HEARNE	25HRN	227	156.2247
120	354	GOSLIN	703GL	1,662	156.1318
121	76	HUNTSVILLE	600HU	1,737	155.1105
122	173	LOVELLS LAKE	142LV	320	155.0938
123	46	NORTH SILSBEE	472NS	308	153.4903
124	94	KICKAPOO	251KP	1,225	152.0441
125	134	CONAIR	512CN	1,241	150.0790
126	91	CORDREY	324CO	1,517	149.9545
127	214	STONEGATE	91STG	1,249	149.9023
128	44	APOLLO	321AP	846	148.6631
129	111	DAYTON BULK	724DY	2,133	147.4834
130	182	MAYHAW	671MA	1,712	146.9445
131	303	ELIZABETH	122EL	973	145.6906
132	357	LAMAR	97LAM	343	144.8047
133	190	HANKAMER	207HA	683	144.5739
134	20	PEE DEE	808PD	2,221	144.5502
135	141	MCLEWIS	382MC	732	144.0601
136	99	CONROE BULK	507CN	2,022	143.0757
137	151	GOSLIN	706GL	1,444	142.4494
138	236	VIRGINIA	130VI	758	141.5567
139	42	MANCHESTER	67MAN	1,000	139.5310
140	313	LOEB	18LOB	545	138.7284
141	211	ELIZABETH	120EL	1,344	138.5967
142	288	ELIZABETH	121EL	1,147	137.9215
143	130	BAYSHORE	212BA	38	137.4737
144	185	DAISETTA	743DA	336	137.1577
145	73	CLEVELAND	406CV	1,398	137.0536
146	309	SOUR LAKE	105SL	1,204	135.7558
147	254	PORT ACRES BULK	70PAS	788	134.9302
148	324	CENTRAL	132CE	1,748	133.5475
149	289	PANORAMA	525PA	1,305	132.4713
150	295	CHEEK	159CH	532	132.4060
151	239	MCHALE	113MC	625	129.9216
152	65	SPLENDORA	308SP	2,224	128.2860
153	225	FLETCHER	457FL	1,457	126.2388
154	164	GROVES	63GRO	1,361	125.9566
155	293	ROSEDALE	153RS	880	125.1398
156	193	KOUNTZE BULK	451KT	1057	123.9820
157	266	WINSHIRE	241WS	970	123.4351
158	18	DOBBIN	519DO	2,037	122.7246
159	170	NEW CANEY	336NC	3,497	121.5991
160	158	LINDBERGH	40LNB	1,150	121.1209
161	286	BAYSHORE	211BA	963	120.7830
162	17	GOREE	682GR	1,615	119.3350
163	148	VIDOR	162VD	1,819	118.2611
164	88	TANGLEWOOD	134TG	2,319	118.0927
165	30	HUMPHREY	107HM	1,861	117.3380
166	234	AVERILL	56AVR	217	115.0691
167	221	CONROE BULK	505CN	790	112.6165
168	139	APOLLO	320AP	1,375	111.3738
169	34	STONEGATE	93STG	1,647	109.7092
170	98	MCDONALD	476MD	987	109.6788
171	350	LAKEVIEW	80LAV	711	106.4388
172	197	FRONT STREET	307FR	486	106.3004

14

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
173	255	LUMBERTON	441LU	3,491	106.2515
174	81	PORT ACRES SUB	68PTA	1,142	105.0560
175	60	TAMINA	599TA	381	105.0157
176	276	PANSY	185PS	624	104.9423
177	72	LOEB	17LOB	844	104.1908
178	77	STOWELL	233ST	500	103.8660
179	328	WYNTEX	633WT	572	100.9056
180	284	CORDREY	326CO	1,133	100.8950
181	208	VWAY	682VI	1,815	99.7405
182	38	GROVES	59GRO	1,656	99.2530
183	63	OAK RIDGE	743OK	1,653	98.9843
184	19	CRYSTAL	566CR	3,152	98.0987
185	84	TANGLEWOOD	137TG	1,515	97.7571
186	93	EGYPT	550EP	2,099	97.7551
187	189	Alden Bridge	765AL	735	97.2830
188	107	HAMPTON	158HA	1,096	94.3914
189	343	VIDOR	161VD	605	93.7058
190	136	MCLEWIS	380MC	2,236	92.3157
191	NA	NAVASOTA	901NA	324	92.1759
192	339	WOODVILLE	593WD	722	91.8573
193	62	DAYTON BULK	726DY	1,471	91.0150
194	216	CORDREY	325CO	1,340	90.7836
195	159	LACON	538LA	1,247	89.8003
196	300	BRIARCLIFF	33BRC	301	88.2757
197	340	LINCOLN	16LCN	331	86.8640
198	242	CROWDER	105CD	886	86.2788
199	166	WYNTEX	634WT	1,212	86.1213
200	155	YANKEE DOODLE	22YAN	2,065	85.1017
201	278	PORT NECHES	46PTN	1,260	84.8976
202	240	AMELIA BULK	182AM	793	84.4061
203	54	WYNTEX	632WT	851	82.3079
204	203	SILSBEE	463SI	632	82.0918
205	294	ROSEDALE	151RS	1,102	79.9483
206	311	CONAIR	516CN	380	79.6026
207	149	DAYTON BULK	723DY	878	79.0353
208	279	YANKEE DOODLE	23YAN	592	78.9189
209	175	CROCKETT	60CRK	259	77.0579
210	69	SILSBEE	462SI	750	76.9387
211	287	GOSLIN	709GL	3,569	76.0395
212	259	KOLBS	36KOL	1,261	75.3093
213	260	GOSLIN	702GL	1,700	75.1535
214	47	OAK RIDGE	742OK	2,443	74.4355
215	96	HANKS	22HKS	1,153	73.8604
216	187	MCHALE	112MC	659	73.7830
217	338	ADAMS BAYOU	331AD	200	72.8700
218	347	Alden Bridge	766AL	1,638	71.5195
219	198	LAKEVIEW	81LAV	1,270	70.9866
220	196	BRIDGE CITY	361BD	1,060	70.8877
221	210	ORANGE	351ON	380	70.4895
222	172	LONGMIRE	583LM	1,295	69.8865
223	332	DAISETTA	744DA	761	69.4021
224	143	ADAMS BAYOU	330AD	140	68.4500
225	119	CONAIR	513CN	1,350	68.4170
226	272	ECHO	71ECH	673	68.1813
227	291	VIDOR	164VD	852	67.7641
228	97	HUNTSVILLE	607HU	3,247	67.7481
229	52	ECHO	70ECH	1,497	67.3260
230	271	MCDONALD	478MD	606	66.7624
231	256	WEST END	80WED	270	64.8593

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
232	238	VWAY	681VI	942	64.2834
233	217	BEVIL	154BE	2,093	64.0812
234	251	ROSEDALE	152RS	558	63.8710
235	257	APRIL	590AP	1,501	63.8634
236	346	CHEEK	165CH	99	63.4242
237	262	CROCKETT	195CR	958	63.2119
238	183	CROWDER	103CD	1,379	62.8564
239	161	KOLBS	34KOL	1,218	62.2791
240	360	DAISETTA	741DA	160	62.1500
241	218	YANKEE DOODLE	25YAN	176	61.6989
242	230	LINDBERGH	41LNB	305	60.9049
243	174	DAYTON BULK	727DY	744	60.8266
244	213	BRIARCLIFF	30BRC	2,352	60.7117
245	39	TAMINA	598TA	671	58.5738
246	147	CORDREY	320CO	81	57.7654
247	308	TYRRELL	37TYR	486	57.7531
248	86	CONAIR	514CN	1,956	57.2055
249	335	CROCKETT	198CR	209	57.1866
250	105	JIROU	78JRU	256	56.7266
251	337	HUMPHREY	108HM	42	56.0000
252	334	WEST ORANGE	393WO	729	54.6145
253	274	VIRGINIA	129VI	619	53.8223
254	282	ELIZABETH	123EL	2,355	53.6255
255	205	HUNTSVILLE	608HU	3,134	53.5520
256	146	FORT WORTH	7FTW	1,317	53.4556
257	123	PLANTATION	545PL	1,039	53.2656
258	68	OAK RIDGE	744OK	2,403	53.0329
259	115	Alden Bridge	762AL	3,803	52.0860
260	241	ECHO	72ECH	500	51.8700
261	53	PLANTATION	546PL	817	51.4553
262	320	TYRRELL	38TYR	36	51.3889
263	110	TANGLEWOOD	135TG	504	51.1885
264	312	CONROE BULK	506CN	2,093	50.5538
265	140	LONGMIRE	581LM	1,497	49.5224
266	179	CORDREY	327CO	1,017	47.9715
267	228	CEDAR	698CE	26	47.6154
268	296	WEST END	88WED	768	46.9818
269	315	STONEGATE	92STG	1,983	46.4962
270	331	AMELIA BULK	181AM	1,616	46.0396
271	365	Alden Bridge	767AL	2,388	45.1646
272	162	MAPLE	90MPL	368	44.8587
273	194	HUNTSVILLE	610HU	1,845	44.2916
274	153	LINDBERGH	43LNB	739	43.8417
275	363	CROCKETT	63CRK	30	43.6333
276	232	CONAIR	511CN	1,340	43.2284
277	59	CRYSTAL	567CR	1,240	41.2339
278	12	GEORGIA	670GE	321	39.7290
279	318	SHEAWILL	535SH	655	38.2137
280	305	CONROE BULK	575CN	577	38.0867
281	237	PEE DEE	806PD	1,332	37.6907
282	227	CROWDER	102CD	2,217	37.6644
283	48	GRIMES	981GR	309	37.5178
284	233	BRIDGE CITY	362BD	1,248	36.7476
285	89	STONEGATE	90STG	1,027	36.5657
286	1	HIMEX	221HI	402	36.5075
287	178	WOODVILLE	594WD	1,187	36.1457
288	177	PORT ACRES SUB	67PTA	577	35.7279
289	95	KOLBS	37KOL	694	35.5865
290	NA	STOWELL	234ST	5572	35.2478

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
291	302	MCHALE	110MC	992	35.1472
292	103	SOMERVILLE	127SO	414	34.6377
293	361	PARKDALE	176PR	525	32.7276
294	352	CROCKETT	64CRK	744	32.4718
295	246	GROVES	61GRO	932	31.0247
296	NA	BROOKS CREEK	270BC	47	30.9149
297	204	SPURLOCK	99SPU	608	30.8931
298	247	BRIDGE CITY	360BD	1,044	30.7414
299	325	ORANGE	350ON	863	30.6698
300	345	JIROU	75JRU	80	30.5625
301	71	SOUR LAKE	104SL	309	30.3851
302	180	CLEVELAND	403CV	1,481	29.9068
303	163	CONAIR	515CN	2,036	28.8752
304	118	CROWDER	104CD	1,571	28.2158
305	165	MAPLE	91MPL	294	28.1735
306	122	PANSY	184PS	415	27.2482
307	273	HANKS	24HKS	841	26.7883
308	184	STOWELL	231ST	875	26.4514
309	370	GOSLIN	704GL	1,669	24.6279
310	212	ECHO	73ECH	789	24.3777
311	131	OAK RIDGE	741OK	726	24.0138
312	117	JIROU	76JRU	235	23.8511
313	253	GROVES	62GRO	1,486	23.5330
314	224	CENTRAL	133CE	1,579	23.3939
315	188	OAK RIDGE	740OK	1,148	23.2787
316	8	CROCKETT	65CRK	502	23.1753
317	92	METRO	723ME	394	22.9619
318	51	NAVASOTA	969NA	819	22.6874
319	219	METRO	718ME	1,552	22.2700
320	229	SOMERVILLE	126SO	824	22.0765
321	152	HIMEX	222HI	280	21.1607
322	351	CENTRAL	131CE	929	20.7600
323	298	WESTSIDE	111WS	428	20.6308
324	250	WALDEN	560WD	606	20.4422
325	314	TRAVIS	11TRV	20	20.0000
326	322	LONGMIRE	584LM	1,321	18.9092
327	344	PARKDALE	171PR	678	18.6209
328	348	HUMPHREY	106HM	1,103	18.5866
329	299	FRONT STREET	308FR	374	18.5187
330	226	GOSLIN	705GL	864	17.8148
331	252	FEDERAL	801FE	224	17.2813
332	171	NORTH END	26NOE	337	16.7537
333	342	LINCOLN	15LCN	272	16.4890
334	133	VIRGINIA	132VI	527	16.3643
335	104	APRIL	592AP	1,041	15.7205
336	264	SILSBEE	461SI	507	15.6055
337	310	TESCO	36TSC	81	14.8025
338	285	WEST ORANGE	392WO	661	14.0484
339	364	BAYOU FANNETT	250BY	34	13.4118
340	329	YANKEE DOODLE	24YAN	335	13.3313
341	327	PORT NECHES	45PTN	914	12.2965
342	215	MCHALE	111MC	570	11.7649
343	168	NORTH END	28NOE	205	10.9610
344	267	GOSLIN	707GL	708	10.8757
345	181	SPURLOCK	98SPU	509	10.8664
346	154	NORTH END	29NOE	361	10.7368
347	49	CORRIGAN BULK	239CR	498	10.5602
348	371	GOSLIN	710GL	840	10.5000
349	356	CORDREY	321CO	52	8.6923

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
350	265	APRIL	591AP	1,492	8.5369
351	87	WESTSIDE	113WS	310	5.7419
352	355	METRO	720ME	523	5.6023
353	358	WEST END	82WED	354	4.9548
354	362	CENTRAL	130CE	684	4.6652
355	372	SPEEDWAY	917SW	27	4.4074
356	244	MEMORIAL	281ML	22	3.6364
357	145	WESTSIDE	112WS	423	3.0473
358	248	JIROU	77JRU	303	2.6139
359	195	CONROE BULK	576CN	836	2.2177
360	368	MEMORIAL	280ML	325	1.9815
361	258	Alden Bridge	768AL	3,074	1.4639
362	367	NORTH END	27NOE	162	1.0617
363	113	Alden Bridge	764AL	1,428	0.0000
364	326	Alden Bridge	769AL	957	0.0000
365	NA	GOSLIN	701GL	1126	0.0000
366	359	HEARNE	28HRN	25	0.0000
367	269	METRO	717ME	125	0.0000
368	235	METRO	721ME	467	0.0000
369	369	METRO	722ME	120	0.0000
370	301	ROSEDALE	150RS	97	0.0000
371	373	TRAVIS	13TRV	42	0.0000
372	374	TRAVIS	14TRV	16	0.0000
373	NA	TRAVIS	6TRV	29	0.0000
374	375	TRAVIS	9TRV	26	0.0000
375	376	WEST END	83WED	178	0.0000
376	377	WEST END	87WED	19	0.0000

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2008 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	14.30%
Vegetation	17.59%
Animals and Birds	4.25%
People (Including cars and farm equip)	14.77%
Utility-owned Equipment	34.43%
Other	7.14%
Unknown	7.52%
	100.00%

LAKESIDE L008F - PLEASURE 77PLS 2007 REPORTING YEAR CONVERSION

Substation	Feeder	CI	CM	# Cust	SAIDI	SAIFI
2007						
LAKESIDE	L008F	509	67526	22	401.9405	3.0298
PLEASURE	77PLS	117	5303	146	31.5655	0.6964
Combined Data						
LAKESIDE	L008F	626	72829	168	433.5060	3.7262
2006						
LAKESIDE	L008F	446	84477	84	1005.6786	5.3095
PLEASURE	77PLS	351	59370	145	409.4483	2.4207
Combined Data						
LAKESIDE	L008F	797	143847	229	628.1529	3.4803
2005						
LAKESIDE	L008F	886	162556	84	1935.1900	10.5500
PLEASURE	77PLS	723	176288	146	1207.4500	4.9500
Combined Data						
LAKESIDE	L008F	1609	338844	230	1473.2333	6.9952
2004						
LAKESIDE	L008F	425	127912	84	1522.7600	5.0600
PLEASURE	77PLS	675	130301	146	892.4700	4.6200
Combined Data						
LAKESIDE	L008F	1100	258212	230	1122.6629	4.7807

LAKESIDE L009F - REBEL 119RB 2007 REPORTING YEAR CONVERSION

Substation	Feeder	CI	CM	# Cust	SAIDI	SAIFI
2007						
LAKESIDE	L009F	1724	280822	155	1811.7548	11.1226
REBEL	119RB	427	58091	395	147.0658	1.0810
Combined Data						
LAKESIDE	L009F	2151	338913	550	616.2055	3.9109
2006						
LAKESIDE	L009F	536	109650	75	1462.0000	7.1467
REBEL	119RB	3476	632166	363	1741.5041	9.5758
Combined Data						
LAKESIDE	L009F	4012	741816	438	1693.6438	9.1598
2005						
LAKESIDE	L009F	359	34097	75	454.6267	4.7867
REBEL	119RB	3740	424668	461	921.1887	8.1128
Combined Data						
LAKESIDE	L009F	4099	458765	536	855.9049	7.6474
2004						
LAKESIDE	L009F	255	28829	75	384.3867	3.4000
REBEL	119RB	1851	204482	461	443.5618	4.0152
Combined Data						
LAKESIDE	L009F	2106	233311	536	435.2817	3.9291