



Control Number: 36484



Item Number: 5

Addendum StartPage: 0

2009 FEB 13 AM 10:34
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2008 Reporting Year

El Paso Electric Company

Project 36484

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2008	0.493	0.016	0.033	0.035	0.019	0.046	0.051	0.061	0.099	0.047	0.024	0.035	0.027
Scheduled													
2008	0.031	0.000	0.000	0.000	0.001	0.000	0.004	0.006	0.001	0.011	0.007	0.000	0.001
Outside Causes													
2008	0.228	0.000	0.031	0.051	0.000	0.000	0.033	0.001	0.046	0.059	0.007	0.000	0.000
Major Events													
2008	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Service Quality Report to the Public Utility Commission of Texas

EI Paso Electric Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced	50.26	3.00	2.35	3.19	1.58	4.82	5.04	7.02	8.04	4.38	2.94	5.14	2.77
2008													
Scheduled	1.58	0.12	0.00	0.01	0.05	0.02	0.14	0.19	0.05	0.26	0.64	0.03	0.04
2008													
Outside Causes	14.53	0.00	1.85	3.11	0.00	0.00	2.34	0.85	2.90	3.19	0.29	0.00	0.00
2008													
Major Events	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2008													

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

235

Add or Delete Rows as Necessary

EI Paso Electric Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
1	113	SANTA TERESA	21	1813	2.82
2	42	LANE	11	1474	2.42
3	131	SHEARMAN	12	2036	2.38
4	80	THORN	12	2544	2.26
5	72	CIELO	01	445	2.22
6	25	RIO GRANDE	13	1193	2.15
7	13	SPARKS	12	1227	2.10
8	226	SUNSET NORTH	12	2907	2.06
9	107	SCOTSDALE	16	1338	1.97
10	116	MILAGRO	12	2469	1.83
11	115	SOL	10	2304	1.79
12	30	SHEARMAN	11	1281	1.44
13	18	LOMALAND	02	229	1.39
14	19	MANN	11	2262	1.37
15	97	SHEARMAN	10	2974	1.36
16	45	TOBIN	02	713	1.32
17	81	LEO	01	1244	1.32
18	158	FIVE POINTS	01	268	1.26
19	105	MANN	12	1448	1.25
20	138	MILAGRO	18	2028	1.23
21	94	TOBIN	01	726	1.20
22	129	THORN	15	2285	1.20
23	23	AUSTIN	02	565	1.19
24	46	CHAPARRAL	10	1409	1.18
25	114	THORN	14	2833	1.17
26	54	LEO	11	1369	1.14
27	14	MONTOYA	20	1184	1.14
28	86	CROMO	12	2109	1.14
29	87	CALIENTE	10	2016	1.13
30	4	CLINT	11	1698	1.11
31	9	SCOTSDALE	15	2662	1.11
32	123	MILAGRO	13	2110	1.10
33	106	MISSION	01	382	1.09
34	6	THORN	13	3241	1.09
35	7	CHAPARRAL	11	1400	1.09
36	71	VALLEY	10	1494	1.07
37	130	ALTURA	05	412	1.06
38	55	FARMER	21	2084	1.03
39	173	RIO BOSQUE	10	1298	1.03
40	169	ASCARATE	13	2717	1.03
41	147	ASCARATE	11	1566	1.02
42	134	ALAMO	20	40	1.01
43	26	SOCORRO	11	1494	1.00

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
44	192	COPPER	12	2003	1.00
45	206	CROMO	10	2064	0.97
46	143	FRESNO	01	280	0.88
47	53	PARKDALE	01	321	0.87
48	211	EAST	01	174	0.85
49	183	THORN	10	2111	0.84
50	137	DALLAS	13	1312	0.84
51	20	RANCHLAND	01	313	0.81
52	73	SPARKS	10	1200	0.80
53	153	AUSTIN	04	739	0.74
54	151	WHITE	01	281	0.72
55	156	SUNSET	15	2395	0.71
56	139	RIO BOSQUE	12	1511	0.67
57	182	SCOTSDALE	14	2405	0.66
58	100	VISTA	10	2666	0.65
59	165	COTTON	01	425	0.60
60	64	MANN	10	1060	0.59
61	15	MIDWAY	02	656	0.57
62	144	THORN	11	2631	0.55
63	126	DIANA	03	545	0.53
64	186	FARAH	11	1957	0.52
65	48	HORIZON	11	4216	0.49
66	202	BUTTERFIELD	11	49	0.43
67	136	VISCOUNT	10	1999	0.42
68	5	HORIZON	10	3149	0.41
69	190	AUSTIN	10	2379	0.40
70	57	AUSTIN	01	296	0.40
71	142	MESA	14	2004	0.39
72	122	ANTHONY	20	1042	0.37
73	11	FELIPE	20	2000	0.35
74	38	SOL	15	2772	0.34
75	16	SCOTSDALE	12	1601	0.34
76	85	VISTA	11	3193	0.33
77	98	LEO	12	2551	0.33
78	141	MESA	17	1274	0.33
79	92	SOL	14	1722	0.33
80	50	ALTURA	06	299	0.32
81	39	CALIENTE	11	1346	0.31
82	2	SOCORRO	10	1388	0.30
83	88	MORNINGSIDE	01	353	0.29
84	103	ANTHONY	22	1605	0.29
85	117	MILAGRO	17	1757	0.28
86	91	BEAUMONT	01	632	0.28
87	69	FRONTERA	01	306	0.28
88	76	MORNINGSIDE	02	382	0.28
89	101	MONTOYA	21	2293	0.28
90	68	ASCARATE	10	2039	0.28
91	63	LOMLAND	01	493	0.27

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
92	24	MESA	12	2405	0.27
93	154	CANUTILLO	01	392	0.26
94	168	LEO	02	697	0.24
95	102	ASCARATE	04	422	0.24
96	75	RANCHLAND	02	288	0.23
97	127	VISTA	15	2744	0.22
98	49	ALAMO	21	507	0.22
99	96	WRANGLER	13	2676	0.22
100	159	VISTA	13	2217	0.21
101	66	FIVE POINTS	03	263	0.21
102	181	RADFORD	01	200	0.20
103	40	COYOTE	10	1853	0.19
104	84	VISTA	14	2497	0.18
105	51	DYER	14	1604	0.18
106	110	AMERICAS	10	2417	0.17
107	194	SUNSET	14	3124	0.17
108	62	HACIENDA	01	326	0.16
109	140	HACIENDA	02	441	0.16
110	93	CROMO	15	1344	0.16
111	193	SANTA FE	11	552	0.15
112	52	WHITE	02	256	0.15
113	12	CINECUE	01	560	0.14
114	67	FABENS	02	688	0.14
115	133	SUNSET	05	429	0.14
116	58	MILAGRO	14	886	0.14
117	109	CLARDY	01	686	0.13
118	70	ASCARATE	02	345	0.13
119	89	GRACE	01	315	0.13
120	31	MANN	13	2214	0.13
121	1	MIDWAY	01	686	0.12
122	125	MONTOYA	23	2442	0.11
123	74	DIANA	01	499	0.11
124	90	AMERICAS	11	1234	0.11
125	43	ASCARATE	03	591	0.10
126	77	NEWTEX	02	539	0.09
127	61	NEWTEX	01	510	0.09
128	82	MILAGRO	11	1320	0.09
129	132	SANTA FE	12	1601	0.09
130	152	SUNSET NORTH	11	1552	0.09
131	108	DYER	11	2711	0.09
132	112	SOL	13	2305	0.09
133	41	CORONADO	01	617	0.08
134	120	YSLETA	01	388	0.08
135	219	RIO BOSQUE	11	1592	0.08
136	104	ALTURA	03	391	0.08
137	135	MILAGRO	15	1312	0.07
138	37	SUNSET	16	255	0.07
139	59	SUNSET	04	387	0.07

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
140	148	AUSTIN	03	330	0.07
141	177	DALLAS	12	1756	0.07
142	157	WRANGLER	10	2052	0.07
143	28	AUSTIN	17	1977	0.06
144	166	SUMMIT	01	254	0.06
145	155	SANTA FE	05	520	0.06
146	163	VISTA	12	2425	0.06
147	205	COPPER	10	2032	0.06
148	111	DYER	13	2514	0.05
149	10	MONTWOOD	20	1921	0.05
150	180	SCOTSDALE	13	2779	0.05
151	8	ALTURA	01	236	0.05
152	44	PARKDALE	02	202	0.04
153	160	SANTA FE	02	429	0.04
154	191	DYER	15	184	0.04
155	208	DALLAS	17	1272	0.04
156	21	MESA	18	1192	0.04
157	99	BUTTERFIELD	12	49	0.04
158	34	MANN	14	2181	0.04
159	175	DYER	12	1568	0.04
160	22	RIO GRANDE	15	1750	0.04
161	179	KEMP	01	281	0.04
162	65	MISSION	02	578	0.03
163	215	MANN	15	1296	0.03
164	187	SCOTSDALE	11	2547	0.03
165	164	DALLAS	01	319	0.03
166	N/A	CLINT	12	982	0.02
167	47	FABENS	01	249	0.02
168	83	ALTURA	04	423	0.02
169	146	DALLAS	11	1550	0.02
170	174	CROMO	13	735	0.02
171	17	MULBERRY	01	119	0.02
172	119	SUMMIT	02	281	0.01
173	161	SOL	12	2331	0.01
174	171	DALLAS	16	1504	0.01
175	213	FIVE POINTS	04	335	0.01
176	33	SOL	11	2539	0.01
177	176	SPARKS	11	1227	0.01
178	189	OCTAVIA	01	315	0.01
179	167	MONTWOOD	21	1068	0.01
180	196	AUSTIN	16	2115	0.01
181	199	AUSTIN	13	1318	0.01
182	185	AMERICAS	12	3119	0.01
183	162	COPPER	11	1388	0.01
184	118	SUNSET	02	299	0.01
185	172	MESA	13	1812	0.01
186	32	CROMO	11	1032	0.01
187	184	LANE	13	2439	0.01

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
188	27	AUSTIN	12	1533	0.01
189	195	ALTURA	02	344	0.00
190	56	ASCARATE	01	242	0.00
191	197	ASCARATE	12	994	0.00
192	95	ASCARATE	14	1530	0.00
193	198	AUSTIN	11	1876	0.00
194	200	AUSTIN	14	2514	0.00
195	170	AUSTIN	15	2851	0.00
196	201	BUTTERFIELD	10	49	0.00
197	203	BUTTERFIELD	14	12	0.00
198	204	CLARDY	02	256	0.00
199	207	CROMO	14	13	0.00
200	209	DALLAS	02	363	0.00
201	210	DALLAS	04	179	0.00
202	212	EAST	02	298	0.00
203	N/A	FARAH	12	1069	0.00
204	121	FIVE POINTS	02	204	0.00
205	188	FT. HANCOCK	01	450	0.00
206	36	GLOBAL REACH	10	0	0.00
207	178	LA TUNA	01	85	0.00
208	35	LANE	12	2303	0.00
209	214	LATTA	01	547	0.00
210	216	MESA	16	1738	0.00
211	128	MONTOYA	22	13	0.00
212	217	MONTOYA	24	11	0.00
213	N/A	MONTOYA	25	1721	0.00
214	218	MULBERRY	02	239	0.00
215	220	RIO GRANDE	11	1869	0.00
216	221	SANTA FE	01	375	0.00
217	223	SANTA FE	03	441	0.00
218	149	SANTA FE	04	498	0.00
219	222	SANTA FE	10	1437	0.00
220	224	SANTA FE	50	815	0.00
221	124	SIERRA BLANCA	01	130	0.00
222	79	SIERRA BLANCA	20	383	0.00
223	227	SUNSET	01	389	0.00
224	230	SUNSET	07	572	0.00
225	231	SUNSET	08	409	0.00
226	229	SUNSET	13	522	0.00
227	228	SUNSET	10101	815	0.00
228	225	SUNSET NORTH	10	2700	0.00
229	145	VAN HORN	01	287	0.00
230	60	VAN HORN	02	221	0.00
231	3	VISCOUNT	11	2109	0.00
232	29	VISCOUNT	12	2657	0.00
233	232	WRANGLER	11	1271	0.00
234	233	WRANGLER	12	14	0.00
235	234	WRANGLER	14	1632	0.00

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With More Than 10 Customers

235.00

Add or Delete Rows as Necessary

EI Paso Electric Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1	108	MISSION	01	382	392.56
2	101	SANTA TERESA	21	1813	350.44
3	72	VALLEY	10	1494	350.44
4	102	SOCORRO	11	1494	301.95
5	61	CIELO	01	445	296.57
6	84	SOL	10	2304	284.96
7	89	SHEARMAN	10	2974	273.10
8	144	FRESNO	01	280	247.96
9	122	ALAMO	20	40	189.86
10	82	MILAGRO	12	2469	184.79
11	30	LANE	11	1474	180.46
12	70	PARKDALE	01	321	180.03
13	111	SHEARMAN	12	2036	179.06
14	150	DALLAS	13	1312	168.68
15	20	MONTOYA	20	1184	157.71
16	47	VISTA	10	2666	154.03
17	55	RIO GRANDE	13	1193	149.29
18	58	THORN	14	2833	149.28
19	45	THORN	12	2544	145.89
20	226	SUNSET NORTH	12	2907	144.71
21	80	SPARKS	10	1200	144.31
22	5	CLINT	11	1698	143.56
23	167	FIVE POINTS	01	268	143.36
24	125	SCOTSDALE	16	1338	128.80
25	158	SUNSET	15	2395	126.67
26	10	SCOTSDALE	15	2662	121.99
27	41	MANN	10	1060	119.03
28	93	MANN	12	1448	116.91
29	59	LEO	11	1369	114.40
30	17	AUSTIN	02	565	112.48
31	23	LOMALAND	02	229	111.83
32	99	CALIENTE	10	2016	111.43
33	202	BUTTERFIELD	11	49	110.79
34	49	CHAPARRAL	10	1409	107.88
35	139	MILAGRO	18	2028	105.34
36	15	SHEARMAN	11	1281	102.68
37	120	MORNINGSIDE	01	353	96.44
38	2	RANCLAND	01	313	96.31
39	124	THORN	11	2631	89.86
40	114	LEO	01	1244	89.13
41	60	CROMO	12	2109	88.18
42	134	ASCARATE	13	2717	86.05
43	13	CHAPARRAL	11	1400	84.86

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
44	206	CROMO	10	2064	83.66
45	12	THORN	13	3241	83.65
46	129	BEAUMONT	01	632	80.51
47	162	COTTON	01	425	75.33
48	29	TOBIN	02	713	71.60
49	16	SPARKS	12	1227	67.89
50	189	COPPER	12	2003	67.04
51	81	AMERICAS	10	2417	65.59
52	131	RIO BOSQUE	12	1511	62.00
53	119	MORNINGSIDE	02	382	60.76
54	126	MILAGRO	13	2110	60.51
55	184	THORN	10	2111	60.29
56	33	MANN	11	2262	60.24
57	25	HORIZON	11	4216	59.40
58	1	SOCORRO	10	1388	59.22
59	86	SOL	14	1722	57.24
60	164	LEO	02	697	55.47
61	112	MESA	17	1274	54.15
62	149	AUSTIN	04	739	52.49
63	123	ANTHONY	20	1042	50.51
64	14	MIDWAY	02	656	50.28
65	46	ALTURA	06	299	47.58
66	121	WHITE	01	281	47.57
67	132	TOBIN	01	726	47.28
68	115	ANTHONY	22	1605	46.65
69	104	DIANA	03	545	45.41
70	76	WRANGLER	13	2676	45.32
71	163	RIO BOSQUE	10	1298	44.00
72	78	CROMO	15	1344	42.75
73	36	SOL	15	2772	40.49
74	66	VISTA	11	3193	40.16
75	105	THORN	15	2285	40.15
76	37	SCOTSDALE	12	1601	39.66
77	183	SCOTSDALE	14	2405	38.38
78	151	VISTA	13	2217	38.30
79	7	MANN	13	2214	38.22
80	97	DYER	14	1604	36.30
81	175	AUSTIN	10	2379	35.74
82	148	ALTURA	05	412	34.82
83	48	FRONTERA	01	306	34.56
84	8	HORIZON	10	3149	34.55
85	95	LOMALAND	01	493	34.16
86	113	MESA	14	2004	33.06
87	9	FELIPE	20	2000	32.11
88	143	ASCARATE	04	422	31.76
89	87	LEO	12	2551	31.52
90	73	VISTA	14	2497	31.17
91	27	FARMER	21	2084	30.99

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
92	110	VISTA	15	2744	29.98
93	109	MONTOYA	21	2293	29.15
94	152	VISCOUNT	10	1999	28.94
95	75	FIVE POINTS	03	263	25.91
96	42	AUSTIN	01	296	25.01
97	147	MILAGRO	17	1757	24.28
98	43	ASCARATE	10	2039	22.26
99	137	MONTOYA	23	2442	21.23
100	74	SOL	13	2305	21.06
101	193	SANTA FE	11	552	20.64
102	166	SANTA FE	12	1601	20.47
103	159	HACIENDA	02	441	19.80
104	39	ALAMO	21	507	19.48
105	194	SUNSET	14	3124	19.03
106	219	RIO BOSQUE	11	1592	18.43
107	182	RADFORD	01	200	17.83
108	6	MIDWAY	01	686	16.93
109	19	COYOTE	10	1853	16.71
110	92	DIANA	01	499	14.85
111	38	ASCARATE	03	591	14.46
112	26	CORONADO	01	617	14.22
113	51	ASCARATE	02	345	14.10
114	71	CALIENTE	11	1346	14.00
115	142	CANUTILLO	01	392	12.76
116	211	EAST	01	174	12.43
117	157	SUNSET	05	429	12.20
118	63	RANCHLAND	02	288	11.82
119	176	SUMMIT	01	254	11.49
120	187	DYER	15	184	11.32
121	177	KEMP	01	281	10.10
122	62	HACIENDA	01	326	10.03
123	103	DYER	11	2711	9.95
124	88	FABENS	02	688	9.59
125	40	SUNSET	16	255	9.56
126	130	YSLETA	01	388	9.36
127	140	VISTA	12	2425	9.23
128	35	MILAGRO	14	886	8.86
129	127	ASCARATE	11	1566	8.85
130	116	AMERICAS	11	1234	8.77
131	65	CLARDY	01	686	8.71
132	171	SANTA FE	05	520	8.39
133	100	MILAGRO	11	1320	8.17
134	135	DALLAS	01	319	7.18
135	191	SCOTSDALE	13	2779	6.99
136	22	CINECUE	01	560	6.95
137	174	SANTA FE	02	429	6.82
138	188	SCOTSDALE	11	2547	6.78
139	44	BUTTERFIELD	12	49	6.64

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
140	133	MILAGRO	15	1312	6.47
141	169	DALLAS	12	1756	6.43
142	141	WRANGLER	10	2052	6.07
143	172	DYER	12	1568	6.01
144	69	WHITE	02	256	5.85
145	156	AUSTIN	03	330	5.71
146	215	MANN	15	1296	5.61
147	94	NEWTEX	02	539	5.29
148	11	MESA	18	1192	5.28
149	107	ALTURA	03	391	4.86
150	85	GRACE	01	315	4.72
151	98	SUNSET	04	387	4.26
152	53	NEWTEX	01	510	4.23
153	186	FARAH	11	1957	4.18
154	54	MONTWOOD	20	1921	3.89
155	96	DYER	13	2514	3.73
156	208	DALLAS	17	1272	3.68
157	31	AUSTIN	17	1977	3.51
158	18	MESA	12	2405	3.45
159	21	RIO GRANDE	15	1750	3.38
160	67	MISSION	02	578	3.25
161	50	FABENS	01	249	3.02
162	155	DALLAS	11	1550	2.80
163	181	DALLAS	16	1504	2.44
164	180	LANE	13	2439	2.38
165	90	MANN	14	2181	2.24
166	199	AUSTIN	13	1318	2.17
167	N/A	CLINT	12	982	2.03
168	213	FIVE POINTS	04	335	1.87
169	77	ALTURA	04	423	1.85
170	138	CROMO	13	735	1.51
171	3	ALTURA	01	236	1.50
172	178	SUNSET NORTH	11	1552	1.48
173	161	SOL	12	2331	1.46
174	196	AUSTIN	16	2115	1.20
175	165	SUMMIT	02	281	1.05
176	24	PARKDALE	02	202	1.02
177	205	COPPER	10	2032	0.89
178	173	OCTAVIA	01	315	0.76
179	179	SPARKS	11	1227	0.73
180	136	MESA	13	1812	0.72
181	64	CROMO	11	1032	0.59
182	56	SOL	11	2539	0.52
183	185	AMERICAS	12	3119	0.44
184	168	MONTWOOD	21	1068	0.44
185	154	COPPER	11	1388	0.23
186	32	MULBERRY	01	119	0.22
187	118	SUNSET	02	299	0.18

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
188	28	AUSTIN	12	1533	0.17
189	195	ALTURA	02	344	0.00
190	83	ASCARATE	01	242	0.00
191	197	ASCARATE	12	994	0.00
192	79	ASCARATE	14	1530	0.00
193	198	AUSTIN	11	1876	0.00
194	200	AUSTIN	14	2514	0.00
195	170	AUSTIN	15	2851	0.00
196	201	BUTTERFIELD	10	49	0.00
197	203	BUTTERFIELD	14	12	0.00
198	204	CLARDY	02	256	0.00
199	207	CROMO	14	13	0.00
200	209	DALLAS	02	363	0.00
201	210	DALLAS	04	179	0.00
202	212	EAST	02	298	0.00
203	N/A	FARAH	12	1069	0.00
204	153	FIVE POINTS	02	204	0.00
205	190	FT. HANCOCK	01	450	0.00
206	52	GLOBAL REACH	10	0	0.00
207	192	LA TUNA	01	85	0.00
208	106	LANE	12	2303	0.00
209	214	LATTA	01	547	0.00
210	216	MESA	16	1738	0.00
211	145	MONTOYA	22	13	0.00
212	217	MONTOYA	24	11	0.00
213	N/A	MONTOYA	25	1721	0.00
214	218	MULBERRY	02	239	0.00
215	220	RIO GRANDE	11	1869	0.00
216	221	SANTA FE	01	375	0.00
217	223	SANTA FE	03	441	0.00
218	128	SANTA FE	04	498	0.00
219	222	SANTA FE	10	1437	0.00
220	224	SANTA FE	50	815	0.00
221	146	SIERRA BLANCA	01	130	0.00
222	57	SIERRA BLANCA	20	383	0.00
223	227	SUNSET	01	389	0.00
224	230	SUNSET	07	572	0.00
225	231	SUNSET	08	409	0.00
226	229	SUNSET	13	522	0.00
227	228	SUNSET	10101	815	0.00
228	225	SUNSET NORTH	10	2700	0.00
229	160	VAN HORN	01	287	0.00
230	68	VAN HORN	02	221	0.00
231	4	VISCOUNT	11	2109	0.00
232	34	VISCOUNT	12	2657	0.00
233	232	WRANGLER	11	1271	0.00
234	233	WRANGLER	12	14	0.00
235	234	WRANGLER	14	1632	0.00

Service Quality Report to the Public Utility Commission of Texas

El Paso Electric Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2008 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	37.80%
Vegetation	5.98%
Animals and Birds	10.58%
People (Including cars and farm equip)	4.99%
Utility-owned Equipment	19.44%
Other	10.69%
Unknown	10.53%