




Control Number: 36484



Item Number: 7

Addendum StartPage: 0

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2008 Reporting Year

AEP Texas Central Company

Project 36484

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2008	1.25	0.09	0.05	0.15	0.13	0.11	0.11	0.09	0.15	0.08	0.07	0.06	0.16
Scheduled													
2008	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Outside Causes													
2008	0.26	0.01	0.01	0.04	0.02	0.02	0.02	0.01	0.04	0.05	0.01	0.01	0.02
Major Events													
2008	0.47			0.08		0.03		0.34	0.01	0.01			

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2008	117.9	7.9	4.2	17.0	13.2	11.4	7.8	7.9	14.2	8.6	6.3	5.5	13.9
Scheduled 2008	1.8	0.0	0.0	0.0	0.1	0.3	0.0	0.1	0.1	0.3	0.4	0.3	0.2
Outside Causes 2008	12.2	0.3	0.5	1.7	1.2	0.8	0.8	0.4	1.7	2.2	0.3	1.0	1.3
Major Events 2008	810.7			14.0		3.5		788.8	1.7	2.7			

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With More Than 10 Customers

Total Number of Feeders

717

Add or Delete Rows as Necessary

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
1	86	MOORE FIELD	94SB3120	127	8.835	
2	8	GOVERNMENT WELLS	94LA7240	178	6.303	
3	245	CRESTONIO	94LA270	594	5.421	
4	223	GOODWIN	94SB4390	409	5.056	
5	267	BEEVILLE	94CN300	1,575	4.890	
6	230	BROWNSVILLE	94SB4290	1,608	4.865	
7	118	GARCENO	94SB2135	1,670	4.856	
8	14	CAVAZOS	94SB3560	252	4.825	
9	17	NIXON	94CN810	486	4.817	
10	146	FALFURRIAS	94LA5210	1,096	4.798	
11	257	GREGORY	94CS5900	109	4.761	
12	321	EAST HARRISON	94SB3950	547	4.722	
13	286	ZAPATA	94LA7330	1,188	4.714	
14	53	CARRIZO SPRINGS	94LA370	238	4.462	
15	295	NORTH PADRE ISLAND	94CS7900	1,828	4.393	
16	52	RAYMONDVILLE #2	94SB3170	671	4.390	
17	464	CLARKWOOD	94CS5525	898	4.383	
18	new	RIO BRAVO	94LA1130	921	4.342	
19	23	RIO BRAVO	94LA5	646	4.300	
20	106	ZAPATA	94LA2710	46	4.217	
21	49	PALMVIEW	94SB9685	3,004	4.188	
22	468	VICTORIA POWER PLANT	94CN8170	741	4.080	
23	451	NORTH ALAMO	94SB3610	3,390	4.071	
24	72	MCKENZIE ROAD	94CS140	246	4.069	
25	152	RODD FIELD	94CS225	1,172	3.974	
26	155	CABANISS	94CS240	1,424	3.920	
27	512	MOORE FIELD	94SB3110	581	3.919	
28	18	HALL ACRES ROAD	94SB5465	1,557	3.861	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
29	415	ROMA	94SB3070	819	3.830	
30	458	RANGERVILLE	94SB4060	853	3.825	
31	542	SOUTH MCALLEN	94SB3640	252	3.817	
32	177	PHARR	94SB1625	1,936	3.763	
33	448	SOUTH SANTA ROSA	94SB1235	625	3.744	
34	383	EDROY	94CS6980	196	3.684	
35	91	ELSA	94SB710	1,578	3.667	
36	64	PORT ISABEL S.S.	94SB9295	442	3.611	
37	621	CHARLOTTE	94LA2790	95	3.558	
38	515	GANADO	94CN5815	572	3.554	
39	337	LOS FRESNOS	94SB3280	1,913	3.554	
40	192	CRYSTAL CITY	94LA330	1,146	3.549	
41	54	LA PRYOR	94LA580	179	3.547	
42	193	HALL ACRES ROAD	94SB5585	676	3.507	
43	57	MALONE	94CN7560	96	3.500	
44	315	HIDALGO	94SB4845	976	3.500	
45	100	BANQUETTE	94CS9000	435	3.474	
46	502	JOURDANTON	94LA5695	1,242	3.461	
47	563	NORTH WESLACO	94SB4810	1,275	3.391	
48	2	RAYMONDVILLE #2	94SB3250	32	3.375	
49	159	PORT ISABEL S.S.	94SB4070	291	3.361	
50	239	CASA BLANCA	94CS1300	1,020	3.334	
51	339	LA PRYOR	94LA570	126	3.333	
52	165	SOUTH PADRE ISLAND	94SB5850	1,387	3.317	
53	333	HARLINGEN	94SB660	2,472	3.311	
54	156	JOURDANTON	94LA880	281	3.281	
55	133	FREER	94LA1500	177	3.243	
56	331	NAVAL BASE	94CS8440	1,556	3.240	
57	26	SOUTH MISSION	94SB3980	1,197	3.234	
58	557	CITRUS CITY	94SB9775	1,921	3.223	
59	243	LOS FRESNOS	94SB3290	1,311	3.174	
60	514	MOORE FIELD	94SB3960	1,514	3.149	
61	51	PORT ISABEL S.S.	94SB3820	203	3.138	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
62	699	HALL ACRES ROAD	94SB8870	3,614	3.136	
63	143	GOODWIN	94SB4625	334	3.135	
64	546	CHARLOTTE	94LA2780	502	3.106	
65	453	MCCOLL ROAD	94SB2810	2,227	3.092	
66	296	SANTO NINO	94LA75	1,424	3.068	
67	426	SANTO NINO	94LA80	2,328	3.028	
68	227	HEARN ROAD	94CS8990	1,144	3.024	
69	1	CAVAZOS	94SB3550	2,270	3.007	
70	20	BONNIEVIEW	94CS8020	505	2.976	
71	534	SOUTH SANTA ROSA	94SB1215	1,864	2.886	
72	16	NORTH MCALLEN	94SB2750	2,859	2.850	
73	457	WEST HARLINGEN	94SB3720	2,005	2.787	
74	36	MUSTANG ISLAND	94CS8510	397	2.746	
75	88	SOUTH EAST EDINBURG	94SB4570	1,321	2.742	
76	566	MCCOLL ROAD	94SB4400	2,147	2.741	
77	275	SINTON	94CS180	936	2.736	
78	13	HIDALGO	94SB3400	843	2.728	
79	680	BEEVILLE	94CN2380	196	2.724	
80	643	RIO BRAVO	94LA300	788	2.723	
81	43	ODEM	94CS375	1,001	2.711	
82	413	SAN YGNACIO	94LA16060	476	2.708	
83	198	FREER	94LA2900	141	2.702	
84	6	RIO RICO	94SB8330	575	2.696	
85	67	UVALDE	94LA480	1,243	2.677	
86	260	SOUTHSIDE	94CS5335	1,139	2.673	
87	374	WEST HARLINGEN	94SB3800	1,288	2.654	
88	104	GREENLAKE	94CN2760	567	2.637	
89	217	SANTO NINO	94LA70	772	2.596	
90	362	PORT ARANSAS	94CS3030	790	2.592	
91	3	RACHAL	94LA8145	356	2.581	
92	259	PORTLAND	94CS9290	1,665	2.557	
93	229	HIGHWAY 9	94CS6720	1,320	2.547	
94	89	HARLINGEN S.S.	94SB4110	935	2.529	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
95	636	POLK AVENUE	94SB4610	1,311	2.471	
96	350	PUEBLO	94LA95	1,878	2.439	
97	70	PREMONT	94LA6610	800	2.434	
98	470	MATHIS	94CS2870	850	2.429	
99	108	MAVERICK	94LA9680	680	2.429	
100	42	NUECES BAY PLANT	94CS350	699	2.423	
101	226	FALFURRIAS	94LA2830	1,623	2.419	
102	688	ROCKSPRINGS	94LA2600	374	2.412	
103	578	EL CAMPO	94CN2800	1,275	2.411	
104	603	HIGHWAY 9	94CS6770	1,182	2.404	
105	134	LA GRULLA	94SB5110	2,146	2.402	
106	647	NORTH MCALLEN	94SB5055	3,159	2.393	
107	256	TAFT	94CS1180	1,050	2.391	
108	309	NORTH EDINBURG	94SB3570	952	2.382	
109	291	EAGLE PASS CITY	94LA2770	3,263	2.361	
110	696	HIGHWAY 9	94CS7210	323	2.347	
111	510	MCKENZIE ROAD	94CS150	27	2.333	
112	231	DEL RIO CITY	94LA420	2,317	2.323	
113	346	WESMER	94SB9705	981	2.318	
114	508	HIGHWAY 9	94CS6730	508	2.315	
115	547	BAY CITY	94CN2700	1,073	2.299	
116	161	FALFURRIAS	94LA1070	846	2.298	
117	564	BROOKHOLLOW	94CN7580	425	2.294	
118	202	BRUNI	94LA1100	632	2.283	
119	590	SOUTHSIDE	94CS8045	1,015	2.278	
120	387	MAGRUDER	94CN6700	1,440	2.276	
121	201	PHARAOH	94CS1185	1,513	2.265	
122	380	POLK AVENUE	94SB4600	3,278	2.239	
123	560	WESLACO UNIT	94SB8610	2,350	2.239	
124	22	HOLLY	94CS7620	2,291	2.218	
125	247	ELSA	94SB3520	397	2.194	
126	439	HIGHWAY 9	94CS7200	560	2.188	
127	4	LOS FRESNOS	94SB3200	497	2.183	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
128	307	EAGLE PASS CITY	94LA2650	1,253	2.173	
129	340	RANGERVILLE	94SB3410	771	2.149	
130	44	LYTLE	94LA2850	581	2.148	
131	191	FREER	94LA6320	149	2.148	
132	334	MILO	94LA3070	2,910	2.136	
133	330	SOUTH PADRE ISLAND	94SB6440	2,368	2.112	
134	478	KLEBERG	94CS9395	1,316	2.107	
135	40	NORTH MCALLEN	94SB3830	1,273	2.097	
136	655	POLK AVENUE	94SB4740	1,735	2.076	
137	649	VICTORIA POWER PLANT	94CN8070	615	2.075	
138	398	HARLINGEN S.S.	94SB320	1,436	2.075	
139	403	KLEBERG	94CS8140	354	2.062	
140	34	PETTUS	94CN8210	351	2.054	
141	639	BLESSING	94CN8780	65	2.031	
142	252	ZAPATA	94LA8300	1,683	2.027	
143	185	UNIVERSITY	94LA950	2,103	2.022	
144	602	VICTORIA POWER PLANT	94CN7600	156	2.000	
145	711	VICTORIA POWER PLANT	94CNNETVIC	71	2.000	
146	481	LIVE OAK	94CS1090	243	2.000	
147	21	HIDALGO	94SB3680	311	1.977	
148	81	DILLEY	94LA6400	767	1.931	
149	168	PLACEDO	94CN7970	452	1.912	
150	277	BROOKHOLLOW	94CN7190	261	1.904	
151	113	NORTH ALAMO	94SB3580	1,803	1.904	
152	126	PEARSALL	94LA9905	716	1.902	
153	77	RANDADO	94LA8360	148	1.899	
154	285	ROBSTOWN	94CS1650	336	1.893	
155	440	NORTH MERCEDES	94SB3770	1,590	1.891	
156	523	CITRUS CITY	94SB3470	2,603	1.876	
157	408	BLESSING	94CN8790	719	1.872	
158	662	LAREDO HEIGHTS	94LA2100	1,707	1.869	
159	310	NORTH MCALLEN	94SB9660	1,962	1.858	
160	558	LEARY LANE	94CN7530	1,890	1.853	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
161	543	MCCOLL ROAD	94SB4790	1,827	1.852	
162	375	SANTO NINO	94LA645	602	1.842	
163	287	SKIDMORE	94CS380	312	1.833	
164	107	UVALDE	94LA5060	1,296	1.829	
165	594	WEST MCALLEN	94SB4535	2,657	1.806	
166	153	CABANISS	94CS75	1,939	1.781	
167	317	PRAIRIE PUMP	94CN1940	58	1.776	
168	535	HARLINGEN	94SB360	2,483	1.768	
169	342	WEST OSO	94CS9085	746	1.753	
170	691	HAINE DRIVE	94SB9240	44	1.750	
171	397	PREMONT	94LA2730	195	1.738	
172	661	KENEDY S.S.	94CN8320	652	1.735	
173	605	RAYMONDVILLE #1	94SB630	767	1.721	
174	56	MILO	94LA8365	2,157	1.708	
175	343	CAUSEWAY	94SB4795	1,138	1.702	
176	144	WEST HARLINGEN	94SB3700	1,650	1.701	
177	79	NORTH MERCEDES	94SB3840	619	1.700	
178	548	ELSA	94SB3500	1,067	1.694	
179	431	ALICE	94CS1770	1,496	1.687	
180	164	PLEASANTON	94LA2080	1,492	1.673	
181	225	LAGUNA	94CS9590	2,077	1.664	
182	305	PORT ARANSAS	94CS6940	1,575	1.655	
183	438	YORKTOWN	94CN8420	1,014	1.654	
184	444	SOUTHSIDE	94CS7955	1,061	1.650	
185	357	TATTON	94CN8490	119	1.647	
186	694	HIGHWAY 9	94CS9830	132	1.644	
187	561	NORTH EDINBURG	94SB4240	2,025	1.643	
188	449	HIGHWAY 9	94CS6760	608	1.641	
189	163	RAYMONDVILLE #1	94SB620	610	1.638	
190	120	NUECES BAY PLANT	94CS7830	152	1.625	
191	476	BEEVILLE	94CN8510	835	1.624	
192	487	NIXON	94CN5990	577	1.622	
193	279	LIVE OAK	94CS1070	2,736	1.616	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
194	205	ARANSAS PASS	94CS9130	303	1.614	
195	601	PORT ARANSAS	94CS990	1,309	1.608	
196	292	WEIL TRACT (138/12KV)	94CS5405	144	1.604	
197	434	ALICE	94CS2540	1,117	1.596	
198	187	RODD FIELD	94CS1730	1,981	1.578	
199	625	WEST MCALLEN	94SB4595	1,037	1.577	
200	141	WESMER	94SB4050	2,471	1.570	
201	271	GREENLAKE	94CN2750	1,075	1.564	
202	455	ALICE	94CS2530	1,432	1.559	
203	511	HALL ACRES ROAD	94SB4895	742	1.559	
204	682	PHARR	94SB1620	2,634	1.558	
205	598	NORTH MERCEDES	94SB4860	1,369	1.548	
206	31	MATTHEWS	94CN1740	160	1.544	
207	242	CLARKWOOD	94CS7230	549	1.543	
208	409	PLEASANTON	94LA9505	1,416	1.535	
209	520	KINGSVILLE	94CS1130	2,096	1.533	
210	103	ELSA	94SB690	2,067	1.532	
211	506	ARCADIA	94CS5020	1,516	1.524	
212	74	TAFT	94CS1260	186	1.522	
213	519	BAY CITY	94CN6670	1,759	1.517	
214	124	BROWNSVILLE	94SB4280	227	1.511	
215	319	ARCADIA	94CS1360	1,534	1.505	
216	58	CARRIZO SPRINGS	94LA860	1,027	1.501	
217	142	MATHIS	94CS340	1,461	1.499	
218	109	POLK AVENUE	94SB4170	1,579	1.495	
219	188	GOLIAD	94CN6540	1,107	1.490	
220	184	GANADO	94CN5795	630	1.478	
221	420	BERCLAIR	94CN990	297	1.478	
222	584	NORDHEIM	94CN470	237	1.477	
223	282	COLUMBUS	94CN930	901	1.466	
224	224	NAVAL BASE	94CS1380	2,167	1.459	
225	222	BRUNI	94LA5160	148	1.459	
226	349	GEORGE WEST	94CN1320	641	1.454	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
227	154	BRUNI	94LA5440	113	1.451	
228	213	MILO	94LA6940	183	1.448	
229	182	SAN BENITO	94SB4030	2,331	1.446	
230	199	KLEBERG	94CS1560	1,290	1.436	
231	452	EAGLE PASS CITY	94LA7060	799	1.432	
232	640	BEEVILLE	94CN490	924	1.430	
233	46	ROMA	94SB3060	1,480	1.430	
234	278	BLESSING	94CN1030	233	1.429	
235	501	STADIUM	94CS7490	1,228	1.429	
236	592	UVALDE	94LA9770	1,248	1.429	
237	635	MINES ROAD	94LA3745	1,293	1.424	
238	485	HARLINGEN	94SB380	2,281	1.423	
239	627	EL CAMPO	94CN7710	1,059	1.416	
240	76	NORTH MCALLEN	94SB4995	1,826	1.415	
241	572	GEORGE WEST	94CN730	859	1.407	
242	158	WEST OSO	94CS9090	1,738	1.405	
243	80	JOURDANTON	94LA5685	532	1.404	
244	700	ROCKSPRINGS	94LA8040	323	1.396	
245	95	PREMONT	94LA6570	723	1.394	
246	472	BANQUETTE	94CS130	233	1.391	
247	116	BROWNSVILLE	94SB3050	1,918	1.389	
248	504	ARANSAS PASS	94CS8280	542	1.386	
249	526	CHARLOTTE	94LA8120	197	1.381	
250	345	FULTON	94CS2020	1,781	1.377	
251	284	WESLACO UNIT	94SB7630	3,436	1.376	
252	500	THREE RIVERS	94CN2010	860	1.374	
253	45	RANGERVILLE	94SB3420	746	1.373	
254	529	WEST HARLINGEN	94SB4870	528	1.371	
255	573	HAINES DRIVE	94SB9700	754	1.369	
256	150	DEL RIO CITY	94LA9790	2,543	1.366	
257	82	EL CAMPO	94CN5745	869	1.364	
258	645	MAGRUDER	94CN6690	551	1.363	
259	127	PHARAOH	94CS5175	979	1.363	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
260	290	VICTORIA POWER PLANT	94CN1390	1,131	1.361	
261	491	REFUGIO	94CN5120	160	1.356	
262	674	MORRIS STREET	94CS7625	535	1.350	
263	101	GATEWAY	94LA350	1,232	1.346	
264	68	SOUTH SANTA ROSA	94SB1240	1,453	1.344	
265	347	STADIUM	94CS8540	1,615	1.342	
266	372	PORT LAVACA	94CN6850	591	1.337	
267	459	SAN DIEGO	94CS2880	1,177	1.329	
268	174	REFUGIO	94CN1170	876	1.325	
269	172	RAYMONDVILLE #1	94SB800	693	1.325	
270	131	STAFFORD HILL	94CN1550	204	1.314	
271	671	HAMILTON ROAD	94LA9665	924	1.314	
272	167	RIO RICO	94SB8290	105	1.314	
273	427	BISHOP	94CS7180	948	1.309	
274	110	CABANISS	94CS80	1,065	1.301	
275	568	PALMHURST	94SB2530	1,775	1.299	
276	197	DEVINE	94LA8100	1,436	1.295	
277	41	MORRIS STREET	94CS5655	1,012	1.293	
278	111	BEEVILLE	94CN2200	735	1.286	
279	171	RACHAL	94LA6595	294	1.286	
280	85	KLEBERG	94CS6410	396	1.285	
281	554	CLARKWOOD	94CS7610	183	1.284	
282	203	WEIL TRACT (138/12KV)	94CS2520	536	1.282	
283	98	LULING - LCRA	94CN10	321	1.274	
284	698	SOUTH MCALLEN	94SB3850	762	1.272	
285	498	COTULLA	94LA110	1,176	1.263	
286	102	ENCINAL	94LA2160	764	1.257	
287	686	ZACATE CREEK	94LA2665	1,634	1.255	
288	261	BISHOP	94CS2690	555	1.252	
289	411	HOLLY	94CS1220	2,433	1.247	
290	646	BAY CITY	94CN1110	1,299	1.245	
291	412	PEARSALL	94LA7050	1,271	1.243	
292	450	ALICE	94CS1780	271	1.232	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
293	595	NORTH WESLACO	94SB4830	474	1.232	
294	195	SOUTH EAST EDINBURG	94SB5045	1,760	1.230	
295	180	EL CAMPO	94CN7260	523	1.229	
296	352	FULTON	94CS440	1,962	1.228	
297	657	NORTH MCALLEN	94SB9640	1,370	1.228	
298	300	KENEDY	94CN6270	473	1.226	
299	611	HAMILTON ROAD	94LA9645	279	1.226	
300	416	DEL RIO CITY	94LA1930	911	1.220	
301	454	BANDERA ELECTRIC (LEAKEY)	94LAL30	264	1.216	
302	638	AIRLINE	94CS6970	1,196	1.214	
303	585	PLEASANTON	94LA120	1,195	1.206	
304	381	SOUTH MISSION	94SB3590	651	1.206	
305	527	HOLLY	94CS1950	786	1.205	
306	new	PALMVIEW	94SB7595	2,580	1.201	
307	30	CONTINENTAL	94SB4080	121	1.198	
308	632	KENEDY S.S.	94CN8340	881	1.193	
309	136	PHARAOH	94CS1285	1,720	1.189	
310	467	LA PRYOR	94LA2440	638	1.188	
311	388	PHARAOH	94CS1365	455	1.182	
312	377	WASHINGTON STREET	94LA7015	1,915	1.182	
313	269	EAST HARRISON	94SB4310	1,155	1.178	
314	363	WEST MCALLEN	94SB4505	1,832	1.174	
315	654	PHARR	94SB1645	1,751	1.172	
316	276	EAGLE PASS CITY	94LA2745	896	1.169	
317	190	SHARYLAND	94SB2035	2,244	1.157	
318	612	NORTH PADRE ISLAND	94CS720	1,027	1.157	
319	436	KENEDY S.S.	94CN6750	754	1.149	
320	619	HOLLY	94CS9675	1,726	1.146	
321	492	EAST HARRISON	94SB3190	1,405	1.144	
322	666	AIRLINE	94CS7270	999	1.135	
323	386	ARANSAS PASS	94CS1250	353	1.133	
324	370	SOUTH PADRE ISLAND	94SB4695	1,309	1.132	
325	604	WEST MCALLEN	94SB4965	697	1.131	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
326	565	TATTON	94CS950	511	1.129	
327	24	BRUNI	94LA1120	144	1.125	
328	435	COLUMBUS	94CN6180	1,175	1.124	
329	660	MCCOLL ROAD	94SB4780	2,021	1.123	
330	390	EAGLE LAKE	94CN320	649	1.122	
331	140	FULTON	94CS9050	1,590	1.122	
332	373	PHARAOH	94CS5185	1,722	1.120	
333	626	SUNCHASE	94SB1150	1,187	1.120	
334	479	LAGUNA	94CS9065	1,962	1.115	
335	62	NORTH PADRE ISLAND	94CS1010	1,801	1.114	
336	10	WEIL TRACT (138/12KV)	94CS1990	1,252	1.109	
337	162	GRETA	94CN7890	295	1.108	
338	580	WESMER	94SB6900	1,433	1.108	
339	530	NORTH VICTORIA	94CN7860	1,447	1.104	
340	606	LAREDO HEIGHTS	94LA6820	2,049	1.102	
341	93	HOLLY	94CS5820	929	1.098	
342	208	SEAWALL	94CS9420	836	1.096	
343	7	MILO	94LA3065	167	1.096	
344	160	THOMASTON	94CN9580	42	1.095	
345	684	WASHINGTON STREET	94LA2360	665	1.092	
346	562	HAINE DRIVE	94SB270	810	1.091	
347	433	PALMHURST	94SB2525	1,661	1.089	
348	624	THREE RIVERS	94CN8430	161	1.081	
349	181	NUECES BAY PLANT	94CS345	51	1.078	
350	395	EAGLE PASS CITY	94LA2510	632	1.078	
351	663	RODD FIELD	94CS205	1,500	1.077	
352	406	PALMVIEW	94SB3930	661	1.067	
353	new	WESMER	94SB7760	1,206	1.066	piece of 94SB4480
354	664	PARKER	94CN9010	16	1.063	
355	692	MINES ROAD	94LA4275	100	1.060	
356	new station	OLMITO	94SB4275	764	1.060	
357	609	LAREDO HEIGHTS	94LA9400	1,367	1.059	
358	293	SEAWALL	94CS9450	283	1.053	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
359	648	PORT ARANSAS	94CS1000	1,303	1.049	
360	681	DEL MAR	94LA490	580	1.045	
361	151	PREMONT	94LA2720	772	1.044	
362	11	MUSTANG ISLAND	94CS9470	641	1.042	
363	616	LEARY LANE	94CN6005	2,039	1.041	
364	474	WOODSBORO	94CS8330	1,072	1.035	
365	336	CONTINENTAL	94SB4880	68	1.029	
366	705	RODD FIELD	94CS245	3,008	1.023	
367	703	MILO	94LA5020	1,277	1.022	
368	702	THREE RIVERS	94CN2580	59	1.017	
369	338	STADIUM	94CS6950	526	1.013	
370	360	MAGRUDER	94CN245	1,120	1.010	
371	586	HOLLY	94CS7740	2,007	1.001	
372	32	NORTH EDINBURG	94SB560	1,382	1.000	
373	105	SHARYLAND	94SB2010	1,543	0.994	
374	327	RIO GRANDE CITY	94SB3740	3,284	0.994	
375	394	CRYSTAL CITY	94LA190	950	0.986	
376	367	SAN BENITO	94SB4135	1,217	0.975	
377	175	RIO GRANDE CITY	94SB3220	1,689	0.974	
378	125	ASHERTON	94LA2670	143	0.972	
379	48	COMSTOCK	94LA290	181	0.972	
380	538	INGLESIDE CITY	94CS8050	1,735	0.964	
381	254	EAST HARRISON	94SB4360	1,660	0.951	
382	344	KINGSVILLE	94CS1670	422	0.945	
383	235	EDROY	94CS6990	267	0.936	
384	351	LOLITA	94CN6330	30	0.933	
385	61	ALAZAN	94CS2740	29	0.931	
386	173	PETTUS	94CN1020	387	0.910	
387	325	HAIN DRIVE	94SB3490	914	0.894	
388	50	ARMSTRONG	94CS6050	65	0.892	
389	311	WEST MCALLEN	94SB6385	190	0.889	
390	610	ARCADIA	94CS5030	1,543	0.887	
391	313	HARLINGEN S.S.	94SB4090	2,216	0.887	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
392	122	WASHINGTON STREET	94LA6525	2,004	0.885	
393	204	KNIPPA	94LA6365	305	0.879	
394	280	SINTON	94CS360	285	0.877	
395	60	RANDADO	94LA8350	121	0.876	
396	94	LOS FRESNOS	94SB930	1,829	0.872	
397	137	MALONE	94CN7550	161	0.870	
398	490	RAYMONDVILLE #2	94SB4160	731	0.870	
399	84	MINES ROAD	94LA3680	821	0.868	
400	298	LEARY LANE	94CN1540	775	0.867	
401	233	GOODWIN	94SB3530	1,225	0.857	
402	289	REFUGIO	94CN1040	721	0.853	
403	69	PEARSALL	94LA5580	1,595	0.852	
404	169	ZAPATA	94LA8290	1,981	0.849	
405	533	CAMPWOOD	94LA3430	78	0.846	
406	246	YORKTOWN	94CN8380	786	0.836	
407	667	DEL MAR	94LA220	635	0.836	
408	35	CONTINENTAL	94SB3650	24	0.833	
409	new	WESMER	94SB1850	450	0.824	
410	39	SOUTH EAST EDINBURG	94SB6580	1,306	0.824	
411	38	STADIUM	94CS7810	1,613	0.816	
412	92	SANTO NINO	94LA515	2,257	0.813	
413	608	CRESTONIO	94LA260	1,738	0.812	
414	466	LULING - LCRA	94CN20	250	0.808	
415	379	HALL ACRES ROAD	94SB3670	785	0.808	
416	704	KENEDY	94CN1960	57	0.807	
417	73	UVALDE	94LA540	1,197	0.807	
418	400	SOUTH SANTA ROSA	94SB1225	797	0.807	
419	12	NIXON	94CN2620	593	0.804	
420	255	KLEBERG	94CS6000	1,486	0.799	
421	629	CRESTONIO	94LA6660	729	0.791	
422	404	WEST MCALLEN	94SB4515	1,328	0.785	
423	119	CLARKWOOD	94CS9570	1,143	0.782	
424	121	MARKHAM	94CN5550	96	0.781	

piece of 94SB4050

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
425	249	BUENA VISTA	94LA9035	1,440	0.776	
426	631	STADIUM	94CS7800	649	0.775	
427	200	ARANSAS PASS	94CS8270	610	0.774	
428	518	NORTH VICTORIA	94CN7770	813	0.772	
429	117	NORTH EDINBURG	94SB3810	794	0.771	
430	582	PORT ISABEL S.S.	94SB3760	1,998	0.762	
431	324	SKIDMORE	94CS600	353	0.759	
432	620	BIG WELLS	94LA1570	396	0.753	
433	5	LA GRULLA	94SB5005	961	0.753	
434	405	PALMHURST	94SB2535	1,179	0.744	
435	59	PHARR	94SB1640	956	0.723	
436	701	AIRLINE	94CS7390	1,433	0.719	
437	304	GATEWAY	94LA390	775	0.715	
438	157	NORTH ALAMO	94SB4370	2,305	0.715	
439	55	ALAZAN	94CS620	157	0.707	
440	499	EAST HARRISON	94SB4620	764	0.704	
441	19	DARST	94CN800	160	0.700	
442	497	SOUTHSIDE	94CS7995	1,529	0.685	
443	517	MILO	94LA3060	73	0.685	
444	132	BEEVILLE	94CN1760	1,740	0.679	
445	265	HOLLY	94CS1480	1,691	0.677	
446	555	ARCADIA	94CS1450	1,868	0.668	
447	186	SAN BENITO	94SB3920	2,226	0.666	
448	316	MORRIS STREET	94CS8820	1,254	0.656	
449	206	PALMVIEW	94SB6790	2,478	0.654	
450	219	TATTON	94CS8200	954	0.650	
451	569	GOVERNMENT WELLS	94LA7250	579	0.648	
452	446	ROCKPORT	94CS5950	547	0.640	
453	348	WADSWORTH	94CN7660	1,254	0.635	
454	384	RIO GRANDE CITY	94SB3230	1,057	0.634	
455	462	WADSWORTH	94CN8630	626	0.629	
456	251	MORRIS STREET	94CS2515	1,086	0.628	
457	540	TAFT	94CS5230	805	0.625	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
458	264	DILLEY	94LA510	514	0.619	
459	183	GOVERNMENT WELLS	94LA6800	225	0.618	
460	634	LA GRULLA	94SB4120	1,216	0.617	
461	483	FULTON	94CS6070	2,932	0.616	
462	419	NORTH MCALLEN	94SB5060	2,095	0.613	
463	574	ARCADIA	94CS6930	1,499	0.612	
464	135	UVALDE	94LA6620	2,619	0.603	
465	532	WEST OSO	94CS9095	1,469	0.602	
466	473	AIRLINE	94CS9030	413	0.600	
467	659	JOURDANTON	94LA250	711	0.588	
468	248	KENEDY	94CN1970	641	0.585	
469	253	SOUTHSIDE	94CS7905	1,826	0.576	
470	297	SEAWALL	94CS9325	1,411	0.573	
471	145	CAUSEWAY	94SB4765	1,162	0.573	
472	341	LIVE OAK	94CS1080	746	0.572	
473	396	SOUTH MCALLEN	94SB3790	1,836	0.572	
474	544	GARCENO	94SB2130	3,150	0.567	
475	503	LEARY LANE	94CN1890	1,553	0.563	
476	148	RODD FIELD	94CS2190	3,305	0.563	
477	633	PARKER	94CN9260	91	0.560	
478	471	ASHERTON	94LA2660	548	0.560	
479	299	SOUTHSIDE	94CS8035	1,080	0.558	
480	306	RIO RICO	94SB5050	1,564	0.558	
481	215	LAREDO HEIGHTS	94LA6810	1,983	0.553	
482	365	INGLESIDE CITY	94CS6040	260	0.550	
483	66	MORRIS STREET	94CS8715	1,577	0.549	
484	221	ARCADIA	94CS1460	1,972	0.547	
485	179	NORTH PADRE ISLAND	94CS5170	1,074	0.547	
486	421	PALACIOS	94CN8550	37	0.541	
487	428	SOUTHSIDE	94CS8005	751	0.541	
488	37	ODEM	94CS5575	57	0.526	
489	78	CARRIZO SPRINGS	94LA910	1,807	0.525	
490	423	FOSTER FIELD	94CN2550	330	0.518	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
491	268	MAGRUDER	94CN6680	683	0.517	
492	460	HIGHWAY 9	94CS6780	790	0.516	
493	90	PALMHURST	94SB2820	1,771	0.513	
494	274	MAGRUDER	94CN7690	562	0.505	
495	216	PORT LAVACA	94CN8310	308	0.503	
496	<10 customers	CHASE FIELD	94CN460	12	0.500	
497	301	NORTH VICTORIA	94CN7440	1,606	0.496	
498	258	SUNCHASE	94SB1155	1,383	0.495	
499	322	SAN DIEGO	94CS1980	581	0.487	
500	414	EAST HARRISON	94SB3030	710	0.487	
501	328	BEEVILLE	94CN8090	1,212	0.480	
502	114	AIRLINE	94CS9605	697	0.479	
503	576	KINGSVILLE	94CS1140	992	0.477	
504	644	DEL RIO CITY	94LA430	2,445	0.467	
505	241	SHARYLAND	94SB6745	2,001	0.465	
506	139	PALACIOS	94CN6840	1,524	0.461	
507	83	SAN BENITO	94SB3910	1,716	0.461	
508	214	UNIVERSITY	94LA920	420	0.460	
509	237	MCKENZIE ROAD	94CS330	2,243	0.457	
510	537	EAST HARRISON	94SB3080	353	0.442	
511	445	WESLACO UNIT	94SB5970	2,754	0.442	
512	303	ANNA STREET	94LA850	1,552	0.441	
513	212	UNIVERSITY	94LA930	699	0.441	
514	665	WEAVER ROAD	94CN1900	48	0.438	
515	456	SOUTHSIDE	94CS8025	1,029	0.430	
516	189	PALACIOS	94CN6830	821	0.425	
517	238	SAN DIEGO	94CS2930	599	0.422	
518	178	FALFURRIAS	94LA1080	434	0.422	
519	525	WESLACO UNIT	94SB7455	1,254	0.419	
520	493	WESLACO UNIT	94SB9805	2,776	0.413	
521	332	WOOLRIDGE	94CS1170	1,265	0.411	
522	488	CAMPWOOD	94LA2610	905	0.409	
523	477	KLEBERG	94CS280	1,124	0.408	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
524	361	ARCADIA	94CS1440	1,591	0.407	
525	480	COFFEE PORT	94SB1090	1,114	0.405	
526	149	THREE RIVERS	94CN5190	783	0.402	
527	570	PORTLAND	94CS9270	1,877	0.400	
528	27	KINGSVILLE	94CS1660	1,540	0.394	
529	209	GREENLAKE	94CN2740	28	0.393	
530	522	CITRUS CITY	94SB7985	1,482	0.387	
531	220	MARKHAM	94CN6440	426	0.385	
532	469	BAY CITY	94CN5960	1,862	0.383	
533	687	DEL RIO CITY	94LA440	822	0.381	
534	308	AIRLINE	94CS8370	295	0.380	
535	630	HAINE DRIVE	94SB9690	830	0.380	
536	613	WEST MCALLEN	94SB4555	1,451	0.378	
537	521	LAREDO HEIGHTS	94LA2450	2,459	0.375	
538	207	CASA BLANCA	94CS55	808	0.371	
539	509	PLEASANTON	94LA9475	1,319	0.367	
540	382	CRYSTAL CITY	94LA140	1,191	0.365	
541	270	SINTON	94CS6860	1,558	0.364	
542	112	GOLIAD	94CN8220	1,016	0.363	
543	589	ANNA STREET	94LA900	2,832	0.362	
544	447	POLK AVENUE	94SB4900	2,569	0.362	
545	15	MATHIS	94CS1410	454	0.357	
546	402	LAREDO HEIGHTS	94LA9080	681	0.354	
547	250	PORT LAVACA	94CN2480	1,509	0.353	
548	596	SABINAL	94LA485	481	0.351	
549	622	LAREDO PLANT	94LA8505	762	0.350	
550	571	GREGORY	94CS8560	803	0.344	
551	552	ARANSAS PASS	94CS590	408	0.343	
552	236	PORT LAVACA	94CN2490	1,069	0.341	
553	549	FREER	94LA5200	990	0.328	
554	482	UVALDE	94LA550	640	0.327	
555	641	FULTON	94CS3070	1,550	0.325	
556	354	NORTH VICTORIA	94CN1580	1,039	0.321	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
557	359	WESLACO UNIT	94SB8195	1,683	0.320	
558	541	PORTLAND	94CS6505	1,629	0.319	
559	531	RUNGE	94CN7320	593	0.314	
560	494	LEARY LANE	94CN1430	1,565	0.313	
561	617	BAY CITY	94CN6450	972	0.313	
562	314	HEARN ROAD	94CS8980	1,012	0.313	
563	244	LAREDO PLANT	94LA9305	873	0.312	
564	364	ELSA	94SB700	1,335	0.310	
565	708	ESCONDIDO	94LA1510	673	0.308	
566	536	HOLLY	94CS1370	1,889	0.307	
567	505	PUEBLO	94LA275	2,573	0.304	
568	495	CARANCAHUA	94CN5870	412	0.301	
569	228	COTULLA	94LA90	687	0.298	
570	600	SAN DIEGO	94CS2890	1,024	0.289	
571	87	EDNA	94CN5775	495	0.285	
572	672	ZACATE CREEK	94LA2675	1,416	0.284	
573	353	SOUTH MCALLEN	94SB3935	1,183	0.282	
574	465	DEVINE	94LA7090	904	0.281	
575	693	NORTH VICTORIA	94CN1470	440	0.280	
576	130	HAMILTON ROAD	94LA9655	1,110	0.270	
577	323	HALL ACRES ROAD	94SB3460	3,335	0.269	
578	463	SAN BENITO	94SB3860	245	0.265	
579	97	ARCADIA	94CS1400	424	0.264	
580	320	WASHINGTON STREET	94LA2350	3,096	0.264	
581	545	BAY CITY	94CN2050	506	0.261	
582	668	WEST MCALLEN	94SB4815	716	0.256	
583	138	EDNA	94CN5785	736	0.253	
584	677	MORRIS STREET	94CS8840	594	0.253	
585	33	O CONNER	94CN390	215	0.251	
586	210	PALMVIEW	94SB9680	1,283	0.249	
587	588	BROOKHOLLOW	94CN8960	551	0.247	
588	623	WEAVER ROAD	94CN1910	353	0.246	
589	593	SOUTH MISSION	94SB3620	1,822	0.244	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
590	461	NAVAL BASE	94CS6330	376	0.242	
591	355	POLK AVENUE	94SB4190	1,672	0.241	
592	389	POLK AVENUE	94SB4180	1,135	0.238	
593	496	NORTH VICTORIA	94CN7430	1,709	0.237	
594	577	HEARN ROAD	94CS870	1,098	0.236	
595	new	GATEWAY	94LA5055	1,805	0.233	
596	176	ODEM	94CS385	382	0.228	
597	437	POINT COMFORT	94CN2460	349	0.226	
598	539	REFUGIO	94CN1210	213	0.225	
599	524	MORRIS STREET	94CS8830	1,523	0.225	
600	170	POINT COMFORT	94CN6060	49	0.224	
601	607	LAREDO PLANT	94LA8695	975	0.224	
602	318	ALICE	94CS1790	339	0.221	
603	28	RIO GRANDE CITY	94SB3210	1,619	0.221	
604	75	DEL MAR	94LA3440	1,368	0.220	
605	266	GREGORY	94CS5920	503	0.219	
606	294	INGLESIDE CITY	94CS8060	2,005	0.217	
607	430	COLUMBUS	94CN9060	382	0.215	
608	194	ROCKPORT	94CS5930	1,046	0.215	
609	658	SABINAL	94LA200	404	0.213	
610	358	GOODWIN	94SB4380	1,361	0.211	
611	679	HEARN ROAD	94CS9665	553	0.208	
612	587	BAY CITY	94CN7480	1,901	0.207	
613	410	BRACKETTVILLE	94LA8460	1,161	0.207	
614	273	BUENA VISTA	94LA9385	2,008	0.202	
615	442	ARANSAS PASS	94CS650	734	0.200	
616	567	SOUTHSIDE	94CS7925	1,362	0.198	
617	689	WOOLRIDGE	94CS1110	1,395	0.196	
618	422	EL CAMPO	94CN2860	550	0.195	
619	418	AIRLINE	94CS5870	853	0.195	
620	669	DEL RIO CITY	94LA9850	906	0.195	
621	288	HAINE DRIVE	94SB8065	1,250	0.193	
622	272	MATHIS	94CS1420	935	0.191	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
623	553	AIRLINE	94CS7280	614	0.191	
624	516	ARCADIA	94CS8570	1,425	0.190	
625	240	ANNA STREET	94LA2250	1,561	0.186	
626	675	RAYMONDVILLE #2	94SB3240	970	0.185	
627	211	FASHING	94CN8160	38	0.184	
628	559	SAN BENITO	94SB4945	1,726	0.183	
629	63	SOUTH EAST EDINBURG	94SB4550	2,114	0.181	
630	196	PALMHURST	94SB1300	1,142	0.179	
631	651	AIRLINE	94CS8260	1,448	0.178	
632	618	BIG WELLS	94LA2630	23	0.174	
633	489	EAST HARRISON	94SB3000	540	0.174	
634	591	LEARY LANE	94CN6175	1,449	0.173	
635	99	KINGSVILLE	94CS1350	350	0.171	
636	581	SOUTH MISSION	94SB5215	1,222	0.170	
637	283	EL CAMPO	94CN6370	706	0.169	
638	376	MORRIS STREET	94CS8850	473	0.169	
639	628	AIRLINE	94CS8890	534	0.169	
640	128	COFFEE PORT	94SB1095	953	0.167	
641	432	MCCOLL ROAD	94SB4910	287	0.167	
642	312	MAGRUDER	94CN7870	1,261	0.165	
643	507	PUEBLO	94LA130	875	0.165	
644	29	EDNA	94CN5765	1,646	0.163	
645	new	GATEWAY	94LA3595	1,242	0.163	
646	599	RAYMONDVILLE #2	94SB1280	652	0.160	
647	676	GARWOOD CITY	94CN2570	132	0.159	
648	597	WESMER	94SB4480	1,071	0.158	
649	9	DARST	94CN790	70	0.157	
650	391	CAUSEWAY	94SB4775	1,044	0.157	
651	653	LAREDO PLANT	94LA8745	720	0.156	
652	234	SOUTH MCALLEN	94SB5065	64	0.156	
653	166	SHARYLAND	94SB5635	1,612	0.152	
654	614	EAGLE LAKE	94CN310	725	0.149	
655	356	WASHINGTON STREET	94LA6355	1,085	0.149	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
656	335	NORTH VICTORIA	94CN6390	1,322	0.148	
657	366	ANNA STREET	94LA780	452	0.148	
658	new station	OLMITO	94SB715	2,067	0.148	
659	690	LAREDO HEIGHTS	94LA2390	742	0.147	
660	385	AMISTAD DAM	94LA5450	1,063	0.144	
661	513	NORTH VICTORIA	94CN2240	778	0.143	
662	475	ROCKPORT	94CS5940	56	0.143	
663	326	KNIPPA	94LA6535	21	0.143	
664	401	SIERRA VISTA	94LA7360	2,417	0.143	
665	417	SIERRA VISTA	94LA3540	296	0.139	
666	575	SOUTH MISSION	94SB4650	970	0.139	
667	329	BUENA VISTA	94LA8965	959	0.138	
668	697	SOUTH MISSION	94SB3940	797	0.137	
669	695	EAGLE PASS CITY	94LA450	665	0.132	
670	263	GOODWIN	94SB7380	2,081	0.131	
671	650	HEARN ROAD	94CS2220	1,526	0.130	
672	652	HALL ACRES ROAD	94SB9595	967	0.127	
673	281	MORRIS STREET	94CS7465	628	0.126	
674	583	THREE RIVERS	94CN5100	34	0.118	
675	129	DEVINE	94LA7100	928	0.116	
676	25	NORTH MCALLEN	94SB2980	1,685	0.114	
677	371	AIRLINE	94CS9390	1,224	0.107	
678	441	SINTON	94CS1750	484	0.103	
679	378	SOUTHSIDE	94CS5345	393	0.102	
680	71	CLARKWOOD	94CS7220	322	0.102	
681	392	POLK AVENUE	94SB4520	880	0.102	
682	556	EAGLE LAKE	94CN9455	582	0.101	
683	642	HARLINGEN S.S.	94SB4230	1,768	0.098	
684	637	PORTLAND	94CS9370	1,416	0.093	
685	232	PLACEDO	94CN7980	397	0.091	
686	486	BROOKHOLLOW	94CN8950	860	0.091	
687	407	SOUTHSIDE	94CS8055	846	0.091	
688	670	DEL MAR	94LA7930	1,457	0.091	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
689	369	SHARYLAND	94SB2020	2,233	0.083	
690	673	CONOCO-CHITTAM RANCH	94LA8580	37	0.081	
691	579	PALMHURST	94SB3890	2,237	0.081	
692	218	SHARYLAND	94SB2150	1,024	0.077	
693	528	HARLINGEN	94SB370	1,133	0.077	
694	615	SOUTH EAST EDINBURG	94SB4015	404	0.074	
695	551	WESLACO UNIT	94SB2195	1,083	0.070	
696	706	ESCONDIDO	94LA2035	2,321	0.065	
697	368	DEL MAR	94LA10	2,612	0.064	
698	484	RAYMONDVILLE #1	94SB3130	265	0.064	
699	new	INGLESIDE CITY	94CS2495	80	0.063	
700	115	WOOLRIDGE	94CS1120	2,334	0.050	
701	96	CASA BLANCA	94CS5115	279	0.047	
702	443	ARANSAS PASS	94CS660	716	0.046	
703	683	GREGORY	94CS420	23	0.043	
704	399	SIERRA VISTA	94LA9900	2,011	0.042	
705	685	RODD FIELD	94CS3010	1,252	0.041	
706	714	ZACATE CREEK	94LA2635	249	0.040	
707	65	LAREDO PLANT	94LA8565	1,091	0.038	
708	424	WASHINGTON STREET	94LA2470	219	0.032	
709	123	SANTO NINO	94LA695	1,489	0.030	
710	147	ASPHALT MINES	94LA500	34	0.029	
711	425	ANNA STREET	94LA5780	731	0.029	
712	429	GARWOOD CITY	94CN2560	190	0.026	
713	302	LAREDO PLANT	94LA8705	205	0.005	
714	707	MORRIS STREET	94CSNET CC	298	0.003	
715	new	ESCONDIDO	94LA3350	881	-	
716	715	WASHINGTON STREET	94LANETLAR	345	-	
717	new station	OLMITO	94SB905	153	-	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value	Notes
--------------------	--------------------	---------------------------	-----------------------	---------------------	------------------	-------

Feeders from last year that are not in this year's list

2007 SAIFI Ranking	Substation Identification	Feeder Identification	Reason not in 2008
47	Robstown	94CS7120	serves <10 customers
262	Ingleside City	94CS7310	serves <10 customers
393	Gateway	94LA380	circuit retired
550	Industrial	94CS5430	serves <10 customers
656	Airline	94CS2180	serves <10 customers
678	Clarkwood	94CS2170	serves <10 customers
709	Fannin	94CN7940	serves <10 customers
710	Foster Field	94CN8880	serves <10 customers
712	Southside	94CS7935	serves <10 customers
713	STEC (Riverside)	94CS9101	delivery point to co-op from other circuit

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With More Than 10 Customers

Add or Delete Rows as Necessary

AEP Texas Central Company

Total Number of Feeders

717

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
1	17	MOORE FIELD	94SB3120	127	1,302.4	
2	8	GOVERNMENT WELLS	94LA7240	178	1,085.5	
3	78	CRESTONIO	94LA270	594	1,043.0	
4	5	RAYMONDVILLE #2	94SB3170	671	995.2	
5	60	CARRIZO SPRINGS	94LA370	238	987.9	
6	19	NIXON	94CN810	486	838.5	
7	111	EAST HARRISON	94SB3950	547	803.8	
8	2	CAVAZOS	94SB3560	252	672.3	
9	618	HAINE DRIVE	94SB9240	44	659.5	
10	16	FREER	94LA1500	177	626.9	
11	33	PALMVIEW	94SB9685	3,004	621.4	
12	141	FALFURRIAS	94LA5210	1,096	572.4	
13	82	LA PRYOR	94LA580	179	565.7	
14	398	ZAPATA	94LA7330	1,188	565.5	
15	303	NORTH PADRE ISLAND	94CS7900	1,828	534.1	
16	26	MALONE	94CN7560	96	531.6	
17	114	PORT ISABEL S.S.	94SB4070	291	521.1	
18	321	CLARKWOOD	94CS5525	898	510.5	
19	4	RAYMONDVILLE #2	94SB3250	32	510.0	
20	1	CAVAZOS	94SB3550	2,270	490.6	
21	343	VICTORIA POWER PLANT	94CN8170	741	489.5	
22	208	LA PRYOR	94LA570	126	485.5	
23	116	LOS FRESNOS	94SB3290	1,311	483.7	
24	new	RIO BRAVO	94LA1130	921	473.6	
25	73	GREGORY	94CS5900	109	472.0	
26	134	BROWNSVILLE	94SB4290	1,608	469.7	
27	14	ARMSTRONG	94CS6050	65	462.7	
28	67	MCKENZIE ROAD	94CS140	246	461.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
29	40	ELSA	94SB710	1,578	447.4	
30	86	SANTO NINO	94LA70	772	443.6	
31	46	PORT ISABEL S.S.	94SB9295	442	440.4	
32	558	CHARLOTTE	94LA2780	502	437.4	
33	71	ZAPATA	94LA2710	46	433.7	
34	355	JOURDANTON	94LA880	281	427.2	
35	90	PHARR	94SB1625	1,936	417.9	
36	29	RANDADO	94LA8360	148	413.3	
37	34	RIO BRAVO	94LA5	646	413.0	
38	588	SOUTH MCALLEN	94SB3640	252	410.8	
39	79	FREER	94LA2900	141	399.0	
40	182	CASA BLANCA	94CS1300	1,020	390.5	
41	697	HALL ACRES ROAD	94SB8870	3,614	386.5	
42	10	CONTINENTAL	94SB4080	121	384.9	
43	242	NUECES BAY PLANT	94CS7830	152	381.5	
44	330	WEST HARLINGEN	94SB3720	2,005	372.6	
45	438	HIDALGO	94SB4845	976	365.2	
46	333	MOORE FIELD	94SB3110	581	364.2	
47	545	RIO BRAVO	94LA300	788	349.8	
48	27	HIDALGO	94SB3400	843	347.9	
49	276	GOODWIN	94SB4390	409	346.2	
50	20	RACHAL	94LA8145	356	342.6	
51	31	LOS FRESNOS	94SB3200	497	340.3	
52	21	HALL ACRES ROAD	94SB5465	1,557	339.9	
53	238	SAN YGNACIO	94LA16060	476	339.1	
54	122	CRYSTAL CITY	94LA330	1,146	336.8	
55	39	BONNIEVIEW	94CS8020	505	336.7	
56	223	RODD FIELD	94CS225	1,172	335.9	
57	267	NUECES BAY PLANT	94CS350	699	335.5	
58	92	BANQUETTE	94CS9000	435	334.7	
59	452	NORTH WESLACO	94SB4830	474	332.0	
60	55	MUSTANG ISLAND	94CS8510	397	327.0	
61	263	CABANISS	94CS240	1,424	322.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
62	419	ROMA	94SB3070	819	321.4	
63	144	ELSA	94SB3520	397	316.3	
64	59	GREENLAKE	94CN2760	567	312.9	
65	25	THOMASTON	94CN9580	42	310.7	
66	47	PREMONT	94LA6610	800	309.6	
67	513	ELSA	94SB3500	1,067	309.6	
68	11	RIO RICO	94SB8330	575	308.9	
69	57	BRUNI	94LA5440	113	305.3	
70	442	SAN DIEGO	94CS2880	1,177	302.7	
71	112	GARCENO	94SB2135	1,670	301.0	
72	406	NORTH ALAMO	94SB3610	3,390	298.8	
73	450	JOURDANTON	94LA5695	1,242	296.2	
74	22	ENCINAL	94LA2160	764	291.9	
75	261	PUEBLO	94LA95	1,878	290.4	
76	99	SOUTH MISSION	94SB3980	1,197	286.5	
77	80	PORT ISABEL S.S.	94SB3820	203	285.8	
78	415	CAUSEWAY	94SB4795	1,138	285.3	
79	13	BRUNI	94LA1120	144	282.8	
80	579	RANGERVILLE	94SB3410	771	281.1	
81	595	PORT ARANSAS	94CS990	1,309	276.3	
82	581	HIGHWAY 9	94CS6770	1,182	275.7	
83	new	WESMER	94SB7760	1,206	274.6	
84	548	BANQUETTE	94CS130	233	274.5	
85	113	PREMONT	94LA6570	723	274.2	
86	108	NORTH ALAMO	94SB3580	1,803	274.1	
87	314	SOUTHSIDE	94CS7955	1,061	267.5	
88	369	RANGERVILLE	94SB4060	853	265.5	
89	629	BLESSING	94CN8780	65	264.8	
90	252	LA GRULLA	94SB5110	2,146	258.0	
91	294	NAVAL BASE	94CS8440	1,556	257.7	
92	637	PORT ARANSAS	94CS1000	1,303	256.8	
93	142	HALL ACRES ROAD	94SB5585	676	253.6	
94	462	MOORE FIELD	94SB3960	1,514	253.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
95	479	LA PRYOR	94LA2440	638	251.1	
96	123	GOODWIN	94SB4625	334	250.6	
97	473	SANTO NINO	94LA80	2,328	249.9	
98	445	WEST HARLINGEN	94SB3800	1,288	249.6	
99	684	HIGHWAY 9	94CS7210	323	248.6	
100	619	CHARLOTTE	94LA2790	95	245.5	
101	56	HIDALGO	94SB3680	311	245.1	
102	309	PORT ARANSAS	94CS3030	790	243.9	
103	503	NORTH EDINBURG	94SB4240	2,025	242.7	
104	304	BERCLAIR	94CN990	297	242.1	
105	632	LAREDO HEIGHTS	94LA2100	1,707	241.0	
106	244	HARLINGEN S.S.	94SB320	1,436	238.3	
107	435	EDROY	94CS6980	196	236.1	
108	43	PETTUS	94CN8210	351	236.0	
109	221	PREMONT	94LA2730	195	235.7	
110	166	SOUTH EAST EDINBURG	94SB4570	1,321	235.4	
111	631	MINES ROAD	94LA3745	1,293	234.7	
112	54	NORTH MERCEDES	94SB3840	619	231.3	
113	589	CITRUS CITY	94SB9775	1,921	230.5	
114	535	SOUTHSIDE	94CS8045	1,015	230.3	
115	673	VICTORIA POWER PLANT	94CN8070	615	230.2	
116	386	CAMPWOOD	94LA3430	78	229.4	
117	218	PHARAOH	94CS5175	979	228.7	
118	711	VICTORIA POWER PLANT	94CNNETVIC	71	228.0	
119	519	LOS FRESNOS	94SB3280	1,913	227.3	
120	365	EAGLE PASS CITY	94LA2770	3,263	225.4	
121	216	SOUTHSIDE	94CS5335	1,139	224.9	
122	505	ARCADIA	94CS5020	1,516	224.8	
123	478	POLK AVENUE	94SB4610	1,311	222.3	
124	162	FREER	94LA6320	149	219.4	
125	563	NORTH WESLACO	94SB4810	1,275	219.1	
126	354	SANTO NINO	94LA75	1,424	217.2	
127	61	NORTH EDINBURG	94SB3570	952	216.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
128	165	WEST OSO	94CS9090	1,738	215.4	
129	364	PRAIRIE PUMP	94CN1940	58	215.2	
130	149	FALFURRIAS	94LA2830	1,623	214.7	
131	93	BROWNSVILLE	94SB3050	1,918	212.9	
132	305	BEEVILLE	94CN300	1,575	211.4	
133	538	BEEVILLE	94CN8510	835	211.2	
134	302	ROBSTOWN	94CS1650	336	209.6	
135	36	BRUNI	94LA5160	148	205.1	
136	38	SOUTH EAST EDINBURG	94SB5045	1,760	205.1	
137	147	PHARAOH	94CS1185	1,513	203.3	
138	195	BRUNI	94LA1100	632	201.4	
139	301	WEST OSO	94CS9085	746	201.4	
140	199	HEARN ROAD	94CS8990	1,144	201.1	
141	281	SANTO NINO	94LA515	2,257	199.8	
142	250	BISHOP	94CS7180	948	199.0	
143	217	JOURDANTON	94LA5685	532	197.2	
144	132	WEST HARLINGEN	94SB3700	1,650	196.3	
145	457	PORT ARANSAS	94CS6940	1,575	196.2	
146	490	MCKENZIE ROAD	94CS150	27	194.3	
147	416	CITRUS CITY	94SB3470	2,603	194.2	
148	253	GREENLAKE	94CN2750	1,075	192.0	
149	483	MCCOLL ROAD	94SB4400	2,147	191.6	
150	169	HIGHWAY 9	94CS6720	1,320	188.8	
151	533	RAYMONDVILLE #1	94SB630	767	188.0	
152	454	PHARAOH	94CS1365	455	187.1	
153	104	MAVERICK	94LA9680	680	187.0	
154	592	MAGRUDER	94CN6700	1,440	186.9	
155	225	BISHOP	94CS2690	555	186.1	
156	379	BANDERA ELECTRIC (LEAKEY)	94LAL30	264	186.1	
157	101	NORTH MCALLEN	94SB2750	2,859	185.7	
158	119	STAFFORD HILL	94CN1550	204	185.0	
159	246	SINTON	94CS180	936	183.2	
160	688	ZACATE CREEK	94LA2665	1,634	182.8	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
161	298	SOUTH SANTA ROSA	94SB1235	625	182.7	
162	155	ELSA	94SB690	2,067	179.0	
163	231	NORTH MCALLEN	94SB4995	1,826	177.7	
164	268	EAGLE PASS CITY	94LA2650	1,253	176.6	
165	353	PORTLAND	94CS9290	1,665	175.6	
166	77	CARRIZO SPRINGS	94LA860	1,027	174.5	
167	468	GANADO	94CN5815	572	174.4	
168	233	LAGUNA	94CS9590	2,077	171.9	
169	346	EAST HARRISON	94SB4620	764	171.4	
170	137	RANGERVILLE	94SB3420	746	171.0	
171	371	STADIUM	94CS6950	526	170.4	
172	332	ALICE	94CS1770	1,496	169.9	
173	277	RIO RICO	94SB8290	105	169.5	
174	160	ZAPATA	94LA8300	1,683	169.3	
175	306	DEL RIO CITY	94LA420	2,317	168.3	
176	521	LIVE OAK	94CS1090	243	167.7	
177	257	MCCOLL ROAD	94SB2810	2,227	167.4	
178	63	MINES ROAD	94LA3680	821	165.9	
179	194	MATHIS	94CS340	1,461	165.6	
180	510	SOUTH SANTA ROSA	94SB1215	1,864	164.3	
181	327	MATHIS	94CS2870	850	164.3	
182	349	MILO	94LA6940	183	164.2	
183	136	LOLITA	94CN6330	30	163.8	
184	131	BROWNSVILLE	94SB4280	227	162.7	
185	254	YORKTOWN	94CN8420	1,014	162.6	
186	120	KLEBERG	94CS1560	1,290	160.7	
187	62	MILO	94LA8365	2,157	160.2	
188	180	SOUTH PADRE ISLAND	94SB5850	1,387	159.1	
189	150	PLACEDO	94CN7970	452	158.8	
190	516	NORTH MCALLEN	94SB5055	3,159	158.1	
191	537	HAINE DRIVE	94SB9700	754	157.1	
192	23	ALAZAN	94CS2740	29	157.0	
193	432	MILO	94LA3070	2,910	156.7	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
194	94	RACHAL	94LA6595	294	156.5	
195	399	HIGHWAY 9	94CS7200	560	155.5	
196	377	WEIL TRACT (138/12KV)	94CS5405	144	155.2	
197	151	CRYSTAL CITY	94LA190	950	154.7	
198	42	LYTLE	94LA2850	581	154.2	
199	687	BEEVILLE	94CN2380	196	153.3	
200	453	KLEBERG	94CS9395	1,316	153.0	
201	226	RAYMONDVILLE #1	94SB620	610	152.9	
202	256	HOLLY	94CS1480	1,691	151.9	
203	280	TAFT	94CS1180	1,050	150.7	
204	648	EL CAMPO	94CN2800	1,275	150.0	
205	638	POLK AVENUE	94SB4740	1,735	149.9	
206	167	TATTON	94CN8490	119	148.7	
207	645	KENEDY S.S.	94CN8320	652	147.4	
208	75	NAVAL BASE	94CS1380	2,167	146.9	
209	274	NORTH MERCEDES	94SB3770	1,590	145.4	
210	389	HALL ACRES ROAD	94SB4895	742	145.3	
211	164	SUNCHASE	94SB1155	1,383	145.1	
212	88	ARANSAS PASS	94CS9130	303	144.8	
213	351	WESMER	94SB9705	981	144.7	
214	109	MATTHEWS	94CN1740	160	144.5	
215	572	HARLINGEN	94SB360	2,483	143.0	
216	50	DILLEY	94LA6400	767	141.9	
217	608	WEST MCALLEN	94SB4595	1,037	141.4	
218	356	HARLINGEN S.S.	94SB4090	2,216	140.5	
219	299	NORTH MCALLEN	94SB9660	1,962	140.2	
220	215	HARLINGEN S.S.	94SB4110	935	139.8	
221	517	RAYMONDVILLE #2	94SB4160	731	139.6	
222	501	HAIN DRIVE	94SB270	810	139.0	
223	265	KINGSVILLE	94CS1670	422	138.6	
224	639	PARKER	94CN9260	91	138.5	
225	470	EAST HARRISON	94SB3190	1,405	138.3	
226	125	CONTINENTAL	94SB4880	68	137.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
227	680	HIGHWAY 9	94CS9830	132	135.4	
228	678	MINES ROAD	94LA4275	100	134.9	
229	511	HARLINGEN	94SB660	2,472	134.7	
230	64	HOLLY	94CS7620	2,291	134.1	
231	118	GOVERNMENT WELLS	94LA6800	225	134.0	
232	135	MARKHAM	94CN5550	96	133.0	
233	207	SOUTHSIDE	94CS7905	1,826	132.9	
234	401	BLESSING	94CN8790	719	132.5	
235	577	CLARKWOOD	94CS7610	183	132.5	
236	129	ODEM	94CS375	1,001	132.2	
237	591	BAY CITY	94CN2700	1,073	132.1	
238	18	ALAZAN	94CS620	157	132.0	
239	409	GOVERNMENT WELLS	94LA7250	579	132.0	
240	506	POLK AVENUE	94SB4600	3,278	131.3	
241	206	RODD FIELD	94CS1730	1,981	131.0	
242	459	CHARLOTTE	94LA8120	197	130.6	
243	203	KENEDY	94CN1970	641	130.2	
244	623	PHARAOH	94CS5185	1,722	129.8	
245	570	WESLACO UNIT	94SB8610	2,350	129.7	
246	477	PALMHURST	94SB2525	1,661	129.7	
247	139	SAN BENITO	94SB4030	2,331	129.4	
248	621	EAST HARRISON	94SB3080	353	129.4	
249	189	GATEWAY	94LA350	1,232	127.8	
250	384	HIGHWAY 9	94CS6760	608	127.7	
251	336	EAGLE PASS CITY	94LA7060	799	127.4	
252	293	EL CAMPO	94CN5745	869	127.3	
253	97	GRETA	94CN7890	295	127.3	
254	51	NORTH EDINBURG	94SB560	1,382	126.3	
255	691	KENEDY	94CN1960	57	126.3	
256	644	VICTORIA POWER PLANT	94CN7600	156	125.6	
257	9	COMSTOCK	94LA290	181	125.5	
258	190	PHARAOH	94CS1285	1,720	125.4	
259	318	ALICE	94CS2540	1,117	125.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
260	451	REFUGIO	94CN5120	160	122.8	
261	403	KINGSVILLE	94CS1130	2,096	122.4	
262	66	SAN BENITO	94SB3920	2,226	122.2	
263	310	SOUTH PADRE ISLAND	94SB6440	2,368	122.0	
264	622	ARCADIA	94CS5030	1,543	121.9	
265	642	PLEASANTON	94LA1120	1,195	121.5	
266	320	FULTON	94CS440	1,962	121.4	
267	325	ALICE	94CS1780	271	120.2	
268	328	STADIUM	94CS8540	1,615	119.2	
269	130	UVALDE	94LA480	1,243	118.0	
270	425	COLUMBUS	94CN930	901	117.4	
271	367	BLESSING	94CN1030	233	116.4	
272	196	KLEBERG	94CS6000	1,486	116.1	
273	287	GOODWIN	94SB3530	1,225	113.9	
274	536	MCCOLL ROAD	94SB4790	1,827	113.8	
275	227	PEARSALL	94LA9905	716	113.5	
276	693	SOUTH MCALLEN	94SB3850	762	113.2	
277	554	CARANCAHUA	94CN5870	412	112.4	
278	564	GEORGE WEST	94CN730	859	112.3	
279	49	MATHIS	94CS1410	454	112.2	
280	661	EL CAMPO	94CN7710	1,059	111.8	
281	335	DEL RIO CITY	94LA1930	911	111.8	
282	202	MORRIS STREET	94CS2515	1,086	111.4	
283	600	WEST MCALLEN	94SB4535	2,657	111.2	
284	259	FALFURRIAS	94LA1070	846	110.3	
285	474	SANTO NINO	94LA645	602	110.3	
286	188	PALMVIEW	94SB6790	2,478	110.1	
287	279	GOLIAD	94CN6540	1,107	109.8	
288	35	RANDADO	94LA8350	121	109.2	
289	156	NORTH MCALLEN	94SB3830	1,273	109.0	
290	255	POLK AVENUE	94SB4170	1,579	109.0	
291	620	CRESTONIO	94LA6660	729	108.8	
292	628	KENEDY S.S.	94CN8340	881	107.8	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
293	322	SKIDMORE	94CS380	312	107.7	
294	597	DEL MAR	94LA220	635	107.7	
295	402	SOUTHSIDE	94CS8035	1,080	107.4	
296	28	CONTINENTAL	94SB3650	24	107.3	
297	427	WASHINGTON STREET	94LA7015	1,915	106.9	
298	222	SOUTH SANTA ROSA	94SB1225	797	106.8	
299	412	SOUTHSIDE	94CS7995	1,529	106.2	
300	163	NORTH EDINBURG	94SB3810	794	106.1	
301	658	THREE RIVERS	94CN8430	161	106.0	
302	524	NIXON	94CN5990	577	105.9	
303	675	BAY CITY	94CN1110	1,299	104.9	
304	556	ARCADIA	94CS6930	1,499	104.4	
305	540	WESMER	94SB6900	1,433	103.9	
306	576	LEARY LANE	94CN1540	775	103.7	
307	508	HIGHWAY 9	94CS6730	508	103.6	
308	337	WEST MCALLEN	94SB4515	1,328	103.6	
309	121	RIO GRANDE CITY	94SB3220	1,689	103.1	
310	557	GEORGE WEST	94CN1320	641	102.9	
311	213	DEVINE	94LA8100	1,436	102.6	
312	385	PALACIOS	94CN8550	37	102.5	
313	117	GANADO	94CN5795	630	102.4	
314	674	MORRIS STREET	94CS7625	535	101.7	
315	520	BIG WELLS	94LA1570	396	101.6	
316	161	PETTUS	94CN1020	387	101.5	
317	357	PLEASANTON	94LA9505	1,416	101.1	
318	115	SAN DIEGO	94CS2930	599	100.1	
319	683	ROCKSPRINGS	94LA2600	374	99.5	
320	74	FULTON	94CS9050	1,590	99.5	
321	12	LA GRULLA	94SB5005	961	99.5	
322	543	BAY CITY	94CN6670	1,759	99.4	
323	705	THREE RIVERS	94CN2580	59	99.1	
324	366	SAN BENITO	94SB4135	1,217	99.0	
325	529	MCCOLL ROAD	94SB4780	2,021	98.9	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
326	518	THREE RIVERS	94CN2010	860	97.9	
327	580	BROOKHOLLOW	94CN7580	425	97.0	
328	172	SKIDMORE	94CS600	353	96.8	
329	562	NORTH MERCEDES	94SB4860	1,369	96.3	
330	177	LOS FRESNOS	94SB930	1,829	95.6	
331	700	MILO	94LA5020	1,277	95.3	
332	249	CABANISS	94CS75	1,939	95.0	
333	664	PARKER	94CN9010	16	95.0	
334	230	WESMER	94SB4050	2,471	94.8	
335	651	BEEVILLE	94CN490	924	94.7	
336	173	CABANISS	94CS80	1,065	94.0	
337	3	MILO	94LA3065	167	93.8	
338	209	EAST HARRISON	94SB4310	1,155	93.3	
339	44	MUSTANG ISLAND	94CS9470	641	93.1	
340	676	MAGRUDER	94CN6690	551	92.1	
341	264	EAST HARRISON	94SB4360	1,660	91.1	
342	461	LA GRULLA	94SB4120	1,216	90.9	
343	574	VICTORIA POWER PLANT	94CN1390	1,131	90.6	
344	32	MALONE	94CN7550	161	90.6	
345	566	NORDHEIM	94CN470	237	90.4	
346	609	HOLLY	94CS9675	1,726	89.8	
347	499	STADIUM	94CS7490	1,228	89.2	
348	586	LEARY LANE	94CN7530	1,890	89.1	
349	669	NORTH MCALLEN	94SB9640	1,370	89.0	
350	308	KLEBERG	94CS8140	354	88.9	
351	375	BROOKHOLLOW	94CN7190	261	88.6	
352	127	WEIL TRACT (138/12KV)	94CS2520	536	88.5	
353	197	ARCADIA	94CS1460	1,972	88.3	
354	260	TATTON	94CS8200	954	88.0	
355	662	DEL MAR	94LA490	580	87.0	
356	204	LIVE OAK	94CS1070	2,736	86.9	
357	410	ALICE	94CS2530	1,432	86.8	
358	234	PLEASANTON	94LA2080	1,492	86.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
359	615	NORTH VICTORIA	94CN7770	813	85.9	
360	602	STADIUM	94CS7800	649	85.7	
361	522	COTULLA	94LA110	1,176	85.0	
362	500	ARCADIA	94CS1450	1,868	84.3	
363	191	PREMONT	94LA2720	772	84.1	
364	449	FULTON	94CS2020	1,781	83.7	
365	248	RIO RICO	94SB5050	1,564	83.5	
366	663	AIRLINE	94CS6970	1,196	83.2	
367	41	WEIL TRACT (138/12KV)	94CS1990	1,252	82.5	
368	30	NIXON	94CN2620	593	82.5	
369	423	SOUTH MCALLEN	94SB3790	1,836	81.8	
370	391	PEARSALL	94LA7050	1,271	81.7	
371	183	CARRIZO SPRINGS	94LA910	1,807	81.1	
372	237	PALMVIEW	94SB3930	661	80.7	
373	625	PHARR	94SB1645	1,751	80.1	
374	573	PALMHURST	94SB2530	1,775	80.0	
375	472	ARANSAS PASS	94CS1250	353	79.8	
376	200	EDROY	94CS6990	267	79.8	
377	52	TAFT	94CS1260	186	79.4	
378	58	STADIUM	94CS7810	1,613	79.3	
379	420	WESLACO UNIT	94SB5970	2,754	79.2	
380	285	CLARKWOOD	94CS7230	549	79.0	
381	652	AIRLINE	94CS7270	999	78.5	
382	258	SAN DIEGO	94CS1980	581	78.3	
383	388	HARLINGEN	94SB380	2,281	78.0	
384	288	WESLACO UNIT	94SB7630	3,436	77.7	
385	76	CLARKWOOD	94CS9570	1,143	77.4	
386	561	PORT ISABEL S.S.	94SB3760	1,998	77.4	
387	103	PALMHURST	94SB2820	1,771	76.7	
388	70	ROMA	94SB3060	1,480	76.3	
389	138	NUECES BAY PLANT	94CS345	51	75.9	
390	338	KLEBERG	94CS280	1,124	75.9	
391	48	SOUTH EAST EDINBURG	94SB6580	1,306	75.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
392	495	SOUTH MISSION	94SB3590	651	74.9	
393	297	SOUTH PADRE ISLAND	94SB4695	1,309	73.8	
394	284	MORRIS STREET	94CS8820	1,254	73.4	
395	526	LEARY LANE	94CN1890	1,553	73.1	
396	315	LULING - LCRA	94CN20	250	73.0	
397	15	LULING - LCRA	94CN10	321	72.9	
398	633	KINGSVILLE	94CS1140	992	72.3	
399	382	UVALDE	94LA5060	1,296	72.0	
400	241	ARANSAS PASS	94CS8270	610	71.5	
401	486	WOODSBORO	94CS8330	1,072	71.3	
402	362	UNIVERSITY	94LA950	2,103	70.9	
403	153	BUENA VISTA	94LA9035	1,440	70.4	
404	434	WADSWORTH	94CN8630	626	70.1	
405	new station	OLMITO	94SB4275	764	69.9	
406	266	HOLLY	94CS1220	2,433	69.6	
407	133	PALMVIEW	94SB9680	1,283	69.5	
408	657	UVALDE	94LA9770	1,248	69.1	
409	214	RAYMONDVILLE #1	94SB800	693	68.8	
410	220	ARCADIA	94CS1360	1,534	67.9	
411	37	ASHERTON	94LA2670	143	67.7	
412	128	KNIPPA	94LA6365	305	67.5	
413	313	ASHERTON	94LA2660	548	67.4	
414	507	WESLACO UNIT	94SB9805	2,776	67.4	
415	395	WEST MCALLEN	94SB6385	190	67.3	
416	408	HIGHWAY 9	94CS6780	790	67.3	
417	new	PALMVIEW	94SB7595	2,580	66.7	
418	413	YORKTOWN	94CN8380	786	65.4	
419	126	SOUTH SANTA ROSA	94SB1240	1,453	65.3	
420	407	MAGRUDER	94CN245	1,120	65.2	
421	6	DARST	94CN800	160	65.0	
422	262	WADSWORTH	94CN7660	1,254	64.8	
423	646	JOURDANTON	94LA250	711	64.7	
424	334	SEAWALL	94CS9420	836	64.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
425	157	ZAPATA	94LA8290	1,981	64.2	
426	551	WEST HARLINGEN	94SB4870	528	63.9	
427	605	INGLESIDE CITY	94CS8050	1,735	63.5	
428	458	ROCKPORT	94CS5950	547	63.3	
429	316	WASHINGTON STREET	94LA6525	2,004	62.5	
430	485	WEST MCALLEN	94SB4505	1,832	62.0	
431	672	WASHINGTON STREET	94LA2360	665	61.9	
432	212	BEEVILLE	94CN1760	1,740	61.6	
433	291	SINTON	94CS360	285	61.5	
434	170	NORTH PADRE ISLAND	94CS5170	1,074	61.5	
435	374	EAGLE PASS CITY	94LA2510	632	60.5	
436	178	UNIVERSITY	94LA930	699	60.5	
437	243	PALACIOS	94CN6830	821	60.5	
438	552	ARANSAS PASS	94CS8280	542	60.4	
439	312	EL CAMPO	94CN7260	523	60.2	
440	224	CAUSEWAY	94SB4765	1,162	59.9	
441	383	KENEDY S.S.	94CN6750	754	59.4	
442	175	GATEWAY	94LA390	775	59.3	
443	695	ROCKSPRINGS	94LA8040	323	58.6	
444	376	EAGLE PASS CITY	94LA2745	896	58.1	
445	604	SUNCHASE	94SB1150	1,187	58.1	
446	65	KLEBERG	94CS6410	396	58.0	
447	105	RIO GRANDE CITY	94SB3740	3,284	58.0	
448	307	PORT LAVACA	94CN8310	308	57.8	
449	480	PORT LAVACA	94CN6850	591	57.7	
450	181	COLUMBUS	94CN6180	1,175	57.5	
451	292	HALL ACRES ROAD	94SB3670	785	57.3	
452	448	FULTON	94CS6070	2,932	57.2	
453	87	MORRIS STREET	94CS5655	1,012	56.9	
454	547	MILO	94LA3060	73	56.9	
455	96	GREENLAKE	94CN2740	28	56.4	
456	681	PHARR	94SB1620	2,634	55.3	
457	269	AIRLINE	94CS8370	295	55.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
458	400	LAGUNA	94CS9065	1,962	55.1	
459	553	WEST MCALLEN	94SB4965	697	55.0	
460	489	GARCENO	94SB2130	3,150	55.0	
461	295	EAGLE LAKE	94CN320	649	54.9	
462	491	WEST OSO	94CS9095	1,469	54.5	
463	210	PALMHURST	94SB2535	1,179	54.3	
464	464	NORTH VICTORIA	94CN7860	1,447	54.2	
465	286	MCKENZIE ROAD	94CS330	2,243	54.2	
466	613	TATTON	94CS950	511	54.1	
467	91	MORRIS STREET	94CS8715	1,577	53.9	
468	598	CRESTONIO	94LA260	1,738	53.8	
469	174	PALACIOS	94CN6840	1,524	53.8	
470	671	HAMILTON ROAD	94LA9645	279	53.6	
471	168	SOUTHSIDE	94CS8005	751	52.8	
472	324	BEEVILLE	94CN2200	735	52.5	
473	<10 customers	CHASE FIELD	94CN460	12	52.5	
474	381	ANNA STREET	94LA850	1,552	52.5	
475	544	HOLLY	94CS7740	2,007	52.2	
476	359	MAGRUDER	94CN6680	683	51.7	
477	396	NAVAL BASE	94CS6330	376	51.4	
478	95	FALFURRIAS	94LA1080	434	51.3	
479	498	INGLESIDE CITY	94CS6040	260	51.2	
480	348	CITRUS CITY	94SB7985	1,482	51.1	
481	460	SEAWALL	94CS9325	1,411	51.0	
482	278	CRYSTAL CITY	94LA140	1,191	50.4	
483	582	TAFT	94CS5230	805	50.2	
484	331	SOUTHSIDE	94CS8025	1,029	50.0	
485	515	PUEBLO	94LA275	2,573	49.7	
486	350	RIO GRANDE CITY	94SB3230	1,057	49.6	
487	430	LAREDO PLANT	94LA9305	873	49.2	
488	317	DEL RIO CITY	94LA9790	2,543	48.5	
489	655	WEST MCALLEN	94SB4815	716	48.0	
490	345	UVALDE	94LA6620	2,619	47.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
491	187	AIRLINE	94CS9605	697	47.6	
492	424	POLK AVENUE	94SB4900	2,569	47.3	
493	418	ELSA	94SB700	1,335	47.0	
494	594	LEARY LANE	94CN6005	2,039	46.6	
495	45	RIO GRANDE CITY	94SB3210	1,619	46.5	
496	159	NORTH ALAMO	94SB4370	2,305	46.3	
497	436	ARCADIA	94CS1440	1,591	46.1	
498	124	DILLEY	94LA510	514	45.8	
499	393	PLEASANTON	94LA9475	1,319	45.7	
500	296	NORTH VICTORIA	94CN7440	1,606	45.3	
501	140	FOSTER FIELD	94CN2550	330	45.2	
502	497	AIRLINE	94CS9030	413	45.0	
503	100	CASA BLANCA	94CS55	808	44.5	
504	593	SAN DIEGO	94CS2890	1,024	44.5	
505	647	LAREDO HEIGHTS	94LA6820	2,049	44.1	
506	232	PEARSALL	94LA5580	1,595	44.1	
507	219	REFUGIO	94CN1040	721	44.0	
508	326	LAREDO HEIGHTS	94LA6810	1,983	43.6	
509	559	HAINE DRIVE	94SB3490	914	43.4	
510	447	WESLACO UNIT	94SB8195	1,683	43.3	
511	441	SHARYLAND	94SB6745	2,001	43.1	
512	465	WOOLRIDGE	94CS1170	1,265	43.1	
513	102	ARCADIA	94CS1400	424	42.9	
514	659	RODD FIELD	94CS205	1,500	42.7	
515	290	REFUGIO	94CN1170	876	42.4	
516	514	PORTLAND	94CS9270	1,877	42.3	
517	534	LAREDO HEIGHTS	94LA9400	1,367	42.0	
518	new	WESMER	94SB1850	450	41.5	
519	689	HAMILTON ROAD	94LA9665	924	41.2	
520	542	FREER	94LA5200	990	41.2	
521	550	LAREDO HEIGHTS	94LA2450	2,459	41.1	
522	240	EAST HARRISON	94SB3030	710	41.0	
523	488	WEST MCALLEN	94SB4555	1,451	40.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
524	617	ANNA STREET	94LA900	2,832	40.1	
525	627	NORTH MCALLEN	94SB5060	2,095	40.0	
526	146	SEAWALL	94CS9450	283	39.6	
527	456	WESLACO UNIT	94SB7455	1,254	39.5	
528	152	HOLLY	94CS5820	929	39.0	
529	610	LAREDO PLANT	94LA8505	762	39.0	
530	145	PHARR	94SB1640	956	38.8	
531	527	LAREDO HEIGHTS	94LA9080	681	38.6	
532	635	ZACATE CREEK	94LA2675	1,416	37.1	
533	531	SINTON	94CS6860	1,558	37.0	
534	106	SOUTH EAST EDINBURG	94SB4550	2,114	36.8	
535	476	MCCOLL ROAD	94SB4910	287	36.7	
536	192	COTULLA	94LA90	687	36.6	
537	81	KINGSVILLE	94CS1660	1,540	36.5	
538	670	WEAVER ROAD	94CN1900	48	36.3	
539	378	NORTH PADRE ISLAND	94CS720	1,027	36.2	
540	702	AIRLINE	94CS7390	1,433	35.8	
541	107	SAN BENITO	94SB3910	1,716	35.6	
542	300	MAGRUDER	94CN7690	562	35.2	
543	171	SAN BENITO	94SB3860	245	34.8	
544	341	UVALDE	94LA540	1,197	34.4	
545	158	EDNA	94CN5775	495	34.0	
546	654	DEL RIO CITY	94LA430	2,445	33.8	
547	397	SOUTH MCALLEN	94SB3935	1,183	33.6	
548	339	SOUTH MCALLEN	94SB5065	64	33.4	
549	596	SOUTH MISSION	94SB3620	1,822	33.3	
550	239	MARKHAM	94CN6440	426	33.1	
551	229	DEL MAR	94LA3440	1,368	32.9	
552	437	POLK AVENUE	94SB4190	1,672	32.4	
553	273	COFFEE PORT	94SB1090	1,114	32.2	
554	494	BAY CITY	94CN2050	506	31.7	
555	665	RAYMONDVILLE #2	94SB3240	970	31.6	
556	361	BEEVILLE	94CN8090	1,212	31.3	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
557	583	PORTLAND	94CS6505	1,629	31.2	
558	198	CAUSEWAY	94SB4775	1,044	31.2	
559	606	WEAVER ROAD	94CN1910	353	31.0	
560	686	HALL ACRES ROAD	94SB9595	967	30.9	
561	567	BAY CITY	94CN5960	1,862	30.8	
562	329	HALL ACRES ROAD	94SB3460	3,335	30.8	
563	624	LEARY LANE	94CN6175	1,449	30.1	
564	245	RODD FIELD	94CS2190	3,305	30.0	
565	411	RUNGE	94CN7320	593	29.7	
566	347	UNIVERSITY	94LA920	420	29.4	
567	636	SABINAL	94LA485	481	29.2	
568	703	DEL RIO CITY	94LA440	822	28.9	
569	380	CAMPWOOD	94LA2610	905	28.8	
570	311	SHARYLAND	94SB2010	1,543	28.7	
571	283	SHARYLAND	94SB2035	2,244	28.5	
572	667	MORRIS STREET	94CS8840	594	28.5	
573	496	MORRIS STREET	94CS8830	1,523	28.5	
574	616	FULTON	94CS3070	1,550	28.4	
575	83	ODEM	94CS5575	57	28.2	
576	601	GREGORY	94CS8560	803	28.2	
577	708	ESCONDIDO	94LA1510	673	28.2	
578	532	WASHINGTON STREET	94LA2350	3,096	28.0	
579	685	HEARN ROAD	94CS9665	553	28.0	
580	405	ANNA STREET	94LA2250	1,561	28.0	
581	24	KINGSVILLE	94CS1350	350	27.6	
582	530	HOLLY	94CS1370	1,889	27.4	
583	469	ARCADIA	94CS8570	1,425	27.4	
584	404	KENEDY	94CN6270	473	27.1	
585	148	NORTH PADRE ISLAND	94CS1010	1,801	26.8	
586	344	LIVE OAK	94CS1080	746	26.8	
587	289	ALICE	94CS1790	339	26.7	
588	443	LEARY LANE	94CN1430	1,565	26.4	
589	466	AIRLINE	94CS7280	614	26.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
590	143	BRACKETTVILLE	94LA8460	1,161	25.7	
591	372	HAINE DRIVE	94SB8065	1,250	25.7	
592	236	GOLIAD	94CN8220	1,016	25.5	
593	72	O CONNER	94CN390	215	25.4	
594	690	WOOLRIDGE	94CS1110	1,395	25.4	
595	696	SOUTH MISSION	94SB3940	797	24.8	
596	360	GOODWIN	94SB4380	1,361	24.7	
597	319	HOLLY	94CS1950	786	24.5	
598	699	NORTH VICTORIA	94CN1470	440	24.4	
599	84	NORTH MCALLEN	94SB2980	1,685	24.2	
600	546	AIRLINE	94CS5870	853	24.0	
601	584	RAYMONDVILLE #2	94SB1280	652	24.0	
602	363	NORTH VICTORIA	94CN1580	1,039	23.9	
603	89	HAMILTON ROAD	94LA9655	1,110	23.9	
604	467	AIRLINE	94CS9390	1,224	23.9	
605	528	POLK AVENUE	94SB4180	1,135	23.8	
606	492	WESMER	94SB4480	1,071	23.8	
607	new	GATEWAY	94LA5055	1,805	23.6	
608	235	PORT LAVACA	94CN2490	1,069	23.4	
609	228	POINT COMFORT	94CN6060	49	23.4	
610	509	BIG WELLS	94LA2630	23	23.2	
611	176	COFFEE PORT	94SB1095	953	22.7	
612	439	POINT COMFORT	94CN2460	349	22.5	
613	706	RODD FIELD	94CS245	3,008	22.4	
614	85	PALMHURST	94SB1300	1,142	22.2	
615	417	SOUTH MISSION	94SB4650	970	21.6	
616	575	HEARN ROAD	94CS870	1,098	21.5	
617	368	HEARN ROAD	94CS8980	1,012	21.4	
618	560	EAGLE LAKE	94CN310	725	21.2	
619	578	BAY CITY	94CN7480	1,901	21.1	
620	512	SOUTHSIDE	94CS7925	1,362	20.8	
621	390	PORT LAVACA	94CN2480	1,509	20.7	
622	568	LAREDO PLANT	94LA8695	975	20.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
623	98	FASHING	94CN8160	38	20.0	
624	587	REFUGIO	94CN1210	213	19.8	
625	271	EDNA	94CN5785	736	19.7	
626	428	MORRIS STREET	94CS7465	628	19.1	
627	392	INGLESIDE CITY	94CS8060	2,005	19.0	
628	565	SOUTH MISSION	94SB5215	1,222	18.9	
629	626	SOUTH EAST EDINBURG	94SB4015	404	18.8	
630	426	DEVINE	94LA7090	904	18.6	
631	421	ARANSAS PASS	94CS650	734	18.6	
632	643	AIRLINE	94CS8260	1,448	18.6	
633	394	WASHINGTON STREET	94LA6355	1,085	18.6	
634	694	LAREDO HEIGHTS	94LA2390	742	18.6	
635	429	GREGORY	94CS5920	503	18.5	
636	555	MORRIS STREET	94CS8850	473	18.5	
637	414	THREE RIVERS	94CN5190	783	17.8	
638	653	HAINE DRIVE	94SB9690	830	17.7	
639	523	UVALDE	94LA550	640	17.5	
640	614	BROOKHOLLOW	94CN8960	551	17.4	
641	482	NORTH VICTORIA	94CN7430	1,709	17.2	
642	270	ODEM	94CS385	382	17.2	
643	211	EAST HARRISON	94SB3000	540	17.1	
644	641	AIRLINE	94CS8890	534	17.1	
645	504	SAN BENITO	94SB4945	1,726	16.8	
646	184	BUENA VISTA	94LA9385	2,008	16.6	
647	275	GOODWIN	94SB7380	2,081	16.6	
648	679	SABINAL	94LA200	404	16.4	
649	201	ROCKPORT	94CS5930	1,046	16.3	
650	7	DARST	94CN790	70	16.1	
651	630	COLUMBUS	94CN9060	382	16.0	
652	431	PUEBLO	94LA130	875	15.8	
653	692	EAGLE PASS CITY	94LA450	665	15.8	
654	571	EAGLE LAKE	94CN9455	582	15.6	
655	new station		94SB715	2,067	15.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
656	541	POLK AVENUE	94SB4520	880	15.1	
657	660	BAY CITY	94CN6450	972	15.0	
658	607	ARANSAS PASS	94CS590	408	14.9	
659	340	SHARYLAND	94SB2150	1,024	14.9	
660	444	SIERRA VISTA	94LA7360	2,417	14.8	
661	649	LAREDO PLANT	94LA8745	720	14.7	
662	new	GATEWAY	94LA3595	1,242	14.4	
663	282	SHARYLAND	94SB5635	1,612	14.3	
664	603	ANNA STREET	94LA780	452	14.3	
665	69	EDNA	94CN5765	1,646	14.0	
666	599	HARLINGEN S.S.	94SB4230	1,768	13.7	
667	698	DEL RIO CITY	94LA9850	906	13.5	
668	640	THREE RIVERS	94CN5100	34	13.5	
669	493	SIERRA VISTA	94LA3540	296	13.3	
670	634	HEARN ROAD	94CS2220	1,526	13.1	
671	373	SOUTHSIDE	94CS8055	846	13.1	
672	463	EL CAMPO	94CN2860	550	13.0	
673	247	AMISTAD DAM	94LA5450	1,063	12.9	
674	656	GARWOOD CITY	94CN2570	132	12.6	
675	612	NORTH VICTORIA	94CN2240	778	12.6	
676	446	RAYMONDVILLE #1	94SB3130	265	12.4	
677	455	MAGRUDER	94CN7870	1,261	12.3	
678	358	EL CAMPO	94CN6370	706	11.8	
679	668	CONOCO-CHITTAM RANCH	94LA8580	37	11.5	
680	590	ROCKPORT	94CS5940	56	11.4	
681	185	CLARKWOOD	94CS7220	322	11.2	
682	549	SINTON	94CS1750	484	11.1	
683	569	HARLINGEN	94SB370	1,133	11.0	
684	484	DEL MAR	94LA10	2,612	10.4	
685	342	SOUTHSIDE	94CS5345	393	10.2	
686	323	KNIPPA	94LA6535	21	10.1	
687	666	DEL MAR	94LA7930	1,457	9.8	
688	502	SHARYLAND	94SB2020	2,233	9.7	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
689	186	MATHIS	94CS1420	935	9.2	
690	475	NORTH VICTORIA	94CN6390	1,322	8.1	
691	154	BUENA VISTA	94LA8965	959	7.9	
692	193	DEVINE	94LA7100	928	7.9	
693	539	BROOKHOLLOW	94CN8950	860	7.9	
694	707	ESCONDIDO	94LA2035	2,321	7.8	
695	205	PLACEDO	94CN7980	397	6.9	
696	525	PORTLAND	94CS9370	1,416	6.4	
697	585	PALMHURST	94SB3890	2,237	6.3	
698	440	SANTO NINO	94LA695	1,489	6.2	
699	682	RODD FIELD	94CS3010	1,252	6.1	
700	611	WESLACO UNIT	94SB2195	1,083	5.9	
701	new	INGLESIDE CITY	94CS2495	80	5.9	
702	68	CASA BLANCA	94CS5115	279	5.4	
703	714	ZACATE CREEK	94LA2635	249	4.3	
704	422	ARANSAS PASS	94CS660	716	4.1	
705	272	SIERRA VISTA	94LA9900	2,011	3.8	
706	481	WASHINGTON STREET	94LA2470	219	3.5	
707	433	WOOLRIDGE	94CS1120	2,334	3.3	
708	471	GARWOOD CITY	94CN2560	190	2.9	
709	677	GREGORY	94CS420	23	2.6	
710	110	ASPHALT MINES	94LA500	34	2.1	
711	387	ANNA STREET	94LA5780	731	2.0	
712	251	LAREDO PLANT	94LA8565	1,091	1.4	
713	704	MORRIS STREET	94CSNET CC	298	0.7	
714	179	LAREDO PLANT	94LA8705	205	0.2	
715	new	ESCONDIDO	94LA3350	881	-	
716	715	WASHINGTON STREET	94LANETLAR	345	-	
717	new station	OLMITO	94SB905	153	-	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value	Notes
--------------------	--------------------	---------------------------	-----------------------	---------------------	------------------	-------

Feeders from last year that are not in this year's list

2007 SAIDI Ranking	Substation Identification	Feeder Identification	Reason not in 2008
53	Robstown	94CS7120	serves <10 customers
352	Gateway	94LA380	circuit retired
370	Ingleside City	94CS7310	serves <10 customers
487	Industrial	94CS5430	serves <10 customers
650	Airline	94CS2180	serves <10 customers
701	Clarkwood	94CS2170	serves <10 customers
709	Fannin	94CN7940	serves <10 customers
710	Foster Field	94CN8880	serves <10 customers
712	Southside	94CS7935	serves <10 customers
713	STEC (Riverside)	94CS9101	delivery point to co-op from other circuit