



Control Number: 36484



Item Number: 9

Addendum StartPage: 0

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2008 Reporting Year

2009 FEB 13 PM 2:55
CLERK

AEP Texas North Company

Project 36484

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2008	0.75	0.03	0.04	0.05	0.08	0.1	0.12	0.05	0.09	0.04	0.05	0.05	0.05
Scheduled 2008	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Outside Causes 2008	0.43	0.04	0.03	0.07	0.11	0.02	0.01	0.02	0.08	0.03	0.00	0.00	0.02
Major Events 2008	0.21				0.04		0.17						

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
System SAIDI	63.9	2.7	2.8	4.2	8.6	9.1	10.4	3.4	8.9	2.9	4.1	2.7	4.1
Forced 2008	0.1	0	0.1	0	0	0	0	0	0	0	0	0	0
Scheduled 2008	25.9	1.2	3.5	3.5	4.5	1.1	0.4	1.3	6.4	2.7	0.1	0.1	1.1
Outside Causes 2008	104.4				2.4		102.0						
Major Events 2008													

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With More Than 10 Customers

Add or Delete Rows as Necessary

AEP Texas North Company

Total Number of Feeders
390

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
1	1	RIO PECOS	97SA3835	131	8.763
2	8	MESA VIEW	97SA7045	106	5.160
3	3	PECOS VALLEY	97SA4080	149	4.181
4	2	INDIAN MESA	97SA2695	182	4.060
5	203	WYLLIE	97AB2665	1,158	3.862
6	74	PUTNAM	97AB2131	118	3.525
7	179	PADUCAH CITY	97AB1930	610	3.493
8	96	ACME BESTWALL	97AB4150	63	3.317
9	218	CISCO	97AB1680	793	3.209
10	40	THROCKMORTON	97AB3190	634	3.197
11	107	CEDAR GAP (TEC)	97AB4115	227	3.189
12	278	BAIRD	97AB5120	439	3.052
13	70	AB COUNTRY CLUB	97AB4855	739	2.962
14	59	PERKINS PROTHO	97SA3180	20	2.950
15	294	AB RAINEY CREEK	97AB4550	945	2.911
16	299	PAULANN	97SA6280	388	2.768
17	68	HAROLD	97AB1495	17	2.765
18	24	MCCAMEY	97SA2415	156	2.692
19	177	AB MCMURRY	97AB3245	780	2.672
20	92	MCCAMEY	97SA2420	104	2.663
21	285	PADUCAH CITY	97AB1935	279	2.631
22	264	SA NORTH	97SA3130	220	2.609
23	155	TANKERSLY (CVEC)	97SA5260	796	2.584
24	325	BENJAMIN (BEPC)	97AB5680	176	2.506
25	222	RIO PECOS	97SA513	20	2.450
26	247	CISCO	97AB1675	859	2.377
27	64	CISCO	97AB1685	231	2.359
28	111	BAIRD	97AB5125	658	2.298

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
29	345	AB HARTFORD ST	97AB3820	906	2.283
30	219	CHILDRESS 69	97AB1480	306	2.222
31	297	WYLIE	97AB6340	673	2.218
32	48	AB DYESS 2	97AB6335	349	2.201
33	75	HAROLD	97AB3055	23	2.174
34	134	CHILLICOTHE	97AB4525	128	2.164
35	196	QUANAH	97AB1830	642	2.154
36	254	VERNON	97AB1520	777	2.148
37	83	BALLINGER	97SA4375	441	2.141
38	273	ALBANY	97AB3640	309	2.113
39	175	TUSCOLA	97AB3730	1,168	2.107
40	260	AFTON	97AB2355	50	2.100
41	62	VERNON CITY PLANT	97AB5770	123	2.098
42	new station	BLUFFS	97SA7280	1,097	2.090
43	129	STAMFORD	97AB4565	850	2.084
44	383	PAULANN	97SA6285	41	2.073
45	30	ASPR CONTINENTAL	97AB4800	35	2.057
46	122	AB COUNTRY CLUB	97AB4730	525	2.050
47	176	CEDAR GAP (TEC)	97AB5445	221	2.045
48	27	CROSS PLAINS	97AB2920	542	2.041
49	211	WAGGONER	97AB5900	26	2.038
50	148	MIDWAY LANE	97SA3440	58	2.000
51	36	SA COKE ST	97SA3905	660	1.982
52	265	PAULANN	97SA6310	818	1.923
53	141	TANKERSLY (CVEC)	97SA5265	11	1.909
54	149	FLOMOT	97AB4089	52	1.904
55	304	AB EAST 12KV	97AB5760	207	1.850
56	305	AB MCMURRY	97AB4355	999	1.837
57	<10 customers	PAISANO	97SAPAI SAN	10	1.800
58	223	BRADY	97SA5015	183	1.792
59	35	CROSS PLAINS	97AB2915	503	1.785
60	60	VALERA HUMBLE	97SA7015	80	1.763
61	6	PECOS VALLEY	97SA4075	20	1.750

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
62	133	PAINT ROCK	97SA5235	184	1.668
63	238	MERKEL	97AB1890	604	1.646
64	108	ABILENE PLANT	97AB1570	665	1.639
65	322	SPUR	97AB411	232	1.603
66	160	MERTZON (CVEC)	97SA2905	561	1.601
67	246	AB DYESS 1	97AB1775	604	1.588
68	14	MCCAMEY	97SA2855	60	1.567
69	327	SA EMERSON ST	97SA4860	245	1.547
70	34	TUSCOLA	97AB3305	956	1.536
71	258	CHILLICOTHE	97AB4530	523	1.518
72	243	SUN VALLEY	97SA4300	88	1.500
73	295	SHEFFIELD	97SA6430	253	1.458
74	329	MERTZON (CVEC)	97SA1530	310	1.445
75	152	CISCO	97AB1690	784	1.435
76	227	ALPINE 12KV	97SA3875	494	1.419
77	312	MUNDAY	97AB2080	484	1.374
78	346	EDEN	97SA3195	504	1.367
79	90	QUANAH	97AB100	104	1.365
80	289	BEN FICKLIN	97SA6185	223	1.359
81	9	RISING STAR	97AB5080	560	1.348
82	291	AB MCMURRY	97AB4350	702	1.342
83	185	SA GRAPE CREEK	97SA4700	687	1.298
84	37	MATADOR	97AB3090	242	1.281
85	337	SPUR	97AB414	241	1.274
86	284	ANSON REA (SEC)	97AB5215	622	1.270
87	204	VERNON	97AB1750	265	1.264
88	286	ALBANY	97AB3655	629	1.264
89	112	WYLIE	97AB2675	736	1.262
90	351	SA LAKE DR	97SA5865	1,130	1.262
91	178	MENARD	97SA3755	791	1.253
92	145	MCELROY	97SA5165	95	1.253
93	66	BRADSHAW (CLIMAX)	97AB11301	48	1.250
94	197	AB ELM CREEK	97AB5045	360	1.244

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
95	118	SPUR	97AB5170	340	1.244
96	69	PECAN BAYOU	97AB6810	419	1.243
97	202	AB VOGEL ST	97AB4410	784	1.228
98	370	SA WALNUT ST	97SA3910	164	1.207
99	234	SA JACKSON ST	97SA4265	966	1.196
100	336	HIGHLAND	97SA6370	514	1.196
101	43	SONORA	97SA2045	645	1.195
102	242	ALBANY	97AB3540	595	1.190
103	352	QUANAH	97AB3100	590	1.188
104	190	SA GRAPE CREEK	97SA5220	641	1.181
105	18	MELVIN	97SA4955	135	1.178
106	164	FT DAVIS	97SA4515	912	1.166
107	163	SPUDDER FLAT	97SA4175	55	1.164
108	353	STAMFORD	97AB2835	148	1.162
109	213	IRAAN	97SA2050	164	1.146
110	338	AB SHELTON ST	97AB4640	645	1.138
111	280	SA EMERSON ST	97SA4630	1,202	1.131
112	<10 customers	ASPR CONTINENTAL	97AB3830	16	1.125
113	57	AILEEN	97AB6435	475	1.118
114	333	MERKEL	97AB1895	732	1.117
115	81	AB ELM CREEK	97AB4775	862	1.117
116	194	BIG LAKE	97SA4655	1,203	1.095
117	341	SA SOUTH	97SA2595	874	1.094
118	23	VALENTINE	97SA5590	185	1.092
119	22	AB REBECCA LANE	97AB6915	978	1.086
120	201	BALLINGER	97SA4395	1,144	1.085
121	208	MCCAMEY	97SA2830	441	1.077
122	142	ROTAN	97AB1860	736	1.075
123	253	SA WALNUT ST	97SA3915	796	1.075
124	85	AB ELM CREEK	97AB4745	938	1.072
125	109	SA CONCHO	97SA1715	296	1.071
126	80	POWELL FIELD	97SA2528	28	1.071
127	139	VALENTINE	97SA6325	561	1.070

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
128	17	DUNEFIELD (N CRANE)	97SA3885	59	1.068
129	317	BALLINGER	97SA4370	844	1.063
130	88	BUSH KNOB	97AB5200	289	1.062
131	162	HIGHLAND	97SA6385	1,399	1.060
132	365	SA CONCHO	97SA1700	480	1.058
133	54	SHAFTER	97SA50803	52	1.058
134	268	AB EAST 12KV	97AB4820	1,125	1.056
135	380	SA CONCHO	97SA3325	54	1.056
136	288	SA EMERSON ST	97SA4620	425	1.045
137	369	MCCAMEY	97SA3670	278	1.043
138	131	ALBANY	97AB2029	238	1.042
139	266	BIG LAKE	97SA4665	429	1.040
140	271	AB SHELTON ST	97AB3435	313	1.032
141	349	SA CONCHO	97SA1725	31	1.032
142	73	WOODSON OIL FIELD	97AB30	35	1.029
143	359	SA WALNUT ST	97SA3925	878	1.028
144	147	INDIAN MESA	97SA2690	73	1.027
145	339	SA SOUTHLAND HILLS	97SA5860	1,129	1.022
146	319	FT DAVIS	97SA3345	416	1.017
147	58	AB ELM CREEK	97AB1820	91	1.011
148	343	SA EMERSON ST	97SA4625	437	1.011
149	362	ANSON 12KV	97AB6630	368	1.005
150	244	WINTERS	97SA2113	905	1.001
151	new	FLOMOT	97AB1335	36	1.000
152	165	EOLA	97SA4950	241	0.979
153	373	ABILENE PLANT	97AB1740	28	0.964
154	79	MORAN	97AB2108	347	0.824
155	267	AB SHELTON ST	97AB3050	645	0.820
156	230	FT CHADBOURNE	97SA6515	80	0.788
157	146	SA MATHIS FIELD	97SA4790	146	0.781
158	4	SAND ROAD	97AB5195	254	0.736
159	119	MUNDAY	97AB6715	240	0.729
160	154	OZONA	97SA3555	135	0.726

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
161	67	PONDER KENNEDY	97SA5105	10	0.700
162	283	FT CHADBOURNE	97SA6520	530	0.677
163	210	FREISS RANCH	97SA4870	106	0.660
164	296	RULE	97AB3378	113	0.655
165	174	RISING STAR	97AB5075	690	0.642
166	86	TEXON	97SA4345	145	0.641
167	95	COLLEGE HILLS	97SA5520	437	0.632
168	100	RANKIN	97SA6405	150	0.593
169	282	ROBY	97AB3795	82	0.573
170	84	CLYDE	97AB1760	405	0.558
171	82	TRENT	97AB2850	31	0.548
172	77	QUANAH	97AB3975	207	0.531
173	382	SILVER	97SA5305	17	0.529
174	29	AB REBECCA LANE	97AB5550	664	0.526
175	110	BRONTE	97SA3590	176	0.523
176	168	CHRISTOVAL	97SA6615	389	0.517
177	12	CROSS PLAINS	97AB1795	709	0.502
178	98	SA SOUTH	97SA3995	1,265	0.484
179	287	KIRKLAND	97AB3545	29	0.483
180	143	PUTNAM	97AB2129	224	0.482
181	16	HAMLIN SHELL	97AB6330	25	0.480
182	292	MENARD	97SA3760	570	0.474
183	356	HIGHLAND	97SA6380	432	0.472
184	364	SA AVENUE N	97SA1655	467	0.460
185	166	ALPINE 12KV	97SA6825	1,761	0.444
186	99	SA NORTH	97SA3120	1,125	0.429
187	32	ABILENE PLANT	97AB1565	290	0.424
188	314	SA AVENUE N	97SA1730	813	0.419
189	87	SAND ROAD	97AB5655	661	0.418
190	182	AB HARTFORD ST	97AB3815	1,124	0.414
191	94	SA COKE ST	97SA4910	1,282	0.413
192	52	SA GRAPE CREEK	97SA5365	725	0.379
193	63	STAMFORD	97AB2815	724	0.374

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
194	237	SA JACKSON ST	97SA4690	1,210	0.361
195	368	AB EAST 12KV	97AB4830	611	0.358
196	270	BEN FICKLIN	97SA6175	643	0.358
197	71	IRAAN	97SA2055	540	0.354
198	5	SARAGOSA	97SA1590	38	0.342
199	20	SAND ROAD	97AB5295	554	0.338
200	161	CLYDE	97AB3635	733	0.336
201	376	AB HARTFORD ST	97AB3690	166	0.331
202	232	ABILENE PLANT	97AB1575	606	0.322
203	225	RULE	97AB3396	469	0.320
204	205	STAMFORD PUMP	97AB3930	29	0.310
205	272	GIRARD	97AB6260	42	0.310
206	26	PECAN BAYOU	97AB6815	1,465	0.308
207	184	STERLING CITY	97SA1445	782	0.304
208	49	ABILENE PLANT	97AB1735	76	0.303
209	310	THROCKMORTON	97AB2090	73	0.301
210	315	ROBY	97AB2276	321	0.299
211	25	ELDORADO	97SA1845	812	0.296
212	186	SANTA ANNA	97SA3415	331	0.293
213	132	AB MCMURRY	97AB4360	1,105	0.290
214	33	HASKELL 12KV	97AB3770	440	0.286
215	281	COLLEGE HILLS	97SA6145	727	0.282
216	340	TRENT	97AB4245	196	0.281
217	355	SA JACKSON ST	97SA4260	665	0.281
218	277	SA WALNUT ST	97SA4635	1,514	0.278
219	216	AB MAPLE ST	97AB5755	1,147	0.276
220	249	ASPERMONT	97AB3380	762	0.268
221	293	HAMLIN	97AB3775	287	0.268
222	229	SPUDDER FLAT	97SA4180	56	0.268
223	374	CORINTH	97AB2590	15	0.267
224	97	MARFA	97SA1900	688	0.260
225	21	SARAGOSA	97SA1552	658	0.257
226	172	CHRISTOVAL	97SA6620	527	0.256

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
227	354	AB ELM CREEK	97AB1810	842	0.251
228	361	AB ELM CREEK	97AB1815	371	0.251
229	61	BOBCAT HILLS	97SA6655	20	0.250
230	11	AB MAPLE ST	97AB5750	405	0.247
231	51	AB SHELTON ST	97AB3060	1,572	0.244
232	252	ONYX REA	97AB3260	151	0.232
233	214	CHILDRESS 69	97AB4865	763	0.231
234	93	RANKIN	97SA5735	338	0.225
235	240	SA AVENUE N	97SA1695	1,373	0.224
236	248	EDEN	97SA1780	253	0.221
237	239	BEN FICKLIN	97SA6180	905	0.217
238	55	ABILENE PLANT	97AB1915	65	0.215
239	171	CLYDE	97AB3630	542	0.212
240	159	OZONA	97SA4185	1,291	0.211
241	128	AB VOGEL ST	97AB4405	557	0.210
242	173	AB CANYON ROCK	97AB5030	858	0.209
243	226	WINTERS	97SA3765	787	0.207
244	290	PEACOCK	97AB43	49	0.204
245	378	KNOX CITY	97AB3985	25	0.200
246	344	ABILENE PLANT	97AB1910	303	0.195
247	193	OZONA	97SA3810	646	0.193
248	137	VERNON	97AB3340	565	0.191
249	207	SA NORTH	97SA3115	531	0.190
250	135	MASTERSON FIELD	97SA2101	218	0.188
251	181	ELDORADO	97SA2880	346	0.188
252	241	CHILDRESS 20TH ST	97AB5720	168	0.185
253	121	IRAAN	97SA4305	81	0.185
254	170	SA WALNUT ST	97SA3920	860	0.179
255	89	AB REBECCA LANE	97AB2710	249	0.177
256	104	SWENSON	97AB136	29	0.172
257	192	HAWLEY	97AB4455	613	0.168
258	307	AB OVER STREET 12KV	97AB1645	780	0.167
259	28	MUNDAY REA (BKEC)	97AB2015	36	0.167

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
260	158	ANSON 12KV	97AB6635	413	0.165
261	261	AB CANYON ROCK	97AB5035	853	0.163
262	13	VERNON	97AB4275	631	0.160
263	350	SA LAKE DR	97SA6030	610	0.157
264	332	CROWELL	97AB3490	186	0.156
265	31	AB RAINEY CREEK	97AB4220	186	0.156
266	180	ALPINE 12KV	97SA3160	1,037	0.156
267	302	ROTAN	97AB1865	189	0.153
268	233	WEINERT	97AB6490	131	0.153
269	367	AB WALNUT ST	97AB3445	92	0.152
270	236	CLYDE	97AB1755	113	0.150
271	113	AB OVER STREET 12KV	97AB3140	639	0.150
272	7	JUNCTION	97SA4335	771	0.147
273	263	RANKIN	97SA6400	146	0.144
274	41	SA JACKSON ST	97SA4685	1,379	0.142
275	371	AB HARTFORD ST	97AB3685	358	0.140
276	new station	BLUFFS	97SA9110	361	0.139
277	105	TURKEY	97AB3825	383	0.138
278	372	SA AVENUE N	97SA1975	323	0.136
279	330	VERNON	97AB5000	260	0.135
280	323	QUANAH	97AB3530	374	0.134
281	274	AB WALNUT ST	97AB3110	1,132	0.133
282	215	CHERRY CREEK TAP	97SA5245	23	0.130
283	320	ROBERT LEE	97SA4125	297	0.128
284	72	JUNCTION	97SA4340	775	0.124
285	298	AB ELM CREEK	97AB1825	220	0.123
286	220	AB MCMURRY	97AB3240	756	0.123
287	183	SA SOUTH	97SA4255	816	0.123
288	15	HASKELL 12KV	97AB3495	820	0.122
289	156	TWILIGHT TRAIL	97AB4290	813	0.122
290	198	AB ELM DALE	97AB4520	214	0.121
291	53	BARNHART	97SA3725	99	0.121
292	91	SAND ROAD	97AB5290	832	0.118

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
293	321	MUNDAY	97AB3365	385	0.117
294	231	AB SHELTON ST	97AB3145	1,057	0.116
295	308	COLLEGE HILLS	97SA4840	232	0.116
296	117	VERNON CITY PLANT	97AB5775	837	0.112
297	116	SA SOUTH	97SA3500	170	0.112
298	144	AB RAINEY CREEK	97AB4225	90	0.111
299	136	TWILIGHT TRAIL	97AB4285	1,166	0.109
300	279	SA SOUTHLAND HILLS	97SA5050	884	0.109
301	228	AB VOGEL ST	97AB4560	1,386	0.108
302	195	MILES	97SA4670	493	0.108
303	301	SA LAKE DR	97SA5880	802	0.107
304	169	HUMBLE KEMPER	97SA1490	19	0.105
305	245	CHILDRESS 69	97AB1800	556	0.104
306	300	AB OVER STREET 12KV	97AB1840	876	0.104
307	76	AB ELMDALE	97AB4085	39	0.103
308	120	TWILIGHT TRAIL	97AB3150	629	0.102
309	102	HASKELL 12KV	97AB5240	642	0.098
310	125	SA CONCHO	97SA1705	823	0.096
311	126	AB SHELTON ST	97AB3660	649	0.092
312	19	MATADOR	97AB3030	523	0.090
313	224	HIGHLAND	97SA6375	247	0.089
314	new station	BLUFFS	97SA3005	115	0.087
315	189	SONORA 138 SUB	97SA4810	1,016	0.086
316	311	AB MCMURRY	97AB3235	834	0.085
317	377	TRUSCOTT	97AB3845	36	0.083
318	275	SONORA 138 SUB	97SA4805	499	0.082
319	347	AB OVER STREET 12KV	97AB1635	518	0.081
320	318	SA SOUTH	97SA3990	502	0.080
321	256	KNOX CITY	97AB3300	481	0.079
322	212	AB RAINEY CREEK	97AB4270	1,343	0.078
323	140	NORTH MCCAMEY	97SA6560	485	0.078
324	375	AB WALNUT ST	97AB3250	13	0.077
325	167	TALPA ATLANTIC	97SA5180	65	0.077

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
326	251	CROWELL	97AB3980	514	0.076
327	200	ALPINE 12KV	97SA3155	1,050	0.076
328	334	SANTA ANNA	97SA3420	355	0.076
329	39	MARFA	97SA1905	1,027	0.075
330	199	KNOX CITY	97AB3390	370	0.073
331	157	ROUNDTOP	97AB4490	41	0.073
332	303	CHILDRESS 20TH ST	97AB5725	655	0.073
333	101	BRONTE	97SA4160	218	0.073
334	45	TWILIGHT TRAIL	97AB5855	1,426	0.068
335	103	BRONTE	97SA3560	251	0.068
336	348	CHILDRESS 69	97AB2800	342	0.067
337	187	ROARING SPRINGS	97AB6155	30	0.067
338	255	STAMFORD	97AB6255	420	0.067
339	114	ROCHESTER	97AB3295	258	0.066
340	78	PRESIDIO	97SA6135	892	0.066
341	309	PRESIDIO	97SA4540	1,315	0.064
342	127	AB ELM CREEK	97AB4780	496	0.060
343	221	AB MCMURRY	97AB4510	819	0.059
344	262	ROWENA	97SA4480	220	0.059
345	313	ALPINE 12KV	97SA6820	735	0.059
346	188	ROBERT LEE	97SA4120	588	0.056
347	331	TURKEY	97AB2980	329	0.055
348	250	MORAN	97AB2107	210	0.052
349	130	AB OIL MILL	97AB3900	715	0.052
350	124	AB COUNTRY CLUB	97AB4735	116	0.052
351	324	AB VOGEL ST	97AB4650	800	0.051
352	65	VERHALEN	97SA4465	40	0.050
353	206	HAMLIN	97AB3270	931	0.047
354	191	AFTON	97AB2310	261	0.046
355	316	SA SOUTHLAND HILLS	97SA5055	716	0.045
356	363	SA JACKSON ST	97SA4695	544	0.040
357	366	AB WALNUT ST	97AB3785	516	0.037
358	115	AFTON	97AB2225	59	0.034

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
359	306	JAYTON	97AB6125	351	0.034
360	276	SA MATHIS FIELD	97SA5100	218	0.032
361	151	PLASTERCO (MWEC)	97AB2720	128	0.031
362	209	AILEEN	97AB4605	620	0.031
363	46	AB OIL MILL	97AB2780	737	0.028
364	150	SA NORTH	97SA3125	1,060	0.028
365	50	AB COUNTRY CLUB	97AB4725	193	0.026
366	38	SA SOUTH	97SA4795	1,068	0.025
367	42	CROCKETT HEIGHTS	97SA73703	80	0.025
368	10	GRAYBACK	97AB3315	42	0.024
369	328	AB SHELTON ST	97AB3045	524	0.019
370	326	SA SOUTHLAND HILLS	97SA5455	1,116	0.019
371	357	EDITH HUMBLE	97SA6170	107	0.019
372	342	SA JACKSON ST	97SA4250	288	0.014
373	56	ROCHESTER	97AB3290	86	0.012
374	360	AB SHELTON ST	97AB3040	181	0.011
375	47	ABILENE PLANT	97AB3175	103	0.010
376	<10 customers	AB OIL MILL	97AB2785	232	0.009
377	123	COLLEGE HILLS	97SA5515	345	0.009
378	44	AB OIL MILL	97AB3895	130	0.008
379	reconfigured	COLLEGE HILLS	97SA4845	179	0.006
380	379	AILEEN	97AB4600	250	0.004
381	138	AB REBECCA LANE	97AB5555	1,014	0.004
382	217	AB EAST 12KV	97AB4825	409	0.002
383	259	ONYX REA	97AB3255	28	-
384	<10 customers	GRAYBACK	97AB3320	11	-
385	358	AB CANYON ROCK	97AB5025	56	-
386	257	SONORA ATLANTIC (SWTEC)	97SA4415	22	-
387	106	COLLEGE HILLS	97SA4835	442	-
388	381	SA COKE ST	97SA4915	15	-
389	335	ESPY WELLS	97SA5522	29	-
390	384	BRONTE AMBASSADOR	97SA6650	16	-

from 97SA4845RE

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIFI Ranking	2007 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIFI Value
--------------------	--------------------	---------------------------	-----------------------	---------------------	------------------

Feeders from last year that are not in this year's list

2007 SAIFI Ranking	Substation Identification	Feeder Identification	Reason not in 2008
153	Spur	97AB417	Retired
235	College Hills	97SA4845RE	97SA4845 serves a piece of this old circuit
269	Powell Field	97SA2529	serves <10 customers

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With More Than 10 Customers

Total Number of Feeders

390

Add or Delete Rows as Necessary

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
1	2	RIO PECOS	97SA3835	131	1,207.1
2	211	SUN VALLEY	97SA4300	88	952.1
3	10	MESA VIEW	97SA7045	106	907.7
4	238	AFTON	97AB2355	50	584.5
5	1	PECOS VALLEY	97SA4080	149	563.6
6	64	ACME BESTWALL	97AB4150	63	559.7
7	179	PADUCAH CITY	97AB1930	610	480.1
8	372	MCCAMEY	97SA3670	278	479.4
9	26	MCCAMEY	97SA2415	156	475.9
10	310	PADUCAH CITY	97AB1935	279	471.7
11	3	INDIAN MESA	97SA2695	182	465.1
12	45	MCCAMEY	97SA2420	104	453.0
13	42	TANKERSLY (CVEC)	97SA5260	796	452.6
14	115	MIDWAY LANE	97SA3440	58	414.8
15	8	PERKINS PROTHO	97SA3180	20	392.4
16	91	CEDAR GAP (TEC)	97AB4115	227	349.7
17	65	MERTZON (CVEC)	97SA2905	561	347.6
18	259	MUNDAY	97AB2080	484	336.6
19	15	CROSS PLAINS	97AB2920	542	333.7
20	48	CISCO	97AB1685	231	331.2
21	99	ASPR CONTINENTAL	97AB4800	35	319.7
22	13	DUNEFIELD (N CRANE)	97SA3885	59	316.8
23	18	VALERA HUMBLE	97SA7015	80	305.3
24	25	PUTNAM	97AB2131	118	290.1
25	219	RIO PECOS	97SA513	20	289.4
26	186	TUSCOLA	97AB3730	1,168	278.9
27	305	PAULANN	97SA6280	388	265.2
28	82	CHILLICOTHE	97AB4525	128	260.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
29	382	SILVER	97SA5305	17	258.8
30	4	PECOS VALLEY	97SA4075	20	251.0
31	33	POWELL FIELD	97SA2528	28	247.4
32	314	BENJAMIN (BEPC)	97AB5680	176	245.3
33	163	SA GRAPE CREEK	97SA4700	687	244.9
34	251	WYLIE	97AB6340	673	240.9
35	112	BUSH KNOB	97AB5200	289	215.0
36	277	BEN FICKLIN	97SA6185	223	213.3
37	68	MELVIN	97SA4955	135	212.0
38	109	FLOMOT	97AB4089	52	211.7
39	313	ALBANY	97AB3640	309	201.5
40	29	HAROLD	97AB1495	17	200.2
41	263	SA WALNUT ST	97SA3915	796	198.8
42	292	AB MCMURRY	97AB4355	999	198.2
43	43	AB DYESS 2	97AB6335	349	191.5
44	299	TANKERSLY (CVEC)	97SA5265	11	187.1
45	104	SPUDDER FLAT	97SA4175	55	181.0
46	270	SA NORTH	97SA3130	220	179.3
47	171	WYLIE	97AB2665	1,158	178.9
48	273	SA JACKSON ST	97SA4265	966	178.2
49	131	AB COUNTRY CLUB	97AB4855	739	177.6
50	291	AB MCMURRY	97AB4350	702	177.1
51	167	BRADY	97SA5015	183	174.8
52	39	SHAFTER	97SA50803	52	173.6
53	106	TEXON	97SA4345	145	173.4
54	218	CISCO	97AB1680	793	169.2
55	209	QUANAH	97AB1830	642	166.1
56	73	TUSCOLA	97AB3305	956	159.7
57	325	MERTZON (CVEC)	97SA1530	310	156.5
58	271	CHILLICOTHE	97AB4530	523	156.4
59	153	WAGGONER	97AB5900	26	153.4
60	140	AB MCMURRY	97AB3245	780	149.8
61	236	MERKEL	97AB1890	604	145.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
62	245	BALLINGER	97SA4395	1,144	145.0
63	255	CHILDRESS 69	97AB1480	306	144.4
64	145	ROTAN	97AB1860	736	144.0
65	17	RISING STAR	97AB5080	560	141.3
66	58	TRENT	97AB2850	31	140.9
67	16	MCCAMEY	97SA2855	60	140.5
68	new station	BLUFFS	97SA7280	1,097	140.2
69	20	WOODSON OIL FIELD	97AB30	35	137.8
70	175	STAMFORD	97AB4565	850	135.9
71	<10 customers	ASPR CONTINENTAL	97AB3830	16	135.4
72	341	AB HARTFORD ST	97AB3820	906	135.3
73	300	ANSON REA (SEC)	97AB5215	622	134.6
74	357	ANSON 12KV	97AB6630	368	133.6
75	215	ALPINE 12KV	97SA3875	494	133.4
76	168	BALLINGER	97SA4375	441	133.2
77	127	QUANAH	97AB100	104	132.9
78	95	BAIRD	97AB5125	658	132.7
79	92	SA MATHIS FIELD	97SA4790	146	131.5
80	383	PAULANN	97SA6285	41	128.8
81	89	THROCKMORTON	97AB3190	634	126.7
82	125	PAINT ROCK	97SA5235	184	126.4
83	330	MERKEL	97AB1895	732	123.5
84	365	SA WALNUT ST	97SA3910	164	121.9
85	359	SA LAKE DR	97SA5865	1,130	120.9
86	<10 customers	PAISANO	97SAPAI SAN	10	118.7
87	35	MCELROY	97SA5165	95	117.9
88	158	WYLIE	97AB2675	736	117.7
89	283	AB RAINEY CREEK	97AB4550	945	117.3
90	293	ALBANY	97AB3540	595	115.6
91	181	VALENTINE	97SA6325	561	114.6
92	337	SA EMERSON ST	97SA4860	245	112.0
93	332	SA SOUTH	97SA2595	874	108.7
94	129	VERNON CITY PLANT	97AB5770	123	108.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
95	229	BAIRD	97AB5120	439	107.2
96	353	STAMFORD	97AB2835	148	105.0
97	30	CROSS PLAINS	97AB2915	503	104.5
98	284	ROBY	97AB3795	82	103.4
99	28	BRADSHAW (CLIMAX)	97AB11301	48	103.3
100	324	SPUR	97AB411	232	103.3
101	56	SA COKE ST	97SA3905	660	102.8
102	267	FT CHADBOURNE	97SA6520	530	102.8
103	90	PECAN BAYOU	97AB6810	419	102.7
104	207	FREISS RANCH	97SA4870	106	101.2
105	11	VALENTINE	97SA5590	185	99.9
106	361	SA AVENUE N	97SA1655	467	98.6
107	189	CEDAR GAP (TEC)	97AB5445	221	97.9
108	254	MCCAMEY	97SA2830	441	96.7
109	21	MUNDAY	97AB6715	240	94.4
110	210	FT CHADBOURNE	97SA6515	80	94.0
111	24	OZONA	97SA3555	135	93.3
112	193	SA GRAPE CREEK	97SA5220	641	93.1
113	113	ABILENE PLANT	97AB1570	665	91.4
114	298	SA EMERSON ST	97SA4630	1,202	90.6
115	14	PONDER KENNEDY	97SA5105	10	89.7
116	83	INDIAN MESA	97SA2690	73	89.4
117	150	AB VOGEL ST	97AB4410	784	89.1
118	285	ALBANY	97AB3655	629	88.4
119	275	SHEFFIELD	97SA6430	253	86.7
120	203	PAULANN	97SA6310	818	85.1
121	327	SA EMERSON ST	97SA4625	437	84.4
122	214	AB SHELTON ST	97AB3050	645	83.6
123	368	SA CONCHO	97SA1700	480	83.4
124	349	SPUR	97AB414	241	82.4
125	187	VERNON	97AB1520	777	81.1
126	71	AB ELM CREEK	97AB1820	91	81.0
127	312	SA EMERSON ST	97SA4620	425	79.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
128	31	SAND ROAD	97AB5195	254	79.2
129	333	SA CONCHO	97SA1725	31	77.4
130	216	AB ELM CREEK	97AB5045	360	77.3
131	121	MORAN	97AB2108	347	77.1
132	346	EDEN	97SA3195	504	76.3
133	40	SPUR	97AB5170	340	76.1
134	287	WINTERS	97SA2113	905	75.4
135	269	CISCO	97AB1675	859	74.7
136	34	RANKIN	97SA6405	150	74.6
137	107	ALBANY	97AB2029	238	74.4
138	197	IRAAN	97SA2050	164	72.2
139	307	HIGHLAND	97SA6370	514	68.9
140	318	MENARD	97SA3760	570	68.7
141	183	MENARD	97SA3755	791	68.1
142	new	FLOMOT	97AB1335	36	68.0
143	302	AB SHELTON ST	97AB4640	645	66.6
144	66	SA CONCHO	97SA1715	296	65.7
145	88	CHRISTOVAL	97SA6615	389	65.4
146	266	AB EAST 12KV	97AB5760	207	64.3
147	19	COLLEGE HILLS	97SA5520	437	62.8
148	87	AB MCMURRY	97AB4360	1,105	62.6
149	94	AB REBECCA LANE	97AB6915	978	62.6
150	50	AB REBECCA LANE	97AB5550	664	61.2
151	151	RISING STAR	97AB5075	690	61.1
152	232	AB DYESS 1	97AB1775	604	59.3
153	198	VERNON	97AB1750	265	59.0
154	143	EOLA	97SA4950	241	57.9
155	352	QUANAH	97AB3100	590	56.2
156	182	AB COUNTRY CLUB	97AB4730	525	55.8
157	53	PUTNAM	97AB2129	224	53.9
158	54	MATADOR	97AB3090	242	49.2
159	32	HAROLD	97AB3055	23	49.1
160	38	CROSS PLAINS	97AB1795	709	47.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
161	41	SA GRAPE CREEK	97SA5365	725	47.0
162	380	SA CONCHO	97SA3325	54	46.5
163	304	BIG LAKE	97SA4665	429	46.5
164	331	SA SOUTHLAND HILLS	97SA5860	1,129	46.3
165	282	BEN FICKLIN	97SA6175	643	46.2
166	70	CISCO	97AB1690	784	45.9
167	279	SA WALNUT ST	97SA4635	1,514	45.3
168	260	EDEN	97SA1780	253	44.7
169	239	KIRKLAND	97AB3545	29	44.4
170	5	HAMLIN SHELL	97AB6330	25	43.7
171	22	SARAGOSA	97SA1552	658	43.5
172	373	ABILENE PLANT	97AB1740	28	43.4
173	97	CHRISTOVAL	97SA6620	527	42.9
174	55	CLYDE	97AB1760	405	41.7
175	311	RULE	97AB3378	113	41.3
176	301	THROCKMORTON	97AB2090	73	41.0
177	173	AB RAINEY CREEK	97AB4225	90	40.4
178	93	SA NORTH	97SA3120	1,125	40.1
179	208	AB HARTFORD ST	97AB3815	1,124	39.1
180	323	TRENT	97AB4245	196	38.2
181	23	AB MAPLE ST	97AB5750	405	38.0
182	138	AB ELM CREEK	97AB4775	862	37.9
183	69	AILEEN	97AB6435	475	37.8
184	278	COLLEGE HILLS	97SA6145	727	37.0
185	57	PECAN BAYOU	97AB6815	1,465	35.9
186	246	AB CANYON ROCK	97AB5035	853	35.6
187	67	HASKELL 12KV	97AB3770	440	35.5
188	157	AB ELM CREEK	97AB4745	938	35.4
189	195	HIGHLAND	97SA6385	1,399	34.5
190	233	AB EAST 12KV	97AB4820	1,125	34.3
191	118	FT DAVIS	97SA4515	912	34.3
192	378	KNOX CITY	97AB3985	25	33.6
193	354	HIGHLAND	97SA6380	432	33.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
194	102	SA COKE ST	97SA4910	1,282	31.9
195	376	AB HARTFORD ST	97AB3690	166	31.8
196	120	QUANAH	97AB3975	207	31.6
197	290	ONYX REA	97AB3260	151	31.5
198	142	ALPINE 12KV	97SA6825	1,761	31.4
199	224	AB MAPLE ST	97AB5755	1,147	30.0
200	159	BRONTE	97SA3590	176	30.0
201	46	STAMFORD	97AB2815	724	29.0
202	235	ASPERMONT	97AB3380	762	29.0
203	234	BIG LAKE	97SA4655	1,203	28.6
204	116	RANKIN	97SA5735	338	27.9
205	117	AB VOGEL ST	97AB4405	557	27.8
206	6	SARAGOSA	97SA1590	38	27.8
207	350	SA JACKSON ST	97SA4260	665	27.7
208	110	SA SOUTH	97SA3995	1,265	27.3
209	133	SAND ROAD	97AB5655	661	27.0
210	247	AB VOGEL ST	97AB4560	1,386	24.8
211	296	SA AVENUE N	97SA1730	813	24.8
212	135	SA SOUTH	97SA4255	816	24.6
213	364	AB EAST 12KV	97AB4830	611	24.1
214	244	SA JACKSON ST	97SA4690	1,210	24.1
215	230	SA NORTH	97SA3115	531	23.5
216	122	ABILENE PLANT	97AB1565	290	23.3
217	199	STAMFORD PUMP	97AB3930	29	22.7
218	47	AB RAINEY CREEK	97AB4220	186	22.6
219	126	SONORA	97SA2045	645	22.6
220	336	HAMLIN	97AB3775	287	22.3
221	77	SA JACKSON ST	97SA4685	1,379	21.7
222	148	CLYDE	97AB3635	733	21.3
223	44	SAND ROAD	97AB5295	554	21.3
224	374	CORINTH	97AB2590	15	21.1
225	268	CHILDRESS 69	97AB4865	763	21.0
226	261	GIRARD	97AB6260	42	20.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
227	191	CHERRY CREEK TAP	97SA5245	23	20.7
228	360	AB ELM CREEK	97AB1810	842	20.3
229	370	AB WALNUT ST	97AB3445	92	20.3
230	59	PRESIDIO	97SA6135	892	20.3
231	228	RULE	97AB3396	469	20.1
232	172	SANTA ANNA	97SA3415	331	20.0
233	343	BALLINGER	97SA4370	844	19.8
234	165	AB CANYON ROCK	97AB5030	858	19.7
235	201	IRAAN	97SA2055	540	19.7
236	84	MASTERSON FIELD	97SA2101	218	19.6
237	130	AB SHELTON ST	97AB3060	1,572	19.4
238	78	BOBCAT HILLS	97SA6655	20	19.3
239	146	ANSON 12KV	97AB6635	413	19.2
240	134	AB OVER STREET 12KV	97AB3140	639	18.6
241	128	CLYDE	97AB3630	542	18.6
242	108	MARFA	97SA1900	688	18.6
243	144	ELDORADO	97SA2880	346	18.2
244	240	WINTERS	97SA3765	787	18.2
245	225	BEN FICKLIN	97SA6180	905	18.0
246	61	IRAAN	97SA4305	81	17.3
247	202	STERLING CITY	97SA1445	782	17.1
248	205	HAWLEY	97AB4455	613	16.9
249	196	TWILIGHT TRAIL	97AB4285	1,166	16.8
250	347	SA WALNUT ST	97SA3925	878	16.8
251	85	BARNHART	97SA3725	99	16.6
252	79	ELDORADO	97SA1845	812	16.5
253	340	ABILENE PLANT	97AB1910	303	16.3
254	76	TWILIGHT TRAIL	97AB4290	813	16.0
255	220	CLYDE	97AB1755	113	15.7
256	321	AB OVER STREET 12KV	97AB1645	780	15.6
257	152	ABILENE PLANT	97AB1915	65	15.5
258	320	ROBY	97AB2276	321	15.4
259	206	SPUDDER FLAT	97SA4180	56	14.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
260	156	AB REBECCA LANE	97AB2710	249	14.3
261	105	OZONA	97SA4185	1,291	14.3
262	328	FT DAVIS	97SA3345	416	14.1
263	326	CROWELL	97AB3490	186	14.0
264	114	SA SOUTH	97SA3500	170	14.0
265	184	SA WALNUT ST	97SA3920	860	13.9
266	257	AB MCMURRY	97AB3240	756	13.4
267	303	SA SOUTH	97SA3990	502	13.2
268	243	WEINERT	97AB6490	131	13.1
269	272	PEACOCK	97AB43	49	13.0
270	294	COLLEGE HILLS	97SA4840	232	13.0
271	139	VERNON	97AB3340	565	12.9
272	362	AB ELM CREEK	97AB1815	371	12.7
273	317	SA LAKE DR	97SA5880	802	12.7
274	111	MUNDAY REA (BKEC)	97AB2015	36	12.6
275	212	AB WALNUT ST	97AB3110	1,132	12.6
276	101	TWILIGHT TRAIL	97AB5855	1,426	12.5
277	289	RANKIN	97SA6400	146	12.4
278	288	ABILENE PLANT	97AB1575	606	12.0
279	344	QUANAH	97AB3530	374	11.9
280	176	OZONA	97SA3810	646	11.9
281	274	CHILDRESS 20TH ST	97AB5720	168	11.8
282	98	HASKELL 12KV	97AB5240	642	11.7
283	27	SWENSON	97AB136	29	11.6
284	217	AB ELMDALE	97AB4520	214	11.6
285	161	ABILENE PLANT	97AB1735	76	11.5
286	264	SA AVENUE N	97SA1695	1,373	11.5
287	81	JUNCTION	97SA4340	775	11.5
288	316	AB ELM CREEK	97AB1825	220	11.2
289	103	TWILIGHT TRAIL	97AB3150	629	10.9
290	309	AB MCMURRY	97AB3235	834	10.9
291	180	AB SHELTON ST	97AB3435	313	10.6
292	74	AB ELMDALE	97AB4085	39	10.6

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
293	338	VERNON	97AB5000	260	10.5
294	72	TURKEY	97AB3825	383	10.4
295	358	SA JACKSON ST	97SA4695	544	10.1
296	new station	BLUFFS	97SA9110	361	9.9
297	308	ROTAN	97AB1865	189	9.8
298	335	ROBERT LEE	97SA4125	297	9.8
299	248	SA SOUTHLAND HILLS	97SA5050	884	9.8
300	367	AB HARTFORD ST	97AB3685	358	9.7
301	256	HAMLIN	97AB3270	931	9.4
302	188	MILES	97SA4670	493	9.3
303	80	AB SHELTON ST	97AB3660	649	9.2
304	62	VERNON	97AB4275	631	9.2
305	36	JUNCTION	97SA4335	771	9.1
306	242	AB SHELTON ST	97AB3145	1,057	8.9
307	371	SA AVENUE N	97SA1975	323	8.9
308	237	AB RAINEY CREEK	97AB4270	1,343	8.7
309	295	ALPINE 12KV	97SA6820	735	8.7
310	100	ROUNDTOP	97AB4490	41	8.5
311	177	ALPINE 12KV	97SA3160	1,037	8.4
312	250	KNOX CITY	97AB3300	481	8.3
313	231	HUMBLE KEMPER	97SA1490	19	8.2
314	119	AB OIL MILL	97AB3900	715	8.1
315	63	ROCHESTER	97AB3295	258	8.0
316	280	SA SOUTHLAND HILLS	97SA5055	716	8.0
317	170	SA CONCHO	97SA1705	823	7.9
318	377	TRUSCOTT	97AB3845	36	7.8
319	221	AB OVER STREET 12KV	97AB1840	876	7.6
320	306	MUNDAY	97AB3365	385	7.5
321	166	AB MCMURRY	97AB4510	819	7.5
322	124	HIGHLAND	97SA6375	247	7.3
323	178	ROBERT LEE	97SA4120	588	7.2
324	49	HASKELL 12KV	97AB3495	820	6.8
325	276	CROWELL	97AB3980	514	6.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
326	137	SAND ROAD	97AB5290	832	6.6
327	227	SONORA 138 SUB	97SA4810	1,016	6.6
328	192	KNOX CITY	97AB3390	370	6.3
329	164	VERNON CITY PLANT	97AB5775	837	6.3
330	319	CHILDRESS 20TH ST	97AB5725	655	6.0
331	249	CHILDRESS 69	97AB1800	556	5.9
332	286	ROWENA	97SA4480	220	5.9
333	12	CROCKETT HEIGHTS	97SA73703	80	5.9
334	155	NORTH MCCAMEY	97SA6560	485	5.7
335	96	AB OIL MILL	97AB2780	737	5.6
336	200	ALPINE 12KV	97SA3155	1,050	5.6
337	355	AB OVER STREET 12KV	97AB1635	518	5.5
338	194	AB ELM CREEK	97AB4780	496	5.4
339	334	SA LAKE DR	97SA6030	610	5.3
340	162	AFTON	97AB2310	261	5.1
341	7	MATADOR	97AB3030	523	5.1
342	369	AB WALNUT ST	97AB3785	516	5.0
343	147	AB COUNTRY CLUB	97AB4735	116	4.8
344	154	TALPA ATLANTIC	97SA5180	65	4.8
345	241	SONORA 138 SUB	97SA4805	499	4.7
346	262	MORAN	97AB2107	210	4.6
347	75	MARFA	97SA1905	1,027	4.5
348	160	BRONTE	97SA3560	251	4.5
349	9	VERHALEN	97SA4465	40	4.4
350	141	ROARING SPRINGS	97AB6155	30	4.3
351	329	AB VOGEL ST	97AB4650	800	4.2
352	new station	BLUFFS	97SA3005	115	3.9
353	252	JAYTON	97AB6125	351	3.8
354	226	SA MATHIS FIELD	97SA5100	218	3.6
355	339	SANTA ANNA	97SA3420	355	3.5
356	366	CHILDRESS 69	97AB2800	342	3.4
357	265	STAMFORD	97AB6255	420	3.3
358	348	TURKEY	97AB2980	329	3.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
359	149	BRONTE	97SA4160	218	3.1
360	204	SA NORTH	97SA3125	1,060	3.0
361	52	GRAYBACK	97AB3315	42	2.7
362	297	PRESIDIO	97SA4540	1,315	2.6
363	375	AB WALNUT ST	97AB3250	13	2.5
364	185	AILEEN	97AB4605	620	2.5
365	174	PLASTERCO (MWEC)	97AB2720	128	2.3
366	322	AB SHELTON ST	97AB3045	524	2.0
367	132	AB COUNTRY CLUB	97AB4725	193	2.0
368	51	AFTON	97AB2225	59	1.9
369	363	EDITH HUMBLE	97SA6170	107	1.3
370	190	AB REBECCA LANE	97AB5555	1,014	1.2
371	60	SA SOUTH	97SA4795	1,068	1.2
372	315	SA SOUTHLAND HILLS	97SA5455	1,116	1.2
373	<10 customers	AB OIL MILL	97AB2785	232	0.9
374	345	SA JACKSON ST	97SA4250	288	0.9
375	86	AB OIL MILL	97AB3895	130	0.7
376	213	COLLEGE HILLS	97SA5515	345	0.7
377	356	AB SHELTON ST	97AB3040	181	0.6
378	reconfigured	COLLEGE HILLS	97SA4845	179	0.6
379	37	ROCHESTER	97AB3290	86	0.4
380	123	ABILENE PLANT	97AB3175	103	0.2
381	253	AB EAST 12KV	97AB4825	409	0.2
382	379	AILEEN	97AB4600	250	0.1
383	223	ONYX REA	97AB3255	28	-
384	<10 customers	GRAYBACK	97AB3320	11	-
385	342	AB CANYON ROCK	97AB5025	56	-
386	258	SONORA ATLANTIC (SWTEC)	97SA4415	22	-
387	222	COLLEGE HILLS	97SA4835	442	-
388	381	SA COKE ST	97SA4915	15	-
389	351	ESPY WELLS	97SA5522	29	-
390	384	BRONTE AMBASSADOR	97SA6650	16	-

from 97SA4845RE

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

2008 SAIDI Ranking	2007 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2008 SAIDI Value
--------------------	--------------------	---------------------------	-----------------------	---------------------	------------------

Feeders from last year that are not in this year's list

2007 SAIDI Ranking	Substation Identification	Feeder Identification	Reason not in 2008
--------------------	---------------------------	-----------------------	--------------------

136	Spur	97AB417	retired
169	College Hills	97SA4845RE	97SA4845 serves a piece of this old circuit
281	Powell Field	97SA2529	serves <10 customers

Service Quality Report to the Public Utility Commission of Texas

AEP Texas North Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2008 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	27.5 %
Vegetation	16.0 %
Animals and Birds	17.5 %
People (Including cars and farm equip)	2.8 %
Utility-owned Equipment	23.2 %
Other	0.4 %
Unknown	12.7 %