



Control Number: 36487



Item Number: 207

Addendum StartPage: 0

SOUTHWESTERN ELECTRIC POWER
CONSTRUCTION PROGRESS REPORT for
September 2009

Public Utility Commission of Texas
Project No. 36487

Utility's Project Number	Project Name	Location (City/County)	Description	Estimated (or Actual) Start Date	Finish Date (or Actual Completion)	Date Reviewed (if Applicable)	Initial Estimated Project Cost (\$)	Final Estimated Project Cost (\$)	Final Actual Project Cost (\$)	Spent %	Percent Complete	Existing Voltage (KV)	Upgraded Voltage (KV)	Circuit Length (Miles)	Conductor Type & Size & Bundling	Structure Type(s)	Existing ROW Width (Feet)	Existing ROW Length (Miles)	New ROW Width (Feet)	New ROW Length (Miles)	Rule Section or PUC Control Number	Comments
41154473	Lake Lamond to Greggton 69KV Line Rebuild	Longview, TX	Rebuild 2.66 mi. of 69KV transmission line from SWEPCCO's Lake Lamond Station to the Greggton Station. The existing 755.5 ACSR conductor will be replaced with 1272 ACSR for the entire 2.66 mi. of the line.	10/09/09	03/19/10			\$ 4,047,100				69		2.66 mi	1272 ACSR	Steel	Varies	2.66 mi	Varies		SUB Rule 25.101(c)(9)(B)	ROW is along existing roadway and varies in width

FILED
2009 SEP 24 AM 10:16
FILING CLERK

207