



Control Number: 37855



Item Number: 10

Addendum StartPage: 0

RECEIVED
10 FEB 12 PM 2:51
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2009 Reporting Year

AEP Texas Central Company

Project 37855

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced	1.44	0.06	0.11	0.06	0.13	0.22	0.11	0.12	0.14	0.16	0.12	0.08	0.14
2009													
Scheduled	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.00	0.00	0.00
2009													
Outside Causes	0.22	0.01	0.01	0.01	0.03	0.07	0.00	0.01	0.03	0.01	0.01	0.00	0.02
2009													
Major Events	0.06										0.02		0.04
2009													

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2009	142.5	6.1	11.2	5.9	12.6	22.2	11.9	11.2	13.1	14.4	12.7	7.3	13.9
Scheduled													
2009	3.0	0.5	0.1	0.1	0.1	0.1	0.2	0.1	0.7	0.2	0.5	0.3	0.1
Outside Causes													
2009	9.9	0.4	0.7	0.4	1.8	2.9	0.1	0.9	1.3	0.1	0.3	0.2	0.8
Major Events													
2009	9.9										3.5		6.4

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

722

Add or Delete Rows as Necessary

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
1	21	PALMVIEW	94SB9685	2,741	9.570	
2	683	HARLINGEN S.S.	94SB4230	1,569	9.377	
3	640	COFFEE PORT	94SB1095	965	8.899	
4	14	CARRIZO SPRINGS	94LA370	238	8.445	
5	48	RAYMONDVILLE #2	94SB3250	31	7.742	
6	499	SAN DIEGO	94CS1980	585	7.186	
7	247	BROWNSVILLE	94SB3050	1,947	7.096	
8	439	ALAZAN	94CS620	160	6.475	
9	88	GREENLAKE	94CN2760	559	6.034	
10	220	GANADO	94CN5795	712	5.914	
11	590	NAVAL BASE	94CS6330	366	5.642	
12	59	LOS FRESNOS	94SB4315	1,323	5.602	was 94SB3290
13	649	DARST	94CN790	73	5.562	
14	328	COLUMBUS	94CN6180	1,168	5.547	
15	660	AMISTAD DAM	94LA5450	1,063	5.451	
16	154	ROBSTOWN	94CS1650	371	5.391	
17	185	TATTON	94CN8490	124	5.234	
18	76	MCCOLL ROAD	94SB4400	1,061	5.164	
19	365	CONTINENTAL	94SB4880	62	5.081	
20	121	PHARAOH	94CS1185	1,506	4.920	
21	362	MUSTANG ISLAND	94CS9470	644	4.911	
22	280	KLEBERG	94CS6410	392	4.765	
23	538	CASA BLANCA	94CS55	812	4.619	
24	57	SOUTH MISSION	94SB3980	1,207	4.496	
25	41	LA PRYOR	94LA580	184	4.489	
26	311	PHARAOH	94CS1365	455	4.431	
27	270	STAFFORD HILL	94CN1550	207	4.430	
28	274	CABANISS	94CS80	1,106	4.312	
29	175	CAUSEWAY	94SB4795	1,138	4.295	
30	40	CRYSTAL CITY	94LA330	1,147	4.287	
31	3	CRESTONIO	94LA270	599	4.210	
32	10	FALFURRIAS	94LA5210	1,096	4.172	
33	35	ELSA	94SB710	1,611	4.166	
34	133	SOUTH PADRE ISLAND	94SB6440	2,368	4.138	
35	689	SHARYLAND	94SB2020	2,267	4.091	
36	630	PALMHURST	94SB1300	1,254	4.061	
37	52	SOUTH PADRE ISLAND	94SB5850	1,451	4.057	
38	36	PORT ISABEL S.S.	94SB9295	444	4.016	
39	227	BRUNI	94LA5440	116	3.991	
40	2	GOVERNMENT WELLS	94LA7240	181	3.967	
41	153	RANDADO	94LA8360	150	3.953	
42	622	MATHIS	94CS1420	930	3.795	
43	17	CLARKWOOD	94CS5525	888	3.774	
44	32	PHARR	94SB1625	1,943	3.762	
45	459	GOVERNMENT WELLS	94LA6800	225	3.738	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
46	219	GOLIAD	94CN6540	1,105	3.735	
47	116	FALFURRIAS	94LA1070	846	3.733	
48	51	LA PRYOR	94LA570	125	3.664	
49	74	MUSTANG ISLAND	94CS8510	397	3.655	
50	208	PLEASANTON	94LA9505	1,429	3.655	
51	376	SAN BENITO	94SB4135	1,133	3.635	
52	676	NORTH MCALLEN	94SB2980	1,697	3.609	
53	139	KLEBERG	94CS8140	370	3.597	
54	16	RAYMONDVILLE #2	94SB3170	676	3.515	
55	385	ALAZAN	94CS2740	30	3.433	
56	253	RANGERVILLE	94SB3420	768	3.392	
57	86	SOUTHSIDE	94CS5335	1,129	3.388	
58	9	NIXON	94CN810	490	3.378	
59	189	RAYMONDVILLE #1	94SB620	609	3.356	
60	24	MCKENZIE ROAD	94CS140	261	3.345	
61	380	INGLESIDE CITY	94CS8050	1,742	3.343	
62	92	PORTLAND	94CS9290	1,669	3.329	
63	519	WESLACO UNIT	94SB7455	1,216	3.315	
64	109	EAGLE PASS CITY	94LA2770	2,939	3.286	
65	467	JOURDANTON	94LA250	725	3.263	
66	684	PORTLAND	94CS9370	1,418	3.257	
67	264	SOUTH SANTA ROSA	94SB1240	1,455	3.256	
68	99	MAVERICK	94LA9680	697	3.251	
69	397	MALONE	94CN7550	172	3.238	
70	23	NORTH ALAMO	94SB3610	3,409	3.227	
71	38	GANADO	94CN5815	583	3.214	
72	205	NORTH MERCEDES	94SB4860	1,376	3.196	
73	298	KENEDY	94CN6270	477	3.157	
74	170	HAINE DRIVE	94SB9240	44	3.114	
75	101	FALFURRIAS	94LA2830	1,625	3.073	
76	435	PHARR	94SB1640	984	3.057	
77	98	MATHIS	94CS2870	848	3.048	
78	403	PEARSALL	94LA5580	1,618	3.042	
79	529	GREENLAKE	94CN2740	26	3.038	
80	307	CONTINENTAL	94SB4080	126	3.032	
81	301	BANDERA ELECTRIC (LEAKEY)	94LAL30	267	3.019	
82	423	CLARKWOOD	94CS9570	1,122	3.016	
83	212	TAFT	94CS1260	181	2.961	
84	594	HEARN ROAD	94CS870	1,105	2.928	
85	405	CAMPWOOD	94LA3430	79	2.911	
86	103	EL CAMPO	94CN2800	1,281	2.892	
87	94	HARLINGEN S.S.	94SB4110	1,205	2.890	
88	73	WEST HARLINGEN	94SB3720	2,046	2.886	
89	396	LOS FRESNOS	94SB5335	1,829	2.884	was 94SB930
90	156	CITRUS CITY	94SB3470	2,864	2.880	
91	383	EDROY	94CS6990	266	2.876	
92	441	DARST	94CN800	166	2.873	
93	84	RIO RICO	94SB8330	593	2.850	
94	335	NORTH PADRE ISLAND	94CS1010	1,783	2.840	
95	408	CONTINENTAL	94SB3650	24	2.792	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
96	39	LOS FRESNOS	94SB7270	1,969	2.725	was 94SB3280
97	507	SAN BENITO	94SB3910	1,762	2.715	
98	261	REFUGIO	94CN5120	174	2.701	
99	56	NAVAL BASE	94CS8440	1,526	2.697	
100	378	ASHERTON	94LA2670	144	2.674	
101	25	RODD FIELD	94CS225	785	2.661	part of 94SB3550
102	230	KLEBERG	94CS1560	1,297	2.651	
103	new	VILLA CAVAZOS	94SB1980	1,430	2.644	
104	675	DEVINE	94LA7100	928	2.625	
105	172	KENEDY S.S.	94CN8320	653	2.616	
106	100	NUECES BAY PLANT	94CS350	699	2.604	
107	489	CARRIZO SPRINGS	94LA910	1,828	2.603	
108	22	VICTORIA POWER PLANT	94CN8170	754	2.598	
109	334	LAGUNA	94CS9065	1,925	2.591	
110	560	LEARY LANE	94CN1430	1,572	2.587	
111	516	PALACIOS	94CN6830	810	2.579	
112	60	MOORE FIELD	94SB3960	1,627	2.575	
113	469	SOUTHSIDE	94CS7905	1,811	2.574	
114	68	HEARN ROAD	94CS8990	1,145	2.573	
115	495	PORT LAVACA	94CN8310	312	2.558	
116	234	BLESSING	94CN1030	234	2.551	
117	478	ASHERTON	94LA2660	529	2.546	
118	610	GOODWIN	94SB4380	1,388	2.530	
119	119	SOUTHSIDE	94CS8045	1,018	2.511	
120	250	FULTON	94CS2020	1,766	2.508	
121	642	MAGRUDER	94CN7870	1,269	2.506	
122	168	HARLINGEN	94SB360	2,434	2.492	
123	294	SOUTH EAST EDINBURG	94SB5045	1,767	2.488	
124	616	SOUTHSIDE	94CS7925	1,349	2.486	
125	574	DEVINE	94LA7090	912	2.485	
126	682	EAGLE LAKE	94CN9455	579	2.466	
127	305	HOLLY	94CS1950	795	2.443	
128	585	O. CONNER	94CN390	216	2.440	
129	332	PHARAOH	94CS5185	1,904	2.432	
130	114	HIGHWAY 9	94CS6730	507	2.426	
131	523	KLEBERG	94CS280	1,114	2.425	
132	646	RAYMONDVILLE #2	94SB1280	1,048	2.425	
133	18	RIO BRAVO	94LA1130	849	2.411	
134	598	REFUGIO	94CN1210	208	2.404	
135	539	PLEASANTON	94LA9475	1,300	2.403	
136	198	RODD FIELD	94CS1730	1,973	2.391	
137	522	CAMPWOOD	94LA2610	918	2.390	
138	451	GOVERNMENT WELLS	94LA7250	576	2.389	
139	550	GREGORY	94CS8560	835	2.388	
140	143	UNIVERSITY	94LA950	2,191	2.367	
141	229	SAN BENITO	94SB4030	2,341	2.362	
142	608	ROCKPORT	94CS5930	1,076	2.359	
143	58	CITRUS CITY	94SB9775	1,933	2.359	
144	333	SUNCHASE	94SB1150	1,239	2.353	
145	296	FULTON	94CS440	1,977	2.350	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
146	91	RACHAL	94LA8145	365	2.348	
147	597	POINT COMFORT	94CN2460	340	2.344	
148	196	WEIL TRACT (138/12KV)	94CS5405	148	2.338	
149	583	EDNA	94CN5785	744	2.337	
150	118	BRUNI	94LA1100	635	2.332	
151	149	PLACEDO	94CN7970	461	2.325	
152	324	SOUTH PADRE ISLAND	94SB4695	1,319	2.309	
153	379	COMSTOCK	94LA290	184	2.299	
154	352	PALMVIEW	94SB3930	675	2.284	
155	654	EAGLE LAKE	94CN310	734	2.277	
156	430	PORT ISABEL S.S.	94SB3760	2,041	2.275	
157	49	PORT ISABEL S.S.	94SB4070	292	2.271	
158	123	WESLACO UNIT	94SB8610	2,350	2.261	
159	242	WEST OSO	94CS9090	1,722	2.254	
160	278	BEEVILLE	94CN2200	740	2.253	
161	568	CARANCAHUA	94CN5870	433	2.242	
162	518	FALFURRIAS	94LA1080	430	2.235	
163	65	MCCOLL ROAD	94SB2810	2,243	2.235	
164	673	MORRIS STREET	94CS7465	628	2.221	
165	500	EAST HARRISON	94SB3030	716	2.218	
166	426	STADIUM	94CS7800	649	2.217	
167	388	ARMSTRONG	94CS6050	66	2.212	
168	624	ARCADIA	94CS8570	1,432	2.205	
169	201	GREENLAKE	94CN2750	1,100	2.196	
170	268	REFUGIO	94CN1170	876	2.194	
171	225	BRUNI	94LA5160	144	2.188	
172	131	FREER	94LA6320	155	2.168	
173	360	DEL MAR	94LA490	721	2.160	
174	142	ZAPATA	94LA8300	1,520	2.147	
175	399	MINES ROAD	94LA3680	849	2.144	
176	337	GRETA	94CN7890	298	2.141	
177	190	NUECES BAY PLANT	94CS7830	145	2.138	
178	497	NORTH VICTORIA	94CN7440	1,601	2.132	
179	368	THREE RIVERS	94CN2580	58	2.121	
180	514	WEAVER ROAD	94CN1900	50	2.120	
181	166	CABANISS	94CS75	1,957	2.113	
182	480	RIO RICO	94SB5050	1,601	2.113	
183	164	UVALDE	94LA5060	1,296	2.108	
184	424	MARKHAM	94CN5550	95	2.105	
185	157	BLESSING	94CN8790	729	2.104	
186	300	DEL RIO CITY	94LA1930	918	2.096	
187	79	BEEVILLE	94CN2380	201	2.090	
188	338	WESMER	94SB6900	1,474	2.087	
189	209	KINGSVILLE	94CS1130	2,042	2.073	
190	318	NORTH PADRE ISLAND	94CS720	1,028	2.072	
191	485	NORTH PADRE ISLAND	94CS5170	1,086	2.063	
192	603	RIO GRANDE CITY	94SB3210	1,628	2.052	
193	167	PRAIRIE PUMP	94CN1940	59	2.051	
194	641	MCCOLL ROAD	94SB4910	283	2.049	
195	638	MORRIS STREET	94CS8850	468	2.045	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
196	317	SHARYLAND	94SB2035	2,264	2.039	
197	158	LAREDO HEIGHTS	94LA2100	2,029	2.037	
198	644	EDNA	94CN5765	1,582	2.035	
199	709	SANTO NINO	94LA695	1,482	2.028	
200	246	BANQUETTE	94CS130	230	2.004	
201	375	CRYSTAL CITY	94LA190	957	1.992	
202	216	CARRIZO SPRINGS	94LA860	1,054	1.964	
203	323	ARANSAS PASS	94CS1250	352	1.963	
204	650	CAUSEWAY	94SB4775	1,049	1.959	
205	173	RAYMONDVILLE #1	94SB630	775	1.948	
206	238	HARLINGEN	94SB380	2,287	1.947	
207	93	HIGHWAY 9	94CS6720	1,302	1.945	
208	55	FREER	94LA1500	175	1.931	
209	71	SOUTH SANTA ROSA	94SB1215	1,616	1.929	
210	87	WEST HARLINGEN	94SB3800	1,314	1.925	
211	373	SHARYLAND	94SB2010	972	1.922	
212	453	WADSWORTH	94CN7660	1,281	1.916	
213	1	MOORE FIELD	94SB3120	124	1.911	
214	155	NORTH MERCEDES	94SB3770	1,633	1.909	
215	490	FOSTER FIELD	94CN2550	331	1.897	
216	96	PUEBLO	94LA95	1,919	1.886	
217	42	HALL ACRES ROAD	94SB5585	692	1.877	
218	699	INGLESIDE CITY	94CS2495	56	1.875	
219	427	ARANSAS PASS	94CS8270	611	1.874	
220	554	UVALDE	94LA550	648	1.850	
221	694	SOUTH EAST EDINBURG	94SB4015	415	1.846	
222	347	PALMHURST	94SB2525	1,695	1.844	
223	449	PALMVIEW	94SB6790	2,772	1.815	
224	138	HARLINGEN S.S.	94SB320	1,464	1.804	
225	6	BROWNSVILLE	94SB4290	368	1.791	
226	527	PORTLAND	94CS9270	1,871	1.786	
227	509	MCKENZIE ROAD	94CS330	2,234	1.764	
228	85	UVALDE	94LA480	1,270	1.764	
229	606	INGLESIDE CITY	94CS8060	1,997	1.760	
230	348	THREE RIVERS	94CN8430	167	1.749	
231	447	SAN BENITO	94SB3920	2,275	1.748	
232	47	NORTH WESLACO	94SB4810	1,322	1.741	
233	171	PREMONT	94LA2730	200	1.735	
234	26	CABANISS	94CS240	1,440	1.719	
235	420	KLEBERG	94CS6000	1,477	1.712	
236	202	ALICE	94CS2530	1,429	1.710	
237	471	CAUSEWAY	94SB4765	1,162	1.705	
238	701	CASA BLANCA	94CS5115	286	1.696	
239	15	NORTH PADRE ISLAND	94CS7900	1,770	1.696	
240	128	EAGLE PASS CITY	94LA2650	1,276	1.687	
241	228	MILO	94LA6940	250	1.684	
242	588	WEAVER ROAD	94CN1910	347	1.683	
243	314	WEST MCALLEN	94SB4505	1,722	1.682	
244	214	BROWNSVILLE	94SB4280	227	1.661	
245	176	WEST HARLINGEN	94SB3700	1,683	1.658	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
246	355	MINES ROAD	94LA4275	87	1.655	
247	695	WESLACO UNIT	94SB2195	1,078	1.651	
248	409	WESMER	94SB1850	1,063	1.650	
249	45	BANQUETTE	94CS9000	422	1.649	
250	251	WESLACO UNIT	94SB7630	3,519	1.642	
251	282	WEIL TRACT (138/12KV)	94CS2520	534	1.640	
252	658	OLMITO	94SB715	685	1.626	
253	462	NORTH MCALLEN	94SB5060	2,175	1.614	
254	545	MATHIS	94CS1410	455	1.613	
255	182	PORT ARANSAS	94CS6940	1,575	1.612	
256	252	THREE RIVERS	94CN2010	856	1.611	
257	486	PALACIOS	94CN8550	36	1.611	
258	393	KNIPPA	94LA6365	301	1.608	
259	627	FASHING	94CN8160	38	1.605	
260	284	SOUTH MCALLEN	94SB3850	770	1.605	
261	473	SOUTH MCALLEN	94SB3790	1,846	1.601	
262	521	WOOLRIDGE	94CS1170	1,265	1.596	
263	541	SINTON	94CS6860	1,582	1.595	
264	626	RAYMONDVILLE #2	94SB3240	959	1.582	
265	192	NIXON	94CN5990	568	1.567	
266	542	GOLIAD	94CN8220	1,018	1.556	
267	669	EAGLE PASS CITY	94LA450	670	1.555	
268	369	STADIUM	94CS6950	534	1.552	
269	690	CONOCO-CHITTAM RANCH	94LA8580	31	1.548	
270	316	EAGLE PASS CITY	94LA2745	910	1.547	
271	413	CRESTONIO	94LA260	1,745	1.542	
272	540	CRYSTAL CITY	94LA140	1,200	1.540	
273	273	BISHOP	94CS7180	927	1.538	
274	458	DILLEY	94LA510	510	1.535	
275	233	ROMA	94SB3060	1,489	1.529	
276	487	SOUTHSIDE	94CS8005	745	1.528	
277	406	YORKTOWN	94CN8380	780	1.523	
278	327	BRUNI	94LA1120	142	1.521	
279	195	PORT ARANSAS	94CS990	1,324	1.519	
280	104	HIGHWAY 9	94CS6770	1,150	1.516	
281	564	ELSA	94SB700	1,354	1.516	
282	417	UVALDE	94LA540	1,198	1.515	
283	33	SOUTH SANTA ROSA	94SB1235	630	1.511	
284	122	POLK AVENUE	94SB4600	2,542	1.509	
285	444	BEEVILLE	94CN1760	1,752	1.507	
286	567	PUEBLO	94LA275	2,629	1.506	
287	248	ARANSAS PASS	94CS8280	546	1.505	
288	330	EAGLE LAKE	94CN320	647	1.498	
289	283	LULING - LCRA	94CN10	326	1.491	
290	580	WASHINGTON STREET	94LA2350	2,854	1.487	
291	137	VICTORIA POWER PLANT	94CN8070	606	1.482	
292	50	CASA BLANCA	94CS1300	970	1.479	
293	517	SAN DIEGO	94CS2930	601	1.479	
294	351	RODD FIELD	94CS205	1,510	1.474	
295	342	SEAWALL	94CS9420	815	1.467	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
296	528	KINGSVILLE	94CS1660	1,572	1.463	
297	272	RIO RICO	94SB8290	113	1.460	
298	614	BUENA VISTA	94LA9385	2,033	1.455	
299	197	ALICE	94CS2540	1,106	1.448	
300	629	SOUTH EAST EDINBURG	94SB4550	2,123	1.447	
301	411	STADIUM	94CS7810	1,615	1.446	
302	515	SOUTHSIDE	94CS8025	1,013	1.442	
303	61	PORT ISABEL S.S.	94SB3820	203	1.438	
304	696	ESCONDIDO	94LA2035	2,381	1.435	
305	466	AIRLINE	94CS9030	413	1.433	
306	106	NORTH MCALLEN	94SB5055	2,963	1.430	
307	442	SOUTHSIDE	94CS7995	1,520	1.421	
308	4	GOODWIN	94SB4390	407	1.413	
309	429	NORTH EDINBURG	94SB3810	804	1.403	
310	448	MORRIS STREET	94CS8820	1,231	1.393	
311	498	SUNCHASE	94SB1155	1,383	1.388	
312	148	DILLEY	94LA6400	770	1.387	
313	new	SOUTH SANTA ROSA	94SB7485	984	1.387	
314	5	BEEVILLE	94CN300	1,584	1.385	
315	349	NUECES BAY PLANT	94CS345	52	1.385	
316	44	HIDALGO	94SB4845	1,003	1.384	
317	321	EAST HARRISON	94SB3190	1,411	1.383	
318	512	ANNA STREET	94LA850	1,531	1.371	
319	484	ARCADIA	94CS1460	1,953	1.365	
320	72	NORTH MCALLEN	94SB2750	2,894	1.363	
321	83	FREER	94LA2900	143	1.357	
322	573	SOUTH MCALLEN	94SB3935	1,245	1.357	
323	621	HAINE DRIVE	94SB8065	1,270	1.354	
324	207	CLARKWOOD	94CS7230	560	1.343	
325	66	SANTO NINO	94LA75	1,457	1.341	
326	503	KINGSVILLE	94CS1140	976	1.340	
327	134	KLEBERG	94CS9395	1,319	1.337	
328	241	GEORGE WEST	94CN730	859	1.336	
329	120	MAGRUDER	94CN6700	1,429	1.334	
330	125	ELSA	94SB3520	398	1.322	
331	325	WEST MCALLEN	94SB4965	700	1.321	
332	623	AIRLINE	94CS7280	607	1.316	
333	211	ARCADIA	94CS5020	1,519	1.308	
334	536	WEST MCALLEN	94SB4555	1,459	1.308	
335	54	JOURDANTON	94LA880	277	1.307	
336	304	SOUTH MISSION	94SB3590	662	1.307	
337	29	ROMA	94SB3070	848	1.297	
338	465	WEST OSO	94CS9095	1,461	1.292	
339	174	MILO	94LA8365	2,204	1.291	
340	421	CRESTONIO	94LA6660	724	1.279	
341	697	DEL MAR	94LA10	2,473	1.278	
342	163	SKIDMORE	94CS380	306	1.271	
343	635	KINGSVILLE	94CS1350	361	1.266	
344	187	NORTH EDINBURG	94SB4240	2,049	1.264	
345	628	SAN BENITO	94SB4945	1,738	1.264	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
346	77	SINTON	94CS180	918	1.259	
347	231	EAGLE PASS CITY	94LA7060	815	1.258	
348	70	BONNIEVIEW	94CS8020	510	1.253	
349	279	RACHAL	94LA6595	290	1.252	
350	326	TATTON	94CS950	525	1.246	
351	604	DEL MAR	94LA3440	1,366	1.241	
352	140	PETTUS	94CN8210	350	1.237	
353	105	LA GRULLA	94SB5110	2,209	1.232	
354	361	PREMONT	94LA2720	779	1.231	
355	404	ZAPATA	94LA8290	2,140	1.228	
356	631	AIRLINE	94CS8260	1,485	1.222	
357	418	SOUTH SANTA ROSA	94SB1225	810	1.214	
358	552	PORT LAVACA	94CN2490	1,059	1.212	
359	700	WOOLRIDGE	94CS1120	2,629	1.212	
360	549	LAREDO PLANT	94LA8505	765	1.210	
361	291	PEARSALL	94LA7050	1,286	1.208	
362	476	RODD FIELD	94CS2190	2,882	1.203	
363	434	PALMHURST	94SB2535	1,104	1.201	
364	562	HEARN ROAD	94CS8980	1,147	1.199	
365	169	WEST OSO	94CS9085	742	1.199	
366	712	GARWOOD CITY	94CN2560	189	1.196	
367	366	RODD FIELD	94CS245	2,498	1.182	
368	302	AIRLINE	94CS6970	1,203	1.179	
369	687	SOUTHSIDE	94CS8055	834	1.176	
370	445	HOLLY	94CS1480	1,688	1.175	
371	281	CLARKWOOD	94CS7610	184	1.174	
372	353	WESMER	94SB7760	1,209	1.170	
373	414	LULING - LCRA	94CN20	254	1.169	
374	354	PARKER	94CN9010	18	1.167	
375	438	NORTH ALAMO	94SB4370	2,376	1.167	
376	661	NORTH VICTORIA	94CN2240	784	1.144	
377	12	EAST HARRISON	94SB3950	552	1.138	
378	309	PHARAOH	94CS1285	1,746	1.136	
379	265	STADIUM	94CS8540	1,606	1.135	
380	508	UNIVERSITY	94LA920	440	1.134	
381	110	HIGHWAY 9	94CS7210	304	1.132	
382	180	PLEASANTON	94LA2080	1,483	1.129	
383	705	RODD FIELD	94CS3010	1,759	1.128	
384	666	SOUTH MISSION	94SB4650	965	1.128	
385	108	NORTH EDINBURG	94SB3570	975	1.125	
386	455	WADSWORTH	94CN8630	628	1.123	
387	27	MOORE FIELD	94SB3110	589	1.122	
388	31	SOUTH MCALLEN	94SB3640	282	1.121	
389	179	ALICE	94CS1770	1,521	1.114	
390	217	MATHIS	94CS340	1,472	1.113	
391	256	DEL RIO CITY	94LA9790	2,535	1.112	
392	43	MALONE	94CN7560	101	1.109	
393	667	BUENA VISTA	94LA8965	923	1.109	
394	374	RIO GRANDE CITY	94SB3740	3,364	1.108	
395	236	UVALDE	94LA9770	1,276	1.103	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
396	341	HOLLY	94CS5820	922	1.098	
397	611	HEARN ROAD	94CS9665	547	1.097	
398	357	LAREDO HEIGHTS	94LA9400	1,394	1.088	
399	82	SAN YGNACIO	94LA16060	494	1.087	
400	63	GOODWIN	94SB4625	338	1.080	
401	127	LOS FRESNOS	94SB2160	1,324	1.073	was 94SB3200
402	711	ANNA STREET	94LA5780	722	1.072	
403	367	MILO	94LA5020	1,268	1.065	
404	312	WASHINGTON STREET	94LA7015	1,874	1.055	
405	389	WEST MCALLEN	94SB6385	200	1.055	
406	468	KENEDY	94CN1970	636	1.053	
407	340	LAREDO HEIGHTS	94LA6820	2,067	1.049	
408	535	HAINE DRIVE	94SB9690	822	1.046	
409	548	SABINAL	94LA485	479	1.035	
410	680	CLARKWOOD	94CS7220	362	1.022	
411	460	LA GRULLA	94SB4120	1,250	1.020	
412	488	ODEM	94CS5575	56	1.000	
413	152	PEARSALL	94LA9905	711	1.000	
414	531	MARKHAM	94CN6440	424	0.998	
415	80	RIO BRAVO	94LA300	859	0.981	
416	600	POINT COMFORT	94CN6060	50	0.980	
417	276	DEVINE	94LA8100	1,450	0.958	
418	130	LYTLE	94LA2850	601	0.955	
419	249	CHARLOTTE	94LA8120	194	0.948	
420	589	SOUTH MISSION	94SB3620	1,812	0.943	
421	115	BAY CITY	94CN2700	1,061	0.934	
422	553	FREER	94LA5200	992	0.932	
423	386	PETTUS	94CN1020	372	0.919	
424	450	TATTON	94CS8200	958	0.919	
425	432	BIG WELLS	94LA1570	398	0.917	
426	356	OLMITO	94SB4275	764	0.903	
427	331	FULTON	94CS9050	1,608	0.898	
428	502	AIRLINE	94CS9605	1,246	0.898	
429	579	ARCADIA	94CS1400	428	0.895	
430	377	RIO GRANDE CITY	94SB3220	1,734	0.893	
431	407	DEL MAR	94LA220	809	0.892	
432	570	SAN DIEGO	94CS2890	1,032	0.878	
433	232	BEEVILLE	94CN490	929	0.872	
434	28	HALL ACRES ROAD	94SB5465	1,499	0.869	
435	691	PALMHURST	94SB3890	2,266	0.863	
436	464	UVALDE	94LA6620	2,623	0.859	
437	221	BERCLAIR	94CN990	306	0.856	
438	30	RANGERVILLE	94SB4060	858	0.855	
439	117	BROOKHOLLOW	94CN7580	417	0.842	
440	112	DEL RIO CITY	94LA420	2,284	0.841	
441	652	SOUTH MCALLEN	94SB5065	80	0.825	
442	75	SOUTH EAST EDINBURG	94SB4570	1,319	0.818	
443	454	RIO GRANDE CITY	94SB3230	1,057	0.816	
444	663	KNIPPA	94LA6535	21	0.810	
445	222	NORDHEIM	94CN470	235	0.809	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
446	89	SANTO NINO	94LA70	1,050	0.807	
447	428	NORTH VICTORIA	94CN7770	805	0.800	
448	470	SEAWALL	94CS9325	1,406	0.799	
449	259	PHARAOH	94CS5175	976	0.796	
450	64	CHARLOTTE	94LA2780	506	0.783	
451	384	LOLITA	94CN6330	26	0.769	
452	381	EAST HARRISON	94SB4360	1,683	0.768	
453	372	NORTH EDINBURG	94SB560	1,501	0.766	
454	113	WESMER	94SB9705	1,032	0.766	
455	395	RANDADO	94LA8350	123	0.764	
456	165	WEST MCALLEN	94SB4535	2,763	0.755	
457	178	ELSA	94SB3500	1,101	0.754	
458	605	GREGORY	94CS5920	500	0.750	
459	254	WEST HARLINGEN	94SB4870	536	0.744	
460	359	PORT ARANSAS	94CS1000	1,335	0.738	
461	129	RANGERVILLE	94SB3410	789	0.736	
462	678	SINTON	94CS1750	496	0.728	
463	586	PALMVIEW	94SB9680	1,298	0.727	
464	472	LIVE OAK	94CS1080	784	0.724	
465	346	HAINE DRIVE	94SB270	735	0.714	
466	144	VICTORIA POWER PLANT	94CN7600	158	0.703	
467	431	SKIDMORE	94CS600	350	0.700	
468	506	PALACIOS	94CN6840	1,514	0.699	
469	437	GATEWAY	94LA390	798	0.699	
470	193	LIVE OAK	94CS1070	2,750	0.695	
471	new	LA GRULLA	94SB6150	1,065	0.695	
472	526	THREE RIVERS	94CN5190	788	0.687	
473	271	HAMILTON ROAD	94LA9665	933	0.686	
474	398	RAYMONDVILLE #2	94SB4160	322	0.686	
475	474	GARCENO	94SB2130	3,210	0.677	
476	97	PREMONT	94LA6610	802	0.673	
477	315	PHARR	94SB1645	2,505	0.672	
478	184	SOUTHSIDE	94CS7955	1,058	0.669	
479	664	SIERRA VISTA	94LA7360	2,442	0.663	
480	457	TAFT	94CS5230	811	0.660	
481	206	MATTHEWS	94CN1740	159	0.654	
482	520	WESLACO UNIT	94SB9805	2,787	0.654	
483	new	VILLA CAVAZOS	94SB7615	913	0.653	part of 94SB3550
484	285	COTULLA	94LA110	1,194	0.652	
485	11	GREGORY	94CS5900	108	0.648	
486	461	FULTON	94CS6070	2,953	0.641	
487	607	COLUMBUS	94CN9060	373	0.638	
488	511	WESLACO UNIT	94SB5970	2,815	0.636	
489	188	HIGHWAY 9	94CS6760	603	0.633	
490	223	COLUMBUS	94CN930	897	0.629	
491	401	GOODWIN	94SB3530	1,304	0.623	
492	210	ELSA	94SB690	2,087	0.623	
493	534	AIRLINE	94CS8370	300	0.610	
494	194	ARANSAS PASS	94CS9130	317	0.609	
495	504	DEL RIO CITY	94LA430	2,462	0.605	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
496	313	EAST HARRISON	94SB4310	1,144	0.584	
497	419	NIXON	94CN2620	548	0.580	
498	651	LAREDO PLANT	94LA8745	715	0.580	
499	482	INGLESIDE CITY	94CS6040	259	0.579	
500	643	PUEBLO	94LA130	1,224	0.577	
501	530	CITRUS CITY	94SB7985	1,505	0.577	
502	203	HALL ACRES ROAD	94SB4895	788	0.576	
503	685	PLACEDO	94CN7980	396	0.568	
504	81	ODEM	94CS375	991	0.564	
505	501	BEEVILLE	94CN8090	1,220	0.557	
506	382	KINGSVILLE	94CS1670	423	0.553	
507	494	MAGRUDER	94CN7690	570	0.551	
508	146	LIVE OAK	94CS1090	244	0.537	
509	53	HARLINGEN	94SB660	1,884	0.536	
510	593	NORTH VICTORIA	94CN7430	1,671	0.531	
511	286	ENCINAL	94LA2160	765	0.527	
512	587	BROOKHOLLOW	94CN8960	548	0.524	
513	200	WESMER	94SB4050	1,887	0.524	
514	492	HIGHWAY 9	94CS6780	793	0.523	
515	483	MORRIS STREET	94CS8715	1,568	0.518	
516	159	NORTH MCALLEN	94SB9660	1,985	0.516	
517	215	ARCADIA	94CS1360	1,508	0.515	
518	306	PALMVIEW	94SB7595	2,589	0.513	
519	275	PALMHURST	94SB2530	1,778	0.512	
520	556	NORTH VICTORIA	94CN1580	1,029	0.506	
521	558	PORTLAND	94CS6505	1,607	0.499	
522	686	BROOKHOLLOW	94CN8950	854	0.494	
523	601	LAREDO PLANT	94LA8695	969	0.489	
524	704	SIERRA VISTA	94LA9900	2,083	0.487	
525	402	REFUGIO	94CN1040	727	0.480	
526	479	SOUTHSIDE	94CS8035	1,076	0.480	
527	141	BLESSING	94CN8780	65	0.477	
528	111	MCKENZIE ROAD	94CS150	21	0.476	
529	671	HEARN ROAD	94CS2220	1,519	0.475	
530	151	NORTH ALAMO	94SB3580	1,848	0.475	
531	618	EL CAMPO	94CN2860	558	0.468	
532	363	LEARY LANE	94CN6005	2,039	0.467	
533	226	GEORGE WEST	94CN1320	641	0.465	
534	160	LEARY LANE	94CN7530	1,882	0.464	
535	577	HALL ACRES ROAD	94SB3460	3,463	0.463	
536	632	BIG WELLS	94LA2630	26	0.462	
537	150	BROOKHOLLOW	94CN7190	260	0.458	
538	181	LAGUNA	94CS9590	2,047	0.457	
539	67	SANTO NINO	94LA80	2,312	0.457	
540	370	MAGRUDER	94CN245	1,084	0.456	
541	107	TAFT	94CS1180	1,049	0.456	
542	456	MORRIS STREET	94CS2515	1,091	0.453	
543	578	SAN BENITO	94SB3860	243	0.453	
544	557	WESLACO UNIT	94SB8195	1,689	0.451	
545	537	LAREDO HEIGHTS	94LA2450	2,442	0.445	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
546	496	CHASE FIELD	94CN460	16	0.438	
547	224	NAVAL BASE	94CS1380	2,118	0.437	
548	364	WOODSBORO	94CS8330	1,064	0.436	
549	491	MAGRUDER	94CN6680	685	0.435	
550	19	RIO BRAVO	94LA5	660	0.433	
551	698	RAYMONDVILLE #1	94SB3130	273	0.429	
552	267	SAN DIEGO	94CS2880	1,186	0.423	
553	634	LEARY LANE	94CN6175	1,452	0.414	
554	293	NORTH WESLACO	94SB4830	483	0.406	
555	620	DEL RIO CITY	94LA9850	909	0.402	
556	532	BAY CITY	94CN5960	1,849	0.401	
557	237	MINES ROAD	94LA3745	1,391	0.393	
558	391	HARLINGEN S.S.	94SB4090	2,224	0.393	
559	245	PREMONT	94LA6570	712	0.392	
560	394	SINTON	94CS360	289	0.391	
561	547	PORT LAVACA	94CN2480	1,507	0.390	
562	90	PORT ARANSAS	94CS3030	798	0.390	
563	559	RUNGE	94CN7320	578	0.389	
564	637	EL CAMPO	94CN6370	704	0.388	
565	213	BAY CITY	94CN6670	1,751	0.385	
566	177	NORTH MERCEDES	94SB3840	635	0.380	
567	670	GOODWIN	94SB7380	2,094	0.369	
568	257	EL CAMPO	94CN5745	868	0.363	
569	46	JOURDANTON	94LA5695	1,249	0.360	
570	34	EDROY	94CS6980	193	0.358	
571	183	YORKTOWN	94CN8420	998	0.352	
572	235	STADIUM	94CS7490	1,224	0.350	
573	544	POLK AVENUE	94SB4900	2,525	0.350	
574	344	THOMASTON	94CN9580	43	0.349	
575	569	COTULLA	94LA90	691	0.346	
576	648	WESMER	94SB4480	1,071	0.346	
577	602	ALICE	94CS1790	337	0.341	
578	543	ANNA STREET	94LA900	2,790	0.338	
579	147	HIDALGO	94SB3680	316	0.335	
580	524	ARCADIA	94CS1440	1,589	0.332	
581	566	HOLLY	94CS1370	1,864	0.331	
582	191	BEEVILLE	94CN8510	852	0.329	
583	288	BISHOP	94CS2690	553	0.329	
584	258	MAGRUDER	94CN6690	545	0.323	
585	37	CHARLOTTE	94LA2790	96	0.323	
586	525	COFFEE PORT	94SB1090	1,133	0.319	
587	693	HARLINGEN	94SB370	1,156	0.319	
588	625	ANNA STREET	94LA2250	1,537	0.318	
589	510	EAST HARRISON	94SB3080	356	0.312	
590	308	KENEDY S.S.	94CN8340	877	0.308	
591	668	SOUTH MISSION	94SB3940	765	0.305	
592	8	VILLA CAVAZOS	94SB5680	1,650	0.305	was 94SB3560
593	new	MCCOLL ROAD	94SB1655	1,119	0.302	
594	289	HOLLY	94CS1220	3,295	0.294	
595	717	OLMITO	94SB905	1,412	0.294	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
596	565	ESCONDIDO	94LA1510	686	0.293	
597	319	KENEDY S.S.	94CN6750	759	0.291	
598	392	WASHINGTON STREET	94LA6525	2,008	0.291	
599	636	SOUTH MISSION	94SB5215	1,218	0.291	
600	576	HAMILTON ROAD	94LA9655	1,163	0.290	
601	599	MORRIS STREET	94CS8830	1,512	0.289	
602	371	HOLLY	94CS7740	1,968	0.286	
603	688	DEL MAR	94LA7930	1,202	0.286	
604	329	MCCOLL ROAD	94SB4780	2,102	0.284	
605	239	EL CAMPO	94CN7710	1,056	0.280	
606	95	POLK AVENUE	94SB4610	1,290	0.277	
607	596	ODEM	94CS385	378	0.275	
608	639	AIRLINE	94CS8890	520	0.275	
609	481	LAREDO HEIGHTS	94LA6810	2,001	0.273	
610	581	BAY CITY	94CN2050	506	0.269	
611	475	LEARY LANE	94CN1890	1,568	0.260	
612	505	SHARYLAND	94SB6745	1,782	0.255	
613	240	NORTH MCALLEN	94SB4995	1,854	0.251	
614	320	HOLLY	94CS9675	1,745	0.250	
615	400	LEARY LANE	94CN1540	776	0.249	
616	612	BAY CITY	94CN7480	1,918	0.249	
617	713	LAREDO PLANT	94LA8705	206	0.248	
618	707	LAREDO PLANT	94LA8565	1,166	0.247	
619	463	ARCADIA	94CS6930	1,498	0.246	
620	310	LA PRYOR	94LA2440	639	0.243	
621	269	RAYMONDVILLE #1	94SB800	674	0.243	
622	440	EAST HARRISON	94SB4620	752	0.242	
623	62	HALL ACRES ROAD	94SB8870	3,652	0.242	
624	336	WEIL TRACT (138/12KV)	94CS1990	1,251	0.241	
625	303	PLEASANTON	94LA120	1,171	0.241	
626	7	GARCENO	94SB2135	1,717	0.236	
627	290	BAY CITY	94CN1110	1,291	0.235	
628	390	ARCADIA	94CS5030	1,550	0.232	
629	533	DEL RIO CITY	94LA440	831	0.227	
630	299	HAMILTON ROAD	94LA9645	286	0.224	
631	563	LAREDO PLANT	94LA9305	942	0.223	
632	124	HOLLY	94CS7620	2,297	0.220	
633	266	PORT LAVACA	94CN6850	594	0.219	
634	218	POLK AVENUE	94SB4170	1,669	0.217	
635	452	ROCKPORT	94CS5950	540	0.207	
636	263	GATEWAY	94LA350	1,282	0.202	
637	551	ARANSAS PASS	94CS590	400	0.200	
638	681	POLK AVENUE	94SB4520	866	0.199	
639	446	ARCADIA	94CS1450	1,863	0.198	
640	653	SHARYLAND	94SB5635	1,862	0.196	
641	292	ALICE	94CS1780	266	0.192	
642	243	JOURDANTON	94LA5685	529	0.191	
643	244	ROCKSPRINGS	94LA8040	324	0.191	
644	255	HAINE DRIVE	94SB9700	764	0.190	
645	425	BUENA VISTA	94LA9035	1,479	0.187	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
646	345	WASHINGTON STREET	94LA2360	665	0.182	
647	493	PALMHURST	94SB2820	1,796	0.178	
648	477	PARKER	94CN9260	94	0.170	
649	277	MORRIS STREET	94CS5655	1,003	0.170	
650	13	ZAPATA	94LA7330	1,271	0.169	
651	339	NORTH VICTORIA	94CN7860	1,431	0.164	
652	358	SEAWALL	94CS9450	281	0.164	
653	433	LA GRULLA	94SB5005	959	0.157	
654	260	VICTORIA POWER PLANT	94CN1390	1,128	0.154	
655	609	SABINAL	94LA200	405	0.151	
656	287	ZACATE CREEK	94LA2665	1,613	0.151	
657	new	SHARYLAND	94SB5105	1,448	0.150	
658	387	HAINE DRIVE	94SB3490	985	0.146	
659	126	HIGHWAY 9	94CS7200	558	0.143	
660	645	GATEWAY	94LA3595	1,489	0.142	
661	161	MCCOLL ROAD	94SB4790	1,866	0.140	
662	677	AIRLINE	94CS9390	1,412	0.139	
663	561	BAY CITY	94CN6450	958	0.138	
664	262	MORRIS STREET	94CS7625	558	0.136	
665	546	LAREDO HEIGHTS	94LA9080	667	0.135	
666	343	MILO	94LA3065	179	0.128	
667	617	WOOLRIDGE	94CS1110	1,381	0.127	
668	78	HIDALGO	94SB3400	843	0.125	
669	410	SOUTH EAST EDINBURG	94SB6580	1,300	0.125	
670	615	ARANSAS PASS	94CS650	740	0.122	
671	204	PHARR	94SB1620	2,622	0.122	
672	555	FULTON	94CS3070	1,559	0.121	
673	592	POLK AVENUE	94SB4180	1,142	0.120	
674	186	HIGHWAY 9	94CS9830	135	0.119	
675	295	EL CAMPO	94CN7260	524	0.118	
676	657	ANNA STREET	94LA780	455	0.116	
677	674	THREE RIVERS	94CN5100	35	0.114	
678	584	MORRIS STREET	94CS8840	586	0.111	
679	132	MILO	94LA3070	3,057	0.110	
680	582	WEST MCALLEN	94SB4815	708	0.109	
681	422	WEST MCALLEN	94SB4515	788	0.107	
682	199	WEST MCALLEN	94SB4595	1,132	0.107	
683	715	ESCONDIDO	94LA3350	889	0.105	
684	656	NORTH VICTORIA	94CN6390	1,311	0.100	
685	591	POLK AVENUE	94SB4190	1,666	0.098	
686	595	GATEWAY	94LA5055	1,856	0.095	
687	135	NORTH MCALLEN	94SB3830	1,279	0.091	
688	571	EDNA	94CN5775	487	0.084	
689	655	WASHINGTON STREET	94LA6355	1,057	0.078	
690	572	ZACATE CREEK	94LA2675	1,111	0.077	
691	633	EAST HARRISON	94SB3000	534	0.077	
692	136	POLK AVENUE	94SB4740	1,772	0.077	
693	619	AIRLINE	94CS5870	852	0.069	
694	613	BRACKETTVILLE	94LA8460	1,156	0.069	
695	692	SHARYLAND	94SB2150	1,064	0.069	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIFI Ranking	2008 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIFI Value	Notes
696	575	NORTH VICTORIA	94CN1470	433	0.067	
697	702	ARANSAS PASS	94CS660	721	0.065	
698	412	SANTO NINO	94LA515	1,881	0.065	
699	162	SANTO NINO	94LA645	844	0.063	
700	350	EAGLE PASS CITY	94LA2510	634	0.060	
701	659	LAREDO HEIGHTS	94LA2390	721	0.058	
702	710	ASPHALT MINES	94LA500	35	0.057	
703	297	NORTH MCALLEN	94SB9640	1,411	0.054	
704	416	KENEDY	94CN1960	59	0.051	
705	706	ZACATE CREEK	94LA2635	248	0.048	
706	647	GARWOOD CITY	94CN2570	128	0.047	
707	679	SOUTHSIDE	94CS5345	397	0.045	
708	20	ZAPATA	94LA2710	46	0.043	
709	662	ROCKPORT	94CS5940	58	0.034	
710	436	AIRLINE	94CS7390	1,039	0.028	
711	415	HALL ACRES ROAD	94SB3670	842	0.024	
712	513	UNIVERSITY	94LA930	708	0.020	
713	672	HALL ACRES ROAD	94SB9595	1,029	0.018	
714	665	SIERRA VISTA	94LA3540	319	0.016	
715	102	ROCKSPRINGS	94LA2600	366	0.014	
716	708	WASHINGTON STREET	94LA2470	187	0.005	
717	322	AIRLINE	94CS7270	995	0.002	
718	145	VICTORIA POWER PLANT	94CNNETVIC	78	-	
719	703	GREGORY	94CS420	23	-	
720	714	MORRIS STREET	94CSNET CC	339	-	
721	443	MILO	94LA3060	105	-	
722	716	WASHINGTON STREET	94LANETLAR	359	-	

Feeders from last year that are not in this year's list

2008 SAIFI Ranking	Substation Identification	Feeder Identification	Reason not in 2009
8	CAVAZOS	94SB3560	now 94SB5680
39	LOS FRESNOS	94SB3280	now 94SB7270
59	LOS FRESNOS	94SB3290	now 94SB4315
69	CAVAZOS	94SB3550	split into 94SB1980 and 94SB7615
127	LOS FRESNOS	94SB3200	now 94SB2160
396	LOS FRESNOS	94SB930	now 94SB5335

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

722

Add or Delete Rows as Necessary

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
1	226	CONTINENTAL	94SB4880	62	1,663.8	
2	19	RAYMONDVILLE #2	94SB3250	31	1,450.2	
3	611	COFFEE PORT	94SB1095	965	1,269.6	
4	206	TATTON	94CN8490	124	1,199.7	
5	238	ALAZAN	94CS620	160	1,184.8	
6	42	CONTINENTAL	94SB4080	126	917.4	
7	131	BROWNSVILLE	94SB3050	1,947	887.7	
8	231	GOVERNMENT WELLS	94LA6800	225	868.9	
9	5	CARRIZO SPRINGS	94LA370	238	797.8	
10	339	MUSTANG ISLAND	94CS9470	644	792.1	
11	36	RANDADO	94LA8360	150	788.1	
12	64	GREENLAKE	94CN2760	559	765.1	
13	29	ELSA	94SB710	1,611	751.8	
14	1	MOORE FIELD	94SB3120	124	745.7	
15	296	CONTINENTAL	94SB3650	24	740.1	
16	22	LA PRYOR	94LA570	125	718.1	
17	192	ALAZAN	94CS2740	30	710.5	
18	116	CAMPWOOD	94LA3430	79	690.2	
19	18	CLARKWOOD	94CS5525	888	671.2	
20	6	NIXON	94CN810	490	625.3	
21	344	MALONE	94CN7550	172	623.5	
22	382	SAN DIEGO	94CS1980	585	610.1	
23	11	PALMVIEW	94SB9685	2,741	609.7	
24	650	DARST	94CN790	73	599.9	
25	666	HARLINGEN S.S.	94SB4230	1,569	597.3	
26	178	MINES ROAD	94LA3680	849	581.2	
27	3	CRESTONIO	94LA270	599	570.1	
28	585	NORTH PADRE ISLAND	94CS1010	1,783	567.9	
29	263	SOUTH PADRE ISLAND	94SB6440	2,368	564.8	
30	411	ASHERTON	94LA2670	144	557.1	
31	12	FALFURRIAS	94LA5210	1,096	554.5	
32	54	CRYSTAL CITY	94LA330	1,147	543.0	
33	60	MUSTANG ISLAND	94CS8510	397	541.2	
34	153	MAVERICK	94LA9680	697	527.9	
35	28	MCKENZIE ROAD	94CS140	261	527.1	
36	156	BANDERA ELECTRIC (LEAKEY)	94LAL30	267	524.8	
37	313	GANADO	94CN5795	712	517.3	
38	599	NORTH MCALLEN	94SB2980	1,697	508.9	
39	167	GANADO	94CN5815	583	505.6	
40	477	NAVAL BASE	94CS6330	366	498.5	
41	350	KLEBERG	94CS8140	370	498.1	
42	372	PALMVIEW	94SB3930	675	497.9	
43	76	SOUTH MISSION	94SB3980	1,207	497.6	
44	113	CITRUS CITY	94SB9775	1,933	478.8	
45	69	BRUNI	94LA5440	116	474.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
46	9	HAINE DRIVE	94SB9240	44	468.6	
47	15	NORTH PADRE ISLAND	94CS7900	1,770	462.1	
48	558	CAUSEWAY	94SB4775	1,049	461.9	
49	4	RAYMONDVILLE #2	94SB3170	676	455.0	
50	377	TAFT	94CS1260	181	445.9	
51	539	NORTH PADRE ISLAND	94CS720	1,028	443.6	
52	134	ROBSTOWN	94CS1650	371	435.3	
53	147	CITRUS CITY	94SB3470	2,864	432.6	
54	673	AMISTAD DAM	94LA5450	1,063	430.6	
55	144	WEST HARLINGEN	94SB3700	1,683	425.7	
56	293	SKIDMORE	94CS380	306	425.4	
57	23	LOS FRESNOS	94SB4315	1,323	425.2	was 94SB3290
58	130	FALFURRIAS	94LA2830	1,625	415.7	
59	57	NUECES BAY PLANT	94CS350	699	410.2	
60	419	SOUTH SANTA ROSA	94SB1240	1,455	404.0	
61	13	LA PRYOR	94LA580	184	400.6	
62	446	KLEBERG	94CS6410	392	397.6	
63	27	ARMSTRONG	94CS6050	66	395.5	
64	78	CAUSEWAY	94SB4795	1,138	393.6	
65	688	SHARYLAND	94SB2020	2,267	386.9	
66	458	LAGUNA	94CS9065	1,925	373.8	
67	689	MATHIS	94CS1420	930	371.1	
68	135	BRUNI	94LA5160	144	369.4	
69	239	GOVERNMENT WELLS	94LA7250	576	366.4	
70	43	NUECES BAY PLANT	94CS7830	145	361.7	
71	149	MCCOLL ROAD	94SB4400	1,061	358.8	
72	158	STAFFORD HILL	94CN1550	207	356.1	
73	79	BRUNI	94LA1120	142	353.2	
74	329	NORTH MERCEDES	94SB4860	1,376	350.9	
75	455	GREENLAKE	94CN2740	26	350.9	
76	287	GOLIAD	94CN6540	1,105	346.1	
77	503	CASA BLANCA	94CS55	812	345.4	
78	421	DARST	94CN800	166	345.0	
79	450	COLUMBUS	94CN6180	1,168	342.5	
80	10	FREER	94LA1500	175	339.1	
81	109	PREMONT	94LA2730	200	337.4	
82	375	ARANSAS PASS	94CS1250	352	330.9	
83	121	SOUTHSIDE	94CS5335	1,129	328.2	
84	2	GOVERNMENT WELLS	94LA7240	181	323.5	
85	207	KENEDY S.S.	94CN8320	653	322.4	
86	129	PRAIRIE PUMP	94CN1940	59	322.2	
87	197	CRYSTAL CITY	94LA190	957	320.7	
88	91	NAVAL BASE	94CS8440	1,526	317.1	
89	137	PHARAOH	94CS1185	1,506	317.0	
90	170	RANGERVILLE	94SB3420	768	315.4	
91	336	CABANISS	94CS80	1,106	314.2	
92	201	RAYMONDVILLE #1	94SB620	609	312.9	
93	434	NORTH PADRE ISLAND	94CS5170	1,086	306.6	
94	614	PALMHURST	94SB1300	1,254	304.3	
95	260	REFUGIO	94CN5120	174	298.3	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
96	332	CABANISS	94CS75	1,957	296.3	
97	569	CAMPWOOD	94LA2610	918	296.3	
98	new	VILLA CAVAZOS	94SB1980	1,430	293.9	part of 94SB3550
99	376	EDROY	94CS6990	266	293.1	
100	35	PHARR	94SB1625	1,943	291.4	
101	138	BRUNI	94LA1100	635	290.6	
102	330	LOS FRESNOS	94SB5335	1,829	289.3	was 94SB930
103	363	PREMONT	94LA2720	779	288.2	
104	188	SOUTH PADRE ISLAND	94SB5850	1,451	286.8	
105	7	EAST HARRISON	94SB3950	552	286.3	
106	500	NORTH VICTORIA	94CN7440	1,601	282.0	
107	630	DEVINE	94LA7090	912	281.6	
108	232	MARKHAM	94CN5550	95	279.2	
109	342	LA GRULLA	94SB4120	1,250	279.1	
110	98	WEST HARLINGEN	94SB3800	1,314	277.9	
111	636	MORRIS STREET	94CS8850	468	276.9	
112	459	WEST MCALLEN	94SB4965	700	276.3	
113	215	HARLINGEN	94SB360	2,434	276.2	
114	56	RODD FIELD	94CS225	785	275.2	
115	696	PORTLAND	94CS9370	1,418	273.9	
116	407	PALMVIEW	94SB9680	1,298	273.6	
117	148	GREENLAKE	94CN2750	1,100	273.5	
118	136	SOUTH EAST EDINBURG	94SB5045	1,767	272.3	
119	478	FALFURRIAS	94LA1080	430	271.4	
120	324	SAN BENITO	94SB4135	1,133	271.3	
121	189	PLACEDO	94CN7970	461	271.2	
122	165	PORTLAND	94CS9290	1,669	269.6	
123	397	LULING - LCRA	94CN10	326	269.4	
124	541	SAN BENITO	94SB3910	1,762	269.1	
125	385	CLARKWOOD	94CS9570	1,122	268.9	
126	24	RIO BRAVO	94LA1130	849	267.7	
127	271	BLESSING	94CN1030	234	266.4	
128	518	WESMER	94SB1850	1,063	266.1	
129	63	ELSA	94SB3520	398	264.6	
130	173	RIO RICO	94SB8290	113	264.4	
131	44	WEST HARLINGEN	94SB3720	2,046	263.8	
132	186	KLEBERG	94CS1560	1,297	263.4	
133	151	RAYMONDVILLE #1	94SB630	775	262.8	
134	253	GRETA	94CN7890	298	261.6	
135	601	RAYMONDVILLE #2	94SB1280	1,048	261.6	
136	284	FALFURRIAS	94LA1070	846	261.2	
137	437	PALACIOS	94CN6830	810	260.2	
138	413	ASHERTON	94LA2660	529	260.0	
139	40	CASA BLANCA	94CS1300	970	260.0	
140	679	CONOCO-CHITTAM RANCH	94LA8580	31	259.0	
141	140	HEARN ROAD	94CS8990	1,145	257.0	
142	620	SOUTHSIDE	94CS7925	1,349	256.6	
143	390	KLEBERG	94CS280	1,114	254.6	
144	448	PORT LAVACA	94CN8310	312	254.1	
145	68	RIO RICO	94SB8330	593	254.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
146	233	SOUTHSIDE	94CS7905	1,811	249.6	
147	26	BROWNSVILLE	94SB4290	368	247.9	
148	93	HALL ACRES ROAD	94SB5585	692	247.6	
149	677	MAGRUDER	94CN7870	1,269	245.0	
150	244	PHARAOH	94CS5185	1,904	242.7	
151	247	SAN BENITO	94SB4030	2,341	238.6	
152	527	WESLACO UNIT	94SB7455	1,216	233.9	
153	31	PORT ISABEL S.S.	94SB9295	444	233.4	
154	234	BLESSING	94CN8790	729	232.5	
155	114	SOUTHSIDE	94CS8045	1,018	232.1	
156	323	THREE RIVERS	94CN2580	58	231.1	
157	184	BROWNSVILLE	94SB4280	227	229.8	
158	220	HARLINGEN S.S.	94SB4110	1,205	228.1	
159	624	REFUGIO	94CN1210	208	227.9	
160	257	COMSTOCK	94LA290	184	227.9	
161	119	LOS FRESNOS	94SB7270	1,969	227.1	was 94SB3280
162	447	RIO GRANDE CITY	94SB3740	3,364	224.9	
163	408	UVALDE	94LA9770	1,276	224.5	
164	484	SOUTHSIDE	94CS8025	1,013	224.0	
165	355	DEL MAR	94LA490	721	222.3	
166	692	DEVINE	94LA7100	928	221.9	
167	17	PORT ISABEL S.S.	94SB4070	292	221.8	
168	530	PHARR	94SB1640	984	221.1	
169	423	JOULDANTON	94LA250	725	219.0	
170	463	PALMHURST	94SB2535	1,104	218.4	
171	128	WEST OSO	94CS9090	1,722	215.6	
172	654	EAGLE LAKE	94CN9455	579	215.3	
173	216	DILLEY	94LA6400	770	215.1	
174	576	GREGORY	94CS8560	835	215.1	
175	427	INGLESIDE CITY	94CS8050	1,742	214.7	
176	386	PORT ISABEL S.S.	94SB3760	2,041	211.2	
177	514	RODD FIELD	94CS205	1,510	210.7	
178	190	NORTH MCALLEN	94SB5055	2,963	210.7	
179	394	MORRIS STREET	94CS8820	1,231	210.0	
180	152	PHARAOH	94CS1365	455	209.0	
181	665	EDNA	94CN5765	1,582	208.7	
182	16	MALONE	94CN7560	101	208.4	
183	444	EAGLE PASS CITY	94LA2745	910	208.2	
184	246	PALMHURST	94SB2525	1,695	207.7	
185	150	HIGHWAY 9	94CS6720	1,302	206.9	
186	39	FREER	94LA2900	143	205.7	
187	440	CAUSEWAY	94SB4765	1,162	204.9	
188	84	BANQUETTE	94CS130	230	204.8	
189	67	ELSA	94SB3500	1,101	204.1	
190	702	CASA BLANCA	94CS5115	286	203.6	
191	241	RODD FIELD	94CS1730	1,973	203.3	
192	94	MOORE FIELD	94SB3960	1,627	202.6	
193	181	MATHIS	94CS2870	848	202.1	
194	21	VICTORIA POWER PLANT	94CN8170	754	202.0	
195	245	WESLACO UNIT	94SB8610	2,350	199.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
196	535	MCCOLL ROAD	94SB4910	283	199.1	
197	412	KNIPPA	94LA6365	301	198.7	
198	700	WESLACO UNIT	94SB2195	1,078	197.8	
199	596	GOODWIN	94SB4380	1,388	197.6	
200	645	SAN BENITO	94SB4945	1,738	196.3	
201	120	EAGLE PASS CITY	94LA2770	2,939	195.4	
202	277	CARANCAHUA	94CN5870	433	194.4	
203	422	WADSWORTH	94CN7660	1,281	194.3	
204	371	CARRIZO SPRINGS	94LA910	1,828	193.2	
205	495	RIO GRANDE CITY	94SB3210	1,628	190.2	
206	616	HEARN ROAD	94CS870	1,105	190.0	
207	424	SEAWALL	94CS9420	815	189.2	
208	125	NORTH WESLACO	94SB4810	1,322	188.8	
209	612	POINT COMFORT	94CN2460	340	188.6	
210	145	PORT ARANSAS	94CS6940	1,575	188.4	
211	512	WOOLRIDGE	94CS1170	1,265	187.6	
212	584	KENEDY	94CN6270	477	187.1	
213	108	PETTUS	94CN8210	350	186.7	
214	302	NIXON	94CN5990	568	185.9	
215	555	RAYMONDVILLE #2	94SB3240	959	184.4	
216	46	MOORE FIELD	94SB3110	589	181.6	
217	259	ALICE	94CS2540	1,106	181.1	
218	58	BANQUETTE	94CS9000	422	181.0	
219	623	FASHING	94CN8160	38	180.9	
220	204	EL CAMPO	94CN2800	1,281	180.1	
221	538	WEAVER ROAD	94CN1900	50	178.8	
222	627	INGLESIDE CITY	94CS8060	1,997	178.7	
223	106	HARLINGEN S.S.	94SB320	1,464	176.6	
224	75	PUEBLO	94LA95	1,919	175.1	
225	142	BISHOP	94CS7180	927	174.6	
226	493	ELSA	94SB700	1,354	173.7	
227	297	WASHINGTON STREET	94LA7015	1,874	171.5	
228	124	FREER	94LA6320	155	171.5	
229	72	NORTH ALAMO	94SB3610	3,409	170.3	
230	638	HAINE DRIVE	94SB9690	822	169.2	
231	533	SINTON	94CS6860	1,582	168.3	
232	209	NORTH MERCEDES	94SB3770	1,633	168.0	
233	618	EAGLE LAKE	94CN310	734	167.4	
234	127	NORTH EDINBURG	94SB3570	975	166.2	
235	62	ROMA	94SB3070	848	166.2	
236	180	SOUTH SANTA ROSA	94SB1215	1,616	164.9	
237	357	ALICE	94CS2530	1,429	164.9	
238	299	SOUTHSIDE	94CS7995	1,520	164.6	
239	613	RODD FIELD	94CS245	2,498	164.5	
240	515	REFUGIO	94CN1170	876	163.3	
241	625	EDNA	94CN5785	744	163.2	
242	655	OLMITO	94SB715	685	162.7	
243	632	AIRLINE	94CS8260	1,485	162.5	
244	653	EAGLE PASS CITY	94LA450	670	162.5	
245	506	PEARSALL	94LA5580	1,618	162.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
246	559	WEAVER ROAD	94CN1910	347	161.9	
247	81	PORT ARANSAS	94CS990	1,324	161.8	
248	365	RIO RICO	94SB5050	1,601	159.0	
249	564	RODD FIELD	94CS2190	2,882	158.5	
250	154	MAGRUDER	94CN6700	1,429	158.5	
251	301	THREE RIVERS	94CN8430	167	158.3	
252	402	UNIVERSITY	94LA950	2,191	158.1	
253	534	SOUTH EAST EDINBURG	94SB4550	2,123	157.3	
254	482	CRYSTAL CITY	94LA140	1,200	156.7	
255	177	MCCOLL ROAD	94SB2810	2,243	156.0	
256	194	RACHAL	94LA6595	290	156.0	
257	174	ZAPATA	94LA8300	1,520	155.9	
258	161	SOUTH SANTA ROSA	94SB1235	630	155.3	
259	317	PLEASANTON	94LA9505	1,429	154.0	
260	228	MINES ROAD	94LA4275	87	153.1	
261	354	TATTON	94CS8200	958	152.3	
262	591	HAINE DRIVE	94SB8065	1,270	152.2	
263	115	VICTORIA POWER PLANT	94CN8070	606	151.6	
264	50	RACHAL	94LA8145	365	151.5	
265	352	WEIL TRACT (138/12KV)	94CS2520	534	151.3	
266	307	HIGHWAY 9	94CS6730	507	149.0	
267	74	ENCINAL	94LA2160	765	148.9	
268	286	PALMVIEW	94SB6790	2,772	147.9	
269	55	BONNIEVIEW	94CS8020	510	147.0	
270	268	STADIUM	94CS8540	1,606	146.3	
271	305	WESMER	94SB6900	1,474	146.1	
272	364	FULTON	94CS2020	1,766	144.8	
273	288	RANDADO	94LA8350	123	144.7	
274	279	MATHIS	94CS1410	455	143.0	
275	384	WESLACO UNIT	94SB7630	3,519	142.8	
276	646	BUENA VISTA	94LA9385	2,033	142.3	
277	368	NIXON	94CN2620	548	142.1	
278	126	SANTO NINO	94LA75	1,457	140.9	
279	388	ROMA	94SB3060	1,489	140.8	
280	383	HARLINGEN	94SB380	2,287	140.5	
281	77	PORT ISABEL S.S.	94SB3820	203	140.3	
282	122	ARCADIA	94CS5020	1,519	140.2	
283	593	O CONNER	94CN390	216	139.2	
284	400	ARANSAS PASS	94CS8270	611	139.0	
285	328	SKIDMORE	94CS600	350	138.7	
286	117	PHARAOH	94CS5175	976	138.4	
287	592	GOLIAD	94CN8220	1,018	138.1	
288	504	SAN DIEGO	94CS2890	1,032	137.8	
289	445	SUNCHASE	94SB1150	1,239	137.5	
290	105	LAREDO HEIGHTS	94LA2100	2,029	137.3	
291	567	SABINAL	94LA485	479	136.8	
292	516	PORTLAND	94CS9270	1,871	136.8	
293	90	LA GRULLA	94SB5110	2,209	136.6	
294	369	SOUTH MCALLEN	94SB3790	1,846	135.7	
295	502	AIRLINE	94CS9030	413	134.9	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
296	430	WEST MCALLEN	94SB4505	1,722	134.4	
297	38	SOUTH MCALLEN	94SB3640	282	133.6	
298	701	INGLESIDE CITY	94CS2495	56	133.3	
299	83	WESMER	94SB7760	1,209	131.8	
300	88	RANGERVILLE	94SB4060	858	130.2	
301	251	EAGLE PASS CITY	94LA7060	815	129.8	
302	223	KINGSVILLE	94CS1670	423	129.5	
303	196	WEIL TRACT (138/12KV)	94CS5405	148	129.3	
304	465	MCKENZIE ROAD	94CS330	2,234	128.2	
305	242	CHARLOTTE	94LA8120	194	128.1	
306	272	KLEBERG	94CS6000	1,477	127.8	
307	707	WOOLRIDGE	94CS1120	2,629	127.5	
308	61	CABANISS	94CS240	1,440	127.4	
309	694	ESCONDIDO	94LA2035	2,381	126.4	
310	276	SOUTH MCALLEN	94SB3850	770	126.2	
311	578	WASHINGTON STREET	94LA2350	2,854	125.5	
312	202	HOLLY	94CS1480	1,688	124.6	
313	684	DEL MAR	94LA10	2,473	124.0	
314	99	HIGHWAY 9	94CS7210	304	123.9	
315	469	PALACIOS	94CN6840	1,514	123.6	
316	389	NUECES BAY PLANT	94CS345	52	123.5	
317	468	CRESTONIO	94LA260	1,745	123.5	
318	45	HIDALGO	94SB4845	1,003	123.5	
319	461	EAGLE LAKE	94CN320	647	123.1	
320	380	CLARKWOOD	94CS7230	560	122.8	
321	176	LIVE OAK	94CS1090	244	122.8	
322	579	HEARN ROAD	94CS9665	547	122.7	
323	166	CARRIZO SPRINGS	94LA860	1,054	122.5	
324	396	LULING - LCRA	94CN20	254	122.2	
325	159	SINTON	94CS180	918	122.1	
326	353	ARCADIA	94CS1460	1,953	121.8	
327	82	HIGHWAY 9	94CS6770	1,150	121.6	
328	405	OLMITO	94SB4275	764	121.6	
329	311	DEVINE	94LA8100	1,450	121.5	
330	637	THREE RIVERS	94CN5190	788	120.5	
331	200	KLEBERG	94CS9395	1,319	120.2	
332	164	EAGLE PASS CITY	94LA2650	1,276	120.1	
333	550	MARKHAM	94CN6440	424	120.1	
334	281	DEL RIO CITY	94LA1930	918	119.3	
335	649	ROCKPORT	94CS5930	1,076	118.5	
336	103	NORTH EDINBURG	94SB4240	2,049	118.1	
337	414	WESLACO UNIT	94SB9805	2,787	117.8	
338	179	MATHIS	94CS340	1,472	117.7	
339	240	POLK AVENUE	94SB4600	2,542	115.7	
340	583	ARCADIA	94CS8570	1,432	115.6	
341	172	ALICE	94CS1770	1,521	115.5	
342	639	UVALDE	94LA550	648	114.4	
343	379	WESLACO UNIT	94SB5970	2,815	114.4	
344	261	KINGSVILLE	94CS1130	2,042	114.1	
345	275	PEARSALL	94LA9905	711	113.3	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
346	300	NORTH EDINBURG	94SB3810	804	112.2	
347	222	HAINE DRIVE	94SB270	735	111.8	
348	485	PUEBLO	94LA275	2,629	111.5	
349	80	RANGERVILLE	94SB3410	789	110.7	
350	262	SAN BENITO	94SB3920	2,275	110.7	
351	269	UVALDE	94LA480	1,270	109.0	
352	312	PALACIOS	94CN8550	36	108.0	
353	171	STADIUM	94CS6950	534	107.7	
354	586	LIVE OAK	94CS1080	784	107.5	
355	316	PETTUS	94CN1020	372	107.1	
356	581	KINGSVILLE	94CS1350	361	106.8	
357	157	NORTH MCALLEN	94SB2750	2,894	105.9	
358	225	EAST HARRISON	94SB3190	1,411	105.8	
359	588	LEARY LANE	94CN1430	1,572	105.4	
360	87	SOUTHSIDE	94CS7955	1,058	104.1	
361	571	SHARYLAND	94SB2035	2,264	104.0	
362	298	SOUTH SANTA ROSA	94SB1225	810	103.7	
363	378	STADIUM	94CS7810	1,615	103.4	
364	250	HIGHWAY 9	94CS6760	603	102.7	
365	575	ODEM	94CS5575	56	102.1	
366	520	FREER	94LA5200	992	101.8	
367	609	POINT COMFORT	94CN6060	50	100.3	
368	326	THREE RIVERS	94CN2010	856	100.2	
369	49	GOODWIN	94SB4390	407	100.2	
370	199	BEEVILLE	94CN2380	201	100.0	
371	370	PEARSALL	94LA7050	1,286	98.7	
372	698	SANTO NINO	94LA695	1,482	98.0	
373	new	VILLA CAVAZOS	94SB7615	913	97.4	part of 94SB3550
374	211	SUNCHASE	94SB1155	1,383	97.4	
375	498	DILLEY	94LA510	510	97.1	
376	496	NORTH ALAMO	94SB4370	2,376	96.6	
377	597	HOLLY	94CS1950	795	96.1	
378	315	BIG WELLS	94LA1570	398	95.7	
379	681	CLARKWOOD	94CS7220	362	94.8	
380	235	CLARKWOOD	94CS7610	184	94.2	
381	320	FULTON	94CS9050	1,608	93.8	
382	393	SOUTH PADRE ISLAND	94SB4695	1,319	93.6	
383	708	GARWOOD CITY	94CN2560	189	93.3	
384	318	SAN DIEGO	94CS2930	601	93.3	
385	466	TATTON	94CS950	525	92.9	
386	341	EAST HARRISON	94SB4360	1,683	92.7	
387	474	ANNA STREET	94LA850	1,531	92.4	
388	266	FULTON	94CS440	1,977	92.2	
389	537	KINGSVILLE	94CS1660	1,572	92.0	
390	404	WADSWORTH	94CN8630	628	91.6	
391	549	SOUTH MISSION	94SB3620	1,812	90.9	
392	66	PREMONT	94LA6610	802	90.8	
393	615	SOUTH MISSION	94SB4650	965	90.3	
394	256	VICTORIA POWER PLANT	94CN7600	158	90.0	
395	392	SOUTH MISSION	94SB3590	662	89.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
396	104	BERCLAIR	94CN990	306	89.5	
397	59	NORTH WESLACO	94SB4830	483	89.2	
398	425	ZAPATA	94LA8290	2,140	88.7	
399	198	LYTLE	94LA2850	601	88.3	
400	new	LA GRULLA	94SB6150	1,065	88.1	
401	32	CHARLOTTE	94LA2780	506	87.9	
402	399	UVALDE	94LA5060	1,296	87.7	
403	416	HIGHWAY 9	94CS6780	793	87.6	
404	472	BEEVILLE	94CN2200	740	87.3	
405	695	PLACEDO	94CN7980	396	86.9	
406	570	SHARYLAND	94SB2010	972	86.9	
407	25	GREGORY	94CS5900	108	86.6	
408	501	FOSTER FIELD	94CN2550	331	86.4	
409	237	BAY CITY	94CN2700	1,061	86.3	
410	471	SOUTHSIDE	94CS8005	745	86.1	
411	345	NORDHEIM	94CN470	235	85.3	
412	47	RIO BRAVO	94LA300	859	85.3	
413	438	ARANSAS PASS	94CS8280	546	84.8	
414	360	STADIUM	94CS7800	649	84.8	
415	462	WEST OSO	94CS9095	1,461	84.6	
416	162	ELSA	94SB690	2,087	83.9	
417	183	LOLITA	94CN6330	26	83.8	
418	547	SOUTH MCALLEN	94SB3935	1,245	83.8	
419	522	EAST HARRISON	94SB3030	716	83.3	
420	221	RAYMONDVILLE #2	94SB4160	322	83.3	
421	457	AIRLINE	94CS8370	300	82.4	
422	525	NORTH MCALLEN	94SB5060	2,175	81.9	
423	528	HOLLY	94CS5820	922	81.3	
424	452	FULTON	94CS6070	2,953	80.9	
425	589	AIRLINE	94CS7280	607	79.5	
426	442	GATEWAY	94LA390	798	79.3	
427	291	CRESTONIO	94LA6660	724	79.2	
428	460	GARCENO	94SB2130	3,210	78.9	
429	490	UVALDE	94LA6620	2,623	78.4	
430	338	EAST HARRISON	94SB4310	1,144	78.4	
431	374	PALMHURST	94SB2530	1,778	78.1	
432	110	SOUTH EAST EDINBURG	94SB4570	1,319	77.8	
433	566	UNIVERSITY	94LA920	440	77.8	
434	218	HARLINGEN S.S.	94SB4090	2,224	77.4	
435	608	PORT LAVACA	94CN2490	1,059	77.4	
436	185	YORKTOWN	94CN8420	998	76.6	
437	270	COLUMBUS	94CN930	897	76.3	
438	544	UVALDE	94LA540	1,198	75.8	
439	34	JOURDANTON	94LA880	277	75.6	
440	671	SOUTHSIDE	94CS8055	834	75.2	
441	443	ROCKSPRINGS	94LA8040	324	74.6	
442	37	RIO BRAVO	94LA5	660	74.6	
443	660	SIERRA VISTA	94LA7360	2,442	74.5	
444	418	YORKTOWN	94CN8380	780	74.5	
445	361	COTULLA	94LA110	1,194	74.1	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
446	626	MORRIS STREET	94CS7465	628	73.8	
447	432	BEEVILLE	94CN1760	1,752	73.8	
448	243	KENEDY	94CN1970	636	73.7	
449	356	LIVE OAK	94CS1070	2,750	73.6	
450	629	SOUTH EAST EDINBURG	94SB4015	415	73.5	
451	214	MATTHEWS	94CN1740	159	73.5	
452	254	NORTH EDINBURG	94SB560	1,501	73.2	
453	309	RIO GRANDE CITY	94SB3220	1,734	72.7	
454	358	PLEASANTON	94LA2080	1,483	72.2	
455	691	BUENA VISTA	94LA8965	923	71.8	
456	273	GOODWIN	94SB3530	1,304	71.7	
457	641	NORTH VICTORIA	94CN7430	1,671	71.1	
458	426	WEST HARLINGEN	94SB4870	536	70.9	
459	359	NORTH VICTORIA	94CN7770	805	70.5	
460	417	PALMVIEW	94SB7595	2,589	70.4	
461	479	INGLESIDE CITY	94CS6040	259	69.9	
462	182	MILO	94LA6940	250	69.8	
463	236	ODEM	94CS375	991	69.6	
464	139	WEST OSO	94CS9085	742	69.5	
465	499	PLEASANTON	94LA9475	1,300	69.4	
466	481	SEAWALL	94CS9325	1,406	69.3	
467	73	JOURDANTON	94LA5695	1,249	69.2	
468	334	WESMER	94SB4050	1,887	69.0	
469	546	DEL RIO CITY	94LA430	2,462	69.0	
470	210	HALL ACRES ROAD	94SB4895	788	68.8	
471	278	GEORGE WEST	94CN730	859	67.8	
472	711	ANNA STREET	94LA5780	722	66.9	
473	635	GREGORY	94CS5920	500	66.5	
474	670	HEARN ROAD	94CS2220	1,519	66.3	
475	699	RODD FIELD	94CS3010	1,759	65.2	
476	398	KINGSVILLE	94CS1140	976	63.5	
477	212	ARANSAS PASS	94CS9130	317	63.3	
478	705	SIERRA VISTA	94LA9900	2,083	63.0	
479	366	AIRLINE	94CS6970	1,203	62.6	
480	513	ARCADIA	94CS1400	428	61.7	
481	132	BEEVILLE	94CN300	1,584	61.5	
482	529	LAREDO PLANT	94LA8505	765	60.7	
483	693	BROOKHOLLOW	94CN8950	854	60.5	
484	517	LAREDO HEIGHTS	94LA9400	1,394	60.2	
485	86	NORTH ALAMO	94SB3580	1,848	60.2	
486	521	LAREDO HEIGHTS	94LA2450	2,442	59.9	
487	551	DEL MAR	94LA3440	1,366	58.9	
488	51	LOS FRESNOS	94SB2160	1,324	58.2	was 94SB3200
489	491	AIRLINE	94CS9605	1,246	58.2	
490	542	MAGRUDER	94CN7690	570	58.2	
491	562	HALL ACRES ROAD	94SB3460	3,463	57.7	
492	112	NORTH MERCEDES	94SB3840	635	57.7	
493	556	BEEVILLE	94CN8090	1,220	57.6	
494	420	MAGRUDER	94CN245	1,084	57.4	
495	617	HEARN ROAD	94CS8980	1,147	57.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
496	175	DEL RIO CITY	94LA420	2,284	57.1	
497	322	BAY CITY	94CN6670	1,751	56.9	
498	480	CITRUS CITY	94SB7985	1,505	56.1	
499	410	ARCADIA	94CS1360	1,508	55.7	
500	543	SAN BENITO	94SB3860	243	55.1	
501	622	LAREDO PLANT	94LA8695	969	55.0	
502	536	COTULLA	94LA90	691	54.7	
503	208	NAVAL BASE	94CS1380	2,118	53.7	
504	494	LEARY LANE	94CN6005	2,039	53.3	
505	146	MCKENZIE ROAD	94CS150	21	53.3	
506	492	POLK AVENUE	94SB4900	2,525	53.3	
507	310	GEORGE WEST	94CN1320	641	53.0	
508	651	COLUMBUS	94CN9060	373	52.2	
509	258	PHARAOH	94CS1285	1,746	51.9	
510	628	SOUTH MISSION	94SB5215	1,218	51.7	
511	647	GOODWIN	94SB7380	2,094	51.6	
512	168	LAGUNA	94CS9590	2,047	51.2	
513	697	PALMHURST	94SB3890	2,266	51.0	
514	686	KNIPPA	94LA6535	21	50.8	
515	224	PARKER	94CN9260	94	50.4	
516	53	SAN YGNACIO	94LA16060	494	50.4	
517	327	BROOKHOLLOW	94CN7580	417	50.3	
518	488	DEL RIO CITY	94LA9790	2,535	49.5	
519	557	PORTLAND	94CS6505	1,607	49.5	
520	96	GOODWIN	94SB4625	338	49.4	
521	587	ALICE	94CS1790	337	49.1	
522	248	EAST HARRISON	94SB3080	356	48.8	
523	70	SAN DIEGO	94CS2880	1,186	48.5	
524	510	WESLACO UNIT	94SB8195	1,689	48.2	
525	602	NORTH VICTORIA	94CN1580	1,029	47.6	
526	676	RAYMONDVILLE #1	94SB3130	273	47.4	
527	717	OLMITO	94SB905	1,412	47.3	
528	92	PORT ARANSAS	94CS1000	1,335	47.3	
529	565	RUNGE	94CN7320	578	46.7	
530	486	RIO GRANDE CITY	94SB3230	1,057	46.6	
531	483	TAFT	94CS5230	811	46.6	
532	283	WEST MCALLEN	94SB4535	2,763	46.5	
533	642	ODEM	94CS385	378	46.3	
534	107	EDROY	94CS6980	193	46.1	
535	675	NORTH VICTORIA	94CN2240	784	46.0	
536	8	VILLA CAVAZOS	94SB5680	1,650	45.9	was 94SB3560
537	403	BUENA VISTA	94LA9035	1,479	45.7	
538	294	DEL MAR	94LA220	809	45.7	
539	373	PHARR	94SB1645	2,505	45.7	
540	97	SANTO NINO	94LA80	2,312	45.4	
541	155	BISHOP	94CS2690	553	44.9	
542	523	WEST MCALLEN	94SB4555	1,459	44.5	
543	335	BEEVILLE	94CN490	929	44.4	
544	644	AIRLINE	94CS8890	520	43.8	
545	548	SOUTH MCALLEN	94SB5065	80	43.3	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
546	476	MAGRUDER	94CN6680	685	43.1	
547	553	COFFEE PORT	94SB1090	1,133	42.8	
548	507	REFUGIO	94CN1040	727	42.3	
549	65	THOMASTON	94CN9580	43	42.3	
550	102	PORT ARANSAS	94CS3030	798	41.8	
551	391	SOUTH EAST EDINBURG	94SB6580	1,300	41.5	
552	290	POLK AVENUE	94SB4170	1,669	41.4	
553	467	MORRIS STREET	94CS8715	1,568	41.4	
554	682	SINTON	94CS1750	496	41.4	
555	295	SOUTHSIDE	94CS8035	1,076	41.3	
556	351	BROOKHOLLOW	94CN7190	260	41.3	
557	433	SINTON	94CS360	289	40.9	
558	213	WESMER	94SB9705	1,032	40.8	
559	348	LEARY LANE	94CN7530	1,882	40.7	
560	610	BIG WELLS	94LA2630	26	40.7	
561	640	BROOKHOLLOW	94CN8960	548	40.0	
562	52	HALL ACRES ROAD	94SB5465	1,499	39.9	
563	595	SOUTH MISSION	94SB3940	765	39.5	
564	505	LAREDO HEIGHTS	94LA6820	2,067	39.2	
565	333	PARKER	94CN9010	18	39.0	
566	219	NORTH MCALLEN	94SB9660	1,985	38.5	
567	100	CHARLOTTE	94LA2790	96	38.3	
568	347	STADIUM	94CS7490	1,224	38.3	
569	new	MCCOLL ROAD	94SB1655	1,119	37.4	
570	606	WESMER	94SB4480	1,071	37.2	
571	new	SOUTH SANTA ROSA	94SB7485	984	36.3	
572	85	PREMONT	94LA6570	712	36.2	
573	678	EL CAMPO	94CN6370	704	36.1	
574	195	HIGHWAY 9	94CS7200	558	35.9	
575	229	HARLINGEN	94SB660	1,884	35.8	
576	554	BAY CITY	94CN2050	506	35.7	
577	187	MILO	94LA8365	2,204	35.7	
578	683	HARLINGEN	94SB370	1,156	35.2	
579	667	DEL RIO CITY	94LA9850	909	34.8	
580	340	MAGRUDER	94CN6690	545	34.7	
581	582	HOLLY	94CS1370	1,864	34.7	
582	429	WASHINGTON STREET	94LA6525	2,008	34.2	
583	101	HIDALGO	94SB3680	316	34.1	
584	71	GARCENO	94SB2135	1,717	34.0	
585	367	WEIL TRACT (138/12KV)	94CS1990	1,251	34.0	
586	577	ESCONDIDO	94LA1510	686	33.9	
587	712	LAREDO PLANT	94LA8565	1,166	33.8	
588	401	WOODSBORO	94CS8330	1,064	33.5	
589	621	PORT LAVACA	94CN2480	1,507	33.3	
590	282	MORRIS STREET	94CS2515	1,091	32.9	
591	561	BAY CITY	94CN5960	1,849	32.9	
592	487	LAREDO PLANT	94LA9305	942	32.2	
593	133	BEEVILLE	94CN8510	852	32.1	
594	267	ALICE	94CS1780	266	31.9	
595	30	SANTO NINO	94LA70	1,050	31.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
596	48	HIDALGO	94SB3400	843	30.9	
597	497	ARCADIA	94CS1440	1,589	30.9	
598	687	DEL MAR	94LA7930	1,202	30.9	
599	475	HOLLY	94CS7740	1,968	30.4	
600	580	ANNA STREET	94LA2250	1,537	30.1	
601	331	MILO	94LA5020	1,268	30.1	
602	123	POLK AVENUE	94SB4610	1,290	30.0	
603	163	NORTH MCALLEN	94SB4995	1,854	29.6	
604	95	LA PRYOR	94LA2440	639	29.4	
605	409	RAYMONDVILLE #1	94SB800	674	29.3	
606	661	LAREDO PLANT	94LA8745	715	29.1	
607	652	PUEBLO	94LA130	1,224	28.7	
608	230	HOLLY	94CS7620	2,297	28.4	
609	524	ANNA STREET	94LA900	2,790	28.0	
610	304	ARCADIA	94CS6930	1,498	27.8	
611	252	EL CAMPO	94CN5745	868	27.8	
612	672	EL CAMPO	94CN2860	558	27.7	
613	531	LAREDO HEIGHTS	94LA9080	667	27.5	
614	511	SHARYLAND	94SB6745	1,782	27.5	
615	573	MORRIS STREET	94CS8830	1,512	26.5	
616	264	ARCADIA	94CS5030	1,550	26.4	
617	41	HALL ACRES ROAD	94SB8870	3,652	25.9	
618	111	MINES ROAD	94LA3745	1,391	25.4	
619	519	HAMILTON ROAD	94LA9665	933	24.9	
620	325	MCCOLL ROAD	94SB4780	2,102	24.8	
621	714	LAREDO PLANT	94LA8705	206	24.2	
622	169	EAST HARRISON	94SB4620	752	23.9	
623	406	HOLLY	94CS1220	3,295	23.4	
624	563	LEARY LANE	94CN6175	1,452	23.2	
625	631	ARANSAS PASS	94CS650	740	22.5	
626	362	ARCADIA	94CS1450	1,863	22.0	
627	656	POLK AVENUE	94SB4520	866	21.8	
628	428	ROCKPORT	94CS5950	540	21.2	
629	217	WEST MCALLEN	94SB4595	1,132	21.0	
630	663	SHARYLAND	94SB5635	1,862	20.8	
631	603	HAMILTON ROAD	94LA9655	1,163	20.4	
632	346	HOLLY	94CS9675	1,745	20.3	
633	568	DEL RIO CITY	94LA440	831	20.3	
634	574	FULTON	94CS3070	1,559	20.2	
635	395	LEARY LANE	94CN1890	1,568	20.0	
636	508	LAREDO HEIGHTS	94LA6810	2,001	20.0	
637	415	WEST MCALLEN	94SB6385	200	20.0	
638	306	LEARY LANE	94CN1540	776	19.9	
639	489	WEST MCALLEN	94SB4815	708	19.9	
640	387	PALMHURST	94SB2820	1,796	19.6	
641	292	KENEDY S.S.	94CN8340	877	19.2	
642	160	ZACATE CREEK	94LA2665	1,613	19.2	
643	526	SEAWALL	94CS9450	281	18.9	
644	89	BLESSING	94CN8780	65	18.8	
645	303	BAY CITY	94CN1110	1,291	18.7	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
646	280	EL CAMPO	94CN7710	1,056	18.6	
647	658	ARANSAS PASS	94CS590	400	18.4	
648	619	BAY CITY	94CN7480	1,918	18.0	
649	441	KENEDY S.S.	94CN6750	759	17.8	
650	662	GATEWAY	94LA3595	1,489	17.8	
651	265	PLEASANTON	94LA120	1,171	17.8	
652	456	PHARR	94SB1620	2,622	17.7	
653	191	HAINE DRIVE	94SB9700	764	17.4	
654	274	MCCOLL ROAD	94SB4790	1,866	16.5	
655	594	WOOLRIDGE	94CS1110	1,381	16.1	
656	227	HIGHWAY 9	94CS9830	135	15.9	
657	453	MORRIS STREET	94CS5655	1,003	15.8	
658	509	HAINE DRIVE	94SB3490	985	15.8	
659	431	WASHINGTON STREET	94LA2360	665	15.7	
660	314	MORRIS STREET	94CS7625	558	15.6	
661	203	TAFT	94CS1180	1,049	15.5	
662	659	SHARYLAND	94SB2150	1,064	15.5	
663	343	VICTORIA POWER PLANT	94CN1390	1,128	15.4	
664	205	POLK AVENUE	94SB4740	1,772	15.4	
665	321	LA GRULLA	94SB5005	959	15.2	
666	715	ESCONDIDO	94LA3350	889	15.1	
667	605	POLK AVENUE	94SB4180	1,142	15.0	
668	337	MILO	94LA3065	179	14.8	
669	648	SABINAL	94LA200	405	14.3	
670	464	NORTH VICTORIA	94CN7860	1,431	13.6	
671	664	ANNA STREET	94LA780	455	12.9	
672	604	AIRLINE	94CS9390	1,412	12.9	
673	657	BAY CITY	94CN6450	958	12.4	
674	710	ASPHALT MINES	94LA500	35	12.2	
675	new	SHARYLAND	94SB5105	1,448	12.1	
676	449	PORT LAVACA	94CN6850	594	11.3	
677	572	MORRIS STREET	94CS8840	586	10.9	
678	634	LAREDO HEIGHTS	94LA2390	721	10.9	
679	289	NORTH MCALLEN	94SB3830	1,279	10.8	
680	590	BRACKETTVILLE	94LA8460	1,156	10.7	
681	470	HAMILTON ROAD	94LA9645	286	10.5	
682	143	JOURDANTON	94LA5685	529	10.4	
683	552	POLK AVENUE	94SB4190	1,666	10.0	
684	607	GATEWAY	94LA5055	1,856	9.8	
685	704	ARANSAS PASS	94CS660	721	9.4	
686	14	ZAPATA	94LA7330	1,271	9.3	
687	249	GATEWAY	94LA350	1,282	9.1	
688	285	SANTO NINO	94LA645	844	8.7	
689	690	NORTH VICTORIA	94CN6390	1,311	8.3	
690	193	MILO	94LA3070	3,057	8.3	
691	349	NORTH MCALLEN	94SB9640	1,411	8.2	
692	308	WEST MCALLEN	94SB4515	788	8.1	
693	439	EL CAMPO	94CN7260	524	8.1	
694	668	THREE RIVERS	94CN5100	35	7.7	
695	545	EDNA	94CN5775	487	7.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value	Notes
696	598	NORTH VICTORIA	94CN1470	433	7.5	
697	141	SANTO NINO	94LA515	1,881	5.9	
698	674	GARWOOD CITY	94CN2570	128	5.9	
699	33	ZAPATA	94LA2710	46	5.8	
700	703	ZACATE CREEK	94LA2635	248	5.5	
701	255	KENEDY	94CN1960	59	5.0	
702	600	AIRLINE	94CS5870	852	4.9	
703	473	CHASE FIELD	94CN460	16	4.8	
704	633	WASHINGTON STREET	94LA6355	1,057	4.5	
705	435	EAGLE PASS CITY	94LA2510	634	4.4	
706	436	UNIVERSITY	94LA930	708	3.9	
707	319	ROCKSPRINGS	94LA2600	366	3.5	
708	532	ZACATE CREEK	94LA2675	1,111	3.2	
709	643	EAST HARRISON	94SB3000	534	3.2	
710	540	AIRLINE	94CS7390	1,039	2.4	
711	680	ROCKPORT	94CS5940	58	2.2	
712	685	SOUTHSIDE	94CS5345	397	2.0	
713	451	HALL ACRES ROAD	94SB3670	842	2.0	
714	560	HALL ACRES ROAD	94SB9595	1,029	1.8	
715	669	SIERRA VISTA	94LA3540	319	0.9	
716	706	WASHINGTON STREET	94LA2470	187	0.5	
717	381	AIRLINE	94CS7270	995	0.1	
718	118	VICTORIA POWER PLANT	94CNNETVIC	78	-	
719	709	GREGORY	94CS420	23	-	
720	713	MORRIS STREET	94CSNET CC	339	-	
721	454	MILO	94LA3060	105	-	
722	716	WASHINGTON STREET	94LANETLAR	359	-	

Feeders from last year that are not in this year's list

2008 SAIDI Ranking		Substation Identification	Feeder Identification	Reason not in 2009
8		CAVAZOS	94SB3560	now 94SB5680
20		CAVAZOS	94SB3550	split into 94SB1980 and 94SB7615
23		LOS FRESNOS	94SB3290	now 94SB4315
51		LOS FRESNOS	94SB3200	now 94SB2160
119		LOS FRESNOS	94SB3280	now 94SB7270
330		LOS FRESNOS	94SB930	now 94SB5335

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2009 Reporting Year

Causes of Forced Interruptions	Percentage
Animals and Birds	9.9 %
People (including cars and farm eqpt)	2.5 %
Unknown	6.6 %
Utility-Owned Equipment	50.1 %
Vegetation	16.5 %
Weather (including lightning)	14.2 %
Other	0.1 %