

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1679	2351	WELRD	0008	1121	39.44
1680	280	WOVER	6111	2241	39.34
1681	866	EULSO	9112	1050	39.22
1682	23	BNTDR	0003	157	39.22
1683	1444	HSKAV	0007	1834	39.15
1684	305	ODESA	0272	1635	39.14
1685	958	MAPLE	0007	101	39.12
1686	2456	RRSTH	1701	2766	39.09
1687	2693	MDDTN	4322	27	39.00
1688	338	EULES	8732	1409	39.00
1689	385	LAVON	1453	2282	38.95
1690	2663	ALPHA	0003	705	38.94
1691	2109	PCUST	2006	1599	38.93
1692	1290	PJPTR	3221	34	38.91
1693	660	FHLSW	1372	1002	38.89
1694	1873	RCHRD	1204	1093	38.81
1695	1931	WNTHW	1116	635	38.49
1696	420	BLTLN	0007	758	38.38
1697	1919	PFFRD	3482	1076	38.33
1698	600	HDWLK	3001	949	38.30
1699	1520	RCHRD	1208	1066	38.30
1700	753	SYCRK	4521	3290	38.20
1701	2097	KFMNW	1201	880	38.16
1702	1003	WMRLD	0004	1472	38.16
1703	1270	BOWEN	3161	1414	38.09
1704	2046	SPRDL	4822	1330	38.08
1705	1790	BDFRD	8842	1441	37.90
1706	2696	CNTRD	0001	1919	37.75
1707	89	BAGWL	1202	47	37.74
1708	2015	RCHHL	0332	1543	37.71
1709	718	TMPTV	2405	473	37.69
1710	624	CRLTR	2002	1092	37.65
1711	1575	MRDCK	0002	1364	37.59
1712	272	RRNES	2401	2967	37.49
1713	1350	ALLEN	2403	1495	37.33
1714	2634	SHRSW	6631	1211	37.32
1715	1905	GRMES	0512	1143	37.31
1716	298	COLDG	4047	427	37.30
1717	N/A	DALLW	0005	119	37.18
1718	2137	RCHRD	1206	665	37.18
1719	1166	WSOTH	1018	1258	37.07
1720	2485	ROLTR	2922	517	37.00
1721	2688	BKWST	0005	842	36.99
1722	1497	GODRD	8151	444	36.91
1723	2559	GODRD	8142	920	36.85
1724	1297	TATSP	4311	1835	36.83
1725	772	HORNE	1991	1383	36.75
1726	1011	GSTHW	1641	84	36.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1727	1786	BRKRG	0232	1716	36.75
1728	1930	ACRLY	1711	156	36.68
1729	1568	MKNNY	1205	471	36.60
1730	845	WWDWY	2015	1120	36.58
1731	2066	TRNTY	7511	1088	36.47
1732	1251	GSTHW	1623	2303	36.45
1733	274	MKNSW	2602	2919	36.45
1734	1783	CLCTY	1021	659	36.44
1735	221	LFSTH	1407	1047	36.43
1736	2182	BRHLW	7632	1383	36.37
1737	1807	LNCST	1603	1416	36.27
1738	1496	JUDCT	0007	636	36.25
1739	1721	REAST	1506	1185	36.23
1740	2178	GAVSW	0012	1164	36.21
1741	198	RKDLN	1401	907	36.20
1742	1764	HMPHL	2742	441	36.19
1743	1840	REAST	1504	1299	36.18
1744	628	RWALL	1203	2955	36.17
1745	1094	BLTSW	3203	987	36.14
1746	2276	IRVND	1208	144	36.06
1747	2189	PWEST	1302	339	36.03
1748	1263	GSTHW	1672	12	36.00
1749	1609	FARON	4072	1459	35.92
1750	446	WTAUG	4621	432	35.92
1751	2038	DALRK	1307	1196	35.79
1752	590	CDCSW	0006	1282	35.78
1753	1031	PALRD	2206	1464	35.74
1754	2020	BSPRG	1903	1599	35.72
1755	2198	ALLEN	2402	3457	35.72
1756	922	WWEST	1219	925	35.70
1757	1952	CRLJL	1506	1924	35.62
1758	1835	EDDYS	0425	209	35.49
1759	2354	LAVON	1454	2690	35.42
1760	2757	FRMBG	1706	55	35.35
1761	808	PRSTN	0006	665	35.29
1762	1846	MCGRG	1902	457	35.28
1763	639	OKCLS	0006	1083	35.23
1764	1128	CRLFR	2155	1340	35.17
1765	846	ABRRD	0008	1033	35.16
1766	1625	BNDRA	0001	1204	35.10
1767	1589	EDGCF	2241	915	35.09
1768	46	BRGPR	1102	1279	35.02
1769	1525	FSHSW	2111	282	35.00
1770	907	SSPNG	1204	943	34.99
1771	N/A	ELMGV	3653	1684	34.99
1772	1220	MDTHN	1703	981	34.96
1773	1210	DAVST	0006	994	34.93
1774	2406	PRKRW	3331	109	34.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1775	2061	BONHM	1204	861	34.85
1776	2685	TMSTH	1405	323	34.83
1777	995	LKHL	0001	1538	34.77
1778	966	POYNR	1201	332	34.67
1779	2303	PCOIT	1002	665	34.61
1780	1351	RSPCK	2105	316	34.56
1781	1436	HMPHL	2752	138	34.53
1782	145	LUFKN	1204	465	34.52
1783	625	TYLER	1012	1707	34.50
1784	2237	PCOIT	1005	1092	34.39
1785	566	TMNTH	1605	1716	34.32
1786	1359	WNTHW	1121	739	34.28
1787	682	CRANE	0311	697	34.27
1788	2677	MAPLE	0006	449	34.27
1789	2183	WATSN	5382	637	34.19
1790	586	MESQW	1802	776	34.18
1791	1526	LKMNT	0005	593	34.15
1792	202	FLMSO	3712	2525	34.11
1793	2550	DGNST	0008	581	34.03
1794	2235	MCKMY	0822	804	33.85
1795	1140	DAVIS	3713	867	33.85
1796	1370	IOWPK	0831	1053	33.80
1797	773	LUFKN	1205	1289	33.74
1798	2588	REAST	1509	62	33.65
1799	791	PRSTN	0008	710	33.64
1800	547	GLNHV	3973	1262	33.64
1801	2474	DGNST	0002	235	33.63
1802	1643	ADISN	1605	1051	33.58
1803	1331	IRVNR	1505	878	33.57
1804	1715	FHLSW	1361	926	33.51
1805	2199	WLWSP	1201	483	33.48
1806	118	DALLW	0004	1204	33.39
1807	2187	ELKTN	2503	800	33.23
1808	1736	TMPSE	1501	1537	33.19
1809	577	KLNCC	1703	3649	33.15
1810	1986	RCHHL	0363	418	33.14
1811	1843	CRLFR	2157	2399	33.12
1812	209	DESPR	1405	515	33.08
1813	758	WHOUS	4122	2060	33.07
1814	127	RDLML	2581	1198	33.07
1815	1489	RNDRK	1505	1136	32.98
1816	223	WELCH	4911	24	32.96
1817	993	CAMRN	1201	1014	32.51
1818	797	ARLNG	1241	586	32.49
1819	1150	EDGCF	2231	756	32.44
1820	1029	STAUG	0004	1107	32.37
1821	910	SGOVL	1404	1846	32.28
1822	2052	SHMNE	1407	785	32.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1823	1410	VLYRN	2951	2271	32.20
1824	2720	HMPHL	2711	462	32.12
1825	592	LKWOD	7411	602	32.07
1826	1896	PFFRD	3492	634	32.03
1827	1247	GRPVN	8223	1982	32.00
1828	2228	PLANO	1103	1556	31.97
1829	989	RSPCK	2108	843	31.96
1830	2194	ROSCO	2911	581	31.93
1831	1910	ROWLT	1102	793	31.91
1832	1286	PWEST	1311	767	31.84
1833	658	JKSNR	4111	412	31.70
1834	10	MEXIA	3015	91	31.64
1835	2106	KLNTF	1806	1172	31.60
1836	170	CHICG	1402	531	31.56
1837	2769	KRGRV	2401	12	31.50
1838	1867	MDWPK	9241	1369	31.50
1839	1379	DESPR	1402	1627	31.49
1840	1700	MNWLL	1207	1845	31.49
1841	2173	GRLND	1606	788	31.46
1842	106	MEXIA	4011	936	31.45
1843	1994	FSTVW	0006	1634	31.38
1844	1177	SSPNG	1201	1067	31.34
1845	1334	MNFLD	2611	2222	31.30
1846	409	KILEN	1201	1568	31.24
1847	1424	WXNTH	2303	1597	31.22
1848	2035	SMFLD	2323	526	31.18
1849	1289	MSHLN	0002	658	31.16
1850	1636	TMPLE	1202	1384	31.15
1851	1998	KLNTF	1801	1043	31.12
1852	1191	WWDWY	2022	992	31.07
1853	2064	SHRSW	6611	1199	30.99
1854	1750	COLNY	2404	1931	30.97
1855	1793	MESQW	1807	1495	30.96
1856	2593	DAVIS	3762	29	30.93
1857	521	MESTE	1202	754	30.91
1858	955	BKBNT	1832	186	30.90
1859	82	FORSW	2025	724	30.89
1860	1769	CRLJL	1507	947	30.78
1861	700	BLTON	1805	1271	30.73
1862	1204	MDWPK	9221	781	30.73
1863	1800	RSNHT	1122	1850	30.73
1864	510	FERIS	1103	851	30.72
1865	878	MESWE	3611	1674	30.69
1866	1469	WALST	0011	669	30.64
1867	1293	LOMAL	0012	659	30.59
1868	536	MEXIA	4008	734	30.58
1869	1842	MESQN	1501	1734	30.47
1870	422	KLRPR	9021	1929	30.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1871	2549	BRHLW	7631	709	30.39
1872	691	ALEDO	9421	1180	30.32
1873	2147	WFNTH	0211	1122	30.32
1874	1258	COTRD	0005	220	30.23
1875	360	TYLGE	1314	827	30.22
1876	1710	ALVRD	1501	1071	30.12
1877	1389	MKNNY	1202	1796	30.09
1878	2681	RECCR	0007	68	30.03
1879	2058	STNVL	1205	867	30.03
1880	2363	TRNTY	7541	627	30.00
1881	2762	GSTHW	1622	30	30.00
1882	2159	CURIE	7221	268	29.90
1883	1940	IRVVV	2801	2152	29.88
1884	2087	MDTHS	1001	1076	29.82
1885	2075	ECTHM	3311	937	29.80
1886	2612	WFALS	0114	426	29.78
1887	515	BRHLW	7621	2201	29.75
1888	1118	CDHCR	2052	1181	29.73
1889	2702	NPKWY	0008	533	29.59
1890	840	TMPNW	1105	1160	29.56
1891	1632	WWDWY	2024	1411	29.53
1892	1878	IRVND	1203	382	29.52
1893	1924	BDFRD	8811	1644	29.52
1894	172	CRLTN	1406	1190	29.52
1895	1167	DALWT	2952	588	29.42
1896	2256	PALMR	2202	934	29.41
1897	1017	NHNSW	0002	647	29.39
1898	2484	NHNSW	0004	548	29.36
1899	1277	ENNIS	1906	1787	29.35
1900	307	MTLDA	0004	715	29.29
1901	117	DAVST	0004	1721	29.23
1902	574	BLTON	1803	415	29.20
1903	2399	CLCTY	1011	1118	29.15
1904	2467	IRASB	3211	254	29.04
1905	664	EDGCF	2223	2907	29.04
1906	2395	GVODS	3031	1362	29.01
1907	2234	MDLNW	1521	2472	28.98
1908	N/A	MURPH	2756	2664	28.97
1909	865	RNDRK	1501	574	28.91
1910	611	CMTSW	0973	1158	28.84
1911	1637	BLKST	1762	1019	28.72
1912	1419	WITTS	1701	1840	28.64
1913	1678	CNTRY	2862	401	28.62
1914	416	CRTLD	4742	1713	28.62
1915	1706	KLNPS	1103	2092	28.60
1916	1221	TROYS	1014	707	28.53
1917	1236	TMSTH	1402	2227	28.36
1918	309	MEXIA	4024	363	28.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1919	2671	GVO DS	3041	1446	28.32
1920	151	TYWST	2013	1500	28.30
1921	506	PCUST	2011	2212	28.24
1922	1114	WRBND	2312	1454	28.18
1923	717	GLNHV	3963	1554	28.15
1924	1777	BOWEN	3151	1682	28.13
1925	466	OKCLS	0007	492	28.01
1926	888	RSPCK	2104	1900	27.97
1927	2103	PRCRK	0003	1596	27.95
1928	1362	WEAST	0629	1780	27.92
1929	297	MCHSN	1201	181	27.87
1930	833	TYLER	1005	1997	27.84
1931	850	ENTOH	0006	1512	27.80
1932	2451	MDLNE	0163	984	27.79
1933	1317	GRPVN	8211	337	27.75
1934	719	RWDHV	1907	750	27.71
1935	1409	TMPNW	1104	1843	27.65
1936	1666	CRKET	1201	313	27.65
1937	1920	RNDRK	1504	932	27.64
1938	1913	RCHRD	1201	1234	27.60
1939	1288	TYOMN	1408	1325	27.52
1940	456	PFFRD	3462	1582	27.45
1941	1658	PARIS	1203	985	27.42
1942	N/A	MASON	3411	14	27.29
1943	1937	ROWLT	1101	1110	27.14
1944	2414	VLYRN	2952	2172	27.11
1945	2423	CMPWI	0002	1699	27.05
1946	1682	MESQW	1803	1622	26.96
1947	1453	RGFTW	6822	22	26.95
1948	891	CHICW	1302	197	26.93
1949	2631	RCLNS	1402	515	26.92
1950	2176	ECTHM	3331	24	26.92
1951	1657	MDLNW	1541	2160	26.85
1952	361	RRNES	2405	2565	26.72
1953	1970	CRLTN	1405	1225	26.61
1954	1965	WXNTH	2301	1207	26.52
1955	2278	MDLNW	1511	2317	26.49
1956	2204	ANDNR	2211	1570	26.45
1957	1795	CMNCH	1401	1151	26.32
1958	2224	KERNS	2401	572	26.23
1959	2638	FRMBR	1808	598	26.22
1960	774	SHAMP	0004	1134	26.20
1961	1734	CNTRY	2824	3096	26.14
1962	1731	CLBRN	1201	1767	26.13
1963	919	COLNY	2402	2401	26.09
1964	2124	DCVSO	1102	666	26.06
1965	2679	KLNTF	1803	1032	25.92
1966	991	WELRD	0003	482	25.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
1967	N/A	GRHWY	5522	2109	25.86
1968	820	BLNKT	0701	276	25.84
1969	2735	ATNRN	3421	1011	25.78
1970	470	RSNHT	1171	2214	25.78
1971	779	SMFLD	2352	612	25.72
1972	1382	NHNSW	0003	528	25.72
1973	532	STHRL	0001	682	25.70
1974	1231	NIPAK	1001	125	25.67
1975	411	CRNAT	4121	63	25.65
1976	557	WHOUS	4128	326	25.65
1977	1548	BLTLN	0005	787	25.60
1978	1944	DAVIS	3721	1284	25.55
1979	283	SYCRK	4522	1941	25.55
1980	N/A	ELMGV	3651	1788	25.53
1981	1482	TRLWD	7721	1332	25.53
1982	2415	HMPHL	2772	246	25.52
1983	2225	DLEON	0131	724	25.48
1984	1763	LNDAL	2201	1691	25.42
1985	2191	ANDNR	2222	78	25.41
1986	1013	AYERS	4421	1408	25.35
1987	2388	ODESA	0251	1739	25.26
1988	2540	MDLNE	0122	255	25.23
1989	2684	WEAST	0628	217	25.21
1990	2255	MLKF2	1202	452	25.18
1991	365	PFLGV	2001	3704	25.13
1992	1642	DALRK	1303	773	25.06
1993	789	PCOIT	1022	2058	25.01
1994	N/A	SWTWR	1362	10	25.00
1995	1344	WXHCH	1202	1669	24.88
1996	1557	WNTHW	1120	1010	24.79
1997	666	LGVST	8521	1659	24.76
1998	1756	IRVNR	1507	1435	24.73
1999	2170	TYLGE	1306	2078	24.70
2000	2096	CMPWI	0004	1585	24.55
2001	1372	BLTSW	3201	2460	24.45
2002	1854	DUVAL	0414	603	24.41
2003	1076	MESTE	1209	212	24.39
2004	324	HRSMD	1907	2190	24.37
2005	372	RCHHL	0321	1667	24.36
2006	659	BLTLN	0003	495	24.35
2007	804	CLKVL	1202	1313	24.25
2008	1676	TYEST	1511	895	24.24
2009	633	GMINI	5821	354	24.19
2010	647	TYOMN	1411	287	24.19
2011	1186	HLSES	0522	1181	24.18
2012	1909	RDLML	2561	817	24.14
2013	2026	CRNDL	2401	524	24.11
2014	2197	ODNTH	2024	2606	24.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2015	1399	MSLSW	0001	1146	24.06
2016	1088	ROBNW	1503	1496	24.05
2017	683	PLKST	0001	733	24.05
2018	1663	COMRC	1204	631	24.04
2019	2410	ROWLT	1107	368	24.02
2020	334	HURST	1822	1345	23.98
2021	2352	GNSVE	1602	1539	23.91
2022	2349	GVODS	3062	1869	23.87
2023	189	EZACH	0008	1479	23.87
2024	569	BRNAV	0723	1291	23.86
2025	2672	WHITE	3542	1528	23.82
2026	2043	RANGR	4321	806	23.79
2027	1034	CDHCR	2050	779	23.75
2028	2335	LOMAL	0005	492	23.69
2029	2211	IRVNR	1506	1356	23.68
2030	2490	JUDCT	0003	1565	23.62
2031	2146	GVODS	3011	2277	23.59
2032	2436	PRSTN	0003	2807	23.58
2033	595	LWRDR	0003	1701	23.53
2034	770	WELRD	0002	727	23.50
2035	1692	MKNSW	2604	3163	23.50
2036	2530	ODNTH	2073	587	23.48
2037	1950	EULES	8724	3082	23.47
2038	1549	PRFTW	4222	3117	23.47
2039	265	ATHNW	1401	891	23.47
2040	1364	PARIS	1201	1204	23.46
2041	1255	PCUST	2009	2265	23.44
2042	2492	ALPHA	0010	522	23.38
2043	2445	MDDTN	4312	1998	23.34
2044	974	ARTHR	0441	1893	23.33
2045	1629	MDTHS	1002	947	23.30
2046	2247	MDLNW	1582	1423	23.29
2047	461	MNSTR	1201	565	23.28
2048	2615	RNKSW	5422	22	23.27
2049	1274	HURST	1841	194	23.24
2050	2283	SHAMP	0003	1606	23.12
2051	2628	BDFWD	8911	914	23.11
2052	826	FSHSW	2121	1691	23.08
2053	673	PPARK	1801	1266	23.05
2054	2370	MDLNW	1522	1470	22.98
2055	1852	CRLTN	1403	111	22.89
2056	2557	KLELM	2204	1744	22.81
2057	1747	OKCLS	0008	1461	22.76
2058	1690	PFLGV	2003	2651	22.76
2059	N/A	ANARN	1911	17	22.71
2060	583	PSHIL	1604	1140	22.69
2061	2412	PCUST	2002	477	22.63
2062	2764	HKBRY	1111	29	22.62

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2063	1821	ALNTH	2853	2789	22.59
2064	992	LMESA	1531	1195	22.57
2065	2627	WBROK	3021	54	22.56
2066	1395	WNRTH	1420	1139	22.55
2067	969	HSKAV	0005	1348	22.46
2068	2699	LWSNR	2212	1747	22.39
2069	162	DENDR	0004	1937	22.36
2070	2527	DAVST	0007	993	22.27
2071	1512	BRCRK	6511	1203	22.24
2072	1505	WALST	0014	777	22.22
2073	1513	LKBLT	2105	845	22.22
2074	1056	MNWLL	1203	716	22.20
2075	2139	TMSTH	1401	1836	22.19
2076	558	WNRTH	1421	1440	22.12
2077	915	KILEN	1205	1288	22.09
2078	2095	TYLER	1004	189	22.07
2079	716	FRNKF	0002	865	22.01
2080	2221	PCUST	2005	1718	21.95
2081	2177	HKHTS	1606	1659	21.95
2082	308	STAUG	0005	1128	21.95
2083	1784	HKHTS	1603	915	21.86
2084	421	CRSGL	1302	1440	21.80
2085	541	OVRTN	4037	120	21.77
2086	2469	MDWCK	0008	882	21.76
2087	2373	MESQW	1806	1577	21.70
2088	2312	COPEL	3052	1309	21.70
2089	1624	PLANO	1104	809	21.68
2090	1417	GRAHM	0721	1136	21.68
2091	1396	DNCNV	1904	1434	21.65
2092	2460	ROWLT	1106	1292	21.63
2093	1714	PWEST	1301	1219	21.58
2094	1762	BBTWN	1504	2000	21.55
2095	1620	HMPHL	2721	456	21.51
2096	1945	LOMAL	0003	1074	21.51
2097	2071	SMFLD	2391	292	21.47
2098	2084	BLMED	1617	302	21.46
2099	2353	CNTRD	0004	1023	21.41
2100	2039	MTLDA	0003	1512	21.33
2101	60	BRIRV	6911	2964	21.32
2102	244	HNYGR	2403	128	21.27
2103	807	MRTNS	1501	473	21.25
2104	2185	PALRD	2205	319	21.18
2105	2680	CPLSO	4321	143	21.06
2106	1187	LNDAL	2202	1141	21.03
2107	1823	RWDHV	1906	631	21.00
2108	1975	CPRCV	1407	1543	20.98
2109	246	TYWST	2004	1000	20.97
2110	1427	WALST	0012	322	20.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2111	567	MRDCK	0003	1199	20.88
2112	2553	LIGSW	1607	1370	20.82
2113	1510	HKHTS	1602	993	20.72
2114	2054	GODRD	8122	872	20.70
2115	1882	LWSNR	2232	2088	20.70
2116	2079	SWDTN	1641	1571	20.58
2117	2122	SHRSW	6612	1725	20.55
2118	662	DESHR	1204	1090	20.45
2119	2010	SWDTN	1611	1532	20.41
2120	1584	BNDRA	0006	485	20.37
2121	260	PPARK	1807	883	20.34
2122	1560	DALRK	1354	1411	20.31
2123	2739	CLBNR	1401	20	20.25
2124	2789	RSPCK	2142	927	20.22
2125	997	PLSTN	1004	1527	20.19
2126	963	MESFR	2102	657	20.18
2127	1824	IRVND	1204	1224	20.06
2128	2418	RWDHV	1901	904	20.04
2129	2179	MSHLN	0005	1575	20.02
2130	366	MESQW	1804	1272	19.97
2131	2019	EULES	8731	1417	19.96
2132	2477	PWEST	1310	224	19.92
2133	109	BLTON	1806	298	19.89
2134	1739	PCUST	2012	1806	19.88
2135	1310	CKRHL	0005	1214	19.83
2136	1667	HKHTS	1607	853	19.79
2137	2776	LVBRD	0001	35	19.74
2138	152	MDWCK	0004	1687	19.73
2139	171	ODESA	0212	1653	19.70
2140	2195	LIGSW	1603	2484	19.65
2141	701	BLKST	1781	1894	19.61
2142	1885	LOMAL	0002	632	19.61
2143	775	DESPR	1403	1655	19.60
2144	1184	ARCTY	1321	899	19.59
2145	898	TMPNW	1103	484	19.59
2146	1830	NCRST	2203	1076	19.56
2147	2360	ODNTH	2033	616	19.52
2148	1179	PRCRK	0001	161	19.51
2149	584	EULES	8712	1037	19.45
2150	909	KLBRG	0001	1510	19.35
2151	2040	BMTWN	1621	1203	19.33
2152	1468	MDLNW	1552	2429	19.30
2153	1787	FRNKF	0003	488	19.29
2154	2801	WWEST	1221	18	19.28
2155	1641	LKBLT	2101	1507	19.27
2156	1538	MESTE	1215	1314	19.24
2157	2287	SWDTN	1631	1517	19.22
2158	1129	MESQT	1307	592	19.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2159	2252	ESKSW	2711	109	19.08
2160	2259	ARLNG	1222	103	18.96
2161	2483	PRKRW	3382	176	18.89
2162	1016	GLNHV	3983	1942	18.87
2163	2285	CNEXP	0002	797	18.85
2164	2172	WFNTH	0221	582	18.81
2165	204	CRLJL	1504	1211	18.76
2166	2640	ANDNR	2231	1616	18.75
2167	1146	HMTRD	0003	388	18.68
2168	2648	ENTOH	0008	85	18.64
2169	2324	CRLJL	1502	352	18.55
2170	1738	CPRCV	1401	1948	18.48
2171	1455	BNMNW	1101	188	18.45
2172	793	CDCSW	0005	1732	18.42
2173	217	CDCSW	0003	663	18.41
2174	1405	REYST	4040	565	18.34
2175	2461	LWSNR	2221	1064	18.29
2176	2668	HKBRY	1103	46	18.26
2177	1653	MDWCK	0006	884	18.21
2178	2271	MDDTN	4321	887	18.20
2179	2083	CPRCV	1405	1491	18.06
2180	323	PFLGV	2004	2816	18.05
2181	1654	ARMST	0004	806	17.99
2182	2240	HRSMD	1957	2348	17.98
2183	520	KLNPS	1101	2128	17.87
2184	1278	IRVNE	1309	1130	17.87
2185	811	LOMAL	0010	1549	17.85
2186	2150	ITSCA	1702	220	17.80
2187	1273	RKDLE	1301	1022	17.80
2188	1182	CMPST	0001	422	17.78
2189	1104	IRVNR	1508	1896	17.70
2190	2142	MESTE	1208	804	17.66
2191	524	ARTHR	0462	1066	17.62
2192	2006	WCOLO	1316	1900	17.62
2193	2555	COPEL	3051	191	17.58
2194	690	BRKRG	0213	1423	17.56
2195	1127	GRFRD	1002	363	17.50
2196	2080	HKHTS	1601	1499	17.44
2197	340	LNCST	1604	557	17.41
2198	1403	MSTLT	1021	1307	17.37
2199	1467	MDLNE	0141	2671	17.36
2200	1531	FRMBG	1707	417	17.36
2201	2525	WFNTH	0241	728	17.32
2202	1578	SORCY	0003	805	17.30
2203	1822	DNCNV	1906	389	17.25
2204	2425	GODRD	8141	851	17.17
2205	98	BRHLW	7651	1083	17.17
2206	2781	NCSTH	1505	13	17.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2207	2141	WWEST	1218	977	17.15
2208	1051	SHMNE	1405	777	17.11
2209	1566	BSPSW	0822	318	17.11
2210	2131	SMPST	0004	1524	17.07
2211	1457	WOVER	6131	2487	17.06
2212	232	CRSWS	1402	921	17.01
2213	N/A	RNGLF	8331	10	17.00
2214	2646	GNSVL	1213	705	16.97
2215	1238	JKSBR	1401	945	16.84
2216	348	BRKRG	0223	251	16.82
2217	2217	BBTWN	1502	1687	16.80
2218	2210	CRTLD	4712	1137	16.80
2219	2488	FRMBR	1806	167	16.78
2220	1176	HLSES	0542	1084	16.74
2221	2336	BKBNT	1842	501	16.73
2222	149	WTAUG	4623	716	16.71
2223	228	SLBLF	1201	138	16.70
2224	2025	MDTHS	1003	1015	16.68
2225	1616	BRNAV	0762	2295	16.66
2226	687	PPARK	1803	986	16.61
2227	2281	PRKWY	1521	1848	16.58
2228	1492	RCHHL	0353	1675	16.53
2229	2030	LKMNT	0004	1989	16.34
2230	2164	AIRPK	8411	751	16.30
2231	1619	PALRD	2204	673	16.29
2232	1596	TYRSW	1701	2148	16.25
2233	474	CRANE	0331	1102	16.23
2234	953	KLELM	2205	2921	16.12
2235	1694	IRVNR	1553	1283	16.11
2236	1414	BSPRG	1902	2141	16.07
2237	1929	LORAN	9711	391	16.03
2238	2442	CNTRD	0003	1383	15.98
2239	1870	PALRD	2207	1096	15.85
2240	1868	WSANG	2801	1290	15.80
2241	1712	WXHCH	1203	1206	15.72
2242	1318	MKNGB	5331	1754	15.72
2243	1309	VANAL	1201	570	15.71
2244	538	TYBLR	2805	1933	15.69
2245	1639	MDWPK	9231	2359	15.66
2246	1812	PALRD	2201	783	15.60
2247	1501	WSOTH	1021	3148	15.60
2248	2331	PFLGV	2002	1941	15.57
2249	1889	GORMN	0411	450	15.56
2250	1826	BBTWN	1501	1954	15.54
2251	2562	DALWT	2941	263	15.51
2252	2447	BRKNR	1221	204	15.49
2253	2390	EDGCF	2221	727	15.46
2254	1733	DESPR	1406	931	15.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2255	2034	GAVSW	0001	1076	15.37
2256	1142	MDLNW	1592	1655	15.29
2257	780	DUBLN	2214	719	15.28
2258	2016	BSPRG	1901	539	15.26
2259	397	FROKS	0005	1317	15.23
2260	1973	PCUST	2003	1021	15.22
2261	2003	GVODS	3072	2220	15.22
2262	294	TYBLR	2806	202	15.19
2263	1993	STAUG	0008	1948	15.18
2264	1515	RDLML	2591	1343	15.10
2265	1911	FLMSO	3711	2033	15.07
2266	1841	PFLGV	2005	3163	15.04
2267	1737	RCLNS	1406	526	15.03
2268	1281	KNLTR	0005	2408	14.95
2269	2239	TRLSW	1202	57	14.93
2270	2133	CHROW	0001	125	14.93
2271	1275	FRNKF	0006	2140	14.92
2272	827	VALVW	1802	408	14.91
2273	1369	INAIR	1414	1098	14.89
2274	817	DALRK	1326	2453	14.84
2275	2356	TRLSW	2401	16	14.81
2276	951	CMPST	0003	216	14.81
2277	921	REAST	1501	303	14.79
2278	1887	RDOAK	1303	709	14.75
2279	2761	GNSVN	1401	24	14.75
2280	2411	FSTVW	0005	1609	14.71
2281	341	ATHNW	1402	383	14.70
2282	2713	BKWST	0007	1637	14.66
2283	205	RENSW	3122	91	14.56
2284	2184	WMMMR	2708	240	14.54
2285	2531	PSHIL	1606	374	14.50
2286	1287	MSTLT	1073	197	14.46
2287	743	CRTLD	4722	3224	14.42
2288	895	HLSBR	1204	546	14.40
2289	1903	BSPRW	2552	886	14.39
2290	83	WMRNR	0002	266	14.39
2291	1426	PLSTN	1005	1883	14.38
2292	1825	CRLTN	1408	125	14.38
2293	69	DCDAM	2003	1528	14.37
2294	868	HSKAV	0008	776	14.28
2295	1342	CMTSW	0921	1848	14.25
2296	2143	PTENN	2354	2522	14.20
2297	1615	WFALS	0193	2285	14.14
2298	2386	KLNPS	1102	1804	14.08
2299	1319	GPLND	1201	670	14.06
2300	1895	WMRLD	0009	18	14.06
2301	781	MESQT	1302	978	14.04
2302	N/A	CURIE	7222	534	14.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2303	2209	NMAIN	0241	673	13.94
2304	2113	CURIE	7211	248	13.94
2305	1579	HMTRD	0001	951	13.93
2306	2024	PCUST	2001	489	13.92
2307	387	ARTHR	0452	626	13.90
2308	2738	CHROW	0006	65	13.88
2309	2246	WRBND	2321	1562	13.80
2310	2599	DAVIS	3733	363	13.76
2311	2232	CLBNR	1407	267	13.75
2312	1966	MDWPK	9211	1229	13.68
2313	2420	CRLTN	1451	288	13.62
2314	2500	TMPNW	1101	2252	13.61
2315	563	PCUST	2007	1445	13.57
2316	2013	TMNTH	1601	27	13.56
2317	N/A	BTRTD	7312	1504	13.53
2318	479	TNSCL	1104	197	13.50
2319	1670	CMTSW	0962	613	13.50
2320	1780	PLANO	1102	126	13.44
2321	1523	STAUG	0006	1890	13.36
2322	2516	BDFWD	8932	1661	13.34
2323	2532	ARTHR	0411	720	13.33
2324	2203	ROWLT	1105	1019	13.31
2325	1816	SMFLD	2343	746	13.26
2326	1524	FARON	4031	1132	13.26
2327	1958	ARLNG	1271	2093	13.24
2328	2121	ANDNR	2242	1618	13.23
2329	367	ROWLT	1103	942	13.18
2330	16	WCITY	2402	684	13.12
2331	19	JKREA	1201	28	13.07
2332	2661	AMLIA	0008	138	12.99
2333	2586	WATSN	5352	1805	12.94
2334	N/A	ATHNS	1202	765	12.94
2335	2683	RRSTH	1708	3894	12.90
2336	1105	ARLNG	1212	130	12.88
2337	2082	FRNKF	0004	992	12.84
2338	2127	WNRTH	1418	1722	12.82
2339	2620	DALWT	2972	230	12.71
2340	2264	KNEDL	6321	2288	12.69
2341	2231	SNYDR	1833	1380	12.67
2342	1122	WELRD	0006	736	12.67
2343	2499	MESTE	1211	2509	12.64
2344	2168	ABBOT	1902	114	12.55
2345	1759	MKNSW	2603	913	12.49
2346	2107	CRLTR	2005	669	12.49
2347	2091	PNTGO	7111	693	12.44
2348	2506	HMPHL	2791	34	12.44
2349	2608	JNKNS	0005	506	12.44
2350	2309	SORCY	0001	2403	12.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2351	1607	OKCLS	0003	1411	12.36
2352	1567	BLTON	1801	892	12.35
2353	810	SANSM	3911	1212	12.34
2354	2669	CKRHL	0003	224	12.31
2355	1962	LAVON	1404	859	12.30
2356	1650	PTENN	2352	1579	12.28
2357	2152	CURIE	7231	1359	12.28
2358	1590	MAPLE	0005	1620	12.28
2359	591	CPRCV	1406	1549	12.26
2360	1862	HKHTS	1605	1343	12.23
2361	112	HOLDY	0921	574	12.23
2362	1845	TEGMN	3040	755	12.21
2363	2472	DLEON	0111	595	12.18
2364	1162	WTAUG	4632	1153	12.18
2365	2140	IRVNR	1552	57	12.18
2366	648	PLGRV	0004	1604	12.16
2367	2705	ODESA	0221	270	12.15
2368	2302	RWALS	1852	1640	12.14
2369	1134	MKNNY	1201	1258	12.12
2370	1021	PFFRD	3472	1252	12.05
2371	935	DNISN	1206	891	12.03
2372	570	NCSFA	1702	832	11.92
2373	2160	DGNST	0001	72	11.78
2374	2618	FRNKF	0007	1154	11.77
2375	916	PRCTR	1601	205	11.77
2376	2037	PNTGO	7121	836	11.76
2377	756	WALST	0010	339	11.73
2378	2654	LVBRD	0005	1272	11.73
2379	2074	RTHGB	1411	2250	11.69
2380	395	FRMBG	1751	732	11.67
2381	2156	KLNPS	1104	1271	11.63
2382	852	CRLTN	1402	502	11.63
2383	2569	CLCTY	1031	1232	11.47
2384	2149	WALST	0013	366	11.43
2385	2697	IRVVV	2803	146	11.42
2386	2554	PPARK	1804	240	11.40
2387	2014	WFALS	0153	1151	11.39
2388	1886	HRSMD	1955	1461	11.37
2389	1963	PCOIT	1006	1016	11.34
2390	2605	KNLTR	0004	1920	11.33
2391	25	GODRD	8132	1534	11.33
2392	2727	MAPLE	0001	578	11.26
2393	1767	RGLRW	0006	33	11.21
2394	2018	HKHTS	1604	809	11.13
2395	2670	PLANO	1106	413	11.07
2396	1337	SHSTH	1301	1929	11.06
2397	2381	PCOIT	1025	2879	11.04
2398	216	CPLSO	4322	181	10.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2399	750	PLANO	1101	308	10.87
2400	2504	KLNTF	1802	791	10.79
2401	1480	WHITE	3531	1858	10.68
2402	998	SACRC	5521	93	10.65
2403	2148	WFALS	0174	1243	10.63
2404	2072	BKBNT	1811	683	10.62
2405	2192	OAKHL	3041	871	10.61
2406	200	PALMR	2201	54	10.59
2407	2344	FROKS	0001	1296	10.57
2408	451	MLDR2	1605	640	10.56
2409	1754	WEAST	0619	2231	10.55
2410	2748	DFWSW	2204	20	10.50
2411	1107	BLMND	3262	122	10.46
2412	2202	RSNHT	1142	815	10.45
2413	2154	MURPH	2754	1040	10.40
2414	2666	HNYGR	2402	161	10.40
2415	2479	CRSCN	1201	800	10.36
2416	568	ENTOH	0005	1069	10.35
2417	675	FROKS	0003	483	10.27
2418	1084	LMBLN	0008	118	10.25
2419	1768	SYCRK	4511	1872	10.21
2420	1308	SIKES	2411	2027	10.20
2421	2238	BNDRA	0005	793	10.15
2422	2560	DENAV	0652	39	10.03
2423	1941	WXHNW	2901	175	10.01
2424	2481	BRKRG	0211	296	10.01
2425	1722	WWEST	1222	152	10.01
2426	1477	LVBRD	0004	990	9.97
2427	2153	CTYVW	2221	1834	9.93
2428	1701	WWEST	1220	187	9.90
2429	2518	TMNTH	1604	51	9.82
2430	2318	SNYDR	1823	1366	9.81
2431	111	CHICC	1701	50	9.72
2432	355	WHTRK	0006	1247	9.68
2433	147	WMRNR	0001	169	9.67
2434	2033	MTLDA	0005	1544	9.66
2435	442	CRSCN	1202	638	9.63
2436	2503	CRNTH	2403	1854	9.52
2437	1858	RNDRK	1506	1644	9.51
2438	1828	FRMBG	1753	1112	9.49
2439	2260	TMPLE	1206	712	9.43
2440	726	PRSTN	0004	652	9.43
2441	1949	CKRHL	0007	230	9.41
2442	2144	WRTHM	5004	233	9.39
2443	1592	MNWLL	1205	438	9.38
2444	2476	DALWT	2921	258	9.37
2445	2208	BRKRG	0221	709	9.36
2446	819	WALST	0003	127	9.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2447	2462	TYLER	1001	156	9.29
2448	2570	WEBBS	8623	2214	9.25
2449	2317	HMPHL	2723	32	9.19
2450	2214	LTVSB	5461	765	9.18
2451	2724	ALPHA	0002	1200	9.09
2452	2632	BSPSW	0812	808	9.06
2453	2405	HRSMD	1951	3863	9.03
2454	2751	DFWSW	2209	22	9.00
2455	1635	FSTVW	0002	147	8.97
2456	1435	NCSFA	1706	969	8.97
2457	1103	PSHIL	1601	1388	8.96
2458	2649	RWDHV	1908	1846	8.93
2459	2346	AMLIA	0007	79	8.92
2460	404	BRYAN	0002	451	8.88
2461	1078	HMPHL	2792	423	8.88
2462	892	EMPCT	0004	349	8.87
2463	1240	WSOTH	1019	713	8.86
2464	1968	BLTLN	0004	665	8.83
2465	1087	SHDYG	7841	337	8.81
2466	2291	BRHLW	7612	691	8.76
2467	392	PLKST	0005	1463	8.73
2468	2236	MSTLT	1063	932	8.73
2469	1420	CPRCV	1403	1405	8.64
2470	2408	RSPCK	2106	347	8.57
2471	1545	CRLTN	1404	96	8.46
2472	483	NPKWY	0013	4037	8.39
2473	2470	BKBNT	1821	1169	8.32
2474	1041	RRSTH	1706	2878	8.27
2475	2138	ARMST	0009	1057	8.18
2476	1972	LEMON	0001	1969	8.14
2477	1015	IRVNE	1302	412	8.12
2478	2419	CLBSN	8821	53	8.09
2479	160	WEBBS	8613	2936	8.09
2480	N/A	KLNSO	4502	1503	8.08
2481	1755	PJPTR	3211	111	8.08
2482	1947	DGNST	0007	186	8.08
2483	882	RCLNS	1407	1670	8.06
2484	N/A	CDHCR	2054	1323	8.00
2485	2639	WEBBS	8631	2933	7.98
2486	1346	VLYRN	2955	3731	7.96
2487	2471	BSPSW	0841	1997	7.95
2488	N/A	RWALE	3326	2155	7.91
2489	2105	MNWLW	1402	1522	7.90
2490	1234	LMBLN	0004	47	7.87
2491	1798	MSLMN	4009	202	7.84
2492	1646	NMAIN	0231	315	7.83
2493	2766	JNKNS	0001	15	7.80
2494	2434	KLELM	2201	1701	7.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2495	225	DENDR	0005	397	7.71
2496	2404	JUDCT	0001	1350	7.66
2497	1681	RCHHL	0344	1076	7.56
2498	2621	HURST	1852	1439	7.46
2499	2145	TMPTV	2404	1317	7.42
2500	1724	GAVSW	0010	485	7.37
2501	2543	LOMAL	0004	1055	7.29
2502	1527	CDHIL	1805	601	7.28
2503	1132	MESQT	1301	1419	7.28
2504	2334	LOMAL	0009	1053	7.16
2505	2265	BRHLW	7622	1259	7.15
2506	1626	WCOLO	1320	652	7.02
2507	2286	RDRSE	2604	2129	6.97
2508	N/A	GRHWY	5521	870	6.97
2509	2475	BLMED	1618	37	6.95
2510	2380	ARLNG	1251	488	6.94
2511	2542	MDLNW	1573	880	6.91
2512	2551	JNKNS	0004	90	6.88
2513	2385	BSPRG	1904	1635	6.87
2514	2513	GRLRD	0004	1537	6.80
2515	468	QNLAN	1202	376	6.79
2516	2304	ODESA	0261	1438	6.79
2517	608	BSPRG	1905	1488	6.77
2518	2613	BOWEN	3142	1032	6.73
2519	2315	LKBLT	2103	1306	6.69
2520	2719	CNEXP	0001	189	6.69
2521	1355	WNTHW	1119	1303	6.62
2522	1218	THRNE	0001	1106	6.59
2523	2048	TMPSE	1503	676	6.54
2524	1979	MSTLT	1042	434	6.52
2525	2665	ALNTH	2854	1911	6.40
2526	1111	BRYAN	0005	2692	6.34
2527	2134	ARTHR	0481	1261	6.27
2528	952	HORNE	1933	1981	6.16
2529	2062	BRYAN	0001	16	6.13
2530	2473	ENTOH	0002	793	6.11
2531	2069	RWDHV	1904	507	6.05
2532	1948	BRHLW	7611	1603	6.01
2533	2519	IRVVV	2802	2181	5.89
2534	2068	DENAV	0673	56	5.84
2535	2482	IRVNR	1559	2259	5.80
2536	2297	CTYVW	2211	1462	5.80
2537	1385	BLSRA	1602	154	5.77
2538	2577	DAVIS	3731	742	5.77
2539	1819	PCOIT	1007	843	5.76
2540	230	RSPVY	1708	933	5.74
2541	2582	PROAD	0005	120	5.72
2542	2298	WWEST	1216	246	5.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2543	414	DESPR	1401	1596	5.59
2544	679	RNDRK	1508	3811	5.52
2545	2341	LIPAN	1303	263	5.50
2546	2514	TRNTY	7551	1756	5.49
2547	987	HLTOM	2411	1365	5.48
2548	1576	MKNNY	1253	93	5.46
2549	2463	MKNNY	1204	35	5.43
2550	1349	ADISN	1603	160	5.39
2551	2387	ARTHUR	0431	455	5.34
2552	2119	CRLTR	2007	1350	5.33
2553	1741	WXNTH	2308	516	5.30
2554	1518	AIRPK	8421	365	5.27
2555	2222	ALLNC	6411	44	5.27
2556	551	BSPRW	2511	725	5.26
2557	847	SSPNG	1203	774	5.22
2558	2626	TMSTH	1406	2227	5.22
2559	1570	FROKS	0007	1373	5.19
2560	894	HKBRY	1104	182	5.16
2561	672	FSTVW	0001	382	5.12
2562	1599	GSTHW	1611	681	5.10
2563	2345	ROBNW	1501	332	5.10
2564	1881	IRVNR	1557	3274	5.08
2565	2253	PRKWY	1552	530	5.06
2566	1904	DAVST	0001	533	5.06
2567	1338	REAST	1503	560	5.05
2568	544	FRNKF	0008	1162	5.02
2569	593	HLSES	0533	1226	4.92
2570	2691	ALPHA	0011	974	4.92
2571	1207	WFALS	0163	348	4.82
2572	2102	WNDWD	3631	304	4.81
2573	2464	FRMNT	0008	1736	4.77
2574	1068	GRAHM	0713	401	4.77
2575	1442	CRNRD	0006	378	4.77
2576	2708	RECCR	0002	103	4.72
2577	1357	JEWET	1202	46	4.72
2578	2359	CHROW	0007	79	4.71
2579	371	CRSGL	1303	80	4.70
2580	2533	ATNRN	3411	2062	4.69
2581	2502	BNMNW	1102	376	4.63
2582	741	DEALY	0004	1289	4.61
2583	2579	IRLBJ	3211	2436	4.61
2584	1020	HMPHL	2733	117	4.57
2585	2568	CNEXP	0006	1130	4.55
2586	1785	ALNTH	2831	901	4.51
2587	1697	TYLER	1010	52	4.50
2588	1848	CRNRD	0005	220	4.50
2589	1645	ENTOH	0001	734	4.48
2590	2215	ALLEN	2401	2196	4.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2591	2637	ROLTR	2911	1740	4.37
2592	1036	WDGWD	1561	1473	4.32
2593	2647	RDRSE	2603	3282	4.31
2594	1386	RRNES	2407	1338	4.28
2595	784	WICKT	0411	114	4.28
2596	511	MDLNE	0172	1208	4.23
2597	960	NPKWY	0014	5945	4.22
2598	N/A	EGFRD	0004	1796	4.19
2599	2487	SYCRK	4531	4209	4.18
2600	1872	MDWCK	0003	1858	4.15
2601	1506	TRLSW	1204	589	4.15
2602	2120	LKBLT	2107	781	4.14
2603	1696	PJPTR	3222	170	4.04
2604	2316	GAVSW	0002	810	3.99
2605	2529	ALPHA	0008	1238	3.89
2606	2438	KLELM	2202	1005	3.86
2607	2129	KNLTR	0006	519	3.82
2608	2426	TMPNW	1102	558	3.80
2609	1054	KERNS	2402	394	3.78
2610	2774	LSCOL	2142	13	3.77
2611	480	JUDCT	0004	155	3.75
2612	1347	BDFWD	8931	1715	3.75
2613	1574	SHAMP	0002	1539	3.73
2614	2163	RDRSE	2602	2663	3.69
2615	801	DGNST	0003	257	3.68
2616	2004	BLTON	1804	462	3.67
2617	1863	HORNE	1981	1496	3.59
2618	1964	ARTHR	0422	1031	3.54
2619	116	DEALY	0002	1130	3.53
2620	2573	CKRHL	0002	390	3.51
2621	2422	CRLUD	1306	24	3.50
2622	2797	WEAST	0621	116	3.49
2623	N/A	EXPKY	8112	15	3.47
2624	2537	WWEST	1217	97	3.40
2625	2591	FHLSW	1382	103	3.37
2626	496	RGLRW	0005	48	3.29
2627	1123	CRKET	2401	143	3.22
2628	2270	MDLNE	0151	269	3.16
2629	705	KLRPR	9011	2698	3.14
2630	2041	ARMST	0006	888	3.07
2631	1110	TYEST	1509	383	2.99
2632	2710	INAIR	1442	109	2.95
2633	999	DAVIS	3741	1161	2.95
2634	2383	MESFR	2103	341	2.95
2635	2254	ALPHA	0007	1371	2.91
2636	2777	MAPLE	0002	69	2.90
2637	1432	NPKWY	0012	1836	2.86
2638	2347	NCSTH	1504	66	2.85

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2639	2229	WFALS	0143	179	2.84
2640	136	GODRD	8161	2154	2.83
2641	454	VLYRN	2954	35	2.74
2642	1564	ARLNG	1291	83	2.71
2643	505	BNDRA	0003	808	2.70
2644	2717	KLNCC	1701	2057	2.64
2645	2561	WTAUG	4651	507	2.58
2646	2716	MAPLE	0004	115	2.57
2647	613	FSTVW	0008	1609	2.54
2648	273	BEAST	4088	122	2.48
2649	1237	GAVSW	0008	118	2.38
2650	2657	LWSNR	2211	815	2.36
2651	N/A	SWTWR	1321	57	2.33
2652	2548	BLMND	3282	76	2.33
2653	90	LFSTH	1405	216	2.30
2654	1033	KNEDL	6342	525	2.30
2655	1999	WALST	0004	51	2.29
2656	2587	FRMBR	1802	1105	2.28
2657	1422	THRNE	0003	1212	2.28
2658	1717	JNKNS	0008	47	2.28
2659	377	CRLTR	2006	51	2.27
2660	1951	MDLNE	0133	277	2.24
2661	2619	CRLFR	2154	3094	2.22
2662	2743	COTRD	0003	29	2.21
2663	2545	MSLSW	0002	1013	2.15
2664	2760	FRMNT	0007	266	2.14
2665	1588	HLTOM	2461	622	2.12
2666	2676	HKBRY	1109	52	2.12
2667	2262	CMTSW	0915	673	2.10
2668	2294	SHDYG	7831	91	2.07
2669	2698	ALPHA	0016	1691	2.06
2670	2162	PFLGV	2007	2041	2.05
2671	N/A	HHSTH	1504	4141	2.05
2672	1381	SCHRD	0008	71	2.04
2673	2660	DGNST	0004	636	2.04
2674	1157	GAVSW	0006	509	2.00
2675	2667	RSPVY	1702	467	1.96
2676	1869	DGNST	0005	115	1.96
2677	2598	FRMNT	0011	44	1.84
2678	2610	PJPTR	3212	79	1.82
2679	2378	REAST	1507	111	1.82
2680	545	LOMAL	0006	1122	1.75
2681	2327	BDFWD	8922	2166	1.74
2682	2753	EMPCT	0005	65	1.72
2683	2603	RSPCK	2133	135	1.71
2684	1149	BRNWD	1206	1324	1.71
2685	832	TNPON	0001	74	1.69
2686	2196	BSPSW	0832	397	1.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2687	2522	PROAD	0007	399	1.62
2688	1202	WHTRK	0007	1228	1.61
2689	1300	HORNE	1923	1553	1.57
2690	2728	FRMNT	0004	1790	1.53
2691	1276	PROAD	0006	117	1.50
2692	2602	CKRHL	0001	406	1.45
2693	578	GNSVN	1403	281	1.40
2694	2636	RGLRW	0002	210	1.38
2695	1256	BKWST	0004	1054	1.37
2696	1925	CKRHL	0006	65	1.37
2697	2606	PARIS	1205	28	1.36
2698	642	STHRL	0007	270	1.35
2699	2643	CURIE	7241	462	1.34
2700	830	CRLJL	1508	289	1.34
2701	165	COPER	0401	135	1.30
2702	2433	PLSTH	1303	551	1.27
2703	2740	CLBWS	8112	1196	1.26
2704	2465	PPARK	1802	1421	1.23
2705	1340	ENTOH	0004	1300	1.23
2706	2594	BKWST	0002	1400	1.20
2707	1516	WSOTH	1022	420	1.18
2708	693	CLLVL	0001	50	1.16
2709	2	FRNKS	1202	85	1.15
2710	2547	BDFWD	8941	617	1.12
2711	1522	LMBLN	0003	166	1.11
2712	2244	MNSTR	1202	263	1.05
2713	2604	WATSN	5372	1321	1.05
2714	2017	WALNT	0002	1179	1.04
2715	1907	IRVND	1206	96	0.97
2716	2576	CHROW	0002	105	0.95
2717	463	PTENN	2358	1156	0.94
2718	2718	CKRHL	0004	296	0.92
2719	2737	BRYAN	0007	267	0.92
2720	1307	REGST	0003	913	0.92
2721	2674	JNKNS	0002	163	0.91
2722	749	ARMST	0005	1466	0.90
2723	1451	MSTLT	1011	87	0.90
2724	1161	GRLRD	0001	1732	0.87
2725	2664	PSHIL	1605	122	0.86
2726	2645	RRSTH	1707	349	0.84
2727	2428	GSTHW	1613	89	0.81
2728	2416	WRTHM	5017	176	0.76
2729	1605	HKBRY	1102	1360	0.73
2730	2658	FRMNT	0003	273	0.72
2731	2558	IRVVV	2804	917	0.68
2732	N/A	BNBOR	1203	334	0.67
2733	1404	MTLDA	0007	1166	0.65
2734	2523	ARMST	0003	632	0.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2735	289	PROAD	0009	104	0.52
2736	2703	RSPCK	2103	1901	0.51
2737	2675	WMMMR	2705	548	0.45
2738	N/A	KLNSO	4501	3726	0.45
2739	2767	JNKNS	0006	493	0.44
2740	2659	PSHIL	1607	445	0.44
2741	604	ALPHA	0001	418	0.42
2742	2692	ALPHA	0006	289	0.35
2743	2534	LEMON	0009	1857	0.30
2744	1354	BNDRA	0002	550	0.28
2745	2494	FARON	4021	283	0.27
2746	2611	COMRC	1202	48	0.23
2747	2446	FRMBG	1750	1136	0.21
2748	2556	WMRNR	0003	572	0.19
2749	1329	LEMON	0002	687	0.15
2750	2711	PROAD	0008	1001	0.12
2751	1139	BNDRA	0004	716	0.11
2752	2721	SHDYG	7832	1816	0.09
2753	938	ALLEN	2405	138	0.09
2754	1898	PWEST	1304	958	0.05
2755	2644	ARMST	0002	1087	0.05
2756	2314	LSCOL	2137	684	0.02
2757	2635	ABBOT	1901	113	0.00
2758	2729	AIRPK	8431	18	0.00
2759	N/A	ALNSW	2656	10	0.00
2760	2731	ALPHA	0004	20	0.00
2761	2732	ALPHA	0005	126	0.00
2762	1048	AMLIA	0003	21	0.00
2763	2733	ARMST	0007	95	0.00
2764	2690	ARTHR	0492	52	0.00
2765	N/A	ATNRN	3422	77	0.00
2766	792	BKWST	0001	382	0.00
2767	2128	BKWST	0006	718	0.00
2768	N/A	BOWIE	0621	10	0.00
2769	1880	BRHLW	7641	22	0.00
2770	75	BRNAV	0741	138	0.00
2771	2741	CLLVL	0003	18	0.00
2772	2497	CMTSW	0914	84	0.00
2773	2407	CNEXP	0003	1400	0.00
2774	2288	COTRD	0008	1037	0.00
2775	2744	CRLUD	1301	15	0.00
2776	2745	CURIE	7212	11	0.00
2777	1827	DAVST	0008	14	0.00
2778	2528	DENDR	0009	49	0.00
2779	2319	DFWNW	2601	51	0.00
2780	905	DFWNW	2602	35	0.00
2781	2746	DFWNW	2606	22	0.00
2782	1901	DFWNW	2610	50	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2783	2747	DFWSW	2203	22	0.00
2784	2749	DFWSW	2207	22	0.00
2785	2756	FRMBG	1704	35	0.00
2786	2617	FRMBG	1708	45	0.00
2787	410	FRMBG	1752	125	0.00
2788	509	FRMBR	1853	265	0.00
2789	2758	FRMNT	0001	1406	0.00
2790	2759	FRMNT	0005	176	0.00
2791	2630	FRMNT	0012	432	0.00
2792	N/A	GRHWY	5512	1672	0.00
2793	2714	GSTHW	1651	41	0.00
2794	2715	HKBRY	1115	13	0.00
2795	1804	HMPHL	2731	11	0.00
2796	2765	JKSNR	4107	19	0.00
2797	N/A	LEMON	0008	673	0.00
2798	460	LKWOD	7421	41	0.00
2799	2770	LOMAL	0007	134	0.00
2800	2772	LSCOL	2135	617	0.00
2801	2773	LSCOL	2140	277	0.00
2802	2641	MAPLE	0008	207	0.00
2803	2701	MCKMY	0821	693	0.00
2804	2678	MESQN	1506	56	0.00
2805	1602	MESQW	1805	83	0.00
2806	2778	MESTE	1201	22	0.00
2807	2505	MESTE	1203	169	0.00
2808	2779	MNWLL	1201	14	0.00
2809	2780	MRSES	4014	18	0.00
2810	1927	NCRST	2202	24	0.00
2811	2782	NMAIN	0252	253	0.00
2812	2595	NMAIN	0262	164	0.00
2813	2783	PJPTR	3231	26	0.00
2814	2364	PROAD	0001	125	0.00
2815	1932	PWEST	1306	290	0.00
2816	2785	PWEST	1309	52	0.00
2817	2218	RCLNS	1401	59	0.00
2818	1946	RDRSE	2605	644	0.00
2819	1006	RECCR	0005	154	0.00
2820	2188	RGFTW	6841	17	0.00
2821	N/A	RICES	0207	582	0.00
2822	N/A	RNKSX	5413	30	0.00
2823	2787	ROANW	9522	29	0.00
2824	2382	SHDYG	7812	121	0.00
2825	2060	SHDYG	7821	87	0.00
2826	2790	SMFLD	2362	59	0.00
2827	2791	SORCY	0002	63	0.00
2828	2792	STERT	2701	26	0.00
2829	1779	WALST	0002	42	0.00
2830	2795	WALST	0007	20	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2009 SAIDI Ranking	2008 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2009 SAIDI Value
2831	971	WALST	0008	15	0.00
2832	2796	WEAST	0620	78	0.00
2833	2798	WEBBS	8634	309	0.00
2834	1664	WMMMR	2704	16	0.00
2835	1120	WMMMR	2706	14	0.00
2836	2803	WXOCF	1402	12	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2009 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	11.00%
Vegetation	10.00%
Animals and Birds	13.00%
People (Including cars and farm equip)	18.00%
Utility-owned Equipment	21.00%
Other	23.00%
Unknown	4.00%