

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1726	792	NHNSW	0005	384	49.31
1727	2621	CRLUD	1306	25	49.28
1728	1358	MDLNW	1563	1256	49.27
1729	1782	LUFKN	1204	526	49.20
1730	1826	PFFRD	3492	534	49.18
1731	1217	EULES	8713	1500	49.10
1732	1468	PRKRW	3392	1570	48.90
1733	1754	BSPRG	1903	1601	48.87
1734	416	MTLDA	0001	2279	48.83
1735	2376	PNTGO	7121	1478	48.79
1736	4	TXHRV	1621	78	48.69
1737	1638	GRDPR	0862	916	48.68
1738	2038	PRFTW	4222	3015	48.67
1739	2077	KILEN	1205	1166	48.57
1740	2508	GRHWY	5521	873	48.56
1741	1095	ENTOH	0007	846	48.55
1742	961	KIMBL	5022	841	48.52
1743	269	DUVAL	0441	964	48.34
1744	1323	RBNSN	2504	1515	48.16
1745	406	RWALS	1851	648	48.09
1746	549	TYBLR	2803	776	48.09
1747	1269	PCUST	2008	627	47.94
1748	2022	GVODS	3062	1886	47.83
1749	1117	PCOIT	1024	2247	47.78
1750	2645	WTAUG	4651	508	47.73
1751	150	KLBRG	0002	1565	47.71
1752	2725	PSHIL	1605	121	47.68
1753	N/A	GSMTH	1742	31	47.68
1754	2708	CLLVL	0001	50	47.56
1755	2451	ALPHA	0002	1200	47.55
1756	318	LAVON	1452	1748	47.52
1757	54	LVOAK	1601	784	47.41
1758	1647	FINKS	1804	2169	47.37
1759	1557	HLTOM	2482	1143	47.35
1760	576	WITTS	1705	1190	47.27
1761	2152	MDLNW	1552	2445	47.26
1762	1310	ROGRS	1301	746	47.21
1763	1968	BLNKT	0701	275	47.17
1764	445	PRSTN	0005	1160	47.16
1765	1945	CMPWI	0002	1474	47.15
1766	1044	CRSCN	1205	791	47.06
1767	1059	IRVNE	1310	1354	47.01
1768	1234	VENSW	2603	24	46.96
1769	2500	GAVSW	0010	485	46.93
1770	2051	BDFWD	8911	932	46.83
1771	1112	EULSO	9141	205	46.71
1772	806	ELZCK	4911	89	46.67
1773	2197	LNCST	1604	616	46.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1774	1504	CRLTN	1407	1519	46.59
1775	216	CRANE	0321	21	46.55
1776	969	ELZCK	4921	1250	46.49
1777	1691	PCUST	2006	1596	46.48
1778	910	FHLSW	1351	1228	46.45
1779	284	SBEND	0611	144	46.42
1780	2244	TYBLR	2805	1932	46.31
1781	136	SANSM	3912	4831	46.29
1782	630	PPARK	1808	582	46.21
1783	892	MEXIA	4007	501	46.18
1784	128	EUSTC	2401	1690	46.13
1785	2366	PLGRV	0004	1598	46.10
1786	1382	GRDPR	0822	580	46.07
1787	1035	WDGWD	1581	643	45.97
1788	1076	CMNCH	1402	1153	45.93
1789	25	LVOAK	1602	791	45.92
1790	949	SMFLD	2392	1001	45.70
1791	1584	TYLER	1002	850	45.62
1792	2315	PCUST	2007	1386	45.62
1793	571	MDTHN	1701	1307	45.61
1794	1286	CMPWI	0003	1721	45.40
1795	319	MESQN	1505	1177	45.40
1796	1404	ARMST	0010	868	45.37
1797	2792	GRHWY	5512	2497	45.35
1798	1039	SMFLD	2341	923	45.27
1799	1306	CLMET	0001	1560	45.25
1800	1393	CPRCV	1402	2378	45.21
1801	2337	FRNKF	0004	993	45.20
1802	1251	DESHR	1201	944	45.15
1803	2170	CPRCV	1401	1906	45.14
1804	64	GPLND	1202	389	45.11
1805	1151	LKMNT	0007	1533	45.10
1806	239	CDCRK	1201	1493	45.02
1807	1896	PALMR	2202	933	44.98
1808	2538	DAVIS	3731	735	44.97
1809	1916	TROYS	1014	791	44.90
1810	1372	BRCRK	6514	550	44.65
1811	1846	KILEN	1201	1772	44.63
1812	895	CDHIL	1803	1409	44.60
1813	584	STANT	1322	119	44.58
1814	1392	MCWHT	3522	3194	44.51
1815	2663	MSLSW	0002	1023	44.47
1816	738	LAVON	1451	1460	44.33
1817	962	CDCSW	0004	1217	44.33
1818	459	MURPH	2752	2099	44.32
1819	2020	HURST	1822	1437	44.25
1820	1549	RWDHV	1902	954	44.10
1821	2290	WMRNR	0002	266	44.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1822	1453	LNCST	1602	1809	43.97
1823	1212	WHITE	3541	915	43.82
1824	1634	MSLSW	0006	101	43.81
1825	2475	ARMST	0009	1046	43.74
1826	1311	MESQW	1801	2069	43.67
1827	362	NAVCO	0001	24	43.67
1828	2119	SWDTN	1611	1534	43.58
1829	2443	MNWLL	1205	431	43.36
1830	348	SHMNE	1403	985	43.17
1831	1888	CDHCR	2052	1159	43.17
1832	1722	GODRD	8151	452	43.12
1833	1455	HUDSN	1605	1664	43.09
1834	850	CRLUD	1304	1087	43.07
1835	1992	DALRK	1303	1279	43.05
1836	1287	ECTHM	3321	2008	43.01
1837	2413	MURPH	2754	1050	42.97
1838	2297	WFALS	0193	2296	42.93
1839	199	WDGWD	1531	1468	42.84
1840	1510	TYWST	2001	154	42.65
1841	2616	BLTON	1804	464	42.60
1842	2131	EULES	8731	1417	42.55
1843	2633	DAVIS	3741	1243	42.50
1844	2326	FARON	4031	1133	42.50
1845	2171	BNMNV	1101	188	42.31
1846	1556	CNTRY	2851	1385	42.19
1847	1923	GLNHV	3963	1562	42.09
1848	605	HURST	1811	1093	42.05
1849	596	IRVBL	2507	790	42.03
1850	877	SHNRW	1610	426	42.03
1851	957	ADISN	1608	381	41.94
1852	993	CRTLD	4734	1816	41.91
1853	1863	RSNHT	1122	1871	41.81
1854	350	MYPRL	1803	468	41.81
1855	2210	SMPST	0004	1463	41.78
1856	2796	JKSNR	4107	19	41.69
1857	20	BRNWD	1201	1495	41.67
1858	147	BRNSO	1806	2043	41.63
1859	1013	WNDWD	3621	2200	41.61
1860	1757	CRLJL	1506	1734	41.58
1861	2377	WALST	0010	333	41.41
1862	1118	WNDWD	3611	1059	41.29
1863	750	PLGRV	0002	2085	41.26
1864	1176	GRDPR	0892	1310	41.25
1865	2480	KLNSO	4502	1779	41.21
1866	649	CDMIL	2401	560	41.08
1867	1560	SWTWR	1382	450	41.05
1868	214	CMTSW	0952	576	40.94
1869	2688	WHTRK	0007	1223	40.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1870	1671	ADISN	1604	1147	40.75
1871	1105	HLTOM	2442	1078	40.70
1872	990	MSLMN	4131	117	40.59
1873	2452	BSPSW	0812	804	40.56
1874	1753	PALRD	2206	1458	40.54
1875	1053	PCOIT	1023	2033	40.49
1876	1216	DNISN	1205	1481	40.45
1877	709	IRVGS	1907	779	40.43
1878	2184	IRVNE	1309	1120	40.43
1879	1337	LAVON	1406	1331	40.29
1880	2325	SMFLD	2343	743	40.23
1881	1657	PCOIT	1008	1246	40.23
1882	2744	BNDRA	0002	549	40.22
1883	1654	CRSWS	1403	2772	40.08
1884	1375	GRMES	0521	515	40.01
1885	1357	SANSM	3913	3000	40.00
1886	968	SHMNE	1401	1190	39.88
1887	1940	PFFRD	3462	1604	39.77
1888	543	BSPRW	2532	1593	39.70
1889	870	CRLFR	2153	547	39.64
1890	2544	RNDRK	1508	3935	39.60
1891	2272	VALVW	1802	409	39.59
1892	246	TMNTH	1603	122	39.57
1893	2565	PRKWY	1552	524	39.52
1894	2517	BSPRG	1905	1520	39.39
1895	2057	OKCLS	0008	1428	39.37
1896	1156	WHITE	3532	1324	39.28
1897	1836	CHICG	1402	526	39.25
1898	432	WBOSE	1103	866	39.09
1899	1505	FRSTN	1604	320	38.96
1900	2090	GRAHM	0721	1213	38.95
1901	2130	MESQW	1804	1284	38.94
1902	976	TYLNE	1613	390	38.90
1903	805	GRLND	1603	307	38.88
1904	1179	ENSSO	2004	1107	38.88
1905	1353	MKNNY	1251	1091	38.88
1906	689	PGSTH	7021	62	38.82
1907	1708	RCHHL	0332	1585	38.77
1908	1878	RECCR	0007	67	38.77
1909	1201	LKHLN	0004	1240	38.74
1910	964	ARMST	0008	238	38.74
1911	1748	GSTHW	1672	12	38.67
1912	1815	RNDRK	1505	1090	38.54
1913	834	WEAST	0627	110	38.41
1914	372	CRNTH	2404	2935	38.34
1915	1683	HSKAV	0007	1819	38.32
1916	2294	HSKAV	0008	775	38.23
1917	1632	KLNCC	1702	3379	38.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1918	1551	ALNSW	2653	3041	38.14
1919	839	HLTOM	2421	1634	37.99
1920	1978	DAVIS	3721	1315	37.95
1921	1690	ALPHA	0003	696	37.91
1922	930	DUBLN	1360	1058	37.77
1923	1790	MESQW	1802	768	37.74
1924	1064	WMRLD	0005	1584	37.72
1925	694	RCHHL	0384	685	37.67
1926	339	BRNAV	0784	2275	37.65
1927	1732	GSTHW	1623	2344	37.64
1928	1610	RNDRK	1507	1542	37.57
1929	2602	LKBLT	2107	1030	37.56
1930	2100	MTLDA	0003	1512	37.46
1931	2552	CRLTR	2007	1361	37.46
1932	1594	MDTHN	1702	1106	37.44
1933	2087	MESQW	1806	1585	37.43
1934	2178	MDDTN	4321	898	37.38
1935	950	ARLNG	1292	1543	37.36
1936	1579	RWALE	3324	1056	37.30
1937	1953	CRLTN	1405	1217	37.18
1938	1869	MESQN	1501	1754	37.14
1939	2127	IRVND	1204	1216	37.14
1940	226	NCSTH	1503	875	37.13
1941	2005	RCHHL	0321	1657	37.10
1942	2019	ROWLT	1107	362	37.07
1943	2382	CRLTN	1402	504	37.07
1944	1569	TMNTH	1602	475	37.05
1945	2247	WSOTH	1021	3200	37.04
1946	2647	FSTVW	0008	1674	37.02
1947	802	MESQN	1502	1744	36.95
1948	1587	CRSCN	1204	602	36.87
1949	2664	FRMNT	0007	267	36.85
1950	1855	MESQW	1807	1482	36.83
1951	887	WDGWD	1591	1151	36.82
1952	1597	TMPTV	2402	2517	36.69
1953	1884	MDTHS	1001	1031	36.63
1954	1332	ENNIS	1905	43	36.63
1955	2765	ATNRN	3422	111	36.57
1956	1704	SPRDL	4822	1344	36.33
1957	837	CRLTR	2001	2440	36.32
1958	2004	HRSMD	1907	2165	36.28
1959	1749	FARON	4072	1462	36.24
1960	1271	BRCRK	6524	789	36.11
1961	879	HMPHL	2743	684	35.93
1962	2531	RWDHV	1904	507	35.93
1963	1949	RCLNS	1402	514	35.89
1964	1660	MESTE	1206	1234	35.80
1965	1554	HORNE	1952	990	35.80

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1966	1581	CPRCV	1404	1558	35.65
1967	1857	MESTE	1202	760	35.59
1968	2829	WALST	0002	42	35.57
1969	2224	MDTHS	1003	1028	35.47
1970	1221	ROSCO	2921	214	35.44
1971	2134	PCUST	2012	1796	35.30
1972	1274	HUDSN	1602	153	35.27
1973	2589	ENTOH	0001	663	35.27
1974	984	TYLGE	1308	1547	35.03
1975	1668	ABRRD	0002	1367	34.87
1976	140	INAIR	1411	2023	34.84
1977	769	MURPH	2755	2514	34.77
1978	1585	SMPST	0003	970	34.72
1979	1167	MSLSW	0007	371	34.58
1980	2185	LOMAL	0010	1533	34.56
1981	1418	BNMAG	1201	187	34.40
1982	1394	WFNTH	0262	241	34.27
1983	1245	VLYRN	2953	2796	34.21
1984	2044	ARTHR	0441	1894	34.18
1985	2231	PALRD	2204	673	34.17
1986	2456	NCSFA	1706	1069	34.14
1987	2625	FHLSW	1382	94	33.96
1988	1572	SMPST	0001	2209	33.92
1989	1570	CRTLD	4714	1480	33.87
1990	2155	LKBLT	2101	1625	33.80
1991	1535	LKHLD	0002	1393	33.70
1992	1653	ARLNG	1282	833	33.70
1993	312	BLVUE	1111	378	33.64
1994	2597	NPKWY	0014	5937	33.59
1995	1977	BLTLN	0005	797	33.51
1996	980	WMMMR	2703	1540	33.51
1997	347	ODESA	0231	2102	33.51
1998	658	CLCRK	1011	188	33.51
1999	2539	PCOIT	1007	844	33.36
2000	2179	CPRCV	1405	1514	33.25
2001	525	ALNTH	2832	1223	33.23
2002	612	ROANW	9521	1247	33.17
2003	1288	PROAD	0002	826	33.07
2004	971	CMPST	0004	958	33.05
2005	391	PTENN	2357	636	32.92
2006	1736	BRHLW	7632	1464	32.92
2007	1536	SYCRK	4512	3085	32.89
2008	278	FRSTN	1602	1082	32.81
2009	340	BRNSO	1805	736	32.81
2010	78	RRWES	1601	529	32.79
2011	1784	PCOIT	1005	1097	32.76
2012	2088	COPEL	3052	1306	32.63
2013	1620	CMHBL	8121	54	32.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2014	125	MCGHR	2003	1262	32.53
2015	741	HURST	1882	1859	32.52
2016	306	MABNK	2404	2362	32.43
2017	2067	HSKAV	0005	1333	32.39
2018	91	FORSW	2015	1763	32.38
2019	1470	HORNE	1911	910	32.30
2020	2361	HOLDY	0921	575	32.30
2021	1751	DALRK	1307	1197	32.26
2022	2260	PCUST	2003	1022	32.17
2023	911	CRLTR	2054	91	32.16
2024	1892	IRVND	1203	348	32.11
2025	1861	BLTON	1805	1280	31.97
2026	126	HUDSN	1603	2101	31.82
2027	1304	ARLNG	1213	1302	31.75
2028	2162	GLNHV	3983	2217	31.65
2029	1139	WATSN	5331	1072	31.63
2030	2108	CPRCV	1407	1542	31.63
2031	2310	DAVIS	3733	375	31.56
2032	414	MYPRL	1801	118	31.54
2033	1285	RRNES	2402	4007	31.51
2034	1958	KERNS	2401	572	31.27
2035	550	CMTSW	0934	1519	31.21
2036	1731	TRNTY	7511	1059	31.16
2037	2425	WWEST	1222	152	31.16
2038	651	PRKRW	3372	1094	31.14
2039	320	IVANS	1612	982	31.14
2040	2356	PTENN	2352	1594	31.13
2041	327	BNTDR	0004	1626	31.05
2042	2052	FSHSW	2121	1707	30.98
2043	152	IRVNG	1404	1381	30.91
2044	2201	WFNTH	0241	703	30.88
2045	988	DUVAL	0452	1766	30.86
2046	1231	TATSP	4313	1600	30.74
2047	315	TAYLR	1203	1803	30.73
2048	2117	SHRSW	6612	1766	30.65
2049	1366	CLBRN	1203	1429	30.58
2050	220	IRVGS	1905	725	30.57
2051	2248	PFLGV	2002	1990	30.52
2052	2336	ARLNG	1212	134	30.26
2053	2292	CRLTN	1408	127	30.24
2054	1789	WATSN	5382	641	30.15
2055	1605	TMNTH	1606	224	30.05
2056	257	IVANS	1621	53	30.02
2057	1160	EUSTC	2402	721	30.02
2058	1370	DENAV	0683	836	30.01
2059	2404	BKBNT	1811	682	29.95
2060	313	HORNE	1942	1296	29.93
2061	1969	ATNRN	3421	575	29.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2062	1894	CRLTN	1406	1182	29.79
2063	2572	WNDWD	3631	305	29.78
2064	529	PRKRW	3321	142	29.77
2065	2629	KLRPR	9011	2709	29.73
2066	2037	EULES	8724	2135	29.68
2067	2010	TYOMN	1411	283	29.66
2068	2324	ROWLT	1105	901	29.64
2069	2420	SIKES	2411	1991	29.61
2070	2018	COMRC	1204	611	29.48
2071	617	WGROB	8422	4067	29.41
2072	2080	PCUST	2005	1717	29.40
2073	1349	MDWCK	0005	1380	29.30
2074	2321	STAUG	0006	1883	29.29
2075	2657	THRNE	0003	1220	29.25
2076	1249	RYSSW	2802	3350	29.11
2077	736	BRCRK	6521	1421	29.10
2078	1177	SMFLD	2333	1013	29.08
2079	462	BRNAV	0711	1568	28.98
2080	2551	ARTHR	0431	453	28.85
2081	936	PLKST	0004	1046	28.66
2082	2392	MAPLE	0001	581	28.62
2083	2354	CKRHL	0003	262	28.59
2084	1326	HORNE	1921	777	28.49
2085	355	MNWLE	1701	582	28.45
2086	2359	CPRCV	1406	1595	28.25
2087	9	GVGLF	9601	51	28.09
2088	2733	MTLDA	0007	1107	28.09
2089	N/A	HNTNG	1302	39	28.08
2090	2666	HKBRY	1109	51	28.02
2091	917	CTYVW	2212	140	28.01
2092	1694	RCHRD	1204	1088	27.93
2093	469	SHAMP	0006	1105	27.88
2094	2230	AIRPK	8411	762	27.79
2095	2579	CRSGL	1303	86	27.66
2096	1608	LKWOD	7432	1483	27.66
2097	637	MSLSW	0008	143	27.63
2098	1172	PLGRV	0001	1167	27.60
2099	1290	CNEXP	0004	876	27.57
2100	2259	FROKS	0005	1340	27.52
2101	708	LAVON	1402	60	27.47
2102	1800	GLNHV	3973	1289	27.42
2103	1435	RWALL	1201	1031	27.40
2104	545	NMAIN	0211	1885	27.38
2105	277	RTHGB	1421	1615	27.22
2106	1502	LFSTH	1404	490	27.09
2107	2646	MAPLE	0004	119	27.00
2108	2473	BKBNT	1821	1163	26.92
2109	2158	MESQT	1307	582	26.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2110	2427	CTYVW	2221	1854	26.88
2111	716	LOMAL	0016	647	26.83
2112	1010	PALRD	2203	981	26.83
2113	2601	TRLSW	1204	574	26.81
2114	2223	SLBLF	1201	124	26.79
2115	2381	KLNPS	1104	1273	26.72
2116	2661	CRLFR	2154	3096	26.67
2117	1871	BRHLW	7631	713	26.52
2118	1138	FRMBR	1805	748	26.52
2119	2542	WWEST	1216	250	26.49
2120	242	CRYVE	3011	279	26.48
2121	1965	KLNTF	1803	1040	26.44
2122	1822	SHMNE	1407	773	26.43
2123	921	RCHRD	1207	1388	26.25
2124	670	JSHUA	1301	1679	26.24
2125	1600	DFWSW	2202	37	26.11
2126	471	BRNSO	1808	698	25.98
2127	2755	ARMST	0002	783	25.93
2128	1345	GRLWS	1704	173	25.88
2129	2208	SHMNE	1405	779	25.83
2130	2364	WTAUG	4632	1166	25.67
2131	401	RNDRK	1509	4284	25.66
2132	929	MCDMT	2551	3409	25.61
2133	667	IRVBL	2502	168	25.56
2134	2707	WSOTH	1022	415	25.52
2135	640	DCVSO	1101	1421	25.52
2136	2118	DESHR	1204	1110	25.47
2137	2665	HLTOM	2461	632	25.44
2138	458	MESQN	1504	1139	25.25
2139	2295	CMTSW	0921	1826	25.17
2140	1779	PCOIT	1002	668	25.16
2141	1943	ROWLT	1101	950	25.12
2142	2116	SWDTN	1641	1578	25.12
2143	803	IRVNR	1551	1084	25.10
2144	228	GRDPR	0871	1504	25.10
2145	1596	TMPNW	1106	694	25.07
2146	2409	WEAST	0619	2270	25.04
2147	2217	BBTWN	1502	1691	25.04
2148	647	TLRWT	2201	1623	24.84
2149	1041	TYBLR	2804	2389	24.84
2150	1264	VGCRK	8011	1475	24.78
2151	1726	GSTHW	1641	84	24.75
2152	1767	EDGCF	2241	912	24.70
2153	1635	ALNTH	2844	1035	24.64
2154	514	RRNES	2404	4256	24.64
2155	2617	HORNE	1981	1505	24.49
2156	2322	BDFWD	8932	1664	24.47
2157	614	DESPR	1408	1775	24.45

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2158	1616	DALRK	1309	824	24.42
2159	712	TMPLE	1201	336	24.38
2160	41	IRVNE	1305	99	24.25
2161	186	WSTHL	3613	3280	24.23
2162	1101	PSHIL	1603	1501	24.22
2163	2390	KNLTR	0004	1923	24.20
2164	208	CRNRD	0007	721	24.18
2165	935	PFFRD	3411	268	24.13
2166	2242	MKNGB	5331	1806	24.12
2167	748	STAUG	0002	1304	24.03
2168	1938	RCHRD	1201	1234	24.02
2169	1764	CRLFR	2155	1339	24.01
2170	1798	REAST	1509	61	23.96
2171	2498	HURST	1852	1446	23.87
2172	1073	EULES	8722	2126	23.85
2173	1532	WTAUG	4622	873	23.84
2174	2204	GODRD	8141	853	23.84
2175	1983	DLEON	0131	705	23.82
2176	1670	ABRRD	0001	705	23.79
2177	428	ROLTR	2921	2456	23.75
2178	487	GRMES	0511	1170	23.72
2179	909	NHNSW	0001	448	23.67
2180	139	WATSN	5361	2443	23.65
2181	2221	BKBNT	1842	509	23.61
2182	730	MSHLN	0006	1101	23.49
2183	1743	REAST	1504	1305	23.48
2184	2543	DESPR	1401	1548	23.46
2185	762	BRCRK	6533	1774	23.43
2186	2074	MNWLL	1203	742	23.37
2187	1368	HMPHL	2762	1061	23.36
2188	2333	WATSN	5352	1866	23.28
2189	1970	RSNHT	1171	2202	23.27
2190	1887	BRHLW	7621	2348	23.15
2191	1721	BKWST	0005	815	23.03
2192	2094	BBTWN	1504	2007	23.01
2193	57	PAYSW	1203	816	22.95
2194	795	STAUG	0003	1684	22.86
2195	1903	CLCTY	1011	1129	22.86
2196	1542	JUDCT	0008	130	22.83
2197	1481	MDLNW	1531	1285	22.79
2198	2031	GVODS	3011	2283	22.69
2199	1309	BRCRK	6523	773	22.69
2200	2049	HURST	1841	142	22.65
2201	1185	GRAHM	0711	1601	22.65
2202	1555	VGCRK	8031	1782	22.63
2203	858	SCYEN	0004	1190	22.43
2204	1576	WFALS	0133	1643	22.43
2205	2510	ARLNG	1251	498	22.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2206	854	PFFRD	3431	578	22.37
2207	2690	FRMNT	0004	1665	22.36
2208	2335	RRSTH	1708	3990	22.35
2209	222	ARLNG	1261	1484	22.31
2210	2434	MTLDA	0005	1544	22.29
2211	2590	ALLEN	2401	2199	22.26
2212	1558	PWEST	1307	944	22.25
2213	2095	HMPHL	2721	488	22.24
2214	2043	MDDTN	4312	2023	22.17
2215	1000	MESQT	1306	956	22.16
2216	2540	RSPVY	1708	953	22.00
2217	1315	CMPWI	0001	1471	21.96
2218	2309	WRBND	2321	1567	21.95
2219	860	TRLSW	1201	591	21.94
2220	787	FROKS	0006	987	21.88
2221	2269	TRLSW	1202	56	21.84
2222	1464	SHAMP	0005	1638	21.77
2223	353	GNSVL	1204	500	21.71
2224	1092	PTENN	2351	1171	21.71
2225	1400	WEAST	0626	240	21.56
2226	1200	MESQT	1304	250	21.52
2227	1717	DALLW	0005	121	21.52
2228	2014	ODNTH	2024	2630	21.51
2229	2457	PSHIL	1601	1380	21.41
2230	916	RCHRD	1205	879	21.34
2231	2640	GODRD	8161	2219	21.33
2232	872	MSLSW	0003	188	21.32
2233	2121	PPARK	1807	874	21.26
2234	2314	TMPNW	1101	2308	21.26
2235	719	HRSMD	1905	2778	21.13
2236	308	CNSES	0750	1134	21.10
2237	1737	LNCST	1603	1445	21.09
2238	2344	ABBOT	1902	110	21.07
2239	987	CRLUD	1305	1139	21.04
2240	1982	HMPHL	2772	247	20.97
2241	370	ADISN	1602	218	20.91
2242	1989	WEAST	0628	227	20.88
2243	1802	ADISN	1605	1041	20.86
2244	1471	KILEN	1203	684	20.83
2245	2483	RCLNS	1407	1672	20.76
2246	2056	KLELM	2204	1921	20.67
2247	2828	STERT	2701	27	20.61
2248	1619	BSPRW	2521	1764	20.55
2249	2289	BSPRW	2552	880	20.39
2250	2293	DCDAM	2003	1537	20.39
2251	1662	WRTHM	5012	318	20.31
2252	2489	MNWLW	1402	1526	20.30
2253	474	PRSTN	0002	1338	20.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2254	2499	TMPTV	2404	1328	20.28
2255	1462	RRNES	2403	4969	20.25
2256	1509	COHMA	1132	47	20.16
2257	1873	WFNTH	0211	1154	20.15
2258	823	WFALS	0184	1294	20.14
2259	1525	IRVHF	2301	1260	20.12
2260	1240	SWAN2	1801	368	20.09
2261	2628	MDLNE	0151	280	20.09
2262	2329	ROWLT	1103	1058	20.03
2263	1714	SHRSW	6631	1232	20.01
2264	659	VENSW	2601	1172	19.89
2265	897	BRLSN	2013	1094	19.87
2266	2746	COMRC	1202	47	19.86
2267	188	CRNRD	0004	448	19.83
2268	2026	RANGR	4321	796	19.78
2269	1839	DESPR	1402	1666	19.76
2270	2195	GRFRD	1002	370	19.74
2271	1227	WDGWD	1523	287	19.69
2272	1419	KNLTR	0003	603	19.59
2273	N/A	BLPOD	1201	76	19.54
2274	2622	WEAST	0621	116	19.46
2275	2660	MDLNE	0133	283	19.44
2276	1054	IRVND	1202	1445	19.36
2277	1806	DALLW	0004	1209	19.32
2278	443	DAVIS	3752	501	19.28
2279	2091	DNCNV	1904	1442	19.26
2280	1022	SPRDL	4812	1223	19.25
2281	628	MSHLN	0003	534	19.23
2282	827	DALWT	2962	451	19.21
2283	2036	ODNTH	2073	601	19.21
2284	1918	MEXIA	4024	358	19.17
2285	2065	WBROK	3021	54	19.15
2286	77	DALWT	2992	333	19.12
2287	2313	CRLTN	1451	291	19.05
2288	1075	WATSN	5342	1962	18.98
2289	1313	MESFR	2105	1017	18.87
2290	2575	CRNRD	0006	351	18.85
2291	2608	TMPNW	1102	587	18.82
2292	1082	DUVAL	0473	1478	18.81
2293	495	PRFTW	4212	1954	18.64
2294	1830	ROSCO	2911	585	18.59
2295	423	SYCRK	4532	3829	18.50
2296	1583	WELRD	0007	437	18.46
2297	898	DALWT	2911	338	18.44
2298	2256	MDLNW	1592	1661	18.44
2299	533	COPEL	3055	2053	18.31
2300	1540	ADMDS	6521	1490	18.30
2301	1150	CDHCR	2055	1156	18.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2302	1775	BONHM	1204	824	18.23
2303	2430	SNYDR	1823	1365	18.19
2304	122	LFSTH	1402	1167	18.19
2305	2227	PRKWY	1521	2230	18.05
2306	2102	HNYGR	2403	125	17.96
2307	142	WEBBS	8622	1759	17.92
2308	1423	LVBRD	0008	1703	17.89
2309	1849	MSHLN	0002	605	17.84
2310	2304	CURIE	7211	548	17.84
2311	1882	CURIE	7221	595	17.80
2312	1879	STNVL	1205	1158	17.80
2313	2472	NPKWY	0013	3816	17.70
2314	1124	MESTE	1204	1699	17.55
2315	654	BRNWD	1203	767	17.50
2316	2403	WFALS	0174	1241	17.43
2317	2355	LAVON	1404	856	17.42
2318	1763	OKCLS	0006	1095	17.35
2319	2277	REAST	1501	296	17.34
2320	2229	LKMNT	0004	2049	17.32
2321	1445	TATSP	4322	2457	17.31
2322	923	RWDHV	1905	1195	17.22
2323	744	FSTVW	0007	1412	17.18
2324	273	BRLSN	2051	1019	17.12
2325	973	MRYNL	2111	27	17.02
2326	492	HSKAV	0002	1610	17.01
2327	2444	DALWT	2921	260	16.99
2328	1523	PSHIL	1602	1007	16.98
2329	1898	NHNSW	0004	549	16.87
2330	2554	AIRPK	8421	391	16.73
2331	2731	IRVVV	2804	916	16.68
2332	2101	BRIRV	6911	3084	16.64
2333	1457	RYSSW	2804	1561	16.62
2334	2176	HKBRY	1103	62	16.53
2335	2164	WFNTH	0221	577	16.50
2336	1019	ALPHA	0013	452	16.46
2337	2620	CKRHL	0002	385	16.45
2338	N/A	RKCRK	6111	726	16.44
2339	2371	DNISN	1206	872	16.40
2340	2160	ARLNG	1222	97	16.31
2341	2526	BRYAN	0005	2806	16.29
2342	1545	GLNHV	3922	706	16.29
2343	404	GSTHW	1633	929	16.28
2344	2525	ALNTH	2854	1914	16.23
2345	1971	SMFLD	2352	570	16.23
2346	2580	ATNRN	3411	2067	16.14
2347	2512	JNKNS	0004	125	16.13
2348	2407	FROKS	0001	1309	16.05
2349	562	DESHR	1206	2160	15.98

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2350	2739	JNKNS	0006	496	15.97
2351	1575	SWDTN	1621	753	15.94
2352	103	TYBLR	2802	982	15.91
2353	516	BRNWD	1205	1261	15.83
2354	1099	GRPVN	8213	1506	15.81
2355	403	BNTDR	0001	1203	15.69
2356	1825	LKWOD	7411	629	15.68
2357	1448	MNWLL	1204	275	15.62
2358	1812	DESPR	1405	522	15.43
2359	1260	VLVRN	2957	4684	15.38
2360	2536	CTYVW	2211	1478	15.35
2361	1247	RWDHV	1903	580	15.31
2362	2478	CLBSN	8821	52	15.30
2363	97	LFEST	1901	971	15.23
2364	2103	MRTNS	1501	475	15.22
2365	2703	CLBWS	8112	247	15.18
2366	1967	GRHWY	5522	2166	15.11
2367	2312	MDWPK	9211	1231	15.05
2368	2511	MDLNW	1573	1025	15.02
2369	2626	RGLRW	0005	49	14.91
2370	2607	KNLTR	0006	515	14.79
2371	438	RDLML	2552	276	14.79
2372	1602	MNWLW	1401	1464	14.70
2373	804	MSTLT	1084	640	14.65
2374	1052	GSTHW	1662	13	14.54
2375	2581	BNMNW	1102	382	14.52
2376	1292	HHSTH	1501	3687	14.50
2377	1734	CLCTY	1021	671	14.50
2378	1351	IRVHF	2303	85	14.44
2379	2675	RSPVY	1702	469	14.42
2380	1469	OKCLS	0001	692	14.38
2381	1378	WTAUG	4642	1292	14.38
2382	167	FARON	4082	1579	14.29
2383	2567	REAST	1503	560	14.28
2384	1060	WTHRF	2001	603	14.26
2385	2712	MNSTR	1202	254	14.25
2386	1444	CRLUD	1303	880	14.21
2387	109	STERT	2703	82	14.19
2388	2345	MKNSW	2603	1119	14.18
2389	1430	HLSBR	1202	1202	14.16
2390	2440	PRSTN	0004	653	14.13
2391	882	MSTLT	1032	32	14.11
2392	1163	MKNSW	1603	1246	14.09
2393	248	DNISN	1203	1590	14.09
2394	400	DAVST	0002	507	14.03
2395	2532	BRHLW	7611	1611	14.00
2396	589	KRUMS	1203	1641	13.99
2397	1526	ARTHR	0472	2054	13.98

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2398	2557	SSPNG	1203	788	13.88
2399	1819	EDGCF	2231	756	13.85
2400	2383	CLCTY	1031	1223	13.81
2401	2684	BRNWD	1206	1494	13.80
2402	2068	LWSNR	2212	1788	13.80
2403	928	BRYAN	0006	731	13.76
2404	2595	WICKT	0411	116	13.72
2405	2524	MSTLT	1042	141	13.72
2406	821	CRLTR	2052	1561	13.69
2407	2466	BRHLW	7612	687	13.61
2408	2669	ALPHA	0016	1705	13.59
2409	229	BRNSO	1807	204	13.55
2410	87	DNINR	1401	77	13.41
2411	1862	MDWPK	9221	764	13.40
2412	235	LKTMS	2411	120	13.27
2413	925	HMPHL	2713	53	13.23
2414	960	CHROW	0008	81	13.15
2415	2063	ALNTH	2853	2896	13.12
2416	1128	ADISN	1601	593	13.11
2417	211	HNYGR	0402	470	13.10
2418	1230	JNKNS	0003	979	13.04
2419	819	HSKAV	0004	1134	13.01
2420	2349	JNKNS	0005	504	12.88
2421	914	MNWLL	1202	672	12.84
2422	2586	ALNTH	2831	760	12.70
2423	1627	PRKWY	1532	2016	12.68
2424	2435	CRSCN	1202	622	12.62
2425	2429	TMNTH	1604	50	12.59
2426	2288	HLSBR	1204	544	12.56
2427	1534	CHYNE	9121	88	12.56
2428	442	GNSVL	1223	1016	12.55
2429	2025	WHITE	3542	1612	12.54
2430	1720	ROLTR	2922	1009	12.46
2431	1181	CLMET	0004	785	12.43
2432	677	ELZCK	4922	28	12.32
2433	1114	SHDYG	7811	374	12.24
2434	2516	ODESA	0261	1446	12.23
2435	729	ELGIN	1003	2102	12.05
2436	693	PRNTH	1403	22	12.01
2437	547	WRBND	2322	883	12.00
2438	N/A	IRVRS	4411	540	12.00
2439	2651	SWTWR	1321	129	12.00
2440	737	FROKS	0002	1248	11.97
2441	2274	DALRK	1326	2647	11.94
2442	2470	RSPCK	2106	346	11.85
2443	2323	ARTHR	0411	719	11.37
2444	2035	MKNSW	2604	3754	11.35
2445	845	ZEPHR	2404	178	11.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2446	2509	BLMED	1618	38	11.31
2447	862	NMAIN	0272	421	11.30
2448	2424	BRKRG	0211	295	11.27
2449	2414	HNYGR	2402	156	11.25
2450	1895	DALWT	2952	606	11.20
2451	2502	CDHIL	1805	603	11.19
2452	2316	TMNTH	1601	27	11.19
2453	869	THRNE	0002	1506	11.02
2454	2215	JKSBR	1401	928	10.94
2455	2433	WMRNR	0001	169	10.86
2456	1844	SSPNG	1201	1054	10.79
2457	999	FRMBG	1702	56	10.75
2458	2415	CRSCN	1201	796	10.75
2459	2280	FSTVW	0005	1651	10.70
2460	1667	SHRSW	6641	950	10.67
2461	413	BDFWD	8912	970	10.66
2462	1070	GORMN	0421	314	10.64
2463	1648	SMFLD	2322	42	10.62
2464	1330	LUFKN	1207	784	10.60
2465	2485	WEBBS	8631	2223	10.38
2466	1173	CRLUD	1307	257	10.36
2467	1494	MSTLT	1054	545	10.30
2468	1611	ATNRN	3412	3198	10.29
2469	2513	BSPRG	1904	1615	10.26
2470	1371	MKNGB	5312	2204	10.23
2471	1577	MURPH	2753	1557	10.11
2472	2596	MDLNE	0172	1210	10.09
2473	2779	DFWNW	2601	51	10.04
2474	2092	ROWLT	1106	1290	10.04
2475	2352	BLTON	1801	901	9.99
2476	2286	MSTLT	1073	201	9.97
2477	1463	MCDMT	2552	1746	9.92
2478	1159	HMPHL	2781	219	9.91
2479	2306	PCUST	2001	488	9.91
2480	1436	ABRRD	0006	180	9.85
2481	1636	PNTGO	7122	1060	9.85
2482	611	FRMBR	1804	284	9.83
2483	1459	FSCRK	6712	3165	9.83
2484	1180	WEBBS	8621	2581	9.82
2485	2353	SANSM	3911	1229	9.79
2486	1999	TYLGE	1306	2104	9.73
2487	1296	HLSBR	1203	1139	9.73
2488	2558	TMSTH	1406	765	9.71
2489	2528	HORNE	1933	2058	9.70
2490	2237	LORAN	9711	396	9.68
2491	2724	GRLRD	0001	1752	9.58
2492	568	WEBBS	8611	2559	9.57
2493	2422	DENAV	0652	40	9.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2494	2728	WRTHM	5017	150	9.53
2495	2562	GSTHW	1611	717	9.52
2496	511	BRCRK	6512	1749	9.51
2497	2148	PRCRK	0001	161	9.51
2498	2264	RDLML	2591	1415	9.42
2499	1824	HMPHL	2711	394	9.41
2500	1793	DGNST	0008	600	9.35
2501	1253	RCHHL	0394	233	9.34
2502	2448	WEBBS	8623	2261	9.32
2503	2639	WFALS	0143	179	9.28
2504	2482	DGNST	0007	187	9.27
2505	1242	GAVSW	0007	1099	9.26
2506	2559	FROKS	0007	1386	9.24
2507	2302	CURIE	7222	312	9.24
2508	2327	ARLNG	1271	2109	9.22
2509	2209	BSPSW	0822	318	9.20
2510	N/A	TIODE	9621	1315	9.20
2511	2412	RSNHT	1142	859	9.18
2512	1845	MNFLD	2611	1721	9.12
2513	2303	NMAIN	0241	686	9.09
2514	1266	THRNE	0008	2083	8.98
2515	N/A	MKNSO	3613	2760	8.97
2516	609	MRSES	4012	402	8.94
2517	1823	VLYRN	2951	2529	8.94
2518	276	ALNSW	2651	1518	8.91
2519	2253	EDGCF	2221	755	8.76
2520	N/A	FLMSO	3714	519	8.76
2521	2686	BSPSW	0832	397	8.72
2522	134	FLRTN	3721	27	8.61
2523	2438	FRMBG	1753	1115	8.58
2524	1066	RANGR	4311	877	8.57
2525	1886	WFALS	0114	418	8.45
2526	2598	EGFRD	0004	1801	8.41
2527	2437	RNDRK	1506	1573	8.38
2528	2387	WFALS	0153	1151	8.36
2529	1336	JREST	2102	946	8.34
2530	2668	SHDYG	7831	92	8.24
2531	68	CRNRD	0002	313	8.16
2532	2029	IRVNR	1506	1352	8.14
2533	2777	DAVST	0008	15	8.13
2534	1656	INAIR	1421	17	8.12
2535	1153	MAPLE	0003	689	8.09
2536	2282	BKWST	0007	1613	8.07
2537	450	HKBRY	1101	112	7.94
2538	1033	TYOMN	1410	1338	7.91
2539	2132	PWEST	1310	232	7.79
2540	818	DCATR	1204	620	7.75
2541	2522	THRNE	0001	1160	7.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2542	2563	ROBNW	1501	429	7.70
2543	49	DGNST	0006	454	7.69
2544	2541	PROAD	0005	124	7.67
2545	421	RRWES	1603	11	7.64
2546	377	HORNE	1992	210	7.63
2547	1141	CRLTR	2004	210	7.61
2548	581	COMSO	1403	1310	7.57
2549	2445	BRKRG	0221	702	7.55
2550	714	RCLNS	1408	161	7.53
2551	781	RGLRW	0008	54	7.46
2552	1327	MCDMT	2554	923	7.46
2553	2168	ENTOH	0008	16	7.44
2554	2618	ARTHR	0422	1037	7.29
2555	2477	IRVNE	1302	380	7.22
2556	1780	RSPCK	2105	315	7.16
2557	2110	WALST	0012	330	7.12
2558	1725	HORNE	1991	1141	7.10
2559	2593	RDRSE	2603	3525	6.96
2560	2085	OVRTN	4037	121	6.95
2561	2455	FSTVW	0002	146	6.95
2562	2797	LEMON	0008	730	6.89
2563	2140	LIGSW	1603	2516	6.87
2564	2798	LKWOD	7421	42	6.85
2565	2710	BDFWD	8941	627	6.75
2566	1341	RDRSE	2607	4223	6.66
2567	2824	SHDYG	7812	123	6.64
2568	2803	MCKMY	0821	1644	6.62
2569	2139	ODESA	0212	1633	6.59
2570	2577	JEWET	1202	45	6.58
2571	2287	CRTLD	4722	3236	6.54
2572	2317	BRTRD	7312	2536	6.44
2573	956	BLMGR	1901	265	6.44
2574	2380	FRMBG	1751	729	6.42
2575	2588	CRNRD	0005	218	6.39
2576	1040	HUDSN	1604	3287	6.38
2577	2574	GRAHM	0713	395	6.28
2578	597	DESPR	1404	283	6.25
2579	2307	ARTHR	0452	652	6.24
2580	N/A	LEMON	0006	683	6.20
2581	207	JKSES	3028	372	6.18
2582	881	FROKS	0008	1407	6.16
2583	1084	JUDCT	0002	1268	6.09
2584	2804	MESQN	1506	57	6.04
2585	2519	LKBLT	2103	1460	6.01
2586	1456	RDLML	2532	1650	5.98
2587	454	NPKWY	0011	2194	5.97
2588	10	LKBRN	2402	167	5.97
2589	2188	CMPST	0001	421	5.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2590	775	COPER	0402	167	5.93
2591	679	EXPKY	8142	29	5.91
2592	N/A	GRHWY	5511	1790	5.91
2593	1085	SHAMP	0007	623	5.82
2594	539	SHNRW	1607	53	5.81
2595	720	FRMNT	0009	1659	5.77
2596	1512	WALST	0001	193	5.76
2597	232	RECCR	0003	191	5.72
2598	1866	WALST	0011	651	5.69
2599	1190	FRMNT	0010	1696	5.68
2600	2722	ARMST	0005	1473	5.59
2601	1624	GRLRD	0002	967	5.59
2602	2827	SORCY	0002	63	5.52
2603	2069	DENDR	0004	2033	5.45
2604	725	WXNTH	2302	1234	5.37
2605	1959	FRMBR	1808	604	5.35
2606	2694	RGLRW	0002	209	5.29
2607	N/A	HKBRY	1117	55	5.29
2608	1137	REGST	0002	163	5.23
2609	2426	LVBRD	0004	1011	5.22
2610	N/A	FLMSO	3716	1992	5.16
2611	171	ROANW	9511	1152	5.12
2612	2571	WFALS	0163	345	5.11
2613	1927	PRCRK	0003	1620	5.04
2614	2219	FRMBR	1806	102	5.03
2615	1149	BLMGR	1902	190	5.03
2616	2153	FRNKF	0003	487	5.01
2617	2783	DFWSW	2203	22	5.00
2618	2030	JUDCT	0003	1585	4.89
2619	1931	ENTOH	0006	1518	4.81
2620	958	ALNTH	2842	1605	4.76
2621	1776	TMSTH	1405	320	4.74
2622	2784	DFWSW	2207	21	4.71
2623	1045	PROAD	0003	1081	4.69
2624	2167	HMTRD	0003	387	4.65
2625	2556	BSPRW	2511	720	4.54
2626	2442	WRTHM	5004	218	4.50
2627	2190	MESTE	1208	795	4.49
2628	1390	STERT	2706	154	4.44
2629	2587	TYLER	1010	53	4.43
2630	2700	CRLJL	1508	299	4.39
2631	588	BRIRV	6921	2349	4.38
2632	1129	STNVL	1204	898	4.36
2633	2740	PSHIL	1607	440	4.23
2634	2549	MKNNY	1204	35	4.22
2635	2146	NCRST	2203	981	4.08
2636	2826	SMFLD	2362	56	4.02
2637	1599	DFWSW	2208	20	4.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2638	2218	CRTLD	4712	1152	4.00
2639	1420	PWEST	1312	1175	3.98
2640	2374	FRNKF	0007	1150	3.98
2641	1609	SCHRD	0004	1802	3.91
2642	2653	LFSTH	1405	215	3.86
2643	2283	RENSW	3122	94	3.80
2644	2251	DALWT	2941	244	3.77
2645	1228	ARMST	0012	491	3.74
2646	2447	TYLER	1001	153	3.73
2647	2129	MSHLN	0005	1578	3.71
2648	2104	PALRD	2205	318	3.66
2649	2235	IRVNR	1553	1297	3.57
2650	2481	PJPTR	3211	108	3.53
2651	2766	BKWST	0001	382	3.50
2652	1219	MCDMT	2553	1041	3.46
2653	2332	AMLIA	0008	132	3.45
2654	1132	EMPCT	0001	31	3.44
2655	635	HKBRY	1113	400	3.39
2656	810	WHTRK	0005	723	3.38
2657	2339	DALWT	2972	234	3.37
2658	2545	LIPAN	1303	263	3.32
2659	2604	GAVSW	0002	823	3.26
2660	379	SMPST	0002	1322	3.13
2661	2591	ROLTR	2911	1732	3.13
2662	202	ARMST	0001	272	3.11
2663	953	WMRLD	0001	205	3.11
2664	2683	RSPCK	2133	135	3.11
2665	2367	ODESA	0221	272	3.10
2666	2822	RNKSW	5413	30	3.10
2667	1875	TYLGE	1314	794	3.09
2668	2584	HMPHL	2733	118	3.07
2669	2757	ABBOT	1901	118	3.04
2670	2758	AIRPK	8431	19	3.03
2671	2097	SMFLD	2391	292	3.01
2672	2459	AMLIA	0007	79	2.90
2673	1297	RSNHT	1152	996	2.88
2674	2453	HRSMD	1951	3827	2.83
2675	2534	DENAV	0673	58	2.72
2676	1929	MCHSN	1201	240	2.72
2677	2402	SACRC	5521	97	2.70
2678	2276	CMPST	0003	206	2.68
2679	2461	HMPHL	2792	426	2.65
2680	2568	FRNKF	0008	1151	2.65
2681	2729	HKBRY	1102	1361	2.64
2682	1629	FRMBR	1807	854	2.63
2683	2676	DGNST	0005	115	2.62
2684	1127	EGFRD	0005	193	2.60
2685	N/A	BNDRA	0013	593	2.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2686	1252	WGROB	8421	3815	2.54
2687	2605	ALPHA	0008	1239	2.54
2688	2750	PROAD	0008	1059	2.53
2689	2311	CLBNR	1407	265	2.52
2690	2810	NCRST	2202	24	2.46
2691	2745	FARON	4021	282	2.20
2692	1485	REAST	1502	1267	2.18
2693	2636	MAPLE	0002	68	2.16
2694	1279	LWSNR	2231	769	2.14
2695	1950	ECTHM	3331	23	2.09
2696	1067	RSPCK	2132	68	2.00
2697	2788	FRMBR	1853	263	1.90
2698	1004	CRLUD	1302	138	1.87
2699	1308	RGLRW	0001	32	1.77
2700	1640	VGCRK	8021	210	1.75
2701	815	HKBRY	1105	170	1.70
2702	767	HRSMD	1953	350	1.68
2703	828	FSTVW	0003	1888	1.65
2704	1295	FSCRK	6713	1670	1.65
2705	2561	FSTVW	0001	385	1.59
2706	2699	CURIE	7241	478	1.55
2707	1856	DAVIS	3762	32	1.53
2708	2659	CRLTR	2006	51	1.47
2709	778	WFALS	0124	132	1.45
2710	2749	LEMON	0002	790	1.42
2711	2817	RCLNS	1401	105	1.40
2712	2713	WATSN	5372	1320	1.27
2713	1807	ELKTN	2503	806	1.23
2714	2800	LSCOL	2135	607	1.14
2715	2805	MESQW	1805	83	1.07
2716	2386	PPARK	1804	241	1.05
2717	2529	BRYAN	0001	16	1.00
2718	1874	COTRD	0005	219	0.95
2719	2685	TNPON	0001	75	0.91
2720	2284	WMMMR	2708	240	0.90
2721	2161	PRKRW	3382	181	0.89
2722	1133	ABRRD	0003	331	0.85
2723	2496	JUDCT	0001	1383	0.83
2724	2624	WWEST	1217	97	0.80
2725	1415	SSPNE	1402	54	0.79
2726	1760	FRMBG	1706	59	0.76
2727	2678	PJPTR	3212	80	0.76
2728	2770	BRNAV	0741	142	0.75
2729	1507	MCWHT	3512	1881	0.74
2730	1314	ARMST	0011	930	0.72
2731	1519	ROLTR	2912	2946	0.72
2732	2163	CNEXP	0002	811	0.69
2733	2460	BRYAN	0002	468	0.66

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2734	2145	TMPNW	1103	522	0.66
2735	1781	HMPHL	2752	151	0.61
2736	N/A	IRVRS	4413	712	0.54
2737	N/A	BNDRA	0011	203	0.52
2738	2720	REGST	0003	911	0.51
2739	2177	MDWCK	0006	878	0.50
2740	793	GAVSW	0011	113	0.50
2741	2811	NMAIN	0252	254	0.48
2742	2719	BRYAN	0007	264	0.47
2743	1788	MAPLE	0006	455	0.45
2744	2635	ALPHA	0007	1393	0.45
2745	2378	LVBRD	0005	1757	0.45
2746	2578	CHROW	0007	82	0.43
2747	2814	PROAD	0001	125	0.40
2748	2701	COPER	0401	125	0.39
2749	752	LSCOL	2148	712	0.39
2750	2050	SHAMP	0003	1646	0.38
2751	2630	ARMST	0006	853	0.35
2752	1685	MAPLE	0007	96	0.34
2753	2603	PJPTR	3222	168	0.32
2754	2611	JUDCT	0004	219	0.31
2755	2789	FRMNT	0001	1411	0.29
2756	1706	CNTRD	0001	2049	0.27
2757	2721	JNKNS	0002	159	0.25
2758	2752	SHDYG	7832	1827	0.25
2759	2691	PROAD	0006	118	0.24
2760	1183	FRMNT	0002	640	0.23
2761	2124	RSPCK	2142	929	0.23
2762	N/A	CRNSO	3913	1502	0.20
2763	692	PTENN	2353	804	0.19
2764	2695	BKWST	0004	1061	0.16
2765	2737	WMMMR	2705	557	0.13
2766	1513	KNLTR	0001	2098	0.12
2767	341	EULES	8714	765	0.12
2768	2613	SHAMP	0002	1543	0.09
2769	2670	PFLGV	2007	2390	0.07
2770	1765	ABRRD	0008	1032	0.02
2771	2753	ALLEN	2405	16	0.00
2772	N/A	ALLEN	2408	517	0.00
2773	2759	ALNSW	2656	16	0.00
2774	2760	ALPHA	0004	21	0.00
2775	2761	ALPHA	0005	133	0.00
2776	2762	AMLIA	0003	20	0.00
2777	2734	ARMST	0003	373	0.00
2778	2764	ARTHR	0492	50	0.00
2779	2767	BKWST	0006	714	0.00
2780	2769	BRHLW	7641	22	0.00
2781	2431	CHICC	1701	50	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2782	504	CNEXP	0005	28	0.00
2783	2662	COTRD	0003	29	0.00
2784	2774	COTRD	0008	1038	0.00
2785	2105	CPLSO	4321	99	0.00
2786	2775	CRLUD	1301	15	0.00
2787	N/A	CRNSO	3911	296	0.00
2788	2776	CURIE	7212	12	0.00
2789	560	DENDR	0006	48	0.00
2790	2780	DFWNW	2602	35	0.00
2791	2781	DFWNW	2606	22	0.00
2792	2782	DFWNW	2610	50	0.00
2793	2410	DFWSW	2204	20	0.00
2794	2454	DFWSW	2209	11	0.00
2795	2682	EMPCT	0005	63	0.00
2796	2623	EXPKY	8112	12	0.00
2797	982	EXPKY	8141	23	0.00
2798	2785	FRMBG	1704	35	0.00
2799	2786	FRMBG	1708	47	0.00
2800	2787	FRMBG	1752	192	0.00
2801	2730	FRMNT	0003	272	0.00
2802	2790	FRMNT	0005	221	0.00
2803	13	GDNVL	1201	58	0.00
2804	2279	GNSVN	1401	23	0.00
2805	2727	GSTHW	1613	93	0.00
2806	1881	GSTHW	1622	29	0.00
2807	2793	GSTHW	1651	41	0.00
2808	2560	HKBRY	1104	175	0.00
2809	2062	HKBRY	1111	29	0.00
2810	2794	HKBRY	1115	13	0.00
2811	2449	HMPHL	2723	36	0.00
2812	2795	HMPHL	2731	12	0.00
2813	2348	HMPHL	2791	32	0.00
2814	2632	INAIR	1442	112	0.00
2815	2658	JNKNS	0008	19	0.00
2816	N/A	KNLTR	0009	264	0.00
2817	1837	KRGRV	2401	11	0.00
2818	N/A	LIGSW	1621	33	0.00
2819	287	LMESA	2833	26	0.00
2820	2756	LSCOL	2137	645	0.00
2821	1514	LSCOL	2138	621	0.00
2822	2801	LSCOL	2140	288	0.00
2823	2610	LSCOL	2142	12	0.00
2824	2137	LVBRD	0001	36	0.00
2825	2802	MAPLE	0008	205	0.00
2826	2808	MNWLL	1201	11	0.00
2827	440	MRSES	3016	40	0.00
2828	2809	MRSES	4014	23	0.00
2829	2812	NMAIN	0262	166	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
2830	N/A	NPKWY	0007	155	0.00
2831	1322	NPKWY	0010	11	0.00
2832	2697	PARIS	1205	24	0.00
2833	1692	PJPTR	3221	34	0.00
2834	2813	PJPTR	3231	26	0.00
2835	N/A	PLHWY	3701	447	0.00
2836	N/A	PLHWY	3703	11	0.00
2837	1774	PRKRW	3331	106	0.00
2838	2735	PROAD	0009	100	0.00
2839	2815	PWEST	1306	279	0.00
2840	2816	PWEST	1309	53	0.00
2841	2819	RECCR	0005	153	0.00
2842	201	RGFTW	6813	15	0.00
2843	2213	RNFLF	8331	11	0.00
2844	N/A	RNKSW	5412	30	0.00
2845	2823	ROANW	9522	29	0.00
2846	1442	RSPCK	2131	46	0.00
2847	1239	SCHRD	0006	345	0.00
2848	2672	SCHRD	0008	60	0.00
2849	2825	SHDYG	7821	89	0.00
2850	415	SMBMG	1701	28	0.00
2851	1057	STNVL	1202	72	0.00
2852	2275	TRLSW	2401	20	0.00
2853	2262	TYBLR	2806	196	0.00
2854	2641	VLYRN	2954	36	0.00
2855	2830	WALST	0007	20	0.00
2856	2831	WALST	0008	613	0.00
2857	2833	WEBBS	8634	423	0.00
2858	2834	WMMMR	2704	16	0.00
2859	2835	WMMMR	2706	16	0.00
2860	2154	WWEST	1221	17	0.00
2861	2836	WXOCF	1402	11	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2010 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13.35%
Vegetation	15.19%
Animals and Birds	16.19%
People (Including cars and farm equip)	7.83%
Utility-owned Equipment	37.19%
Other	5.03%
Unknown	5.22%