

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2206	1883	WRTHM	5012	318	0.18
2207	1032	FSTVW	0007	1412	0.18
2208	729	THRNE	0002	1506	0.18
2209	2392	AIRPK	8421	391	0.18
2210	358	WALST	0001	193	0.18
2211	2126	TRLWD	7721	1375	0.18
2212	1384	BONHM	1204	824	0.18
2213	902	PROAD	0002	826	0.18
2214	2588	HORNE	1981	1505	0.18
2215	1233	TYBLR	2802	982	0.18
2216	2154	VALVW	1802	409	0.18
2217	1394	CMTSW	0934	1519	0.18
2218	99	DALWT	2992	333	0.18
2219	1906	MESTE	1206	1234	0.18
2220	2483	BKBNT	1821	1163	0.18
2221	1490	PRSTN	0005	1160	0.18
2222	1417	RWDHV	1903	580	0.18
2223	730	LKHLD	0004	1240	0.18
2224	2367	CURIE	7211	548	0.18
2225	772	RECCR	0006	367	0.17
2226	690	VENSW	2601	1172	0.17
2227	2042	GRFRD	1002	370	0.17
2228	1665	ROSCO	2911	585	0.17
2229	972	MNWLL	1202	672	0.17
2230	2497	CURIE	7231	1067	0.17
2231	2353	TMPNW	1101	2308	0.17
2232	64	GPLND	1202	389	0.17
2233	433	CRYVE	3011	279	0.17
2234	951	MKNSW	1603	1246	0.17
2235	664	SWDTN	1621	753	0.17
2236	1787	FRMBR	1805	748	0.17
2237	1900	BRCRK	6523	773	0.17
2238	2488	BRYAN	0005	2806	0.17
2239	1555	KLELM	2204	1921	0.17
2240	1774	COHMA	1132	47	0.17
2241	2185	BKBNT	1811	682	0.17
2242	2421	WEAST	0619	2270	0.17
2243	2559	TMSTH	1406	765	0.17
2244	670	MKNNY	1251	1091	0.17
2245	231	ROLTR	2921	2456	0.17
2246	758	BLVUE	1111	378	0.17
2247	2295	ROWLT	1103	1058	0.17
2248	910	HLTOM	2421	1634	0.17
2249	2170	EDGCF	2241	912	0.17
2250	1347	SWAN2	1801	368	0.17
2251	620	MSLSW	0008	143	0.17
2252	785	LFSTH	1402	1167	0.17
2253	771	EDGCF	2272	1025	0.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2254	2033	WFALS	0133	1643	0.17
2255	2335	GSTHW	1641	84	0.17
2256	1824	WBROK	3021	54	0.17
2257	2418	GSTHW	1672	12	0.17
2258	1910	CLCTY	1011	1129	0.17
2259	2433	TMPTV	2404	1328	0.17
2260	2605	CKRHL	0002	385	0.17
2261	1121	MSLSW	0007	371	0.16
2262	956	GRPVN	8213	1506	0.16
2263	2414	FROKS	0007	1386	0.16
2264	686	TRNTY	7511	1059	0.16
2265	2256	CRSCN	1201	796	0.16
2266	2672	DAVIS	3731	735	0.16
2267	1571	PTENN	2351	1171	0.16
2268	1137	NPKWY	0013	3816	0.16
2269	1693	TYBLR	2804	2389	0.16
2270	1050	DNISN	1203	1590	0.16
2271	1974	RCHRD	1201	1234	0.16
2272	201	BRNSO	1807	204	0.16
2273	270	IRVNE	1305	99	0.16
2274	N/A	SALSW	3004	1318	0.16
2275	1977	SHRSW	6631	1232	0.16
2276	639	TLRWT	2201	1623	0.16
2277	1723	CRLFR	2155	1339	0.16
2278	2569	CRLUD	1306	25	0.16
2279	2457	BBTWN	1502	1691	0.16
2280	111	CNSES	0750	1134	0.16
2281	1790	WATSN	5331	1072	0.16
2282	2056	MDDTN	4312	2023	0.16
2283	1497	ADMDS	6521	1490	0.16
2284	386	HLSBR	1203	1139	0.16
2285	1244	BSPRW	2521	1764	0.16
2286	309	CRNRD	0004	448	0.16
2287	2189	CLBNR	1401	19	0.16
2288	N/A	MKNSO	3613	2760	0.16
2289	2671	HKBRY	1109	51	0.16
2290	2523	ARMST	0009	1046	0.16
2291	1128	INAIR	1423	199	0.16
2292	2176	EDGCF	2231	756	0.15
2293	700	CMTSW	0952	576	0.15
2294	1998	MDWPK	9211	1231	0.15
2295	2565	WNDWD	3631	305	0.15
2296	300	GNSVL	1223	1016	0.15
2297	2429	RDLML	2591	1415	0.15
2298	2345	FRSTN	1604	320	0.15
2299	119	WATSN	5361	2443	0.15
2300	2520	HURST	1852	1446	0.15
2301	2451	MDLNE	0172	1210	0.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2302	919	VGCRK	8011	1475	0.15
2303	723	NMAIN	0211	1885	0.15
2304	2592	TMPNW	1102	587	0.15
2305	817	VLYRN	2957	4684	0.15
2306	125	DGNST	0006	454	0.15
2307	2670	FSTVW	0008	1674	0.15
2308	1839	ROLTR	2922	1009	0.14
2309	1680	DESPR	1402	1666	0.14
2310	2279	ODESA	0212	1633	0.14
2311	2274	HNYGR	2403	125	0.14
2312	2202	WFNTH	0221	577	0.14
2313	1379	DAVIS	3752	501	0.14
2314	1651	ALPHA	0003	696	0.14
2315	2136	ROWLT	1101	950	0.14
2316	726	NMAIN	0272	421	0.14
2317	2039	HMPHL	2762	1061	0.14
2318	2655	SHDYG	7831	92	0.14
2319	1613	ROWLT	1107	362	0.14
2320	2072	JKSBR	1401	928	0.14
2321	351	WGROB	8422	4067	0.14
2322	1005	THRNE	0008	2083	0.14
2323	777	IRVHF	2301	1260	0.14
2324	1255	WTHRF	2001	603	0.14
2325	511	DESPR	1408	1775	0.14
2326	N/A	RKCRK	6111	726	0.14
2327	1702	MSTLT	1084	640	0.14
2328	746	RCLNS	1402	514	0.14
2329	2091	GSTHW	1623	2344	0.14
2330	1445	ARTHR	0472	2054	0.14
2331	2143	BRHLW	7631	713	0.14
2332	2317	FROKS	0005	1340	0.14
2333	48	GVGLF	9601	51	0.14
2334	372	MSHLN	0003	534	0.14
2335	338	IRVNR	1551	1084	0.14
2336	521	RWDHV	1905	1195	0.14
2337	2024	CMTSW	0921	1826	0.14
2338	2436	REAST	1503	560	0.14
2339	574	ROANW	9521	1247	0.13
2340	2652	GODRD	8161	2219	0.13
2341	2428	CTYVW	2211	1478	0.13
2342	1426	SSPNG	1201	1054	0.13
2343	1031	NHNSW	0005	384	0.13
2344	1546	ALPHA	0013	452	0.13
2345	129	GSTHW	1633	929	0.13
2346	2235	HLSBR	1204	544	0.13
2347	2469	PTENN	2352	1594	0.13
2348	1768	VLYRN	2951	2529	0.13
2349	876	TYOMN	1410	1338	0.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2350	626	RDLML	2552	276	0.13
2351	1309	PSHIL	1602	1007	0.13
2352	2535	WXNTH	2308	577	0.13
2353	2000	IRVND	1203	348	0.13
2354	2359	SHRSW	6612	1766	0.13
2355	2468	SSPNG	1203	788	0.13
2356	641	CRLTR	2052	1561	0.13
2357	584	GORMN	0421	314	0.13
2358	1903	GRLWS	1704	173	0.13
2359	2394	BDFWD	8932	1664	0.13
2360	694	WHITE	3532	1324	0.13
2361	1391	ARLNG	1292	1543	0.13
2362	2437	RCLNS	1407	1672	0.13
2363	1650	LKWOD	7411	629	0.13
2364	1378	LKTMS	2411	120	0.13
2365	1537	VENSW	2603	24	0.13
2366	1414	SMFLD	2352	570	0.12
2367	1970	TATSP	4322	2457	0.12
2368	854	MCDMT	2552	1746	0.12
2369	1024	VGCRK	8031	1782	0.12
2370	2439	WWEST	1216	250	0.12
2371	942	MESFR	2105	1017	0.12
2372	1232	ZEPHR	2404	178	0.12
2373	1954	PFFRD	3411	268	0.12
2374	810	MKNGB	5312	2204	0.12
2375	971	HHSTH	1501	3687	0.12
2376	855	COPEL	3055	2053	0.12
2377	1837	PRKWY	1532	2016	0.12
2378	2736	BNDRA	0002	549	0.12
2379	2200	ODNTH	2073	601	0.12
2380	1453	BRCRK	6521	1421	0.12
2381	608	WRBND	2322	883	0.12
2382	2461	ODESA	0261	1446	0.12
2383	1817	GLNHV	3973	1289	0.12
2384	989	IRVHF	2303	85	0.12
2385	289	RANGR	4311	877	0.12
2386	430	DESPR	1404	283	0.12
2387	1828	HORNE	1991	1141	0.12
2388	2501	ATNRN	3411	2067	0.12
2389	2216	LNCST	1603	1445	0.12
2390	2238	LKBLT	2103	1460	0.12
2391	2465	PCOIT	1007	844	0.11
2392	2383	REAST	1501	296	0.11
2393	2057	PPARK	1807	874	0.11
2394	530	SCYEN	0004	1190	0.11
2395	2386	WATSN	5352	1866	0.11
2396	2207	ALNTH	2853	2896	0.11
2397	1078	TMPNW	1106	694	0.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2398	2284	PRKWY	1521	2230	0.11
2399	2508	WWEST	1222	152	0.11
2400	1317	MRYNL	2111	27	0.11
2401	1696	PFFRD	3431	578	0.11
2402	22	HNYGR	0402	470	0.11
2403	654	ARLNG	1261	1484	0.11
2404	341	MYPRL	1801	118	0.11
2405	N/A	FLMSO	3714	519	0.11
2406	320	STERT	2703	82	0.11
2407	253	BRYAN	0006	731	0.11
2408	2297	NHNSW	0004	549	0.11
2409	1915	LORAN	9711	396	0.11
2410	1627	WHITE	3542	1612	0.11
2411	918	ELZCK	4922	28	0.11
2412	2732	IRVVV	2804	916	0.11
2413	1986	OKCLS	0001	692	0.11
2414	2264	DAVIS	3733	375	0.11
2415	875	FROKS	0008	1407	0.11
2416	377	EGFRD	0001	1700	0.11
2417	2591	ARTHR	0422	1037	0.11
2418	2140	ODNTH	2024	2630	0.11
2419	2158	WELRD	0007	437	0.11
2420	1189	SYCRK	4532	3829	0.11
2421	2252	FSTVW	0005	1651	0.10
2422	92	RECCR	0003	191	0.10
2423	306	FARON	4082	1579	0.10
2424	823	ARLNG	1223	1564	0.10
2425	1794	DALWT	2911	338	0.10
2426	2631	BLTON	1804	464	0.10
2427	212	BNTDR	0001	1203	0.10
2428	325	ARMST	0012	491	0.10
2429	2003	BRHLW	7621	2348	0.10
2430	773	KRUMS	1203	1641	0.10
2431	1675	MKNSW	2604	3754	0.10
2432	2554	DESPR	1401	1548	0.10
2433	1221	DESHR	1206	2160	0.10
2434	2425	THRNE	0001	1160	0.10
2435	1888	DUVAL	0473	1478	0.10
2436	2191	PRKRW	3392	1570	0.10
2437	1115	JUDCT	0008	130	0.10
2438	1616	CLCTY	1021	671	0.10
2439	2636	GAVSW	0002	823	0.10
2440	743	BRCRK	6533	1774	0.10
2441	2104	BLTON	1801	901	0.10
2442	2568	ENTOH	0001	663	0.10
2443	2562	BSPRG	1904	1615	0.10
2444	499	BRLSN	2013	1094	0.10
2445	116	PRFTW	4212	1954	0.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2446	2277	DALRK	1326	2647	0.10
2447	2458	ARLNG	1251	498	0.10
2448	2397	FROKS	0001	1309	0.10
2449	2036	WTAUG	4622	873	0.10
2450	2450	HNYGR	2402	156	0.10
2451	2080	CLBSN	8821	52	0.10
2452	2121	FSTVW	0002	146	0.10
2453	336	CRNRD	0002	313	0.10
2454	29	HSKAV	0004	1134	0.10
2455	741	MESQT	1306	956	0.09
2456	1720	WDGWD	1523	287	0.09
2457	2610	LFSTH	1405	215	0.09
2458	2669	BRHLW	7611	1611	0.09
2459	332	BDFWD	8912	970	0.09
2460	2470	DCDAM	2003	1537	0.09
2461	2687	RSPVY	1702	469	0.09
2462	2118	CRSCN	1202	622	0.09
2463	N/A	TIODE	9621	1315	0.09
2464	2163	CHYNE	9121	88	0.09
2465	106	RRWES	1603	11	0.09
2466	796	STNVL	1204	898	0.09
2467	2385	GRAHM	0713	395	0.09
2468	745	MNFLD	2611	1721	0.09
2469	2446	GRHWY	5522	2166	0.09
2470	1092	LVBRD	0004	1011	0.09
2471	1148	RDRSE	2607	4223	0.09
2472	786	LOMAL	0016	647	0.09
2473	2415	CURIE	7222	312	0.09
2474	2674	CDHIL	1805	603	0.09
2475	2196	RRSTH	1708	3990	0.09
2476	661	REGST	0002	163	0.09
2477	2534	BSPSW	0832	397	0.09
2478	1743	WEBBS	8621	2581	0.09
2479	2417	CTYVW	2221	1854	0.08
2480	2372	WFALS	0153	1151	0.08
2481	1750	DALWT	2962	451	0.08
2482	1059	SHRSW	6641	950	0.08
2483	1057	KNLTR	0003	603	0.08
2484	2499	IRVNE	1302	380	0.08
2485	2107	BRKRG	0221	702	0.08
2486	2363	TMNTH	1604	50	0.08
2487	2073	ROWLT	1106	1290	0.08
2488	290	BLPOD	1201	76	0.08
2489	2012	BSPSW	0822	318	0.08
2490	2803	MCKMY	0821	1644	0.08
2491	949	PNTGO	7122	1060	0.08
2492	1630	RYSSW	2804	1561	0.08
2493	2521	PRSTN	0004	653	0.08

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2494	2576	MSTLT	1042	141	0.08
2495	1167	WATSN	5342	1962	0.08
2496	731	COPER	0402	167	0.08
2497	N/A	LEMON	0006	683	0.08
2498	345	PRKRW	3321	142	0.08
2499	2364	FRNKF	0007	1150	0.08
2500	819	GSTHW	1662	13	0.08
2501	43	NPKWY	0011	2194	0.08
2502	2448	RNDRK	1506	1573	0.08
2503	2065	IRVNR	1506	1352	0.08
2504	2766	BKWST	0001	382	0.08
2505	340	SHNRW	1607	53	0.08
2506	2665	JNKNS	0005	504	0.08
2507	1854	JNKNS	0003	979	0.07
2508	993	RENSW	3122	94	0.07
2509	159	FLRTN	3721	27	0.07
2510	2828	STERT	2701	27	0.07
2511	2193	TMNTH	1601	27	0.07
2512	2505	GSTHW	1611	717	0.07
2513	388	ALNSW	2651	1518	0.07
2514	1053	ABRRD	0006	180	0.07
2515	2341	TRLNW	1202	56	0.07
2516	1483	SMFLD	2322	42	0.07
2517	2462	BRKRG	0211	295	0.07
2518	2443	DALWT	2952	606	0.07
2519	2564	HORNE	1933	2058	0.07
2520	124	JKSES	3028	372	0.07
2521	646	MRSES	4012	402	0.07
2522	2378	ARTHR	0411	719	0.07
2523	2560	RDRSE	2603	3525	0.07
2524	813	LVBRD	0008	1703	0.07
2525	2485	DALWT	2921	260	0.07
2526	2007	MAPLE	0001	581	0.07
2527	2271	JUDCT	0003	1585	0.07
2528	2494	PRCRK	0001	161	0.07
2529	2607	WTAUG	4632	1166	0.07
2530	1298	JREST	2102	946	0.07
2531	2366	RSNHT	1142	859	0.07
2532	2305	COPEL	3052	1306	0.07
2533	1382	SHDYG	7811	374	0.07
2534	2640	WFALS	0163	345	0.07
2535	2709	WRTHM	5017	150	0.07
2536	2777	DAVST	0008	15	0.07
2537	1186	ADISN	1601	593	0.07
2538	2484	ARLNG	1271	2109	0.07
2539	990	FSCRK	6712	3165	0.06
2540	1408	WFALS	0114	418	0.06
2541	1100	EMPCT	0001	31	0.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2542	962	RCHHL	0394	233	0.06
2543	2137	OKCLS	0006	1095	0.06
2544	622	ROANW	9511	1152	0.06
2545	2492	BRYAN	0001	16	0.06
2546	268	MAPLE	0003	689	0.06
2547	818	CHROW	0008	81	0.06
2548	259	CLMET	0004	785	0.06
2549	2438	BSPRW	2511	720	0.06
2550	2694	CLBWS	8112	247	0.06
2551	832	ELGIN	1003	2102	0.06
2552	2797	LEMON	0008	730	0.06
2553	504	LKBRN	2402	167	0.06
2554	982	WTAUG	4642	1292	0.06
2555	1694	INAIR	1421	17	0.06
2556	1188	ATNRN	3412	3198	0.06
2557	2496	BKWST	0007	1613	0.06
2558	2649	ROBNW	1501	429	0.06
2559	774	PWEST	1312	1175	0.06
2560	2087	CRLTR	2004	210	0.06
2561	2146	HMPHL	2772	247	0.06
2562	2601	FRMBG	1751	729	0.06
2563	954	FRNKF	0003	487	0.06
2564	1708	LUFKN	1207	784	0.05
2565	2749	PSHIL	1607	440	0.05
2566	2393	NMAIN	0241	686	0.05
2567	2312	ARTHR	0452	652	0.05
2568	1431	FRMBG	1702	56	0.05
2569	2168	PALRD	2205	318	0.05
2570	610	BLMGR	1901	265	0.05
2571	2804	MESQN	1506	57	0.05
2572	2758	AIRPK	8431	19	0.05
2573	2734	JNKNS	0006	496	0.05
2574	1076	MSTLT	1054	545	0.05
2575	1856	LWSNR	2212	1788	0.05
2576	2330	MESTE	1208	795	0.05
2577	1959	HMPHL	2781	219	0.05
2578	1988	GAVSW	0007	1099	0.05
2579	1509	DENAV	0652	40	0.05
2580	1021	DFWSW	2208	20	0.05
2581	524	BRCRK	6512	1749	0.05
2582	2218	OVRTN	4037	121	0.05
2583	1626	MURPH	2753	1557	0.05
2584	1230	HUDSN	1604	3287	0.05
2585	657	WHTRK	0005	723	0.05
2586	2546	PROAD	0005	124	0.05
2587	N/A	FLMSO	3716	1992	0.05
2588	2798	LKWOD	7421	42	0.05
2589	2784	DFWSW	2207	21	0.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2590	2533	FRMBG	1753	1115	0.05
2591	420	WEBBS	8611	2559	0.05
2592	695	FROKS	0002	1248	0.05
2593	2070	FRMBR	1808	604	0.05
2594	5	ADISN	1602	218	0.05
2595	265	PRNTH	1403	22	0.05
2596	2244	EDGCF	2221	755	0.05
2597	2423	MSTLT	1073	201	0.04
2598	218	HKBRY	1101	112	0.04
2599	1657	FRMNT	0009	1659	0.04
2600	1809	JEWET	1202	45	0.04
2601	2022	ECTHM	3331	23	0.04
2602	141	BRIRV	6921	2349	0.04
2603	2113	PWEST	1310	232	0.04
2604	2597	WICKT	0411	116	0.04
2605	564	HORNE	1992	210	0.04
2606	1123	WALST	0012	330	0.04
2607	2009	TYLGE	1306	2104	0.04
2608	2616	EGFRD	0004	1801	0.04
2609	2810	NCRST	2202	24	0.04
2610	2586	WRTHM	5004	218	0.04
2611	963	CRTLD	4712	1152	0.04
2612	1875	TMSTH	1405	320	0.04
2613	672	DCATR	1204	620	0.04
2614	571	ALNTH	2842	1605	0.04
2615	2285	TYLER	1001	153	0.04
2616	2370	FRMBR	1806	102	0.04
2617	2395	PCUST	2001	488	0.04
2618	364	WXNTH	2302	1234	0.04
2619	1034	LIGSW	1603	2516	0.04
2620	318	SHAMP	0007	623	0.04
2621	1114	WALST	0011	651	0.04
2622	903	DENDR	0004	2033	0.04
2623	1339	FRMNT	0010	1696	0.04
2624	1104	HMPHL	2713	53	0.04
2625	1814	NCRST	2203	981	0.04
2626	2490	PJPTR	3211	108	0.04
2627	2161	PRCRK	0003	1620	0.04
2628	2750	PROAD	0008	1059	0.04
2629	926	GRLRD	0002	967	0.04
2630	2589	RSPCK	2106	346	0.03
2631	261	EXPKY	8142	29	0.03
2632	283	BRLSN	2051	1019	0.03
2633	1134	PROAD	0003	1081	0.03
2634	2757	ABBOT	1901	118	0.03
2635	2632	WFALS	0143	179	0.03
2636	2076	RDLML	2532	1650	0.03
2637	2822	RNKSW	5413	30	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2638	193	ARMST	0001	272	0.03
2639	2320	MSHLN	0005	1578	0.03
2640	1035	CRTLD	4722	3236	0.03
2641	2824	SHDYG	7812	123	0.03
2642	N/A	GRHWY	5511	1790	0.03
2643	2827	SORCY	0002	63	0.03
2644	2131	DAVIS	3762	32	0.03
2645	948	RGLRW	0001	32	0.03
2646	1996	SACRC	5521	97	0.03
2647	2338	SMFLD	2391	292	0.03
2648	1044	FRMBR	1807	854	0.03
2649	N/A	BNDRA	0013	593	0.03
2650	2420	CLBNR	1407	265	0.03
2651	2695	CRLJL	1508	299	0.03
2652	2690	MAPLE	0002	68	0.03
2653	1002	WMRLD	0001	205	0.03
2654	1022	MCHSN	1201	240	0.03
2655	2817	RCLNS	1401	105	0.03
2656	2518	MKNNY	1204	35	0.03
2657	1412	HMPHL	2711	394	0.03
2658	N/A	SALSW	3003	648	0.03
2659	2635	CRNRD	0005	218	0.03
2660	720	SMPST	0002	1322	0.03
2661	2700	TNPON	0001	75	0.03
2662	913	BLMGR	1902	190	0.03
2663	2205	CMPST	0001	421	0.03
2664	1362	STERT	2706	154	0.03
2665	2603	HMPHL	2733	118	0.03
2666	2288	RCLNS	1408	161	0.02
2667	2519	HMPHL	2792	426	0.02
2668	2472	LIPAN	1303	263	0.02
2669	2422	SANSM	3911	1229	0.02
2670	2078	SCHRD	0004	1802	0.02
2671	2486	AMLIA	0008	132	0.02
2672	1133	WFALS	0124	132	0.02
2673	2634	ALPHA	0008	1239	0.02
2674	2738	ARMST	0005	1473	0.02
2675	2653	RSPCK	2133	135	0.02
2676	924	REAST	1502	1267	0.02
2677	2540	ODESA	0221	272	0.02
2678	333	CRLUD	1302	138	0.02
2679	2371	DALWT	2972	234	0.02
2680	2156	BRTRD	7312	2536	0.02
2681	1921	EGFRD	0005	193	0.02
2682	2747	LEMON	0002	790	0.02
2683	2666	CRLTR	2006	51	0.02
2684	2779	DFWNW	2601	51	0.02
2685	1087	ENTOH	0006	1518	0.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2686	2515	TYLER	1010	53	0.02
2687	2148	SSPNE	1402	54	0.02
2688	2500	ROLTR	2911	1732	0.02
2689	1156	MCDMT	2553	1041	0.02
2690	N/A	HKBRY	1117	55	0.02
2691	1502	HMTRD	0003	387	0.02
2692	1011	RSNHT	1152	996	0.02
2693	2582	HRSMD	1951	3827	0.02
2694	2826	SMFLD	2362	56	0.02
2695	2717	DGNST	0005	115	0.02
2696	2593	DENAV	0673	58	0.02
2697	706	HRSMD	1953	350	0.02
2698	2201	FRMBG	1706	59	0.02
2699	1663	LWSNR	2231	769	0.02
2700	2602	JUDCT	0001	1383	0.02
2701	836	FSTVW	0003	1888	0.02
2702	1132	WGROB	8421	3815	0.02
2703	1811	RSPCK	2132	68	0.01
2704	1112	CMPST	0003	206	0.01
2705	2725	BDFWD	8941	627	0.01
2706	2770	BRNAV	0741	142	0.01
2707	857	HMPHL	2752	151	0.01
2708	2489	AMLIA	0007	79	0.01
2709	2646	PJPTR	3212	80	0.01
2710	2159	PPARK	1804	241	0.01
2711	2389	DALWT	2941	244	0.01
2712	2445	CHROW	0007	82	0.01
2713	1041	ABRRD	0003	331	0.01
2714	2805	MESQW	1805	83	0.01
2715	861	ARMST	0011	930	0.01
2716	941	HKBRY	1105	170	0.01
2717	1990	TYLGE	1314	794	0.01
2718	1058	ELKTN	2503	806	0.01
2719	2431	PRKRW	3382	181	0.01
2720	2741	WATSN	5372	1320	0.01
2721	959	MAPLE	0007	96	0.01
2722	2661	WWEST	1217	97	0.01
2723	1070	VGCRK	8021	210	0.01
2724	2693	IRVNR	1553	1297	0.01
2725	1810	GAVSW	0011	113	0.01
2726	2706	HKBRY	1102	1361	0.01
2727	2720	PROAD	0006	118	0.01
2728	1770	FSCRK	6713	1670	0.01
2729	2686	COPER	0401	125	0.01
2730	2814	PROAD	0001	125	0.01
2731	2526	FSTVW	0001	385	0.01
2732	1622	TMPNW	1103	522	0.01
2733	1090	CNEXP	0002	811	0.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2734	1095	FRNKF	0008	1151	0.01
2735	2733	JNKNS	0002	159	0.01
2736	2379	PJPTR	3222	168	0.01
2737	1113	ROLTR	2912	2946	0.01
2738	1103	HKBRY	1113	400	0.01
2739	N/A	BNDRA	0011	203	0.00
2740	1085	COTRD	0005	219	0.00
2741	2668	JUDCT	0004	219	0.00
2742	2656	REGST	0003	911	0.00
2743	1073	BRYAN	0002	468	0.00
2744	759	MCWHT	3512	1881	0.00
2745	2512	WMMMR	2708	240	0.00
2746	2611	LVBRD	0005	1757	0.00
2747	2811	NMAIN	0252	254	0.00
2748	2788	FRMBR	1853	263	0.00
2749	2685	BRYAN	0007	264	0.00
2750	2728	WMMMR	2705	557	0.00
2751	2744	FARON	4021	282	0.00
2752	2697	ARMST	0006	853	0.00
2753	2328	MDWCK	0006	878	0.00
2754	1925	RSPCK	2142	929	0.00
2755	2487	ALPHA	0007	1393	0.00
2756	515	LSCOL	2148	712	0.00
2757	1093	MAPLE	0006	455	0.00
2758	2789	FRMNT	0001	1411	0.00
2759	2667	CURIE	7241	478	0.00
2760	2529	CNTRD	0001	2049	0.00
2761	2735	BKWST	0004	1061	0.00
2762	2517	SHAMP	0003	1646	0.00
2763	2800	LSCOL	2135	607	0.00
2764	2751	SHDYG	7832	1827	0.00
2765	680	FRMNT	0002	640	0.00
2766	1014	KNLTR	0001	2098	0.00
2767	N/A	IRVRS	4413	712	0.00
2768	N/A	CRNSO	3913	1502	0.00
2769	454	EULES	8714	765	0.00
2770	2628	SHAMP	0002	1543	0.00
2771	738	PTENN	2353	804	0.00
2772	1252	ABRRD	0008	1032	0.00
2773	2713	PFLGV	2007	2390	0.00
2774	2774	COTRD	0008	1038	0.00
2775	2767	BKWST	0006	714	0.00
2776	2752	LSCOL	2137	645	0.00
2777	1094	LSCOL	2138	621	0.00
2778	2831	WALST	0008	613	0.00
2779	N/A	ALLEN	2408	517	0.00
2780	N/A	PLHWY	3701	447	0.00
2781	2833	WEBBS	8634	423	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2782	N/A	TUODE	9611	391	0.00
2783	2739	ARMST	0003	373	0.00
2784	1065	SCHRD	0006	345	0.00
2785	N/A	CRNSO	3911	296	0.00
2786	2801	LSCOL	2140	288	0.00
2787	2815	PWEST	1306	279	0.00
2788	2710	FRMNT	0003	272	0.00
2789	N/A	KNLTR	0009	264	0.00
2790	2790	FRMNT	0005	221	0.00
2791	2802	MAPLE	0008	205	0.00
2792	1083	TYBLR	2806	196	0.00
2793	2787	FRMBG	1752	192	0.00
2794	2547	HKBRY	1104	175	0.00
2795	2812	NMAIN	0262	166	0.00
2796	N/A	NPKWY	0007	155	0.00
2797	2819	RECCR	0005	153	0.00
2798	2761	ALPHA	0005	133	0.00
2799	N/A	TUODE	9621	119	0.00
2800	2716	INAIR	1442	112	0.00
2801	1071	PRKRW	3331	106	0.00
2802	2623	PROAD	0009	100	0.00
2803	2268	CPLSO	4321	99	0.00
2804	2604	GSTHW	1613	93	0.00
2805	2825	SHDYG	7821	89	0.00
2806	544	STNVL	1202	72	0.00
2807	2618	EMPCT	0005	63	0.00
2808	2630	SCHRD	0008	60	0.00
2809	120	GDNVL	1201	58	0.00
2810	2816	PWEST	1309	53	0.00
2811	2764	ARTHR	0492	50	0.00
2812	2426	CHICC	1701	50	0.00
2813	2782	DFWNW	2610	50	0.00
2814	1004	DENDR	0006	48	0.00
2815	2786	FRMBG	1708	47	0.00
2816	1649	RSPCK	2131	46	0.00
2817	2793	GSTHW	1651	41	0.00
2818	34	MRSES	3016	40	0.00
2819	2613	HMPHL	2723	36	0.00
2820	2307	LVBRD	0001	36	0.00
2821	2627	VLYRN	2954	36	0.00
2822	2780	DFWNW	2602	35	0.00
2823	2785	FRMBG	1704	35	0.00
2824	1784	PJPTR	3221	34	0.00
2825	N/A	LIGSW	1621	33	0.00
2826	2197	HMPHL	2791	32	0.00
2827	N/A	RNKSW	5412	30	0.00
2828	2599	COTRD	0003	29	0.00
2829	2477	GSTHW	1622	29	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
2830	2600	HKBRY	1111	29	0.00
2831	2823	ROANW	9522	29	0.00
2832	1097	CNEXP	0005	28	0.00
2833	1109	SMBMG	1701	28	0.00
2834	95	LMESA	2833	26	0.00
2835	2813	PJPTR	3231	26	0.00
2836	2594	PARIS	1205	24	0.00
2837	1669	EXPKY	8141	23	0.00
2838	2023	GNSVN	1401	23	0.00
2839	2809	MRSES	4014	23	0.00
2840	2769	BRHLW	7641	22	0.00
2841	2781	DFWNW	2606	22	0.00
2842	2760	ALPHA	0004	21	0.00
2843	2762	AMLIA	0003	20	0.00
2844	2545	DFWSW	2204	20	0.00
2845	2275	TRLSW	2401	20	0.00
2846	2830	WALST	0007	20	0.00
2847	2658	JNKNS	0008	19	0.00
2848	1825	WWEST	1221	17	0.00
2849	2689	ALLEN	2405	16	0.00
2850	2759	ALNSW	2656	16	0.00
2851	2834	WMMMR	2704	16	0.00
2852	2835	WMMMR	2706	16	0.00
2853	2775	CRLUD	1301	15	0.00
2854	987	RGFTW	6813	15	0.00
2855	2794	HKBRY	1115	13	0.00
2856	2776	CURIE	7212	12	0.00
2857	2475	EXPKY	8112	12	0.00
2858	2795	HMPHL	2731	12	0.00
2859	2442	LSCOL	2142	12	0.00
2860	1099	DFWSW	2209	11	0.00
2861	2147	KRGRV	2401	11	0.00
2862	2808	MNWLL	1201	11	0.00
2863	1844	NPKWY	0010	11	0.00
2864	N/A	PLHWY	3703	11	0.00
2865	1108	RNFLF	8331	11	0.00
2866	2836	WXOCF	1402	11	0.00

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2866

Add or Delete Rows as Necessary

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1	27	SBEAN	6011	98	4215.76
2	40	LOVNG	2511	175	1980.35
3	1942	MASON	3411	14	1791.92
4	5	EMMAS	4012	13	1771.18
5	254	ECTHP	4911	965	1462.98
6	599	EMMAS	4021	41	1435.40
7	1639	WINKS	0521	50	1406.09
8	1816	WELCH	4911	22	1271.40
9	1098	BRKTN	1201	493	1231.13
10	17	VESTS	3111	53	1172.08
11	79	SMOUR	0721	21	1149.77
12	483	DHIDE	2811	104	1120.92
13	1103	ECTHP	4921	183	1077.41
14	2406	PALMR	2201	54	986.51
15	76	MIDWY	0621	156	969.54
16	102	BRNSY	1211	128	962.10
17	591	SALDO	3004	138	954.93
18	70	NYLDV	1201	181	897.29
19	133	WTHRF	2002	1586	886.97
20	205	HNTNG	1301	2058	878.17
21	44	SNDHL	3821	68	868.17
22	1446	WCOLO	1318	1654	867.70
23	1994	SWTWR	1362	10	865.53
24	48	ELCTR	1221	137	799.76
25	33	ELMAR	3211	108	787.07
26	639	DCDAM	2001	729	780.33
27	N/A	CRNSO	0002	23	780.26
28	1543	SHNRW	1612	724	763.70
29	37	SCSES	1202	188	738.09
30	7	PLDAV	4221	203	731.54
31	2083	HKHTS	1603	915	707.08
32	779	DCVSO	1104	1317	699.49
33	16	FKLCY	5121	112	694.91
34	197	SNYDR	1813	229	684.14
35	59	FRNKS	4168	956	676.48
36	1015	ENSSO	2003	494	671.45
37	479	HOWRD	3921	69	669.20
38	1363	BRGPR	1103	834	669.09
39	2196	HKHTS	1601	1482	667.71
40	161	CHRNO	1203	903	664.62
41	551	PGSTH	7011	103	656.84
42	263	LWRDR	0002	985	654.42
43	948	WINKS	0531	78	652.56
44	766	MNRVA	1301	311	643.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
45	1412	TYSTH	1202	1051	639.36
46	410	JDKNS	0811	39	632.53
47	412	WNRTH	1417	1370	626.96
48	1537	NLNVL	2001	115	626.35
49	1282	NPKWY	0005	63	618.07
50	61	JKSES	3029	1152	617.06
51	18	BRNWD	1202	439	614.19
52	447	FLRTN	3711	100	613.62
53	620	EMMAS	4011	71	606.75
54	42	KMASB	1721	110	592.18
55	1399	FORSN	5621	41	591.89
56	1501	LGVST	8522	356	587.13
57	1026	DALRK	1358	1735	585.99
58	137	GRSMN	3027	325	584.62
59	402	WXHCH	1205	909	577.89
60	127	SSPNE	1401	1309	577.51
61	2066	WNRTH	1420	1149	572.97
62	2570	ALPHA	0011	1143	564.42
63	1441	JKWST	4178	323	562.01
64	2318	TNSCL	1104	195	561.07
65	1235	LOMAL	0008	1028	560.49
66	141	BNBOR	1202	691	559.02
67	106	TYLGE	1311	831	556.77
68	11	MDFRM	2111	53	551.14
69	323	COMSO	1401	378	551.13
70	2709	FRNKS	1202	88	549.95
71	30	CSHNG	1202	64	542.89
72	1408	DNCNV	1905	1302	533.80
73	1623	TRLSW	1203	699	531.92
74	788	LMESA	2813	125	529.47
75	2450	LTVSB	5461	771	521.95
76	1889	NPKWY	0008	556	521.29
77	2203	DNCNV	1906	387	516.69
78	2832	WEAST	0620	78	506.95
79	970	GRLRD	0003	620	506.87
80	510	RWALE	3322	1334	506.28
81	336	CNI45	2401	535	502.52
82	101	MASON	3421	196	501.46
83	435	TRIRA	6222	621	499.48
84	38	THSES	2402	1316	498.96
85	98	TRPMN	4001	766	498.77
86	1205	TYLNE	1607	665	498.57
87	586	BRKTN	1202	112	497.57
88	104	FKLCY	5111	92	492.86
89	2674	GAVSW	0006	509	492.29
90	116	BEAST	4082	507	491.68
91	523	WBOSE	1102	62	489.67
92	723	DWSON	3121	28	488.24
93	1417	EZACH	0004	1086	487.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
94	1801	DGNST	0002	233	487.76
95	553	GRDNC	1211	371	482.07
96	735	JKSNR	4105	318	479.33
97	71	LWRDR	0004	796	477.57
98	58	ACRLY	1721	57	469.90
99	1388	BLKRV	8321	52	468.96
100	945	WINKS	0511	506	467.55
101	1362	BAKKE	6921	1390	466.24
102	1434	JKWST	4035	155	465.38
103	567	SCHRD	0001	1401	463.42
104	912	LMBLN	0005	684	463.28
105	1719	WSOTH	1018	1278	461.33
106	1580	CRYVE	3021	1259	460.72
107	351	CGDEL	5411	30	460.36
108	32	MDFRM	2131	12	460.07
109	2423	WXHNW	2901	178	456.22
110	2113	HKHTS	1602	1004	454.94
111	120	CSHNG	1201	912	450.80
112	1614	MABNK	2401	2030	445.96
113	1988	MDLNE	0122	248	442.39
114	943	COMSO	1405	652	437.95
115	452	HNTNG	1307	1451	437.64
116	1175	TRLWD	7711	2585	437.61
117	325	PLSTN	1003	1383	434.93
118	498	POWEL	2706	232	429.63
119	233	TYLNW	1910	1493	422.48
120	2207	WWEST	1218	992	421.84
121	1236	PLSTH	1302	1011	418.06
122	300	BNBOR	1201	699	416.19
123	1701	KFMNW	1201	891	415.91
124	2491	MSLMN	4009	201	415.70
125	1458	TYOMN	1402	1621	414.65
126	177	HNTNG	1306	1005	414.08
127	85	EDWDS	5921	892	413.25
128	754	GRDPR	0811	1153	412.29
129	1220	TEGMN	3038	1688	411.52
130	566	CRLCC	2703	643	409.84
131	519	HOWRD	3911	37	409.70
132	557	TROYS	1013	1071	403.13
133	19	DGLAS	2401	725	401.81
134	595	LOT69	3024	995	400.68
135	503	CUMBY	1201	398	395.16
136	218	OAKHL	3031	597	394.31
137	270	TSLVL	4002	2332	393.67
138	663	SALDO	3003	96	389.47
139	751	CRISP	1501	863	389.42
140	N/A	CNANG	1804	24	386.91
141	144	NCSFA	1704	1417	385.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
142	2034	WELRD	0002	727	383.28
143	146	GSMTH	1732	47	380.47
144	1870	KLRPR	9021	1946	380.29
145	662	RICES	0208	661	377.97
146	1213	DNCNV	1901	859	377.24
147	1948	CHICW	1302	193	373.56
148	1615	EDDYS	0712	1301	367.49
149	110	TSLVL	4001	944	366.39
150	552	WLSPT	1001	1904	365.75
151	1859	FORSW	2025	734	364.67
152	1833	JKSNR	4111	421	363.77
153	2515	QNLAN	1202	373	362.47
154	138	GSMTH	1711	50	362.01
155	204	RYLTY	1411	136	361.86
156	88	FRFWS	3001	1791	354.93
157	73	CRNES	2711	151	352.35
158	2033	LWRDR	0003	1713	345.54
159	424	ENNIS	1902	1227	343.11
160	1291	MLKF2	1201	1715	342.78
161	1517	MEXIA	3016	265	340.58
162	74	AMMFG	5621	535	340.01
163	1680	WOVER	6111	2308	336.27
164	621	WALNT	0001	1403	334.86
165	2255	GAVSW	0001	1077	333.11
166	1472	TYSTH	1203	423	332.38
167	884	BNMAG	1202	378	332.16
168	3	PLDAV	4231	113	331.35
169	119	MSTNG	2611	141	330.46
170	608	BKWWF	0521	454	328.77
171	2643	BNDRA	0003	809	328.03
172	2360	HKHTS	1605	1348	327.18
173	2013	CRNDL	2401	518	327.03
174	324	SCURY	1921	104	325.83
175	1562	WALNT	0005	1094	325.78
176	1951	MDLNW	1541	2123	325.46
177	1431	IRVNR	1555	3332	325.32
178	39	CNANG	1806	2349	324.38
179	1893	BDFRD	8811	1694	323.77
180	467	CRTLD	4731	3319	323.47
181	N/A	KNOTT	5221	16	323.43
182	2211	WOVER	6131	3091	323.23
183	8	VANSB	1501	776	322.61
184	564	BNDRA	0007	603	322.28
185	1794	MCKMY	0822	134	320.56
186	329	LUFKN	1206	1181	320.07
187	931	CRSGL	1301	86	318.59
188	2342	WELRD	0006	731	316.65
189	2400	KLNTF	1802	826	316.50

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
190	26	MEANS	4421	64	315.45
191	1229	LMESA	1512	623	313.98
192	1518	LMESA	1561	2054	313.75
193	1225	GRDPR	0891	863	309.24
194	343	JDKNS	0821	37	306.66
195	1718	RCHRD	1206	35	306.06
196	1829	RSPCK	2108	843	305.88
197	2506	WCOLO	1320	653	305.65
198	345	MABNK	2402	935	305.46
199	148	DIALV	3911	1037	305.29
200	1422	PALRD	2208	1068	304.24
201	2076	WNRTH	1421	1462	301.56
202	746	WATCO	2603	2285	301.18
203	305	KFMNW	1202	709	299.70
204	274	NCDSW	3811	1417	298.92
205	337	CHALK	0951	77	297.48
206	1340	EULES	8723	6766	296.09
207	375	TYSTH	1206	1263	295.58
208	954	CAMRN	1202	1385	294.87
209	299	IRVND	1205	184	294.47
210	118	WSTHL	3642	2248	294.37
211	1058	WNTHW	1118	1501	293.30
212	2125	PLSTN	1004	1545	292.62
213	411	RCLNS	1405	630	292.50
214	2200	FRMBG	1707	419	292.47
215	153	RSKMN	3057	1148	291.92
216	156	CNI45	2402	1381	291.45
217	1166	BLSRA	1601	1311	291.28
218	509	CRTLD	4711	3162	291.17
219	606	WEBBS	8614	2524	291.14
220	100	PKRVL	1051	3985	289.87
221	1276	KRUMS	1202	607	289.85
222	82	FHLSW	1321	344	288.65
223	365	HORNE	1972	753	287.74
224	1997	LGVST	8521	1684	287.48
225	2723	MSTLT	1011	88	286.63
226	1606	BRCRK	6522	2160	285.93
227	1920	TYWST	2013	1493	285.70
228	1402	NCRST	2204	398	285.26
229	1255	BONHM	1202	734	285.19
230	322	LKHLD	0005	1076	284.42
231	537	MESFR	2101	1911	283.86
232	490	MKNGB	5322	982	283.82
233	24	CLNSE	4201	909	283.31
234	172	MIDWY	0612	28	283.25
235	2112	LIGSW	1607	1384	282.97
236	36	DHIDE	2821	110	282.58
237	422	MKNSW	2601	2785	282.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
238	1733	MKNSW	2602	3038	282.34
239	2169	CRLJL	1502	359	282.11
240	392	TERSO	2501	180	281.53
241	1145	IRVVV	2851	2791	281.30
242	2637	NPKWY	0012	1582	280.75
243	1797	LUFKN	1205	1339	280.57
244	1817	CAMRN	1201	1014	279.87
245	933	KLBRG	0003	1182	279.77
246	538	CNTRY	2823	1823	279.23
247	1688	EULES	8732	1403	276.52
248	317	CDHCR	2053	269	276.05
249	963	HUBRD	1402	1024	275.89
250	114	MDAIR	2921	54	275.13
251	346	ARCTY	1311	436	275.04
252	2254	DESPR	1406	937	274.90
253	822	ODNTH	2014	661	274.60
254	1030	WNRTH	1419	306	273.85
255	536	STHRL	0004	1058	270.31
256	425	CDCSW	0007	859	269.77
257	497	PAYSW	1202	1638	268.20
258	676	NCNTH	1802	1650	265.80
259	113	GRSMN	3071	340	264.24
260	558	TYEST	1507	1184	264.05
261	1347	COYAN	6311	95	263.93
262	920	WEAST	0616	573	263.72
263	149	MRSES	4006	569	263.42
264	522	TYLNE	1624	223	262.13
265	812	OVRTN	4015	629	262.07
266	2183	KLNPS	1101	2096	259.43
267	1360	LIGSW	1608	321	258.78
268	1119	KEENE	1501	1530	258.50
269	182	ARPMN	4149	291	257.80
270	760	TMSTH	1408	748	257.49
271	1531	OTTOJ	3059	1170	257.01
272	1316	KIMBL	5011	678	256.83
273	439	LOT69	3023	911	254.48
274	2689	HORNE	1923	1561	253.88
275	1674	ALDTU	9411	2001	253.78
276	169	CSHNG	1204	329	253.33
277	1589	ATHNW	1403	2162	252.16
278	2064	LMESA	1531	1179	252.11
279	1072	CRNTH	2406	1542	252.10
280	734	PLSTH	1305	718	251.34
281	673	LOMAL	0001	682	250.88
282	1995	WXHCH	1202	1687	250.28
283	1553	LKHLN	0008	1139	248.94
284	176	SHNRW	1614	783	247.60
285	168	LNGLK	1602	653	247.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
286	2465	SHDYG	7841	336	246.94
287	1520	PKRVL	1053	3183	246.61
288	1191	WXNTH	2304	673	245.79
289	185	SHLMT	1801	308	243.99
290	393	LVBRD	0002	409	243.96
291	515	RYLTY	1421	409	243.88
292	2174	REYST	4040	568	243.73
293	797	NCNTH	1801	2435	243.03
294	1515	COPEL	3054	158	242.89
295	244	NCDCH	1203	1806	242.72
296	616	PRHLL	2402	67	241.25
297	2490	LMBLN	0004	47	240.56
298	1046	CNTRY	2822	2799	240.35
299	1188	NYLDV	1202	116	240.30
300	1416	GRSMN	4029	980	240.15
301	2138	MDWCK	0004	1691	239.96
302	847	MESQN	1508	1634	239.95
303	959	LKHLN	0007	1217	239.76
304	770	ECTOR	1201	258	239.69
305	789	HUTCH	1505	1175	239.46
306	1272	BRNSY	1221	79	238.85
307	981	DCATR	1201	1315	238.25
308	366	FLINT	3212	3246	238.15
309	1477	MCKMY	0811	1624	237.94
310	724	PWEST	1303	930	237.52
311	2008	TYEST	1511	886	237.13
312	2606	KLELM	2202	1112	236.24
313	1364	RRSTH	1705	444	235.48
314	825	MESQT	1305	835	235.07
315	1838	MDWPK	9241	1170	234.73
316	1496	REYST	4129	455	233.61
317	573	BSPSW	0851	1141	233.18
318	2330	WCITY	2402	693	233.17
319	765	CRSGL	1306	589	233.01
320	648	ATHNW	1405	888	232.84
321	158	PLGRV	0003	575	232.73
322	1699	RCHRD	1208	1067	232.52
323	1267	TMPLE	1204	1042	232.46
324	475	WALNT	0004	1455	231.60
325	641	LKHLN	0003	1345	231.25
326	1476	OTTOJ	3060	10	230.98
327	55	LFEST	1905	1705	230.59
328	145	SSPNE	1403	1741	230.28
329	301	CHALK	0911	130	230.20
330	1211	INDIA	2501	349	230.12
331	572	TYWST	2012	1791	229.51
332	1628	ALVDO	1902	857	229.50
333	2394	HKHTS	1604	817	229.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
334	2150	KLBRG	0001	311	229.26
335	1466	DAVIS	3782	960	229.10
336	2271	FRNKF	0006	2133	227.18
337	660	BNBRK	4121	4602	226.12
338	508	MNFLD	2672	2171	225.57
339	704	TRPMN	4094	548	225.19
340	N/A	CHSPG	2401	3011	225.16
341	2428	WWEST	1220	190	224.08
342	1907	MDLNW	1521	2474	223.58
343	2548	MKNNY	1253	97	222.83
344	624	WFNTH	0252	896	222.41
345	1385	CLYVL	9323	2227	222.00
346	759	WHITE	3512	1446	221.91
347	237	CNSES	3056	1891	221.78
348	387	CMEXP	1601	213	221.73
349	2546	TRNTY	7551	1757	221.40
350	1682	BNTDR	0003	356	221.13
351	155	MRSES	3015	589	221.10
352	286	CPLND	1101	942	220.64
353	934	WCOLO	1317	1287	220.34
354	2714	WALNT	0002	1229	220.26
355	979	SCHRD	0007	1252	219.88
356	1305	SPRDL	4811	1079	219.88
357	1277	SCYEN	0003	1219	218.71
358	132	NCWDN	1121	53	218.58
359	84	SHMNE	1409	876	218.34
360	131	SHDYG	7842	669	218.26
361	1747	PWEST	1302	338	218.11
362	31	MEANS	4411	131	217.89
363	456	RDOAK	1302	1200	217.54
364	657	EZACH	0001	1001	217.45
365	967	COMRC	1201	1016	216.87
366	1148	CLLVL	0002	491	216.76
367	334	PARIS	1206	984	216.18
368	989	BNBRK	4112	2105	215.73
369	250	MKNNY	1252	1855	215.26
370	2418	LMBLN	0008	118	214.42
371	1238	BDFRD	8831	745	213.51
372	749	PLKST	0008	1682	213.19
373	135	ANDRD	0931	178	211.55
374	367	TRSES	1202	518	211.46
375	215	DNCNV	1902	1037	211.44
376	1666	CHROW	0004	177	211.35
377	1621	HLSES	0553	1817	211.26
378	1762	MCGRG	1902	457	211.01
379	476	CRLTN	1453	249	210.43
380	2398	CPLSO	4322	56	210.17
381	2501	LOMAL	0004	154	209.94

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
382	2042	ALPHA	0010	514	209.89
383	15	COYAN	6321	300	209.80
384	664	TYWST	2002	60	209.48
385	388	CNSES	0370	613	209.28
386	105	ELCTR	1211	294	208.94
387	1317	DENAV	0662	570	208.86
388	N/A	PCOMM	3313	461	208.79
389	780	LFSTH	1406	1868	208.73
390	2234	KLELM	2205	2991	208.71
391	261	CRKET	2403	1397	208.24
392	396	RSPCK	2102	1560	207.90
393	685	LFEST	1902	1481	206.66
394	309	FERIS	1101	1091	206.53
395	1397	GNSVE	1603	1527	206.11
396	160	MESQT	1303	204	205.83
397	627	ALNSW	2654	2214	205.70
398	1912	WITTS	1701	1843	205.61
399	1740	GAVSW	0012	1173	205.52
400	2673	DGNST	0004	632	204.70
401	2299	GPLND	1201	663	204.47
402	93	CMBTP	1201	255	203.24
403	238	RYLTY	1431	72	202.69
404	2070	DAVST	0007	995	202.61
405	2040	PARIS	1201	1152	202.60
406	843	HUBRD	1401	901	202.58
407	644	ELGIN	1002	2099	202.31
408	2291	PLSTN	1005	1870	202.02
409	223	TXHRV	1611	153	201.82
410	1450	MESQN	1507	626	201.64
411	288	LRENA	2901	921	200.90
412	1586	CNI45	1202	803	200.82
413	672	LOMAL	0013	1006	200.46
414	2141	BLKST	1781	1918	200.16
415	2726	RRSTH	1707	352	199.92
416	304	ROANW	9512	1817	199.72
417	1005	GAVSW	0005	1341	198.88
418	1573	CRLTR	2051	3854	198.63
419	593	LNCST	1605	699	198.45
420	740	CLBRN	1202	990	198.37
421	2488	RWALE	3326	2337	198.35
422	357	MCGRG	0775	525	198.18
423	2320	PLANO	1102	122	198.11
424	225	PERIN	1511	611	197.82
425	2391	GODRD	8132	1547	197.77
426	60	EDGWD	1101	578	196.28
427	1533	WESTS	1602	883	195.89
428	2039	ATHNW	1401	891	195.81
429	65	DNINR	1403	1192	194.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
430	600	DUVAL	0421	1185	194.63
431	2388	HRSMD	1955	1412	194.40
432	52	NCSTH	1506	86	194.14
433	1096	LWSNR	2241	1131	193.77
434	1768	BRGPR	1102	1263	193.48
435	1607	FSCRK	6724	5046	193.46
436	2084	CRSGL	1302	1439	193.35
437	1061	PLSTH	1301	671	192.69
438	1984	LNDAL	2201	1727	192.22
439	307	ELKTN	2508	1249	191.94
440	1467	RDOAK	1304	2537	191.68
441	463	BDFRD	8821	950	191.47
442	376	KNEDL	6312	2760	191.25
443	1792	FLMSO	3712	2521	191.11
444	924	NLNVL	2002	2324	190.92
445	1730	WWDWY	2015	1219	190.63
446	1493	WHTRK	0003	1225	190.49
447	311	DIBOL	1506	642	189.76
448	66	CRSSN	7911	664	189.64
449	385	CANTN	1303	850	189.54
450	166	FRFWS	3004	832	189.51
451	615	SHLMT	1802	391	189.26
452	507	MCGRG	0776	210	189.00
453	1669	WMRLD	0003	479	188.85
454	2202	SORCY	0003	818	188.74
455	2173	CDCSW	0003	658	188.18
456	1100	MRTSP	1504	696	188.13
457	1460	PRFTW	4211	3284	187.97
458	1524	LSCOL	2114	61	187.88
459	1068	FRNKS	1201	363	187.83
460	389	MDWCK	0007	1064	187.81
461	761	SWAN2	1803	1041	187.33
462	1248	IOWPK	0811	771	185.90
463	2585	CNEXP	0006	1129	185.70
464	1852	WWDWY	2022	1001	185.21
465	1071	HHSTH	1502	2668	184.96
466	631	ODESW	5221	1420	184.94
467	1841	GRLND	1606	793	184.45
468	2408	MLDR2	1605	815	183.75
469	99	ITALY	2101	513	183.71
470	2705	ENTOH	0004	1304	183.40
471	1189	LWRDR	0001	1155	183.13
472	1009	GAVSW	0009	1086	183.13
473	2479	WEBBS	8613	594	183.05
474	521	HUTCH	1502	553	182.82
475	1246	ALLEN	2404	1987	182.51
476	1056	SGOVL	1402	896	182.37
477	2338	WNRTH	1418	1745	181.96

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
478	919	RCHRD	1202	796	181.71
479	1203	WDGWD	1592	1164	180.52
480	1650	WSOTH	1020	1132	179.65
481	1226	MESTE	1207	876	179.36
482	1262	CRNDL	2403	877	179.31
483	1001	CNTRY	2813	2980	179.26
484	1352	DENDR	0008	79	179.18
485	397	TYEST	1503	1054	178.83
486	1544	OKLND	0002	1180	178.79
487	1941	PARIS	1203	965	178.30
488	866	CHNDL	1201	1801	177.56
489	601	DUVAL	0483	1127	177.23
490	978	LOMAL	0015	337	176.98
491	2495	DENDR	0005	397	176.71
492	1630	BLKST	1752	1163	176.52
493	983	BNBRK	4111	2844	176.48
494	2107	RWDHV	1906	630	176.32
495	2024	BRNAV	0723	1306	175.62
496	1328	ATHNS	1203	968	175.35
497	1503	RICES	0206	590	174.82
498	151	DNIWS	1601	901	174.51
499	358	FRFWS	3002	840	174.46
500	1791	LKMNT	0005	595	174.31
501	1342	TRNTY	7521	844	174.11
502	1136	DNISN	1204	1248	173.97
503	195	KFMISO	1301	903	173.81
504	2564	IRVNR	1557	3315	173.77
505	1915	KLNPS	1103	2088	173.62
506	878	CNTRY	2842	1120	173.54
507	1695	WNTHW	1116	637	173.28
508	34	TSLVL	4008	1919	173.27
509	903	BRHLW	7642	924	173.11
510	2365	IRVNR	1552	56	172.86
511	1604	FARON	4052	1076	172.39
512	1565	REYST	4051	1075	171.69
513	1904	IRASB	3211	745	171.59
514	570	SIKES	2421	1150	171.28
515	604	GLNHV	3942	1354	171.14
516	2537	BLSRA	1602	152	170.90
517	2582	DEALY	0004	866	170.74
518	247	FSCRK	6732	2773	170.42
519	2521	WNTHW	1119	1308	170.04
520	2698	STHRL	0007	241	170.01
521	1293	RWALL	1204	1073	169.96
522	1928	WEAST	0629	1807	169.69
523	1414	WELRD	0004	799	169.12
524	1110	WICKT	0431	11	168.74
525	1329	FRMBG	1701	72	167.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
526	1244	TRNTH	1503	1690	167.38
527	395	TATSP	4323	2158	167.29
528	1215	NCDSW	3813	384	167.11
529	2350	SORCY	0001	2448	166.84
530	2078	TYLER	1004	188	166.43
531	1934	RWDHV	1907	737	166.43
532	53	TRPMN	4023	406	166.20
533	2016	ROBNW	1503	1539	166.03
534	N/A	ALDTU	9421	1243	165.95
535	2071	BRCRK	6511	1207	165.76
536	383	PRFTW	4221	1321	165.66
537	1976	WHOUS	4128	334	165.52
538	1778	POYNR	1201	339	165.51
539	1687	MDDTN	4322	27	165.45
540	2791	FRMNT	0012	428	165.23
541	541	ODESA	0242	625	165.17
542	280	ATHNW	1404	1587	164.92
543	1865	MESWE	3611	1669	164.80
544	2192	WCOLO	1316	1965	164.77
545	283	KRGRV	2403	3099	164.72
546	107	GVFTW	1801	596	164.16
547	174	RSPVY	1706	1307	163.68
548	1566	GLNHV	3911	1348	163.59
549	1642	MKNSW	1602	664	163.49
550	561	DNISN	1201	1301	163.38
551	726	LMBLN	0001	1812	163.36
552	2144	ARCTY	1321	892	163.29
553	2120	BNDRA	0006	484	162.89
554	481	WKATY	1718	2147	162.83
555	1312	PAYSW	1213	1412	162.48
556	650	ELKTN	2506	1719	162.47
557	829	OAKHL	3062	2027	162.35
558	687	CRTL D	4732	3073	162.30
559	851	GMINI	5811	2861	162.09
560	745	HSKAV	0001	1012	162.08
561	1930	TYLER	1005	1993	161.86
562	267	CLMET	0002	1358	161.78
563	426	CRNTH	2401	2264	161.27
564	2115	LWSNR	2232	2193	161.14
565	1877	MKNNY	1202	1760	160.98
566	1233	SHDYG	7822	500	160.92
567	1012	BLMND	3221	89	160.67
568	95	CRKET	2402	2912	160.55
569	1955	MDLNW	1511	2327	160.49
570	952	MURPH	2751	2186	160.39
571	1143	ELGIN	1001	478	159.94
572	1637	HMTRD	0002	996	159.88
573	1516	MEXIA	4040	878	159.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
574	344	TYRSW	1703	1297	159.76
575	1490	BLMED	1619	1023	159.56
576	977	WDGWD	1522	1467	159.42
577	2270	CHROW	0001	125	159.27
578	991	PREST	1603	1485	159.02
579	1344	CHROW	0005	163	158.99
580	2334	ATHNS	1202	767	158.97
581	2754	PWEST	1304	1259	158.41
582	1047	DALRK	1305	1067	158.32
583	995	AYERS	4411	1136	158.31
584	1914	CRTLD	4742	1730	158.30
585	419	WTHRE	2101	1093	158.04
586	772	DIBOL	1505	1444	158.00
587	390	IRLBJ	3221	3181	157.98
588	448	MAREA	1201	143	157.85
589	2631	TYEST	1509	383	157.72
590	2594	RRNES	2407	1345	157.50
591	994	SMFLD	2311	974	157.39
592	710	DENAV	0611	843	157.19
593	427	WSTHL	3621	4221	157.19
594	67	MYPTX	2401	227	156.90
595	1864	FERIS	1103	874	156.71
596	1696	BLTLN	0007	758	156.36
597	1389	TYEST	1506	456	155.78
598	2086	MDWCK	0008	881	155.35
599	2583	IRLBJ	3211	2499	155.07
600	1759	LAVON	1454	2525	154.81
601	453	IRVNG	1403	508	154.81
602	701	LFSTH	1408	1884	154.78
603	354	TRLWD	7722	3806	154.69
604	1925	OKCLS	0007	466	154.68
605	2362	TEGMN	3040	776	154.66
606	783	CMPST	0002	611	154.48
607	785	TATSP	4312	2467	154.44
608	747	DUVAL	0434	2317	154.38
609	613	RKDLE	1302	1142	153.96
610	285	ENSSO	2001	215	153.84
611	291	DNINR	1402	542	153.19
612	1769	FSHSW	2111	297	153.15
613	938	WMRLD	0002	1560	152.77
614	1028	GSTHW	1692	697	152.68
615	2634	MESFR	2103	355	152.30
616	2711	LMBLN	0003	167	152.10
617	2015	MSLSW	0001	1143	152.04
618	1006	HURST	1831	1336	151.97
619	2194	BRKRG	0213	745	151.82
620	1162	MNHNS	1911	1239	151.66
621	2487	BSPSW	0841	1989	151.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
622	505	TRIRA	6221	910	151.54
623	2187	RKDLE	1301	1194	150.45
624	1821	SGOVL	1404	1949	150.44
625	717	KMASB	1711	310	149.96
626	1546	LKMNT	0008	992	149.91
627	1834	MEXIA	3015	99	149.76
628	1698	HDWLK	3001	952	149.75
629	75	LKBRN	2401	1649	149.73
630	63	LUFKN	1203	1527	149.56
631	2535	IRVNR	1559	2266	148.93
632	173	EDGWD	1102	955	148.90
633	N/A	MKNSO	3611	1044	148.87
634	6	PEGAS	2311	111	148.39
635	2340	KNEDL	6321	2320	148.38
636	518	LGVST	8511	736	148.24
637	23	HUTCH	1503	506	148.23
638	997	WDGWD	1552	315	147.84
639	451	INAIR	1413	1660	147.83
640	2028	LOMAL	0005	494	147.83
641	944	RCHLD	2101	761	147.22
642	918	DAVIS	3743	485	146.97
643	2738	KLNSO	4501	2856	146.90
644	732	WEAST	0618	884	146.74
645	1147	PLSTH	1304	1291	146.62
646	374	MRTNS	1502	434	146.49
647	1204	REGST	0004	953	146.21
648	352	TYOMN	1409	1466	146.16
649	94	PPARK	1806	842	145.54
650	937	INAIR	1432	2814	144.69
651	974	EULSO	9122	1303	144.59
652	678	PRCTR	1602	228	144.54
653	163	NCDCH	1206	1080	144.48
654	1689	LAVON	1453	2223	144.15
655	574	WCITY	2401	942	144.05
656	129	EDGCF	2252	389	144.02
657	457	CHYNE	9111	30	143.70
658	835	BNTDR	0002	1579	143.70
659	468	ESTLD	3621	1446	143.68
660	697	CLMET	0003	875	143.36
661	1359	WGROB	8411	2823	143.34
662	794	ALNSW	2652	4258	143.16
663	1089	MNHNS	1921	1758	143.11
664	1224	TMPLE	1203	1433	142.79
665	1324	AMMFG	5611	802	142.60
666	753	GRDPR	0842	1240	142.44
667	1773	DAVST	0006	1151	142.26
668	1787	CRANE	0311	709	142.00
669	524	TRSES	1201	497	141.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
670	1294	KEENE	1503	803	141.54
671	1157	HORNE	1961	1464	141.47
672	1102	RENSW	3121	1957	141.30
673	2436	CRNTH	2403	1462	141.25
674	243	WSTHL	3652	2863	140.88
675	478	RBNSN	2501	1915	140.78
676	1482	ALLEN	2406	2632	140.08
677	1195	WMRLD	0007	1662	139.90
678	2648	BEAST	4088	120	139.86
679	1475	GRPVN	8222	687	139.50
680	1679	WELRD	0008	1129	139.45
681	1369	BOWEN	3171	1708	139.17
682	2060	PSHIL	1604	1144	139.01
683	2462	EMPCT	0004	348	138.48
684	842	CRLJL	1501	1456	138.36
685	123	RBNSN	2502	1160	138.27
686	1646	BAKKE	6911	114	138.12
687	489	RDOAK	1301	3137	138.04
688	259	COMRC	1203	650	137.97
689	2	GLSCK	2411	221	137.89
690	695	IRVNG	1406	1171	137.83
691	2751	BNDRA	0004	716	137.70
692	1492	NMAIN	0282	1155	137.51
693	268	NHNSW	0007	925	137.23
694	1002	RCHHL	0342	965	137.18
695	619	TYLNE	1605	1092	137.17
696	1146	FORSW	2051	2044	137.15
697	1320	KLNTF	1804	1032	137.07
698	1074	SNYDR	1852	1321	136.98
699	1676	BARRY	1801	85	136.93
700	1122	MEXIA	4012	1125	136.85
701	1926	RSPCK	2104	1906	136.80
702	1711	MRDCK	0002	1363	136.71
703	189	TERSO	2503	1613	136.69
704	888	CLYVL	9321	957	136.33
705	1785	TMNTH	1605	1728	136.29
706	592	MRTNS	1503	355	136.23
707	1439	WEBBS	8624	3052	135.87
708	1574	KRUMS	1201	181	135.56
709	1489	SPRDL	4831	1230	135.44
710	1020	EDGCF	2282	998	135.36
711	326	WXHCH	1204	1604	135.28
712	727	WCOLO	1319	2011	135.28
713	2245	MDWPK	9231	2363	135.26
714	1265	LMESA	1522	1338	135.19
715	1275	JKSNR	4109	665	135.02
716	1808	TMPSE	1501	1510	134.87
717	83	CRLTN	1454	306	134.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
718	951	SPRTN	1801	1685	134.69
719	756	NECSP	2401	518	134.48
720	1425	HKHTS	1608	1301	134.44
721	1957	CMNCH	1401	976	134.37
722	569	KMP SO	2400	906	134.35
723	1256	WATCO	2605	1715	134.11
724	1783	TYLER	1012	785	134.06
725	108	VANSB	1502	1633	134.04
726	848	WLSPT	1002	580	133.95
727	407	NCDCH	1204	1224	133.84
728	1727	BRKRG	0232	1722	133.59
729	1111	NCWDN	1111	677	133.51
730	1411	CMTSW	0941	866	133.46
731	69	NSTAR	2011	542	133.00
732	14	UPTON	0721	85	132.98
733	2250	BBTWN	1501	1968	132.83
734	1848	SMFLD	2323	524	132.31
735	2241	WXHCH	1203	1221	132.27
736	947	SGOVL	1401	1674	132.26
737	2530	ENTOH	0002	789	132.11
738	867	WEAST	0617	1322	132.04
739	2206	NCSTH	1505	12	132.00
740	1631	PROAD	0004	982	131.87
741	2399	PLANO	1101	312	131.85
742	610	SANSM	3922	1674	131.66
743	271	IRVNG	1407	1425	131.56
744	1140	RHOME	2402	1212	131.51
745	1091	STAUG	0001	621	131.40
746	1483	CTYVW	2222	1391	131.25
747	2166	ANDNR	2231	2019	131.24
748	2627	CRKET	2401	142	131.11
749	527	HLSES	0561	1763	130.92
750	1702	WMRLD	0004	1476	130.71
751	2368	RWALS	1852	1625	130.30
752	1142	CRSCN	1206	1529	129.82
753	2555	ALLNC	6411	43	129.72
754	1206	ATHNS	1201	949	129.62
755	1202	LUFKN	1208	2130	129.38
756	436	OKCLS	0004	1420	129.35
757	941	MKNGB	5321	527	129.19
758	2619	DEALY	0002	1131	129.07
759	926	CLBWS	8121	1379	128.87
760	472	JKSBR	1402	1189	128.72
761	431	MESTE	1213	1323	128.65
762	470	DCVSO	1107	1031	128.47
763	1799	PRSTN	0008	706	128.38
764	836	CLLVL	0004	49	128.29
765	297	TAYLR	1202	1433	128.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
766	1257	HKBRY	1107	35	128.23
767	773	SPRDL	4821	1333	128.00
768	1280	PAYSW	1205	680	127.77
769	1187	LKHLD	0006	739	127.74
770	579	MCGHR	2004	18	127.61
771	653	ALPHA	0015	810	127.40
772	35	HNRTA	0321	857	127.37
773	830	EZACH	0005	526	127.28
774	875	RRSTH	1702	3090	127.24
775	187	RSKMN	3046	1070	127.08
776	915	SORCY	0004	592	127.02
777	811	HLSES	0511	1427	126.99
778	1588	WSOTH	1017	1765	126.98
779	1254	HSKAV	0003	1320	126.86
780	488	TAYLR	1204	1599	126.68
781	939	MSHLN	0004	1018	126.53
782	231	JKWST	4033	733	126.29
783	330	LNDAL	2203	2011	126.28
784	2238	CNTRD	0003	1381	126.03
785	1038	HKBRY	1106	1626	125.74
786	871	DCATR	1202	1654	125.54
787	1094	WALNT	0008	863	125.39
788	2799	LOMAL	0007	134	125.01
789	245	CDHIL	1613	2685	124.89
790	1663	JEWET	1204	1457	124.71
791	646	WESTS	1601	1093	124.54
792	2007	CLKVL	1202	1318	124.28
793	349	CDCSW	0008	671	124.14
794	484	GODLY	1601	595	124.07
795	2175	LWSNR	2221	1071	124.03
796	1036	WSANG	2802	631	123.99
797	905	ODNTH	2044	2073	123.91
798	310	AMMFG	5631	1343	123.91
799	2405	OAKHL	3041	895	123.73
800	2009	GMINI	5821	359	123.47
801	2742	ALPHA	0006	292	122.97
802	1539	KILEN	1202	1762	122.91
803	359	HNYGR	2401	459	122.79
804	682	HNTNG	1305	1142	122.73
805	632	EULSO	9131	1968	122.67
806	1048	PLSTN	1002	1169	122.61
807	1484	RHOME	2401	1096	122.44
808	2249	GORMN	0411	451	122.14
809	2566	DAVST	0001	536	121.86
810	764	PREST	1601	997	121.83
811	2716	CHROW	0002	109	121.65
812	633	BLKST	1711	1905	121.56
813	1093	KILEN	1204	1394	121.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
814	302	SHNRW	1609	1437	121.27
815	699	PFFRD	3421	889	120.99
816	449	RENSW	3124	599	120.89
817	1383	EZACH	0007	1561	120.89
818	2261	GVODS	3072	2216	120.88
819	2419	SYCRK	4511	1883	120.32
820	2285	PSHIL	1606	377	120.25
821	686	NCDCH	1202	1053	120.07
822	755	MRLNS	4002	454	119.99
823	1897	NHNSW	0002	647	119.80
824	643	WXHCH	1201	1654	119.58
825	1956	ANDNR	2211	1612	119.55
826	2319	CMTSW	0962	598	119.52
827	294	TYWST	2003	1497	119.30
828	1113	MCWHT	3511	2853	119.16
829	625	FRMBG	1705	190	119.15
830	2467	PLKST	0005	1457	119.06
831	2023	EZACH	0008	1490	119.03
832	2505	BRHLW	7622	1120	119.02
833	768	KNEDL	6311	2355	118.85
834	840	SSPSW	1604	1109	118.75
835	786	HMTRD	0004	1021	118.59
836	531	GRLWS	1706	258	118.42
837	563	KLNCC	1704	1777	118.40
838	833	FRNKF	0005	1567	118.27
839	2114	GODRD	8122	872	118.03
840	264	CDHIL	1623	1825	117.91
841	1993	PCOIT	1022	2054	117.84
842	112	MRSES	3019	15	117.63
843	2243	VANAL	1201	562	117.57
844	1381	TRNTH	1504	855	117.51
845	1617	DAVST	0005	1769	117.49
846	1021	HOLDY	0911	1135	117.37
847	927	FHLSW	1332	287	117.20
848	1207	OAKHL	3052	724	117.03
849	1023	EDGCF	2213	3011	116.80
850	790	BDFRD	8812	767	116.75
851	1975	CRNAT	4121	62	116.75
852	1827	GRPVN	8223	2001	116.75
853	526	CKRHL	0008	1617	116.59
854	2128	RWDHV	1901	905	116.58
855	1165	DENAV	0621	1635	116.50
856	1192	ESTLD	3611	1522	116.43
857	2679	REAST	1507	108	116.41
858	824	LFEST	1904	1313	116.40
859	2474	RRSTH	1706	2943	116.37
860	22	ANDRD	0921	88	116.29
861	1131	WHOUS	4121	1226	116.23

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
862	2027	CDHCR	2050	802	116.09
863	1278	IRVNE	1303	1400	115.93
864	1672	HUTTO	2721	3911	115.83
865	256	BNBRK	4122	2060	115.80
866	2706	BKWST	0002	1298	115.75
867	1080	STNVL	1203	1373	115.74
868	942	MSHLN	0007	717	115.65
869	96	MAYFD	5524	3029	115.49
870	913	BLKST	1771	1212	115.45
871	1996	WNTHW	1120	1011	115.36
872	707	TAYLR	1201	1624	115.32
873	292	PRCRK	0004	1398	115.07
874	1936	CRKET	1201	313	115.04
875	972	BELLS	1201	539	114.99
876	1880	TRNTY	7541	636	114.94
877	1011	BLTON	1802	1294	114.88
878	1659	SCYEN	0001	1901	114.84
879	193	TYLGE	1316	2568	114.70
880	219	GRNGR	1801	868	114.68
881	1218	ALVDO	1901	1148	114.46
882	985	NHNSW	0006	925	114.38
883	607	PARIS	1202	1189	114.38
884	2233	CRANE	0331	1099	114.15
885	1979	SYCRK	4522	1175	113.99
886	2341	SNYDR	1833	1410	113.93
887	2273	INAIR	1414	759	113.62
888	2263	STAUG	0008	1949	113.52
889	1474	HDWLK	3003	925	113.33
890	577	SGOVL	1403	1939	113.25
891	1438	BLKST	1721	1003	113.19
892	2820	RGFTW	6841	17	113.11
893	2393	RGLRW	0006	34	113.08
894	1130	MNHNS	1912	1607	112.99
895	1090	CLKVL	1201	442	112.95
896	1902	BLTON	1803	416	112.89
897	857	OAKHL	3072	2335	112.87
898	583	PRNTH	1406	1079	112.85
899	1164	RRSTH	1703	3401	112.50
900	183	QNLAN	1201	820	112.15
901	946	RDLML	2521	969	112.12
902	2527	ARTHR	0481	1250	111.86
903	1454	CRLTN	1401	779	111.82
904	1123	CRNTH	2405	3140	111.82
905	1155	OAKHL	3011	1994	111.63
906	380	TYLNE	1623	446	111.58
907	901	GODRD	8131	1657	111.52
908	975	PRKWY	1511	1281	111.37
909	316	MRLNS	4003	1006	111.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
910	2615	DGNST	0003	266	111.32
911	1049	BONHM	1210	1120	110.96
912	496	KYSTN	1031	24	110.92
913	800	CLKVL	1203	610	110.85
914	1008	SALDO	3001	383	110.81
915	1909	RNDRK	1501	577	110.80
916	1935	TMPNW	1104	1844	110.80
917	1208	WALST	0005	215	110.79
918	356	KIMBL	5021	2333	110.74
919	192	BRLSN	2041	3950	110.56
920	2652	BLMND	3282	76	110.52
921	1644	CRSWS	1401	1331	110.27
922	645	AZLES	2111	2773	110.26
923	28	PEGAS	2321	114	110.21
924	1499	CLBNR	1404	1321	110.09
925	279	PLSTN	1001	1677	110.02
926	1487	SHRSW	6621	1741	109.93
927	702	FRMBR	1803	1624	109.91
928	1281	IRVNE	1306	968	109.86
929	2614	RDRSE	2602	2713	109.77
930	1365	PRNTH	1401	1362	109.47
931	622	HLTOM	2472	1762	109.37
932	210	BRGPR	1101	638	109.18
933	1771	ELMGV	3653	1682	109.18
934	190	BRLSN	2033	1663	109.16
935	1752	CDCSW	0006	1285	109.03
936	1744	RWALL	1203	3051	108.85
937	2089	PLANO	1104	839	108.71
938	1954	WXNTH	2301	1217	108.63
939	776	WXNTH	2305	1472	108.63
940	517	EDDYS	0710	658	108.58
941	2458	RWDHV	1908	1861	108.37
942	1086	HDWLK	3005	941	108.20
943	1433	WBROK	3011	192	108.20
944	1814	RDLML	2581	1215	108.09
945	965	CRLTR	2053	1705	107.97
946	1756	WWEST	1219	935	107.96
947	844	THRNE	0005	1261	107.74
948	1548	RCLNS	1404	295	107.69
949	1710	CRLTR	2002	1094	107.62
950	1237	AYERS	4431	1598	107.40
951	165	TLRWT	2203	766	107.29
952	N/A	FRMNT	0006	10	107.10
953	530	DALWT	2991	1183	107.08
954	2743	LEMON	0009	1695	106.88
955	1379	GRLND	1605	1394	106.88
956	121	IRVGS	1902	1386	106.85
957	2298	KLNPS	1102	1834	106.71

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
958	2186	ITSCA	1702	217	106.70
959	2281	ATHNW	1402	420	106.62
960	1613	MRSES	4005	1536	106.29
961	1186	CDHIL	1802	813	106.25
962	224	LOMAL	0011	1104	106.18
963	703	WATCO	2602	2063	106.17
964	217	WOVER	6142	1459	106.09
965	706	BRKRG	0242	16	106.07
966	2220	HLSES	0542	1090	106.05
967	1919	GVODS	3041	1454	106.04
968	1868	MEXIA	4008	728	105.98
969	1677	ELKTN	2501	1595	105.93
970	1	PLDAV	4211	50	105.84
971	2296	PTENN	2354	2561	105.75
972	2469	CPRCV	1403	1416	105.70
973	1506	LNCST	1601	675	105.69
974	966	CRLTN	1452	573	105.69
975	1377	BDFRD	8841	812	105.43
976	482	IRVGS	1904	711	105.10
977	598	CRWLY	7011	414	104.79
978	743	DCVSO	1103	1542	104.69
979	1832	PWEST	1311	767	104.59
980	230	BRLSN	2052	2647	104.57
981	1820	STAUG	0004	1109	104.48
982	1813	WHOUS	4122	2087	104.42
983	179	WICKT	0421	205	104.39
984	1432	IRVHF	2305	1402	104.30
985	47	UPTON	0711	118	104.24
986	742	NPKWY	0006	2511	104.22
987	45	EZACH	0003	1282	104.21
988	2133	BLTON	1806	602	103.93
989	408	GRDPR	0881	2024	103.82
990	1443	EMPCT	0008	32	103.69
991	2681	BDFWD	8922	2159	103.45
992	2687	PROAD	0007	401	103.36
993	666	TYBLR	2811	1038	103.30
994	2142	LOMAL	0002	635	103.26
995	669	WNRTH	1416	732	103.22
996	1077	CRSCN	1203	1918	103.18
997	394	MRVLY	2311	376	103.17
998	1198	KLNPS	1105	1565	102.72
999	361	BOWEN	3132	1716	102.63
1000	1333	ABRRD	0004	817	102.57
1001	813	COLNY	2401	741	102.33
1002	1858	BKBNT	1832	189	102.18
1003	240	CRTL D	4721	3430	102.14
1004	221	OKLND	0004	1418	102.10
1005	889	OAKHL	3082	1379	102.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1006	661	TRNTH	1501	1420	102.02
1007	2736	RSPCK	2103	17	102.00
1008	N/A	AMLIA	0006	75	101.89
1009	117	GDPRW	9611	1164	101.81
1010	721	COPEL	3056	2219	101.71
1011	1626	ENNIS	1903	1289	101.33
1012	1161	MNWLW	1403	857	101.14
1013	1318	SHSTH	1305	428	101.00
1014	2109	TYWST	2004	998	100.92
1015	535	WOVER	6122	2586	100.90
1016	1723	GODRD	8142	941	100.65
1017	430	NCDCH	1205	1058	100.47
1018	2369	MKNNY	1201	1270	100.16
1019	1960	SHAMP	0004	907	100.08
1020	1713	ALLEN	2403	1494	100.06
1021	1461	CDCSW	0001	254	100.03
1022	603	MDAIR	2911	427	99.98
1023	115	GRLND	1604	1902	99.95
1024	196	GLNHV	3953	793	99.89
1025	281	BRTRD	7311	963	99.74
1026	688	MAYFD	5511	4050	99.67
1027	2385	IRVVV	2803	143	99.66
1028	1171	TRNTH	1502	457	99.58
1029	62	BRKNR	1211	107	99.57
1030	1386	FRNKF	0001	502	99.38
1031	2268	KNLTR	0005	2418	99.28
1032	2257	DUBLN	2214	700	99.27
1033	506	BRLSN	2062	3171	99.20
1034	582	WELRD	0001	1217	98.96
1035	1885	ECTHM	3311	1300	98.95
1036	494	FORSW	2053	2947	98.84
1037	2198	MSTLT	1021	1309	98.62
1038	1818	ARLNG	1241	636	98.35
1039	2507	RDRSE	2604	2186	98.20
1040	2492	NMAIN	0231	314	98.11
1041	1745	BLTSW	3203	1117	97.92
1042	838	GRPVN	8231	375	97.92
1043	1973	STHRL	0001	642	97.89
1044	86	RYSSW	2801	1754	97.58
1045	295	MDLNE	0112	615	97.41
1046	328	RDRSE	2601	1215	97.30
1047	429	FINKS	1803	1238	97.21
1048	1065	PRKRW	3341	431	97.17
1049	2216	BRKRG	0223	254	97.14
1050	1541	BLTLN	0006	898	97.12
1051	2600	MDWCK	0003	1860	97.07
1052	590	IRVNG	1408	1023	97.02
1053	791	PCOIT	1004	738	96.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1054	1715	GRMES	0512	1140	96.85
1055	1741	RKDLN	1401	900	96.81
1056	2226	PPARK	1803	1044	96.76
1057	2395	PLANO	1106	482	96.72
1058	2439	TMPLE	1206	731	96.69
1059	2106	LNDAL	2202	1161	96.64
1060	1850	TMPLE	1202	1371	96.63
1061	227	SHAMP	0001	1034	96.53
1062	2093	PWEST	1301	1231	96.48
1063	1591	DESHR	1202	1872	96.40
1064	718	ITSCA	1701	733	96.34
1065	1016	IRLBJ	3212	2541	96.23
1066	1465	RSNHT	1162	1428	95.94
1067	1946	MESQW	1803	1622	95.71
1068	485	HORNE	1932	1069	95.66
1069	2379	RTHGB	1411	2281	95.58
1070	623	CRLJL	1505	866	95.50
1071	272	BRTLTL	1402	116	95.41
1072	266	MSLMN	4007	130	95.13
1073	198	ALLNC	6412	2204	95.12
1074	1593	BOWEN	3181	754	95.08
1075	333	BDFWD	8921	721	95.03
1076	1387	WDGWD	1541	1127	95.02
1077	1135	CDCSW	0002	2170	94.98
1078	437	WTAUG	4641	555	94.85
1079	1197	STNVL	1207	965	94.85
1080	849	WTAUG	4611	1399	94.79
1081	1811	CRLFR	2157	2401	94.78
1082	418	PRNTH	1404	1447	94.73
1083	1913	CNTRY	2862	398	94.67
1084	1395	IRVNR	1501	868	94.51
1085	1270	SPRTN	1802	840	94.40
1086	559	IRVNG	1405	1123	94.25
1087	1069	LKMNT	0003	550	94.05
1088	1932	MDLNE	0163	1013	93.87
1089	2417	FROKS	0003	489	93.82
1090	1334	AZLES	2121	2640	93.69
1091	2156	MESTE	1215	1322	93.59
1092	548	PREST	1604	1173	93.36
1093	1088	DALLW	0001	603	93.33
1094	2533	IRVVV	2802	1038	92.73
1095	2520	CNEXP	0001	189	92.64
1096	2081	HKHTS	1606	1679	92.45
1097	1196	MTLDA	0006	1733	92.44
1098	1384	CLYVL	9312	1230	92.44
1099	181	KRUMS	1204	331	92.42
1100	859	DEALY	0003	1049	92.39
1101	381	DALRK	1301	737	92.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1102	1480	WTAUG	4613	1806	92.35
1103	1651	CRLJL	1503	739	92.04
1104	1592	ODESW	5211	2009	92.02
1105	465	OAKCK	2211	42	92.00
1106	700	FHLSW	1311	1295	91.94
1107	1559	ABRRD	0005	557	91.92
1108	1598	CRLCC	2704	498	91.87
1109	626	SSPNG	1202	1155	91.78
1110	1901	DAVST	0004	1722	91.56
1111	368	COPER	1201	320	91.54
1112	696	WDGWD	1512	821	91.46
1113	2372	NCSFA	1702	952	91.42
1114	1500	MSLSW	0005	484	91.36
1115	681	WTAUG	4631	1118	91.30
1116	1261	BOWEN	3112	890	91.29
1117	922	LOMAL	0014	601	91.25
1118	1410	BDFRD	8832	946	91.25
1119	1891	WWDWY	2024	1412	91.22
1120	56	HNRTA	0311	1164	91.20
1121	2773	CNEXP	0003	1400	91.18
1122	1777	LKHLN	0001	1596	91.09
1123	2045	MDTHS	1002	959	91.09
1124	1972	NHNSW	0003	527	90.94
1125	2667	CMTSW	0915	683	90.53
1126	1810	RCHHL	0363	577	90.39
1127	2099	CNTRD	0004	1023	90.32
1128	2126	MESFR	2102	654	90.27
1129	90	BRIRV	6922	3184	90.12
1130	1828	PLANO	1103	1555	89.99
1131	2573	FRMNT	0008	1836	89.95
1132	1853	SHRSW	6611	1206	89.85
1133	807	TRLWD	7712	3756	89.84
1134	2806	MESTE	1201	22	89.70
1135	683	PFFRD	3441	1186	89.58
1136	2006	BLTLN	0003	1041	89.58
1137	N/A	SHNRW	1601	581	89.54
1138	2151	BMTWN	1621	1216	89.34
1139	986	LIGSW	1602	1125	89.33
1140	886	MKNNY	1254	799	89.30
1141	1398	TYEST	1508	617	89.25
1142	2191	ARTHR	0462	1075	89.21
1143	896	TYSTH	1201	983	89.14
1144	1497	CRNRD	0001	718	88.97
1145	1406	WCOLO	1315	1589	88.85
1146	1729	MKNNY	1205	471	88.82
1147	1321	BDFRD	8822	1048	88.82
1148	1686	RRSTH	1701	3266	88.80
1149	2504	LOMAL	0009	1052	88.74

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1150	902	RWALE	3321	1133	88.62
1151	1652	HORNE	1913	2255	88.62
1152	2252	BRKNR	1221	873	88.51
1153	486	ODNTH	2013	1584	88.46
1154	578	EULES	8711	2144	88.41
1155	1391	MESQN	1503	1817	88.38
1156	883	BRNAV	0753	1275	88.31
1157	249	WXNTH	2306	1511	88.28
1158	907	COPEL	3053	2056	88.27
1159	1705	BDFRD	8842	1438	88.27
1160	12	ELMAR	3221	112	88.26
1161	1437	FRMBG	1703	33	88.24
1162	2612	BDFWD	8931	1707	88.23
1163	444	DUVAL	0462	970	88.21
1164	2053	PPARK	1801	1263	88.10
1165	2569	HLSES	0533	49	88.10
1166	1803	IRVNR	1505	829	88.10
1167	2189	IRVNR	1508	1900	88.02
1168	1451	BLKST	1732	1291	87.96
1169	705	NVARO	1502	197	87.91
1170	618	DALLW	0002	64	87.86
1171	587	PFFRD	3452	552	87.81
1172	1182	RSKMN	3053	488	87.65
1173	1641	ALNTH	2851	1930	87.63
1174	1772	MDTHN	1703	993	87.55
1175	2642	ARLNG	1291	87	87.40
1176	1582	MRDCK	0001	2621	87.22
1177	2305	HMTRD	0001	947	87.09
1178	1521	TMSTH	1407	55	86.98
1179	491	CNEXP	0007	457	86.80
1180	2159	ESKSW	2711	109	86.79
1181	841	TYBLR	2808	888	86.68
1182	1154	FINKS	1801	1457	86.65
1183	1987	ODESA	0251	1749	86.24
1184	1552	DCVSO	1106	1169	86.18
1185	2001	BLTSW	3201	2459	86.11
1186	499	PSHIL	1608	1852	85.97
1187	213	LAVON	1401	1630	85.93
1188	652	SWTWR	1341	240	85.92
1189	2111	MRDCK	0003	1192	85.91
1190	2696	CKRHL	0006	66	85.83
1191	2741	ALPHA	0001	414	85.77
1192	2328	ANDNR	2242	1739	85.76
1193	1910	CMTSW	0973	1172	85.70
1194	1974	NIPAK	1001	124	85.68
1195	2370	PFFRD	3472	1260	85.34
1196	1169	MAYFD	5521	2925	85.32
1197	865	TATSP	4321	1452	85.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1198	251	FLINT	3211	1908	85.29
1199	282	NCNTH	1804	716	85.23
1200	1739	REAST	1506	1186	85.17
1201	386	NCRST	2201	1946	85.11
1202	1905	EDGCF	2223	3038	84.92
1203	2011	HLSES	0522	1459	84.77
1204	80	LIPAN	1301	479	84.76
1205	1728	ACRLY	1711	154	84.42
1206	1407	ROWLT	1104	877	84.36
1207	1355	DAVIS	3723	344	84.20
1208	1681	EULSO	9112	1865	84.17
1209	665	OAKHL	3021	1862	84.16
1210	2082	STAUG	0005	1134	84.05
1211	1622	DNISN	1202	787	84.03
1212	1980	ELMGV	3651	1826	83.95
1213	2692	CKRHL	0001	405	83.88
1214	1017	CRLFR	2152	3304	83.69
1215	1990	MLKF2	1202	454	83.60
1216	863	IRVBL	2501	379	83.47
1217	1742	HMPHL	2742	444	83.38
1218	891	CDHCR	2051	2025	83.38
1219	831	GSTHW	1682	149	83.27
1220	1079	WSTHL	3631	2071	83.25
1221	2054	MDLNW	1522	1329	83.17
1222	1478	MESTE	1205	1610	83.12
1223	1055	TYOMN	1405	1572	83.11
1224	2494	KLELM	2201	1525	82.83
1225	2165	CRLJL	1504	1216	82.81
1226	342	EDGCF	2262	838	82.67
1227	1986	AYERS	4421	1431	82.55
1228	293	MCKMY	0812	2215	82.34
1229	255	HOLND	1901	917	82.30
1230	2446	WALST	0003	118	82.21
1231	2484	CDHCR	2054	1336	82.12
1232	2771	CLLVL	0003	18	82.00
1233	668	COLNY	2403	2337	81.90
1234	1051	MDWCK	0001	854	81.90
1235	493	ENNIS	1904	1194	81.83
1236	1661	KLBRG	0004	899	81.83
1237	1307	IRVNE	1304	339	81.46
1238	1037	RWALL	1202	2268	81.03
1239	1563	WNDWD	3641	1455	80.87
1240	209	CLBNR	1406	104	80.85
1241	1043	PLKST	0003	1904	80.78
1242	1939	TYOMN	1408	1328	80.71
1243	89	REYST	4118	723	80.71
1244	2464	BLTLN	0004	660	80.64
1245	1488	IRVNR	1510	285	80.62

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1246	2702	PLSTH	1303	558	80.59
1247	2732	BNBOR	1203	302	80.52
1248	321	DNIWS	1602	1376	80.38
1249	2715	IRVND	1206	98	80.25
1250	1268	PLKST	0007	1867	80.06
1251	1348	NCSTH	1501	821	79.88
1252	1170	STANT	1311	1345	79.85
1253	2236	BSPRG	1902	2224	79.81
1254	2098	BLMED	1617	305	79.79
1255	2225	BRNAV	0762	2320	79.70
1256	2432	WHTRK	0006	1246	79.69
1257	1633	BOWEN	3192	1239	79.59
1258	2396	SHSTH	1301	1961	79.37
1259	1373	BLMND	3252	958	79.33
1260	1529	DNIWS	1603	1340	79.30
1261	2389	PCOIT	1006	1011	79.22
1262	1547	GODRD	8112	1403	79.22
1263	1263	PRKRW	3352	1346	78.85
1264	1761	PRSTN	0006	666	78.81
1265	1700	SYCRK	4521	4522	78.75
1266	832	SHRSW	6622	1473	78.74
1267	464	RDMLL	2542	344	78.74
1268	2747	FRMBG	1750	1139	78.66
1269	253	GVFTW	1802	831	78.64
1270	634	EDGCF	2211	2042	78.61
1271	384	EZACH	0006	1103	78.53
1272	1603	WWDWY	2020	1215	78.48
1273	2704	PPARK	1802	1436	78.45
1274	1900	MTLDA	0004	710	78.31
1275	1115	COPER	1202	863	78.30
1276	1109	RECCR	0006	367	78.26
1277	1571	MKNNY	1203	864	78.18
1278	2718	CKRHL	0004	298	78.17
1279	382	LKWOD	7442	726	78.03
1280	1860	CRLJL	1507	948	78.00
1281	2550	ADISN	1603	165	77.88
1282	1018	ADISN	1607	1245	77.88
1283	1843	FSTVW	0006	1649	77.86
1284	1025	TYOMN	1401	1510	77.81
1285	728	CLYVL	9311	1510	77.80
1286	338	SHNRW	1608	1420	77.73
1287	1645	SSPNG	1205	860	77.73
1288	808	BRCRK	6513	1111	77.67
1289	733	MAYFD	5522	2759	77.67
1290	81	RCHHL	0374	533	77.61
1291	466	ALVRD	1504	149	77.57
1292	1712	RRNES	2401	3397	77.51
1293	43	PAYSW	1223	115	77.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1294	241	IRVGS	1901	1292	77.44
1295	1250	FROKS	0004	118	77.34
1296	289	AZLES	2112	1466	77.32
1297	2416	ENTOH	0005	1065	77.26
1298	N/A	ALLEN	2410	2280	77.18
1299	998	HHSTH	1503	559	77.15
1300	203	WMMMR	2707	1505	77.06
1301	885	SCURY	1911	176	77.02
1302	1786	WNTHW	1121	743	77.01
1303	1356	EULSO	9121	1310	76.93
1304	1346	PCUST	2004	1056	76.74
1305	258	SHNRW	1611	891	76.50
1306	1174	KNLTR	0008	907	76.26
1307	955	RRSTH	1704	2904	76.23
1308	1921	PCUST	2011	2210	76.10
1309	2357	CURIE	7231	1067	76.07
1310	1413	PRCRK	0002	2034	75.96
1311	1168	JSHUA	1302	1292	75.93
1312	739	TMSTH	1404	1323	75.81
1313	2032	PRSTN	0003	2892	75.75
1314	143	KYSTN	1021	42	75.69
1315	1299	PLANO	1105	103	75.64
1316	992	WRBND	2311	1333	75.64
1317	1684	ODESA	0272	1637	75.61
1318	1643	CDHIL	1804	1139	75.53
1319	2772	CMTSW	0914	81	75.41
1320	417	RCHRD	1203	834	75.32
1321	1707	BAGWL	1202	49	75.30
1322	1426	MRDCK	0004	784	75.23
1323	1835	KLNTF	1806	1162	75.20
1324	1770	SSPNG	1204	953	75.02
1325	1847	WXNTH	2303	1650	74.99
1326	2239	PALRD	2207	1094	74.92
1327	546	VANAL	2412	2602	74.92
1328	162	RDLML	2512	1151	74.91
1329	655	SMFLD	2313	2178	74.81
1330	265	CDHIL	1801	725	74.80
1331	1223	RECCR	0001	157	74.78
1332	1367	MESFR	2104	146	74.70
1333	2807	MESTE	1203	169	74.69
1334	758	SMFLD	2381	843	74.68
1335	502	ARLNG	1232	1240	74.68
1336	2463	WSOTH	1019	719	74.63
1337	1755	ALLEN	2402	3179	74.47
1338	1024	EMPCT	0003	1427	74.01
1339	92	PKRVL	1052	2185	74.00
1340	1473	MCDMT	2531	2189	73.97
1341	364	DEALY	0001	1017	73.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1342	680	CPLSO	4312	1518	73.84
1343	1428	GMINI	5812	732	73.75
1344	2222	WTAUG	4623	723	73.70
1345	1963	COLNY	2402	2399	73.46
1346	674	CRLTR	2003	1343	73.41
1347	1998	IRVNR	1507	1801	73.40
1348	894	NWARD	3511	55	73.39
1349	2258	BSPRG	1901	551	73.29
1350	814	IOWPK	0821	739	73.26
1351	2214	GNSVL	1213	709	73.13
1352	175	JREST	2101	1099	73.07
1353	855	MESWE	3621	739	73.00
1354	774	BLMND	3211	11	73.00
1355	1331	FORSN	5611	231	72.98
1356	1027	MNWLE	1702	1224	72.95
1357	852	LWSNR	2242	1130	72.87
1358	2671	HHSTH	1504	2333	72.87
1359	500	RSPVY	1704	1237	72.84
1360	542	WMRLD	0006	570	72.81
1361	2650	LWSNR	2211	862	72.76
1362	638	CMTSW	0983	839	72.71
1363	433	ARLNG	1223	1564	72.46
1364	446	MNWLL	1206	1038	72.42
1365	890	CLBRN	1204	1092	72.40
1366	602	EULSO	9132	1723	72.32
1367	2301	MESQT	1302	1069	72.04
1368	2476	LEMON	0001	2051	72.03
1369	1158	BRNAV	0732	743	72.00
1370	1746	IRVND	1208	146	71.98
1371	2072	WALST	0014	771	71.96
1372	477	DALLW	0006	1873	71.94
1373	2073	LKBLT	2105	1155	71.94
1374	763	HUDSN	1601	946	71.90
1375	2599	SYCRK	4531	2240	71.88
1376	782	MESQW	1808	1333	71.86
1377	816	CHROW	0003	140	71.79
1378	1961	CNTRY	2824	3555	71.69
1379	1243	BMTWN	1611	1818	71.68
1380	554	PMBRK	1821	74	71.65
1381	1007	RGLRW	0003	91	71.64
1382	1840	MNWLL	1207	1931	71.52
1383	1831	ROWLT	1102	780	71.48
1384	2055	CRLTN	1403	114	71.27
1385	820	PRKRW	3311	786	71.12
1386	21	CADDO	0911	430	71.05
1387	1222	WHTRK	0008	1468	70.71
1388	2266	PFLGV	2005	3160	70.68
1389	555	WITTS	1703	1515	70.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1390	1259	SANSM	3921	4387	70.54
1391	876	EDGCF	2272	1025	70.52
1392	940	IRVGS	1908	765	70.52
1393	1209	FSCRK	6723	2887	70.51
1394	1805	WLWSP	1201	493	70.50
1395	1697	PFFRD	3482	1079	70.47
1396	1083	CNTRY	2814	900	70.45
1397	1283	ADMDS	6511	762	70.45
1398	2411	BLMND	3262	124	70.42
1399	2401	WHITE	3531	1854	70.42
1400	1194	EZACH	0002	1393	70.40
1401	1673	CLBWS	8111	1494	70.40
1402	2122	DALRK	1354	1415	70.36
1403	2363	DLEON	0111	602	70.26
1404	170	TYSTH	1209	816	70.14
1405	2172	CDCSW	0005	1768	70.08
1406	1962	CLBRN	1201	1743	70.08
1407	900	NHNSW	0008	564	70.07
1408	1405	GRSMN	4028	659	70.03
1409	398	CNTRY	2831	1165	69.89
1410	363	OKLND	0001	791	69.89
1411	690	IRVGS	1906	789	69.73
1412	580	BLMED	1622	982	69.63
1413	2523	TMPSE	1503	600	69.61
1414	2576	RECCR	0002	103	69.60
1415	893	HURST	1861	1835	69.51
1416	534	IRVBL	2504	1561	69.50
1417	642	KNAPP	4021	40	69.49
1418	1491	BLMND	3241	222	69.48
1419	906	WFNTH	0232	622	69.35
1420	1429	PCOIT	1003	1490	69.34
1421	111	BANGS	1201	1112	69.32
1422	1561	LUFKN	1201	1315	69.30
1423	1952	RRNES	2405	3219	69.29
1424	1104	ALPHA	0014	629	69.29
1425	191	DCVSO	1105	2235	69.12
1426	184	CLYVL	9313	1846	68.98
1427	1335	VGCRK	8041	1034	68.74
1428	1804	FHLSW	1361	942	68.68
1429	1106	JUDCT	0006	1165	68.67
1430	1241	GSTHW	1631	2178	68.62
1431	1452	FSCRK	6721	3540	68.59
1432	1735	LFSTH	1407	1637	68.52
1433	1530	ARPMN	4147	592	68.34
1434	N/A	BNDRA	0009	717	68.31
1435	2592	WDGWD	1561	1475	68.22
1436	1403	BEAST	4084	850	68.11
1437	2553	WXNTH	2308	577	68.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1438	1424	INAIR	1423	199	68.09
1439	1716	COLDG	4047	413	67.95
1440	585	WHTRK	0002	1404	67.90
1441	853	CANTN	1302	1307	67.89
1442	378	PPARK	1805	957	67.89
1443	880	IRVBL	2503	1364	67.81
1444	2075	TMSTH	1401	1830	67.73
1445	1081	WMMMR	2702	2144	67.73
1446	154	MRKLY	0811	122	67.72
1447	236	SPRDL	4841	915	67.71
1448	50	BRLSN	2023	1809	67.61
1449	826	MNFLD	2682	2183	67.46
1450	691	CDMIL	1201	601	67.45
1451	1232	SNYDR	1822	1617	67.43
1452	405	IRVNG	1401	1362	67.38
1453	262	SCHRD	0003	375	67.34
1454	520	SLAKE	8321	2768	67.17
1455	1906	GVODS	3031	1385	67.12
1456	2205	BRHLW	7651	1087	67.02
1457	817	PTENN	2355	81	67.01
1458	409	WHTRK	0001	2096	67.00
1459	473	HSKAV	0006	488	66.84
1460	1097	GVODS	3021	572	66.72
1461	1440	HURST	1872	2121	66.72
1462	2193	COPEL	3051	1531	66.71
1463	2180	PFLGV	2004	2956	66.54
1464	2375	PRCTR	1601	209	66.52
1465	1922	WRBND	2312	1458	66.42
1466	2503	MESQT	1301	1419	66.14
1467	1527	HLSBR	1201	1648	66.07
1468	784	COHMA	1111	700	66.06
1469	1528	ODNTH	2034	2662	65.96
1470	260	CANTN	1301	4052	65.94
1471	2047	MNSTR	1201	568	65.90
1472	722	FARON	4041	993	65.86
1473	314	BRNAV	0774	1381	65.81
1474	1796	IOWPK	0831	1065	65.78
1475	2181	ARMST	0004	708	65.72
1476	996	WHTRK	0004	1134	65.64
1477	512	WALST	0009	695	65.62
1478	771	THRDN	1901	1602	65.58
1479	1899	ENNIS	1906	1987	65.51
1480	1273	ELKHR	1201	946	65.45
1481	2680	LOMAL	0006	1126	65.41
1482	1380	EULSO	9111	1865	65.29
1483	1214	BLTLN	0001	655	65.27
1484	1890	TMPNW	1105	1131	65.25
1485	2654	KNEDL	6342	1747	65.17

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1486	861	CLYVL	9322	2129	65.11
1487	801	GRDPR	0831	1192	65.02
1488	1199	GODRD	8171	826	64.89
1489	856	CPLSO	4311	64	64.89
1490	159	RCHHL	0311	972	64.74
1491	1709	TMPTV	2405	481	64.73
1492	2638	NCSTH	1504	65	64.61
1493	1298	DNCNV	1903	1178	64.54
1494	684	FRMBR	1801	1241	64.53
1495	2079	FRNKF	0002	870	64.51
1496	1625	MDDTN	4311	192	64.51
1497	1449	PRKRW	3362	1058	64.27
1498	2656	FRMBR	1802	1105	64.26
1499	194	NCNTH	1806	859	64.22
1500	1508	BEAST	4090	924	64.19
1501	1427	GAVSW	0004	787	64.10
1502	656	WTAUG	4633	983	64.08
1503	629	WMRLD	0008	1577	63.99
1504	1479	DAVST	0003	1418	63.89
1505	373	MABNK	2403	1701	63.78
1506	1564	THRNE	0004	790	63.63
1507	1578	MKNSW	1601	1541	63.53
1508	2182	HRSMD	1957	2336	63.31
1509	2347	PNTGO	7111	713	63.31
1510	434	SMPST	0006	1000	63.30
1511	1883	IRVVV	2801	2213	63.23
1512	1947	RGFTW	6822	23	63.22
1513	1933	GRPVN	8211	355	63.20
1514	2441	CKRHL	0007	222	63.16
1515	2346	CRLTR	2005	670	63.09
1516	1738	JUDCT	0007	633	62.91
1517	275	STNVL	1201	2153	62.86
1518	2278	RDOAK	1303	705	62.83
1519	1062	BRNSO	1801	1441	62.80
1520	1063	RWALS	1853	2671	62.74
1521	1981	TRLWD	7721	1375	62.62
1522	2143	DESPR	1403	1757	62.51
1523	1567	BLTLN	0002	883	62.49
1524	1144	MSHLN	0008	656	62.46
1525	711	IRVND	1201	980	62.41
1526	2763	ARMST	0007	97	62.36
1527	2308	CHROW	0006	63	62.27
1528	2021	GNSVE	1602	1547	62.26
1529	899	PCUST	2010	2262	62.13
1530	1258	MRTSP	1501	1125	62.06
1531	N/A	BAYLC	1201	101	62.03
1532	399	TMPLE	1205	2426	61.98
1533	1116	BONHM	1206	2050	61.96

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1534	2351	OKCLS	0003	1403	61.94
1535	460	LKMNT	0002	1003	61.86
1536	1693	FHLSW	1372	1297	61.81
1537	1917	TMSTH	1402	1612	61.56
1538	2061	PCUST	2002	477	61.55
1539	1014	WDGWD	1513	844	61.42
1540	1350	WTAUG	4652	785	61.42
1541	2486	VLYRN	2955	4318	61.33
1542	157	KIMBL	5012	1625	61.25
1543	731	BRIRV	6912	796	61.20
1544	698	KNEDL	6332	2651	61.04
1545	1325	FSCRK	6711	3637	61.01
1546	868	CLBRN	1206	1420	61.00
1547	1376	RGLRW	0004	79	60.97
1548	1078	BLKST	1742	1648	60.95
1549	1658	WEBBS	8612	3015	60.92
1550	2000	CMPWI	0004	1570	60.90
1551	1498	PWEST	1308	615	60.89
1552	544	DALWT	2931	1488	60.86
1553	1300	RDLML	2571	362	60.85
1554	1029	CNTRY	2811	2497	60.84
1555	1675	GLNHV	3931	1339	60.82
1556	1050	WHITE	3522	1659	60.64
1557	1664	HLTOM	2431	1270	60.61
1558	757	MSHLN	0001	1040	60.60
1559	671	DENAV	0642	907	60.48
1560	2644	KLNCC	1701	2077	60.47
1561	420	PNTGO	7112	738	60.41
1562	846	BSPRW	2542	713	60.35
1563	1538	PLKST	0006	781	60.33
1564	1851	KLNTF	1801	1044	60.27
1565	2609	KERNS	2402	395	60.22
1566	2343	MESTE	1211	2494	60.18
1567	1301	COLNY	2405	2296	60.16
1568	200	TYEST	1501	1637	60.15
1569	1409	DALLW	0003	588	60.14
1570	332	RSKMN	3078	131	59.89
1571	298	CNTRY	2833	2336	59.86
1572	1486	COLNY	2406	745	59.85
1573	1724	TATSP	4311	1832	59.80
1574	501	DALWT	2982	982	59.79
1575	798	OKLND	0003	890	59.74
1576	1522	SMFLD	2372	611	59.53
1577	2468	MSTLT	1063	936	59.53
1578	1944	VLYRN	2952	2180	59.51
1579	296	GNSVL	1205	880	59.45
1580	1966	WELRD	0003	511	59.06
1581	180	OVRTN	4019	674	59.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1582	932	DAVIS	3772	1717	58.91
1583	252	LTLRV	1701	1034	58.83
1584	1121	CRTLD	4724	2682	58.50
1585	2421	BNDRA	0005	795	58.50
1586	1361	MEXIA	4023	605	58.49
1587	1339	BRYAN	0004	1592	58.48
1588	2228	RCHHL	0353	1465	58.48
1589	2199	MDLNE	0141	2710	58.45
1590	N/A	IRVHF	2302	1355	58.23
1591	2358	MAPLE	0005	1631	58.20
1592	1120	CRNTH	2402	1544	58.12
1593	1678	HUTTO	2711	2146	58.11
1594	1032	IRVVV	2853	3000	57.95
1595	556	STNVL	1206	2177	57.85
1596	904	RSNHT	1131	2661	57.62
1597	2157	SWDTN	1631	1518	57.38
1598	1303	HUTCH	1501	842	57.31
1599	713	BLMED	1620	1882	57.28
1600	2265	FLMSO	3711	2343	57.09
1601	2818	RDRSE	2605	645	57.06
1602	2649	GAVSW	0008	118	57.00
1603	1374	WTAUG	4643	982	56.99
1604	1550	MCDMT	2532	1970	56.86
1605	2012	RDLML	2561	819	56.82
1606	2058	PFLGV	2003	2757	56.81
1607	1750	WTAUG	4621	435	56.71
1608	1396	ORANS	1501	762	56.65
1609	455	SHSTH	1303	656	56.54
1610	1108	LUFKN	1202	1105	56.53
1611	532	IRVGS	1903	821	56.53
1612	2017	PLKST	0001	755	56.42
1613	206	PMBRK	1811	21	56.40
1614	1134	DESHR	1203	1310	56.37
1615	2397	PCOIT	1025	2883	56.26
1616	331	BARRY	1802	271	56.22
1617	2096	LOMAL	0003	1077	56.21
1618	2748	WMRNR	0003	582	56.21
1619	528	EGFRD	0001	1700	55.94
1620	1595	HLTOM	2452	1781	55.91
1621	1964	DCVSO	1102	666	55.83
1622	1284	PRSTN	0001	834	55.76
1623	2232	TYRSW	1701	2200	55.75
1624	1766	BNDRA	0001	1209	55.56
1625	1590	WTAUG	4612	1207	55.52
1626	513	IRVNG	1402	1083	55.46
1627	908	KLNTF	1805	1242	55.39
1628	796	BRCRK	6543	1474	55.37
1629	212	DCATR	1203	806	55.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1630	461	FARON	4062	1133	55.24
1631	2267	RCLNS	1406	518	55.22
1632	1842	MEXIA	4011	934	55.21
1633	2123	CLBNR	1401	19	55.06
1634	1854	COLNY	2404	1843	54.95
1635	124	PRNTH	1405	929	54.92
1636	2046	MDLNW	1582	1435	54.91
1637	335	CNSES	3054	1830	54.88
1638	290	GNSVL	1203	1672	54.79
1639	371	ENSSO	2002	994	54.72
1640	1343	BLMND	3231	1190	54.72
1641	441	CLBNR	1402	2398	54.71
1642	N/A	IRLBJ	3231	2781	54.69
1643	178	NCDCH	1201	799	54.68
1644	715	ODNTH	2053	2361	54.67
1645	799	BOWEN	3122	1261	54.62
1646	2547	HLTOM	2411	1376	54.58
1647	234	TYBLR	2801	1236	54.58
1648	1876	ALVRD	1501	1127	54.47
1649	1758	EDDYS	0425	207	54.33
1650	1338	KNEDL	6322	2516	54.26
1651	164	WHITE	3521	1033	54.18
1652	2003	MESTE	1209	215	54.10
1653	1354	CMTSW	0925	1332	54.05
1654	1003	NLNVL	2003	606	54.02
1655	1867	LOMAL	0012	667	53.95
1656	1495	LKMNT	0001	195	53.86
1657	1924	BOWEN	3151	1718	53.79
1658	1985	ANDNR	2222	79	53.70
1659	2717	PTENN	2358	1156	53.68
1660	1152	CNEXP	0008	426	53.66
1661	1107	GRDPR	0852	1381	53.63
1662	1511	ENNIS	1901	347	53.53
1663	1568	MDLNW	1532	1957	53.46
1664	2002	DUVAL	0414	606	53.45
1665	2147	ODNTH	2033	634	53.40
1666	540	IRVBL	2505	485	53.37
1667	1447	PLKST	0002	1478	53.25
1668	1210	DESPR	1407	883	53.24
1669	873	PREST	1602	1288	53.22
1670	480	GRPVN	8212	3992	53.19
1671	1401	LIGSW	1604	609	53.17
1672	565	DAVIS	3711	676	53.13
1673	1031	TYSTH	1208	299	53.07
1674	2655	WALST	0004	49	53.06
1675	1087	REAST	1505	604	53.04
1676	2514	GRLRD	0004	1534	53.04
1677	2518	BOWEN	3142	1040	53.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
1678	2059	ANARN	1911	16	53.00
1679	1809	KLNCC	1703	4363	52.82
1680	2693	GNSVN	1403	271	52.75
1681	1126	FINKS	1802	698	52.74
1682	1795	DAVIS	3713	867	52.73
1683	864	MESQT	1308	2436	52.69
1684	1042	FSTVW	0004	1971	52.69
1685	1908	MURPH	2756	2805	52.57
1686	1193	PCOIT	1001	1222	52.38
1687	1937	RNDRK	1504	960	52.29
1688	636	CNTRD	0002	1429	52.22
1689	874	LTVSB	5451	1208	52.06
1690	777	AZLES	2122	2167	52.02
1691	303	RSNHT	1181	1631	51.89
1692	2778	DENDR	0009	53	51.89
1693	2384	WALST	0013	306	51.83
1694	2331	JKREA	1201	28	51.83
1695	360	KYSTN	1011	57	51.74
1696	2300	WMRLD	0009	25	51.72
1697	1302	WEAST	0615	354	51.63
1698	130	WGROB	8412	1742	51.51
1699	1655	MNFLD	2621	2202	51.45
1700	1034	WDGWD	1572	1469	51.44
1701	1319	FHLSW	1342	1831	51.26
1702	72	CAMRN	1203	1242	51.16
1703	1703	BOWEN	3161	1446	51.16
1704	369	BRNWD	1204	1681	51.03
1705	1601	BLMED	1621	2021	50.83
1706	2149	EULES	8712	1035	50.82
1707	1184	ALPHA	0009	59	50.69
1708	1618	SCYEN	0002	1857	50.63
1709	675	PARIS	1204	1117	50.48
1710	1911	BLKST	1762	1023	50.31
1711	29	FARON	4011	631	50.28
1712	1421	MSLSW	0004	398	50.19
1713	809	RBNSN	2503	923	50.19
1714	2041	PCUST	2009	2128	50.17
1715	2136	HKHTS	1607	883	50.13
1716	1649	WHITE	3511	1304	50.11
1717	2135	CKRHL	0005	1207	50.09
1718	1991	PFLGV	2001	3798	50.05
1719	2497	RCHHL	0344	1080	49.89
1720	2212	CRSWS	1402	922	49.76
1721	2246	PALRD	2201	782	49.75
1722	575	MTLDA	0002	1909	49.74
1723	2240	WSANG	2801	1315	49.69
1724	N/A	RKCRK	6112	1491	49.66
1725	1612	PRKWY	1542	463	49.40