




Control Number: 39035



Item Number: 7

Addendum StartPage: 0

RECEIVED
11 FEB 14 PM 2:47
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2010 Reporting Year

AEP Texas Central Company

Project 39035

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced	1.19	0.12	0.07	0.06	0.10	0.14	0.13	0.13	0.10	0.10	0.07	0.11	0.07
2010													
Scheduled	0.03	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
2010													
Outside Causes	0.12	0.02	0.02	0.00	0.01	0.00	0.01	0.00	0.00	0.00	0.01	0.03	0.01
2010													
Major Events	0.30	0.02			0.01	0.01	0.13	0.01		0.10			
2010													

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2010	116.8	11.0	5.9	5.1	10.6	15.7	14.4	11.5	8.2	11.8	6.2	9.9	6.8
Scheduled 2010	2.8	0.1	0.1	0.1	0.2	0.5	0.1	0.3	0.2	0.5	0.3	0.3	0.1
Outside Causes 2010	6.6	0.9	0.6	0.2	0.4	0.1	0.5	0.1	0.2	0.1	0.6	2.1	0.8
Major Events 2010	140.7	6.5			3.2	2.9	62.7	16.9		48.5			

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

724

Add or Delete Rows as Necessary

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
1	5	RAYMONDVILLE #2	94SB3250	31	6.774	
2	9	GREENLAKE	94CN2760	559	6.555	
3	344	NORTH EDINBURG	94SB4240	2,075	5.991	
4	75	FALFURRIAS	94LA2830	1,625	5.897	
5	51	SAN BENITO	94SB4135	1,152	5.318	
6	213	MOORE FIELD	94SB3120	125	5.312	
7	139	GREGORY	94CS8560	869	5.236	
8	702	ASPHALT MINES	94LA500	35	4.714	
9	291	VICTORIA POWER PLANT	94CN8070	603	4.658	
10	238	CASA BLANCA	94CS5115	290	4.555	
11	15	AMISTAD DAM	94LA5450	1,085	4.505	
12	1	PALMVIEW	94SB9685	2,793	4.483	
13	292	CASA BLANCA	94CS1300	960	4.481	
14	4	CARRIZO SPRINGS	94LA370	255	4.384	
15	595	OLMITO	94SB905	1,432	4.325	
16	16	ROBSTOWN	94CS1650	341	4.299	
17	321	FREER	94LA2900	156	4.288	
18	7	BROWNSVILLE	94SB3050	1,966	4.260	
19	216	PUEBLO	94LA95	1,954	4.246	
20	358	PORT LAVACA	94CN2490	1,076	4.225	
21	14	COLUMBUS	94CN6180	1,168	4.211	
22	514	HIGHWAY 9	94CS6780	782	4.097	
23	158	WESLACO UNIT	94SB8610	2,368	4.013	
24	184	MARKHAM	94CN5550	95	4.000	
25	634	POLK AVENUE	94SB4170	930	3.982	
26	185	BLESSING	94CN8790	729	3.856	
27	135	PLEASANTON	94LA9475	1,302	3.845	
28	171	BRUNI	94LA5160	147	3.673	
29	271	CRESTONIO	94LA260	1,745	3.664	
30	288	EAGLE LAKE	94CN320	640	3.659	
31	249	BANQUETTE	94CS9000	420	3.643	
32	257	PALACIOS	94CN8550	36	3.639	
33	174	ZAPATA	94LA8300	1,778	3.629	
34	263	SINTON	94CS6860	1,582	3.611	
35	511	ENCINAL	94LA2160	799	3.528	
36	394	RIO GRANDE CITY	94SB3740	3,142	3.516	
37	324	CLARKWOOD	94CS7230	560	3.477	
38	226	PORTLAND	94CS9270	1,879	3.459	
39	221	SOUTH EAST EDINBURG	94SB4015	415	3.419	
40	329	MAGRUDER	94CN6700	1,421	3.413	
41	548	WOODSBORO	94CS8330	1,069	3.411	
42	688	EDNA	94CN5775	487	3.407	
43	84	HEARN ROAD	94CS870	1,105	3.391	
44	409	SABINAL	94LA485	479	3.386	
45	277	YORKTOWN	94CN8380	780	3.368	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
46	666	MILO	94LA3065	184	3.364	
47	560	SINTON	94CS360	292	3.325	
48	159	WEST OSO	94CS9090	1,722	3.324	
49	355	ZAPATA	94LA8290	2,240	3.319	
50	100	ASHERTON	94LA2670	167	3.281	
51	535	HALL ACRES ROAD	94SB3460	3,463	3.270	
52	116	BLESSING	94CN1030	234	3.248	
53	382	PLEASANTON	94LA2080	1,509	3.243	
54	342	SKIDMORE	94CS380	305	3.213	
55	176	GRETA	94CN7890	298	3.178	
56	365	WEST OSO	94CS9085	733	3.166	
57	597	KENEDY S.S.	94CN6750	759	3.146	
58	572	STADIUM	94LA7490	1,243	3.128	was 94CS7490
59	423	PETTUS	94CN1020	372	3.118	
60	12	LOS FRESNOS	94SB4315	953	3.113	
61	453	NORTH EDINBURG	94SB560	1,592	3.101	
62	266	GOLIAD	94CN8220	1,018	3.100	
63	13	DARST	94CN790	73	3.096	
64	41	RANDADO	94LA8360	156	2.942	
65	31	CRESTONIO	94LA270	611	2.912	
66	316	HIDALGO	94SB4845	1,042	2.869	
67	11	NAVAL BASE	94CS6330	383	2.838	
68	146	RACHAL	94LA8145	365	2.808	
69	8	ALAZAN	94CS620	164	2.805	
70	425	BIG WELLS	94LA1570	409	2.804	
71	375	NORTH ALAMO	94SB4370	2,410	2.801	
72	21	MUSTANG ISLAND	94CS9470	649	2.769	
73	93	RIO RICO	94SB8330	370	2.765	
74	253	NORTH MCALLEN	94SB5060	2,178	2.755	
75	517	ARCADIA	94CS1360	1,508	2.718	
76	23	CASA BLANCA	94CS55	812	2.716	
77	154	PALMVIEW	94SB3930	1,062	2.708	
78	421	BAY CITY	94CN2700	1,058	2.697	
79	245	WEST HARLINGEN	94SB3700	1,706	2.695	
80	73	KENEDY	94CN6270	477	2.690	
81	485	GREGORY	94CS5900	108	2.676	
82	112	MOORE FIELD	94SB3960	1,705	2.665	
83	79	GREENLAKE	94CN2740	26	2.654	
84	17	TATTON	94CN8490	124	2.645	
85	202	CARRIZO SPRINGS	94LA860	1,093	2.639	
86	256	THREE RIVERS	94CN2010	888	2.630	
87	43	CLARKWOOD	94CS5525	888	2.625	
88	333	ARCADIA	94CS5020	1,517	2.621	
89	540	MAGRUDER	94CN245	1,091	2.607	
90	143	CITRUS CITY	94SB9775	1,963	2.594	
91	45	GOVERNMENT WELLS	94LA6800	225	2.578	
92	636	GATEWAY	94LA350	1,598	2.568	
93	39	BRUNI	94LA5440	120	2.550	
94	164	MORRIS STREET	94CS7465	627	2.493	
95	445	NORDHEIM	94CN470	235	2.489	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
96	654	VICTORIA POWER PLANT	94CN1390	1,134	2.473	
97	147	POINT COMFORT	94CN2460	347	2.450	
98	580	ARCADIA	94CS1440	1,589	2.428	
99	58	NIXON	94CN810	496	2.423	
100	373	LULING - LCRA	94CN20	274	2.416	
101	186	DEL RIO CITY	94LA1930	918	2.401	
102	481	MATTHEWS	94CN1740	158	2.386	
103	40	GOVERNMENT WELLS	94LA7240	194	2.381	
104	655	SABINAL	94LA200	410	2.378	
105	505	BEEVILLE	94CN8090	1,220	2.375	
106	506	KINGSVILLE	94CS1670	423	2.371	
107	130	HIGHWAY 9	94CS6730	512	2.367	
108	390	MATHIS	94CS340	1,472	2.365	
109	230	THREE RIVERS	94CN8430	165	2.364	
110	234	CABANISS	94CS240	1,444	2.356	
111	92	DARST	94CN800	164	2.354	
112	410	CLARKWOOD	94CS7220	362	2.354	
113	371	CLARKWOOD	94CS7610	187	2.348	
114	57	SOUTHSIDE	94CS5335	1,140	2.332	
115	468	PALACIOS	94CN6840	1,509	2.324	
116	466	VICTORIA POWER PLANT	94CN7600	158	2.316	
117	6	SAN DIEGO	94LA1980	600	2.275	was 94CS1980
118	178	NORTH VICTORIA	94CN7440	1,585	2.274	
119	360	LAREDO PLANT	94LA8505	775	2.271	
120	328	GEORGE WEST	94CN730	847	2.269	
121	243	WEST MCALLEN	94SB4505	1,742	2.269	
122	331	WEST MCALLEN	94SB4965	702	2.264	
123	70	NORTH ALAMO	94SB3610	3,457	2.258	
124	326	KINGSVILLE	94CS1140	976	2.251	
125	356	AIRLINE	94CS8260	1,488	2.237	
126	60	MCKENZIE ROAD	94CS140	263	2.228	
127	220	UVALDE	94LA550	656	2.221	
128	571	YORKTOWN	94CN8420	998	2.220	
129	54	RAYMONDVILLE #2	94SB3170	681	2.214	
130	442	SOUTH EAST EDINBURG	94SB4570	1,333	2.208	
131	63	WESLACO UNIT	94SB7455	1,217	2.184	
132	298	BUENA VISTA	94LA9385	2,056	2.183	
133	65	JOURDANTON	94LA250	743	2.170	
134	168	ARCADIA	94CS8570	1,430	2.169	
135	138	GOVERNMENT WELLS	94LA7250	576	2.158	
136	190	NORTH PADRE ISLAND	94CS720	1,074	2.143	
137	389	ALICE	94LA1770	1,548	2.143	was 94CS1770
138	455	RANDADO	94LA8350	124	2.137	
139	144	SUNCHASE	94SB1150	1,250	2.134	
140	698	SANTO NINO	94LA515	1,900	2.131	
141	108	VICTORIA POWER PLANT	94CN8170	754	2.130	
142	118	GOODWIN	94SB4380	1,402	2.122	
143	516	NORTH MCALLEN	94SB9660	1,988	2.120	
144	294	RODD FIELD	94CS205	1,510	2.115	
145	78	PEARSALL	94LA5580	1,618	2.112	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
146	579	HIDALGO	94SB3680	321	2.112	
147	348	BONNIEVIEW	94CS8020	505	2.111	
148	103	VILLA CAVAZOS	94SB1980	1,453	2.105	
149	528	MCKENZIE ROAD	94CS150	21	2.095	
150	492	ELSA	94SB690	2,131	2.076	
151	192	RIO GRANDE CITY	94SB3210	1,683	2.068	
152	148	WEIL TRACT (138/12KV)	94CS5405	149	2.047	
153	199	SANTO NINO	94LA695	1,486	2.038	
154	352	PETTUS	94CN8210	350	2.026	
155	625	PLEASANTON	94LA120	1,201	2.020	
156	412	ODEM	94CS5575	57	2.018	
157	141	SAN BENITO	94SB4030	2,382	2.005	
158	497	NIXON	94CN2620	547	1.974	
159	433	BEEVILLE	94CN490	929	1.946	
160	476	PREMONT	94LA6610	814	1.941	
161	289	LULING - LCRA	94CN10	326	1.917	
162	122	HARLINGEN	94SB360	2,441	1.915	
163	205	RAYMONDVILLE #1	94SB630	775	1.902	
164	115	PORT LAVACA	94CN8310	312	1.897	
165	430	RIO GRANDE CITY	94SB3220	1,776	1.896	
166	83	TAFT	94CS1260	181	1.895	
167	32	FALFURRIAS	94LA5210	1,105	1.891	
168	77	MATHIS	94CS2870	852	1.890	
169	301	STADIUM	94LA7810	1,636	1.883	was 94CS7810
170	95	CONTINENTAL	94SB3650	24	1.875	
171	34	SOUTH PADRE ISLAND	94SB6440	2,399	1.874	
172	686	GATEWAY	94LA5055	1,920	1.855	
173	314	BEEVILLE	94CN300	1,584	1.853	
174	27	STAFFORD HILL	94CN1550	208	1.846	
175	33	ELSA	94SB710	1,641	1.820	
176	198	EDNA	94CN5765	1,582	1.815	
177	250	WESLACO UNIT	94SB7630	3,555	1.814	
178	393	BUENA VISTA	94LA8965	923	1.804	
179	293	SAN DIEGO	94LA2930	601	1.800	was 94CS2930
180	153	COMSTOCK	94LA290	184	1.788	
181	303	PORT ISABEL S.S.	94SB3820	208	1.760	
182	566	NORTH MERCEDES	94SB3840	637	1.758	
183	295	SEAWALL	94CS9420	797	1.743	
184	332	AIRLINE	94CS7280	617	1.726	
185	501	CITRUS CITY	94SB7985	1,523	1.720	
186	296	KINGSVILLE	94CS1660	1,572	1.719	
187	456	WEST MCALLEN	94SB4535	2,773	1.712	
188	302	SOUTHSIDE	94CS8025	1,029	1.685	
189	552	SAN DIEGO	94LA2880	1,223	1.684	was 94CS2880
190	561	PORT LAVACA	94CN2480	1,518	1.674	
191	649	MORRIS STREET	94CS5655	950	1.665	
192	201	CRYSTAL CITY	94LA190	971	1.636	
193	602	HOLLY	94CS7740	1,995	1.634	
194	626	GARCENO	94SB2135	1,798	1.633	
195	363	PALMHURST	94SB2535	1,123	1.619	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
196	137	CAMPWOOD	94LA2610	927	1.598	
197	94	NORTH PADRE ISLAND	94CS1010	1,783	1.575	
198	47	FALFURRIAS	94LA1070	1,022	1.572	
199	297	RIO RICO	94SB8290	346	1.566	
200	374	PARKER	94CN9010	18	1.556	
201	299	ALICE	94LA2540	1,106	1.551	was 94CS2540
202	449	PHARAOH	94CS5175	976	1.549	
203	18	MCCOLL ROAD	94SB4400	1,105	1.545	
204	272	CRYSTAL CITY	94LA140	1,212	1.535	
205	432	SAN DIEGO	94LA2890	1,038	1.529	was 94CS2890
206	436	UVALDE	94LA6620	2,647	1.526	
207	265	NIXON	94CN5990	557	1.522	
208	111	PALACIOS	94CN6830	803	1.509	
209	451	LOLITA	94CN6330	26	1.500	
210	162	FALFURRIAS	94LA1080	432	1.498	
211	261	SOUTH MCALLEN	94SB3790	1,848	1.495	
212	189	KINGSVILLE	94CS1130	2,042	1.492	
213	652	SEAWALL	94CS9450	287	1.491	
214	106	NUECES BAY PLANT	94CS350	801	1.476	
215	37	SOUTH PADRE ISLAND	94SB5850	1,451	1.476	
216	123	SOUTH EAST EDINBURG	94SB5045	1,781	1.471	
217	494	ARANSAS PASS	94CS9130	321	1.455	
218	64	EAGLE PASS CITY	94LA2770	2,940	1.455	
219	435	PALMHURST	94SB3890	2,296	1.451	
220	255	PORT ARANSAS	94CS6940	1,581	1.442	
221	559	PREMONT	94LA6570	712	1.442	
222	283	SOUTH SANTA ROSA	94SB1235	630	1.441	
223	248	WESMER	94SB1850	1,117	1.437	
224	25	LA PRYOR	94LA580	188	1.436	
225	439	BROOKHOLLOW	94CN7580	417	1.434	
226	28	CABANISS	94CS80	1,066	1.434	
227	62	PORTLAND	94CS9290	1,658	1.430	
228	290	WASHINGTON STREET	94LA2350	2,899	1.415	
229	151	PLACEDO	94CN7970	459	1.412	
230	422	FREER	94LA5200	1,017	1.409	
231	531	EL CAMPO	94CN2860	818	1.406	
232	36	PALMHURST	94SB1300	1,260	1.404	
233	465	HAIN DRIVE	94SB270	864	1.400	
234	102	KLEBERG	94CS1560	1,297	1.395	
235	244	BROWNSVILLE	94SB4280	227	1.392	
236	125	DEVINE	94LA7090	912	1.390	
237	378	PHARAOH	94CS1285	1,741	1.386	
238	69	MALONE	94CN7550	172	1.378	
239	416	POINT COMFORT	94CN6060	50	1.360	
240	629	DEL RIO CITY	94LA440	844	1.360	
241	604	MCCOLL ROAD	94SB4780	2,148	1.360	
242	376	NORTH VICTORIA	94CN2240	784	1.355	
243	532	LEARY LANE	94CN6005	1,784	1.353	
244	542	MORRIS STREET	94CS2515	1,083	1.353	
245	550	RIO BRAVO	94LA5	664	1.348	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
246	578	ANNA STREET	94LA900	2,964	1.347	
247	359	WOOLRIDGE	94CS1120	2,629	1.345	
248	223	PALMVIEW	94SB6790	2,876	1.344	
249	628	ARCADIA	94CS5030	1,546	1.341	
250	400	GOODWIN	94SB4625	338	1.340	
251	385	NORTH EDINBURG	94SB3570	990	1.339	
252	639	ARCADIA	94CS1450	1,863	1.337	
253	335	JOURDANTON	94LA880	288	1.337	
254	55	ALAZAN	94CS2740	30	1.333	
255	621	RAYMONDVILLE #1	94SB800	674	1.332	
256	706	GARWOOD CITY	94CN2570	132	1.326	
257	583	BISHOP	94CS2690	551	1.321	
258	469	GATEWAY	94LA390	947	1.320	
259	285	BEEVILLE	94CN1760	1,780	1.312	
260	588	ANNA STREET	94LA2250	1,553	1.307	
261	155	EAGLE LAKE	94CN310	725	1.305	
262	273	BISHOP	94CS7180	920	1.304	
263	508	LIVE OAK	94CS1090	244	1.303	
264	395	UVALDE	94LA9770	1,286	1.297	
265	<i>new</i>	HOMEPORT	94CS4665	433	1.289	<i>new</i>
266	59	RAYMONDVILLE #1	94SB620	613	1.289	
267	538	LAGUNA	94CS9590	2,088	1.286	
268	523	LAREDO PLANT	94LA8695	987	1.285	
269	61	INGLESIDE CITY	94CS8050	1,311	1.283	
270	3	COFFEE PORT	94SB1095	956	1.281	
271	377	EAST HARRISON	94SB3950	552	1.279	
272	613	NORTH MCALLEN	94SB4995	1,867	1.276	
273	246	MINES ROAD	94LA4275	11	1.273	
274	703	NORTH MCALLEN	94SB9640	1,427	1.272	
275	338	WEST OSO	94CS9095	1,445	1.271	
276	48	LA PRYOR	94LA570	127	1.268	
277	680	WEST MCALLEN	94SB4815	708	1.267	
278	549	MAGRUDER	94CN6680	684	1.263	
279	446	SANTO NINO	94LA70	1,147	1.262	
280	219	ARANSAS PASS	94CS8270	595	1.252	
281	415	RIO BRAVO	94LA300	859	1.251	
282	568	EL CAMPO	94CN5745	868	1.249	
283	233	PREMONT	94LA2730	229	1.245	
284	632	HOLLY	94CS7620	2,327	1.239	
285	300	SOUTH EAST EDINBURG	94SB4550	2,123	1.237	
286	518	PALMVIEW	94SB7595	2,629	1.236	
287	575	COTULLA	94LA90	724	1.235	
288	306	NORTH MCALLEN	94SB5055	2,995	1.228	
289	50	PLEASANTON	94LA9505	1,443	1.227	
290	582	BEEVILLE	94CN8510	852	1.223	
291	651	NORTH VICTORIA	94CN7860	1,431	1.222	
292	624	WEIL TRACT (138/12KV)	94CS1990	1,251	1.213	
293	539	SANTO NINO	94LA80	2,345	1.213	
294	320	NORTH MCALLEN	94SB2750	2,987	1.210	
295	195	MORRIS STREET	94CS8850	473	1.203	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
296	232	NORTH WESLACO	94SB4810	1,350	1.197	
297	370	HOLLY	94CS1480	1,679	1.192	
298	101	RODD FIELD	94CS225	785	1.192	
299	247	WESLACO UNIT	94SB2195	1,090	1.188	
300	493	AIRLINE	94CS8370	302	1.185	
301	443	RIO GRANDE CITY	94SB3230	1,418	1.183	
302	692	POLK AVENUE	94SB4740	1,848	1.181	
303	558	HARLINGEN S.S.	94SB4090	2,257	1.173	
304	49	MUSTANG ISLAND	94CS8510	402	1.172	
305	325	SANTO NINO	94LA75	1,490	1.172	
306	513	WESMER	94SB4050	1,889	1.170	
307	262	WOOLRIDGE	94CS1170	1,265	1.169	
308	315	NUECES BAY PLANT	94CS345	54	1.167	
309	699	SANTO NINO	94LA645	923	1.165	
310	437	BERCLAIR	94CN990	305	1.157	
311	510	NORTH VICTORIA	94CN7430	1,696	1.156	
312	487	COLUMBUS	94CN9060	366	1.153	
313	98	REFUGIO	94CN5120	174	1.149	
314	590	KENEDY S.S.	94CN8340	877	1.149	
315	337	ROMA	94SB3070	860	1.149	
316	397	HEARN ROAD	94CS9665	547	1.146	
317	24	SOUTH MISSION	94SB3980	1,208	1.142	
318	581	HOLLY	94CS1370	1,841	1.137	
319	228	UVALDE	94LA480	1,276	1.136	
320	175	MINES ROAD	94LA3680	874	1.132	
321	208	FREER	94LA1500	180	1.128	
322	694	BRACKETTVILLE	94LA8460	1,158	1.125	
323	496	EAST HARRISON	94SB4310	1,144	1.124	
324	479	SIERRA VISTA	94LA7360	2,481	1.123	
325	68	MAVERICK	94LA9680	700	1.123	
326	392	MALONE	94CN7560	98	1.122	
327	429	ARCADIA	94CS1400	428	1.119	
328	642	JOURDANTON	94LA5685	529	1.115	
329	35	SHARYLAND	94SB2020	2,279	1.114	
330	427	FULTON	94CS9050	1,610	1.113	
331	182	RIO RICO	94SB5050	1,628	1.112	
332	91	EDROY	94CS6990	267	1.109	
333	305	AIRLINE	94CS9030	420	1.107	
334	570	EDROY	94CS6980	192	1.094	
335	367	RODD FIELD	94CS245	2,544	1.093	
336	260	SOUTH MCALLEN	94SB3850	785	1.093	
337	612	SHARYLAND	94SB6745	1,883	1.092	
338	193	PRAIRIE PUMP	94CN1940	62	1.081	
339	483	VILLA CAVAZOS	94SB7615	934	1.081	
340	242	WEAVER ROAD	94CN1910	358	1.075	
341	675	EL CAMPO	94CN7260	524	1.067	
342	633	PORT LAVACA	94CN6850	592	1.063	
343	150	BRUNI	94LA1100	636	1.061	
344	631	LAREDO PLANT	94LA9305	959	1.054	
345	679	MILO	94LA3070	3,187	1.048	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
346	351	DEL MAR	94LA3440	1,386	1.048	
347	474	RAYMONDVILLE #2	94SB4160	346	1.043	
348	565	BAY CITY	94CN6670	1,751	1.037	
349	354	PREMONT	94LA2720	783	1.028	
350	617	LAREDO PLANT	94LA8705	211	1.024	
351	711	HALL ACRES ROAD	94SB3670	867	1.007	
352	546	CHASE FIELD	94CN460	14	1.000	
353	236	ALICE	94LA2530	1,433	1.000	was 94CS2530
354	700	EAGLE PASS CITY	94LA2510	639	0.998	
355	380	UNIVERSITY	94LA920	327	0.997	
356	30	CRYSTAL CITY	94LA330	1,158	0.991	
357	402	ANNA STREET	94LA5780	722	0.988	
358	709	ROCKPORT	94CS5940	42	0.976	
359	713	HALL ACRES ROAD	94SB9595	1,032	0.976	
360	448	SEAWALL	94CS9325	1,370	0.972	
361	44	PHARR	94SB1625	2,008	0.953	
362	648	PARKER	94CN9260	94	0.947	
363	46	GOLIAD	94CN6540	1,105	0.945	
364	556	BAY CITY	94CN5960	1,806	0.941	
365	418	LYTLE	94LA2850	617	0.940	
366	270	EAGLE PASS CITY	94LA2745	915	0.936	
367	681	WEST MCALLEN	94SB4515	801	0.931	
368	361	PEARSALL	94LA7050	1,298	0.927	
369	29	CAUSEWAY	94SB4795	1,193	0.927	
370	417	DEVINE	94LA8100	1,465	0.926	
371	82	CLARKWOOD	94CS9570	1,100	0.913	
372	156	PORT ISABEL S.S.	94SB3760	2,096	0.913	
373	440	DEL RIO CITY	94LA420	2,295	0.912	
374	653	LA GRULLA	94SB5005	968	0.906	
375	350	TATTON	94CS950	526	0.905	
376	478	SOUTHSIDE	94CS7955	1,041	0.873	
377	586	COFFEE PORT	94SB1090	1,154	0.873	
378	623	HALL ACRES ROAD	94SB8870	3,670	0.857	
379	19	CONTINENTAL	94SB4880	62	0.855	
380	408	HAIN DRIVE	94SB9690	835	0.843	
381	500	PUEBLO	94LA130	1,245	0.841	
382	403	MILO	94LA5020	1,287	0.832	
383	407	LAREDO HEIGHTS	94LA6820	2,091	0.831	
384	413	PEARSALL	94LA9905	746	0.831	
385	525	REFUGIO	94CN1040	720	0.829	
386	217	HALL ACRES ROAD	94SB5585	697	0.828	
387	664	MORRIS STREET	94CS7625	564	0.809	
388	346	SINTON	94CS180	902	0.804	
389	534	LEARY LANE	94CN7530	1,882	0.803	
390	489	HIGHWAY 9	94CS6760	598	0.803	
391	462	SINTON	94CS1750	500	0.798	
392	72	NORTH MERCEDES	94SB4860	1,387	0.786	
393	463	PALMVIEW	94SB9680	1,015	0.783	
394	457	ELSA	94SB3500	1,108	0.773	
395	658	HAIN DRIVE	94SB3490	1,029	0.769	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
396	420	SOUTH MISSION	94SB3620	1,855	0.765	
397	464	LIVE OAK	94CS1080	781	0.763	
398	188	WESMER	94SB6900	1,537	0.763	
399	619	ARCADIA	94CS6930	1,498	0.762	
400	684	NORTH VICTORIA	94CN6390	1,311	0.761	
401	142	ROCKPORT	94CS5930	1,076	0.755	
402	357	SOUTH SANTA ROSA	94SB1225	818	0.754	
403	401	LOS FRESNOS	94SB2160	1,111	0.753	
404	251	WEIL TRACT (138/12KV)	94CS2520	533	0.743	
405	239	NORTH PADRE ISLAND	94CS7900	1,836	0.740	
406	340	CRESTONIO	94LA6660	728	0.739	
407	589	EAST HARRISON	94SB3080	364	0.734	
408	22	KLEBERG	94CS6410	392	0.732	
409	585	CHARLOTTE	94LA2790	97	0.722	
410	120	FULTON	94CS2020	1,766	0.721	
411	470	LIVE OAK	94CS1070	2,740	0.718	
412	587	HARLINGEN	94SB370	1,177	0.717	
413	157	PORT ISABEL S.S.	94SB4070	292	0.716	
414	541	TAFT	94CS1180	1,044	0.712	
415	81	BANDERA ELECTRIC (LEAKEY)	94LAL30	267	0.708	
416	207	HIGHWAY 9	94CS6720	1,302	0.704	
417	504	ODEM	94CS375	991	0.702	
418	486	FULTON	94CS6070	2,999	0.701	
419	369	SOUTHSIDE	94CS8055	854	0.701	
420	222	PALMHURST	94SB2525	1,879	0.699	
421	280	HIGHWAY 9	94CS6770	1,158	0.697	
422	128	O CONNER	94CN390	213	0.690	
423	89	LOS FRESNOS	94SB5335	1,852	0.676	
424	281	ELSA	94SB700	1,354	0.675	
425	610	BAY CITY	94CN2050	512	0.672	
426	119	SOUTHSIDE	94CS8045	1,017	0.670	
427	129	PHARAOH	94CS5185	1,906	0.669	
428	309	NORTH EDINBURG	94SB3810	827	0.669	
429	313	SOUTH SANTA ROSA	94SB7485	1,031	0.669	
430	414	MARKHAM	94CN6440	424	0.660	
431	66	PORTLAND	94CS9370	1,418	0.655	
432	499	INGLESIDE CITY	94CS6040	249	0.651	
433	671	PHARR	94SB1620	2,662	0.651	
434	310	MORRIS STREET	94CS8820	1,231	0.648	
435	495	DEL RIO CITY	94LA430	2,462	0.647	
436	507	MAGRUDER	94CN7690	570	0.644	
437	279	PORT ARANSAS	94CS990	1,335	0.634	
438	278	BRUNI	94LA1120	142	0.634	
439	334	WEST MCALLEN	94SB4555	1,476	0.628	
440	90	CITRUS CITY	94SB3470	3,020	0.624	
441	145	FULTON	94CS440	1,974	0.622	
442	399	SAN YGNACIO	94LA16060	494	0.619	
443	121	MAGRUDER	94CN7870	1,269	0.615	
444	411	LA GRULLA	94SB4120	270	0.611	
445	169	GREENLAKE	94CN2750	1,099	0.608	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
446	215	FOSTER FIELD	94CN2550	332	0.596	
447	107	CARRIZO SPRINGS	94LA910	1,882	0.589	
448	282	UVALDE	94LA540	1,198	0.588	
449	330	ELSA	94SB3520	398	0.580	
450	86	EL CAMPO	94CN2800	1,291	0.579	
451	109	LAGUNA	94CS9065	1,925	0.574	
452	635	ROCKPORT	94CS5950	531	0.573	
453	134	REFUGIO	94CN1210	208	0.567	
454	657	SHARYLAND	94SB5105	1,518	0.567	
455	<i>new</i>	HARLINGEN S.S.	94SB5350	728	0.552	<i>new</i>
456	600	HAMILTON ROAD	94LA9655	1,191	0.551	
457	526	SOUTHSIDE	94CS8035	1,079	0.547	
458	386	WADSWORTH	94CN8630	624	0.545	
459	677	THREE RIVERS	94CN5100	35	0.543	
460	620	LA PRYOR	94LA2440	643	0.543	
461	522	BROOKHOLLOW	94CN8950	852	0.542	
462	488	WESLACO UNIT	94SB5970	2,889	0.541	
463	396	HOLLY	94CS5820	926	0.537	
464	533	GEORGE WEST	94CN1320	641	0.532	
465	515	MORRIS STREET	94CS8715	1,568	0.529	
466	167	ARMSTRONG	94CS6050	67	0.522	
467	447	NORTH VICTORIA	94CN7770	792	0.521	
468	131	KLEBERG	94CS280	1,074	0.521	
469	530	NORTH ALAMO	94SB3580	1,860	0.518	
470	438	RANGERVILLE	94SB4060	868	0.510	
471	268	STADIUM	94LA6950	534	0.506	<i>was 94CS6950</i>
472	611	LEARY LANE	94CN1890	1,565	0.504	
473	183	UVALDE	94LA5060	1,297	0.504	
474	482	WESLACO UNIT	94SB9805	1,811	0.502	
475	503	PLACEDO	94CN7980	396	0.497	
476	622	EAST HARRISON	94SB4620	766	0.495	
477	697	ARANSAS PASS	94CS660	723	0.494	
478	105	KENEDY S.S.	94CN8320	653	0.492	
479	227	MCKENZIE ROAD	94CS330	2,234	0.485	
480	237	CAUSEWAY	94SB4765	1,160	0.480	
481	670	ARANSAS PASS	94CS650	726	0.479	
482	307	SOUTHSIDE	94CS7995	1,526	0.476	
483	209	SOUTH SANTA ROSA	94SB1215	1,616	0.476	
484	259	FASHING	94CN8160	38	0.474	
485	319	ARCADIA	94CS1460	1,921	0.473	
486	286	PUEBLO	94LA275	2,657	0.473	
487	312	DILLEY	94LA6400	782	0.473	
488	275	ROMA	94SB3060	1,535	0.455	
489	274	DILLEY	94LA510	520	0.452	
490	287	ARANSAS PASS	94CS8280	546	0.441	
491	80	CONTINENTAL	94SB4080	127	0.441	
492	387	MOORE FIELD	94SB3110	612	0.433	
493	459	WEST HARLINGEN	94SB4870	705	0.433	
494	484	COTULLA	94LA110	1,269	0.429	
495	317	EAST HARRISON	94SB3190	1,412	0.426	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
496	673	POLK AVENUE	94SB4180	1,159	0.424	
497	210	WEST HARLINGEN	94SB3800	1,323	0.420	
498	212	WADSWORTH	94CN7660	1,281	0.417	
499	127	HOLLY	94CS1950	798	0.414	
500	179	THREE RIVERS	94CN2580	57	0.404	
501	461	RANGERVILLE	94SB3410	795	0.404	
502	708	ZAPATA	94LA2710	50	0.400	
503	71	GANADO	94CN5815	580	0.398	
504	160	BEEVILLE	94CN2200	749	0.397	
505	593	MCCOLL ROAD	94SB1655	1,136	0.396	
506	113	SOUTHSIDE	94CS7905	1,821	0.395	
507	641	ALICE	94LA1780	269	0.394	was 94CS1780
508	124	SOUTHSIDE	94CS7925	1,342	0.390	
509	318	ANNA STREET	94LA850	1,552	0.386	
510	569	JOURDANTON	94LA5695	1,261	0.385	
511	322	SOUTH MCALLEN	94SB3935	1,260	0.383	
512	170	REFUGIO	94CN1170	880	0.382	
513	206	HARLINGEN	94SB380	2,298	0.379	
514	687	NORTH MCALLEN	94SB3830	1,288	0.378	
515	567	GOODWIN	94SB7380	2,122	0.376	
516	519	PALMHURST	94SB2530	1,799	0.374	
517	607	ODEM	94CS385	386	0.373	
518	368	AIRLINE	94CS6970	1,206	0.372	
519	133	RIO BRAVO	94LA1130	914	0.372	
520	229	INGLESIDE CITY	94CS8060	1,802	0.371	
521	682	WEST MCALLEN	94SB4595	1,132	0.370	
522	529	HEARN ROAD	94CS2220	1,515	0.368	
523	117	ASHERTON	94LA2660	554	0.366	
524	608	AIRLINE	94CS8890	527	0.364	
525	520	NORTH VICTORIA	94CN1580	1,030	0.363	
526	458	GREGORY	94CS5920	507	0.363	
527	627	BAY CITY	94CN1110	1,277	0.361	
528	441	SOUTH MCALLEN	94SB5065	92	0.359	
529	557	MINES ROAD	94LA3745	1,414	0.356	
530	391	DEL RIO CITY	94LA9790	2,535	0.351	
531	149	EDNA	94CN5785	743	0.349	
532	203	ARANSAS PASS	94CS1250	352	0.349	
533	362	RODD FIELD	94CS2190	2,882	0.349	
534	573	POLK AVENUE	94SB4900	3,292	0.349	
535	563	RUNGE	94CN7320	578	0.344	
536	327	KLEBERG	94CS9395	1,315	0.341	
537	254	MATHIS	94CS1410	448	0.339	
538	490	COLUMBUS	94CN930	881	0.338	
539	606	POLK AVENUE	94SB4610	1,310	0.337	
540	454	WESMER	94SB9705	1,054	0.337	
541	136	RODD FIELD	94CS1730	1,973	0.332	
542	460	PORT ARANSAS	94CS1000	1,335	0.321	
543	547	NAVAL BASE	94CS1380	2,118	0.317	
544	480	TAFT	94CS5230	813	0.317	
545	231	SAN BENITO	94SB3920	2,331	0.317	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
546	424	TATTON	94CS8200	972	0.316	
547	645	BUENA VISTA	94LA9035	1,479	0.315	
548	323	HAIN DRIVE	94SB8065	1,276	0.315	
549	605	EL CAMPO	94CN7710	1,056	0.314	
550	67	SOUTH SANTA ROSA	94SB1240	1,471	0.309	
551	252	OLMITO	94SB715	504	0.306	
552	646	WASHINGTON STREET	94LA2360	671	0.304	
553	618	LAREDO PLANT	94LA8565	1,446	0.304	
554	163	MCCOLL ROAD	94SB2810	2,303	0.304	
555	431	DEL MAR	94LA220	1,544	0.300	
556	616	BAY CITY	94CN7480	1,899	0.299	
557	398	LAREDO HEIGHTS	94LA9400	1,410	0.294	
558	521	PORTLAND	94CS6505	1,607	0.290	
559	601	MORRIS STREET	94CS8830	1,512	0.290	
560	647	PALMHURST	94SB2820	1,640	0.290	
561	544	WESLACO UNIT	94SB8195	1,689	0.288	
562	404	WASHINGTON STREET	94LA7015	1,911	0.286	
563	104	DEVINE	94LA7100	940	0.284	
564	241	MILO	94LA6940	361	0.283	
565	264	RAYMONDVILLE #2	94SB3240	959	0.283	
566	225	BROWNSVILLE	94SB4290	381	0.283	
567	452	EAST HARRISON	94SB4360	1,709	0.283	
568	341	DEL MAR	94LA10	2,473	0.280	
569	467	SKIDMORE	94CS600	352	0.278	
570	672	FULTON	94CS3070	1,567	0.274	
571	475	GARCENO	94SB2130	3,349	0.270	
572	509	HARLINGEN	94SB660	1,884	0.269	
573	584	MAGRUDER	94CN6690	545	0.268	
574	640	SHARYLAND	94SB5635	1,862	0.267	
575	56	RANGERVILLE	94SB3420	774	0.265	
576	38	PORT ISABEL S.S.	94SB9295	444	0.264	
577	114	HEARN ROAD	94CS8990	1,136	0.263	
578	426	OLMITO	94SB4275	764	0.262	
579	52	NORTH MCALLEN	94SB2980	1,703	0.261	
580	284	POLK AVENUE	94SB4600	2,641	0.261	
581	96	LOS FRESNOS	94SB7270	2,008	0.261	
582	406	KENEDY	94CN1970	631	0.260	
583	181	CABANISS	94CS75	1,990	0.259	
584	715	ROCKSPRINGS	94LA2600	367	0.259	
585	603	DEL MAR	94LA7930	1,213	0.256	
586	683	ESCONDIDO	94LA3350	931	0.255	
587	166	STADIUM	94LA7800	654	0.255	was 94CS7800
588	165	EAST HARRISON	94SB3030	716	0.250	
589	592	VILLA CAVAZOS	94SB5680	1,661	0.249	
590	224	HARLINGEN S.S.	94SB320	1,470	0.246	
591	693	AIRLINE	94CS5870	852	0.245	
592	214	NORTH MERCEDES	94SB3770	1,633	0.243	
593	434	HALL ACRES ROAD	94SB5465	1,522	0.242	
594	472	THREE RIVERS	94CN5190	788	0.239	
595	498	LAREDO PLANT	94LA8745	715	0.239	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
596	717	AIRLINE	94CS7270	991	0.234	
597	598	WASHINGTON STREET	94LA6525	2,064	0.234	
598	473	HAMILTON ROAD	94LA9665	943	0.234	
599	366	GARWOOD CITY	94CN2560	189	0.233	
600	536	BIG WELLS	94LA2630	26	0.231	
601	88	WEST HARLINGEN	94SB3720	1,852	0.230	
602	676	ANNA STREET	94LA780	456	0.228	
603	110	LEARY LANE	94CN1430	1,576	0.227	
604	663	BAY CITY	94CN6450	946	0.226	
605	512	BROOKHOLLOW	94CN8960	548	0.226	
606	308	GOODWIN	94SB4390	2,397	0.219	
607	668	HIDALGO	94SB3400	865	0.216	
608	353	LA GRULLA	94SB5110	2,262	0.216	
609	379	STADIUM	94LA8540	1,706	0.215	was 94CS8540
610	235	KLEBERG	94CS6000	1,464	0.213	
611	609	LAREDO HEIGHTS	94LA6810	2,049	0.212	
612	42	MATHIS	94CS1420	930	0.209	
613	594	HOLLY	94CS1220	3,295	0.208	
614	471	LA GRULLA	94SB6150	130	0.208	
615	276	SOUTHSIDE	94CS8005	744	0.206	
616	491	GOODWIN	94SB3530	1,343	0.206	
617	97	SAN BENITO	94SB3910	1,762	0.203	
618	126	EAGLE LAKE	94CN9455	575	0.202	
619	343	KINGSVILLE	94CS1350	361	0.202	
620	564	EL CAMPO	94CN6370	704	0.196	
621	304	ESCONDIDO	94LA2035	2,433	0.195	
622	99	NAVAL BASE	94CS8440	1,559	0.192	
623	200	BANQUETTE	94CS130	230	0.187	
624	419	CHARLOTTE	94LA8120	194	0.186	
625	364	HEARN ROAD	94CS8980	1,147	0.185	
626	187	BEEVILLE	94CN2380	201	0.184	
627	450	CHARLOTTE	94LA2780	516	0.182	
628	644	HAIN DRIVE	94SB9700	780	0.182	
629	537	BROOKHOLLOW	94CN7190	260	0.181	
630	240	EAGLE PASS CITY	94LA2650	1,298	0.173	
631	596	ESCONDIDO	94LA1510	693	0.172	
632	196	SHARYLAND	94SB2035	2,121	0.172	
633	381	HIGHWAY 9	94CS7210	304	0.171	
634	678	MORRIS STREET	94CS8840	584	0.171	
635	477	PHARR	94SB1645	2,538	0.171	
636	669	SOUTH EAST EDINBURG	94SB6580	1,310	0.171	
637	524	SIERRA VISTA	94LA9900	2,246	0.170	
638	132	RAYMONDVILLE #2	94SB1280	1,048	0.170	
639	172	FREER	94LA6320	161	0.168	
640	660	GATEWAY	94LA3595	1,489	0.163	
641	76	PHARR	94SB1640	1,029	0.161	
642	562	PORT ARANSAS	94CS3030	798	0.160	
643	20	PHARAOH	94CS1185	1,504	0.158	
644	428	AIRLINE	94CS9605	701	0.158	
645	349	RACHAL	94LA6595	292	0.154	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value	Notes
646	527	BLESSING	94CN8780	66	0.152	
647	173	DEL MAR	94LA490	739	0.152	
648	638	POLK AVENUE	94SB4520	880	0.149	
649	662	AIRLINE	94CS9390	1,412	0.147	
650	345	SAN BENITO	94SB4945	1,771	0.147	
651	10	GANADO	94CN5795	712	0.143	
652	444	KNIPPA	94LA6535	21	0.143	
653	685	POLK AVENUE	94SB4190	1,693	0.140	
654	691	EAST HARRISON	94SB3000	534	0.139	
655	704	KENEDY	94CN1960	59	0.136	
656	712	UNIVERSITY	94LA930	727	0.136	
657	74	HAINÉ DRIVE	94SB9240	44	0.136	
658	336	SOUTH MISSION	94SB3590	805	0.134	
659	372	WESMER	94SB7760	2,360	0.131	
660	258	KNIPPA	94LA6365	301	0.130	
661	659	HIGHWAY 9	94CS7200	538	0.128	
662	197	LAREDO HEIGHTS	94LA2100	2,051	0.128	
663	152	SOUTH PADRE ISLAND	94SB4695	1,362	0.128	
664	661	MCCOLL ROAD	94SB4790	1,896	0.126	
665	637	ARANSAS PASS	94CS590	392	0.125	
666	599	SOUTH MISSION	94SB5215	1,237	0.125	
667	2	HARLINGEN S.S.	94SB4230	1,300	0.123	
668	347	EAGLE PASS CITY	94LA7060	820	0.122	
669	339	MILO	94LA8365	1,782	0.119	
670	545	LAREDO HEIGHTS	94LA2450	2,476	0.118	
671	85	CAMPWOOD	94LA3430	85	0.118	
672	591	SOUTH MISSION	94SB3940	797	0.115	
673	551	RAYMONDVILLE #1	94SB3130	274	0.113	
674	383	RODD FIELD	94CS3010	1,759	0.106	
675	690	ZACATE CREEK	94LA2675	1,144	0.102	
676	650	ZAPATA	94LA7330	1,278	0.101	
677	630	HAMILTON ROAD	94LA9645	290	0.100	
678	714	SIERRA VISTA	94LA3540	329	0.097	
679	667	WOOLRIDGE	94CS1110	1,381	0.094	
680	574	THOMASTON	94CN9580	43	0.093	
681	161	CARANCAHUA	94CN5870	433	0.092	
682	26	PHARAOH	94CS1365	448	0.092	
683	576	WESMER	94SB4480	1,071	0.092	
684	710	AIRLINE	94CS7390	1,035	0.089	
685	384	SOUTH MISSION	94SB4650	965	0.089	
686	543	SAN BENITO	94SB3860	243	0.086	
687	211	SHARYLAND	94SB2010	1,018	0.085	
688	191	NORTH PADRE ISLAND	94CS5170	1,086	0.080	
689	311	SUNCHASE	94SB1155	1,434	0.079	
690	554	NORTH WESLACO	94SB4830	491	0.079	
691	405	WEST MCALLEN	94SB6385	202	0.079	
692	689	WASHINGTON STREET	94LA6355	1,076	0.077	
693	696	NORTH VICTORIA	94CN1470	436	0.076	
694	269	CONOCO-CHITTAM RANCH	94LA8580	40	0.075	
695	614	HOLLY	94CS9675	1,747	0.072	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIFI Ranking	2009 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIFI Value
696	577	ALICE	94LA1790	337	0.071
697	553	LEARY LANE	94CN6175	1,452	0.065
698	140	UNIVERSITY	94LA950	2,840	0.065
699	180	WEAVER ROAD	94CN1900	49	0.061
700	555	DEL RIO CITY	94LA9850	918	0.059
701	721	MILO	94LA3060	105	0.057
702	388	SOUTH MCALLEN	94SB3640	282	0.053
703	656	ZACATE CREEK	94LA2665	1,652	0.048
704	695	SHARYLAND	94SB2150	1,132	0.046
705	674	HIGHWAY 9	94CS9830	139	0.043
706	716	WASHINGTON STREET	94LA2470	187	0.043
707	194	MCCOLL ROAD	94SB4910	311	0.042
708	218	INGLESIDE CITY	94CS2495	200	0.035
709	707	SOUTHSIDE	94CS5345	398	0.033
710	701	LAREDO HEIGHTS	94LA2390	733	0.033
711	615	LEARY LANE	94CN1540	1,046	0.031
712	53	KLEBERG	94CS8140	382	0.029
713	267	EAGLE PASS CITY	94LA450	680	0.026
714	87	HARLINGEN S.S.	94SB4110	796	0.023
715	643	ROCKSPRINGS	94LA8040	324	0.019
716	502	HALL ACRES ROAD	94SB4895	795	0.015
717	665	LAREDO HEIGHTS	94LA9080	679	0.013
718	705	ZACATE CREEK	94LA2635	262	0.011
719	204	CAUSEWAY	94SB4775	1,059	0.006
720	718	VICTORIA POWER PLANT	94CNNETVIC	78	-
721	719	GREGORY	94CS420	22	-
722	<i>new</i>	NUECES BAY PLANT	94CS7840	45	-
723	720	MORRIS STREET	94CSNET CC	339	-
724	722	WASHINGTON STREET	94LANETLAR	359	-

Notes
was 94CS1790

new

Feeders from last year that are not in this year's list

2009 SAIFI Ranking	Substation Identification	Feeder Identification	Reason not in 2010
177	NUECES BAY PLANT	94CS7830	retired

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or More Customers

724

Add or Delete Rows as Necessary

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
1	2	RAYMONDVILLE #2	94SB3250	31	1,716.2	
2	139	CASA BLANCA	94CS1300	960	1,581.2	
3	9	CARRIZO SPRINGS	94LA370	255	946.1	
4	75	GREENLAKE	94CN2740	26	862.8	
5	267	ENCINAL	94LA2160	799	842.1	
6	12	GREENLAKE	94CN2760	559	830.6	
7	45	BRUNI	94LA5440	120	819.3	
8	186	FREER	94LA2900	156	799.4	
9	291	SABINAL	94LA485	479	740.2	
10	120	SAN BENITO	94SB4135	1,152	732.2	
11	190	CASA BLANCA	94CS5115	290	696.5	
12	7	BROWNSVILLE	94SB3050	1,966	695.4	
13	11	RANDADO	94LA8360	156	686.8	
14	50	TAFT	94CS1260	181	677.0	
15	674	ASPHALT MINES	94LA500	35	640.6	
16	160	COMSTOCK	94LA290	184	613.7	
17	557	SINTON	94CS360	292	600.5	
18	669	SABINAL	94LA200	410	592.4	
19	52	ROBSTOWN	94CS1650	341	556.8	
20	108	MARKHAM	94CN5550	95	551.8	
21	84	GOVERNMENT WELLS	94LA7240	194	549.3	
22	336	NORTH EDINBURG	94SB4240	2,075	545.7	
23	58	FALFURRIAS	94LA2830	1,625	544.2	
24	27	CRESTONIO	94LA270	611	534.9	
25	273	RANDADO	94LA8350	124	526.1	
26	396	BERCLAIR	94CN990	305	521.5	
27	8	GOVERNMENT WELLS	94LA6800	225	508.4	
28	5	ALAZAN	94CS620	164	502.1	
29	68	BRUNI	94LA5160	147	498.7	
30	491	HALL ACRES ROAD	94SB3460	3,463	480.8	
31	14	MOORE FIELD	94SB3120	125	458.1	
32	43	SOUTH MISSION	94SB3980	1,208	447.3	
33	446	MORRIS STREET	94CS7465	627	445.4	
34	30	ASHERTON	94LA2670	167	438.3	
35	15	CONTINENTAL	94SB3650	24	438.0	
36	394	VICTORIA POWER PLANT	94CN7600	158	430.5	
37	123	LULING - LCRA	94CN10	326	429.9	
38	403	HIGHWAY 9	94CS6780	782	426.0	
39	464	WEST OSO	94CS9085	733	423.4	
40	24	DARST	94CN790	73	422.6	
41	57	LOS FRESNOS	94SB4315	953	422.1	
42	69	GOVERNMENT WELLS	94LA7250	576	421.6	
43	194	VICTORIA POWER PLANT	94CN8170	754	420.8	
44	98	VILLA CAVAZOS	94SB1980	1,453	411.6	
45	452	NORTH EDINBURG	94SB560	1,592	404.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
46	264	RACHAL	94LA8145	365	404.3	
47	4	TATTON	94CN8490	124	402.3	
48	407	GREGORY	94CS5900	108	401.9	
49	77	CASA BLANCA	94CS55	812	382.1	
50	416	ELSA	94SB690	2,131	382.0	
51	450	SOUTH EAST EDINBURG	94SB4015	415	375.1	
52	668	MILO	94LA3065	184	372.8	
53	127	BLESSING	94CN1030	234	371.0	
54	174	GREGORY	94CS8560	869	369.9	
55	154	BLESSING	94CN8790	729	362.2	
56	436	YORKTOWN	94CN8420	998	361.0	
57	224	PUEBLO	94LA95	1,954	359.4	
58	171	WEST OSO	94CS9090	1,722	358.9	
59	145	RIO RICO	94SB8330	370	358.6	
60	251	THREE RIVERS	94CN8430	165	356.8	
61	257	ZAPATA	94LA8300	1,778	345.6	
62	352	PALACIOS	94CN8550	36	342.8	
63	552	POLK AVENUE	94SB4170	930	341.5	
64	269	BONNIEVIEW	94CS8020	505	338.9	
65	23	PALMVIEW	94SB9685	2,793	338.6	
66	22	SAN DIEGO	94LA1980	600	336.1	was 94CS1980
67	324	LULING - LCRA	94CN20	274	335.7	
68	71	MCCOLL ROAD	94SB4400	1,105	335.7	
69	80	FREER	94LA1500	180	328.1	
70	444	YORKTOWN	94CN8380	780	325.8	
71	378	BIG WELLS	94LA1570	409	323.3	
72	355	PETTUS	94CN1020	372	320.4	
73	338	MATHIS	94CS340	1,472	307.4	
74	695	EDNA	94CN5775	487	307.3	
75	263	VICTORIA POWER PLANT	94CN8070	603	303.3	
76	494	MAGRUDER	94CN245	1,091	302.3	
77	379	CLARKWOOD	94CS7220	362	301.4	
78	56	SKIDMORE	94CS380	305	301.2	
79	51	NORTH PADRE ISLAND	94CS720	1,074	297.7	
80	106	NORTH VICTORIA	94CN7440	1,585	292.4	
81	218	BANQUETTE	94CS9000	420	290.3	
82	134	GRETA	94CN7890	298	284.9	
83	49	RAYMONDVILLE #2	94SB3170	681	284.2	
84	17	ALAZAN	94CS2740	30	282.6	
85	130	RIO RICO	94SB8290	346	281.6	
86	119	FALFURRIAS	94LA1080	432	275.5	
87	527	OLMITO	94SB905	1,432	275.3	
88	10	MUSTANG ISLAND	94CS9470	649	273.6	
89	303	WEIL TRACT (138/12KV)	94CS5405	149	273.6	
90	121	PLACEDO	94CN7970	459	271.4	
91	287	GOLIAD	94CN8220	1,018	270.6	
92	432	SOUTH EAST EDINBURG	94SB4570	1,333	268.6	
93	465	PLEASANTON	94LA9475	1,302	268.0	
94	583	HIDALGO	94SB3680	321	266.8	
95	192	MOORE FIELD	94SB3960	1,705	262.8	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value
96	363	STADIUM	94LA7810	1,636	262.6
97	31	FALFURRIAS	94LA5210	1,105	261.0
98	35	MCKENZIE ROAD	94CS140	263	256.7
99	451	MATTHEWS	94CN1740	158	256.6
100	254	CRYSTAL CITY	94LA140	1,212	255.7
101	319	EAGLE LAKE	94CN320	640	255.5
102	195	WESLACO UNIT	94SB8610	2,368	253.8
103	209	POINT COMFORT	94CN2460	347	252.9
104	137	PALACIOS	94CN6830	803	252.9
105	162	RIO GRANDE CITY	94SB3740	3,142	252.6
106	205	RIO GRANDE CITY	94SB3210	1,683	250.4
107	435	PORT LAVACA	94CN2490	1,076	250.3
108	54	AMISTAD DAM	94LA5450	1,085	248.8
109	509	PHARAOH	94CS1285	1,741	246.9
110	368	THREE RIVERS	94CN2010	888	245.6
111	243	AIRLINE	94CS8260	1,488	244.4
112	347	ALICE	94LA1770	1,548	243.3
113	266	HIGHWAY 9	94CS6730	512	242.6
114	20	NIXON	94CN810	496	242.1
115	684	GATEWAY	94LA5055	1,920	242.1
116	572	PREMONT	94LA6570	712	240.6
117	302	KINGSVILLE	94CS1670	423	239.8
118	321	LIVE OAK	94CS1090	244	239.0
119	442	RIO BRAVO	94LA5	664	238.0
120	81	PREMONT	94LA2730	229	236.8
121	72	STAFFORD HILL	94CN1550	208	236.5
122	476	KINGSVILLE	94CS1140	976	234.5
123	40	NAVAL BASE	94CS6330	383	233.8
124	19	CLARKWOOD	94CS5525	888	232.9
125	663	VICTORIA POWER PLANT	94CN1390	1,134	232.8
126	260	MINES ROAD	94LA4275	11	232.6
127	392	PREMONT	94LA6610	814	232.5
128	212	KENEDY	94CN6270	477	231.8
129	28	NORTH PADRE ISLAND	94CS1010	1,783	231.0
130	151	SAN BENITO	94SB4030	2,382	230.8
131	277	NIXON	94CN2620	547	230.7
132	214	NIXON	94CN5990	557	228.6
133	588	WOODSBORO	94CS8330	1,069	228.0
134	454	PLEASANTON	94LA2080	1,509	228.0
135	182	MALONE	94CN7560	98	226.0
136	697	SANTO NINO	94LA515	1,900	225.7
137	376	NORTH ALAMO	94SB4370	2,410	223.3
138	170	PALMHURST	94SB2535	1,123	222.7
139	380	CLARKWOOD	94CS7610	187	221.4
140	16	LA PRYOR	94LA570	127	220.8
141	36	BANDERA ELECTRIC (LEAKEY)	94LAL30	267	220.8
142	296	WEST MCALLEN	94SB4505	1,742	218.9
143	692	WEST MCALLEN	94SB4515	801	217.5
144	417	LOLITA	94CN6330	26	215.0
145	616	ARCADIA	94CS5030	1,546	215.0

Notes
was 94CS7810

was 94CS1770

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
146	568	STADIUM	94LA7490	1,243	214.7	Notes was 94CS7490
147	193	MATHIS	94CS2870	852	212.3	
148	281	PORT ISABEL S.S.	94SB3820	208	209.9	
149	79	COLUMBUS	94CN6180	1,168	209.0	
150	455	BUENA VISTA	94LA8965	923	205.4	
151	434	HARLINGEN S.S.	94SB4090	2,257	204.6	
152	409	BAY CITY	94CN2700	1,058	203.1	
153	698	GARWOOD CITY	94CN2570	132	202.2	
154	199	GOODWIN	94SB4380	1,402	202.0	
155	365	ODEM	94CS5575	57	201.4	
156	691	NORTH MCALLEN	94SB9640	1,427	200.6	
157	665	LA GRULLA	94SB5005	968	197.0	
158	317	CRESTONIO	94LA260	1,745	195.4	
159	318	HIDALGO	94SB4845	1,042	194.4	
160	584	GARCENO	94SB2135	1,798	193.7	
161	231	SINTON	94CS6860	1,582	193.2	
162	177	RODD FIELD	94CS205	1,510	192.8	
163	78	DARST	94CN800	164	192.7	
164	21	MALONE	94CN7550	172	192.4	
165	133	RAYMONDVILLE #1	94SB630	775	192.2	
166	502	COTULLA	94LA90	724	191.6	
167	99	EDROY	94CS6990	267	190.9	
168	104	SOUTH PADRE ISLAND	94SB5850	1,451	188.0	
169	101	BRUNI	94LA1100	636	187.9	
170	268	PALMVIEW	94SB6790	2,876	187.7	
171	534	EDROY	94CS6980	192	187.2	
172	1	CONTINENTAL	94SB4880	62	185.2	
173	87	CRYSTAL CITY	94LA190	971	183.7	
174	425	AIRLINE	94CS7280	617	183.4	
175	13	ELSA	94SB710	1,641	181.8	
176	178	NORTH MCALLEN	94SB5055	2,995	180.3	
177	320	CLARKWOOD	94CS7230	560	178.9	
178	421	AIRLINE	94CS8370	302	178.2	
179	275	WESLACO UNIT	94SB7630	3,555	177.7	
180	213	PETTUS	94CN8210	350	176.9	
181	323	CARRIZO SPRINGS	94LA860	1,093	175.1	
182	<i>new</i>	HOMEPORT	94CS4665	433	174.1	<i>new</i>
183	157	BROWNSVILLE	94SB4280	227	173.5	
184	55	WEST HARLINGEN	94SB3700	1,706	173.3	
185	132	KLEBERG	94CS1560	1,297	173.3	
186	245	PEARSALL	94LA5580	1,618	171.8	
187	83	SOUTHSIDE	94CS5335	1,140	171.3	
188	109	LA GRULLA	94SB4120	270	171.2	
189	250	MAGRUDER	94CN6700	1,421	170.5	
190	136	FALFURRIAS	94LA1070	1,022	170.4	
191	61	LA PRYOR	94LA580	188	170.4	
192	91	CABANISS	94CS80	1,066	169.8	
193	477	ARANSAS PASS	94CS9130	321	169.2	
194	32	CRYSTAL CITY	94LA330	1,158	168.2	
195	384	SAN DIEGO	94LA2930	601	167.4	was 94CS2930

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
196	585	WEIL TRACT (138/12KV)	94CS1990	1,251	167.2	
197	498	CITRUS CITY	94SB7985	1,523	166.8	
198	520	GOODWIN	94SB4625	338	166.5	
199	112	WEST MCALLEN	94SB4965	702	166.4	
200	144	PORT LAVACA	94CN8310	312	165.7	
201	398	ZAPATA	94LA8290	2,240	162.6	
202	92	RAYMONDVILLE #1	94SB620	613	161.9	
203	128	WESMER	94SB1850	1,117	161.4	
204	463	ODEM	94CS375	991	159.1	
205	164	SOUTHSIDE	94CS8025	1,029	158.1	
206	100	PHARR	94SB1625	2,008	158.1	
207	342	UVALDE	94LA550	656	157.2	
208	44	CITRUS CITY	94SB9775	1,963	156.7	
209	286	PHARAOH	94CS5175	976	156.2	
210	482	LAREDO PLANT	94LA8505	775	155.8	
211	689	NORTH VICTORIA	94CN6390	1,311	155.3	
212	217	ALICE	94LA2540	1,106	154.5	was 94CS2540
213	34	MAVERICK	94LA9680	700	154.5	
214	206	HEARN ROAD	94CS870	1,105	152.9	
215	169	JOURDANTON	94LA250	743	152.8	
216	651	PLEASANTON	94LA120	1,201	151.5	
217	680	BRACKETTVILLE	94LA8460	1,158	151.2	
218	97	CAMPWOOD	94LA2610	927	150.9	
219	590	MORRIS STREET	94CS2515	1,083	149.3	
220	621	LAREDO PLANT	94LA8705	211	148.3	
221	42	PALMVIEW	94SB3930	1,062	148.1	
222	208	NORTH WESLACO	94SB4810	1,350	146.6	
223	389	KINGSVILLE	94CS1660	1,572	146.4	
224	258	SOUTH SANTA ROSA	94SB1235	630	146.0	
225	471	GEORGE WEST	94CN730	847	144.9	
226	504	LEARY LANE	94CN6005	1,784	144.1	
227	460	PALMVIEW	94SB7595	2,629	143.9	
228	315	PALACIOS	94CN6840	1,509	143.4	
229	373	VILLA CAVAZOS	94SB7615	934	143.3	
230	26	MINES ROAD	94LA3680	874	143.2	
231	399	LYTLE	94LA2850	617	143.1	
232	447	BEEVILLE	94CN1760	1,780	141.4	
233	522	EAST HARRISON	94SB3080	364	140.7	
234	237	ALICE	94LA2530	1,433	140.0	was 94CS2530
235	512	LAGUNA	94CS9590	2,088	139.8	
236	499	ARCADIA	94CS1360	1,508	139.6	
237	412	RIO BRAVO	94LA300	859	139.2	
238	565	PARKER	94CN9010	18	139.0	
239	3	COFFEE PORT	94SB1095	956	138.4	
240	649	KENEDY S.S.	94CN6750	759	136.5	
241	679	NORTH MCALLEN	94SB3830	1,288	135.4	
242	276	BUENA VISTA	94LA9385	2,056	135.0	
243	390	WADSWORTH	94CN8630	624	134.6	
244	225	BISHOP	94CS7180	920	134.3	
245	422	NORTH MCALLEN	94SB5060	2,178	134.2	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
246	47	NORTH PADRE ISLAND	94CS7900	1,836	134.0	
247	643	SEAWALL	94CS9450	287	133.6	
248	189	ELSA	94SB3500	1,108	133.6	
249	493	BEEVILLE	94CN8090	1,220	132.9	
250	547	COFFEE PORT	94SB1090	1,154	132.8	
251	429	UVALDE	94LA6620	2,647	132.2	
252	543	BEEVILLE	94CN490	929	131.8	
253	381	FULTON	94CS9050	1,610	131.6	
254	142	SOUTHSIDE	94CS7925	1,342	130.2	
255	284	ARANSAS PASS	94CS8270	595	128.4	
256	107	DEVINE	94LA7090	912	127.3	
257	207	SEAWALL	94CS9420	797	127.0	
258	605	RAYMONDVILLE #1	94SB800	674	126.4	
259	443	SIERRA VISTA	94LA7360	2,481	126.4	
260	308	CABANISS	94CS240	1,444	125.6	
261	566	NORTH MCALLEN	94SB9660	1,988	125.5	
262	367	POINT COMFORT	94CN6060	50	125.4	
263	294	SOUTH MCALLEN	94SB3790	1,848	121.3	
264	292	PORTLAND	94CS9270	1,879	121.1	
265	129	ELSA	94SB3520	398	120.6	
266	612	EL CAMPO	94CN2860	818	120.5	
267	175	INGLESIDE CITY	94CS8050	1,311	120.2	
268	481	BEEVILLE	94CN300	1,584	118.8	
269	59	NUECES BAY PLANT	94CS350	801	118.8	
270	554	SINTON	94CS1750	500	118.8	
271	597	ARCADIA	94CS1440	1,589	118.3	
272	238	SOUTHSIDE	94CS7995	1,526	117.8	
273	282	ARCADIA	94CS5020	1,517	117.7	
274	501	LAREDO PLANT	94LA8695	987	116.6	
275	468	WESMER	94SB4050	1,889	116.5	
276	334	DEL RIO CITY	94LA1930	918	116.4	
277	657	MORRIS STREET	94CS5655	950	116.3	
278	105	EAST HARRISON	94SB3950	552	115.3	
279	508	COLUMBUS	94CN9060	366	114.4	
280	113	HARLINGEN	94SB360	2,441	114.3	
281	226	ELSA	94SB700	1,354	113.9	
282	73	BRUNI	94LA1120	142	113.6	
283	513	PALMHURST	94SB3890	2,296	113.5	
284	311	WASHINGTON STREET	94LA2350	2,899	113.4	
285	415	WEST OSO	94CS9095	1,445	113.4	
286	440	SOUTHSIDE	94CS8055	854	113.3	
287	589	PORT LAVACA	94CN2480	1,518	112.9	
288	64	CAUSEWAY	94SB4795	1,193	112.6	
289	711	ROCKPORT	94CS5940	42	112.3	
290	345	PEARSALL	94LA9905	746	112.3	
291	461	INGLESIDE CITY	94CS6040	249	112.1	
292	152	WESLACO UNIT	94SB7455	1,217	112.0	
293	480	ARCADIA	94CS1400	428	112.0	
294	210	PORT ARANSAS	94CS6940	1,581	111.9	
295	229	NORTH ALAMO	94SB3610	3,457	111.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
296	372	SANTO NINO	94LA695	1,486	111.1	
297	688	SANTO NINO	94LA645	923	111.0	
298	385	TATTON	94CS950	526	110.1	
299	714	HALL ACRES ROAD	94SB9595	1,032	110.0	
300	523	SAN DIEGO	94LA2880	1,223	109.9	was 94CS2880
301	95	REFUGIO	94CN5120	174	109.8	
302	595	SANTO NINO	94LA70	1,147	109.4	
303	411	NORDHEIM	94CN470	235	109.3	
304	198	WESLACO UNIT	94SB2195	1,090	109.1	
305	453	RIO GRANDE CITY	94SB3220	1,776	108.8	
306	492	NORTH MERCEDES	94SB3840	637	108.1	
307	541	BISHOP	94CS2690	551	107.4	
308	578	HARLINGEN	94SB370	1,177	106.7	
309	246	WEAVER ROAD	94CN1910	358	106.3	
310	327	HIGHWAY 9	94CS6770	1,158	106.0	
311	176	PORT ISABEL S.S.	94SB3760	2,096	105.1	
312	259	PLEASANTON	94LA9505	1,443	105.0	
313	233	EAGLE LAKE	94CN310	725	104.6	
314	143	KLEBERG	94CS280	1,074	104.4	
315	466	SEAWALL	94CS9325	1,370	103.9	
316	347	HAIN DRIVE	94SB270	864	103.7	
317	515	PARKER	94CN9260	94	102.9	
318	360	SOUTHSIDE	94CS7955	1,041	102.9	
319	546	MAGRUDER	94CN6680	684	101.7	
320	426	GATEWAY	94LA390	947	101.1	
321	457	NORTH VICTORIA	94CN7430	1,696	100.1	
322	325	SINTON	94CS180	902	99.3	
323	340	ARCADIA	94CS8570	1,430	99.2	
324	535	NORTH VICTORIA	94CN2240	784	98.6	
325	248	RIO RICO	94SB5050	1,628	98.5	
326	598	DEL MAR	94LA7930	1,213	98.3	
327	703	CHASE FIELD	94CN460	14	98.0	
328	559	LEARY LANE	94CN7530	1,882	97.0	
329	103	PREMONT	94LA2720	783	96.5	
330	670	NORTH VICTORIA	94CN7860	1,431	95.9	
331	362	SOUTH SANTA ROSA	94SB1225	818	95.9	
332	163	UVALDE	94LA9770	1,286	95.7	
333	690	MILO	94LA3070	3,187	95.5	
334	295	AIRLINE	94CS9030	420	95.2	
335	610	ARCADIA	94CS6930	1,498	95.2	
336	234	NORTH EDINBURG	94SB3570	990	94.7	
337	424	FULTON	94CS6070	2,999	94.3	
338	614	SHARYLAND	94SB6745	1,883	93.9	
339	405	PLACEDO	94CN7980	396	93.9	
340	661	TAFT	94CS1180	1,044	93.4	
341	652	PHARR	94SB1620	2,662	93.2	
342	86	PRAIRIE PUMP	94CN1940	62	93.1	
343	316	NUECES BAY PLANT	94CS345	54	93.0	
344	288	SAN DIEGO	94LA2890	1,038	92.3	was 94CS2890
345	658	HAIN DRIVE	94SB3490	1,029	91.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
346	497	BAY CITY	94CN6670	1,751	91.4	
347	265	WEIL TRACT (138/12KV)	94CS2520	533	90.5	
348	185	HIGHWAY 9	94CS6720	1,302	90.4	
349	626	ARCADIA	94CS1450	1,863	90.1	
350	449	LIVE OAK	94CS1070	2,740	89.9	
351	599	HOLLY	94CS7740	1,995	89.7	
352	307	WOOLRIDGE	94CS1120	2,629	89.7	
353	633	DEL RIO CITY	94LA440	844	88.8	
354	609	ANNA STREET	94LA900	2,964	87.7	
355	335	ROCKPORT	94CS5930	1,076	87.1	
356	329	DEVINE	94LA8100	1,465	86.5	
357	564	LAREDO HEIGHTS	94LA6820	2,091	86.5	
358	459	NORTH VICTORIA	94CN7770	792	86.4	
359	125	CLARKWOOD	94CS9570	1,100	86.2	
360	181	EDNA	94CN5765	1,582	85.6	
361	600	ANNA STREET	94LA2250	1,553	85.5	
362	272	FULTON	94CS2020	1,766	85.2	
363	346	NORTH EDINBURG	94SB3810	827	84.9	
364	271	WESMER	94SB6900	1,537	84.8	
365	118	SOUTH EAST EDINBURG	94SB5045	1,781	84.4	
366	364	HIGHWAY 9	94CS6760	598	84.3	
367	148	HALL ACRES ROAD	94SB5585	697	83.6	
368	591	BAY CITY	94CN5960	1,806	82.4	
369	122	PORTLAND	94CS9290	1,658	82.0	
370	310	SOUTH MCALLEN	94SB3850	785	81.7	
371	211	WOOLRIDGE	94CS1170	1,265	81.5	
372	430	EAST HARRISON	94SB4310	1,144	81.1	
373	603	NORTH MCALLEN	94SB4995	1,867	80.9	
374	247	PORT ARANSAS	94CS990	1,335	80.9	
375	312	HOLLY	94CS1480	1,679	80.1	
376	62	KLEBERG	94CS6410	392	79.4	
377	184	PALMHURST	94SB2525	1,879	79.4	
378	204	CARRIZO SPRINGS	94LA910	1,882	79.4	
379	682	JOURDANTON	94LA5685	529	79.0	
380	82	ARANSAS PASS	94CS1250	352	79.0	
381	74	NORTH MERCEDES	94SB4860	1,387	78.4	
382	608	HOLLY	94CS7620	2,327	78.1	
383	676	PORT LAVACA	94CN6850	592	78.1	
384	262	HAINE DRIVE	94SB8065	1,276	78.1	
385	116	PALMVIEW	94SB9680	1,015	77.7	
386	239	RODD FIELD	94CS245	2,544	77.6	
387	126	RIO BRAVO	94LA1130	914	77.4	
388	472	ANNA STREET	94LA5780	722	76.8	
389	371	PEARSALL	94LA7050	1,298	76.8	
390	235	ROMA	94SB3070	860	76.2	
391	156	THREE RIVERS	94CN2580	57	76.2	
392	366	FREER	94LA5200	1,017	75.2	
393	516	SAN YGNACIO	94LA16060	494	74.7	
394	53	CITRUS CITY	94SB3470	3,020	74.4	
395	439	JOURDANTON	94LA880	288	73.6	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
396	283	O CONNER	94CN390	213	73.3	
397	114	RODD FIELD	94CS225	785	73.2	
398	201	EAGLE PASS CITY	94LA2770	2,940	72.8	
399	620	MCCOLL ROAD	94SB4780	2,148	72.2	
400	639	WEST MCALLEN	94SB4815	708	71.8	
401	617	HALL ACRES ROAD	94SB8870	3,670	71.7	
402	344	KINGSVILLE	94CS1130	2,042	70.9	
403	94	PALMHURST	94SB1300	1,260	70.9	
404	607	PUEBLO	94LA130	1,245	70.7	
405	576	BAY CITY	94CN2050	512	70.7	
406	485	NORTH ALAMO	94SB3580	1,860	70.4	
407	391	SOUTH MISSION	94SB3620	1,855	70.3	
408	76	GOLIAD	94CN6540	1,105	69.6	
409	592	LAREDO PLANT	94LA9305	959	68.8	
410	326	ARCADIA	94CS1460	1,921	68.8	
411	111	MORRIS STREET	94CS8850	473	68.1	
412	6	CONTINENTAL	94SB4080	127	68.1	
413	458	WEST HARLINGEN	94SB4870	705	67.9	
414	253	SOUTH EAST EDINBURG	94SB4550	2,123	67.8	
415	427	CRESTONIO	94LA6660	728	67.7	
416	102	LOS FRESNOS	94SB5335	1,852	67.7	
417	601	MILO	94LA5020	1,287	67.5	
418	532	WEST MCALLEN	94SB4535	2,773	67.4	
419	496	DEL RIO CITY	94LA420	2,295	67.4	
420	548	REFUGIO	94CN1040	720	67.2	
421	530	RIO GRANDE CITY	94SB3230	1,418	67.1	
422	333	MARKHAM	94CN6440	424	66.9	
423	687	GATEWAY	94LA350	1,598	66.6	
424	167	PORT ISABEL S.S.	94SB4070	292	66.6	
425	660	MORRIS STREET	94CS7625	564	65.6	
426	187	CAUSEWAY	94SB4765	1,160	65.4	
427	555	SOUTHSIDE	94CS8035	1,079	65.3	
428	611	EL CAMPO	94CN5745	868	64.9	
429	179	MORRIS STREET	94CS8820	1,231	64.4	
430	146	SOUTHSIDE	94CS7905	1,821	64.4	
431	351	UVALDE	94LA480	1,276	64.3	
432	353	STADIUM	94LA6950	534	64.2	was 94CS6950
433	236	SOUTH SANTA ROSA	94SB1215	1,616	64.2	
434	540	SANTO NINO	94LA80	2,345	63.7	
435	66	LAGUNA	94CS9065	1,925	63.5	
436	138	ASHERTON	94LA2660	554	62.8	
437	343	WESLACO UNIT	94SB5970	2,889	62.6	
438	553	MORRIS STREET	94CS8715	1,568	62.6	
439	278	SANTO NINO	94LA75	1,490	62.5	
440	431	PALMHURST	94SB2530	1,799	62.1	
441	596	HIDALGO	94SB3400	865	62.1	
442	488	LOS FRESNOS	94SB2160	1,111	61.8	
443	289	SUNCHASE	94SB1150	1,250	61.2	
444	505	MCKENZIE ROAD	94CS150	21	60.7	
445	349	RANGERVILLE	94SB3410	795	60.5	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
446	63	ARMSTRONG	94CS6050	67	60.3	
447	525	NORTH VICTORIA	94CN1580	1,030	60.1	
448	203	WADSWORTH	94CN7660	1,281	59.9	
449	300	RANGERVILLE	94SB4060	868	59.3	
450	279	ROMA	94SB3060	1,535	59.1	
451	490	MAGRUDER	94CN7690	570	59.0	
452	117	GREENLAKE	94CN2750	1,099	58.9	
453	542	WEST MCALLEN	94SB4555	1,476	58.2	
454	533	ODEM	94CS385	386	57.9	
455	354	LIVE OAK	94CS1080	781	57.5	
456	635	LEARY LANE	94CN1890	1,565	56.9	
457	230	HAINE DRIVE	94SB9690	835	56.7	
458	29	SOUTH PADRE ISLAND	94SB6440	2,399	56.4	
459	693	EL CAMPO	94CN7260	524	55.9	
460	511	GOODWIN	94SB7380	2,122	55.7	
461	149	MAGRUDER	94CN7870	1,269	54.9	
462	216	MOORE FIELD	94SB3110	612	54.7	
463	350	SAN BENITO	94SB3920	2,331	54.5	
464	155	SOUTHSIDE	94CS8045	1,017	54.3	
465	322	HEARN ROAD	94CS9665	547	54.0	
466	664	POLK AVENUE	94SB4740	1,848	53.6	
467	386	EAST HARRISON	94SB4360	1,709	53.6	
468	487	DEL MAR	94LA3440	1,386	52.7	
469	659	WASHINGTON STREET	94LA2360	671	52.5	
470	593	BEEVILLE	94CN8510	852	52.3	
471	357	NORTH MCALLEN	94SB2750	2,987	52.3	
472	215	RAYMONDVILLE #2	94SB3240	959	52.3	
473	581	HOLLY	94CS1370	1,841	52.2	
474	408	FOSTER FIELD	94CN2550	332	52.0	
475	220	EL CAMPO	94CN2800	1,291	52.0	
476	261	TATTON	94CS8200	972	51.8	
477	694	THREE RIVERS	94CN5100	35	51.7	
478	348	PUEBLO	94LA275	2,657	51.3	
479	594	ALICE	94LA1780	269	51.3	was 94CS1780
480	618	MINES ROAD	94LA3745	1,414	51.2	
481	545	SOUTH MCALLEN	94SB5065	92	50.8	
482	484	LAREDO HEIGHTS	94LA9400	1,410	50.4	
483	604	LA PRYOR	94LA2440	643	49.4	
484	580	MAGRUDER	94CN6690	545	49.0	
485	571	SOUTH SANTA ROSA	94SB7485	1,031	48.9	
486	159	REFUGIO	94CN1210	208	48.6	
487	337	WESLACO UNIT	94SB9805	1,811	48.4	
488	445	COTULLA	94LA110	1,269	48.2	
489	641	KENEDY S.S.	94CN8340	877	48.0	
490	375	DILLEY	94LA510	520	48.0	
491	675	SHARYLAND	94SB5105	1,518	47.3	
492	705	EAGLE PASS CITY	94LA2510	639	47.1	
493	483	BROOKHOLLOW	94CN8950	852	47.1	
494	423	HOLLY	94CS5820	926	46.9	
495	38	NORTH MCALLEN	94SB2980	1,703	46.9	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
496	65	SHARYLAND	94SB2020	2,279	46.8	
497	413	ARANSAS PASS	94CS8280	546	46.6	
498	438	UVALDE	94LA540	1,198	46.5	
499	536	VILLA CAVAZOS	94SB5680	1,661	46.1	
500	631	HAMILTON ROAD	94LA9655	1,191	45.8	
501	437	COLUMBUS	94CN930	881	45.2	
502	517	BROOKHOLLOW	94CN7580	417	45.1	
503	506	POLK AVENUE	94SB4900	3,292	44.9	
504	147	BROWNSVILLE	94SB4290	381	44.9	
505	183	EAGLE PASS CITY	94LA2745	915	44.7	
506	377	HOLLY	94CS1950	798	44.7	
507	645	BAY CITY	94CN1110	1,277	44.7	
508	529	RUNGE	94CN7320	578	44.7	
509	304	MCKENZIE ROAD	94CS330	2,234	44.3	
510	567	CHARLOTTE	94LA2790	97	43.7	
511	404	BEEVILLE	94CN2200	749	43.5	
512	388	FULTON	94CS440	1,974	43.1	
513	241	EDNA	94CN5785	743	43.1	
514	629	WEST MCALLEN	94SB4595	1,132	42.4	
515	648	BAY CITY	94CN7480	1,899	42.3	
516	622	EAST HARRISON	94SB4620	766	42.2	
517	615	MORRIS STREET	94CS8830	1,512	42.1	
518	628	ROCKPORT	94CS5950	531	42.0	
519	418	SOUTH MCALLEN	94SB3935	1,260	42.0	
520	150	PHARAOH	94CS5185	1,906	41.8	
521	531	TAFT	94CS5230	813	41.4	
522	280	HARLINGEN	94SB380	2,298	41.3	
523	85	KENEDY S.S.	94CN8320	653	41.2	
524	173	DILLEY	94LA6400	782	40.9	
525	39	GANADO	94CN5815	580	40.7	
526	255	MCCOLL ROAD	94SB2810	2,303	40.1	
527	469	DEL RIO CITY	94LA430	2,462	39.5	
528	587	LAREDO PLANT	94LA8565	1,446	39.4	
529	358	EAST HARRISON	94SB3190	1,412	38.4	
530	166	DEVINE	94LA7100	940	38.2	
531	242	OLMITO	94SB715	504	38.0	
532	625	ARANSAS PASS	94CS650	726	37.9	
533	274	MATHIS	94CS1410	448	37.7	
534	474	HEARN ROAD	94CS2220	1,515	37.6	
535	569	MCCOLL ROAD	94SB1655	1,136	37.5	
536	489	AIRLINE	94CS9605	701	36.5	
537	60	SOUTH SANTA ROSA	94SB1240	1,471	36.4	
538	467	JOURDANTON	94LA5695	1,261	36.3	
539	313	DEL MAR	94LA10	2,473	36.2	
540	558	WESMER	94SB9705	1,054	36.1	
541	707	ROCKSPRINGS	94LA2600	367	36.1	
542	219	FASHING	94CN8160	38	34.8	
543	414	STADIUM	94LA7800	654	34.7	was 94CS7800
544	387	ANNA STREET	94LA850	1,552	34.6	
545	330	THREE RIVERS	94CN5190	788	34.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
546	602	POLK AVENUE	94SB4610	1,310	33.9	
547	630	SHARYLAND	94SB5635	1,862	33.8	
548	653	HAIN DRIVE	94SB9700	780	33.6	
549	331	KLEBERG	94CS9395	1,315	33.5	
550	551	SOUTH EAST EDINBURG	94SB6580	1,310	33.3	
551	507	GEORGE WEST	94CN1320	641	33.2	
552	634	FULTON	94CS3070	1,567	33.1	
553	223	HARLINGEN S.S.	94SB320	1,470	33.1	
554	110	WEST HARLINGEN	94SB3800	1,323	32.8	
555	640	PALMHURST	94SB2820	1,640	32.8	
556	518	DEL RIO CITY	94LA9790	2,535	32.4	
557	<i>new</i>	HARLINGEN S.S.	94SB5350	728	31.9	<i>new</i>
558	685	ARANSAS PASS	94CS660	723	31.8	
559	96	CABANISS	94CS75	1,990	31.8	
560	227	WASHINGTON STREET	94LA7015	1,911	31.5	
561	562	HALL ACRES ROAD	94SB5465	1,522	31.5	
562	560	BIG WELLS	94LA2630	26	31.2	
563	479	AIRLINE	94CS6970	1,206	31.1	
564	124	SAN BENITO	94SB3910	1,762	31.1	
565	328	OLMITO	94SB4275	764	30.9	
566	606	LAREDO PLANT	94LA8745	715	30.8	
567	33	MUSTANG ISLAND	94CS8510	402	30.7	
568	240	REFUGIO	94CN1170	880	30.6	
569	285	SKIDMORE	94CS600	352	30.5	
570	410	SOUTHSIDE	94CS8005	744	30.5	
571	503	NAVAL BASE	94CS1380	2,118	30.4	
572	369	GOODWIN	94SB4390	2,397	30.4	
573	713	HALL ACRES ROAD	94SB3670	867	30.3	
574	222	INGLESIDE CITY	94CS8060	1,802	30.3	
575	582	WASHINGTON STREET	94LA6525	2,064	30.2	
576	188	BANQUETTE	94CS130	230	30.2	
577	356	KINGSVILLE	94CS1350	361	30.1	
578	131	WEST HARLINGEN	94SB3720	1,852	29.9	
579	544	AIRLINE	94CS8890	527	29.7	
580	462	MILO	94LA6940	361	29.7	
581	519	PORTLAND	94CS6505	1,607	29.5	
582	671	ANNA STREET	94LA780	456	29.5	
583	428	GARCENO	94SB2130	3,349	29.4	
584	699	ZAPATA	94LA2710	50	29.3	
585	402	UVALDE	94LA5060	1,297	28.7	
586	667	POLK AVENUE	94SB4180	1,159	28.1	
587	575	HARLINGEN	94SB660	1,884	28.1	
588	673	BAY CITY	94CN6450	946	28.0	
589	538	DEL MAR	94LA220	1,544	27.8	
590	293	LA GRULLA	94SB5110	2,262	27.3	
591	433	UNIVERSITY	94LA920	327	27.1	
592	37	GANADO	94CN5795	712	27.1	
593	161	LOS FRESNOS	94SB7270	2,008	27.0	
594	153	PORT ISABEL S.S.	94SB9295	444	26.8	
595	89	PHARAOH	94CS1185	1,504	26.7	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
596	115	PORTLAND	94CS9370	1,418	26.5	
597	191	RODD FIELD	94CS1730	1,973	26.3	
598	141	HEARN ROAD	94CS8990	1,136	26.1	
599	301	EAGLE PASS CITY	94LA7060	820	26.0	
600	561	BROOKHOLLOW	94CN8960	548	25.9	
601	473	GREGORY	94CS5920	507	25.7	
602	383	GARWOOD CITY	94CN2560	189	25.4	
603	270	STADIUM	94LA8540	1,706	25.4	was 94CS8540
604	382	SOUTH PADRE ISLAND	94SB4695	1,362	25.4	
605	165	DEL MAR	94LA490	739	25.1	
606	537	BUENA VISTA	94LA9035	1,479	24.8	
607	478	SIERRA VISTA	94LA9900	2,246	24.0	
608	419	EAST HARRISON	94SB3030	716	23.5	
609	168	PHARR	94SB1640	1,029	23.5	
610	314	HIGHWAY 9	94CS7210	304	23.2	
611	524	WESLACO UNIT	94SB8195	1,689	23.0	
612	90	RANGERVILLE	94SB3420	774	22.8	
613	636	LAREDO HEIGHTS	94LA6810	2,049	22.5	
614	306	KLEBERG	94CS6000	1,464	22.4	
615	172	EAGLE LAKE	94CN9455	575	22.4	
616	654	MCCOLL ROAD	94SB4790	1,896	22.4	
617	448	KENEDY	94CN1970	631	22.3	
618	93	NORTH PADRE ISLAND	94CS5170	1,086	22.2	
619	539	PHARR	94SB1645	2,538	22.1	
620	180	PHARAOH	94CS1365	448	22.1	
621	309	ESCONDIDO	94LA2035	2,433	21.6	
622	627	POLK AVENUE	94SB4520	880	21.6	
623	359	LEARY LANE	94CN1430	1,576	21.5	
624	339	POLK AVENUE	94SB4600	2,641	21.2	
625	495	HEARN ROAD	94CS8980	1,147	20.5	
626	650	GATEWAY	94LA3595	1,489	20.5	
627	249	RODD FIELD	94CS2190	2,882	20.3	
628	232	NORTH MERCEDES	94SB3770	1,633	19.9	
629	706	UNIVERSITY	94LA930	727	19.8	
630	702	AIRLINE	94CS5870	852	19.7	
631	88	NAVAL BASE	94CS8440	1,559	19.7	
632	401	CHARLOTTE	94LA2780	516	19.7	
633	135	RAYMONDVILLE #2	94SB1280	1,048	19.4	
634	646	EL CAMPO	94CN7710	1,056	19.3	
635	701	KENEDY	94CN1960	59	19.1	
636	577	MILO	94LA8365	1,782	18.5	
637	256	RACHAL	94LA6595	292	18.3	
638	574	HIGHWAY 9	94CS7200	538	17.8	
639	25	HARLINGEN S.S.	94SB4230	1,300	17.7	
640	563	SOUTH MISSION	94SB3940	797	17.4	
641	683	POLK AVENUE	94SB4190	1,693	17.1	
642	704	WASHINGTON STREET	94LA6355	1,076	17.1	
643	456	GOODWIN	94SB3530	1,343	17.0	
644	677	MORRIS STREET	94CS8840	584	16.9	
645	395	SOUTH MISSION	94SB3590	805	16.9	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
646	550	PORT ARANSAS	94CS3030	798	16.8	
647	717	AIRLINE	94CS7270	991	16.7	
648	67	MATHIS	94CS1420	930	16.7	
649	332	EAGLE PASS CITY	94LA2650	1,298	16.5	
650	299	WESMER	94SB7760	2,360	16.4	
651	623	HOLLY	94CS1220	3,295	16.3	
652	573	EL CAMPO	94CN6370	704	15.3	
653	228	FREER	94LA6320	161	15.1	
654	420	RAYMONDVILLE #2	94SB4160	346	14.8	
655	361	SHARYLAND	94SB2035	2,121	14.6	
656	500	SAN BENITO	94SB3860	243	14.5	
657	475	RODD FIELD	94CS3010	1,759	14.4	
658	586	ESCONDIDO	94LA1510	693	14.2	
659	197	KNIPPA	94LA6365	301	13.5	
660	528	PORT ARANSAS	94CS1000	1,335	13.4	
661	619	HAMILTON ROAD	94LA9665	943	13.4	
662	715	SIERRA VISTA	94LA3540	329	13.2	
663	721	MILO	94LA3060	105	13.1	
664	370	BEEVILLE	94CN2380	201	13.0	
665	644	BLESSING	94CN8780	66	13.0	
666	18	CAMPWOOD	94LA3430	85	13.0	
667	200	SAN BENITO	94SB4945	1,771	12.8	
668	297	SOUTH MCALLEN	94SB3640	282	12.8	
669	570	WESMER	94SB4480	1,071	12.7	
670	709	EAST HARRISON	94SB3000	534	12.5	
671	305	CHARLOTTE	94LA8120	194	12.1	
672	202	CARANCAHUA	94CN5870	433	11.9	
673	374	SUNCHASE	94SB1155	1,434	11.9	
674	672	AIRLINE	94CS9390	1,412	11.3	
675	655	WOOLRIDGE	94CS1110	1,381	11.2	
676	290	LAREDO HEIGHTS	94LA2100	2,051	10.9	
677	549	THOMASTON	94CN9580	43	10.7	
678	393	SOUTH MISSION	94SB4650	965	10.6	
679	666	ESCONDIDO	94LA3350	931	10.2	
680	708	ZACATE CREEK	94LA2675	1,144	9.9	
681	624	LEARY LANE	94CN6175	1,452	9.8	
682	510	SOUTH MISSION	94SB5215	1,237	9.5	
683	486	LAREDO HEIGHTS	94LA2450	2,476	9.5	
684	514	KNIPPA	94LA6535	21	9.4	
685	521	ALICE	94LA1790	337	9.1	was 94CS1790
686	400	LA GRULLA	94SB6150	130	8.8	
687	686	ZAPATA	94LA7330	1,278	8.7	
688	556	BROOKHOLLOW	94CN7190	260	8.6	
689	526	RAYMONDVILLE #1	94SB3130	274	8.5	
690	710	AIRLINE	94CS7390	1,035	8.4	
691	140	CONOCO-CHITTAM RANCH	94LA8580	40	8.4	
692	406	SHARYLAND	94SB2010	1,018	8.3	
693	46	HAINE DRIVE	94SB9240	44	8.2	
694	632	HOLLY	94CS9675	1,747	7.8	
695	696	NORTH VICTORIA	94CN1470	436	7.4	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2010 SAIDI Ranking	2009 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2010 SAIDI Value	Notes
696	647	ARANSAS PASS	94CS590	392	7.3	
697	642	ZACATE CREEK	94LA2665	1,652	7.2	
698	221	WEAVER ROAD	94CN1900	49	6.7	
699	41	KLEBERG	94CS8140	382	6.6	
700	397	NORTH WESLACO	94SB4830	491	6.5	
701	252	UNIVERSITY	94LA950	2,840	6.5	
702	637	WEST MCALLEN	94SB6385	202	5.6	
703	638	LEARY LANE	94CN1540	1,046	5.6	
704	716	WASHINGTON STREET	94LA2470	187	4.8	
705	712	SOUTHSIDE	94CS5345	398	4.8	
706	579	DEL RIO CITY	94LA9850	918	4.5	
707	681	HAMILTON ROAD	94LA9645	290	4.2	
708	662	SHARYLAND	94SB2150	1,132	4.2	
709	298	INGLESIDE CITY	94CS2495	200	3.7	
710	678	LAREDO HEIGHTS	94LA2390	733	3.5	
711	196	MCCOLL ROAD	94SB4910	311	3.4	
712	158	HARLINGEN S.S.	94SB4110	796	3.2	
713	470	HALL ACRES ROAD	94SB4895	795	2.7	
714	656	HIGHWAY 9	94CS9830	139	2.0	
715	700	ZACATE CREEK	94LA2635	262	1.8	
716	613	LAREDO HEIGHTS	94LA9080	679	1.7	
717	48	CAUSEWAY	94SB4775	1,059	1.7	
718	441	ROCKSPRINGS	94LA8040	324	1.5	
719	244	EAGLE PASS CITY	94LA450	680	1.1	
720	718	VICTORIA POWER PLANT	94CNNETVIC	78	-	
721	719	GREGORY	94CS420	22	-	
722	<i>new</i>	NUECES BAY PLANT	94CS7840	45	-	<i>new</i>
723	720	MORRIS STREET	94CSNET CC	339	-	
724	722	WASHINGTON STREET	94LANETLAR	359	-	

Feeders from last year that are not in this year's list

2009 SAIDI Ranking	Substation Identification	Feeder Identification	Reason not in 2010
70	NUECES BAY PLANT	94CS7830	retired

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2010 Reporting Year

Causes of Forced Interruptions	Percentage
Animals and Birds	12.5 %
People (including cars and farm eqpt)	2.9 %
Unknown	8.4 %
Utility-Owned Equipment	47.2 %
Vegetation	17.3 %
Weather (including lightning)	11.7 %
Other	0.0 %