




Control Number: 41089



Item Number: 25

Addendum StartPage: 0

| Utility's<br>Project<br>Number | Project Name  | Location (City/County) | Description                                                | Estimated for<br>Construction<br>Start Date | Final Date<br>Construction<br>Completed | Date<br>Engineer<br>Applied | Initial Estimated<br>Project Cost (\$) | Final Actual<br>Project Cost (\$) | Percent<br>Complete, % | Ending<br>Voltage<br>KV | Upgraded or<br>New Voltage<br>KV | Gross<br>Length<br>Feet | Conductor Type<br>& Size &<br>Spacing | Structure Type           | Ending<br>ROW Width<br>(Feet) | Ending ROW<br>Length (Feet) | New ROW<br>Width<br>(Feet) | New ROW<br>Length<br>(Feet) | Rule Section or PUC<br>Control Number | Comments                   |
|--------------------------------|---------------|------------------------|------------------------------------------------------------|---------------------------------------------|-----------------------------------------|-----------------------------|----------------------------------------|-----------------------------------|------------------------|-------------------------|----------------------------------|-------------------------|---------------------------------------|--------------------------|-------------------------------|-----------------------------|----------------------------|-----------------------------|---------------------------------------|----------------------------|
| 130188                         | Trinity 10-20 | Kaufman                | Transmission line to feed the new 10-20 substation<br>site | 07/13/12                                    |                                         |                             | 2,705,221                              |                                   | 0%                     | na                      | 138                              | 3.45                    | 795-LDM-ACSR<br>207' Spacing          | TU-LDC Double<br>Circuit |                               |                             | 100                        | 3.45                        | 31442                                 | ROW acquisition in process |

2013 FEB 14 PM 12:43

25