

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1628	169	LOMAL	0011	1123	44.71
1629	2171	DESHR	1206	2167	44.48
1630	355	IRVNR	1551	1346	44.36
1631	1375	CLBNR	1404	1337	44.36
1632	1192	WNRTH	1420	1140	44.34
1633	755	BRCRK	6524	785	44.28
1634	49	WDGWD	1581	656	44.20
1635	1737	DGNST	0008	637	44.20
1636	1202	BDFWD	8912	999	44.20
1637	1495	BNDRA	0004	729	44.08
1638	851	AMLIA	0007	89	43.99
1639	1932	TYEST	1509	387	43.94
1640	1691	DAVIS	3752	503	43.92
1641	622	TMSTH	1404	1318	43.90
1642	796	RECCR	0006	540	43.90
1643	1291	PRSTN	0004	671	43.85
1644	2693	FORSN	5621	40	43.77
1645	307	ALLNC	6412	2357	43.76
1646	1478	MNWLL	1203	637	43.68
1647	1060	PCOIT	1006	1039	43.67
1648	500	WTAUG	4641	565	43.63
1649	485	WSOTH	1018	1285	43.55
1650	2174	MEXIA	4011	1036	43.55
1651	318	RDMLL	2552	276	43.51
1652	2015	PNTGO	7112	741	43.40
1653	787	CHICG	1402	534	43.39
1654	203	RKCRK	6111	2136	43.33
1655	888	FARON	4052	1082	43.33
1656	1570	ARMST	0003	362	43.29
1657	1612	DUVAL	0462	999	43.25
1658	2301	SMFLD	2322	41	43.19
1659	245	KNEDL	6321	2348	43.12
1660	1369	FINKS	1804	2307	42.97
1661	1746	CRLJL	1506	1940	42.94
1662	2390	BSPRG	1905	1580	42.93
1663	2555	RGLRW	0006	32	42.88
1664	234	VESTS	3111	59	42.85
1665	1090	PLKST	0006	798	42.80
1666	1504	HKHTS	1604	872	42.75
1667	979	JSHUA	1302	1300	42.75
1668	418	MURPH	2753	675	42.74
1669	1615	LOMAL	0009	1024	42.72
1670	1787	ATHNS	1202	777	42.71
1671	884	PLKST	0003	1915	42.64
1672	2007	FARON	4041	998	42.64
1673	1794	MESQN	1502	1095	42.61
1674	2086	WHTRK	0006	1271	42.58
1675	2821	EMPCT	0005	66	42.57

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1676	1126	CRLTN	1405	1247	42.44
1677	2450	PALRD	2205	323	42.44
1678	1785	IRVGS	1905	755	42.33
1679	2627	PLANO	1105	141	42.30
1680	320	PGSTH	7021	46	42.25
1681	1471	GODRD	8132	2457	42.15
1682	798	RCHRD	1208	1068	42.11
1683	1771	PPARK	1806	837	42.10
1684	2603	VANAL	2412	2761	42.08
1685	1984	PPARK	1807	892	42.03
1686	928	RRNES	2403	4620	42.01
1687	1388	GLNHV	3953	928	42.01
1688	1070	IRVNR	1557	3408	42.01
1689	1213	PLGRV	0004	1646	41.93
1690	2853	MDDTN	4322	26	41.93
1691	2681	HRSMD	1953	391	41.90
1692	2525	WDCR	0241	711	41.90
1693	1224	DNISN	1204	1250	41.85
1694	2449	MESTE	1209	1442	41.73
1695	754	ENNIS	1903	1348	41.71
1696	1702	CNTRY	2811	2515	41.62
1697	765	ARTHR	0431	467	41.49
1698	129	SSPNG	1201	1315	41.46
1699	2855	MLFRD	2101	849	41.30
1700	2585	RDRSE	2602	3064	41.25
1701	965	LOMAL	0015	177	41.23
1702	1248	CPRCV	1402	1887	41.03
1703	2428	WELCH	4911	23	41.00
1704	177	FRMBG	1707	423	40.93
1705	1720	LKHLD	0007	1218	40.90
1706	2658	KLNSO	4501	3191	40.81
1707	740	EULES	8731	1426	40.77
1708	1534	CRSWS	1402	931	40.70
1709	362	LKMNT	0008	995	40.64
1710	69	GAVSW	0005	1352	40.63
1711	717	ARTHR	0422	1060	40.58
1712	2381	ESTLD	3611	1557	40.48
1713	2476	PCOIT	1002	672	40.34
1714	1053	AYERS	4431	1629	40.28
1715	1432	HORNE	1961	1454	40.26
1716	456	FLRTN	3711	100	39.94
1717	2838	GSTHW	1662	12	39.94
1718	2663	HSKAV	0006	628	39.93
1719	1927	SALSW	3001	1348	39.88
1720	2088	WATCO	2603	2811	39.85
1721	1225	GRMES	0512	1198	39.81
1722	913	IRVNG	1401	1547	39.72
1723	1415	TROYS	1014	1181	39.67

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1724	1946	CPLSO	4322	248	39.67
1725	1934	MESFR	2102	665	39.65
1726	509	DNIWS	1602	1423	39.61
1727	770	FORSW	2051	2681	39.58
1728	1580	CPRCV	1407	2612	39.55
1729	2133	TYBLR	2806	216	39.53
1730	1232	MNFLD	2621	2231	39.52
1731	336	LKMNT	0005	610	39.51
1732	1686	TYRSW	1701	2303	39.40
1733	1178	FHLSW	1311	1298	39.36
1734	850	NPKWY	0005	828	39.35
1735	2618	PLANO	1101	404	39.28
1736	954	DGNST	0007	312	39.27
1737	1320	WCOLO	1319	2009	39.24
1738	1833	LOT69	3024	967	39.21
1739	639	SLBLF	1201	129	38.86
1740	N/A	HUTTO	2742	3316	38.81
1741	2054	PRCRK	0002	2137	38.80
1742	1609	PALRD	2201	785	38.79
1743	2188	ELGIN	1003	1892	38.74
1744	991	LIGSW	1607	1380	38.74
1745	366	MDLNE	0141	625	38.72
1746	1931	PRKRW	3392	1588	38.70
1747	2504	LFSTH	1402	1186	38.62
1748	1366	TRSES	1201	509	38.59
1749	1018	CLYVL	9312	1265	38.59
1750	2130	RCHHL	0374	551	38.56
1751	2271	WWEST	1216	256	38.48
1752	1884	PLSTH	1305	851	38.40
1753	2349	FRNKF	0001	947	38.39
1754	702	ALNTH	2832	1025	38.38
1755	1298	RBNSN	2502	1182	38.32
1756	1336	GVODS	3011	2291	38.24
1757	2050	NMAIN	0211	1895	38.13
1758	468	WHTRK	0008	1504	38.11
1759	445	BNTDR	0002	1660	38.08
1760	2501	MKNNY	1201	1342	37.96
1761	1338	LOT69	3023	899	37.95
1762	1800	WDGWD	1592	1131	37.95
1763	1643	FROKS	0002	1294	37.91
1764	2393	GODRD	8171	838	37.90
1765	13	ALVRD	1501	1176	37.75
1766	198	CLCTY	1021	676	37.73
1767	776	FRMBR	1805	752	37.68
1768	1168	TMPNW	1104	1928	37.64
1769	621	WWDWY	2015	1142	37.59
1770	454	AZLES	2111	3011	37.56
1771	820	NHNSW	0008	578	37.41

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1772	1881	PCOIT	1004	733	37.39
1773	480	ITSCA	1701	731	37.33
1774	19	LOMAL	0003	1125	37.32
1775	2144	BLTON	1805	1530	37.08
1776	633	ELCTR	1221	128	37.07
1777	346	KYSTN	1021	43	37.06
1778	1105	CRTLD	4734	779	37.05
1779	968	GLNHV	3963	1598	37.01
1780	1727	MESQT	1306	970	36.99
1781	1627	WHTRK	0007	1238	36.96
1782	167	DESHR	1203	1319	36.94
1783	1969	PRSTN	0003	2962	36.92
1784	1222	SNYDR	1813	288	36.80
1785	1138	KFMNW	1202	855	36.78
1786	1506	KLNPS	1102	1884	36.75
1787	1273	WHITE	3521	1050	36.71
1788	219	EULSO	9121	121	36.70
1789	805	DENAV	0642	918	36.69
1790	1413	ROLTR	2911	1811	36.64
1791	2526	HLSBR	1203	1144	36.58
1792	619	IRVNG	1402	1120	36.52
1793	1886	MNSTR	1201	680	36.52
1794	609	DALRK	1309	835	36.38
1795	2713	REGST	0002	169	36.37
1796	1689	GODRD	8141	870	36.36
1797	1368	SALSW	3003	651	36.32
1798	2661	HKBRY	1107	43	36.14
1799	73	CKRHL	0005	1217	36.13
1800	1536	TAYLR	1204	1526	36.06
1801	354	MLFRD	2103	1001	35.99
1802	1364	IRVGS	1906	730	35.95
1803	2038	DALWT	2972	235	35.94
1804	1716	BRCRK	6522	2195	35.94
1805	618	DAVIS	3772	1736	35.87
1806	1379	DALRK	1326	2675	35.87
1807	2613	CLBNR	1406	111	35.83
1808	1554	MKNGB	5331	1716	35.81
1809	2382	HUBRD	1401	898	35.73
1810	2690	PRCTR	1601	201	35.73
1811	1456	KRUMS	1203	1768	35.56
1812	438	RENSW	3124	1695	35.54
1813	2430	PFFRD	3472	1267	35.51
1814	2280	LWSNR	2231	782	35.45
1815	1150	HLSES	0561	1779	35.44
1816	1918	MESQW	1804	1276	35.36
1817	419	GRDPR	0811	1191	35.28
1818	2629	RRWES	1603	11	35.23
1819	1179	ADMDS	6521	1539	35.22

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1820	1917	BSPRW	2532	1654	35.15
1821	934	MESQT	1303	815	35.11
1822	2045	RWDHV	1903	1134	35.11
1823	2632	TMNTH	1604	49	35.08
1824	580	ARMST	0005	1527	35.07
1825	1469	CPRCV	1406	1632	35.06
1826	769	SHNRW	1614	855	34.99
1827	2027	EDGCF	2272	1030	34.98
1828	312	WMRLD	0006	576	34.86
1829	995	BRHLW	7612	693	34.85
1830	1420	IRVBL	2504	1577	34.84
1831	1532	BRTRD	7312	2817	34.79
1832	2589	ARTHR	0481	1279	34.78
1833	2044	GPLND	1202	408	34.78
1834	1973	BRNSO	1805	761	34.78
1835	413	CPRCV	1405	1524	34.77
1836	2730	CRNSO	3913	1517	34.72
1837	2021	BMTWN	1621	1368	34.70
1838	246	TYOMN	1410	1407	34.69
1839	1623	LAVON	1401	1757	34.68
1840	2748	WCOLO	1318	1639	34.64
1841	1398	SORCY	0001	2535	34.63
1842	2087	CRLTR	2007	1377	34.61
1843	2030	ACRLY	1711	163	34.54
1844	2478	WALNT	0001	1486	34.48
1845	924	ELCTR	1211	292	34.48
1846	241	CMPWI	0004	1596	34.46
1847	1049	LFSTH	1404	493	34.29
1848	1846	IRVND	1206	107	34.22
1849	655	CRLFR	2157	2413	34.19
1850	1134	MSHLN	0002	609	34.19
1851	1071	GORMN	0421	353	34.18
1852	1399	BOWEN	3181	750	34.16
1853	999	EULES	8713	1561	34.13
1854	103	DUVAL	0441	1007	34.12
1855	859	HLSES	0542	762	34.00
1856	1545	DESPR	1408	1843	33.96
1857	478	PEGAS	2321	132	33.89
1858	2209	GRDPR	0881	2073	33.86
1859	2714	COTRD	0003	30	33.85
1860	2069	ODESA	0272	1644	33.80
1861	1926	CRNTH	2406	1221	33.75
1862	1394	GVODS	3031	1378	33.68
1863	2340	WDCR	0232	642	33.63
1864	455	ROSCO	2921	217	33.52
1865	1313	LGVST	8521	1628	33.48
1866	1195	BRLSN	2062	2860	33.41
1867	1518	PSHIL	1608	1933	33.35

## Service Quality Report to the Public Utility Commission of Texas

### Oncor Electric Delivery

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
1868	600	AIRPK	8411	808	33.32
1869	1945	PLANO	1103	1582	33.14
1870	1880	CRLUD	1303	995	33.12
1871	858	EDGCF	2211	2105	33.08
1872	994	TEGMN	3038	1714	33.07
1873	2697	WXNTH	2301	1299	33.03
1874	1555	MESQT	1305	1144	33.03
1875	1970	STHRL	0007	288	33.02
1876	2096	CHROW	0008	86	33.00
1877	206	LMBLN	0003	171	32.94
1878	1171	KLNTF	1804	1006	32.93
1879	2139	KLNPS	1105	1595	32.86
1880	1075	MDWCK	0005	1385	32.83
1881	2592	GRHWY	5511	1860	32.80
1882	55	MCHSN	1201	246	32.79
1883	910	PSHIL	1603	1523	32.76
1884	2283	PFFRD	3492	300	32.74
1885	1684	WTAUG	4643	982	32.72
1886	2392	MESTE	1207	942	32.71
1887	2308	MESQT	1301	1428	32.71
1888	2483	MDLNW	1531	1261	32.68
1889	2353	MDLNE	0163	1037	32.58
1890	1276	OKLND	0002	1179	32.56
1891	329	OAKHL	3041	911	32.52
1892	1813	CRLFR	2154	3436	32.40
1893	2508	CMNCH	1401	1159	32.36
1894	370	LOMAL	0001	676	32.34
1895	1740	CLYVL	9322	2138	32.30
1896	2547	WTAUG	4622	968	32.28
1897	107	BRIRV	6911	3251	32.20
1898	854	PPARK	1802	606	32.18
1899	919	FSCRK	6721	3611	32.16
1900	849	ALPHA	0014	643	32.14
1901	242	ROWLT	1105	1062	32.09
1902	75	BRGPR	1102	1320	32.06
1903	2235	CRTLD	4721	3018	32.06
1904	1517	RDLML	2561	833	32.03
1905	N/A	WFALS	0124	125	32.00
1906	176	TMPLE	1202	1389	31.98
1907	2741	MESQT	1302	647	31.98
1908	343	CRNTH	2401	2326	31.95
1909	645	CURIE	7221	829	31.94
1910	2143	DAVST	0008	13	31.94
1911	97	ECTOR	1201	384	31.88
1912	442	GVFTW	1801	641	31.82
1913	446	MURPH	2756	3162	31.79
1914	1709	LKHLD	0003	1350	31.60
1915	1858	LKHLD	0006	738	31.55

## Service Quality Report to the Public Utility Commission of Texas

### Oncor Electric Delivery

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
1916	695	LIGSW	1603	2509	31.54
1917	532	LGVST	8522	350	31.52
1918	2214	RNDRK	1501	690	31.51
1919	2744	TYSTH	1208	306	31.37
1920	819	RCHHL	0332	1630	31.32
1921	2084	WEAST	0629	1798	31.23
1922	2784	RWDHV	1905	1207	31.16
1923	1346	DNISN	1205	1497	31.15
1924	472	HLSES	0522	1625	31.09
1925	2674	MAPLE	0001	671	31.08
1926	1736	HMTRD	0001	953	31.07
1927	1568	SORCY	0004	590	30.99
1928	1466	CLBNR	1402	2399	30.98
1929	132	BRKRG	0242	20	30.94
1930	672	BLTSW	3201	2560	30.92
1931	1267	COMSO	1401	626	30.92
1932	2438	FSTVW	0003	1915	30.87
1933	473	CMTSW	0925	1370	30.87
1934	443	HKHTS	1603	1043	30.85
1935	2488	ARMST	0011	888	30.82
1936	1221	WNRTH	1421	1464	30.79
1937	782	LWSNR	2241	1079	30.75
1938	553	MLKF2	1201	1733	30.71
1939	1789	TRNTH	1503	1747	30.70
1940	2159	DFWSW	2202	41	30.59
1941	1923	ROWLT	1101	1257	30.59
1942	139	HKBRY	1117	132	30.58
1943	1459	RCLNS	1407	1382	30.56
1944	2094	WWDWY	2020	1229	30.48
1945	841	BONHM	1206	2106	30.44
1946	328	MAPLE	0006	1561	30.35
1947	209	SBEND	0611	160	30.32
1948	2877	SHSTH	1302	19	30.21
1949	2126	RRNES	2404	4447	30.21
1950	2557	PLSTH	1303	568	30.21
1951	1614	WWEST	1219	940	30.20
1952	2258	PWEST	1304	1281	30.17
1953	729	HDWLK	3001	934	30.13
1954	1814	SYCRK	4521	3601	30.08
1955	35	SCSES	1201	281	30.07
1956	2177	SNYDR	1833	1424	30.04
1957	1160	RCHHL	0353	1728	29.94
1958	1468	SANSM	3912	4958	29.81
1959	2032	ODNTH	2024	2698	29.80
1960	2707	KNEDL	6332	2163	29.79
1961	2346	AMMFG	5611	807	29.78
1962	1059	WDCR	0211	1226	29.77
1963	2049	HURST	1822	1477	29.68

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
1964	87	CHALK	0951	76	29.66
1965	2039	KLNCC	1703	5217	29.63
1966	2009	IRVGS	1908	934	29.55
1967	170	PRKRW	3352	1468	29.50
1968	2583	DFWSW	2207	23	29.47
1969	2484	CLCRK	1011	192	29.44
1970	2184	CNSES	3054	1932	29.31
1971	2391	TAYLR	1203	1832	29.27
1972	2064	FORSW	2025	775	29.21
1973	2457	WATSN	5372	1339	29.20
1974	1990	BLMED	1617	310	29.18
1975	2698	GAVSW	0004	830	29.02
1976	1675	TERSO	2503	1585	28.97
1977	2295	HUTTO	2711	2288	28.90
1978	185	SCHRD	0001	1434	28.86
1979	2035	SPRDL	4821	1333	28.81
1980	923	MDLNW	1513	2026	28.79
1981	2129	CRLTN	1401	798	28.77
1982	435	RSPCK	2104	1780	28.75
1983	284	LVOAK	1602	861	28.75
1984	359	WXHNW	2901	180	28.72
1985	1935	SHNRW	1608	1431	28.68
1986	N/A	ALNTH	2851	2093	28.65
1987	393	BRTRD	7311	1247	28.59
1988	1726	PRSTN	0008	779	28.53
1989	217	RSNHT	1181	1679	28.41
1990	N/A	MRSDO	9611	1242	28.41
1991	2647	KLNSO	4502	2399	28.36
1992	523	CHROW	0001	136	28.30
1993	2758	RGFTW	6813	18	28.26
1994	964	RHOME	2402	1242	28.26
1995	952	CRLUD	1305	1354	28.24
1996	852	MCKMY	0821	1688	28.15
1997	1110	BRCRK	6533	1790	28.12
1998	1868	LOMAL	0002	503	28.07
1999	1349	CRNTH	2405	3772	28.02
2000	1564	MESQN	1503	1864	27.95
2001	1775	MESQW	1807	1503	27.91
2002	N/A	MRSDO	9621	13	27.89
2003	570	ATHNW	1404	1600	27.86
2004	2398	GLNHV	3973	1342	27.83
2005	1799	SCHRD	0004	1888	27.68
2006	2131	MEXIA	4012	1157	27.65
2007	548	GRHWY	5521	872	27.64
2008	2052	ITALY	2101	554	27.55
2009	94	LOMAL	0013	1022	27.51
2010	1314	RYSSW	2801	1954	27.47
2011	925	ARLNG	1241	626	27.44



## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2012	1437	WKATY	1718	2143	27.40
2013	2060	DGNST	0003	22	27.40
2014	269	GAVSW	0012	882	27.35
2015	36	WBROK	3021	56	27.33
2016	707	MESFR	2104	158	27.33
2017	1435	PCUST	2012	1816	27.32
2018	2509	ARMST	0008	238	27.30
2019	1875	KLNPS	1101	2288	27.26
2020	971	CRLTR	2003	1335	27.09
2021	1748	CHROW	0007	86	27.08
2022	2158	MCGHR	2003	1261	27.00
2023	2864	PKRMX	4703	2825	26.99
2024	2556	GAVSW	0001	1088	26.98
2025	2342	GAVSW	0002	969	26.96
2026	1389	BOWEN	3122	1271	26.91
2027	2357	FORSW	2053	3051	26.90
2028	1588	CMNCH	1402	1182	26.89
2029	171	PKRVL	1053	1020	26.84
2030	1561	HMPHL	2743	714	26.80
2031	1739	SMFLD	2392	1022	26.77
2032	2529	FRMNT	0009	1650	26.75
2033	2248	HURST	1882	1874	26.69
2034	2498	LMBLN	0004	46	26.65
2035	1099	HUDSN	1605	137	26.62
2036	2848	KRGRV	2401	12	26.62
2037	526	BRHLW	7651	1106	26.61
2038	2721	MESTE	1203	171	26.59
2039	2224	HLTOM	2411	1418	26.59
2040	1350	LWSNR	2232	2378	26.55
2041	592	PSHIL	1602	1030	26.54
2042	2579	SYCRK	4511	1939	26.51
2043	2776	INAIR	1414	767	26.44
2044	821	TYBLR	2805	1941	26.43
2045	2367	CMTSW	0962	601	26.43
2046	1100	WBOSE	1102	348	26.43
2047	2121	ALPHA	0007	1445	26.40
2048	1501	VLYRN	2957	506	26.38
2049	1769	WWDWD	3611	1096	26.35
2050	2320	MCDMT	2531	2432	26.35
2051	1611	BNTDR	0004	1664	26.33
2052	2419	TYOMN	1411	277	26.32
2053	1824	MNHNS	1921	1819	26.31
2054	516	NSTAR	2011	526	26.27
2055	2620	PRKWY	1561	1703	26.16
2056	2263	ALVDO	1902	873	26.14
2057	2345	IRLBJ	3231	2188	26.10
2058	2278	WWEST	1218	995	26.09
2059	221	LAVON	1452	1783	26.02

## Service Quality Report to the Public Utility Commission of Texas

### Oncor Electric Delivery

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
2060	1577	BOWEN	3112	893	26.02
2061	626	GNSVL	1203	1612	25.97
2062	2373	BRNSO	1808	771	25.96
2063	1539	COMRC	1204	602	25.89
2064	1776	BLTON	1802	1380	25.86
2065	310	LGVST	8511	750	25.81
2066	2885	WEAST	0620	2465	25.74
2067	1915	EULSO	9132	1085	25.74
2068	948	BMTWN	1611	1741	25.68
2069	253	PRSTN	0006	673	25.52
2070	1723	KLNTF	1801	1191	25.48
2071	1357	WCOLO	1316	2057	25.47
2072	775	LMESA	1512	639	25.46
2073	1385	TMSTH	1401	1821	25.45
2074	2344	STNVL	1201	2235	25.39
2075	2269	ROLTR	2922	2390	25.39
2076	802	PRSTN	0002	1330	25.38
2077	1286	BRCRK	6513	1146	25.36
2078	856	HHSTH	1502	3016	25.30
2079	827	MLDR2	1605	846	25.25
2080	741	AMMFG	5631	1377	24.94
2081	2151	MESTE	1211	1178	24.94
2082	1730	CPRCV	1403	1430	24.94
2083	1919	ROWLT	1106	1303	24.94
2084	1505	JUDCT	0008	135	24.90
2085	1551	CLBRN	1201	1772	24.89
2086	2549	MLKF2	1202	467	24.84
2087	1475	WEBBS	8622	1580	24.84
2088	53	FSCRK	6732	3190	24.82
2089	698	GNSVL	1223	1028	24.77
2090	896	SPRDL	4812	1225	24.76
2091	409	RRSTH	1705	131	24.74
2092	2202	KFMNW	1201	1021	24.72
2093	1299	CKRHL	0006	250	24.72
2094	1339	DAVIS	3762	41	24.61
2095	882	SWDTN	1631	1531	24.55
2096	1047	ENNIS	1904	1256	24.53
2097	1234	GRSMN	4028	704	24.42
2098	2332	RTHGB	1411	2195	24.34
2099	2089	CMTSW	0973	1159	24.33
2100	1960	DNINR	1403	1200	24.17
2101	2548	RGLRW	0004	79	23.98
2102	2275	RSPVY	1706	1342	23.95
2103	1910	DGNST	0002	494	23.86
2104	2753	LEMON	0008	762	23.79
2105	490	WWDWY	2022	1010	23.78
2106	540	CRTLD	4724	3164	23.77
2107	1929	LKWOD	7432	1603	23.75

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2108	1391	PRNTH	1406	1094	23.70
2109	912	BRHLW	7631	709	23.69
2110	2122	MABNK	2401	2075	23.67
2111	2327	WFALS	0153	1160	23.63
2112	2503	FROKS	0006	990	23.62
2113	2083	SHRSW	6641	992	23.61
2114	2245	MKNSO	3613	3201	23.55
2115	140	WHITE	3522	1724	23.50
2116	1145	WNTHW	1116	649	23.42
2117	1019	ROANW	9521	1419	23.39
2118	466	BNMAG	1201	187	23.33
2119	691	GNSVE	1602	1712	23.23
2120	2279	MRVLY	2311	377	23.22
2121	2150	MKNSW	2602	3427	23.21
2122	795	SLAKE	8321	3446	23.19
2123	1096	TRLWD	7722	3864	23.19
2124	2099	VGCRK	8011	1497	23.18
2125	2514	THRNE	0008	2183	23.17
2126	1384	MDWPK	9241	1360	23.15
2127	1842	REAST	1504	1316	23.12
2128	804	BLKST	1721	1011	23.09
2129	737	PCUST	2010	2257	23.05
2130	1949	CNTRD	0004	1105	23.05
2131	1630	DAVIS	3721	1318	23.02
2132	1651	LMESA	1531	1205	23.00
2133	195	KILEN	1203	714	22.99
2134	615	PRKWY	1542	478	22.99
2135	N/A	WFALS	0143	181	22.98
2136	1815	WFALS	0174	1261	22.92
2137	2322	PWEST	1307	945	22.90
2138	636	PSHIL	1604	1154	22.87
2139	1436	WSANG	2802	634	22.86
2140	2104	PRKWY	1552	535	22.77
2141	N/A	NOLNW	2111	24	22.74
2142	510	FRMBR	1806	148	22.72
2143	2246	RRSTH	1701	2809	22.72
2144	812	RTHGB	1421	1642	22.70
2145	2480	MDLNE	0133	2543	22.69
2146	2773	BSPRG	1901	582	22.69
2147	2863	PKRMX	4701	1726	22.67
2148	2550	SWTWR	1362	10	22.65
2149	18	LKTMS	2411	112	22.64
2150	642	NHNSW	0003	525	22.60
2151	85	WELRD	0006	736	22.56
2152	2580	WITTS	1701	1889	22.55
2153	1245	CRYVE	3021	1269	22.54
2154	2350	BSPRG	1902	2357	22.48
2155	1001	EGFRD	0004	1828	22.46

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2156	1109	WSOTH	1021	2073	22.44
2157	578	BNMNW	1101	198	22.42
2158	1191	RWALL	1204	1138	22.40
2159	1000	THRNE	0001	1762	22.39
2160	420	LVOAK	1601	823	22.37
2161	1989	WMMMR	2707	1530	22.36
2162	1250	NYLDV	1202	136	22.33
2163	1596	SNYDR	1822	1625	22.33
2164	1473	SCYEN	0004	1200	22.31
2165	2626	RRSTH	1707	582	22.23
2166	1722	MRDCK	0002	1399	22.23
2167	2736	FROKS	0008	1496	22.17
2168	1038	MKNSW	2601	3050	22.14
2169	2475	KLELM	2204	2955	22.09
2170	628	BLMND	3262	124	22.08
2171	2541	RSPCK	2131	57	22.05
2172	1114	DCATR	1203	846	21.99
2173	2668	TRLSW	1204	572	21.97
2174	1905	SWTWR	1382	448	21.90
2175	970	GNSVE	1603	1687	21.89
2176	1278	PLKST	0004	1063	21.88
2177	2766	ALPHA	0011	1155	21.82
2178	2024	WFALS	0133	1646	21.79
2179	2343	MNWLL	1205	438	21.69
2180	1660	PALRD	2208	1076	21.69
2181	1928	RRNES	2401	4100	21.66
2182	1750	RCHRD	1203	838	21.61
2183	1751	CMTSW	0941	1002	21.59
2184	441	RHOME	2401	1118	21.58
2185	1625	MDLNW	1511	2393	21.57
2186	550	HMPHL	2772	276	21.54
2187	1258	KLNTF	1805	1236	21.53
2188	2296	HRSMD	1951	4435	21.41
2189	568	BRNWD	1202	442	21.33
2190	1189	RCHHL	0342	994	21.32
2191	1788	FARON	4082	1571	21.30
2192	N/A	MDLNW	1564	1270	21.29
2193	1282	PARIS	1206	996	21.25
2194	2716	ABRRD	0003	330	21.14
2195	2431	OAKHL	3021	1905	21.08
2196	1721	FRNKF	0005	1642	21.02
2197	1272	SMFLD	2311	993	20.97
2198	489	WSTHL	3621	4669	20.94
2199	2460	SSPNE	1402	68	20.92
2200	2117	CDHIL	1802	824	20.91
2201	1017	WBOSE	1103	875	20.83
2202	233	BRNAV	0732	751	20.79
2203	2638	HKBRY	1109	81	20.70

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2204	1819	SHMNE	1405	784	20.70
2205	2621	CLCTY	1031	1242	20.68
2206	2560	TYLGE	1314	833	20.43
2207	2546	MDLNE	0122	261	20.39
2208	1165	POYNR	1201	342	20.38
2209	2400	JUDCT	0006	1182	20.34
2210	1997	SHAMP	0003	1721	20.30
2211	848	RWDHV	1906	636	20.27
2212	1690	GNSVL	1205	883	20.24
2213	469	TMNTH	1602	512	20.22
2214	2286	WTAUG	4632	1247	20.18
2215	1678	CRSCN	1202	616	20.18
2216	686	RCHRD	1207	1534	20.16
2217	66	MESTE	1215	1499	20.13
2218	496	IRVND	1204	1352	20.12
2219	2359	HORNE	1932	1097	20.09
2220	1871	OAKHL	3082	1387	20.05
2221	1454	TMPLE	1201	348	20.04
2222	2062	KLNPS	1104	1364	20.02
2223	701	RSPVY	1702	530	20.02
2224	1209	TYOMN	1405	1664	19.97
2225	373	GLNHV	3931	1327	19.97
2226	879	TMNTH	1605	1727	19.94
2227	2642	PRKRW	3331	112	19.93
2228	1255	FRNKF	0007	1173	19.88
2229	1587	GRPVN	8223	2029	19.82
2230	1641	MESQW	1802	799	19.74
2231	344	WXHCH	1204	1696	19.73
2232	321	TMSTH	1408	752	19.66
2233	2138	SCHRD	0007	1378	19.66
2234	1307	LOMAL	0005	401	19.62
2235	2659	PTENN	2354	2579	19.60
2236	2772	WTAUG	4651	517	19.57
2237	944	PWEST	1311	816	19.53
2238	1117	HNYGR	2402	162	19.50
2239	2464	GRLRD	0001	1763	19.49
2240	658	LOMAL	0008	460	19.39
2241	2002	PSHIL	1601	1403	19.38
2242	226	SWTWR	1321	130	19.36
2243	763	OKLND	0003	1306	19.35
2244	358	GNSVN	1403	282	19.34
2245	2172	BRYAN	0002	220	19.31
2246	403	CNEXP	0002	848	19.25
2247	2312	WRTHM	5012	318	19.22
2248	1982	PKRVL	1054	2332	19.21
2249	1396	HKHTS	1607	953	19.17
2250	59	LOMAL	0006	1435	19.12
2251	2287	PNTGO	7122	1095	19.12

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2252	2352	HSKAV	0004	1250	19.12
2253	1679	PROAD	0002	830	19.11
2254	1216	BLMGR	1902	185	19.05
2255	1966	EDDYS	0710	648	19.02
2256	2163	GSTHW	1633	972	19.01
2257	316	IVANS	1612	1040	19.00
2258	865	BSPRW	2511	744	18.97
2259	1784	WDGWD	1591	1154	18.93
2260	1959	SMFLD	2343	740	18.87
2261	2634	CRNRD	0006	314	18.85
2262	2212	WALST	0009	737	18.79
2263	2335	CNTRD	0001	2080	18.79
2264	1558	SPRDL	4841	930	18.78
2265	493	SCYEN	0002	1870	18.76
2266	2802	BNDRA	0005	1218	18.69
2267	2114	LKBLT	2105	1848	18.64
2268	1500	MAYFD	5521	3196	18.63
2269	920	ANARN	1911	18	18.63
2270	1123	SHNRW	1610	423	18.61
2271	2631	WDGWD	1523	309	18.58
2272	2812	CURIE	7212	13	18.57
2273	1804	MEXIA	3016	276	18.46
2274	1634	NCSFA	1702	1169	18.42
2275	1447	CRNTH	2404	2180	18.41
2276	2628	RDRSE	2603	3640	18.35
2277	1028	VLYRN	2951	2202	18.33
2278	1906	VLYRN	2953	2822	18.32
2279	1563	DUVAL	0473	1524	18.29
2280	349	MNWLL	1204	284	18.27
2281	1767	WDGWD	1572	1466	18.27
2282	1443	MRLNS	4002	424	18.17
2283	1034	RDMLL	2591	1516	18.12
2284	197	OAKCK	2211	38	18.10
2285	2092	SHMNE	1403	985	18.08
2286	2168	BRYAN	0005	3225	18.07
2287	2700	JNKNS	0003	1038	18.00
2288	1760	PRFTW	4222	3209	17.98
2289	2254	SIKES	2411	2034	17.94
2290	1303	WSOTH	1017	1758	17.93
2291	799	IRVNR	1553	1328	17.92
2292	72	RDMLL	2581	1228	17.91
2293	2752	GAVSW	0008	118	17.89
2294	2358	BLTON	1801	891	17.88
2295	514	PRFTW	4212	2005	17.87
2296	2388	BRNSO	1806	2055	17.82
2297	862	WDGWD	1552	316	17.73
2298	1483	TRSES	1202	503	17.73
2299	2521	WTAUG	4642	1292	17.63

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2300	2285	BRHLW	7622	1133	17.62
2301	158	HLTOM	2442	1081	17.53
2302	757	NLNVL	2001	362	17.53
2303	988	MSTLT	1042	243	17.49
2304	2472	MTLDA	0005	1565	17.46
2305	2372	GAVSW	0009	1024	17.46
2306	1552	CRLUD	1304	1388	17.38
2307	2081	ODESA	0231	2164	17.38
2308	822	WEBBS	8621	2639	17.29
2309	758	BRNWD	1204	1796	17.29
2310	145	CLKVL	1203	614	17.28
2311	1479	PARIS	1204	1180	17.26
2312	1428	WTAUG	4633	989	17.24
2313	899	CTYVW	2212	142	17.23
2314	2324	DNISN	1206	912	17.15
2315	1873	MURPH	2755	2677	17.15
2316	2256	ENNIS	1901	355	17.10
2317	1280	KNAPP	4021	42	17.06
2318	728	IVANS	1621	53	17.03
2319	1549	ROBNW	1503	1594	17.03
2320	2410	BLTLN	0004	657	17.03
2321	1031	HOLDY	0921	607	17.02
2322	1262	MNWLL	1207	2005	16.99
2323	2572	ECTHM	3331	22	16.91
2324	1925	KLBRG	0003	1248	16.82
2325	2288	CRSCN	1201	814	16.82
2326	1958	MEANS	4421	62	16.79
2327	2351	TYBLR	2802	992	16.75
2328	2729	KNLTR	0011	218	16.75
2329	1383	GRAHM	0713	425	16.73
2330	1319	GRSMN	4029	988	16.71
2331	2474	JNKNS	0005	550	16.65
2332	1818	MCKMY	0812	125	16.64
2333	2423	CRLJL	1508	326	16.48
2334	837	IRVBL	2501	392	16.43
2335	1283	MKNNY	1203	1059	16.37
2336	955	PPARK	1803	1064	16.37
2337	213	WOVER	6111	1691	16.32
2338	935	MDLNW	1532	2152	16.28
2339	179	WBROK	3011	190	16.24
2340	958	MSLSW	0008	167	16.23
2341	2835	GNSVN	1401	26	16.17
2342	903	RBNSN	2504	1593	16.16
2343	1405	CRSWS	1403	1888	16.09
2344	2540	LIPAN	1301	509	16.09
2345	1586	DUVAL	0452	1801	16.07
2346	1944	SPRTN	1801	1748	16.07
2347	2185	HHSTH	1501	3532	16.02

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2348	2057	PLKST	0001	633	16.01
2349	223	MDTHS	1001	1293	15.98
2350	118	GNSVL	1213	722	15.97
2351	1015	WALST	0007	27	15.96
2352	2077	RWALL	1201	1175	15.94
2353	1259	BRNWD	1201	1524	15.89
2354	1738	LOMAL	0016	653	15.88
2355	981	BRNAV	0723	1302	15.88
2356	905	TMPSE	1501	1512	15.87
2357	1005	DCATR	1204	646	15.85
2358	1971	SMFLD	2352	596	15.85
2359	1676	GRFRD	1002	374	15.83
2360	2615	PFLGV	2005	3647	15.79
2361	2403	COPER	0402	172	15.78
2362	2394	MTLDA	0006	2445	15.72
2363	2149	TMPTV	2404	1382	15.69
2364	786	PCOIT	1005	1096	15.58
2365	1953	PPARK	1804	246	15.57
2366	2070	MSLSW	0005	743	15.57
2367	2113	MDDTN	4321	930	15.55
2368	2461	ATNRN	3412	3305	15.54
2369	1826	MNWLE	1702	1264	15.54
2370	237	RDOAK	1303	1925	15.53
2371	2605	SHMNE	1407	789	15.48
2372	1687	PRKWY	1532	2077	15.46
2373	966	MEXIA	4024	363	15.41
2374	508	PRKRW	3362	1063	15.39
2375	24	RNFLF	8331	12	15.37
2376	1488	WALST	0011	703	15.29
2377	2596	CRNRD	0001	730	15.26
2378	1243	LKHLN	0002	1440	15.20
2379	1913	LKMNT	0004	2148	15.19
2380	2646	EGFRD	0001	1724	15.10
2381	2008	TMPNW	1101	2408	15.09
2382	2134	ENTOH	0008	10	15.06
2383	2135	PCOIT	1007	843	14.99
2384	1598	FSHSW	2121	1711	14.97
2385	1682	MDWPK	9231	2428	14.95
2386	1058	DUBLN	1360	1111	14.90
2387	1311	SUNNY	2301	586	14.90
2388	63	BLTLN	0005	805	14.88
2389	2305	KLRPR	9011	2736	14.88
2390	652	MKNNY	1254	801	14.88
2391	303	MMSLW	0006	101	14.83
2392	1821	SALSW	3004	1277	14.78
2393	277	ARTHR	0462	202	14.72
2394	2013	MNWLW	1402	1554	14.64
2395	1812	THRNE	0004	832	14.63



## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2396	1409	MESTE	1201	22	14.59
2397	2330	CRTLD	4722	3244	14.55
2398	1452	GRAHM	0711	1654	14.51
2399	2369	BLMED	1618	38	14.49
2400	2215	BLSRA	1602	157	14.49
2401	901	SWDTN	1641	1582	14.49
2402	390	BDFWD	8941	1332	14.44
2403	2180	WNDWD	3621	2304	14.43
2404	713	HORNE	1942	1312	14.35
2405	2197	HNRTA	0311	1043	14.33
2406	1323	WRBND	2322	854	14.28
2407	1463	LAVON	1454	2753	14.24
2408	1312	ELMGV	3651	1893	14.21
2409	1616	FHLSW	1332	296	14.15
2410	301	KMPSO	2400	920	14.14
2411	2220	MESQN	1508	1791	14.10
2412	2316	KLELM	2205	3094	14.08
2413	2762	MESQW	1805	76	14.02
2414	1093	ALVRD	1504	156	14.00
2415	2361	RECCR	0005	158	14.00
2416	1897	NVARO	1502	200	13.99
2417	2329	LKBLT	2103	1951	13.97
2418	1516	BRGPR	1101	644	13.94
2419	2261	PWEST	1303	928	13.78
2420	774	RSPCK	2106	346	13.77
2421	2417	WMMMR	2703	1103	13.76
2422	212	WWEST	1220	197	13.71
2423	2259	MRTNS	1503	368	13.69
2424	984	MDWCK	0006	889	13.67
2425	1133	GRPVN	8213	1840	13.64
2426	281	FSCRK	6724	4363	13.61
2427	750	PSHIL	1607	453	13.57
2428	904	KNLTR	0008	898	13.50
2429	1986	KLNTF	1802	847	13.46
2430	266	PCOIT	1022	2127	13.46
2431	2500	PFLGV	2007	2638	13.42
2432	2510	CURIE	7222	345	13.37
2433	299	EMMAS	4021	58	13.34
2434	2437	LVBRD	0001	38	13.33
2435	962	WNRTH	1419	304	13.28
2436	372	ALNTH	2842	1633	13.19
2437	2516	MCDMT	2532	1977	13.17
2438	723	CRTLD	4732	2758	13.17
2439	1823	TMPLE	1206	751	13.14
2440	759	SIKES	2421	1182	13.14
2441	332	PRKWY	1521	2282	13.13
2442	1712	HLSBR	1202	1225	13.11
2443	584	NMAIN	0282	1188	13.08

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2444	2334	EDGCF	2221	744	13.02
2445	2611	FRMBG	1706	61	12.97
2446	1041	CRLTR	2001	2436	12.97
2447	950	LKMNT	0001	188	12.96
2448	953	ODNTH	2033	666	12.94
2449	2567	FRNKF	0006	1719	12.93
2450	1324	WEAST	0616	566	12.87
2451	2645	BKBNT	1842	518	12.86
2452	813	EDDYS	0425	401	12.84
2453	1301	SANSM	3911	1247	12.78
2454	2513	PCOIT	1008	1247	12.74
2455	2339	VANAL	1201	583	12.74
2456	836	ALNTH	2844	1546	12.69
2457	2337	BLMED	1621	2012	12.68
2458	2694	CRNRD	0002	362	12.61
2459	1629	EULES	8732	631	12.56
2460	1086	CMTSW	0915	704	12.52
2461	2233	IRVNR	1552	63	12.50
2462	833	SMFLD	2313	2198	12.47
2463	2317	EMPCT	0008	35	12.46
2464	945	PRKRW	3341	491	12.46
2465	2436	KLNCC	1701	2211	12.43
2466	1547	FRMBR	1808	664	12.42
2467	1741	RRSTH	1708	4080	12.36
2468	2033	MKNSW	1603	1306	12.34
2469	261	PRCRK	0001	194	12.33
2470	2622	LMBLN	0008	117	12.33
2471	601	MSTLT	1011	57	12.21
2472	646	LVBRD	0008	1729	12.20
2473	1714	ROSCO	2911	606	12.19
2474	2566	GSTHW	1692	825	12.19
2475	1891	VLYRN	2955	4454	12.18
2476	1732	BLMED	1620	1944	12.18
2477	188	CRLTN	1404	99	12.15
2478	2297	TMNTH	1601	30	12.13
2479	2462	ABBOT	1902	119	12.09
2480	1698	BLMND	3282	83	12.05
2481	1381	BSPSW	0841	2093	12.02
2482	2641	BRYAN	0001	16	12.02
2483	2590	KLELM	2202	1750	11.97
2484	2016	ALNTH	2854	523	11.94
2485	1632	BSPRG	1904	1646	11.92
2486	2597	TYLER	1001	154	11.91
2487	N/A	LFKHL	2101	117	11.90
2488	560	MSLSW	0007	399	11.83
2489	N/A	HKBRY	1115	13	11.73
2490	1859	TMSTH	1405	516	11.70
2491	2819	DFWSW	2204	22	11.67

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2492	1680	PKRVL	1051	4291	11.64
2493	2607	WNRTH	1416	723	11.43
2494	173	GMINI	5812	769	11.42
2495	1718	RWALE	3326	2592	11.40
2496	2101	ARLNG	1261	1441	11.38
2497	1305	IOWPK	0821	756	11.37
2498	2829	FRMBG	1708	46	11.34
2499	2415	NPKWY	0006	4802	11.28
2500	878	BRNWD	1203	804	11.28
2501	1653	HKHTS	1606	1710	11.22
2502	1329	COPER	1201	321	11.21
2503	1440	RNDRK	1508	3986	11.13
2504	2277	BLTON	1803	421	11.08
2505	2333	STNVL	1205	436	11.07
2506	1902	RWALE	3321	1387	11.01
2507	1027	ELZCK	4922	29	10.97
2508	1968	FRNKF	0003	494	10.94
2509	2796	ARLNG	1212	134	10.92
2510	599	WEAST	0615	340	10.83
2511	574	HMPHL	2721	510	10.76
2512	1087	PRKRW	3321	157	10.66
2513	603	CHROW	0003	150	10.62
2514	1268	ROLTR	2912	3380	10.61
2515	2852	LSCOL	2142	12	10.60
2516	2817	DFWNW	2610	55	10.55
2517	2314	ARLNG	1222	101	10.53
2518	236	MSTLT	1073	191	10.46
2519	2200	SSPNG	1203	1371	10.41
2520	2505	ODESA	0261	1483	10.28
2521	364	CRLTN	1451	208	10.26
2522	607	CRLJL	1502	373	10.19
2523	2808	CPLSO	4311	83	10.19
2524	1541	ARTHR	0452	696	10.13
2525	594	LWRDR	0003	1708	10.10
2526	1529	REAST	1507	113	10.07
2527	N/A	CLLVL	0006	644	10.06
2528	2702	ARMST	0006	867	9.92
2529	2192	FARON	4031	1150	9.92
2530	1194	HOLDY	0911	1166	9.80
2531	1816	CTYVW	2221	1865	9.80
2532	1300	IRVNE	1302	310	9.77
2533	1883	MESFR	2103	360	9.76
2534	2840	HKBRY	1111	25	9.69
2535	2452	BRLSN	2013	1101	9.68
2536	1765	GVODS	3041	1468	9.67
2537	2028	BRKRG	0211	307	9.66
2538	2005	ATNRN	3421	588	9.57
2539	289	TERSO	2501	179	9.48

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2540	2467	CLLVL	0002	500	9.48
2541	2612	BRIRV	6922	3141	9.45
2542	2789	ABBOT	1901	115	9.42
2543	1037	WSANG	2801	1326	9.38
2544	2252	BRKRG	0221	695	9.36
2545	1810	ANDNR	2242	1818	9.31
2546	2299	CRSCN	1205	797	9.29
2547	1728	WOVER	6122	1442	9.27
2548	2175	WEBBS	8611	2589	9.19
2549	1378	HORNE	1991	1436	9.18
2550	1318	DESHR	1208	389	9.18
2551	2584	SHNRW	1612	754	9.17
2552	1140	PALRD	2204	690	9.16
2553	1144	MKNNY	1253	103	9.15
2554	2408	STERT	2702	16	9.13
2555	360	WDCR	0262	248	9.13
2556	494	TMSTH	1407	71	9.12
2557	2338	INAIR	1432	2495	9.05
2558	571	FROKS	0007	1425	9.02
2559	2527	MRSES	3019	13	8.98
2560	2837	GSTHW	1651	12	8.75
2561	2407	WEBBS	8633	1961	8.71
2562	497	WEBBS	8612	3298	8.71
2563	2686	WWEST	1221	21	8.70
2564	1166	ESTLD	3621	1464	8.62
2565	1707	MSTLT	1054	599	8.60
2566	2672	HKHTS	1608	1321	8.59
2567	2386	MCDMT	2551	3593	8.59
2568	1626	BRCRK	6521	1428	8.59
2569	2846	KNLTR	0006	535	8.54
2570	1758	HNYGR	0402	463	8.51
2571	2575	ODESA	0221	279	8.49
2572	1200	RSPVY	1708	973	8.37
2573	1993	CMPST	0002	626	8.26
2574	1112	MSHLN	0007	722	8.24
2575	735	ABRRD	0008	1082	8.17
2576	2617	BLNKT	0701	287	8.14
2577	278	WXHCH	1205	925	8.10
2578	853	ALNSW	2654	1801	8.04
2579	748	IRVHF	2303	83	7.99
2580	2820	DGNST	0004	728	7.98
2581	2587	MNWLW	1401	1561	7.91
2582	2364	RANGR	4321	862	7.90
2583	2798	ATNRN	3422	204	7.90
2584	1111	DENAV	0621	1662	7.86
2585	2004	TMPSE	1503	637	7.79
2586	1664	KLNTF	1803	1056	7.77
2587	2524	HURST	1841	813	7.76

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2588	976	POWEL	2706	242	7.66
2589	228	CNTRD	0003	1328	7.63
2590	1260	GORMN	0411	542	7.61
2591	2141	LAVON	1404	951	7.58
2592	808	WHITE	3511	1347	7.57
2593	2644	DENDR	0009	59	7.53
2594	2630	CMPST	0001	420	7.52
2595	1149	NCSTH	1504	65	7.50
2596	43	MDWCK	0008	887	7.46
2597	2219	BLMGR	1901	265	7.44
2598	288	BNBRK	4112	2165	7.39
2599	172	CRLTN	1454	323	7.37
2600	2455	NPKWY	0013	3720	7.31
2601	565	CLBWS	8112	253	7.29
2602	2491	GRLRD	0002	979	7.28
2603	598	IRLBJ	3211	2561	7.23
2604	2624	KIMBL	5022	875	7.21
2605	151	MRSES	3015	574	7.20
2606	2481	BKBNT	1811	686	7.20
2607	1659	GRMES	0511	1196	7.19
2608	1939	DNISN	1201	1432	7.17
2609	2695	WFALS	0114	418	7.13
2610	2270	SPRTN	1802	859	7.09
2611	2553	WDGWD	1561	1484	7.08
2612	1032	ITSCA	1702	213	7.07
2613	309	GVFTW	1802	843	7.02
2614	1042	HNYGR	2403	135	7.01
2615	1444	IRVGS	1903	869	6.98
2616	1763	DENAV	0652	40	6.98
2617	375	LOMAL	0010	1561	6.92
2618	2578	MSLSW	0002	1012	6.92
2619	1978	ADISN	1603	190	6.88
2620	2078	SHDYG	7812	121	6.82
2621	1774	LNCST	1603	1437	6.82
2622	2760	CKRHL	0003	322	6.71
2623	1756	KLNCC	1704	2098	6.62
2624	2176	TYLER	1010	53	6.52
2625	2507	ELKTN	2503	823	6.50
2626	2673	CRLTR	2004	220	6.48
2627	1735	ARMST	0001	273	6.46
2628	551	LNDAL	2202	1195	6.31
2629	2782	GAVSW	0006	519	6.27
2630	2872	RGFTW	6822	23	6.25
2631	2542	TMPNW	1103	594	6.24
2632	2191	HHSTH	1503	640	6.22
2633	773	LOMAL	0007	157	6.19
2634	2108	PJPTR	3211	117	6.14
2635	2563	KLELM	2201	2182	6.12

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2636	2867	PRNTH	1403	22	6.12
2637	2751	WMMMR	2708	244	6.07
2638	2170	RWDHV	1908	2184	6.00
2639	1930	TRNTY	7551	1375	5.86
2640	969	JKSNR	4107	20	5.83
2641	768	LEMON	0004	280	5.79
2642	10	VENSW	2603	25	5.78
2643	654	BNMNW	1102	397	5.78
2644	1310	CRLTN	1408	131	5.77
2645	1951	ATNRN	3411	2810	5.75
2646	778	WALNT	0002	1241	5.75
2647	680	HORNE	1923	1563	5.72
2648	2156	ARMST	0010	888	5.72
2649	1513	PWEST	1312	1355	5.69
2650	2477	DLEON	0111	851	5.64
2651	2493	INAIR	1421	18	5.62
2652	2441	DESPR	1404	562	5.62
2653	1661	GNSVL	1204	514	5.61
2654	2242	CMHBL	8121	50	5.61
2655	2310	GSTHW	1622	29	5.52
2656	2657	NMAIN	0231	326	5.51
2657	1424	EZACH	0005	535	5.48
2658	1648	ZEPHR	2404	184	5.39
2659	127	HMPHL	2781	226	5.37
2660	1302	LUFKN	1204	37	5.36
2661	1786	HKBRY	1105	168	5.36
2662	1662	LKWOD	7442	706	5.35
2663	2598	BKWST	0005	849	5.32
2664	644	JDKNS	0811	57	5.32
2665	588	ADISN	1608	372	5.27
2666	2623	LKBLT	2107	1037	5.23
2667	1856	BDFWD	8932	1677	5.23
2668	2201	CLBNR	1401	21	5.12
2669	444	FRMNT	0010	1737	5.10
2670	2841	HMPHL	2723	36	5.07
2671	685	FRMBG	1752	204	5.00
2672	742	NHNSW	0001	457	4.99
2673	1604	FROKS	0001	1325	4.97
2674	2453	MDWPK	9211	1232	4.94
2675	605	WMMMR	2705	573	4.92
2676	2097	JNKNS	0004	128	4.90
2677	1909	MNSTR	1202	267	4.86
2678	2708	PALRD	2203	1092	4.85
2679	2649	SMFLD	2391	288	4.80
2680	2284	SHNRW	1607	59	4.75
2681	1656	EDGCF	2231	772	4.72
2682	1438	MRSES	4012	405	4.68
2683	348	FRMBG	1703	36	4.64

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2684	1035	ADISN	1604	1148	4.62
2685	2309	WRTHM	5004	227	4.54
2686	2037	DNINR	1401	85	4.47
2687	2459	NPKWY	0011	2758	4.42
2688	2395	FRMNT	0005	263	4.39
2689	1279	WNRTH	1418	1751	4.35
2690	1779	ALPHA	0008	1256	4.34
2691	2795	AMLIA	0008	131	4.29
2692	1537	ROBNW	1501	477	4.24
2693	1393	PFFRD	3411	320	4.13
2694	2429	PROAD	0008	1134	4.12
2695	2610	GRLWS	1706	267	3.93
2696	1156	SYCRK	4531	2320	3.88
2697	2205	RRNES	2405	1944	3.88
2698	2374	ARMST	0002	791	3.87
2699	1991	CRLTR	2051	3925	3.83
2700	2368	HORNE	1933	2001	3.75
2701	975	PRHLL	2402	68	3.71
2702	2703	ARMST	0007	113	3.71
2703	869	ENTOH	0002	824	3.66
2704	2609	RECCR	0003	205	3.62
2705	1546	BRNAV	0774	186	3.53
2706	1370	MRTNS	1501	483	3.52
2707	2602	VALVW	1802	419	3.50
2708	2103	WMMMR	2702	1399	3.48
2709	2426	WWEST	1217	96	3.42
2710	2379	JNKNS	0001	15	3.41
2711	2844	IRVRS	4413	697	3.34
2712	2075	RSPCK	2133	142	3.31
2713	2530	WRTHM	5017	169	3.26
2714	16	HUTCH	1502	189	3.23
2715	2534	HURST	1852	1454	3.18
2716	1607	SMBMG	1701	28	3.14
2717	2705	EXPKY	8142	28	3.13
2718	1423	RANGR	4311	905	3.08
2719	2595	GDNVL	1201	63	3.07
2720	2348	HNTNG	1302	39	3.01
2721	1747	BRNSO	1804	10	2.92
2722	243	CKRHL	0004	417	2.83
2723	2422	FSCRK	6713	1817	2.80
2724	2692	WFALS	0163	344	2.78
2725	128	KYSTN	1011	60	2.76
2726	2225	WALST	0012	342	2.73
2727	2552	GSTHW	1682	148	2.72
2728	1527	HMPHL	2711	475	2.70
2729	1051	GMINI	5821	1388	2.67
2730	1340	WHITE	3532	1353	2.61
2731	2878	SORCY	0002	65	2.61

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2732	1164	SHRSW	6631	1312	2.56
2733	1753	KNLTR	0005	2443	2.52
2734	2830	FRMNT	0004	1510	2.48
2735	1244	LUFKN	1207	47	2.47
2736	1852	MAPLE	0008	214	2.45
2737	2836	GSTHW	1613	92	2.40
2738	2804	BRYAN	0007	273	2.36
2739	2195	MCGHR	2004	20	2.30
2740	2244	MESTE	1213	851	2.27
2741	2494	DGNST	0005	147	2.26
2742	2561	FRMBR	1853	290	2.25
2743	2300	CKRHL	0007	81	2.22
2744	2125	DENDR	0008	84	2.21
2745	371	MAPLE	0002	290	2.19
2746	449	FRMBG	1705	278	2.18
2747	2543	RGLRW	0005	52	2.13
2748	2738	WSOTH	1022	1565	2.09
2749	2792	ALPHA	0001	424	2.08
2750	2625	DCATR	1205	123	2.07
2751	2879	STERT	2701	29	2.06
2752	1095	RRNES	2407	1607	2.05
2753	2537	CRLTN	1452	576	2.02
2754	2731	COPER	0401	128	1.99
2755	2849	LENSW	0321	48	1.98
2756	2635	PLANO	1106	494	1.92
2757	2710	SHAMP	0002	1688	1.90
2758	2680	BKWST	0007	1719	1.87
2759	2856	MRSES	3016	42	1.86
2760	2689	HMTRD	0003	398	1.82
2761	1668	SORCY	0003	827	1.82
2762	2321	RECCR	0001	161	1.80
2763	2797	ARMST	0004	1173	1.78
2764	2029	WWEST	1222	156	1.75
2765	1251	CMPST	0003	209	1.69
2766	1125	CDHCR	2055	1228	1.68
2767	1987	LKWOD	7421	42	1.66
2768	1461	CRLUD	1302	150	1.65
2769	2262	PSHIL	1606	386	1.64
2770	2768	NMAIN	0262	410	1.62
2771	2111	SHAMP	0007	708	1.59
2772	1204	MCWHT	3522	2884	1.57
2773	12	WEBBS	8634	670	1.57
2774	2809	CRLTR	2006	53	1.47
2775	2770	LVBRD	0005	1326	1.45
2776	2728	PROAD	0001	124	1.35
2777	727	LFSTH	1405	209	1.31
2778	1933	STNVL	1202	98	1.28
2779	2854	MKNNY	1204	36	1.24



## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2780	998	FRMBG	1751	806	1.23
2781	731	CRTLD	4712	1154	1.18
2782	1337	WALST	0010	385	1.18
2783	1321	MCDMT	2553	1663	1.18
2784	2742	HKBRY	1103	76	1.16
2785	162	ENTOH	0006	1570	1.10
2786	1892	TMPNW	1106	491	1.09
2787	2006	FRNKF	0004	1006	1.07
2788	2594	TMNTH	1603	125	1.05
2789	2785	BLTLN	0001	663	1.05
2790	2313	IRVNE	1304	595	1.03
2791	2416	SCHRD	0006	464	1.01
2792	2764	BRIRV	6912	820	1.00
2793	2249	FRMNT	0003	281	0.99
2794	2489	ARLNG	1291	84	0.98
2795	1048	LOMAL	0014	592	0.96
2796	724	MCDMT	2554	1249	0.94
2797	2485	MESQN	1506	63	0.94
2798	2268	LKBLT	2101	1096	0.93
2799	40	LSCOL	2148	737	0.92
2800	670	BLMND	3221	91	0.91
2801	378	DGNST	0006	788	0.89
2802	1903	THRNE	0005	1272	0.89
2803	507	WALNT	0005	1106	0.88
2804	2754	WEAST	0628	267	0.87
2805	907	CMTSW	0914	82	0.84
2806	2026	SHDYG	7832	1832	0.76
2807	1108	ALPHA	0006	297	0.75
2808	1235	WEAST	0627	126	0.74
2809	2833	FRMNT	0012	511	0.56
2810	2843	IRLBJ	3222	495	0.52
2811	2186	HMPHL	2742	440	0.51
2812	2767	BKWST	0004	1075	0.49
2813	1325	JNKNS	0006	508	0.49
2814	2448	INAIR	1411	916	0.48
2815	1406	BNDRA	0013	171	0.43
2816	2765	LSCOL	2137	500	0.40
2817	2763	LSCOL	2135	535	0.40
2818	1792	MESFR	2105	1025	0.37
2819	2061	FARON	4021	288	0.36
2820	1724	FRMNT	0007	447	0.34
2821	2375	ARMST	0012	464	0.34
2822	2682	RGFTW	6841	19	0.29
2823	2886	WEAST	0621	103	0.29
2824	947	CKRHL	0001	407	0.28
2825	2832	FRMNT	0011	364	0.26
2826	1382	WMRNR	0003	781	0.24
2827	2660	CURIE	7241	712	0.21

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2828	2711	SANSM	3921	1254	0.20
2829	193	BKWST	0001	384	0.19
2830	2876	RSPCK	2105	309	0.18
2831	989	HKBRY	1113	425	0.17
2832	2761	FRMNT	0001	847	0.14
2833	2331	BRHLW	7611	1614	0.13
2834	2746	IRLBJ	3221	623	0.07
2835	2492	EULES	8714	790	0.04
2836	2606	ALLEN	2401	368	0.00
2837	2790	ALLEN	2405	22	0.00
2838	2794	AMLIA	0003	17	0.00
2839	1849	AMLIA	0005	13	0.00
2840	2737	ARTHR	0492	47	0.00
2841	2800	BKWST	0006	791	0.00
2842	2803	BRHLW	7641	24	0.00
2843	2539	CHICC	1701	52	0.00
2844	N/A	COLDG	4048	10	0.00
2845	2807	COTRD	0005	224	0.00
2846	2544	COTRD	0008	1039	0.00
2847	1174	CRLTR	2054	99	0.00
2848	2810	CRLUD	1301	15	0.00
2849	2811	CRLUD	1306	25	0.00
2850	806	DENAV	0673	58	0.00
2851	2814	DFWNW	2602	35	0.00
2852	2816	DFWNW	2606	23	0.00
2853	2818	DFWSW	2203	43	0.00
2854	2739	DFWSW	2208	17	0.00
2855	N/A	DFWSW	2209	10	0.00
2856	1295	DGNST	0001	232	0.00
2857	2823	ENSSE	3011	10	0.00
2858	2825	EXPKY	8112	14	0.00
2859	2826	EXPKY	8141	19	0.00
2860	2828	FRMBG	1704	35	0.00
2861	1103	FRMNT	0002	681	0.00
2862	2831	FRMNT	0006	11	0.00
2863	2834	GAVSW	0011	111	0.00
2864	2839	GSTHW	1672	42	0.00
2865	2696	HMPHL	2713	54	0.00
2866	2842	INAIR	1442	114	0.00
2867	2236	IRVVV	2803	150	0.00
2868	2775	JNKNS	0002	171	0.00
2869	2845	JNKNS	0008	19	0.00
2870	1600	LOMAL	0004	136	0.00
2871	2571	LSCOL	2138	636	0.00
2872	2851	LSCOL	2140	297	0.00
2873	1359	MNWLL	1201	12	0.00
2874	1147	MRSES	4014	19	0.00
2875	306	NCRST	2202	26	0.00

## Service Quality Report to the Public Utility Commission of Texas

### **Oncor Electric Delivery**

<b>2012 SAIDI Ranking</b>	<b>2011 SAIDI Ranking</b>	<b>Substation Identification</b>	<b>Feeder Identification</b>	<b>Number of Customers</b>	<b>2012 SAIDI Value</b>
2876	2522	PARIS	1205	28	0.00
2877	2860	PJPTR	3221	38	0.00
2878	2861	PJPTR	3222	171	0.00
2879	2862	PJPTR	3231	25	0.00
2880	2866	PLHWY	3701	450	0.00
2881	2562	PLHWY	3703	14	0.00
2882	2747	PROAD	0006	125	0.00
2883	2683	PSHIL	1605	123	0.00
2884	2868	PWEST	1306	281	0.00
2885	2569	PWEST	1309	59	0.00
2886	2704	RCLNS	1401	106	0.00
2887	2781	RCLNS	1402	652	0.00
2888	2869	RDLML	2542	16	0.00
2889	1176	RECCR	0002	102	0.00
2890	N/A	REGST	0007	10	0.00
2891	56	RNDRK	1509	147	0.00
2892	2874	RNKSW	5413	31	0.00
2893	2875	ROANW	9522	31	0.00
2894	2538	RSPCK	2132	66	0.00
2895	940	SHDYG	7821	93	0.00
2896	2880	TRLSW	2401	22	0.00
2897	1778	WALST	0003	129	0.00
2898	2883	WALST	0006	11	0.00
2899	2884	WALST	0008	14	0.00
2900	2470	WMMMR	2704	14	0.00
2901	2743	WMRLD	0009	29	0.00

Service Quality Report to the Public Utility Commission of Texas

**Oncor Electric Delivery**

**INTERRUPTION CAUSES**

Provide the percentage of interruptions attributable to each cause.

2012 Reporting Year

<b>Causes of Forced Interruptions</b>	<b>Percentage</b>
Weather (Including Lightning)	20.24%
Vegetation	19.49%
Animals and Birds	13.52%
People (Including cars and farm equip)	4.19%
Utility-owned Equipment	35.42%
Other	3.02%
Unknown	4.12%