



Control Number: 41092



Item Number: 9

Addendum StartPage: 0

2013 FEB 14 PM 2:44
PUBLIC UTILITY COMMISSION
FILED CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2012 Reporting Year

AEP Texas Central Company

Project 41092

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2012	1.34	0.06	0.12	0.12	0.13	0.13	0.14	0.12	0.11	0.13	0.09	0.06	0.13
Scheduled 2012	0.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.00
Outside Causes 2012	0.16	0.02	0.01	0.02	0.01	0.01	0.01	0.02	0.02	0.02	0.02	0.00	0.01
Major Events 2012	0.20			0.05	0.02	0.08						0.06	

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
System SAIDI													
Forced 2012	140.5	6.1	11.8	11.9	13.0	18.0	16.7	11.8	9.5	12.4	10.8	5.7	12.9
Scheduled 2012	2.6	0.3	0.2	0.1	0.2	0.2	0.1	0.2	0.2	0.2	0.3	0.3	0.3
Outside Causes 2012	9.7	0.3	0.9	2.0	0.2	0.5	0.6	1.1	1.1	0.9	1.2	0.5	0.4
Major Events 2012	74.1			25.7	2.9	29.4							16.0

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

731

Add or Delete Rows as Necessary

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
1	12	GOVERNMENT WELLS	94LA6800	217	12.180
2	9	JOURDANTON	94LA250	760	11.438
3	34	MAVERICK	94LA9680	725	11.012
4	152	SAN YGNACIO	94LA16060	477	9.249
5	89	LOS FRESNOS	94SB4315	964	6.791
6	26	CARRIZO SPRINGS	94LA860	1,377	6.618
7	228	MOORE FIELD	94SB3120	128	6.453
8	431	DILLEY	94LA6400	908	6.401
9	254	THREE RIVERS	94CN8430	180	6.256
10	79	PEARSALL	94LA9905	750	6.009
11	545	PETTUS	94CN8210	372	5.796
12	147	SOUTHSIDE	94CS5335	1,142	5.459
13	11	NORTH EDINBURG	94SB4240	2,221	5.374
14	283	POINT COMFORT	94CN2460	350	5.360
15	499	BEEVILLE	94CN300	1,709	5.341
16	200	CONTINENTAL	94SB4080	63	5.333
17	360	JOURDANTON	94LA5685	559	5.299
18	16	TATTON	94CN8490	125	5.176
19	343	MORRIS STREET	94CS8830	1,555	5.125
20	21	ASHERTON	94LA2670	260	5.054
21	520	PORT LAVACA	94CN2480	1,539	4.936
22	476	BRUNI	94LA5440	127	4.724
23	220	GOLIAD	94CN6540	1,147	4.596
24	270	LA PRYOR	94LA570	142	4.500
25	443	TAFT	94CS1180	1,053	4.463
26	259	NORTH ALAMO	94SB3580	818	4.443
27	149	RAYMONDVILLE #2	94SB3250	28	4.429
28	510	PHARR	94SB1625	2,131	4.427
29	35	CHARLOTTE	94LA2790	101	4.426
30	439	PALACIOS	94CN8550	38	4.342
31	17	RIO RICO	94SB8290	365	4.337
32	205	ELSA	94SB690	2,255	4.330
33	561	MAGRUDER	94CN245	1,096	4.285
34	554	PHARAOH	94CS5175	990	4.142
35	528	CARRIZO SPRINGS	94LA910	2,088	4.119
36	107	GREENLAKE	94CN2750	1,127	4.097
37	383	EAST HARRISON	94SB3950	553	4.081
38	293	MARKHAM	94CN5550	100	4.080
39	83	CRYSTAL CITY	94LA330	1,293	4.046
40	474	VILLA CAVAZOS	94SB1980	1,511	4.011
41	140	MORRIS STREET	94CS5655	959	4.004
42	57	RAYMONDVILLE #2	94SB3170	704	3.972
43	459	PETTUS	94CN1020	396	3.909
44	77	GILA	94CS350	813	3.889
45	264	MATTHEWS	94CN1740	162	3.679
46	302	MAGRUDER	94CN6700	1,360	3.578
47	138	HALL ACRES ROAD	94SB5585	686	3.563
48	578	WOODSBORO	94CS8330	1,088	3.537
49	86	BLESSING	94CN1030	254	3.520
50	13	LA PRYOR	94LA580	199	3.518
51	198	MORRIS STREET	94CS8820	1,254	3.506
52	458	AMISTAD DAM	94LA5450	1,144	3.506
53	707	MCKENZIE ROAD	94CS150	25	3.400
54	103	NORTH ALAMO	94SB4370	1,459	3.369
55	462	SABINAL	94LA200	413	3.356
56	389	HALL ACRES ROAD	94SB8870	1,942	3.351
57	7	GOVERNMENT WELLS	94LA7240	203	3.330
58	632	CHARLOTTE	94LA2780	558	3.326
59	276	NORTH VICTORIA	94CN7430	1,740	3.297

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
60	190	UNIVERSITY	94LA950	2,908	3.280
61	310	VICTORIA POWER PLANT	94CN1390	1,155	3.263
62	442	HAMILTON ROAD	94LA9655	1,214	3.261
63	604	MAGRUDER	94CN6680	695	3.210
64	94	STAFFORD HILL	94CN1550	216	3.208
65	59	EL CAMPO	94CN7710	1,057	3.190
66	166	PHARAOH	94CS1365	443	3.120
67	19	GREGORY	94CS5900	107	3.112
68	567	O CONNER	94CN390	210	3.105
69	142	PORT ARANSAS	94CS6940	1,601	3.097
70	517	WEST OSO	94CS9095	1,588	3.088
71	129	JOURDANTON	94LA880	297	3.071
72	524	FULTON	94CS6070	3,201	3.064
73	370	GARWOOD CITY	94CN2560	196	3.046
74	242	THREE RIVERS	94CN2580	96	3.042
75	454	CITRUS CITY	94SB9775	1,455	3.034
76	210	BRUNI	94LA1120	136	3.029
77	195	SIERRA VISTA	94LA9900	2,321	2.993
78	354	ZAPATA	94LA7330	1,334	2.984
79	108	PLEASANTON	94LA9475	1,328	2.972
80	432	PLEASANTON	94LA9505	1,503	2.957
81	245	FALFURRIAS	94LA5210	1,115	2.949
82	330	BROWNSVILLE	94SB3050	1,945	2.927
83	279	TAFT	94CS1260	184	2.913
84	50	NAVAL BASE	94CS6330	322	2.910
85	68	FREER	94LA1500	198	2.894
86	268	DEVINE	94LA8100	1,520	2.892
87	366	ELSA	94SB710	1,747	2.885
88	481	DILLEY	94LA510	517	2.884
89	234	UVALDE	94LA9770	1,381	2.865
90	371	BLESSING	94CN8790	741	2.829
91	376	THREE RIVERS	94CN5190	895	2.817
92	668	ROMA	94SB3070	1,246	2.811
93	237	NORTH PADRE ISLAND	94CS7900	1,271	2.786
94	194	WEST MCALLEN	94SB4515	799	2.777
95	534	CONOCO-CHITTAM RANCH	94LA8580	31	2.774
96	5	PORT ISABEL S.S.	94SB4070	292	2.771
97	329	KNIPPA	94LA6535	21	2.762
98	650	UNIVERSITY	94LA920	290	2.734
99	607	PEARSALL	94LA5580	1,601	2.730
100	47	NORTH VICTORIA	94CN7440	1,617	2.729
101	587	BISHOP	94CS7180	935	2.724
102	398	UVALDE	94LA550	667	2.720
103	192	PLEASANTON	94LA2080	1,587	2.706
104	470	BAY CITY	94CN2700	1,063	2.696
105	110	HARLINGEN	94SB380	2,333	2.693
106	569	MCKENZIE ROAD	94CS140	256	2.621
107	495	PLACEDO	94CN7980	402	2.609
108	8	CABANISS	94CS80	1,155	2.571
109	467	ZAPATA	94LA8300	1,694	2.563
110	197	KENEDY	94CN1970	667	2.562
111	418	CAMPWOOD	94LA3430	82	2.561
112	664	LAREDO PLANT	94LA8705	211	2.555
113	409	THREE RIVERS	94CN2010	1,143	2.544
114	122	BROWNSVILLE	94SB4290	382	2.537
115	603	TATTON	94CS8200	1,006	2.533
116	250	COTULLA	94LA90	842	2.529
117	106	SOUTH PADRE ISLAND	94SB6440	2,492	2.528
118	393	SANTO NINO	94LA695	1,537	2.509
119	453	SOUTH EAST EDINBURG	94SB5045	1,853	2.492
120	45	PARKER	94CN9260	106	2.472
121	273	GREENLAKE	94CN2740	30	2.467
122	421	BROOKHOLLOW	94CN8950	869	2.459
123	90	EAGLE LAKE	94CN320	632	2.453

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
124	91	CRESTONIO	94LA260	1,790	2.414
125	591	COLUMBUS	94CN930	893	2.409
126	116	UVALDE	94LA6620	2,730	2.398
127	558	HALL ACRES ROAD	94SB4895	816	2.395
128	420	HAMILTON ROAD	94LA9665	945	2.392
129	594	WEST MCALLEN	94SB4595	1,168	2.371
130	450	INGLESIDE CITY	94CS6040	246	2.337
131	616	LAREDO HEIGHTS	94LA2450	2,523	2.328
132	60	BUENA VISTA	94LA9035	1,502	2.316
133	67	WESLACO UNIT	94SB8610	1,155	2.313
134	463	MATHIS	94CS2870	871	2.312
135	23	HIDALGO	94SB4845	1,090	2.311
136	119	PORTLAND	94CS9290	1,690	2.309
137	303	RIO BRAVO	94LA1130	942	2.306
138	117	LAGUNA	94CS9590	2,179	2.268
139	472	MAGRUDER	94CN6690	562	2.256
140	193	DEL RIO CITY	94LA420	2,218	2.249
141	335	SHARYLAND	94SB2020	2,319	2.234
142	460	ODEM	94CS385	397	2.227
143	529	SOUTH SANTA ROSA	94SB7485	1,018	2.223
144	695	WEST MCALLEN	94SB4965	697	2.222
145	585	SOUTHSIDE	94CS8025	1,058	2.220
146	471	CHARLOTTE	94LA8120	199	2.216
147	414	PORT ARANSAS	94CS990	1,418	2.179
148	537	SOUTHSIDE	94CS7955	1,042	2.179
149	369	SANTO NINO	94LA80	2,374	2.179
150	207	POLK AVENUE	94SB4520	911	2.175
151	101	BAY CITY	94CN6670	1,776	2.173
152	677	RAYMONDVILLE #2	94SB1280	1,065	2.162
153	71	PEARSALL	94LA7050	1,550	2.159
154	181	GILA	94CS7840	51	2.157
155	56	BANQUETTE	94CS130	228	2.132
156	700	RAYMONDVILLE #1	94SB3130	279	2.115
157	139	CARANCAHUA	94CN5870	454	2.112
158	271	CRYSTAL CITY	94LA140	768	2.112
159	3	FREER	94LA2900	156	2.109
160	715	SOUTH EAST EDINBURG	94SB4015	421	2.102
161	511	VICTORIA POWER PLANT	94CN7600	152	2.099
162	78	LULING - LCRA	94CN20	279	2.097
163	236	WEST HARLINGEN	94SB3700	1,691	2.094
164	550	WOOLRIDGE	94CS1120	2,540	2.093
165	1	CAUSEWAY	94SB4765	971	2.070
166	66	MORRIS STREET	94CS8850	484	2.068
167	238	REFUGIO	94CN1040	179	2.061
168	288	MUSTANG ISLAND	94CS8510	410	2.056
169	42	NORTH MERCEDES	94SB3840	643	2.042
170	51	GANADO	94CN5815	597	2.040
171	388	LOS FRESNOS	94SB2160	1,133	2.021
172	716	AIRLINE	94CS7270	1,011	2.008
173	718	CHASE FIELD	94CN460	15	2.000
174	137	GREGORY	94CS420	23	2.000
175	678	GOLIAD	94CN8220	1,040	1.998
176	218	FALFURRIAS	94LA1070	1,037	1.994
177	593	UVALDE	94LA540	1,211	1.987
178	413	RAYMONDVILLE #1	94SB620	619	1.974
179	367	MUSTANG ISLAND	94CS9470	657	1.971
180	430	YORKTOWN	94CN8380	821	1.970
181	580	WEAVER ROAD	94CN1900	52	1.962
182	339	AIRLINE	94CS9030	417	1.952
183	400	PORT LAVACA	94CN8310	314	1.952
184	62	OLMITO	94SB4275	764	1.952
185	685	HAIN DRIVE	94SB3490	1,071	1.940
186	291	LULING - LCRA	94CN10	356	1.935
187	102	WESLACO UNIT	94SB7630	1,822	1.935

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
188	22	WEST OSO	94CS9085	767	1.935
189	141	BERCLAIR	94CN990	330	1.909
190	100	ALICE	94LA2540	1,147	1.895
191	438	GEORGE WEST	94CN1320	752	1.895
192	38	ALICE	94LA2530	1,456	1.891
193	416	ARCADIA	94CS1360	1,540	1.886
194	80	CLARKWOOD	94CS7230	620	1.866
195	514	OLMITO	94SB715	534	1.858
196	169	MORRIS STREET	94CS7625	561	1.857
197	130	BONNIEVIEW	94CS8020	505	1.850
198	146	LOS FRESNOS	94SB5335	1,974	1.846
199	206	ENCINAL	94LA2160	874	1.836
200	196	ZAPATA	94LA8290	2,074	1.836
201	24	SOUTH PADRE ISLAND	94SB4675	151	1.828
202	54	WEST MCALLEN	94SB6385	208	1.822
203	267	CRESTONIO	94LA270	613	1.817
204	353	HIGHWAY 9	94CS7210	334	1.808
205	426	WEST MCALLEN	94SB4555	1,491	1.803
206	692	RAYMONDVILLE #1	94SB800	684	1.801
207	143	WESMER	94SB1850	1,244	1.799
208	313	WESMER	94SB4050	1,912	1.796
209	244	PALACIOS	94CN6830	801	1.783
210	586	GREGORY	94CS5920	607	1.781
211	132	GANADO	94CN5795	470	1.764
212	627	HOLLY	94CS1220	3,384	1.764
213	576	HARLINGEN S.S.	94SB320	1,492	1.762
214	148	RIO RICO	94SB8330	389	1.761
215	252	GREENLAKE	94CN2760	573	1.749
216	239	UVALDE	94LA5060	1,311	1.748
217	512	CASA BLANCA	94CS55	828	1.746
218	469	NORTH MERCEDES	94SB4860	1,397	1.741
219	347	RIO GRANDE CITY	94SB3210	1,766	1.732
220	588	BROOKHOLLOW	94CN7580	447	1.727
221	280	MINES ROAD	94LA3745	1,611	1.722
222	624	ARCADIA	94CS5030	1,567	1.721
223	63	COLUMBUS	94CN6180	1,214	1.716
224	612	LEARY LANE	94CN6005	1,796	1.710
225	266	PHARR	94SB1645	2,590	1.703
226	65	PORT ARANSAS	94CS1000	1,507	1.687
227	316	LIVE OAK	94CS1090	273	1.681
228	294	MORRIS STREET	94CS2515	1,093	1.675
229	191	SOUTH SANTA ROSA	94SB1240	1,578	1.667
230	648	BROOKHOLLOW	94CN8960	579	1.667
231	579	SANTO NINO	94LA70	1,141	1.665
232	364	SHARYLAND	94SB6745	1,958	1.663
233	37	ZAPATA	94LA2710	44	1.659
234	577	WOOLRIDGE	94CS1170	734	1.658
235	546	HOLLY	94CS1480	1,702	1.651
236	308	WEST HARLINGEN	94SB3800	1,324	1.647
237	525	BEEVILLE	94CN1760	1,813	1.645
238	549	SOUTH EAST EDINBURG	94SB4550	2,121	1.638
239	251	PORTLAND	94CS9270	1,934	1.629
240	126	SOUTHSIDE	94CS7925	1,326	1.624
241	235	PALMHURST	94SB1300	1,929	1.623
242	493	CARRIZO SPRINGS	94LA370	525	1.619
243	480	RIO BRAVO	94LA5	691	1.612
244	434	ARCADIA	94CS1450	1,914	1.612
245	46	NORTH PADRE ISLAND	94CS5170	1,127	1.598
246	14	PORT ISABEL S.S.	94SB3820	206	1.597
247	212	GEORGE WEST	94CN730	965	1.589
248	602	NORTH PADRE ISLAND	94CS1010	2,548	1.584
249	289	VILLA CAVAZOS	94SB5680	1,691	1.578
250	710	KENEDY	94CN1960	64	1.578
251	318	HALL ACRES ROAD	94SB3460	3,302	1.568

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
252	2	NORDHEIM	94CN470	245	1.563
253	412	BRUNI	94LA1100	635	1.559
254	555	ROCKPORT	94CS5930	1,109	1.555
255	675	ALICE	94LA1790	344	1.549
256	634	BANDERA ELECTRIC (LEAKEY)	94LAL30	259	1.548
257	346	SOUTHSIDE	94CS7995	1,545	1.548
258	333	JOURDANTON	94LA5695	1,313	1.545
259	436	EAST HARRISON	94SB4620	750	1.539
260	208	WEST HARLINGEN	94SB4870	725	1.523
261	312	RUNGE	94CN7320	647	1.516
262	151	HOLLY	94CS1950	803	1.511
263	491	SEAWALL	94CS9325	1,436	1.511
264	162	COTULLA	94LA110	1,559	1.502
265	690	BROOKHOLLOW	94CN7190	265	1.494
266	327	SOUTHSIDE	94CS8005	743	1.489
267	98	COFFEE PORT	94SB1090	1,154	1.488
268	661	DEL MAR	94LA490	751	1.487
269	631	SOUTHSIDE	94CS7905	1,826	1.485
270	73	SAN DIEGO	94LA2880	1,284	1.484
271	363	MILO	94LA3065	184	1.478
272	174	PORT LAVACA	94CN6850	593	1.477
273	287	DEL RIO CITY	94LA430	2,505	1.474
274	475	SAN DIEGO	94LA2930	601	1.469
275	673	TATTON	94CS950	534	1.468
276	175	MCCOLL ROAD	94SB2810	2,344	1.466
277	519	KENEDY S.S.	94CN6750	864	1.465
278	274	EDNA	94CN5785	752	1.463
279	27	HOMEPORT	94CS4665	438	1.463
280	445	PUEBLO	94LA95	2,120	1.462
281	272	RAYMONDVILLE #2	94SB3240	974	1.461
282	613	AIRLINE	94CS7280	622	1.461
283	655	POLK AVENUE	94SB4740	1,902	1.456
284	351	LAREDO PLANT	94LA9305	979	1.456
285	592	RIO BRAVO	94LA300	780	1.455
286	697	ARANSAS PASS	94CS8280	559	1.447
287	446	EL CAMPO	94CN5745	887	1.441
288	536	NORTH WESLACO	94SB4810	1,356	1.440
289	638	GARWOOD CITY	94CN2570	134	1.433
290	180	SOUTH MISSION	94SB3590	674	1.430
291	304	PRAIRIE PUMP	94CN1940	69	1.420
292	518	ARCADIA	94CS1460	2,142	1.415
293	323	NIXON	94CN5990	634	1.415
294	163	GRETA	94CN7890	322	1.413
295	334	PUEBLO	94LA275	2,755	1.412
296	501	ARCADIA	94CS6930	1,499	1.410
297	125	LEARY LANE	94CN7530	2,066	1.404
298	598	EAGLE LAKE	94CN310	722	1.403
299	95	YORKTOWN	94CN8420	1,079	1.402
300	532	BAY CITY	94CN1110	1,277	1.401
301	705	MILO	94LA3060	110	1.400
302	253	ARCADIA	94CS8570	1,434	1.397
303	357	SOUTH EAST EDINBURG	94SB6560	1,351	1.394
304	457	LIVE OAK	94CS1080	796	1.394
305	597	HALL ACRES ROAD	94SB5465	1,659	1.394
306	284	LEARY LANE	94CN1430	1,580	1.392
307	574	LAREDO HEIGHTS	94LA6810	2,066	1.390
308	263	HIDALGO	94SB3400	850	1.380
309	382	ESCONDIDO	94LA1510	710	1.377
310	506	INGLESIDE CITY	94CS8060	1,808	1.375
311	429	SHARYLAND	94SB5105	1,589	1.373
312	309	BANQUETTE	94CS9000	430	1.363
313	637	SOUTHSIDE	94CS8055	860	1.363
314	246	STADIUM	94LA7490	1,289	1.360
315	645	KLEBERG	94CS9395	1,310	1.356

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
316	177	PORT ISABEL S.S.	94SB9295	637	1.355
317	265	RANDADO	94LA8350	130	1.354
318	581	WEST MCALLEN	94SB4505	1,765	1.353
319	422	NORTH ALAMO	94SB3610	1,770	1.345
320	295	KINGSVILLE	94CS1660	1,623	1.344
321	248	HIGHWAY 9	94CS6730	524	1.342
322	531	NORTH MCALLEN	94SB2750	3,152	1.341
323	680	HARLINGEN S.S.	94SB4090	2,296	1.338
324	10	CRYSTAL CITY	94LA190	1,545	1.329
325	538	SOUTHSIDE	94CS8035	1,087	1.328
326	311	GOODWIN	94SB7380	2,161	1.326
327	322	KENEDY S.S.	94CN8340	972	1.323
328	48	SOUTH SANTA ROSA	94SB1225	822	1.318
329	659	CLARKWOOD	94CS7610	200	1.305
330	230	KENEDY	94CN6270	524	1.302
331	157	REFUGIO	94CN5120	706	1.302
332	25	GOVERNMENT WELLS	94LA7250	594	1.300
333	44	EDNA	94CN5765	1,673	1.299
334	278	EDROY	94CS6990	266	1.297
335	689	KINGSVILLE	94CS1350	370	1.297
336	337	ALAZAN	94CS620	166	1.295
337	29	RODD FIELD	94CS225	1,093	1.292
338	492	TAFT	94CS5230	827	1.291
339	341	VICTORIA POWER PLANT	94CN8170	763	1.284
340	328	HEARN ROAD	94CS870	1,129	1.282
341	608	NORTH VICTORIA	94CN7860	1,481	1.273
342	292	CITRUS CITY	94SB7985	1,660	1.270
343	92	BIG WELLS	94LA2630	26	1.269
344	319	NORTH MERCEDES	94SB3770	1,687	1.260
345	359	HARLINGEN S.S.	94SB4230	1,303	1.253
346	164	EAST HARRISON	94SB3190	1,421	1.247
347	516	LAREDO HEIGHTS	94LA9400	1,411	1.246
348	349	HEARN ROAD	94CS8980	1,196	1.237
349	485	KLEBERG	94CS6000	1,469	1.235
350	221	HOLLY	94CS1370	1,872	1.235
351	214	SANTO NINO	94LA515	1,957	1.235
352	159	RANGERVILLE	94SB3420	772	1.233
353	361	PREMONT	94LA2730	207	1.227
354	269	WADSWORTH	94CN8630	643	1.222
355	620	BISHOP	94CS2690	547	1.218
356	255	CONTINENTAL	94SB3650	23	1.217
357	331	PHARAOH	94CS1285	1,743	1.213
358	282	ROMA	94SB3060	1,558	1.212
359	325	SHARYLAND	94SB2035	2,257	1.210
360	223	GATEWAY	94LA3595	1,510	1.208
361	686	NORTH MCALLEN	94SB3830	1,263	1.207
362	81	FALFURRIAS	94LA1080	441	1.204
363	307	ARMSTRONG	94CS6050	69	1.203
364	605	HARLINGEN S.S.	94SB5350	776	1.202
365	694	NORTH MCALLEN	94SB9640	1,384	1.186
366	654	GOODWIN	94SB4380	1,443	1.186
367	687	POLK AVENUE	94SB4170	1,323	1.185
368	247	GILA	94CS345	49	1.184
369	160	PHARAOH	94CS1185	1,557	1.182
370	211	FOSTER FIELD	94CN2550	332	1.181
371	260	WEST HARLINGEN	94SB3720	1,884	1.179
372	153	CAMPWOOD	94LA2610	945	1.178
373	672	PORT LAVACA	94CN2490	1,072	1.174
374	176	HOLLY	94CS7620	2,507	1.172
375	660	AIRLINE	94CS7390	1,448	1.168
376	185	KNIPPA	94LA6365	306	1.154
377	461	FREER	94LA6320	158	1.152
378	402	SOUTH MCALLEN	94SB3935	1,294	1.143
379	377	HARLINGEN S.S.	94SB4110	811	1.136

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
380	99	CONTINENTAL	94SB4880	60	1.133
381	483	HOLLY	94CS9675	1,762	1.131
382	87	ESCONDIDO	94LA2035	2,545	1.130
383	6	HAMILTON ROAD	94LA9645	288	1.128
384	419	LYTLE	94LA2850	609	1.122
385	417	BEEVILLE	94CN8090	1,334	1.114
386	118	NORTH MCALEEN	94SB5060	2,327	1.113
387	113	BLESSING	94CN8780	63	1.111
388	681	LAREDO HEIGHTS	94LA2100	2,108	1.110
389	572	EDNA	94CN5775	503	1.107
390	651	SANTO NINO	94LA75	1,525	1.106
391	521	ARCADIA	94CS1400	432	1.102
392	709	GATEWAY	94LA5055	1,999	1.102
393	570	PHARR	94SB1620	2,330	1.095
394	18	WEIL TRACT (138/12KV)	94CS5405	157	1.089
395	155	RIO GRANDE CITY	94SB3740	2,241	1.087
396	204	PLACEDO	94CN7970	462	1.084
397	186	HALL ACRES ROAD	94SB3670	859	1.084
398	541	RODD FIELD	94CS2190	2,602	1.082
399	202	ROBSTOWN	94CS1650	351	1.080
400	667	AIRLINE	94CS8890	532	1.075
401	596	MILO	94LA6940	644	1.071
402	498	ARCADIA	94CS1440	1,686	1.065
403	599	GATEWAY	94LA350	1,695	1.063
404	584	SAN BENITO	94SB4945	1,759	1.062
405	104	SINTON	94CS6860	1,609	1.061
406	539	MCCOLL ROAD	94SB1655	1,153	1.059
407	571	RIO GRANDE CITY	94SB3220	1,675	1.053
408	156	EAGLE PASS CITY	94LA2510	593	1.049
409	658	WOOLRIDGE	94CS1110	1,585	1.047
410	397	LAREDO HEIGHTS	94LA9080	690	1.046
411	105	RANDADO	94LA8360	161	1.037
412	684	RAYMONDVILLE #2	94SB4160	350	1.034
413	407	SAN BENITO	94SB4135	1,253	1.034
414	713	SHARYLAND	94SB2150	1,173	1.031
415	165	WESMER	94SB9705	1,083	1.030
416	618	MILO	94LA5020	1,301	1.027
417	691	KLEBERG	94CS8140	402	1.020
418	74	NORTH PADRE ISLAND	94CS720	1,083	1.018
419	317	CASA BLANCA	94CS5115	280	1.018
420	224	LA GRULLA	94SB4120	1,412	1.009
421	258	EAGLE PASS CITY	94LA450	718	1.008
422	415	UNIVERSITY	94LA930	756	1.003
423	683	SHARYLAND	94SB2010	1,104	1.001
424	240	PREMONT	94LA6610	816	1.000
425	396	PHARAOH	94CS5185	2,748	0.995
426	215	PREMONT	94LA6570	720	0.994
427	542	ARANSAS PASS	94CS650	748	0.993
428	262	MATHIS	94CS340	1,467	0.993
429	630	KENEDY S.S.	94CN8320	858	0.993
430	4	CAUSEWAY	94SB4795	1,199	0.992
431	134	LA GRULLA	94SB5005	1,972	0.985
432	150	EAGLE LAKE	94CN9455	575	0.984
433	70	OLMITO	94SB905	1,467	0.983
434	222	BIG WELLS	94LA1570	463	0.974
435	299	SUNCHASE	94SB1150	1,271	0.970
436	625	NORTH VICTORIA	94CN1470	437	0.968
437	217	SOUTH PADRE ISLAND	94SB5850	1,302	0.951
438	404	ESCONDIDO	94LA3350	1,097	0.941
439	144	UVALDE	94LA480	1,320	0.933
440	399	SANTO NINO	94LA645	1,126	0.931
441	482	MOORE FIELD	94SB3110	640	0.927
442	31	COFFEE PORT	94SB1095	966	0.922
443	455	FALFURRIAS	94LA2830	1,473	0.908

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
444	131	MARKHAM	94CN6440	433	0.901
445	345	HIGHWAY 9	94CS6770	1,158	0.898
446	52	RANGERVILLE	94SB4060	881	0.890
447	464	RACHAL	94LA8145	355	0.876
448	553	DEVINE	94LA7090	944	0.870
449	488	SEAWALL	94CS9450	288	0.865
450	358	BRUNI	94LA5160	139	0.849
451	626	RANGERVILLE	94SB3410	808	0.837
452	565	ANNA STREET	94LA780	465	0.832
453	500	BEEVILLE	94CN8510	871	0.828
454	32	PORT ISABEL S.S.	94SB3760	2,126	0.823
455	646	ANNA STREET	94LA900	2,899	0.819
456	167	HIGHWAY 9	94CS6720	1,311	0.813
457	33	SUNCHASE	94SB1155	1,445	0.794
458	229	BAY CITY	94CN2050	510	0.794
459	428	HIGHWAY 9	94CS6780	801	0.792
460	619	SINTON	94CS360	301	0.787
461	621	GATEWAY	94LA390	1,195	0.782
462	326	PHARR	94SB1640	1,104	0.777
463	427	DEL RIO CITY	94LA9790	2,524	0.775
464	127	CABANISS	94CS240	1,464	0.773
465	440	ASHERTON	94LA2660	665	0.771
466	39	MORRIS STREET	94CS8715	1,595	0.771
467	712	COMSTOCK	94LA230	181	0.768
468	502	EL CAMPO	94CN2800	1,319	0.763
469	595	PALMHURST	94SB2820	1,653	0.758
470	30	DARST	94CN790	247	0.757
471	560	STADIUM	94LA7800	673	0.749
472	682	PORTLAND	94CS9370	1,471	0.742
473	115	SOUTH SANTA ROSA	94SB1235	627	0.740
474	484	ODEM	94CS375	1,020	0.735
475	154	WESMER	94SB6900	1,564	0.733
476	405	BEEVILLE	94CN490	986	0.728
477	509	NIXON	94CN2620	558	0.703
478	332	CLARKWOOD	94CS9570	1,119	0.699
479	380	ARANSAS PASS	94CS8270	605	0.694
480	188	WEST OSO	94CS9090	1,672	0.691
481	465	GOODWIN	94SB3530	1,502	0.686
482	93	GOODWIN	94SB4625	353	0.680
483	58	GREGORY	94CS8560	852	0.670
484	551	BAY CITY	94CN5960	1,801	0.656
485	170	EAGLE PASS CITY	94LA2770	2,981	0.649
486	350	NIXON	94CN810	523	0.646
487	479	MINES ROAD	94LA3680	934	0.643
488	171	SOUTH SANTA ROSA	94SB1215	1,646	0.637
489	478	NORTH EDINBURG	94SB560	1,004	0.635
490	507	SEAWALL	94CS9420	826	0.631
491	473	LOLITA	94CN6330	27	0.630
492	494	HIGHWAY 9	94CS9830	141	0.624
493	526	EL CAMPO	94CN2860	829	0.612
494	424	INGLESIDE CITY	94CS2495	257	0.611
495	184	NAVAL BASE	94CS8440	1,607	0.607
496	209	RIO RICO	94SB5050	1,699	0.605
497	394	RODD FIELD	94CS205	1,630	0.598
498	64	ALAZAN	94CS2740	32	0.594
499	120	DEL RIO CITY	94LA1930	1,037	0.590
500	385	KINGSVILLE	94CS1130	2,180	0.589
501	new	MINES ROAD	94LA4275	17	0.588
502	85	SOUTH MISSION	94SB3980	1,244	0.582
503	615	HARLINGEN	94SB360	2,474	0.578
504	513	NORTH VICTORIA	94CN7770	811	0.575
505	315	CITRUS CITY	94SB3470	3,364	0.574
506	489	MALONE	94CN7550	177	0.571
507	49	ASPHALT MINES	94LA500	39	0.564

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
508	336	BEEVILLE	94CN2200	775	0.559
509	28	PARKER	94CN9010	18	0.556
510	575	MAGRUDER	94CN7870	1,311	0.554
511	563	SIERRA VISTA	94LA7360	2,611	0.553
512	55	SAN BENITO	94SB4030	2,441	0.547
513	441	POLK AVENUE	94SB4180	1,186	0.546
514	547	KLEBERG	94CS1560	1,345	0.545
515	611	NORTH MCALLEN	94SB2980	1,687	0.545
516	557	ALICE	94LA1780	274	0.544
517	61	SOUTH PADRE ISLAND	94SB4695	1,373	0.538
518	321	EAST HARRISON	94SB4360	1,715	0.538
519	559	POLK AVENUE	94SB4900	3,053	0.538
520	97	RIO GRANDE CITY	94SB3230	2,494	0.534
521	639	RACHAL	94LA6595	296	0.527
522	543	SAN DIEGO	94LA2890	1,053	0.527
523	552	BAY CITY	94CN6450	949	0.527
524	227	SINTON	94CS180	920	0.526
525	652	STADIUM	94LA6950	545	0.516
526	643	SKIDMORE	94CS600	365	0.515
527	219	SAN BENITO	94SB3920	2,418	0.505
528	693	NORTH VICTORIA	94CN2240	783	0.502
529	688	POLK AVENUE	94SB4610	1,352	0.500
530	582	KLEBERG	94CS6410	443	0.497
531	216	LOS FRESNOS	94SB7270	2,035	0.497
532	305	HEARN ROAD	94CS8990	1,174	0.497
533	136	POLK AVENUE	94SB4600	2,668	0.497
534	226	FULTON	94CS9050	1,613	0.495
535	456	LIVE OAK	94CS1070	2,797	0.495
536	15	GOODWIN	94SB4390	406	0.490
537	583	SOUTH MISSION	94SB3620	1,876	0.490
538	425	EDROY	94CS6980	190	0.489
539	391	NORTH VICTORIA	94CN6390	1,601	0.488
540	88	LA PRYOR	94LA2440	678	0.485
541	423	SAN BENITO	94SB3910	1,756	0.482
542	662	LAGUNA	94CS9065	2,021	0.481
543	721	ROCKPORT	94CS5940	40	0.475
544	522	ALICE	94LA1770	1,611	0.475
545	447	EAST HARRISON	94SB3030	709	0.474
546	243	LEARY LANE	94CN1890	1,599	0.472
547	533	STADIUM	94LA7810	1,651	0.472
548	249	ARANSAS PASS	94CS9130	358	0.469
549	375	CASA BLANCA	94CS1300	997	0.468
550	338	DEVINE	94LA7100	958	0.466
551	114	PLEASANTON	94LA120	1,237	0.451
552	368	WESMER	94SB4480	1,085	0.448
553	406	WESLACO UNIT	94SB2195	1,090	0.447
554	75	GARCENO	94SB2130	3,040	0.444
555	515	FULTON	94CS2020	1,795	0.443
556	486	WESLACO UNIT	94SB9805	1,748	0.442
557	340	ROCKPORT	94CS5950	542	0.439
558	437	WESLACO UNIT	94SB5970	2,949	0.437
559	179	ELSA	94SB3500	1,136	0.434
560	123	BUENA VISTA	94LA9385	2,105	0.430
561	635	BAY CITY	94CN7480	1,908	0.425
562	281	HAIN DRIVE	94SB9690	827	0.421
563	145	WEAVER ROAD	94CN1910	361	0.421
564	84	WESMER	94SB7760	2,393	0.421
565	199	HAIN DRIVE	94SB270	977	0.419
566	527	RAYMONDVILLE #1	94SB630	780	0.419
567	386	PALACIOS	94CN6840	1,518	0.418
568	372	CLARKWOOD	94CS5525	975	0.416
569	530	DEL RIO CITY	94LA440	841	0.409
570	233	PORTLAND	94CS6505	1,660	0.408
571	36	LA GRULLA	94SB6150	1,100	0.405

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
572	173	WASHINGTON STREET	94LA2350	2,942	0.402
573	573	NAVAL BASE	94CS1380	2,309	0.400
574	new	MAGNOLIA	94CN2840	10	0.400
575	43	ELSA	94SB3520	422	0.398
576	623	COLUMBUS	94CN9060	368	0.386
577	161	PALMHURST	94SB2535	1,169	0.383
578	290	EL CAMPO	94CN6370	724	0.383
579	286	PALMVIEW	94SB6790	2,958	0.383
580	306	HAIN DRIVE	94SB8065	1,311	0.381
581	670	KINGSVILLE	94CS1140	1,058	0.381
582	641	MOORE FIELD	94SB3960	1,790	0.379
583	342	DEL MAR	94LA7930	1,301	0.377
584	656	PREMONT	94LA2720	788	0.371
585	640	BRACKETTVILLE	94LA8460	1,142	0.370
586	497	SABINAL	94LA485	480	0.365
587	490	POINT COMFORT	94CN6060	56	0.357
588	201	INGLESIDE CITY	94CS8050	1,335	0.346
589	203	WESLACO UNIT	94SB7455	1,209	0.345
590	556	WESLACO UNIT	94SB8195	1,684	0.334
591	564	BROWNSVILLE	94SB4280	270	0.333
592	277	MCCOLL ROAD	94SB4400	1,199	0.333
593	566	NORTH VICTORIA	94CN1580	1,038	0.331
594	182	SAN DIEGO	94LA1980	595	0.328
595	610	LEARY LANE	94CN1540	1,049	0.325
596	241	VILLA CAVAZOS	94SB7615	961	0.323
597	698	EAST HARRISON	94SB3080	364	0.321
598	158	DEL RIO CITY	94LA9850	904	0.317
599	590	STADIUM	94LA8540	1,609	0.310
600	275	FULTON	94CS440	2,031	0.307
601	633	ARANSAS PASS	94CS590	421	0.306
602	314	VICTORIA POWER PLANT	94CN8070	613	0.305
603	301	SOUTH EAST EDINBURG	94SB4570	1,354	0.305
604	504	WADSWORTH	94CN7660	1,316	0.300
605	487	MAGRUDER	94CN7690	591	0.298
606	392	EAGLE PASS CITY	94LA2745	910	0.290
607	225	POLK AVENUE	94SB4190	1,706	0.290
608	362	SOUTH MISSION	94SB4650	998	0.285
609	671	HARLINGEN	94SB3370	1,174	0.284
610	348	AIRLINE	94CS6970	1,227	0.284
611	642	FULTON	94CS3070	1,584	0.278
612	449	PALMVIEW	94SB7595	2,658	0.273
613	505	SOUTH MCALLEN	94SB3850	797	0.272
614	232	WASHINGTON STREET	94LA6525	2,072	0.264
615	124	NORTH MCALLEN	94SB9660	1,975	0.262
616	503	PALMHURST	94SB3890	2,362	0.260
617	600	MALONE	94CN7560	102	0.255
618	666	SOUTH MISSION	94SB5215	1,241	0.255
619	468	HARLINGEN	94SB660	1,898	0.254
620	665	NORTH MCALLEN	94SB4995	1,914	0.246
621	82	LA GRULLA	94SB5110	1,352	0.245
622	523	HEARN ROAD	94CS2220	1,516	0.245
623	568	HEARN ROAD	94CS9665	570	0.244
624	297	LAREDO PLANT	94LA8505	774	0.242
625	96	NORTH WESLACO	94SB4830	495	0.240
626	373	ELSA	94SB700	1,400	0.240
627	622	ARCADIA	94CS5020	1,519	0.240
628	696	NORTH MCALLEN	94SB5055	3,094	0.237
629	256	HOLLY	94CS7740	1,987	0.237
630	448	MCKENZIE ROAD	94CS330	2,261	0.237
631	344	THOMASTON	94CN9580	47	0.234
632	609	MATHIS	94CS1420	930	0.233
633	435	WEST MCALLEN	94SB4535	2,795	0.230
634	new	EL GATO	94SB780	1,676	0.227
635	617	EAGLE PASS CITY	94LA2650	1,308	0.227

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
636	379	MCCOLL ROAD	94SB4790	1,906	0.225
637	378	WASHINGTON STREET	94LA7015	1,516	0.224
638	285	FREER	94LA5200	1,057	0.222
639	719	THREE RIVERS	94CN5100	36	0.222
640	320	REFUGIO	94CN1210	205	0.220
641	606	SKIDMORE	94CS380	333	0.210
642	676	AIRLINE	94CS9605	706	0.208
643	540	SOUTHSIDE	94CS8045	1,017	0.206
644	133	LAREDO PLANT	94LA8695	1,011	0.201
645	496	SHARYLAND	94SB5635	1,922	0.196
646	189	ZACATE CREEK	94LA2665	1,671	0.195
647	708	AIRLINE	94CS5870	883	0.194
648	544	ARANSAS PASS	94CS660	740	0.191
649	40	PORT ARANSAS	94CS3030	817	0.190
650	628	MORRIS STREET	94CS8840	608	0.186
651	589	CRESTONIO	94LA6660	769	0.186
652	653	ANNA STREET	94LA850	1,603	0.185
653	562	PUEBLO	94LA130	1,331	0.183
654	704	LAREDO HEIGHTS	94LA6820	2,090	0.179
655	187	WEIL TRACT (138/12KV)	94CS2520	545	0.172
656	300	PALMHURST	94SB2530	1,795	0.168
657	395	HOLLY	94CS5820	928	0.163
658	711	MCCOLL ROAD	94SB4780	2,165	0.160
659	601	NORTH EDINBURG	94SB3570	1,795	0.159
660	381	WEIL TRACT (138/12KV)	94CS1990	1,277	0.159
661	433	PALMVIEW	94SB9680	970	0.156
662	112	SOUTH MCALLEN	94SB3790	1,880	0.154
663	679	REFUGIO	94CN1170	877	0.153
664	355	DEL MAR	94LA10	1,903	0.152
665	53	FASHING	94CN8160	33	0.152
666	384	PALMHURST	94SB2525	1,930	0.152
667	296	HIGHWAY 9	94CS7200	657	0.151
668	508	KLEBERG	94CS280	1,059	0.151
669	298	EAGLE PASS CITY	94LA7060	844	0.143
670	374	LEARY LANE	94CN6175	1,645	0.143
671	183	ZACATE CREEK	94LA2635	253	0.142
672	466	LAREDO PLANT	94LA8745	719	0.140
673	324	EAST HARRISON	94SB4310	1,145	0.139
674	636	MATHIS	94CS1410	458	0.133
675	614	SOUTHSIDE	94CS5345	397	0.131
676	168	ROCKSPRINGS	94LA2600	381	0.131
677	20	PALMVIEW	94SB9685	2,805	0.128
678	213	BUENA VISTA	94LA8965	924	0.128
679	706	RODD FIELD	94CS1730	2,096	0.128
680	410	ARANSAS PASS	94CS1250	386	0.127
681	647	WEST MCALLEN	94SB4815	701	0.127
682	663	HAIN DRIVE	94SB9700	751	0.125
683	657	KINGSVILLE	94CS1670	420	0.124
684	477	HIGHWAY 9	94CS6760	667	0.123
685	365	LAREDO PLANT	94LA8565	1,363	0.123
686	408	DEL MAR	94LA220	1,800	0.120
687	69	AIRLINE	94CS8370	271	0.118
688	644	LAREDO HEIGHTS	94LA2390	1,687	0.114
689	41	CABANISS	94CS75	2,045	0.114
690	548	PALMVIEW	94SB3930	1,081	0.111
691	257	HIDALGO	94SB3680	328	0.110
692	535	NORTH EDINBURG	94SB3810	887	0.109
693	111	GARCENO	94SB2135	2,093	0.105
694	new	CLARKWOOD	94CS2170	10	0.100
695	135	ODEM	94CS5575	61	0.098
696	178	ZACATE CREEK	94LA2675	1,162	0.094
697	128	MILO	94LA3070	3,224	0.088
698	172	WASHINGTON STREET	94LA6355	1,067	0.083
699	629	AIRLINE	94CS8260	1,498	0.081

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIFI Ranking	2011 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIFI Value
700	444	DEL MAR	94LA3440	1,395	0.078
701	76	SINTON	94CS1750	506	0.075
702	401	CLARKWOOD	94CS7220	415	0.072
703	703	ANNA STREET	94LA2250	1,567	0.070
704	451	MORRIS STREET	94CS7465	641	0.069
705	261	RODD FIELD	94CS245	2,553	0.069
706	699	AIRLINE	94CS9390	1,874	0.062
707	702	EL CAMPO	94CN7260	531	0.062
708	231	HALL ACRES ROAD	94SB9595	1,126	0.060
709	new	EL GATO	94SB720	2,429	0.060
710	411	WASHINGTON STREET	94LA2470	188	0.059
711	452	SAN BENITO	94SB3860	241	0.058
712	109	SOUTH MCALLEN	94SB3640	304	0.053
713	403	EAST HARRISON	94SB3000	525	0.046
714	674	ANNA STREET	94LA5780	705	0.040
715	387	RODD FIELD	94CS3010	1,889	0.038
716	352	SOUTH MISSION	94SB3940	801	0.037
717	669	BEEVILLE	94CN2380	211	0.028
718	356	WASHINGTON STREET	94LA2360	192	0.021
719	new	EL GATO	94SB890	2,828	0.019
720	717	MCCOLL ROAD	94SB4910	328	0.018
721	new	EL GATO	94SB910	2,422	0.013
722	714	MILO	94LA8365	1,809	0.013
723	390	ROCKSPRINGS	94LA8040	334	0.009
724	649	SIERRA VISTA	94LA3540	337	0.006
725	72	CAUSEWAY	94SB4775	1,057	0.006
726	121	SOUTH MCALLEN	94SB5065	111	-
727	701	HAIN DRIVE	94SB9240	45	-
728	720	VICTORIA POWER PLANT	94CNNETVIC	77	-
729	722	MORRIS STREET	94CSNET CC	359	-
730	723	WASHINGTON STREET	94LANETLAR	181	-
731	new	FOSTER FIELD	94CN8880	10	-

Feeders from last year that are not in this year's list

2011 Ranking	Substation Identification
none	

Feeder ID	Reason not in 2012

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

731

Add or Delete Rows as Necessary

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
1	1	GOVERNMENT WELLS	94LA6800	217	2,978.1
2	155	LA PRYOR	94LA570	142	2,382.4
3	19	JOURDANTON	94LA250	760	1,825.6
4	58	MAVERICK	94LA9680	725	1,484.9
5	94	SAN YGNACIO	94LA16060	477	1,215.7
6	12	TATTON	94CN8490	125	1,187.1
7	540	PETTUS	94CN8210	372	1,176.4
8	34	CONTINENTAL	94SB4080	63	1,140.4
9	239	CAMPWOOD	94LA3430	82	1,010.2
10	349	THREE RIVERS	94CN8430	180	984.4
11	517	CARRIZO SPRINGS	94LA910	2,088	943.7
12	314	MOORE FIELD	94SB3120	128	927.8
13	522	JOURDANTON	94LA5685	559	923.9
14	4	GOVERNMENT WELLS	94LA7240	203	891.0
15	182	LOS FRESNOS	94SB4315	964	889.6
16	482	PETTUS	94CN1020	396	881.4
17	172	ELSA	94SB710	1,747	806.9
18	26	RAYMONDVILLE #2	94SB3250	28	798.6
19	33	RAYMONDVILLE #2	94SB3170	704	732.0
20	109	ELSA	94SB690	2,255	707.0
21	378	PALACIOS	94CN8550	38	699.2
22	201	JOURDANTON	94LA880	297	686.4
23	37	FREER	94LA1500	198	679.1
24	10	LA PRYOR	94LA580	199	669.4
25	391	BRUNI	94LA5440	127	621.3
26	365	CONOCO-CHITAM RANCH	94LA8580	31	618.3
27	11	CARRIZO SPRINGS	94LA860	1,377	605.7
28	63	GREGORY	94CS5900	107	577.1
29	221	DEVINE	94LA8100	1,520	577.0
30	466	O CONNER	94CN390	210	566.1
31	204	BROWNSVILLE	94SB3050	1,945	557.7
32	46	ASHERTON	94LA2670	260	556.6
33	370	CRESTONIO	94LA260	1,790	549.7
34	108	KNIPPA	94LA6535	21	546.6
35	238	SOUTHSIDE	94CS5335	1,142	541.3
36	217	POINT COMFORT	94CN2460	350	538.8
37	96	CRYSTAL CITY	94LA330	1,293	530.1
38	136	MARKHAM	94CN5550	100	528.3
39	133	RANDADO	94LA8350	130	516.9
40	30	NORTH EDINBURG	94SB4240	2,221	514.0
41	256	SABINAL	94LA200	413	509.3
42	479	DILLEY	94LA6400	908	489.0
43	88	NAVAL BASE	94CS6330	322	479.5
44	223	BROWNSVILLE	94SB4290	382	479.4
45	229	NORTH ALAMO	94SB3580	818	477.9
46	5	RIO RICO	94SB8290	365	472.9
47	232	STAFFORD HILL	94CN1550	216	467.2
48	315	MORRIS STREET	94CS8830	1,555	462.4
49	245	BRUNI	94LA1120	136	459.4
50	442	JOURDANTON	94LA5695	1,313	450.1
51	296	WADSWORTH	94CN8630	643	448.3
52	718	CHASE FIELD	94CN460	15	442.7
53	7	BIG WELLS	94LA2630	26	441.8
54	61	BLESSING	94CN1030	254	437.2
55	6	SOUTH PADRE ISLAND	94SB4675	151	428.2
56	31	PORT ISABEL S S	94SB4070	292	399.2
57	532	MAGRUDER	94CN245	1,096	394.9
58	153	GOLIAD	94CN6540	1,147	389.3
59	434	VILLA CAVAZOS	94SB1980	1,511	388.5
60	390	CARRIZO SPRINGS	94LA370	525	387.2
61	142	ALAZAN	94CS620	166	386.8
62	512	ZAPATA	94LA8300	1,694	386.0
63	400	ZAPATA	94LA7330	1,334	385.6
64	255	PLACEDO	94CN7980	402	384.7
65	130	THREE RIVERS	94CN2580	96	380.9
66	156	LULING - LCRA	94CN20	279	380.5
67	126	ENCINAL	94LA2160	874	379.5
68	381	NORTH VICTORIA	94CN7430	1,740	378.7
69	523	PHARR	94SB1625	2,131	376.5
70	132	ALICE	94LA2540	1,147	371.2
71	85	KENEDY	94CN1970	667	370.9
72	17	PARKER	94CN9260	106	367.5
73	250	GREENLAKE	94CN2760	573	366.2

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
74	181	MUSTANG ISLAND	94CS8510	410	365.3
75	306	BLESSING	94CN8790	741	363.8
76	268	PLEASANTON	94LA2080	1,587	361.4
77	538	PORT LAVACA	94CN2480	1,539	360.3
78	510	DILLEY	94LA510	517	359.6
79	364	HAMILTON ROAD	94LA9655	1,214	356.9
80	219	MORRIS STREET	94CS8820	1,254	356.3
81	348	SOUTH MCALLEN	94SB3935	1,294	356.2
82	113	PLEASANTON	94LA9475	1,328	351.6
83	481	BROOKHOLLOW	94CN8950	869	349.7
84	636	MCKENZIE ROAD	94CS140	256	347.7
85	367	TAFT	94CS1180	1,053	340.5
86	383	WEST MCALLEN	94SB4555	1,491	340.2
87	43	NORDHEIM	94CN470	245	338.6
88	227	PORT ARANSAS	94CS990	1,418	336.6
89	541	BEEVILLE	94CN300	1,709	335.7
90	41	BERCLAIR	94CN990	330	335.3
91	357	HIDALGO	94SB3400	850	332.4
92	627	WOODSBORO	94CS8330	1,088	328.1
93	292	COTULLA	94LA90	842	325.5
94	498	VICTORIA POWER PLANT	94CN7600	152	322.7
95	59	ALICE	94LA2530	1,456	319.5
96	168	NORTH ALAMO	94SB4370	1,459	315.9
97	716	MCKENZIE ROAD	94CS150	25	315.4
98	187	GREENLAKE	94CN2740	30	314.6
99	35	CHARLOTTE	94LA2790	101	313.2
100	215	UNIVERSITY	94LA950	2,908	310.5
101	379	THREE RIVERS	94CN5190	895	309.8
102	461	WEAVER ROAD	94CN1900	52	307.4
103	148	EAST HARRISON	94SB3950	553	307.2
104	234	AMISTAD DAM	94LA5450	1,144	300.7
105	53	CONTINENTAL	94SB3650	23	298.3
106	102	CRESTONIO	94LA270	613	294.1
107	604	TATTON	94CS8200	1,006	290.2
108	548	BISHOP	94CS7180	935	290.1
109	343	MAGRUDER	94CN6700	1,360	287.9
110	423	CITRUS CITY	94SB9775	1,455	287.5
111	602	SANTO NINO	94LA70	1,141	287.5
112	2	FREER	94LA2900	156	286.4
113	228	LULING - LCRA	94CN10	356	281.5
114	351	MORRIS STREET	94CS5655	959	278.2
115	578	BANDERA ELECTRIC (LEAKEY)	94LAL30	259	277.2
116	316	HALL ACRES ROAD	94SB5585	686	275.6
117	547	PHARAOH	94CS5175	990	274.2
118	120	LAGUNA	94CS9590	2,179	269.7
119	104	NORTH VICTORIA	94CN7440	1,617	268.9
120	66	HIDALGO	94SB4845	1,090	266.7
121	207	RAYMONDVILLE #1	94SB620	619	263.3
122	593	FULTON	94CS6070	3,201	261.6
123	649	UNIVERSITY	94LA920	290	260.9
124	211	PEARSALL	94LA9905	750	260.3
125	202	MCCOLL ROAD	94SB2810	2,344	260.1
126	165	BIG WELLS	94LA1570	463	258.5
127	167	HIGHWAY 9	94CS6780	801	257.6
128	70	GOODWIN	94SB7380	2,161	257.4
129	273	UVALDE	94LA550	667	257.0
130	427	TAFT	94CS1260	184	256.2
131	645	HALL ACRES ROAD	94SB8870	1,942	254.9
132	331	BAY CITY	94CN6670	1,776	254.8
133	25	GREENLAKE	94CN2750	1,127	252.2
134	50	WESLACO UNIT	94SB7630	1,822	251.0
135	91	NORTH PADRE ISLAND	94CS5170	1,127	250.8
136	107	FALFURRIAS	94LA5210	1,115	250.2
137	591	ARCADIA	94CS1460	2,142	250.2
138	374	MATTHEWS	94CN1740	162	249.8
139	329	VICTORIA POWER PLANT	94CN1390	1,155	249.6
140	330	SANTO NINO	94LA695	1,537	249.3
141	414	GILA	94CS7840	51	248.4
142	60	NORTH PADRE ISLAND	94CS720	1,083	247.3
143	337	MAGRUDER	94CN6690	562	245.4
144	519	WEST OSO	94CS9095	1,588	244.4
145	164	LOS FRESNOS	94SB5335	1,974	243.8
146	463	INGLESIDE CITY	94CS6040	246	243.2
147	402	ZAPATA	94LA8290	2,074	241.9
148	42	CARANCAHUA	94CN5870	454	241.8
149	193	PRAIRIE PUMP	94CN1940	69	241.7
150	304	LOS FRESNOS	94SB2160	1,133	241.3
151	143	MORRIS STREET	94CS8850	484	240.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
152	115	BONNIEVIEW	94CS8020	505	240.6
153	40	PORT ARANSAS	94CS1000	1,507	240.6
154	54	NORTH MERCEDES	94SB3840	643	240.3
155	161	HARLINGEN	94SB380	2,333	239.2
156	496	NORTH VICTORIA	94CN1470	437	238.8
157	140	ESCONDIDO	94LA2035	2,545	238.7
158	626	ROMA	94SB3070	1,246	238.4
159	617	GREGORY	94CS5920	607	236.2
160	380	VILLA CAVAZOS	94SB5680	1,691	235.7
161	21	CONTINENTAL	94SB4880	60	232.8
162	609	MAGRUDER	94CN6680	695	232.0
163	62	SOUTH PADRE ISLAND	94SB6440	2,492	231.1
164	171	WEST MCALLEN	94SB4515	799	230.9
165	64	GILA	94CS350	813	230.6
166	393	PHARAOH	94CS1365	443	230.3
167	200	GARWOOD CITY	94CN2560	196	229.0
168	276	RIO BRAVO	94LA5	691	225.7
169	303	MUSTANG ISLAND	94CS9470	657	224.6
170	595	CHARLOTTE	94LA2780	558	224.0
171	14	WEST OSO	94CS9085	767	223.2
172	87	ARMSTRONG	94CS6050	69	223.2
173	371	MINES ROAD	94LA3745	1,611	223.1
174	23	GOVERNMENT WELLS	94LA7250	594	222.8
175	236	RAYMONDVILLE #2	94SB3240	974	222.5
176	22	CAUSEWAY	94SB4765	971	221.9
177	150	MARKHAM	94CN6440	433	219.1
178	399	BAY CITY	94CN2700	1,063	218.5
179	192	WEST MCALLEN	94SB6385	208	217.7
180	184	WESLACO UNIT	94SB8610	1,155	216.0
181	310	PALMHURST	94SB1300	1,929	212.8
182	39	ZAPATA	94LA2710	44	211.4
183	67	BUENA VISTA	94LA9035	1,502	209.8
184	340	RACHAL	94LA8145	355	209.0
185	3	PORT ISABEL S.S.	94SB3820	206	208.2
186	213	SIERRA VISTA	94LA9900	2,321	207.5
187	80	UVALDE	94LA6620	2,730	207.3
188	408	WESMER	94SB9705	1,083	207.2
189	489	SOUTHSIDE	94CS8005	743	206.8
190	490	HALL ACRES ROAD	94SB4895	816	206.1
191	431	ODEM	94CS385	397	205.9
192	484	GEORGE WEST	94CN1320	752	205.5
193	513	PLEASANTON	94LA9505	1,503	205.0
194	82	GANADO	94CN5815	597	203.8
195	410	AIRLINE	94CS9030	417	200.5
196	318	PORT LAVACA	94CN8310	314	199.4
197	170	PORT ISABEL S.S.	94SB9295	637	199.3
198	527	SOUTHSIDE	94CS7955	1,042	198.7
199	101	FALFURRIAS	94LA1080	441	196.3
200	695	GOLIAD	94CN8220	1,040	195.8
201	145	NORTH PADRE ISLAND	94CS7900	1,271	195.0
202	249	GILA	94CS345	49	194.2
203	631	WEST MCALLEN	94SB4595	1,168	193.5
204	682	RAYMONDVILLE #1	94SB800	684	193.0
205	175	PALACIOS	94CN6830	801	191.4
206	49	OLMITO	94SB4275	764	191.1
207	706	MILO	94LA3060	110	190.3
208	433	SOUTH SANTA ROSA	94SB7485	1,018	190.2
209	277	POLK AVENUE	94SB4520	911	190.1
210	289	BRUNI	94LA1100	635	189.7
211	664	ALICE	94LA1790	344	187.1
212	611	EAGLE LAKE	94CN310	722	186.8
213	456	NORTH PADRE ISLAND	94CS1010	2,548	186.4
214	180	LEARY LANE	94CN7530	2,066	184.5
215	205	CRYSTAL CITY	94LA140	768	183.4
216	169	COFFEE PORT	94SB1090	1,154	183.3
217	24	RIO RICO	94SB8330	389	183.2
218	293	PORT ARANSAS	94CS6940	1,601	180.9
219	127	DEL RIO CITY	94LA420	2,218	180.9
220	698	RAYMONDVILLE #1	94SB3130	279	179.8
221	670	MILO	94LA6940	644	179.8
222	633	LAREDO HEIGHTS	94LA2450	2,523	179.4
223	660	GARWOOD CITY	94CN2570	134	178.4
224	135	CAMPWOOD	94LA2610	945	175.3
225	114	EL CAMPO	94CN7710	1,057	174.5
226	300	PUEBLO	94LA95	2,120	174.5
227	653	RAYMONDVILLE #2	94SB1280	1,065	173.3
228	444	PUEBLO	94LA275	2,755	173.3
229	405	CITRUS CITY	94SB7985	1,660	173.3

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
230	319	SOUTH EAST EDINBURG	94SB5045	1,853	172.6
231	166	MILO	94LA3065	184	171.8
232	86	ASHERTON	94LA2660	665	169.9
233	105	PEARSALL	94LA7050	1,550	168.8
234	258	FALFURRIAS	94LA1070	1,037	168.2
235	576	LEARY LANE	94CN6005	1,796	167.8
236	646	WOOLRIDGE	94CS1120	2,540	163.8
237	308	LEARY LANE	94CN1430	1,580	163.3
238	89	PHARAOH	94CS1185	1,557	162.5
239	389	ARCADIA	94CS1450	1,914	162.3
240	311	THREE RIVERS	94CN2010	1,143	162.0
241	48	PREMONT	94LA6570	720	162.0
242	386	PHARR	94SB1645	2,590	161.0
243	27	BLESSING	94CN8780	63	161.0
244	411	OLMITO	94SB905	1,467	160.9
245	233	YORKTOWN	94CN8420	1,079	160.7
246	336	RIO GRANDE CITY	94SB3210	1,766	160.6
247	163	UVALDE	94LA9770	1,381	159.9
248	476	GEORGE WEST	94CN730	965	159.3
249	195	EAGLE LAKE	94CN320	632	156.5
250	332	REFUGIO	94CN1040	179	156.0
251	590	WOOLRIDGE	94CS1170	734	155.6
252	188	GRETA	94CN7890	322	154.6
253	640	POLK AVENUE	94SB4740	1,902	154.5
254	189	SOUTH SANTA ROSA	94SB1240	1,578	153.6
255	335	SOUTH EAST EDINBURG	94SB6580	1,351	153.6
256	361	ARCADIA	94CS1360	1,540	153.5
257	501	ARCADIA	94CS1400	432	153.5
258	404	SAN DIEGO	94LA2930	601	153.1
259	459	KLEBERG	94CS8000	1,469	152.8
260	243	HALL ACRES ROAD	94SB3460	3,302	152.4
261	493	UVALDE	94LA540	1,211	152.2
262	539	SOUTH EAST EDINBURG	94SB4550	2,121	151.8
263	265	MORRIS STREET	94CS2515	1,093	150.6
264	76	PLACEDO	94CN7970	462	150.6
265	673	DEL MAR	94LA490	751	150.3
266	95	FOSTER FIELD	94CN2550	332	150.2
267	194	NIXON	94CN5990	634	150.0
268	147	MORRIS STREET	94CS7625	561	149.6
269	515	BAY CITY	94CN1110	1,277	148.5
270	284	SANTO NINO	94LA80	2,374	148.3
271	619	DEVINE	94LA7090	944	147.7
272	354	WEST HARLINGEN	94SB3800	1,324	147.1
273	452	ARCADIA	94CS6930	1,499	146.3
274	174	SOUTHSIDE	94CS7925	1,326	146.0
275	703	BROOKHOLLOW	94CN7190	265	145.8
276	29	CAUSEWAY	94SB4795	1,199	145.5
277	28	CRYSTAL CITY	94LA190	1,545	145.4
278	492	HARLINGEN S.S.	94SB320	1,492	144.6
279	717	AIRLINE	94CS7270	1,011	143.9
280	287	WESMER	94SB4480	1,085	143.9
281	713	KENEDY	94CN1960	64	143.7
282	455	ESCONDIDO	94LA1510	710	143.0
283	407	CASA BLANCA	94CS55	828	142.8
284	121	SAN DIEGO	94LA2880	1,284	142.4
285	83	GANADO	94CN5795	470	141.6
286	261	STADIUM	94LA7490	1,289	141.6
287	75	BANQUETTE	94CS130	228	141.4
288	641	ARCADIA	94CS5030	1,567	141.0
289	486	LIVE OAK	94CS1080	796	140.9
290	686	HAIN DRIVE	94SB3490	1,071	139.7
291	546	STADIUM	94LA7800	673	139.4
292	139	UVALDE	94LA5060	1,311	139.1
293	20	ALAZAN	94CS2740	32	138.4
294	507	ARANSAS PASS	94CS650	748	137.8
295	449	NORTH ALAMO	94SB3610	1,770	137.4
296	269	PREMONT	94LA2730	207	137.3
297	488	SHARYLAND	94SB5105	1,589	136.8
298	106	ELSA	94SB3520	422	135.7
299	264	WEST HARLINGEN	94SB3700	1,691	134.9
300	465	MATHIS	94CS2870	871	134.8
301	714	SOUTH EAST EDINBURG	94SB4015	421	134.1
302	244	EAGLE LAKE	94CN9455	575	133.6
303	409	RUNGE	94CN7320	647	133.5
304	210	ARCADIA	94CS8570	1,434	133.4
305	668	NORTH MCALLEN	94SB3830	1,263	133.4
306	262	WEST HARLINGEN	94SB3720	1,884	133.3
307	562	BROOKHOLLOW	94CN7580	447	132.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
308	544	MOORE FIELD	94SB3110	640	132.2
309	635	PEARSALL	94LA5580	1,601	132.1
310	297	KENEDY	94CN6270	524	131.0
311	473	SOUTHSIDE	94CS8035	1,087	130.5
312	671	NORTH MCALLEN	94SB9640	1,384	130.4
313	403	BEEVILLE	94CN8090	1,334	130.3
314	684	WEST MCALLEN	94SB4965	697	129.6
315	93	WESMER	94SB1850	1,244	129.4
316	401	WESMER	94SB4050	1,912	128.7
317	112	PREMONT	94LA6610	816	128.2
318	149	WEIL TRACT (138/12KV)	94CS5405	157	127.9
319	280	HOLLY	94CS1950	803	127.4
320	240	RIO BRAVO	94LA1130	942	126.9
321	526	CHARLOTTE	94LA8120	199	126.6
322	290	SOUTHSIDE	94CS7995	1,545	125.8
323	321	NORTH MERCEDES	94SB4860	1,397	125.4
324	416	HAMILTON ROAD	94LA9665	945	125.2
325	257	REFUGIO	94CN5120	706	124.8
326	45	RANDADO	94LA8360	161	124.5
327	333	SEAWALL	94CS9450	288	124.5
328	560	ALICE	94LA1780	274	124.5
329	325	LAREDO PLANT	94LA9305	979	124.3
330	561	RANGERVILLE	94SB3410	808	123.6
331	16	CABANISS	94CS80	1,155	123.4
332	582	BISHOP	94CS2690	547	122.5
333	652	CLARKWOOD	94CS7610	200	122.3
334	429	SHARYLAND	94SB6745	1,958	122.2
335	144	LA GRULLA	94SB5005	1,972	122.2
336	683	HARLINGEN S.S.	94SB4090	2,296	120.8
337	119	RODD FIELD	94CS225	1,093	120.8
338	448	HALL ACRES ROAD	94SB3670	859	120.3
339	679	AIRLINE	94CS7390	1,448	119.4
340	137	SOUTH PADRE ISLAND	94SB5850	1,302	119.4
341	173	RANGERVILLE	94SB4060	881	119.4
342	377	POLK AVENUE	94SB4180	1,186	119.0
343	471	NORTH WESLACO	94SB4810	1,356	118.9
344	73	PORT ISABEL S.S.	94SB3760	2,126	118.9
345	387	HEARN ROAD	94CS8980	1,196	118.8
346	468	ESCONDIDO	94LA3350	1,097	117.7
347	462	EAST HARRISON	94SB4620	750	117.3
348	317	LIVE OAK	94CS1090	273	117.0
349	71	KNIPPA	94LA6365	306	116.9
350	286	NORTH MERCEDES	94SB3770	1,687	116.4
351	123	MORRIS STREET	94CS8715	1,595	116.4
352	608	ANNA STREET	94LA900	2,899	115.6
353	581	TYFT	94CS5230	827	115.5
354	275	LYTLE	94LA2850	609	115.0
355	18	NORTH WESLACO	94SB4830	495	115.0
356	116	GREGORY	94CS420	23	114.9
357	428	GATEWAY	94LA3595	1,510	114.7
358	266	CASA BLANCA	94CS5115	280	114.4
359	637	GATEWAY	94LA350	1,695	114.2
360	362	FALFURRIAS	94LA2830	1,473	113.8
361	413	HEARN ROAD	94CS870	1,129	113.5
362	587	HOLLY	94CS1480	1,702	113.0
363	363	EDROY	94CS6990	266	112.5
364	347	BANQUETTE	94CS9000	430	111.8
365	373	HIGHWAY 9	94CS6770	1,158	110.9
366	218	COTULLA	94LA110	1,559	109.2
367	579	KENEDY S.S.	94CN6750	864	108.9
368	632	SOUTHSIDE	94CS7905	1,826	108.6
369	676	COMSTOCK	94LA230	181	108.5
370	176	LA GRULLA	94SB4120	1,412	108.2
371	246	CLARKWOOD	94CS7230	620	108.1
372	543	RIO BRAVO	94LA300	780	107.8
373	607	SAN BENITO	94SB4945	1,759	107.6
374	103	BRUNI	94LA5160	139	106.7
375	678	KINGSVILLE	94CS1350	370	106.6
376	44	SOUTH SANTA ROSA	94SB1225	822	105.8
377	688	KLEBERG	94CS8140	402	105.7
378	392	HIGHWAY 9	94CS7210	334	105.3
379	648	BROOKHOLLOW	94CN8960	579	105.0
380	705	RAYMONDVILLE #2	94SB4160	350	104.8
381	177	NORTH MCALLEN	94SB5060	2,327	103.6
382	687	PORTLAND	94CS9370	1,471	103.6
383	183	SINTON	94CS6860	1,609	102.9
384	505	RACHAL	94LA6595	296	102.8
385	282	RIO RICO	94SB5050	1,699	102.7

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
386	395	PORT LAVACA	94CN6850	593	101.9
387	252	MATHIS	94CS340	1,467	101.7
388	98	HIGHWAY 9	94CS6720	1,311	101.5
389	555	INGLESIDE CITY	94CS8060	1,808	101.2
390	618	LAREDO HEIGHTS	94LA9400	1,411	100.6
391	557	COLUMBUS	94CN930	893	100.4
392	100	GOODWIN	94SB4625	353	100.4
393	552	STADIUM	94LA8540	1,609	99.5
394	657	TATTON	94CS950	534	99.3
395	146	WESMER	94SB6900	1,564	99.0
396	438	EDNA	94CN5785	752	98.7
397	570	PALMHURST	94SB2820	1,653	98.4
398	528	VICTORIA POWER PLANT	94CN8170	763	98.3
399	110	HOMEPORT	94CS4665	438	98.2
400	520	SEAWALL	94CS9325	1,436	97.0
401	344	MALONE	94CN7550	177	96.2
402	397	NORTH EDINBURG	94SB560	1,004	95.7
403	509	LAREDO HEIGHTS	94LA6810	2,066	95.6
404	551	WEST MCALLEN	94SB4505	1,765	95.5
405	366	PORTLAND	94CS9270	1,934	95.0
406	220	SHARYLAND	94SB2020	2,319	94.5
407	564	ROCKPORT	94CS5930	1,109	93.3
408	601	SOUTHSIDE	94CS8025	1,058	93.2
409	259	SOUTH SANTA ROSA	94SB1235	627	93.2
410	295	PORTLAND	94CS9290	1,690	93.1
411	621	GATEWAY	94LA390	1,195	93.0
412	647	POLK AVENUE	94SB4170	1,323	92.8
413	124	KINGSVILLE	94CS1660	1,623	92.3
414	440	MINES ROAD	94LA3680	934	91.7
415	690	SANTO NINO	94LA75	1,525	91.2
416	666	WOOLRIDGE	94CS1110	1,585	91.2
417	694	LAREDO PLANT	94LA8705	211	91.1
418	272	DEL RIO CITY	94LA430	2,505	90.8
419	206	SOUTH MISSION	94SB3590	674	90.6
420	92	PALMHURST	94SB2535	1,169	89.8
421	639	GOODWIN	94SB4380	1,443	88.9
422	323	SHARYLAND	94SB2035	2,257	88.8
423	209	CLARKWOOD	94CS5525	975	87.4
424	398	GOODWIN	94SB3530	1,502	87.0
425	494	FREER	94LA6320	158	86.4
426	475	KENEDY S.S.	94CN8340	972	86.1
427	710	GATEWAY	94LA5055	1,999	86.1
428	662	KLEBERG	94CS9395	1,310	85.9
429	424	PHARAOH	94CS1285	1,743	85.8
430	412	YORKTOWN	94CN8380	821	84.7
431	291	EAGLE PASS CITY	94LA2770	2,981	84.6
432	74	GOODWIN	94SB4390	406	84.2
433	51	COFFEE PORT	94SB1095	966	83.8
434	248	HOLLY	94CS1370	1,872	83.7
435	301	SANTO NINO	94LA515	1,957	83.5
436	199	COLUMBUS	94CN6180	1,214	81.9
437	644	NIXON	94CN2820	558	81.8
438	663	LAGUNA	94CS9065	2,021	80.9
439	508	EL CAMPO	94CN2800	1,319	80.8
440	558	HARLINGEN S.S.	94SB4110	811	80.6
441	13	SOUTH MISSION	94SB3980	1,244	80.4
442	511	HARLINGEN	94SB360	2,474	80.0
443	485	ARCADIA	94CS1440	1,686	79.9
444	567	BEEVILLE	94CN1760	1,813	79.1
445	598	KENEDY S.S.	94CN8320	858	78.7
446	542	KLEBERG	94CS1560	1,345	78.7
447	704	SHARYLAND	94SB2150	1,173	78.4
448	421	INGLESIDE CITY	94CS2495	257	78.3
449	118	UVALDE	94LA480	1,320	77.4
450	573	HALL ACRES ROAD	94SB5465	1,659	77.1
451	614	PHARR	94SB1620	2,330	77.1
452	129	SUNCHASE	94SB1155	1,445	77.0
453	32	DARST	94CN790	247	76.9
454	305	DEVINE	94LA7100	958	76.8
455	596	HARLINGEN S.S.	94SB4230	1,303	76.2
456	503	SEAWALL	94CS9420	826	76.2
457	445	ARANSAS PASS	94CS8270	605	76.1
458	131	NIXON	94CN810	523	75.9
459	154	SOUTH SANTA ROSA	94SB1215	1,646	75.3
460	72	SAN BENITO	94SB4030	2,441	75.2
461	279	BAY CITY	94CN2050	510	75.1
462	658	POLK AVENUE	94SB4610	1,352	74.6
463	630	MAGRUDER	94CN7870	1,311	74.1

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
464	111	SOUTH PADRE ISLAND	94SB4695	1,373	74.1
465	190	EAGLE PASS CITY	94LA2510	593	73.4
466	568	SOUTHSIDE	94CS8055	860	73.2
467	15	ASPHALT MINES	94LA500	39	73.2
468	151	SAN BENITO	94SB4135	1,253	72.3
469	495	EAST HARRISON	94SB4360	1,715	72.2
470	491	MCCOLL ROAD	94SB1655	1,153	71.9
471	267	ZACATE CREEK	94LA2665	1,671	71.9
472	283	ROBSTOWN	94CS1650	351	71.8
473	196	HOLLY	94CS7620	2,507	71.7
474	235	BEEVILLE	94CN490	986	70.8
475	577	ANNA STREET	94LA780	465	70.4
476	324	CLARKWOOD	94CS9570	1,119	70.4
477	566	NAVAL BASE	94CS1380	2,309	70.4
478	606	BAY CITY	94CN5960	1,801	70.3
479	585	NORTH MCALLEN	94SB2980	1,687	70.1
480	696	NORTH VICTORIA	94CN2240	783	69.7
481	415	WESLACO UNIT	94SB5970	2,949	69.7
482	384	ODEM	94CS375	1,020	69.3
483	518	BROWNSVILLE	94SB4280	270	69.1
484	162	EAST HARRISON	94SB3190	1,421	68.7
485	339	HAIN DRIVE	94SB8065	1,311	68.6
486	701	ARANSAS PASS	94CS8280	559	67.3
487	56	LA PRYOR	94LA2440	678	67.1
488	152	EDNA	94CN5765	1,673	67.0
489	556	POLK AVENUE	94SB4900	3,053	66.9
490	575	KLEBERG	94CS6410	443	66.8
491	36	HAMILTON ROAD	94LA9645	288	65.9
492	197	WEST HARLINGEN	94SB4870	725	65.8
493	157	HIGHWAY 9	94CS6730	524	65.8
494	307	RIO GRANDE CITY	94SB3740	2,241	65.3
495	480	EL CAMPO	94CN5745	887	64.2
496	529	HOLLY	94CS9675	1,762	63.8
497	622	BAY CITY	94CN7480	1,908	63.7
498	419	HAIN DRIVE	94SB9690	827	63.6
499	360	SAN BENITO	94SB3920	2,418	63.5
500	178	CITRUS CITY	94SB3470	3,364	63.4
501	458	PHARAOH	94CS5185	2,748	61.9
502	721	ROCKPORT	94CS5940	40	61.7
503	341	LEARY LANE	94CN1890	1,599	61.2
504	487	SANTO NINO	94LA645	1,128	60.7
505	260	WASHINGTON STREET	94LA2350	2,942	60.6
506	534	SIERRA VISTA	94LA7360	2,611	60.0
507	613	BRACKETTVILLE	94LA8460	1,142	59.2
508	128	WEST OSO	94CS9090	1,672	59.1
509	674	SKIDMORE	94CS600	365	59.1
510	565	NORTH VICTORIA	94CN7770	811	58.7
511	224	MCCOLL ROAD	94SB4790	1,906	58.7
512	464	NORTH MCALLEN	94SB2750	3,152	58.4
513	451	LOLITA	94CN6330	27	58.2
514	474	POINT COMFORT	94CN6060	56	58.0
515	530	STADIUM	94LA7810	1,651	57.8
516	38	WEAVER ROAD	94CN1910	361	57.8
517	537	HIGHWAY 9	94CS9830	141	57.6
518	432	MOORE FIELD	94SB3960	1,790	57.5
519	586	SOUTH MISSION	94SB3620	1,876	57.4
520	675	AIRLINE	94CS8890	532	57.3
521	274	LOS FRESNOS	94SB7270	2,035	57.1
522	new	MINES ROAD	94LA4275	17	56.9
523	231	CASA BLANCA	94CS1300	997	56.4
524	406	KINGSVILLE	94CS1130	2,180	55.5
525	439	DEL RIO CITY	94LA9790	2,524	54.8
526	436	EAST HARRISON	94SB3030	709	54.3
527	545	SINTON	94CS360	301	54.2
528	376	BEEVILLE	94CN2200	775	54.2
529	125	CABANISS	94CS240	1,464	53.7
530	467	SAN DIEGO	94LA2890	1,053	53.3
531	514	NAVAL BASE	94CS8440	1,607	52.4
532	597	RIO GRANDE CITY	94SB3220	1,675	52.2
533	122	GREGORY	94CS8560	852	51.9
534	352	EAGLE PASS CITY	94LA450	718	51.8
535	186	FULTON	94CS9050	1,613	51.6
536	84	WESMER	94SB7760	2,393	51.6
537	483	OLMITO	94SB715	534	50.9
538	571	HARLINGEN S.S.	94SB5350	776	50.6
539	222	RIO GRANDE CITY	94SB3230	2,494	49.8
540	580	SAN BENITO	94SB3910	1,756	49.1
541	672	STADIUM	94LA6950	545	48.8

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
542	342	HEARN ROAD	94CS8990	1,174	48.8
543	620	LEARY LANE	94CN1540	1,049	48.8
544	615	BAY CITY	94CN6450	949	48.7
545	422	PHARR	94SB1640	1,104	48.4
546	375	ELSA	94SB700	1,400	48.2
547	612	AIRLINE	94CS7280	622	47.9
548	185	ELSA	94SB3500	1,136	47.9
549	350	POLK AVENUE	94SB4600	2,668	47.8
550	535	WESLACO UNIT	94SB9805	1,748	47.8
551	655	PREMONT	94LA2720	788	47.5
552	453	ALICE	94LA1770	1,611	47.1
553	685	PORT LAVACA	94CN2490	1,072	46.5
554	583	WESLACO UNIT	94SB2195	1,090	46.5
555	368	ROCKPORT	94CS5950	542	46.5
556	605	DEL RIO CITY	94LA440	841	46.4
557	634	UNIVERSITY	94LA930	756	46.3
558	623	BEEVILLE	94CN8510	871	46.0
559	216	SINTON	94CS180	920	45.8
560	312	PLEASANTON	94LA120	1,237	45.6
561	497	VICTORIA POWER PLANT	94CN8070	613	45.4
562	313	WADSWORTH	94CN7660	1,316	45.4
563	447	LIVE OAK	94CS1070	2,797	45.3
564	179	MCCOLL ROAD	94SB4400	1,199	45.0
565	521	RODD FIELD	94CS2190	2,602	44.4
566	472	EL CAMPO	94CN6370	724	44.3
567	8	PARKER	94CN9010	18	44.2
568	new	MAGNOLIA	94CN2840	10	44.1
569	712	MCCOLL ROAD	94SB4780	2,165	43.4
570	78	HAIINE DRIVE	94SB270	977	43.2
571	443	LAREDO HEIGHTS	94LA9080	690	42.9
572	478	NORTH VICTORIA	94CN1580	1,038	42.9
573	270	PALACIOS	94CN6840	1,518	42.5
574	506	DEL MAR	94LA7930	1,301	42.2
575	697	EAST HARRISON	94SB3080	364	42.2
576	394	SOUTH MISSION	94SB4650	998	41.8
577	624	NORTH MCALLEN	94SB5055	3,094	41.6
578	426	RAYMONDVILLE #1	94SB630	780	41.4
579	470	WASHINGTON STREET	94LA7015	1,516	41.0
580	326	INGLESIDE CITY	94CS8050	1,335	40.7
581	665	HARLINGEN	94SB370	1,174	40.6
582	90	SAN DIEGO	94LA1980	595	40.4
583	327	PORTLAND	94CS6505	1,660	40.2
584	355	LAREDO PLANT	94LA8505	774	40.1
585	536	EL CAMPO	94CN2860	829	39.4
586	299	SUNCHASE	94SB1150	1,271	39.1
587	417	NORTH VICTORIA	94CN6390	1,601	39.1
588	57	GARCENO	94SB2130	3,040	39.0
589	693	KINGSVILLE	94CS1140	1,058	39.0
590	214	RANGERVILLE	94SB3420	772	38.8
591	385	ROMA	94SB3060	1,558	38.6
592	247	VILLA CAVAZOS	94SB7615	961	38.0
593	525	FREER	94LA5200	1,057	38.0
594	47	LA GRULLA	94SB5110	1,352	37.9
595	677	HAIINE DRIVE	94SB9700	751	37.9
596	253	BUENA VISTA	94LA9385	2,105	36.8
597	117	PALMVIEW	94SB7595	2,658	36.7
598	328	WASHINGTON STREET	94LA6525	2,072	36.7
599	588	MILO	94LA5020	1,301	36.6
600	254	EAGLE PASS CITY	94LA2745	910	36.3
601	656	HOLLY	94CS1220	3,384	36.2
602	572	SOUTHSIDE	94CS5345	397	36.0
603	242	WESLACO UNIT	94SB7455	1,209	35.0
604	338	EDROY	94CS6980	190	34.9
605	141	PALMVIEW	94SB6790	2,958	34.4
606	667	ANNA STREET	94LA850	1,603	34.4
607	469	SABINAL	94LA485	480	34.3
608	208	NORTH MCALLEN	94SB9660	1,975	34.2
609	334	FULTON	94CS440	2,031	34.1
610	158	ARANSAS PASS	94CS9130	358	34.0
611	616	WESLACO UNIT	94SB8195	1,684	33.0
612	309	ZACATE CREEK	94LA2675	1,162	32.9
613	65	DEL RIO CITY	94LA1930	1,037	32.7
614	298	REFUGIO	94CN1210	205	32.7
615	625	FULTON	94CS3070	1,584	32.4
616	138	LA GRULLA	94SB6150	1,100	31.9
617	230	POLK AVENUE	94SB4190	1,706	31.6
618	278	AIRLINE	94CS6970	1,227	31.6
619	477	HARLINGEN	94SB660	1,898	31.5

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
620	212	THOMASTON	94CN9580	47	31.3
621	441	NORTH EDINBURG	94SB3570	1,795	31.0
622	603	ARANSAS PASS	94CS590	421	29.6
623	559	HEARN ROAD	94CS9665	570	29.6
624	553	AIRLINE	94CS9605	706	29.6
625	574	RODD FIELD	94CS205	1,630	29.0
626	592	NORTH VICTORIA	94CN7860	1,481	28.7
627	549	FULTON	94CS2020	1,795	28.5
628	198	SOUTH EAST EDINBURG	94SB4570	1,354	28.3
629	594	COLUMBUS	94CN9060	368	28.0
630	237	DEL RIO CITY	94LA9850	904	27.3
631	584	SOUTHSIDE	94CS8045	1,017	26.9
632	628	MORRIS STREET	94CS8840	608	26.5
633	271	WEIL TRACT (138/12KV)	94CS2520	545	26.3
634	420	MAGRUDER	94CN7690	591	26.1
635	353	PALMHURST	94SB3890	2,362	26.1
636	569	NORTH MCALLEN	94SB4995	1,914	25.4
637	159	LAREDO PLANT	94LA8695	1,011	25.4
638	134	ROCKSPRINGS	94LA2600	381	25.3
639	719	THREE RIVERS	94CN5100	36	25.1
640	600	MATHIS	94CS1420	930	24.7
641	new	EL GATO	94SB780	1,676	24.3
642	358	HOLLY	94CS7740	1,987	23.9
643	372	MCKENZIE ROAD	94CS330	2,261	23.9
644	437	WEST MCALLEN	94SB4535	2,795	23.6
645	599	MALONE	94CN7560	102	23.2
646	499	HEARN ROAD	94CS2220	1,516	22.6
647	504	HIGHWAY 9	94CS7200	657	22.6
648	651	EAGLE PASS CITY	94LA2650	1,308	22.5
649	322	DEL MAR	94LA10	1,903	22.4
650	661	LAREDO HEIGHTS	94LA2100	2,108	22.3
651	610	EDNA	94CN5775	503	22.0
652	9	FASHING	94CN8160	33	21.8
653	502	DEL MAR	94LA220	1,800	21.8
654	550	ARCADIA	94CS5020	1,519	21.3
655	418	SOUTH MCALLEN	94SB3850	797	20.7
656	524	NORTH EDINBURG	94SB3810	887	20.5
657	563	PUEBLO	94LA130	1,331	20.4
658	669	SOUTH MISSION	94SB5215	1,241	20.2
659	708	LAREDO HEIGHTS	94LA6820	2,090	20.0
660	457	EAGLE PASS CITY	94LA7060	844	19.9
661	533	ARANSAS PASS	94CS1250	386	19.7
662	52	PORT ARANSAS	94CS3030	817	19.5
663	531	WEIL TRACT (138/12KV)	94CS1990	1,277	19.4
664	554	SHARYLAND	94SB5635	1,922	18.6
665	589	SKIDMORE	94CS380	333	18.5
666	79	SOUTH MCALLEN	94SB3790	1,880	18.3
667	460	HIGHWAY 9	94CS6760	667	17.9
668	700	REFUGIO	94CN1170	877	17.8
669	454	ARANSAS PASS	94CS660	740	17.5
670	160	GARCENO	94SB2135	2,093	17.0
671	281	PALMHURST	94SB2530	1,795	16.8
672	191	PALMVIEW	94SB9680	970	16.7
673	356	DEL MAR	94LA3440	1,395	16.7
674	68	PALMVIEW	94SB9685	2,805	16.1
675	659	MATHIS	94CS1410	458	15.9
676	203	HIDALGO	94SB3680	328	15.8
677	new	CLARKWOOD	94CS2170	10	15.2
678	302	LEARY LANE	94CN6175	1,645	15.0
679	294	EAST HARRISON	94SB4310	1,145	14.8
680	709	AIRLINE	94CS5870	883	14.4
681	99	AIRLINE	94CS8370	271	14.2
682	345	LAREDO PLANT	94LA8565	1,363	13.4
683	369	PALMHURST	94SB2525	1,930	13.3
684	629	KINGSVILLE	94CS1670	420	13.2
685	500	HOLLY	94CS5820	928	12.9
686	450	KLEBERG	94CS280	1,059	12.8
687	346	BUENA VISTA	94LA8965	924	12.8
688	650	WEST MCALLEN	94SB4815	701	11.9
689	643	CRESTONIO	94LA6660	769	11.8
690	320	ZACATE CREEK	94LA2635	253	11.8
691	225	MILO	94LA3070	3,224	11.4
692	654	LAREDO HEIGHTS	94LA2390	1,687	11.1
693	241	WASHINGTON STREET	94LA6355	1,067	11.0
694	707	RODD FIELD	94CS1730	2,096	10.8
695	97	CABANISS	94CS75	2,045	10.3
696	430	WASHINGTON STREET	94LA2470	188	10.3
697	691	AIRLINE	94CS9390	1,874	10.0

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2012 SAIDI Ranking	2011 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2012 SAIDI Value
698	681	SHARYLAND	94SB2010	1,104	9.8
699	638	AIRLINE	94CS8260	1,498	9.3
700	89	ODEM	94CS5575	61	9.2
701	263	CLARKWOOD	94CS7220	415	9.1
702	692	ANNA STREET	94LA2250	1,567	9.1
703	516	PALMVIEW	94SB3930	1,081	8.5
704	285	MORRIS STREET	94CS7465	641	8.2
705	228	SINTON	94CS1750	506	7.8
706	642	ANNA STREET	94LA5780	705	7.4
707	388	LAREDO PLANT	94LA8745	719	7.0
708	288	HALL ACRES ROAD	94SB9595	1,126	6.7
709	new	EL GATO	94SB720	2,429	5.5
710	702	EL CAMPO	94CN7260	531	5.4
711	396	RODD FIELD	94CS245	2,553	5.2
712	435	SAN BENITO	94SB3860	241	5.2
713	81	SOUTH MCALLEN	94SB3640	304	5.0
714	359	RODD FIELD	94CS3010	1,889	3.9
715	new	EL GATO	94SB890	2,828	3.9
716	251	EAST HARRISON	94SB3000	525	3.8
717	680	SIERRA VISTA	94LA3540	337	2.6
718	425	SOUTH MISSION	94SB3940	801	2.4
719	715	MCCOLL ROAD	94SB4910	328	2.3
720	382	WASHINGTON STREET	94LA2360	192	2.1
721	55	CAUSEWAY	94SB4775	1,057	1.1
722	689	BEEVILLE	94CN2380	211	1.0
723	new	EL GATO	94SB910	2,422	1.0
724	446	ROCKSPRINGS	94LA8040	334	0.9
725	711	MILO	94LA8365	1,809	0.8
726	77	SOUTH MCALLEN	94SB5065	111	-
727	699	HAIN DRIVE	94SB9240	45	-
728	720	VICTORIA POWER PLANT	94CNNETVIC	77	-
729	722	MORRIS STREET	94CSNET CC	359	-
730	723	WASHINGTON STREET	94LANETLAR	181	-
731	new	FOSTER FIELD	94CN8880	10	-

Feeders from last year that are not in this year's list

2011 Ranking	Substation Identification
none	

Feeder ID	Reason not in 2012

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2012 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	16.97%
Vegetation	15.91%
Animals and Birds	7.83%
People (Including cars and farm equip)	2.77%
Utility-owned Equipment	45.57%
Other	0.13%
Unknown	10.81%