

1 Q83. WHAT OVERALL CONCLUSION DO YOU DRAW FROM YOUR  
2 SUPPORTING EVIDENCE REGARDING THE TRANSMISSION  
3 OPERATIONS CLASS OF AFFILIATE SERVICES?

4 A. From the evidence presented, I conclude that the products and services  
5 provided by the Transmission Operations Class of affiliate services are  
6 necessary because they support the operations of ETI's transmission  
7 system and ensure compliance with the applicable codes and standards. I  
8 conclude that the expenses for this cost class are reasonable because  
9 ETI's total transmission O&M costs compare favorably to other utilities, as  
10 demonstrated by the benchmarking analyses discussed above. Finally,  
11 the affiliate charges associated with these products and services are billed  
12 at a cost and at a rate no higher than the charges to the other affiliates for  
13 the same or similar services. In addition, these services are not  
14 duplicated by ETI or any other affiliate or third party.

15

16 IV. TRANSMISSION CAPITAL PROJECTS

17 A. Overview of Transmission Capital Projects

18 Q84. WHAT IS THE PURPOSE OF THIS SECTION OF YOUR TESTIMONY?

19 A. In this section of my testimony, I describe the capital additions to rate base  
20 for transmission plant closed to plant-in-service since the end of the test  
21 year in Docket No. 39896; that is, from July 1, 2011 through the end of the  
22 test year in this docket – March 31, 2013. Transmission plant-in-service  
23 capital additions include those made in the categories of General Plant,

1 Intangible additions, and Transmission Plant for the Transmission  
2 Function. The breakdown for each of these categories is shown in  
3 Table 7.

**Table 7**

<b>Transmission Capital Projects Summary by Category</b>		
<i>July 1, 2011 – March 31, 2013</i>		
	<b>DOLLARS CLOSED TO PLANT</b>	<b>PERCENT</b>
General Plant	\$1,071,966	1.7%
Intangible	\$3,720,089	5.8%
Transmission Plant	\$59,149,808	92.5%
<b>Total Transmission Function</b>	<b>\$63,941,863</b>	<b>100.0%</b>

4 Q85. WHAT IS THE TOTAL AMOUNT OF CAPITAL ADDITIONS FOR  
5 TRANSMISSION PROJECTS THAT YOU ADDRESS IN THIS  
6 PROCEEDING?

7 A. The total amount of transmission capital additions I address is  
8 \$63,941,863. The specific projects included in this amount are detailed in  
9 Exhibit MFM-11 attached to this testimony.

10

11 Q86. PLEASE DESCRIBE THE INFORMATION PROVIDED ON  
12 EXHIBIT MFM-11.

13 A. Exhibit MFM-11 is a spreadsheet that details the specific projects  
14 including the total amount of capital addition closed to plant from July 1,  
15 2011 through March 31, 2013. It is organized by asset class, which  
16 includes General Plant, Intangible additions, and Transmission Plant.  
17 Each project can be identified by a specific project code and project code

1 description, which provides an explanation for the expense. The exhibit  
2 includes the following information under column headers:

3	Column A	Project Code
4	Column B	Project Code Description
5	Column C	Asset Class
6	Column D	In service Date
7	Column E	Asset Location Description
8	Column F	State Location
9	Column G	Business Unit ("BU")
10	Column H	Non-Affiliate Charges Excluding Capital Suspense
11		and Reimbursements
12	Column I	Reimbursements
13	Column J	Represents capital suspense overhead costs
14		associated with administrators, engineers and
15		supervisors to the capital projects for which they
16		provide services. Each function charges their capital
17		suspense to a "Capital Suspense" project, which is
18		then allocated out to the appropriate capital projects.
19		Capital Suspense costs and the subsequent
20		allocation is separated by BU and function
21		combination to more accurately match such costs on
22		the actual projects worked on for each function within
23		a BU.
24	Column K	Represents the portion of capital suspense overhead
25		costs (in Column J) from an affiliate.
26	Column L	Represents the portion of capital suspense overhead
27		costs (in Column J) that are charged to the project by
28		ETI employees.
29	Column M	Represents charges incurred by the ESI service
30		company and allocated out to the appropriate BUs
31		based on the ESI billing method assigned to the
32		project plus loaned resource charges incurred at one

1 BU and charged to another BU for services rendered  
2 on behalf of that BU.

3 Column N Represents the total affiliate portion of the charges  
4 included in Column O, and is the total of Columns K  
5 and M.

6 Column O Represents the total amount of capital additions  
7 closed to plant in service.

8

9 Q87. PLEASE DESCRIBE THE MAJOR TYPES OF TRANSMISSION  
10 ADDITIONS TO RATE BASE.

11 A. From July 1, 2011 through March 30, 2013, ETI added \$63,941,863 to  
12 plant-in-service for transmission as shown in Exhibit MFM-11. In this  
13 testimony, I discuss in detail the 18 transmission-related projects with  
14 costs exceeding \$1M. These projects constitute 72% of the total  
15 transmission additions to ETI's rate base. Information regarding the  
16 remaining 28% of additions is contained in Exhibit MFM-11.

17 Transmission projects can generally be categorized as one of  
18 seven types: Reliability, Revenue, Failure, Infrastructure, Mandated,  
19 Transmission Service, and Other. Each type is described below.

20 **Reliability** – A project (i) that is needed for the continued  
21 uninterrupted operation of the transmission system to prevent an  
22 operational deficiency, or (ii) that is the result of load growth. Examples of  
23 projects undertaken to address operational deficiencies include the  
24 shielding of lines for lightning protection, the addition of switches/circuit  
25 breakers for quicker or easier restoration of customers, the addition of

1 lines for improved reliability, and the replacement of obsolete or deficient  
2 equipment or hardware. Examples of projects undertaken to address load  
3 growth include the re-conductoring of overloaded lines, the addition of  
4 transformer capacity to a substation for area load growth, the addition of  
5 substation capacitor banks, and the construction of a new line into an area  
6 to increase import capacity.

7 **Revenue** – A project required (i) to connect a new customer to the  
8 transmission system, (ii) to provide capability to serve increased load for  
9 an existing customer, or (iii) for the addition of facilities to be fully covered  
10 under facility charges. The majority of these projects require the customer  
11 to provide a payment in the form of a monthly facilities charge. Examples  
12 include the addition of a new substation for an industrial customer, the  
13 addition of a new transmission line for a specific customer, or an increase  
14 of transformer capacity at an industrial site. All are required to meet  
15 specific load requirements of individual customers.

16 **Failures** – A project necessary to replace or repair failed  
17 equipment. Examples include the rewinding or replacing of a failed  
18 transformer; and replacing damaged poles, insulators, breakers, shield  
19 wire, etc.

20 **Infrastructure** – A project that provides for replacement of  
21 antiquated, technologically-outdated equipment or equipment no longer  
22 supported by the manufacturer. Examples include certain types of  
23 lightning arresters, batteries, relays, or any obsolete equipment.

1                   **Mandated** – Projects that must be funded and completed without  
2                   delay due to contractual agreement, law or regulatory requirements.  
3                   Examples include moving facilities at the request of the highway  
4                   department, adding/modifying facilities under a contractual agreement,  
5                   independent power producer (“IPP”) work for which the IPP receives  
6                   transmission credits, and reimbursable projects for interconnecting  
7                   utilities.

8                   **Transmission Service** – Transmission upgrades necessary to  
9                   designate generation as a network resource or accommodate  
10                  point-to-point transmission service.

11                  **Other** – Projects that are needed to support the operation of the  
12                  electrical system but are not a direct part of the electrical system.  
13                  Examples include facility additions, the funds used to replace or purchase  
14                  new tools required for construction and/or maintenance, and general and  
15                  intangible additions that were specifically related to transmission functions.

16

17                  B.     Discussion of Specific Transmission Capital Projects

18     Q88. PLEASE DESCRIBE THE 18 TRANSMISSION CAPITAL PROJECTS  
19                  THAT YOU INDICATED INCURRED THE HIGHEST TOTAL COSTS.

20     A.     Table 8 lists the 18 transmission capital projects that incurred the majority  
21                  of the costs, in order of highest-to-lowest cost. The projects are listed by  
22                  Project Code, as seen in Exhibit MFM-11.

**Table 8: 18 Highest Transmission Capital Projects by Cost**

	<b>Project Code</b>	<b>Description</b>	<b>Asset Class</b>	<b>Type</b>	<b>Dollars Closed to Plant</b>
1	F1PPU75349	Grand Gulf Uprate TSR 206 MW GGU	Transmission Plant	Transmission Service	\$ 11,882,194
2	F1PPU75446	Construct ETI-ERCOT Emergency Tie	Transmission Plant	Mandated	\$ 4,029,966
3	F1PCUX5009	Replace Transformer at Metro Substation	Transmission Plant	Reliability (Distribution)	\$ 3,039,707
4	F1PPU50694	Purchase 230/138kV Autotransformer at Mid-County Substation	Transmission Plant	Failures	\$ 2,913,945
5	F1PPU50717	Purchase 500/230kV Autotransformer for Cypress Substation	Transmission Plant	Failures	\$ 2,866,178
6	F1PPU50537	Land Purchase for Ponderosa Switching Station	Transmission Plant	Reliability	\$ 2,834,082
7	F1PCUD0556E	Distribution Substation Equipment Failures	Transmission Plant	Failures	\$ 2,324,994
8	F1PCUD0551E	Transmission Equipment Failures Blanket	Transmission Plant and Intangible	Failures	\$ 2,284,715
9	F1PPUD0074E	EMS/SCADA Reconfigure Host Plan	Intangible	Reliability/ Infrastructure	\$ 1,920,757
10	F1PPU50623	ETI Spare Transformer	Transmission Plant	Failures	\$ 1,776,367
11	F1PCUD0279E	Transmission Line Program Blanket	Transmission Plant	Reliability/ Infrastructure	\$ 1,655,773
12	F1PPUD0129E	Skylining Tree Hazard Blanket	Transmission Plant	Reliability	\$ 1,536,145
13	F1PPSTORM3	Hurricane Ike Restoration	Transmission Plant	Failures	\$ 1,506,433
14	F1PPU75486	NERC Alert ETI Line Mitigation	Transmission Plant	Infrastructure/ Mandated	\$ 1,279,375
15	F1PPU50636	System Substation Facility Upgrade Project	Transmission Plant	Reliability/ Infrastructure	\$ 1,136,067
16	F1PCUD0122E	Wood Pole Replacement	Transmission Plant	Infrastructure	\$ 1,059,723
17	F1PPUD0238	NERC Alert LIDAR Inspection	Intangible	Reliability/ Mandated	\$ 1,032,652
18	F1PCUD0117E	Distribution Substation Relay Improvement Blanket	Transmission Plant	Reliability/ Infrastructure	\$ 1,024,611
				<b>TOTAL</b>	<b>\$ 46,103,683</b>

- 1      1.      **Project F1PPU75349: Grand Gulf Uprate (206 MW Transmission**
- 2                      **Service Request).** ESI's System Planning and Operations ("SPO")

1 organization requested, on behalf of System Entergy Resources, Inc.,  
2 an Arkansas Corporation, to designate 206 MW from the Grand Gulf  
3 Station Generation Plant as a 'Network Resource' from June 1, 2012 to  
4 June 1, 2042 as part of a transmission service request ("TSR"). The  
5 ICT determined that adding this incremental generation to the Entergy  
6 Transmission System would not be feasible without making  
7 improvements across the transmission systems of ELL, EGSL, EMI,  
8 and ETI. The portfolio of projects within ETI includes:

- 9 1. Hartburg – McLewis 230 kV Transmission Line – Upgrade the  
10 line capacity to 740 MVA.
- 11 2. Inland Orange 230 kV Substation – Replace jumpers from  
12 transmission lines to bus.
- 13 3. Hartburg 230 kV Substation – Replace jumpers from  
14 transmission lines to bus.
- 15 4. McLewis 230 kV Substation – Replace line switches and  
16 jumpers from transmission lines to switches.

17 The total cost of this portfolio of projects was \$11,882,194.

- 18 **2. Project F1PPU75446: Construct ETI-ERCOT Emergency Tie.** The  
19 purpose of this project was to provide a transmission interconnection to  
20 tie part of the ETI transmission system in the College Station area to  
21 the Electric Reliability Council of Texas, Inc. ("ERCOT") system under  
22 emergency conditions. This proposal resulted from two bills passed  
23 during the 2009 Texas legislative session (HB 1831 and SB 1492)



1           which gave certain authority to the PUC during an emergency and  
2           required a study to identify the need for emergency power and actions  
3           to prepare for emergency power. The total cost of this project was  
4           \$4,029,966.

5           **3. Project F1PCUX5009: Replace Transformer at Metro Substation.**

6           The purpose of this project was to remove the Metro T1 75 MVA  
7           transformer and install a new 100 MVA transformer to serve area load  
8           growth. Metro Substation had one 75 MVA transformer (T1) and one  
9           100 MVA transformer (T2). By 2013, transformer T1 was projected to  
10          be loaded by 110% of its nameplate rating during peak conditions.  
11          Much of the load increase is due to spot loads in the Town Center area  
12          of The Woodlands, Texas. Some of these loads include two hotels, a  
13          condominium tower, two office buildings, and a large apartment  
14          complex. The total cost of this project was \$3,039,706.

15          **4. Project F1PPU50694: Purchase 230/138 kV Autotransformer for**  
16          **Mid County Substation.** ETI's Mid County Substation

17          autotransformer failed during operation on May 2, 2011. This project's  
18          purpose was to purchase a new 230/138 kV 180/240/300 MVA  
19          three-phase autotransformer for replacement of the failed  
20          autotransformer. The total cost of this project was \$2,913,944.

21          **5. Project F1PPU50717: Purchase a 500/230 kV Autotransformer for**  
22          **Cypress Substation.** ETI's Cypress Substation autotransformer failed

23          during operation on September 1, 2011. This project's purpose was to

1 purchase a new 500/230/13.8 kV 150/200/250 MVA single-phase  
2 autotransformer for replacement of the failed autotransformer. The  
3 total cost of this project was \$2,866,177.

4 **6. Project F1PPU50537: Land Purchase for Ponderosa Switching**  
5 **Station.** As determined by reliability planning studies to comply with  
6 NERC Reliability Standard TPL-002, it was determined that, under the  
7 contingency loss of the Lewis Creek-to-Longmire 138 kV transmission  
8 line (line 596), overloading of the Tubular-to-Dobbin 138 kV  
9 transmission line segment could occur. In addition, potential  
10 unacceptable voltage levels at Navasota, Tubular, Dobbin, Fish Creek,  
11 Spring Branch, and Longmire substations may arise for various N-1,  
12 G-1 scenarios.<sup>9</sup> The purpose of building this switching station is to  
13 mitigate these risks. The scope of this project is to install a 138 kV  
14 switching station (4-breaker ring bus) where the Longmire-to-Fish  
15 Creek 138 kV transmission line parallels the Conroe-to-Woodhaven  
16 138 kV line (lines 96 and 112), cut both lines into the switching station,  
17 and relocate Line 569 (Lewis Creek-to-Alden 138 kV). This project will  
18 mitigate the single-contingency loss of the source from Lewis Creek  
19 and provide long term benefits in the Conroe area. Land was  
20 purchased in order to provide a location to construct the Ponderosa

---

<sup>9</sup> N-1, G-1 scenarios are outage scenarios in which a single transmission line component and a single generator are concurrently out of service.

1           Switching Station. The total cost of this land purchase was  
2           \$2,834,082.

3       **7. Project F1PCUD0556E: Distribution Substation Equipment**  
4       **Failures.** This project's purpose was to replace failed substation  
5       equipment such as small instrument transformers, regulators, circuit  
6       breakers, circuit switches, capacitor banks, bushings, switches, bus,  
7       structures and more. Replacement is generally associated with  
8       service/capacity restoration. The total cost of ETI's share of this  
9       project was \$2,324,993.

10      **8. Project F1PCUD0551E: Transmission Equipment Failures**  
11      **Blanket.** This program funds the repair and/or replacement of failed  
12      transmission line components, such as poles, insulators, cross arms,  
13      shield wire, conductor, cross braces, and line switches. Additionally,  
14      this program funds the capital requirements to repair and/or replace  
15      property damaged during minor storm events. The objective of this  
16      program is to respond to material failures that occur due to  
17      degradation, storm events, public-inflicted damage and other  
18      miscellaneous modes of failure. The total cost of ETI's share of this  
19      project was \$2,284,714.

20      **9. Project F1PPUD0074E: EMS/SCADA Reconfigure Host Plan.** This  
21      project's purpose is to design, purchase, install, and implement  
22      software and hardware for the Emergency Management Systems of  
23      the EOCs' Transmission Operations Centers, Distribution Operations

1 Centers, and System Operations Center. These computer systems  
2 replace obsolete hardware and software and provide redundant  
3 computer systems for the Transmission System's critical control  
4 applications, and address the NERC Reliability Standard CIP-009,  
5 which includes a requirement for all critical control centers that control  
6 the reliability of the electrical grid have backup capabilities. The total  
7 cost of ETI's share of this project was \$1,920,757.

8 **10. Project F1PPU50623: ETI Spare Transformer.** A 230/69 kV  
9 autotransformer failed during operation on September 16, 2005,  
10 immediately following Hurricane Katrina. An ETI spare 230/69 kV,  
11 120/160/200 MVA LTC autotransformer was used as its replacement.  
12 The purpose of this project was to purchase a new 230/69 kV,  
13 120/160/200 MVA LTC autotransformer to replace the spare  
14 transformer that was utilized for the failure. The total cost of this  
15 project was \$1,776,367.

16 **11. Project F1PCUD0279E: Transmission Line Program Blanket.** This  
17 program includes corrective maintenance activities, which involve  
18 replacement of "units of property." Work includes those tasks identified  
19 through aerial and ground inspections. Climbing or aerial inspections  
20 are performed on each line cyclically identifying needed repairs. The  
21 deficiencies include damages and structural degradation due to age.  
22 Problems resulting from line outages are logged in the LWMS

1 database for repair. The total cost of ETI's share of this project was  
2 \$1,655,772.

3 **12. Project F1PPUD0129E: Skylining Tree Hazard Blanket.** A high  
4 percentage of vegetation-related outages are due to vegetation growth  
5 outside of the EOCs' rights-of-way. This program is managed by the  
6 T&D Asset Management department and is aimed at shaping the  
7 off-ROW perimeter to reduce off-ROW vegetation contact. The total  
8 cost of ETI's share of this project was \$1,536,145.

9 **13. Project F1PPSTORM3: Hurricane Ike Restoration.** This project  
10 was necessary to restore transmission line and substation facilities  
11 damaged by Hurricane Ike, a strong Category 2 hurricane that made  
12 landfall near Galveston, Texas on September 13, 2008. Restoration  
13 projects placed in service from July 1, 2011 to March 31, 2013  
14 included replacing relays and an RTU at the Sabine Substation,  
15 replacing relays and motor operators at the Gulfrich Substation and  
16 replacing a leased fiber optic line at the Carroll Street Park Substation.  
17 From July 1, 2011 through March 31, 2013, ETI's total cost for  
18 Hurricane Ike repairs captured under this budget item was \$1,506,432.

19 **14. Project F1PPU75486: NERC Alert ETI Line Mitigation.** This project  
20 is one of two funding projects that capture the costs to comply with an  
21 October 2010 NERC Facilities Ratings Alert requiring all utilities to  
22 verify that all Bulk Electric System transmission lines operating at  
23 100 kV and above remain within intended design tolerances to support

1 the assigned ratings. Following identification of needed remediation  
2 under Project F1PPUD0238, this funding project captured the costs for  
3 scoping, engineering time, construction, etc. for the transmission line  
4 and distribution wires capital work or other infrastructure improvements  
5 performed within ETI's service territory that were required to comply  
6 with the Facilities Ratings Alert. The total cost of this project was  
7 \$1,279,374.

8 **15. Project F1PPU50636: System Substation Facility Upgrade**  
9 **Project.** This project was necessary to upgrade under-rated  
10 substation equipment on ETI's transmission system. The total cost of  
11 this project was \$1,136,066.

12 **16. Project F1PCUD0122E: Wood Pole Replacement.** Approximately  
13 75% of the structures supporting the EOCs' transmission lines are of  
14 wood pole type with an average age of over 35 years. Wood pole  
15 inspections have identified more than 3,000 poles needing  
16 replacement or repair. This program funds the repair or replacement  
17 of poles no longer meeting NESC strength requirements. Each year,  
18 approximately 300 additional poles are identified for replacement or  
19 repair. The cost to replace a pole ranges from \$4,000 to \$15,000 per  
20 structure. The total cost of ETI's share of this project was \$1,059,723.

21 **17. Project F1PPUD0238: NERC Alert LiDAR Inspection.** This project  
22 is one of two funding projects that capture the costs to comply with an  
23 October 2010 NERC Facilities Ratings Alert requiring all utilities to

1           verify that all Bulk Electric System transmission lines operating at  
2           100 kV and above remain within intended design tolerances to support  
3           the assigned ratings. This funding project uses a combination of  
4           LiDAR radar technology, aerial inspections, and manual surveys in  
5           order to collect data needed for assessments and remediation. Data  
6           analysis is then performed to determine capital improvement plans for  
7           corrective actions. Once approved, capital improvements are  
8           completed to finalize remediation under Project F1PPU75486. The  
9           total cost of ETI's share of this project was \$1,032,651.

10       **18. Project F1PCUD0117E: Distribution Substation Relay**  
11       **Improvement Blanket.** This project involves the replacement of relay  
12       systems and related minor components to resolve system protection  
13       performance and coordination/settings issues arising from obsolete  
14       technology, incompatibility with related scheme components, and  
15       system or operating procedure changes. This project also provides  
16       required funding to meet SERC relay misoperation mitigation plans  
17       filed semi-annually. It reduces customer interruption and customer  
18       minutes associated with relaying misoperations. It also reduces O&M  
19       spending by utilizing self-diagnostic technology. The total cost of ETI's  
20       share of this project was \$1,024,611.

1           C.    Transmission Capital Projects Were Reasonable and Necessary

2   Q89.  ARE THE CAPITAL PROJECT COSTS IDENTIFIED IN EXHIBIT MFM-11  
3       PROPERLY INCLUDED IN RATE BASE IN THIS PROCEEDING?

4   A.   Yes.  The \$64 million in expenditures were reasonable and necessary to  
5       construct transmission capital projects required to continue providing  
6       reliable service to ETI's customers.  These investments are for ETI  
7       substations and transmission lines that are required to serve customers in  
8       ETI's service territory.

9  
10  Q90.  ARE THESE ITEMS USED AND USEFUL IN PROVIDING SERVICE?

11  A.   Yes.  Each of the items shown on Exhibit MFM-11 is in-service and being  
12       used to provide service to ETI's customers or is a necessary part of  
13       planned investments that will be operational within ten years under a  
14       definite plan.

15  
16  Q91.  ARE ANY AFFILIATE COSTS INCLUDED IN THE REQUESTED  
17       CAPITAL ADDITIONS TO RATE BASE?

18  A.   Yes.  Affiliate costs totaled \$10,882,791 of the requested capital additions  
19       of \$63,941,863 for transmission projects shown in Exhibit MFM-11.

20  
21  Q92.  WHY WERE THESE AFFILIATE COSTS NECESSARY?

22  A.   These costs are the result of ESI employees providing the design and  
23       construction management of specific capital projects for ETI's



1 transmission system, as well as for general planning, design, design  
2 engineering services, project management, and construction  
3 management. These affiliate charges are for services that benefit the  
4 entire Entergy Transmission System, including the ETI system, and are  
5 necessary to meet the current and future needs of the EOS' customers.  
6

7 Q93. HAVE YOU DISCUSSED THE REASONABLENESS OF THE AFFILIATE  
8 CHARGES IN THIS TESTIMONY?

9 A. Yes. In the affiliate charges portion of this testimony supporting the  
10 Transmission Operations affiliate cost class, I discussed the necessity and  
11 reasonableness of charges by ESI employees, including budget and cost  
12 controls, and some of the efficiencies captured through process  
13 improvements and technology advances. That discussion is applicable to  
14 the types of costs that are represented in the affiliate costs included in the  
15 capital additions discussed above. Moreover, the affiliate charges for  
16 capital costs are made under the same cost-causative system of billing  
17 methods previously discussed. Accordingly, the affiliate charges for  
18 capital costs are at-cost and at a rate no higher than the charges made to  
19 other affiliates for the same or similar services.

1 Q94. WERE THE NON-AFFILIATE COSTS ADDED TO RATE BASE  
2 REASONABLE?

3 A. Yes. The non-affiliate costs are largely composed of capitalized ETI  
4 direct-labor costs, and the cost of materials, subcontractors and  
5 independent contractors, and land rights procurement. The  
6 reasonableness of the compensation and benefits program associated  
7 with the direct-labor costs for ETI employees is addressed in the testimony  
8 of Company witness Raeder. As discussed below, with regard to  
9 materials and subcontractors, ETI purchases materials and secures  
10 subcontractors in a manner that ensures that reasonable costs are  
11 incurred. Similarly, as discussed below, the interests in real property that  
12 are necessary to site these transmission projects are procured in a  
13 manner that ensures reasonable costs are incurred.

14

15 Q95. WHAT PROCESS AND BUDGET CONTROL DOES ETI HAVE IN PLACE  
16 TO ENSURE THAT MATERIALS ARE PROCURED AT A REASONABLE  
17 COST?

18 A. As explained in more detail in the Direct Testimony of Company witness  
19 Reginald T. Jackson, ETI has a number of cost control measures in place.  
20 First, all materials purchases are made through arm's-length transactions  
21 from non-affiliated parties in a competitive market. ETI chooses among  
22 several suppliers for comparable materials. For some commonly used  
23 materials and equipment, ETI has negotiated alliance agreements with

1 suppliers. Such alliances are based on a competitive bid process that  
2 takes place on a regular basis. All other materials are procured through a  
3 competitive bid process from a list of approved suppliers. ETI has also  
4 used reverse auctions to bid commodity-type products. All alliance  
5 agreements and bid results are checked against market indices to ensure  
6 that the pricing is reasonable and prudent.

7

8 Q96. WHAT STEPS DOES ETI TAKE TO ENSURE THAT  
9 SUBCONTRACTORS AND INDEPENDENT CONTRACTORS ARE  
10 PROCURED AT A REASONABLE COST?

11 A. As is the case with materials, ETI has a number of cost-control measures  
12 in place to ensure that subcontracting costs are reasonable. The primary  
13 method of ensuring reasonable costs for contractors is through the  
14 utilization of a competitive bid process and fixed-price contracts. ETI  
15 ensures that costs stay within the estimates by providing  
16 inspectors/representatives on all jobs that involve the construction of  
17 facilities in order to ensure that ETI's contractors are performing quality  
18 work and keeping within the scope of all contracts. ETI requires  
19 documented change requests to be approved by management before any  
20 work outside the scope of a contract is performed. In some cases, ETI  
21 has negotiated alliance agreements with contractors. These alliances are  
22 the result of a competitive bid process and are re-bid on a regular basis.  
23 In the case of a contract alliance, ETI also maintains and uses the right to

1 bid individual contracts during the life of the alliance to ensure that the  
2 alliance is still a reasonable and competitive vehicle for conducting  
3 business.

4

5 Q97. WHAT MEASURES ENSURE THAT REAL PROPERTY RIGHTS ARE  
6 OBTAINED AT A REASONABLE COST?

7 A. Rights in real property are purchased from third parties through  
8 arm's-length transactions based on the market value of the land. If  
9 necessary, appraisers are retained to determine the reasonable value. If  
10 the price demanded by a landowner is unreasonable, ETI has the option  
11 to seek condemnation of the property and have a court set the value of the  
12 property. If feasible, ETI acquires only an easement from property owners  
13 (as opposed to acquiring outright title to the land) to reduce the cost of the  
14 acquisition.

15

16 Q98. WHAT MEASURES OR PROCESSES DOES ETI HAVE IN PLACE TO  
17 ENSURE THAT THE CONSTRUCTION OF A TRANSMISSION FACILITY  
18 PROCEEDS IN A TIMELY MANNER AND AT A REASONABLE COST?

19 A. As previously discussed, ESI's Engineering and Construction department  
20 provides project management on the construction of all transmission  
21 facilities. Project Management involves a number of cost-control  
22 measures. First and foremost, construction of transmission facilities is  
23 done predominantly via a firm, fixed-price contract or through the use of

1 an alliance agreement. The contract itself helps ensure reasonableness  
2 through the bidding process and serves as a cost-control instrument. To  
3 ensure that ETI's contractors are working safely, performing quality work  
4 and building within the scope of all contracts, ETI utilizes  
5 inspectors/representatives on all jobs that involve the construction of  
6 facilities. The inspectors keep daily job logs for use when approving  
7 contractor timesheets or invoices. ETI also utilizes a change-control  
8 process to document and approve all changes to the construction of  
9 transmission facilities before those changes take place. Finally, project  
10 schedules and estimates, and the tracking and management of each, are  
11 also used to ensure reasonable cost.

12

13 Q99. PLEASE EXPLAIN THE BUDGETING AND COST CONTROL  
14 PROCESSES THAT SUPPORT THE REASONABLENESS OF THE  
15 TOTAL ETI TRANSMISSION CAPITAL COSTS TO BE ADDED TO RATE  
16 BASE.

17 A. As explained earlier, budgeting processes are employed that build from  
18 budgets prepared by each EOC, such as ETI, and more specifically, from  
19 budgets prepared by functional organizations whose costs are reflected on  
20 a legal-entity basis. The Transmission Organization prepares a budget  
21 reflecting ETI transmission capital projects. Once the budget is approved,  
22 that budget is periodically compared to actual spending levels for the  
23 same organization and the same entity. The Transmission Organization

1 monitors actual spending compared to budget through the following  
2 reports and measures, at the time intervals indicated, to assist in  
3 controlling costs:

- 4 • Monthly – Capital budget to actual report by legal entity with  
5 explanations of the variances. This document reports  
6 current-month spending versus current-month budget,  
7 current-month spending versus prior-year same-month spending,  
8 year-to-date spending versus year-to-date budget, and year-to-date  
9 spending versus year-to-date spending prior year.
- 10 • Monthly/Quarterly – Capital current year-end projection (present  
11 estimate) by legal entity.
- 12 • Monthly – Construction work in progress at the detail capital work  
13 order level, including the preparation of reports showing which work  
14 orders are past the estimated in-service date and field updates on a  
15 monthly basis for all projects that are in-service or updates on the  
16 estimated in-service date for those projects that have been  
17 delayed.

18

19 Q100. EXPLAIN HOW THE BUDGET REPORTS ARE UTILIZED.

20 A. On a monthly basis, budget versus actual reports are monitored by each  
21 department within the Transmission Organization. Costs are analyzed by  
22 resources (e.g., labor, material, contract labor, and employee expenses),  
23 which are tracked through the accounting systems. Any significant  
24 variances are reviewed, and updated spending plans are implemented.  
25 The Transmission Organization's updated plan is submitted to Utility  
26 Operations with any changes to the original plan.

1 Q101. BASED ON ALL OF THIS INFORMATION, HAVE YOU REACHED A  
2 CONCLUSION REGARDING THE REASONABLENESS OF ETI'S  
3 CAPITAL ADDITIONS?

4 A. Yes. It is reasonable to include these capital costs in ETI's rate base in  
5 this case because these investments are necessary for ETI to provide  
6 transmission services to its customers. These capital additions to ETI's  
7 transmission system are used and useful in providing service to its  
8 customers. In addition, the construction projects were carefully  
9 supervised, and procedures were followed to ensure costs of materials,  
10 contractors, and real estate were reasonable.

11

12 V. DEMAND AND ENERGY LOSS FACTORS

13 A. Development of Transmission and Distribution  
14 Demand and Energy Losses

15 Q102. WHAT ARE LOSS FACTORS, AND WHAT IS THE PURPOSE OF  
16 CALCULATING TRANSMISSION AND DISTRIBUTION SYSTEMS'  
17 DEMAND AND ENERGY LOSSES?

18 A. In broad terms, loss factors represent energy consumed during the  
19 process of moving the power from generation to load. Because  
20 transmission and distribution losses are so widespread and vary  
21 depending on distance and grid infrastructure, metered losses are not  
22 readily available. Instead they are usually estimated. The Transmission  
23 and Distribution Systems' demand and energy losses are calculated by

1 the Energy Delivery Organization to enable the Rate Design group to  
2 develop allocation factors for use in the cost-of-service study. There are  
3 two types of losses: (1) demand loss, which is the increased generating  
4 capacity requirements necessary to meet the power consumption of a  
5 utility's customers (capacity demanded by customers); and (2) energy  
6 loss, which is the increased energy requirements over a certain period of  
7 time to meet the energy usage requirements of a utility's customers  
8 (energy consumption).

9  
10 Q103. WHAT ARE TRANSMISSION AND DISTRIBUTION SYSTEM DEMAND  
11 LOSSES?

12 A. Demand losses result mainly from electrical impedance as power flows  
13 through transmission and distribution facilities. The demand losses add to  
14 the power generation requirements such that the total generation capacity  
15 output at the power plants must be greater than the total demand of the  
16 customers. Electric utilities generally analyze system demand losses  
17 during a system peak for a relevant time period. The total power  
18 generation requirements of ETI's power system are made up of its area  
19 generation and net power interchange.

20  
21 Q104. WHAT ARE TRANSMISSION AND DISTRIBUTION ENERGY LOSSES?

22 A. Energy losses are electrical energy that must be generated in excess of  
23 customer demand in order to serve customer energy consumption.



1 Energy losses for a given time period are calculated by summing the  
2 instantaneous demand loss for the relevant time period.

3 Utilities cannot measure the instantaneous demand of all  
4 customers and do not have instantaneous demand meters on all  
5 components of the transmission and distribution network. Therefore,  
6 energy loss factors are estimated by using load descriptors such as the  
7 peak responsibility factor,<sup>10</sup> the coincidence factor,<sup>11</sup> the load factor,<sup>12</sup> and  
8 the loss factor.<sup>13</sup>

9  
10 B. Development of Transmission and Distribution Demand Losses

11 Q105. PLEASE PROVIDE AN OVERVIEW OF HOW ETI DEVELOPED ITS  
12 DEMAND LOSS FACTORS.

13 A. ETI utilizes a top-down approach to estimate its demand loss; that is, it  
14 analyzes demand losses for the highest voltage level in the system and  
15 then for each successively lower voltage level. The Company calculated  
16 demand loss factors for the analysis period, April 1, 2012 through  
17 March 31, 2013. The demand loss analysis that I sponsor estimates

---

<sup>10</sup> The peak responsibility factor is the ratio of the on-peak load for each component of the transmission and distribution system to the peak design ("rated") load for each component of the transmission and distribution system.

<sup>11</sup> The coincidence factor is a ratio of the maximum demand coincident with the Company's system peak for a specified group of customers to the sum of the individual maximum non-coincident demands of the members of such group.

<sup>12</sup> Load factor is calculated by dividing the energy consumed for a specified time period by the product of the number of time units for such specified time period and the peak demand that occurred during such time period.

<sup>13</sup> Loss factor is defined as the energy loss during a specific time period divided by the product of the specific time period and the peak demand loss.

1 demand losses for four voltage levels: (1) the transmission system at  
2 230 kV and above ("bulk transmission system"); (2) the transmission  
3 system below 230 kV and above or equal to 69 kV ("local transmission  
4 system"); (3) the primary distribution system; and (4) the secondary  
5 distribution system.

6 ETI analyzes measured on-peak generation and net power  
7 interchange on the supply-side and the on-peak power demands of its  
8 customers for comparable time periods. On-peak power deliveries were  
9 estimated by using demand data for all locations equipped with interval  
10 recording demand meters installed for billing purposes and by using  
11 estimated hourly demands of customers who normally do not have hourly  
12 demand meters at their service location.

13 The average of the 12 monthly coincident peaks ("12 CP") during  
14 the analysis period is used to estimate demand losses. The Company's  
15 average 12 CP generation plus net power interchange for the analysis  
16 period was 3,494 Megawatt ("MW"), and the average 12 CP demand for  
17 the analysis period was 3,073 MW.

18  
19 Q106. PLEASE DESCRIBE HOW THE COMPANY CALCULATES DEMAND  
20 LOSS FACTORS.

21 A. Transmission demand losses are determined by performing transmission  
22 load-flow simulations using the Power System Simulator for Engineering  
23 ("PSS/E") model for ETI's 12 CP in the analysis period. The demand

1 losses of the bulk transmission system are the sum of average demand  
2 losses in the 500 kV, 345 kV and 230 kV systems. The demand losses of  
3 the local transmission system are the sum of average demand losses in  
4 the 138 kV, 115 kV and 69 kV systems. Distribution demand losses are  
5 calculated by the Simplified Calculation of Loss Equations ("SCALE")  
6 model developed by the Electric Power Research Institute ("EPRI").  
7 SCALE uses the observed customer demand patterns to calculate  
8 demand losses for substation transformers, distribution primaries (feeders  
9 and laterals), distribution secondaries, and distribution transformers.

10 After the demand losses are estimated for all voltage levels, loss  
11 ratios for each voltage level are determined as the ratio of input power to  
12 the input power, less the demand loss calculated for each voltage level.  
13 The cumulative demand loss factor for a given voltage level is determined  
14 as the product of the loss ratio for each voltage level and the cumulative  
15 demand loss factor for the next lower voltage level.

16  
17 Q107. HOW DID ETI ESTIMATE TRANSMISSION DEMAND LOSSES?

18 A. ETI uses the PSS/E transmission network load-flow analysis software to  
19 estimate demand losses for the transmission system. The results from the  
20 PSS/E software show that transmission system losses accounted for  
21 42 MW of the total system losses: 11 MW were lost in the bulk  
22 transmission system, and 31 MW were lost in the local transmission  
23 system (rounded and as reflected on Exhibit MFM-12). Therefore, the

1 remaining 162 MW of losses were attributable to losses in the distribution  
2 primary and distribution secondary systems. These losses are reflected  
3 on Exhibit MFM-12.

4

5 Q108. PLEASE DESCRIBE THE PSS/E MODEL.

6 A. The PSS/E software, created by Power Technologies, Inc., is electric  
7 transmission system network simulation software used by many of the  
8 major utilities in the world to simulate power flows. PSS/E is an  
9 integrated, interactive program for simulating, analyzing, and optimizing  
10 power system performance.

11

12 Q109. PLEASE DESCRIBE HOW SUBSTATION DEMAND LOSSES ARE  
13 ESTIMATED.

14 A. Substation demand losses are estimated for the average of 12 CP for the  
15 test period. Only substation transformer losses are considered in  
16 calculating substation losses. Additional losses, such as in the substation  
17 transformer cooling fans, the control equipment, the feeder bay  
18 equipment, the lightning arrestors, and the capacitor banks, are minimal  
19 and not considered. Test data for a representative group of transformers  
20 are studied. The load loss characteristics of the transformers under  
21 no-load and on-peak conditions are used in developing the loss  
22 estimation.

1           The demands measured in megawatts on the transformers are  
2           determined from the transmission deliveries to the substation (*i.e.*, the net  
3           input into the transmission system less the sum of deliveries to bulk and  
4           local transmission customers and bulk and local transmission system  
5           losses). The total substation transformer loss is determined by multiplying  
6           the sum of the no-load losses per transformer and on-peak transformer  
7           losses per transformer by the number of transformers on the system.

8           The substation transformer demand losses for the bulk  
9           transmission system are estimated to be 3 MW, and the substation  
10          transformer demand losses for the local transmission system are  
11          estimated to be 30 MW, for a total of 33 MW (rounded and as reflected on  
12          Exhibit MFM-12).

13

14   Q110. HOW WERE PRIMARY DISTRIBUTION DEMAND LOSSES  
15   ESTIMATED?

16   A.   The primary distribution system is composed mainly of feeders and  
17          laterals.<sup>14</sup> The typical voltage of ETI's distribution primary system is  
18          13.2 kV or 34.5 kV. The Company calculated losses separately for  
19          feeders and laterals.

---

<sup>14</sup> A feeder is a three-phase circuit that originates at a distribution substation. Feeders generally distribute power to laterals and provide three-phase service to large customers. A typical feeder consists of 3/4-inch diameter aluminum composite steel reinforced cable. A lateral is generally a single-phase circuit that branches from a feeder. Laterals distribute power to smaller customers.

1           The load injected into the distribution feeders was determined by  
2           subtracting the substation transformer losses from transmission supply.  
3           The average loss per feeder was determined for three-phase feeders.<sup>15</sup>  
4           The total feeder demand losses were estimated to be 87 MW for the  
5           analysis period. The equation used to calculate line losses for lateral  
6           distribution lines was the same as the equation used for feeders, except  
7           the Distribution Factor reflected the load diversity characteristics of lateral  
8           distribution lines. For the analysis period, the allocated demand loss for  
9           distribution laterals was 1 MW. The total primary distribution demand  
10          losses, including feeders, laterals, and other losses, were 91 MW  
11          (rounded and as reflected on Exhibit MFM-12).

12

13   Q111. HOW WERE SECONDARY DISTRIBUTION SYSTEM DEMAND LOSSES  
14       DETERMINED?

15   A.   The secondary distribution system consists of many different components.  
16       There are the two major components of the secondary distribution system:  
17       distribution transformers and the secondaries (service drops from the  
18       distribution transformers to the service locations). The voltage of the

---

<sup>15</sup> The formula used to calculate feeder and lateral line losses was  $L = I^2 * R * \text{Distribution Factor}$ . Where:

L = the average demand loss per feeder/lateral for the average of the 12 CP;

I = the average current on the feeder/lateral;

R = the average resistance for the feeder/lateral; and

Distribution Factor = a coefficient which describes the equivalent aggregated distribution along a distribution feeder or lateral. The Distribution Factor is 1.15 for feeders and for laterals.

1 secondary distribution system is typically 240 volts. Distribution  
2 transformer losses and the losses on secondaries were calculated for  
3 ETI's average of 12 CP. Both the no-load and load loss characteristics of  
4 a representative distribution transformer were used to calculate  
5 distribution demand losses.

6 For a secondary, the average on-peak current per secondary  
7 (240 volts) was determined from a representative sampling of ETI's  
8 secondary lines. The average on-peak demand loss per secondary was  
9 determined based upon the average current and the average resistance  
10 for the line.<sup>16</sup> The total secondary demand loss was determined by  
11 multiplying the average loss per secondary by the number of secondaries.  
12 The estimated secondary line loss was 4 MW.

13 The total secondary distribution transformer demand loss was  
14 determined by summing the demand loss under no-load conditions and  
15 the on-peak demand loss of representative secondary distribution  
16 transformers multiplied by the number of secondary distribution  
17 transformers on the Company's distribution system. The estimated  
18 distribution transformer losses were 34 MW. The total secondary  
19 distribution demand losses, including distribution transformers and  
20 distribution secondaries, were 39 MW (as reflected on Exhibit MFM-12).

---

<sup>16</sup> The formula used to calculate secondary line losses was  $L = I^2 * R$ . Where:  
L = the average demand loss per secondary line for the average of the 12 CP;  
I = the average current on the secondary line; and  
R = the average resistance for the secondary line.

1           C.     Development of Transmission and Distribution Energy Losses

2     Q112. PLEASE PROVIDE AN OVERVIEW OF HOW ETI DEVELOPED ITS  
3     ENERGY LOSS FACTORS.

4     A.     Energy loss factors were developed from engineering studies of ETI's  
5     transmission and distribution systems. The Company first estimated  
6     demand loss in order to estimate energy loss; that is, demand loss was an  
7     input into the Company's energy loss calculation. Exhibit MFM-12 depicts  
8     the process used by ETI to estimate demand losses, and Exhibit MFM-13  
9     diagrams the process used by ETI to estimate energy losses.

10           The estimation process for energy losses was bottom-up; that is,  
11     the energy losses were determined for the lowest voltage level on the  
12     system and then for each successively higher voltage level from the  
13     secondary distribution system to the bulk transmission system. The  
14     Company calculated energy loss factors for the analysis period April 1,  
15     2012 through March 31, 2013. The energy loss analysis that I sponsor  
16     estimated energy losses for four voltage levels: (1) the secondary  
17     distribution system; (2) the primary distribution system; (3) the  
18     transmission system below 230 kV and above 69 kV (local transmission  
19     system); and (4) the transmission system 230 kV and above (bulk  
20     transmission system).



1 Q113. PLEASE DESCRIBE HOW THE COMPANY CALCULATES ENERGY  
2 LOSS FACTORS.

3 A. Distribution energy losses are calculated by the SCALE model developed  
4 by EPRI. The SCALE model utilizes known energy loss characteristics of  
5 electric systems and observed customer demand patterns to estimate  
6 energy losses for distribution transformers, distribution secondaries,  
7 distribution primaries (feeders and laterals), and substation transformers.  
8 Observed analysis period load characteristics from a representative  
9 sampling of ETI's distribution system are input into SCALE to determine  
10 distribution energy losses. Transmission energy losses are determined by  
11 performing transmission load-flow simulations using the PSS/E model.

12 After the energy losses are estimated for all voltage levels, loss  
13 ratios for each voltage level are determined as the ratio of input energy to  
14 the input energy less the energy loss calculated for each voltage level.  
15 The cumulative energy loss factor for a given voltage level is determined  
16 as the product of the loss ratio for each voltage level and the cumulative  
17 energy loss factor for the next lower voltage level.

18

19 Q114. WHAT WERE THE COMPANY'S ENERGY LOSSES DURING THE  
20 ANALYSIS PERIOD?

21 A. During the analysis period, the energy injected into ETI's electric system  
22 by ETI's net generation and net interchange was 21,288,833 MWh. The  
23 energy consumed by ETI's customers was 19,344,597 MWh for the same

1           period. The estimated energy loss of the Company's transmission and  
2           distribution system for the analysis period (using engineering equations  
3           and models) was estimated to be 1,102,565 MWh.

4

5   Q115. HOW WERE ENERGY LOSSES DETERMINED FOR ETI'S  
6       DISTRIBUTION TRANSFORMERS AND SECONDARIES?

7   A.   Energy loss for secondary distribution transformers was determined by  
8       multiplying the product of the number of secondary distribution  
9       transformers on the ETI system by the sum of the full-load energy loss  
10      and the no-load energy loss for representative secondary distribution  
11      transformers. The secondary distribution transformer energy loss under  
12      both loading conditions was estimated from manufacturer test data of  
13      energy loss of representative test transformers under prescribed  
14      conditions. The following system load characteristics were utilized to  
15      determine distribution transformer energy losses: the peak responsibility  
16      factor (0.90 for the analysis period), the load factor (0.42 for the analysis  
17      period), and the loss factor (0.22 for the analysis period). Energy losses  
18      estimated for secondary distribution transformers were 250,733 MWh  
19      during the analysis period.

20           For distribution secondaries, ETI utilized the SCALE model and  
21      observed load data for the analysis period from a representative sampling  
22      of its secondary distribution system to determine secondary losses. The  
23      following system load characteristics were utilized to determine secondary

1 losses: the peak responsibility factor (0.85 for the analysis period), the  
2 service coincident factor (0.85 for the analysis period), and the loss factor  
3 (0.22 for the analysis period). During the analysis period, the energy loss  
4 estimated for ETI's distribution secondaries was 16,447 MWh. The total  
5 secondary distribution energy losses including distribution transformers  
6 and distribution secondaries were 267,180 MWh (as reflected on  
7 Exhibit MFM-13).

8

9 Q116. PLEASE DESCRIBE HOW ENERGY LOSSES OF PRIMARY  
10 DISTRIBUTION WERE DETERMINED.

11 A. The energy losses for feeders and the laterals were calculated using the  
12 SCALE model. Annual energy losses were determined by calculating the  
13 product of full-load demand loss, the loss factor (0.25), and the number of  
14 hours per year. Primary distribution energy losses were estimated to be  
15 309,456 MWh for the analysis period (as reflected on Exhibit MFM-13).

16

17 Q117. HOW WERE SUBSTATION TRANSFORMER ENERGY LOSSES  
18 ANALYZED?

19 A. The SCALE model estimated substation losses. ETI analyzed only the  
20 energy losses of substation transformers. Additional losses, such as in  
21 the substation transformer cooling fans, the control equipment, the feeder  
22 bay equipment, the lightning arrestors, and the capacitor banks, were  
23 minimal and not considered. Energy losses were determined under

1 no-load and full-load conditions from manufacturer test data for  
2 representative substation transformers. During the analysis period,  
3 energy losses for substation transformers were estimated at  
4 164,242 MWh (as reflected on Exhibit MFM-13).

5

6 Q118. HOW WERE TRANSMISSION ENERGY LOSSES DETERMINED?

7 A. ETI utilized the PSS/E transmission network load-flow analysis to estimate  
8 energy losses in the bulk and local transmission systems. PSS/E  
9 calculated the power flows for each transmission line and auto-transformer  
10 in the interconnected transmission network. The energy losses were  
11 analyzed at each transmission voltage level. One scenario for each  
12 month of the analysis period was run to calculate transmission energy  
13 losses. The scenarios analyzed changes in area generation, loads, sales,  
14 purchases, and seasonal changes on both the generation and  
15 transmission systems of neighboring utilities. During the analysis period,  
16 the estimated energy losses for the bulk transmission system were  
17 97,645 MWh, and the estimated energy losses at the local transmission  
18 system were 264,043 MWh (as reflected on Exhibit MFM-13).

D. Summary of Results

Q119. PLEASE DESCRIBE THE RESULTS OF YOUR ANALYSIS.

A. Summarizing from Exhibits MFM-12 and MFM-13, and as further presented in Schedule O-6.3, the results of the analyses described above are listed in Table 9.

**Table 9**

Voltage Level	Cumulative Demand Loss Factor	Cumulative Energy Loss Factor
Transmission 230 kV and Above (Bulk Transmission System)	<b>1.003190</b>	<b>1.004608</b>
Transmission below 230 and above 69 kV (Local Transmission System)	<b>1.013438</b>	<b>1.019753</b>
Distribution Primary System	<b>1.068849</b>	<b>1.060855</b>
Distribution Secondary System	<b>1.088532</b>	<b>1.088718</b>

The loss factors cited in the table above were calculated with respect to the generation source.

Q120. ARE THE DEMAND AND ENERGY LOSS FACTORS PROPOSED BY ETI IN THIS DOCKET THE SAME AS THE LOSS FACTORS PROPOSED BY ETI IN DOCKET NOS. 37744 AND 39896?

A. No. The demand and energy loss factors vary slightly among these dockets. Table 10 summarizes the loss factors calculated in Docket Nos. 37744 and 39896. Also, the percentage changes from the factors proposed in this proceeding to the factors calculated and proposed in those dockets are summarized. The variances in the loss factors in Table 10 are the result of changes in generation patterns and load patterns from one analysis period to the next. For Docket No. 37744, the

- 1 analysis period was January 1, 2008 through December 31, 2008, and for  
2 Docket No. 39896, it was January 1, 2010 through December 31, 2010.

**Table 10**


<b>Voltage Classes</b>	<b>Docket No. 37744</b>	<b>Docket No. 39896</b>	<b>Proposed Factors in this Proceeding</b>
<b>Demand</b>			
Bulk	1.003675	1.003696	1.003190
Local	1.017129	1.015907	1.013438
Primary	1.069755	1.073141	1.068849
Secondary	1.090548	1.092546	1.088532
<b>% Changes From Proposed Factors</b>			
Bulk	0.00%	-0.05%	
Local	-0.12%	-0.24%	
Primary	0.32%	-0.40%	
Secondary	0.18%	-0.37%	
<b>Energy</b>			
Bulk	1.005793	1.005774	1.004608
Local	1.025272	1.023010	1.019753
Primary	1.058685	1.060428	1.060855
Secondary	1.087199	1.088754	1.088718
<b>% Changes From Proposed Factors</b>			
Bulk	0.00%	-0.12%	
Local	-0.22%	-0.32%	
Primary	0.16%	0.04%	
Secondary	0.14%	0.00%	

- 3 Q121. ARE THE RESULTS FROM THE LOSS ANALYSIS PRESENTED IN  
4 THIS TESTIMONY REASONABLE?  
5 A. Yes. The demand and energy loss factors were calculated in a manner  
6 consistent with standard utility transmission planning practices. The

3

5 Q122. DOES THIS CONCLUDE YOUR DIRECT TESTIMONY?


6 A. Yes, at this time.






This page has been intentionally left blank.

# Operations Functions & Classes (\$ Total ETI Adjusted)



This page has been intentionally left blank.

# ENERGY DELIVERY SERVICES OVERVIEW




This page has been intentionally left blank.

**List of Utilities Considered for Entergy's Benchmarking Analysis**

1. Alabama Power Company
2. Ameren Illinois
3. Ameren Missouri
4. Baltimore Gas & Electric Company
5. CenterPoint Energy Houston Electric, L.L.C.
6. Cleveland Electric Illuminating Company (The)
7. Commonwealth Edison Company
8. Detroit Edison Company (The)
9. Duke Energy Carolinas
10. Duke Energy Indiana
11. Duke Energy Kentucky
12. Duke Energy Ohio
13. Entergy Arkansas, Inc.
14. Entergy Gulf States Louisiana, L.L.C.
15. Entergy Louisiana, LLC
16. Entergy Mississippi, Inc.
17. Entergy New Orleans, Inc.
18. Entergy Texas, Inc.
19. Florida Power & Light Company
20. Georgia Power Company
21. Gulf Power Company
22. Jersey Central Power & Light Company
23. Kansas City Power & Light Company
24. KCP&L Greater Missouri Operations Company
25. Kentucky Utilities Company
26. Louisville Gas & Electric Company
27. Metropolitan Edison Company
28. Mississippi Power Company
29. Monogahela Power Company

30. Northern States Power Company (Minnesota)
31. Northern States Power Company (Wisconsin)
32. Ohio Edison Company
33. Oncor Electric Delivery
34. PECO Energy Company
35. Pennsylvania Electric Company
36. Pennsylvania Power Company
37. Potomac Edison Company (The)
38. PPL Electric Utilities Corporation
39. Progress Energy Carolinas
40. Progress Energy Florida
41. Public Service Company of Colorado
42. Public Service Electric & Gas Company
43. South Carolina Electric & Gas Company
44. Southwestern Public Service Company
45. Tampa Electric Company
46. Toledo Edison Company (The)
47. Virginia Electric & Power Company
48. West Penn Power Company

**ETI's Transmission O&M Expenses Per Transmission Line  
Mile (FERC Form 1) 3-Year Average (2010 to 2012)**



**T-O&M per T-Line Mile**      **Average**      **1st Quartile**



This page has been intentionally left blank.

## ETI's Transmission O&M Expenses as a Percent of ETI's Total

