



Control Number: 42146



Item Number: 12

Addendum StartPage: 0

RECEIVED
11 FEB 14 PM 2:57
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2013 Reporting Year

AEP Texas Central Company

Project 42146

12

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2013	1.40	0.16	0.05	0.10	0.17	0.14	0.15	0.11	0.10	0.12	0.07	0.12	0.11
Scheduled													
2013	0.06	0.00	0.01	0.01	0.01	0.01	0.01	0.00	0.01	0.00	0.00	0.00	0.00
Outside Causes													
2013	0.17	0.01	0.01	0.03	0.01	0.02	0.02	0.01	0.00	0.02	0.00	0.01	0.02
Major Events													
2013	0.10		0.06		0.04		0.00				0.00	0.00	0.00

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2013	148.69	20.38	5.17	11.52	19.09	14.52	16.12	11.18	9.32	9.89	7.80	12.55	11.15
Scheduled													
2013	3.71	0.13	0.49	0.31	0.48	0.41	0.54	0.14	0.33	0.19	0.30	0.14	0.26
Outside Causes													
2013	11.28	0.74	0.37	2.73	0.79	0.97	1.24	1.95	0.17	1.05	0.09	0.53	0.63
Major Events													
2013	20.95		9.35		6.78		1.12				1.41	2.28	

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

737

Add or Delete Rows as Necessary

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1	44	GILA	94CS350	140	11.879
2	1	GOVERNMENT WELLS	94LA6800	217	10.180
3	13	NORTH EDINBURG	94SB4240	2,291	8.803
4	432	EAGLE LAKE	94CN9455	577	6.315
5	106	MCKENZIE ROAD	94CS140	259	5.857
6	566	RAYMONDVILLE #1	94SB630	787	5.773
7	430	CAUSEWAY	94SB4795	1,199	5.697
8	413	SAN BENITO	94SB4135	1,249	5.667
9	39	CRYSTAL CITY	94LA330	1,317	5.552
10	541	SAN BENITO	94SB3910	1,768	5.476
11	7	MOORE FIELD	94SB3120	129	5.473
12	81	FALFURRIAS	94LA5210	1,140	5.440
13	96	PORT ISABEL S.S.	94SB4070	296	5.395
14	108	CABANISS	94CS80	1,170	5.312
15	153	PEARSALL	94LA7050	913	5.286
16	312	BANQUETTE	94CS9000	435	5.276
17	509	PARKER	94CN9010	18	5.222
18	324	CRYSTAL CITY	94LA190	1,573	5.139
19	37	EAST HARRISON	94SB3950	555	5.074
20	58	CHARLOTTE	94LA2780	481	4.952
21	380	CONTINENTAL	94SB4880	62	4.726
22	145	SOUTHSIDE	94CS8025	1,064	4.706
23	57	GOVERNMENT WELLS	94LA7240	211	4.659
24	165	CAUSEWAY	94SB4765	966	4.626
25	267	COFFEE PORT	94SB1090	1,153	4.499
26	294	GRETA	94CN7890	326	4.420
27	415	WESMER	94SB9705	1,088	4.404
28	256	BANDERA ELECTRIC (LEAKEY)	94LAL30	251	4.367
29	356	CONTINENTAL	94SB3650	23	4.348
30	336	ALAZAN	94CS620	164	4.311
31	280	PUEBLO	94LA95	2,165	4.289
32	245	NORTH PADRE ISLAND	94CS5170	1,157	4.221
33	87	ELSA	94SB710	1,797	4.187
34	475	WESMER	94SB6900	1,605	4.135
35	183	PORT LAVACA	94CN8310	310	3.987
36	73	GARWOOD CITY	94CN2560	200	3.955
37	31	RIO RICO	94SB8290	370	3.938
38	189	BERCLAIR	94CN990	208	3.880
39	429	KENEDY S.S.	94CN8320	958	3.873
40	343	BIG WELLS	94LA2630	28	3.857
41	512	SAN BENITO	94SB4030	2,419	3.852
42	116	COTULLA	94LA90	223	3.843
43	196	MORRIS STREET	94CS7625	567	3.799
44	3	MAVERICK	94LA9680	729	3.796
45	582	MOORE FIELD	94SB3960	1,826	3.767

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
46	188	WEST OSO	94CS9085	782	3.753
47	123	EAGLE LAKE	94CN320	631	3.732
48	209	PALACIOS	94CN6830	788	3.708
49	79	PLEASANTON	94LA9475	1,328	3.677
50	49	BLESSING	94CN1030	261	3.648
51	580	HAIN DRIVE	94SB8065	1,334	3.593
52	499	DEL RIO CITY	94LA1930	1,054	3.590
53	42	RAYMONDVILLE #2	94SB3170	697	3.577
54	198	LOS FRESNOS	94SB5335	2,015	3.574
55	300	BAY CITY	94CN1110	1,281	3.533
56	363	ARMSTRONG	94CS6050	67	3.522
57	453	BEEVILLE	94CN8510	876	3.511
58	626	ELSA	94SB700	1,410	3.487
59	29	CHARLOTTE	94LA2790	178	3.483
60	216	UVALDE	94LA5060	1,337	3.476
61	431	LA GRULLA	94SB5005	2,016	3.367
62	218	NORTH MERCEDES	94SB4860	1,396	3.304
63	643	SOUTHSIDE	94CS8045	1,018	3.303
64	38	MARKHAM	94CN5550	109	3.303
65	119	SOUTH EAST EDINBURG	94SB5045	1,903	3.273
66	558	WESLACO UNIT	94SB5970	2,270	3.261
67	8	DILLEY	94LA6400	180	3.261
68	709	EL GATO	94SB720	2,448	3.259
69	581	KINGSVILLE	94CS1140	1,010	3.228
70	352	RANGERVILLE	94SB3420	771	3.200
71	469	PALMHURST	94SB2820	1,672	3.194
72	190	ALICE	94LA2540	1,131	3.188
73	172	AIRLINE	94CS7270	1,030	3.177
74	400	AIRLINE	94CS8890	532	3.175
75	199	ENCINAL	94LA2160	897	3.168
76	new station	CATARINA	94LA2380	204	3.157
77	219	RIO GRANDE CITY	94SB3210	1,776	3.139
78	90	BLESSING	94CN8790	746	3.137
79	676	ROCKSPRINGS	94LA2600	378	3.135
80	586	SABINAL	94LA485	485	3.101
81	723	ROCKSPRINGS	94LA8040	329	3.100
82	483	GREGORY	94CS8560	245	3.090
83	368	GILA	94CS345	49	3.061
84	215	GREENLAKE	94CN2760	567	3.046
85	619	HARLINGEN	94SB660	1,894	3.036
86	186	LULING - LCRA	94CN10	368	3.027
87	246	PORT ISABEL S.S.	94SB3820	212	3.024
88	378	SOUTH MCALLEN	94SB3935	1,309	3.015
89	531	LOS FRESNOS	94SB7270	2,051	3.014
90	544	ALICE	94LA1770	1,617	2.999
91	716	SOUTH MISSION	94SB3940	815	2.999
92	492	HIGHWAY 9	94CS9830	140	2.986
93	171	LOS FRESNOS	94SB2160	1,151	2.983
94	722	MILO	94LA8365	1,842	2.983
95	253	BRUNI	94LA1100	628	2.976

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
96	487	MINES ROAD	94LA3680	952	2.893
97	398	RODD FIELD	94CS2190	2,630	2.891
98	105	HARLINGEN	94SB380	2,338	2.888
99	35	CARRIZO SPRINGS	94LA910	2,103	2.886
100	489	NORTH EDINBURG	94SB560	999	2.883
101	344	NORTH MERCEDES	94SB3770	1,692	2.868
102	67	GREGORY	94CS5900	104	2.856
103	178	RAYMONDVILLE #1	94SB620	619	2.855
104	214	RIO RICO	94SB8330	393	2.852
105	693	GARCENO	94SB2135	2,129	2.832
106	85	FREER	94LA1500	216	2.829
107	226	PORT ARANSAS	94CS1000	1,603	2.816
108	5	LOS FRESNOS	94SB4315	983	2.814
109	80	PLEASANTON	94LA9505	1,583	2.765
110	239	PORTLAND	94CS9270	1,401	2.760
111	591	BROWNSVILLE	94SB4280	286	2.748
112	103	PLEASANTON	94LA2080	1,615	2.739
113	659	NORTH EDINBURG	94SB3570	1,874	2.723
114	635	EAGLE PASS CITY	94LA2650	1,326	2.715
115	217	CASA BLANCA	94CS55	833	2.711
116	125	COLUMBUS	94CN930	911	2.684
117	353	PREMONT	94LA2730	205	2.663
118	486	NIXON	94CN810	538	2.651
119	237	BEEVILLE	94CN1760	1,824	2.651
120	12	SOUTHSIDE	94CS5335	1,149	2.636
121	40	VILLA CAVAZOS	94SB1980	1,554	2.610
122	473	SOUTH SANTA ROSA	94SB1235	621	2.594
123	22	BRUNI	94LA5440	132	2.576
124	327	KENEDY S.S.	94CN8340	996	2.576
125	163	WEST HARLINGEN	94SB3700	1,729	2.560
126	367	POLK AVENUE	94SB4170	1,738	2.554
127	298	EAGLE LAKE	94CN310	724	2.525
128	288	NORTH WESLACO	94SB4810	1,354	2.504
129	115	TATTON	94CS8200	1,032	2.500
130	135	HIDALGO	94SB4845	1,118	2.485
131	240	SOUTHSIDE	94CS7925	1,341	2.485
132	133	WESLACO UNIT	94SB8610	1,164	2.478
133	672	LAREDO PLANT	94LA8745	716	2.472
134	64	STAFFORD HILL	94CN1550	215	2.456
135	303	SOUTH EAST EDINBURG	94SB6580	1,378	2.455
136	269	SOUTHSIDE	94CS7905	1,838	2.454
137	457	SUNCHASE	94SB1155	1,456	2.440
138	282	AIRLINE	94CS7280	625	2.440
139	156	RAYMONDVILLE #1	94SB3130	276	2.431
140	56	HALL ACRES ROAD	94SB8870	1,898	2.424
141	703	ANNA STREET	94LA2250	1,562	2.414
142	230	BROOKHOLLOW	94CN8960	573	2.408
143	442	COFFEE PORT	94SB1095	977	2.398
144	36	GREENLAKE	94CN2750	1,142	2.394
145	121	GREENLAKE	94CN2740	31	2.387

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
146	476	BEEVILLE	94CN490	978	2.383
147	652	ANNA STREET	94LA850	1,608	2.380
148	433	OLMITO	94SB905	1,493	2.370
149	169	NORTH MERCEDES	94SB3840	637	2.369
150	695	ODEM	94CS5575	60	2.367
151	611	FULTON	94CS3070	1,596	2.362
152	502	SOUTH MISSION	94SB3980	1,251	2.353
153	15	BEEVILLE	94CN300	1,740	2.345
154	328	SOUTH SANTA ROSA	94SB1225	825	2.342
155	new circuit	DILLEY	94LA2885	803	2.341
156	249	VILLA CAVAZOS	94SB5680	1,690	2.341
157	532	HEARN ROAD	94CS8990	1,184	2.329
158	27	RAYMONDVILLE #2	94SB3250	31	2.323
159	206	RAYMONDVILLE #1	94SB800	675	2.319
160	527	SAN BENITO	94SB3920	2,419	2.313
161	638	FREER	94LA5200	1,073	2.282
162	434	BIG WELLS	94LA1570	469	2.277
163	326	GOODWIN	94SB7380	2,181	2.271
164	191	GEORGE WEST	94CN1320	782	2.271
165	421	EAGLE PASS CITY	94LA450	752	2.267
166	387	BLESSING	94CN8780	61	2.262
167	391	ARCADIA	94CS1400	434	2.258
168	660	WEIL TRACT (138/12KV)	94CS1990	1,300	2.248
169	686	DEL MAR	94LA220	1,877	2.236
170	51	MORRIS STREET	94CS8820	1,202	2.236
171	371	WEST HARLINGEN	94SB3720	1,991	2.233
172	340	HEARN ROAD	94CS870	1,153	2.218
173	587	POINT COMFORT	94CN6060	57	2.211
174	714	ANNA STREET	94LA5780	706	2.210
175	159	FREER	94LA2900	164	2.189
176	150	POLK AVENUE	94SB4520	891	2.173
177	19	MORRIS STREET	94CS8830	1,550	2.166
178	467	COMSTOCK	94LA230	181	2.149
179	21	PORT LAVACA	94CN2480	1,532	2.129
180	248	NORTH PADRE ISLAND	94CS1010	2,595	2.129
181	275	TATTON	94CS950	536	2.116
182	657	HOLLY	94CS5820	928	2.113
183	425	PHARAOH	94CS5185	2,822	2.107
184	697	MILO	94LA3070	3,290	2.098
185	319	NORTH ALAMO	94SB3610	1,782	2.096
186	14	POINT COMFORT	94CN2460	343	2.085
187	374	HOLLY	94CS7620	2,580	2.084
188	420	LA GRULLA	94SB4120	1,416	2.075
189	704	MORRIS STREET	94CS7465	641	2.073
190	50	LA PRYOR	94LA580	204	2.064
191	271	MILO	94LA3065	185	2.059
192	548	ARANSAS PASS	94CS9130	367	2.057
193	151	BAY CITY	94CN6670	1,777	2.050
194	138	LAGUNA	94CS9590	2,201	2.045
195	379	HARLINGEN S.S.	94SB4110	820	2.038

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
196	32	ELSA	94SB690	2,276	2.032
197	542	LAGUNA	94CS9065	2,070	2.028
198	562	HAIN DRIVE	94SB9690	827	2.025
199	88	DILLEY	94LA510	579	2.000
200	143	SOUTH SANTA ROSA	94SB7485	1,016	1.973
201	568	CLARKWOOD	94CS5525	1,021	1.969
202	126	UVALDE	94LA6620	2,714	1.962
203	477	NIXON	94CN2620	406	1.901
204	403	GATEWAY	94LA350	1,731	1.897
205	384	LYTLE	94LA2850	620	1.890
206	299	YORKTOWN	94CN8420	1,084	1.888
207	61	VICTORIA POWER PLANT	94CN1390	1,165	1.857
208	711	SAN BENITO	94SB3860	236	1.856
209	140	DEL RIO CITY	94LA420	2,236	1.839
210	25	TAFT	94CS1180	1,038	1.829
211	305	HALL ACRES ROAD	94SB5465	1,684	1.822
212	207	WESMER	94SB1850	1,262	1.813
213	104	BAY CITY	94CN2700	1,065	1.808
214	574	MAGNOLIA	94CN2840	10	1.800
215	192	ALICE	94LA2530	1,488	1.798
216	573	NAVAL BASE	94CS1380	2,348	1.790
217	441	MOORE FIELD	94SB3110	644	1.783
218	317	RANDADO	94LA8350	124	1.782
219	175	GOLIAD	94CN8220	1,042	1.776
220	549	CASA BLANCA	94CS1300	994	1.769
221	701	SINTON	94CS1750	503	1.765
222	24	LA PRYOR	94LA570	147	1.755
223	168	MUSTANG ISLAND	94CS8510	409	1.753
224	620	NORTH MCALLEN	94SB4995	1,962	1.747
225	655	WEIL TRACT (138/12KV)	94CS2520	543	1.744
226	456	HIGHWAY 9	94CS6720	1,317	1.739
227	295	PUEBLO	94LA275	2,784	1.735
228	424	PREMONT	94LA6610	811	1.725
229	690	PALMVIEW	94SB3930	1,100	1.723
230	404	SAN BENITO	94SB4945	1,761	1.720
231	136	PORTLAND	94CS9290	1,719	1.710
232	229	SOUTH SANTA ROSA	94SB1240	1,583	1.702
233	235	HOLLY	94CS1480	1,716	1.689
234	323	HARLINGEN S.S.	94SB4090	2,292	1.688
235	86	DEVINE	94LA8100	1,536	1.687
236	364	HARLINGEN S.S.	94SB5350	765	1.686
237	445	HIGHWAY 9	94CS6770	1,148	1.678
238	539	NORTH VICTORIA	94CN6390	1,653	1.666
239	332	GOVERNMENT WELLS	94LA7250	592	1.660
240	683	KINGSVILLE	94CS1670	418	1.641
241	258	JOURDANTON	94LA5695	1,330	1.624
242	16	CONTINENTAL	94SB4080	63	1.619
243	313	SOUTHSIDE	94CS8055	862	1.618
244	333	EDNA	94CN5765	1,685	1.608
245	498	ALAZAN	94CS2740	33	1.606

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
246	30	PALACIOS	94CN8550	38	1.605
247	23	GOLIAD	94CN6540	1,165	1.597
248	560	BUENA VISTA	94LA9385	2,097	1.596
249	220	BROOKHOLLOW	94CN7580	460	1.587
250	242	CARRIZO SPRINGS	94LA370	541	1.584
251	454	PORT ISABEL S.S.	94SB3760	2,135	1.574
252	390	SANTO NINO	94LA75	1,521	1.572
253	45	MATTHEWS	94CN1740	160	1.569
254	362	FALFURRIAS	94LA1080	443	1.564
255	205	WEST MCALLEN	94SB4555	1,504	1.561
256	417	KLEBERG	94CS8140	419	1.551
257	561	BAY CITY	94CN7480	1,887	1.544
258	641	SKIDMORE	94CS380	336	1.539
259	197	BONNIEVIEW	94CS8020	514	1.533
260	634	EL GATO	94SB780	1,690	1.530
261	225	PHARR	94SB1645	2,588	1.526
262	496	RIO RICO	94SB5050	1,721	1.518
263	642	AIRLINE	94CS9605	709	1.518
264	260	WEST HARLINGEN	94SB4870	729	1.517
265	337	RODD FIELD	94CS225	1,224	1.513
266	194	CLARKWOOD	94CS7230	628	1.505
267	18	TATTON	94CN8490	124	1.500
268	26	NORTH ALAMO	94SB3580	837	1.484
269	443	FALFURRIAS	94LA2830	1,468	1.478
270	93	NORTH PADRE ISLAND	94CS7900	1,303	1.475
271	447	RACHAL	94LA8145	346	1.474
272	485	EAGLE PASS CITY	94LA2770	2,950	1.474
273	599	STADIUM	94LA8540	1,610	1.473
274	570	PORTLAND	94CS6505	1,679	1.470
275	223	COLUMBUS	94CN6180	1,167	1.470
276	685	LAREDO PLANT	94LA8565	1,405	1.468
277	381	HOLLY	94CS9675	1,780	1.466
278	525	STADIUM	94LA6950	538	1.450
279	446	RANGERVILLE	94SB4060	876	1.445
280	167	REFUGIO	94CN1040	182	1.445
281	236	WEST HARLINGEN	94SB3800	1,337	1.445
282	459	HIGHWAY 9	94CS6780	795	1.428
283	565	HAIN DRIVE	94SB270	991	1.428
284	528	NORTH VICTORIA	94CN2240	773	1.427
285	325	SOUTHSIDE	94CS8035	1,092	1.425
286	355	BISHOP	94CS2690	544	1.417
287	48	WOODSBORO	94CS8330	1,098	1.414
288	78	ZAPATA	94LA7330	1,346	1.412
289	662	SOUTH MCALLEN	94SB3790	1,904	1.409
290	526	SKIDMORE	94CS600	368	1.408
291	621	LA GRULLA	94SB5110	1,393	1.407
292	146	CHARLOTTE	94LA8120	210	1.405
293	376	KNIPPA	94LA6365	305	1.400
294	654	LAREDO HEIGHTS	94LA6820	2,112	1.394
295	551	PLEASANTON	94LA120	1,255	1.392

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
296	262	HOLLY	94CS1950	801	1.391
297	187	WESLACO UNIT	94SB7630	2,522	1.391
298	682	HAIN DRIVE	94SB9700	787	1.388
299	649	PORT ARANSAS	94CS3030	825	1.388
300	513	POLK AVENUE	94SB4180	1,209	1.378
301	419	CASA BLANCA	94CS5115	280	1.375
302	605	MAGRUDER	94CN7690	592	1.373
303	47	HALL ACRES ROAD	94SB5585	686	1.367
304	500	KINGSVILLE	94CS1130	2,295	1.366
305	148	SOUTHSIDE	94CS7955	1,048	1.365
306	577	PALMHURST	94SB2535	1,191	1.363
307	257	SOUTHSIDE	94CS7995	1,549	1.363
308	624	LAREDO PLANT	94LA8505	757	1.363
309	571	LA GRULLA	94SB6150	1,099	1.359
310	314	STADIUM	94LA7490	1,308	1.356
311	653	PUEBLO	94LA130	1,368	1.351
312	590	WESLACO UNIT	94SB8195	1,670	1.344
313	358	ROMA	94SB3060	1,562	1.335
314	281	RAYMONDVILLE #2	94SB3240	969	1.335
315	366	GOODWIN	94SB4380	1,451	1.331
316	210	GREGORY	94CS5920	597	1.330
317	663	REFUGIO	94CN1170	869	1.330
318	101	BISHOP	94CS7180	935	1.325
319	623	HEARN ROAD	94CS9665	571	1.322
320	157	CARANCAHUA	94CN5870	453	1.322
321	428	MATHIS	94CS340	1,480	1.316
322	162	LULING - LCRA	94CN20	287	1.314
323	66	PHARAOH	94CS1365	461	1.304
324	439	UVALDE	94LA480	1,321	1.304
325	128	HAMILTON ROAD	94LA9665	940	1.301
326	142	ODEM	94CS385	408	1.289
327	102	UVALDE	94LA550	670	1.284
328	536	GOODWIN	94SB4390	405	1.284
329	110	KENEDY	94CN1970	678	1.277
330	373	PORT LAVACA	94CN2490	1,079	1.272
331	674	MATHIS	94CS1410	460	1.272
332	179	MUSTANG ISLAND	94CS9470	665	1.271
333	357	PHARAOH	94CS1285	1,766	1.270
334	109	ZAPATA	94LA8300	1,704	1.267
335	63	MAGRUDER	94CN6680	698	1.266
336	345	HARLINGEN S.S.	94SB4230	1,323	1.263
337	360	GATEWAY	94LA3595	1,513	1.260
338	468	EL CAMPO	94CN2800	1,332	1.259
339	481	GOODWIN	94SB3530	1,544	1.258
340	614	WASHINGTON STREET	94LA6525	2,079	1.257
341	33	MAGRUDER	94CN245	1,103	1.257
342	600	FULTON	94CS440	2,047	1.249
343	84	NAVAL BASE	94CS6330	314	1.248
344	208	WESMER	94SB4050	1,913	1.247
345	559	ELSA	94SB3500	1,162	1.246

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
346	322	NORTH MCALLEN	94SB2750	3,220	1.243
347	203	CRESTONIO	94LA270	614	1.238
348	82	BROWNSVILLE	94SB3050	1,960	1.236
349	361	NORTH MCALLEN	94SB3830	1,305	1.234
350	350	HOLLY	94CS1370	1,885	1.227
351	321	HIGHWAY 9	94CS6730	531	1.226
352	529	POLK AVENUE	94SB4610	1,347	1.217
353	618	SOUTH MISSION	94SB5215	1,249	1.217
354	185	HAINE DRIVE	94SB3490	1,058	1.213
355	606	EAGLE PASS CITY	94LA2745	919	1.213
356	479	ARANSAS PASS	94CS8270	606	1.211
357	11	PETTUS	94CN8210	369	1.209
358	628	NORTH MCALLEN	94SB5055	3,179	1.209
359	347	LAREDO HEIGHTS	94LA9400	1,428	1.208
360	95	CONOCO-CHITTAM RANCH	94LA8580	29	1.207
361	650	MORRIS STREET	94CS8840	600	1.205
362	261	RUNGE	94CN7320	643	1.204
363	622	HEARN ROAD	94CS2220	1,522	1.202
364	593	NORTH VICTORIA	94CN1580	1,037	1.199
365	72	FULTON	94CS6070	3,273	1.198
366	564	WESMER	94SB7760	2,368	1.197
367	348	HEARN ROAD	94CS8980	1,205	1.197
368	141	SHARYLAND	94SB2020	2,329	1.196
369	195	OLMITO	94SB715	533	1.186
370	335	KINGSVILLE	94CS1350	367	1.185
371	575	ELSA	94SB3520	435	1.184
372	658	MCCOLL ROAD	94SB4780	2,160	1.177
373	435	SUNCHASE	94SB1150	1,276	1.176
374	708	HALL ACRES ROAD	94SB9595	1,140	1.166
375	277	KENEDY S.S.	94CN6750	899	1.165
376	613	SOUTH MCALLEN	94SB3850	794	1.162
377	308	HIDALGO	94SB3400	852	1.162
378	647	AIRLINE	94CS5870	890	1.161
379	455	ANNA STREET	94LA900	2,918	1.155
380	286	ARANSAS PASS	94CS8280	564	1.152
381	388	LAREDO HEIGHTS	94LA2100	2,106	1.150
382	316	PORT ISABEL S.S.	94SB9295	654	1.150
383	726	SOUTH MCALLEN	94SB5065	114	1.149
384	399	ROBSTOWN	94CS1650	353	1.147
385	680	ARANSAS PASS	94CS1250	393	1.145
386	731	FOSTER FIELD	94CN8880	112	1.143
387	699	AIRLINE	94CS8260	1,502	1.143
388	341	NORTH VICTORIA	94CN7860	1,487	1.143
389	518	EAST HARRISON	94SB4360	1,724	1.136
390	472	PORTLAND	94CS9370	1,481	1.133
391	268	DEL MAR	94LA490	751	1.124
392	342	CITRUS CITY	94SB7985	1,708	1.121
393	422	UNIVERSITY	94LA930	775	1.121
394	407	RIO GRANDE CITY	94SB3220	1,716	1.121
395	394	WEIL TRACT (138/12KV)	94CS5405	161	1.118

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
396	629	HOLLY	94CS7740	1,987	1.117
397	177	UVALDE	94LA540	1,210	1.113
398	553	WESLACO UNIT	94SB2195	1,086	1.112
399	41	MORRIS STREET	94CS5655	978	1.104
400	452	ANNA STREET	94LA780	469	1.104
401	583	DEL MAR	94LA7930	1,315	1.102
402	675	SOUTHSIDE	94CS5345	396	1.101
403	6	CARRIZO SPRINGS	94LA860	1,388	1.097
404	160	SOUTH EAST EDINBURG	94SB4015	424	1.092
405	438	ESCONDIDO	94LA3350	1,123	1.092
406	97	KNIPPA	94LA6535	22	1.091
407	204	HIGHWAY 9	94CS7210	336	1.086
408	689	CABANISS	94CS75	2,112	1.086
409	233	ZAPATA	94LA2710	47	1.085
410	667	HIGHWAY 9	94CS7200	656	1.082
411	651	CRESTONIO	94LA6660	762	1.079
412	174	GREGORY	94CS420	383	1.078
413	354	WADSWORTH	94CN8630	643	1.070
414	666	PALMHURST	94SB2525	1,936	1.068
415	new station	MAYO	94CS625	223	1.067
416	202	WEST MCALLEN	94SB6385	207	1.063
417	359	SHARYLAND	94SB2035	2,289	1.062
418	276	MCCOLL ROAD	94SB2810	2,234	1.049
419	423	SHARYLAND	94SB2010	1,117	1.041
420	725	CAUSEWAY	94SB4775	1,056	1.040
421	382	ESCONDIDO	94LA2035	2,604	1.036
422	408	EAGLE PASS CITY	94LA2510	584	1.027
423	74	THREE RIVERS	94CN2580	119	1.025
424	717	BEEVILLE	94CN2380	208	1.024
425	519	POLK AVENUE	94SB4900	2,638	1.013
426	411	RANDADO	94LA8360	161	1.012
427	new circuit	PEARSALL	94LA3675	1,437	1.001
428	694	CLARKWOOD	94CS2170	12	1.000
429	28	PHARR	94SB1625	2,136	0.998
430	386	NORTH MCALLEN	94SB5060	2,357	0.997
431	515	NORTH MCALLEN	94SB2980	1,710	0.996
432	673	EAST HARRISON	94SB4310	1,167	0.991
433	401	MILO	94LA6940	778	0.990
434	418	NORTH PADRE ISLAND	94CS720	1,103	0.985
435	533	POLK AVENUE	94SB4600	2,714	0.982
436	193	ARCADIA	94CS1360	1,569	0.978
437	94	WEST MCALLEN	94SB4515	806	0.974
438	71	JOURDANTON	94LA880	310	0.968
439	278	EDNA	94CN5785	743	0.956
440	252	NORDHEIM	94CN470	257	0.953
441	596	VILLA CAVAZOS	94SB7615	968	0.951
442	633	WEST MCALLEN	94SB4535	2,823	0.950
443	521	RACHAL	94LA6595	295	0.929
444	470	DARST	94CN790	249	0.928
445	727	HAIN DRIVE	94SB9240	41	0.927

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
446	493	EL CAMPO	94CN2860	823	0.921
447	684	HIGHWAY 9	94CS6760	661	0.908
448	517	SOUTH PADRE ISLAND	94SB4695	1,373	0.904
449	227	LIVE OAK	94CS1090	275	0.887
450	584	PREMONT	94LA2720	776	0.884
451	255	ALICE	94LA1790	344	0.884
452	9	THREE RIVERS	94CN8430	185	0.881
453	396	PLACEDO	94CN7970	456	0.877
454	547	STADIUM	94LA7810	1,653	0.876
455	397	HALL ACRES ROAD	94SB3670	881	0.871
456	291	PRAIRIE PUMP	94CN1940	70	0.843
457	589	WESLACO UNIT	94SB7455	1,220	0.841
458	540	LA PRYOR	94LA2440	687	0.837
459	505	CITRUS CITY	94SB3470	3,495	0.835
460	664	DEL MAR	94LA10	1,927	0.833
461	161	VICTORIA POWER PLANT	94CN7600	153	0.830
462	617	MALONE	94CN7560	105	0.829
463	122	BROOKHOLLOW	94CN8950	873	0.827
464	510	MAGRUDER	94CN7870	1,324	0.819
465	158	CRYSTAL CITY	94LA140	766	0.813
466	426	PREMONT	94LA6570	711	0.800
467	173	CHASE FIELD	94CN460	10	0.800
468	471	STADIUM	94LA7800	671	0.799
469	385	BEEVILLE	94CN8090	1,362	0.790
470	370	FOSTER FIELD	94CN2550	212	0.783
471	287	EL CAMPO	94CN5745	886	0.782
472	221	MINES ROAD	94LA3745	1,686	0.762
473	311	SHARYLAND	94SB5105	1,558	0.757
474	339	VICTORIA POWER PLANT	94CN8170	776	0.742
475	213	HARLINGEN S.S.	94SB320	1,492	0.741
476	75	CITRUS CITY	94SB9775	1,478	0.740
477	482	GOODWIN	94SB4625	355	0.724
478	304	LIVE OAK	94CS1080	813	0.716
479	91	THREE RIVERS	94CN5190	903	0.698
480	70	WEST OSO	94CS9095	1,589	0.696
481	52	AMISTAD DAM	94LA5450	1,156	0.690
482	488	SOUTH SANTA ROSA	94SB1215	1,639	0.686
483	478	CLARKWOOD	94CS9570	1,144	0.680
484	285	RIO BRAVO	94LA300	790	0.668
485	534	FULTON	94CS9050	1,646	0.666
486	new station	BIG OAK	94CN420	131	0.664
487	130	INGLESIDE CITY	94CS6040	251	0.657
488	579	PALMVIEW	94SB6790	3,009	0.651
489	180	YORKTOWN	94CN8380	824	0.644
490	511	SIERRA VISTA	94LA7360	2,675	0.639
491	334	EDROY	94CS6990	269	0.636
492	514	KLEBERG	94CS1560	1,361	0.635
493	270	SAN DIEGO	94LA2880	1,279	0.633
494	523	BAY CITY	94CN6450	924	0.632
495	114	BROWNSVILLE	94SB4290	382	0.628

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
496	444	MARKHAM	94CN6440	427	0.625
497	461	GATEWAY	94LA390	1,944	0.622
498	228	MORRIS STREET	94CS2515	1,090	0.620
499	346	EAST HARRISON	94SB3190	1,467	0.620
500	330	KENEDY	94CN6270	544	0.619
501	244	ARCADIA	94CS1450	1,925	0.618
502	449	SEAWALL	94CS9450	290	0.617
503	293	NIXON	94CN5990	815	0.613
504	520	RIO GRANDE CITY	94SB3230	2,532	0.613
505	537	SOUTH MISSION	94SB3620	1,887	0.599
506	200	ZAPATA	94LA8290	2,087	0.584
507	296	ARCADIA	94CS6930	1,519	0.583
508	466	MORRIS STREET	94CS8715	1,603	0.583
509	59	NORTH VICTORIA	94CN7430	1,754	0.583
510	504	NORTH VICTORIA	94CN7770	810	0.583
511	100	NORTH VICTORIA	94CN7440	1,623	0.575
512	480	WEST OSO	94CS9090	1,671	0.574
513	460	SINTON	94CS360	295	0.569
514	99	PEARSALL	94LA5580	1,618	0.566
515	43	PETTUS	94CN1020	394	0.556
516	506	MALONE	94CN7550	180	0.556
517	451	RANGERVILLE	94SB3410	816	0.555
518	134	MATHIS	94CS2870	870	0.552
519	264	COTULLA	94LA110	1,587	0.549
520	402	ARCADIA	94CS1440	1,697	0.547
521	273	DEL RIO CITY	94LA430	2,490	0.547
522	315	KLEBERG	94CS9395	1,313	0.547
523	365	NORTH MCALLEN	94SB9640	1,425	0.544
524	117	SOUTH PADRE ISLAND	94SB6440	2,500	0.542
525	107	PLACEDO	94CN7980	410	0.541
526	112	LAREDO PLANT	94LA8705	220	0.541
527	310	INGLESIDE CITY	94CS8060	1,818	0.538
528	588	INGLESIDE CITY	94CS8050	1,348	0.532
529	465	ASHERTON	94LA2660	680	0.529
530	691	HIDALGO	94SB3680	316	0.525
531	62	HAMILTON ROAD	94LA9655	1,222	0.523
532	616	PALMHURST	94SB3890	2,391	0.520
533	491	LOLITA	94CN6330	27	0.519
534	569	DEL RIO CITY	94LA440	1,083	0.519
535	259	EAST HARRISON	94SB4620	761	0.518
536	524	SINTON	94CS180	939	0.518
537	721	EL GATO	94SB910	2,424	0.517
538	604	WADSWORTH	94CN7660	1,328	0.516
539	2	JOURDANTON	94LA250	763	0.516
540	290	SOUTH MISSION	94SB3590	682	0.515
541	68	O CONNER	94CN390	211	0.512
542	83	TAFT	94CS1260	178	0.500
543	458	BAY CITY	94CN2050	512	0.500
544	597	EAST HARRISON	94SB3080	361	0.499
545	182	AIRLINE	94CS9030	420	0.493

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
546	176	FALFURRIAS	94LA1070	1,040	0.488
547	567	PALACIOS	94CN6840	1,524	0.485
548	627	ARCADIA	94CS5020	1,533	0.464
549	76	BRUNI	94LA1120	275	0.462
550	538	EDROY	94CS6980	195	0.462
551	120	PARKER	94CN9260	108	0.454
552	241	PALMHURST	94SB1300	1,949	0.453
553	640	REFUGIO	94CN1210	207	0.449
554	670	LEARY LANE	94CN6175	1,676	0.443
555	377	FREER	94LA6320	156	0.442
556	508	BEEVILLE	94CN2200	762	0.441
557	555	FULTON	94CS2020	1,795	0.437
558	297	LEARY LANE	94CN7530	2,079	0.432
559	320	KINGSVILLE	94CS1660	1,644	0.431
560	516	ALICE	94LA1780	256	0.430
561	263	SEAWALL	94CS9325	1,463	0.428
562	550	DEVINE	94LA7100	964	0.428
563	535	LIVE OAK	94CS1070	2,857	0.424
564	395	RIO GRANDE CITY	94SB3740	2,259	0.424
565	594	SAN DIEGO	94LA1980	592	0.419
566	609	HARLINGEN	94SB370	1,176	0.416
567	4	SAN YGNACIO	94LA16060	484	0.413
568	692	NORTH EDINBURG	94SB3810	908	0.411
569	89	UVALDE	94LA9770	1,473	0.410
570	372	CAMPWOOD	94LA2610	946	0.410
571	60	UNIVERSITY	94LA950	3,124	0.409
572	265	BROOKHOLLOW	94CN7190	264	0.398
573	238	SOUTH EAST EDINBURG	94SB4550	2,114	0.395
574	113	THREE RIVERS	94CN2010	1,165	0.393
575	243	RIO BRAVO	94LA5	698	0.390
576	302	ARCADIA	94CS8570	1,437	0.388
577	274	SAN DIEGO	94LA2930	599	0.384
578	170	GANADO	94CN5815	601	0.379
579	576	COLUMBUS	94CN9060	365	0.375
580	545	EAST HARRISON	94SB3030	705	0.374
581	375	AIRLINE	94CS7390	1,462	0.373
582	349	KLEBERG	94CS6000	1,476	0.371
583	678	BUENA VISTA	94LA8965	929	0.371
584	700	DEL MAR	94LA3440	1,411	0.368
585	283	POLK AVENUE	94SB4740	1,905	0.367
586	351	SANTO NINO	94LA515	1,983	0.366
587	612	PALMVIEW	94SB7595	2,671	0.363
588	406	MCCOLL ROAD	94SB1655	1,308	0.362
589	632	MATHIS	94CS1420	936	0.355
590	55	SABINAL	94LA200	428	0.353
591	306	LEARY LANE	94CN1430	1,595	0.346
592	552	WESMER	94SB4480	1,070	0.342
593	656	PALMHURST	94SB2530	1,818	0.340
594	234	WOOLRIDGE	94CS1170	757	0.339
595	556	WESLACO UNIT	94SB9805	1,788	0.334

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
596	639	THREE RIVERS	94CN5100	36	0.333
597	251	HALL ACRES ROAD	94SB3460	3,377	0.333
598	247	GEORGE WEST	94CN730	978	0.331
599	124	CRESTONIO	94LA260	1,808	0.327
600	222	ARCADIA	94CS5030	1,575	0.326
601	554	GARCENO	94SB2130	3,091	0.319
602	602	VICTORIA POWER PLANT	94CN8070	617	0.319
603	392	GATEWAY	94LA5055	2,123	0.316
604	669	EAGLE PASS CITY	94LA7060	850	0.314
605	648	ARANSAS PASS	94CS660	741	0.308
606	484	BAY CITY	94CN5960	1,787	0.307
607	427	ARANSAS PASS	94CS650	745	0.305
608	20	ASHERTON	94LA2670	87	0.299
609	184	OLMITO	94SB4275	765	0.299
610	127	HALL ACRES ROAD	94SB4895	826	0.299
611	201	SOUTH PADRE ISLAND	94SB4675	151	0.298
612	494	INGLESIDE CITY	94CS2495	261	0.291
613	463	DEL RIO CITY	94LA9790	2,319	0.290
614	405	SINTON	94CS6860	1,634	0.288
615	546	LEARY LANE	94CN1890	1,617	0.283
616	698	WASHINGTON STREET	94LA6355	1,068	0.274
617	503	HARLINGEN	94SB360	2,470	0.272
618	new circuit	GREGORY	94CS2420	622	0.272
619	155	BANQUETTE	94CS130	224	0.268
620	329	CLARKWOOD	94CS7610	185	0.265
621	34	PHARAOH	94CS5175	988	0.264
622	231	SANTO NINO	94LA70	1,154	0.264
623	131	LAREDO HEIGHTS	94LA2450	2,549	0.257
624	557	ROCKPORT	94CS5950	544	0.256
625	603	SOUTH EAST EDINBURG	94SB4570	1,353	0.256
626	610	AIRLINE	94CS6970	1,238	0.255
627	331	REFUGIO	94CN5120	704	0.254
628	338	TAFT	94CS5230	833	0.251
629	266	SOUTHSIDE	94CS8005	743	0.250
630	232	SHARYLAND	94SB6745	1,999	0.246
631	607	POLK AVENUE	94SB4190	1,715	0.244
632	448	DEVINE	94LA7090	957	0.243
633	644	LAREDO PLANT	94LA8695	1,074	0.242
634	630	MCKENZIE ROAD	94CS330	2,271	0.236
635	677	PALMVIEW	94SB9685	2,800	0.232
636	137	RIO BRAVO	94LA1130	963	0.232
637	54	NORTH ALAMO	94SB4370	1,475	0.231
638	710	WASHINGTON STREET	94LA2470	188	0.229
639	522	SAN DIEGO	94LA2890	1,073	0.229
640	615	NORTH MCALLEN	94SB9660	1,977	0.225
641	719	EL GATO	94SB890	2,815	0.221
642	393	PHARR	94SB1620	2,394	0.218
643	69	PORT ARANSAS	94CS6940	1,634	0.217
644	592	MCCOLL ROAD	94SB4400	1,228	0.215
645	254	ROCKPORT	94CS5930	1,135	0.213

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
646	416	MILO	94LA5020	1,314	0.212
647	490	SEAWALL	94CS9420	832	0.212
648	436	NORTH VICTORIA	94CN1470	450	0.207
649	563	WEAVER ROAD	94CN1910	353	0.207
650	292	ARCADIA	94CS1460	2,142	0.206
651	464	CABANISS	94CS240	1,490	0.205
652	410	LAREDO HEIGHTS	94LA9080	682	0.204
653	46	MAGRUDER	94CN6700	1,333	0.204
654	437	SOUTH PADRE ISLAND	94SB5850	1,295	0.202
655	645	SHARYLAND	94SB5635	1,987	0.199
656	new circuit	COTULLA	94LA460	638	0.191
657	625	NORTH WESLACO	94SB4830	499	0.188
658	497	RODD FIELD	94CS205	1,678	0.185
659	474	ODEM	94CS375	1,021	0.183
660	132	BUENA VISTA	94LA9035	1,465	0.182
661	309	ESCONDIDO	94LA1510	716	0.182
662	595	LEARY LANE	94CN1540	798	0.180
663	166	MORRIS STREET	94CS8850	479	0.175
664	636	MCCOLL ROAD	94SB4790	1,936	0.172
665	507	ASPHALT MINES	94LA500	41	0.171
666	224	LEARY LANE	94CN6005	2,066	0.171
667	696	ZACATE CREEK	94LA2675	1,188	0.171
668	211	GANADO	94CN5795	467	0.163
669	668	KLEBERG	94CS280	1,284	0.157
670	17	JOURDANTON	94LA5685	586	0.157
671	289	GARWOOD CITY	94CN2570	135	0.156
672	92	ROMA	94SB3070	1,272	0.155
673	164	WOOLRIDGE	94CS1120	2,576	0.152
674	598	DEL RIO CITY	94LA9850	1,015	0.149
675	637	WASHINGTON STREET	94LA7015	1,527	0.148
676	212	HOLLY	94CS1220	3,409	0.146
677	284	LAREDO PLANT	94LA9305	984	0.143
678	147	PORT ARANSAS	94CS990	1,453	0.142
679	144	WEST MCALLEN	94SB4965	699	0.142
680	671	ZACATE CREEK	94LA2635	241	0.141
681	318	WEST MCALLEN	94SB4505	1,774	0.139
682	152	RAYMONDVILLE #2	94SB1280	1,059	0.139
683	585	BRACKETTVILLE	94LA8460	1,137	0.137
684	679	RODD FIELD	94CS1730	2,155	0.137
685	530	KLEBERG	94CS6410	213	0.136
686	688	LAREDO HEIGHTS	94LA2390	1,701	0.133
687	139	MAGRUDER	94CN6690	558	0.131
688	462	PHARR	94SB1640	1,218	0.131
689	631	THOMASTON	94CN9580	47	0.128
690	307	LAREDO HEIGHTS	94LA6810	2,073	0.127
691	409	WOOLRIDGE	94CS1110	1,600	0.122
692	65	EL CAMPO	94CN7710	1,063	0.119
693	707	EL CAMPO	94CN7260	530	0.119
694	250	KENEDY	94CN1960	67	0.119
695	53	MCKENZIE ROAD	94CS150	26	0.115

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
696	272	PORT LAVACA	94CN6850	680	0.113
697	495	NAVAL BASE	94CS8440	1,597	0.111
698	715	RODD FIELD	94CS3010	1,962	0.109
699	98	UNIVERSITY	94LA920	301	0.106
700	687	AIRLINE	94CS8370	263	0.103
701	440	SANTO NINO	94LA645	1,152	0.102
702	111	CAMPWOOD	94LA3430	82	0.098
703	412	RAYMONDVILLE #2	94SB4160	346	0.092
704	414	SHARYLAND	94SB2150	1,185	0.091
705	661	PALMVIEW	94SB9680	980	0.091
706	578	EL CAMPO	94CN6370	736	0.091
707	149	SANTO NINO	94LA80	1,785	0.090
708	369	PHARAOH	94CS1185	1,564	0.088
709	601	ARANSAS PASS	94CS590	425	0.085
710	279	HOMEPORT	94CS4665	445	0.085
711	181	WEAVER ROAD	94CN1900	60	0.083
712	389	EDNA	94CN5775	505	0.081
713	129	WEST MCALLEN	94SB4595	1,181	0.079
714	718	WASHINGTON STREET	94LA2360	196	0.071
715	705	RODD FIELD	94CS245	2,560	0.070
716	383	HAMILTON ROAD	94LA9645	291	0.062
717	608	SOUTH MISSION	94SB4650	1,003	0.059
718	713	EAST HARRISON	94SB3000	521	0.058
719	646	ZACATE CREEK	94LA2665	1,681	0.057
720	706	AIRLINE	94CS9390	1,878	0.054
721	118	SANTO NINO	94LA695	1,563	0.054
722	543	ROCKPORT	94CS5940	42	0.048
723	681	WEST MCALLEN	94SB4815	699	0.043
724	712	SOUTH MCALLEN	94SB3640	302	0.043
725	702	CLARKWOOD	94CS7220	427	0.035
726	572	WASHINGTON STREET	94LA2350	2,955	0.028
727	new circuit	FASHING	94CN360	39	0.026
728	301	MILO	94LA3060	111	0.018
729	77	SIERRA VISTA	94LA9900	2,368	0.011
730	720	MCCOLL ROAD	94SB4910	327	0.006
731	724	SIERRA VISTA	94LA3540	341	0.006
732	154	GILA	94CS7840	733	0.005
733	501	MINES ROAD	94LA4275	17	-
734	728	VICTORIA POWER PLANT	94CNNETVIC	59	-
735	729	MORRIS STREET	94CSNET CC	334	-
736	730	WASHINGTON STREET	94LANETLAR	126	-
737	new circuit	COTULLA	94LA610	56	-

Feeders from last year that are not in this year's list

2012 Ranking	Substation Identification	Feeder ID	Reason not in 2013
450	BRUNI	94LA5160	Retired, customers moved to 94LA1120
665	FASHING	94CN8160	Retired, customers moved to 94CN360
10	PEARSALL	94LA9905	Retired, customers moved to 94LA3675

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or more Customers

Total Number of Feeders

737

Add or Delete Rows as Necessary

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1	1	GOVERNMENT WELLS	94LA6800	217	2,397.57
2	14	GOVERNMENT WELLS	94LA7240	211	1,739.52
3	12	MOORE FIELD	94SB3120	129	1,224.10
4	161	CONTINENTAL	94SB4880	62	1,153.53
5	165	GILA	94CS350	140	1,085.51
6	25	BRUNI	94LA5440	132	1,028.72
7	new station	CATARINA	94LA2380	204	972.26
8	115	BANDERA ELECTRIC (LEAKEY)	94LAL30	251	970.10
9	103	EAST HARRISON	94SB3950	555	961.54
10	105	CONTINENTAL	94SB3650	23	817.57
11	93	COTULLA	94LA90	223	805.56
12	23	FREER	94LA1500	216	804.95
13	202	GILA	94CS345	49	781.18
14	578	RAYMONDVILLE #1	94SB630	787	769.71
15	540	SAN BENITO	94SB3910	1,768	765.96
16	135	NORTH PADRE ISLAND	94CS5170	1,157	739.92
17	53	BIG WELLS	94LA2630	28	733.07
18	331	CABANISS	94CS80	1,170	715.64
19	188	WESMER	94SB9705	1,088	696.65
20	172	ARMSTRONG	94CS6050	67	679.31
21	481	WESLACO UNIT	94SB5970	2,270	657.01
22	217	RIO RICO	94SB8330	393	641.07
23	37	CRYSTAL CITY	94LA330	1,317	634.90
24	56	PORT ISABEL S.S.	94SB4070	296	626.90
25	40	NORTH EDINBURG	94SB4240	2,291	616.46
26	170	CHARLOTTE	94LA2780	481	615.31
27	567	PARKER	94CN9010	18	610.78
28	468	SAN BENITO	94SB4135	1,249	610.24
29	112	FREER	94LA2900	164	606.30
30	136	FALFURRIAS	94LA5210	1,140	602.66
31	619	HARLINGEN	94SB660	1,894	586.90
32	364	BANQUETTE	94CS9000	435	586.63
33	171	WEST OSO	94CS9085	782	577.57
34	631	SOUTHSIDE	94CS8045	1,018	573.74
35	70	ALICE	94LA2540	1,131	570.12
36	99	CHARLOTTE	94LA2790	178	558.80
37	335	LA GRULLA	94SB5005	2,016	550.30
38	590	RANGERVILLE	94SB3420	771	550.12
39	210	BRUNI	94LA1100	628	546.74
40	385	RIO RICO	94SB5050	1,721	544.50
41	39	RANDADO	94LA8350	124	518.99
42	377	KLEBERG	94CS8140	419	489.24
43	128	GOODWIN	94SB7380	2,181	488.50
44	441	SOUTH MISSION	94SB3980	1,251	487.78
45	61	ALAZAN	94CS620	164	486.67
46	11	CARRIZO SPRINGS	94LA910	2,103	485.34
47	107	TATTON	94CS8200	1,032	485.15
48	113	LULING - LCRA	94CN10	368	484.51

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
49	724	ROCKSPRINGS	94LA8040	329	481.50
50	17	ELSA	94SB710	1,797	480.86
51	369	COMSTOCK	94LA230	181	480.48
52	82	PLEASANTON	94LA9475	1,328	480.43
53	252	GRETA	94CN7890	326	477.72
54	106	CRESTONIO	94LA270	614	475.75
55	607	SABINAL	94LA485	485	475.26
56	638	ROCKSPRINGS	94LA2600	378	471.58
57	176	CAUSEWAY	94SB4765	966	467.86
58	154	NORTH MERCEDES	94SB3840	637	465.61
59	4	MAVERICK	94LA9680	729	464.95
60	84	MCKENZIE ROAD	94CS140	259	460.90
61	308	MOORE FIELD	94SB3110	644	459.83
62	302	EAGLE LAKE	94CN9455	577	447.69
63	46	RIO RICO	94SB8290	370	434.15
64	412	POLK AVENUE	94SB4170	1,738	428.04
65	155	HARLINGEN	94SB380	2,338	424.98
66	323	NORTH MERCEDES	94SB4860	1,396	424.52
67	458	NIXON	94CN810	538	422.85
68	452	SUNCHASE	94SB1155	1,456	416.92
69	521	LOS FRESNOS	94SB7270	2,051	414.71
70	395	WESMER	94SB6900	1,605	410.62
71	703	PALMVIEW	94SB3930	1,100	407.23
72	616	LA GRULLA	94SB6150	1,099	406.41
73	216	COFFEE PORT	94SB1090	1,153	397.17
74	460	SAN BENITO	94SB4030	2,419	397.00
75	350	NORTH MERCEDES	94SB3770	1,692	396.00
76	394	TATTON	94CS950	536	393.09
77	131	HALL ACRES ROAD	94SB8870	1,898	392.61
78	15	LOS FRESNOS	94SB4315	983	391.20
79	408	SOUTHSIDE	94CS8025	1,064	388.03
80	81	SOUTH MCALLEN	94SB3935	1,309	386.02
81	196	PORT LAVACA	94CN8310	310	381.92
82	73	GREENLAKE	94CN2760	567	381.89
83	126	BIG WELLS	94LA1570	469	378.78
84	283	CASA BLANCA	94CS55	833	377.23
85	59	VILLA CAVAZOS	94SB1980	1,554	373.69
86	19	RAYMONDVILLE #2	94SB3170	697	373.52
87	185	PORT ISABEL S.S.	94SB3820	212	373.03
88	409	SOUTH SANTA ROSA	94SB1235	621	371.88
89	496	HOLLY	94CS9675	1,780	368.82
90	28	GREGORY	94CS5900	104	368.50
91	120	HIDALGO	94SB4845	1,118	367.88
92	332	BISHOP	94CS2690	544	367.52
93	75	BLESSING	94CN8790	746	366.96
94	47	STAFFORD HILL	94CN1550	215	366.74
95	552	ALICE	94LA1770	1,617	366.45
96	613	DEL RIO CITY	94LA1930	1,054	362.23
97	483	BROWNSVILLE	94SB4280	286	361.63
98	296	PREMONT	94LA2730	205	359.02
99	230	SOUTH EAST EDINBURG	94SB5045	1,903	355.29
100	150	LOS FRESNOS	94SB2160	1,151	355.28
101	67	ENCINAL	94LA2160	897	353.96

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
102	98	GREENLAKE	94CN2740	31	351.68
103	8	CONTINENTAL	94SB4080	63	350.65
104	472	ROBSTOWN	94CS1650	353	345.30
105	709	EL GATO	94SB720	2,448	344.48
106	518	MOORE FIELD	94SB3960	1,826	341.68
107	593	FREER	94LA5200	1,073	339.75
108	24	LA PRYOR	94LA580	204	336.59
109	514	POINT COMFORT	94CN6060	57	326.58
110	402	NORTH EDINBURG	94SB560	999	325.42
111	277	CRYSTAL CITY	94LA190	1,573	318.52
112	226	PUEBLO	94LA95	2,165	318.07
113	233	PEARSALL	94LA7050	913	317.78
114	299	WEST HARLINGEN	94SB3700	1,729	317.28
115	499	SAN BENITO	94SB3920	2,419	316.66
116	397	PALMHURST	94SB2820	1,672	315.06
117	205	PALACIOS	94CN6830	788	312.52
118	268	MORRIS STREET	94CS7625	567	311.86
119	621	NORTH EDINBURG	94SB3570	1,874	309.74
120	429	PHARAOH	94CS1285	1,766	306.91
121	21	PALACIOS	94CN8550	38	304.39
122	423	CLARKWOOD	94CS5525	1,021	303.79
123	199	FALFURRIAS	94LA1080	443	302.63
124	2	LA PRYOR	94LA570	147	301.19
125	680	AIRLINE	94CS5870	890	301.14
126	54	BLESSING	94CN1030	261	300.30
127	517	HIGHWAY 9	94CS9830	140	299.45
128	38	MARKHAM	94CN5550	109	293.14
129	133	GREENLAKE	94CN2750	1,142	292.55
130	292	UVALDE	94LA5060	1,337	291.52
131	201	NORTH PADRE ISLAND	94CS7900	1,303	290.00
132	405	PORTLAND	94CS9270	1,401	288.95
133	485	HAIN DRIVE	94SB8065	1,334	288.51
134	276	CAUSEWAY	94SB4795	1,199	287.30
135	414	MINES ROAD	94LA3680	952	286.33
136	498	HAIN DRIVE	94SB9690	827	285.68
137	42	DILLEY	94LA6400	180	283.77
138	632	MORRIS STREET	94CS8840	600	277.52
139	179	WEST MCALLEN	94SB6385	207	275.51
140	523	CASA BLANCA	94CS1300	994	275.24
141	700	ODEM	94CS5575	60	269.98
142	663	WEIL TRACT (138/12KV)	94CS1990	1,300	269.86
143	444	BEEVILLE	94CN1760	1,824	269.68
144	198	SOUTHSIDE	94CS7955	1,048	268.29
145	474	BEEVILLE	94CN490	978	267.93
146	184	RACHAL	94LA8145	346	266.27
147	274	SOUTHSIDE	94CS7925	1,341	263.84
148	666	SOUTH MCALLEN	94SB3790	1,904	262.68
149	477	NAVAL BASE	94CS1380	2,348	261.44
150	376	SOUTH SANTA ROSA	94SB1225	825	259.01
151	433	COFFEE PORT	94SB1095	977	258.25
152	43	NAVAL BASE	94CS6330	314	256.10
153	86	WEST MCALLEN	94SB4555	1,504	254.44
154	66	LULING - LCRA	94CN20	287	253.95

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
155	110	CITRUS CITY	94SB9775	1,478	253.29
156	726	SOUTH MCALLEN	94SB5065	114	249.42
157	35	SOUTHSIDE	94CS5335	1,149	249.14
158	180	WESLACO UNIT	94SB8610	1,164	248.23
159	213	NORTH PADRE ISLAND	94CS1010	2,595	247.17
160	548	ELSA	94SB3500	1,162	246.25
161	145	LOS FRESNOS	94SB5335	2,015	246.05
162	200	GOLIAD	94CN8220	1,042	244.75
163	594	LA GRULLA	94SB5110	1,393	241.84
164	6	TATTON	94CN8490	124	240.35
165	391	COLUMBUS	94CN930	911	237.64
166	174	GOVERNMENT WELLS	94LA7250	592	237.35
167	542	HEARN ROAD	94CS8990	1,184	237.26
168	220	RAYMONDVILLE #1	94SB3130	276	236.07
169	255	SOUTH EAST EDINBURG	94SB6580	1,378	233.88
170	610	ARANSAS PASS	94CS9130	367	233.19
171	286	STADIUM	94LA7490	1,308	233.13
172	167	GARWOOD CITY	94CN2560	200	232.17
173	182	ZAPATA	94LA2710	47	231.47
174	63	ZAPATA	94LA7330	1,346	226.88
175	326	RANDADO	94LA8360	161	225.51
176	388	HIGHWAY 9	94CS6720	1,317	223.55
177	381	NORTH MCALLEN	94SB5060	2,357	219.83
178	379	BROOKHOLLOW	94CN8960	573	218.84
179	132	BAY CITY	94CN6670	1,777	218.23
180	341	RANGERVILLE	94SB4060	876	217.92
181	29	DEVINE	94LA8100	1,536	216.49
182	142	NORTH PADRE ISLAND	94CS720	1,103	216.08
183	121	RAYMONDVILLE #1	94SB620	619	214.81
184	558	BEEVILLE	94CN8510	876	214.30
185	370	LA GRULLA	94SB4120	1,416	212.73
186	546	ELSA	94SB700	1,410	212.10
187	373	SAN BENITO	94SB4945	1,761	211.27
188	384	RACHAL	94LA6595	295	211.05
189	721	CAUSEWAY	94SB4775	1,056	209.38
190	624	AIRLINE	94CS9605	709	208.54
191	new circuit	DILLEY	94LA2885	803	208.42
192	204	RAYMONDVILLE #1	94SB800	675	207.88
193	246	RIO GRANDE CITY	94SB3210	1,776	207.72
194	437	NIXON	94CN2620	406	207.72
195	36	POINT COMFORT	94CN2460	343	204.45
196	365	HIGHWAY 9	94CS6770	1,148	203.98
197	new station	MAYO	94CS625	223	202.66
198	192	GEORGE WEST	94CN1320	782	200.91
199	633	WEIL TRACT (138/12KV)	94CS2520	543	200.77
200	298	ELSA	94SB3520	435	200.22
201	315	WESMER	94SB1850	1,262	200.00
202	264	PLACEDO	94CN7970	456	199.63
203	704	MORRIS STREET	94CS7465	641	199.07
204	89	BEEVILLE	94CN300	1,740	198.31
205	568	MAGNOLIA	94CN2840	10	198.20
206	20	ELSA	94SB690	2,276	197.19
207	241	PREMONT	94LA6570	711	196.68

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
208	587	NORTH VICTORIA	94CN6390	1,653	196.22
209	295	NORTH ALAMO	94SB3610	1,782	195.78
210	228	PUEBLO	94LA275	2,784	195.20
211	684	KINGSVILLE	94CS1670	418	193.65
212	293	ALAZAN	94CS2740	33	193.24
213	254	SOUTH SANTA ROSA	94SB1240	1,583	192.27
214	438	LAGUNA	94CS9065	2,070	190.97
215	361	HEARN ROAD	94CS870	1,153	189.97
216	48	MORRIS STREET	94CS8830	1,550	189.32
217	354	LYTLE	94LA2850	620	187.89
218	606	ANNA STREET	94LA850	1,608	187.60
219	595	HAIN DRIVE	94SB9700	787	187.47
220	347	EAST HARRISON	94SB4620	761	185.08
221	306	WEST HARLINGEN	94SB3720	1,991	184.03
222	473	HOLLY	94CS7620	2,580	183.91
223	378	HIGHWAY 9	94CS7210	336	183.81
224	707	LAREDO PLANT	94LA8745	716	183.43
225	76	PLEASANTON	94LA2080	1,615	182.04
226	551	PREMONT	94LA2720	776	181.91
227	520	AIRLINE	94CS8890	532	181.25
228	160	VILLA CAVAZOS	94SB5680	1,690	180.86
229	466	SOUTHSIDE	94CS8055	862	180.34
230	90	BERCLAIR	94CN990	208	180.18
231	208	SOUTH SANTA ROSA	94SB7485	1,016	179.88
232	541	STADIUM	94LA6950	538	178.47
233	303	RUNGE	94CN7320	643	178.18
234	450	HALL ACRES ROAD	94SB5465	1,684	177.76
235	58	GOLIAD	94CN6540	1,165	176.80
236	257	ARCADIA	94CS1400	434	175.77
237	647	HIGHWAY 9	94CS7200	656	175.52
238	665	SKIDMORE	94CS380	336	174.49
239	279	AIRLINE	94CS7270	1,030	174.46
240	589	KINGSVILLE	94CS1140	1,010	173.76
241	691	MILO	94LA3070	3,290	173.23
242	60	CARRIZO SPRINGS	94LA370	541	172.11
243	269	BAY CITY	94CN1110	1,281	171.71
244	712	SAN BENITO	94SB3860	236	171.43
245	193	PLEASANTON	94LA9505	1,583	170.89
246	243	BLESSING	94CN8780	61	170.59
247	615	FULTON	94CS3070	1,596	169.39
248	244	OLMITO	94SB905	1,493	169.33
249	27	CARRIZO SPRINGS	94LA860	1,388	167.25
250	653	DEL MAR	94LA220	1,877	166.54
251	512	NORTH MCALLEN	94SB2750	3,220	166.33
252	641	EL GATO	94SB780	1,690	166.22
253	501	PHARAOH	94CS5185	2,822	165.30
254	280	WESMER	94SB4480	1,070	165.20
255	187	UVALDE	94LA6620	2,714	163.69
256	670	GARCENO	94SB2135	2,129	163.64
257	62	ZAPATA	94LA8300	1,704	163.48
258	533	GREGORY	94CS8560	245	163.33
259	7	PETTUS	94CN8210	369	163.33
260	77	PORT LAVACA	94CN2480	1,532	163.11

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
261	307	BROOKHOLLOW	94CN7580	460	162.63
262	445	KENEDY S.S.	94CN8320	958	161.64
263	229	CITRUS CITY	94SB7985	1,708	160.64
264	565	RODD FIELD	94CS2190	2,630	160.32
265	393	STADIUM	94LA8540	1,610	160.19
266	659	LAREDO HEIGHTS	94LA6820	2,112	155.71
267	153	PORT ARANSAS	94CS1000	1,603	154.65
268	424	GOODWIN	94SB3530	1,544	154.58
269	10	THREE RIVERS	94CN8430	185	153.68
270	337	RODD FIELD	94CS225	1,224	152.55
271	138	MATTHEWS	94CN1740	160	152.23
272	311	SOUTHSIDE	94CS8035	1,092	151.50
273	242	PHARR	94SB1645	2,588	149.30
274	318	WEIL TRACT (138/12KV)	94CS5405	161	149.14
275	129	UVALDE	94LA550	670	148.45
276	683	PALMHURST	94SB2525	1,936	148.01
277	538	HARLINGEN S.S.	94SB5350	765	146.45
278	18	RAYMONDVILLE #2	94SB3250	31	146.00
279	462	POLK AVENUE	94SB4610	1,347	143.99
280	661	ARANSAS PASS	94CS1250	393	141.78
281	317	PREMONT	94LA6610	811	141.67
282	623	HEARN ROAD	94CS9665	571	141.33
283	321	CHARLOTTE	94LA8120	210	141.15
284	327	SEAWALL	94CS9450	290	141.08
285	667	HIGHWAY 9	94CS6760	661	140.64
286	212	EAGLE LAKE	94CN310	724	139.81
287	689	CRESTONIO	94LA6660	762	139.76
288	26	CONOCO-CHITTAM RANCH	94LA8580	29	139.38
289	358	CASA BLANCA	94CS5115	280	139.22
290	114	MORRIS STREET	94CS5655	978	139.09
291	31	BROWNSVILLE	94SB3050	1,960	139.04
292	85	TAFT	94CS1180	1,038	138.91
293	536	WESMER	94SB7760	2,368	137.30
294	406	SHARYLAND	94SB2020	2,329	136.74
295	420	PALMHURST	94SB2535	1,191	135.96
296	319	HOLLY	94CS1950	801	135.47
297	648	EAGLE PASS CITY	94LA2650	1,326	134.01
298	108	BISHOP	94CS7180	935	133.86
299	372	RIO BRAVO	94LA300	790	133.76
300	650	LAREDO HEIGHTS	94LA2100	2,106	133.65
301	636	NORTH MCALLEN	94SB4995	1,962	133.54
302	266	FOSTER FIELD	94CN2550	212	133.42
303	560	PLEASANTON	94LA120	1,255	132.42
304	148	CARANCAHUA	94CN5870	453	132.33
305	685	HOLLY	94CS5820	928	131.83
306	95	ALICE	94LA2530	1,488	130.09
307	698	SHARYLAND	94SB2010	1,117	129.71
308	537	OLMITO	94SB715	533	129.36
309	265	DEL MAR	94LA490	751	129.21
310	598	WASHINGTON STREET	94LA6525	2,079	129.01
311	116	HALL ACRES ROAD	94SB5585	686	128.90
312	469	EAST HARRISON	94SB4360	1,724	128.81
313	479	NORTH MCALLEN	94SB2980	1,710	128.51

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
314	415	SANTO NINO	94LA75	1,521	128.03
315	368	SOUTHSIDE	94CS7905	1,838	127.60
316	534	EAGLE PASS CITY	94LA450	752	127.58
317	583	PORTLAND	94CS6505	1,679	126.78
318	65	THREE RIVERS	94CN2580	119	126.70
319	725	MILO	94LA8365	1,842	126.65
320	426	KENEDY S.S.	94CN8340	996	126.45
321	357	GATEWAY	94LA3595	1,513	126.05
322	345	HEARN ROAD	94CS8980	1,205	126.04
323	118	LAGUNA	94CS9590	2,201	125.59
324	731	FOSTER FIELD	94CN8880	112	123.90
325	349	KNIPPA	94LA6365	305	123.59
326	152	BONNIEVIEW	94CS8020	514	123.55
327	488	EDNA	94CN5765	1,685	123.36
328	497	BAY CITY	94CN7480	1,887	123.11
329	421	GOODWIN	94SB4380	1,451	122.99
330	702	ANNA STREET	94LA2250	1,562	122.68
331	480	NORTH VICTORIA	94CN2240	773	122.31
332	718	SOUTH MISSION	94SB3940	815	122.22
333	557	UNIVERSITY	94LA930	775	121.47
334	591	ROMA	94SB3060	1,562	121.20
335	492	WEST HARLINGEN	94SB4870	729	121.01
336	215	CRYSTAL CITY	94LA140	766	120.54
337	410	PORTLAND	94CS9290	1,719	119.41
338	16	PETTUS	94CN1020	394	119.04
339	78	DILLEY	94LA510	579	118.84
340	486	ARANSAS PASS	94CS8280	564	118.74
341	547	AIRLINE	94CS7280	625	118.10
342	371	CLARKWOOD	94CS7230	628	118.08
343	644	WEST MCALLEN	94SB4535	2,823	117.62
344	305	NORTH MCALLEN	94SB3830	1,305	117.36
345	453	DARST	94CN790	249	117.20
346	127	HIGHWAY 9	94CS6780	795	116.09
347	603	WESLACO UNIT	94SB7455	1,220	115.58
348	634	MAGRUDER	94CN7690	592	114.80
349	464	SOUTH PADRE ISLAND	94SB4695	1,373	114.64
350	69	PHARR	94SB1625	2,136	114.48
351	509	SKIDMORE	94CS600	368	113.86
352	139	VICTORIA POWER PLANT	94CN1390	1,165	112.86
353	344	PORT ISABEL S.S.	94SB3760	2,135	112.53
354	209	POLK AVENUE	94SB4520	891	112.06
355	249	EAGLE LAKE	94CN320	631	111.96
356	51	WADSWORTH	94CN8630	643	111.77
357	291	STADIUM	94LA7800	671	111.66
358	596	BUENA VISTA	94LA9385	2,097	111.29
359	50	JOURDANTON	94LA5695	1,330	109.86
360	245	YORKTOWN	94CN8420	1,084	109.57
361	436	COLUMBUS	94CN6180	1,167	109.40
362	562	WADSWORTH	94CN7660	1,328	108.63
363	574	DEL MAR	94LA7930	1,315	107.99
364	524	KINGSVILLE	94CS1130	2,295	107.46
365	278	HARLINGEN S.S.	94SB320	1,492	107.27
366	250	REFUGIO	94CN1040	182	107.02

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
367	705	SINTON	94CS1750	503	106.79
368	609	FULTON	94CS440	2,047	106.73
369	256	ARCADIA	94CS1360	1,569	106.50
370	401	MALONE	94CN7550	180	106.49
371	322	SOUTHSIDE	94CS7995	1,549	106.33
372	584	LAREDO PLANT	94LA8505	757	105.56
373	166	PHARAOH	94CS1365	461	105.31
374	489	POLK AVENUE	94SB4900	2,638	105.02
375	240	THREE RIVERS	94CN2010	1,165	104.65
376	585	EL CAMPO	94CN2860	823	104.64
377	290	HAINE DRIVE	94SB3490	1,058	104.31
378	211	ALICE	94LA1790	344	104.27
379	80	MORRIS STREET	94CS8820	1,202	103.94
380	45	NORTH ALAMO	94SB3580	837	103.94
381	440	HARLINGEN S.S.	94SB4110	820	103.26
382	611	WESLACO UNIT	94SB8195	1,670	102.66
383	343	NORTH WESLACO	94SB4810	1,354	102.59
384	168	RIO BRAVO	94LA5	698	102.01
385	679	EAST HARRISON	94SB4310	1,167	101.91
386	104	AMISTAD DAM	94LA5450	1,156	101.91
387	443	ARCADIA	94CS1440	1,697	101.82
388	175	RAYMONDVILLE #2	94SB3240	969	101.25
389	221	MILO	94LA6940	778	101.08
390	231	MILO	94LA3065	185	100.76
391	178	BAY CITY	94CN2700	1,065	99.36
392	602	SOUTHSIDE	94CS5345	396	99.26
393	553	PORT LAVACA	94CN2490	1,079	99.08
394	532	RIO GRANDE CITY	94SB3220	1,716	97.89
395	72	PARKER	94CN9260	108	97.19
396	580	INGLESIDE CITY	94CS8050	1,348	97.12
397	22	JOURDANTON	94LA880	310	97.10
398	375	KINGSVILLE	94CS1350	367	96.75
399	592	VILLA CAVAZOS	94SB7615	968	96.74
400	94	VICTORIA POWER PLANT	94CN7600	153	95.95
401	125	MCCOLL ROAD	94SB2810	2,234	95.55
402	392	GOODWIN	94SB4625	355	95.43
403	324	HAMILTON ROAD	94LA9665	940	95.28
404	92	WOODSBORO	94CS8330	1,098	94.88
405	658	SOUTH MISSION	94SB5215	1,249	94.88
406	662	PORT ARANSAS	94CS3030	825	94.69
407	706	ANNA STREET	94LA5780	706	94.60
408	313	BEEVILLE	94CN8090	1,362	94.26
409	new circuit	PEARSALL	94LA3675	1,437	94.13
410	146	INGLESIDE CITY	94CS6040	251	93.88
411	655	SOUTH MCALLEN	94SB3850	794	93.51
412	32	ASHERTON	94LA2670	87	93.22
413	570	HAINE DRIVE	94SB270	991	92.73
414	310	KENEDY	94CN6270	544	92.12
415	387	MATHIS	94CS340	1,480	90.68
416	396	EDNA	94CN5785	743	89.77
417	515	STADIUM	94LA7810	1,653	89.64
418	273	ARCADIA	94CS6930	1,519	89.29
419	575	EAST HARRISON	94SB3080	361	89.11

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
420	232	ASHERTON	94LA2660	680	88.31
421	535	FULTON	94CS9050	1,646	88.19
422	164	WEST MCALLEN	94SB4515	806	87.76
423	263	MORRIS STREET	94CS2515	1,090	87.50
424	487	LA PRYOR	94LA2440	687	87.42
425	463	MAGRUDER	94CN7870	1,324	87.10
426	360	FALFURRIAS	94LA2830	1,468	86.99
427	91	HIDALGO	94SB3400	852	86.97
428	459	SOUTH SANTA ROSA	94SB1215	1,639	86.85
429	500	CITRUS CITY	94SB3470	3,495	86.79
430	645	MALONE	94CN7560	105	86.78
431	348	LIVE OAK	94CS1090	275	86.69
432	455	HARLINGEN S.S.	94SB4230	1,323	86.45
433	676	HIDALGO	94SB3680	316	86.28
434	434	HOLLY	94CS1370	1,885	85.98
435	657	PUEBLO	94LA130	1,368	85.43
436	446	KLEBERG	94CS1560	1,361	85.25
437	600	EAGLE PASS CITY	94LA2745	919	84.82
438	44	BROWNSVILLE	94SB4290	382	84.77
439	362	HOLLY	94CS1480	1,716	84.59
440	330	RANGERVILLE	94SB3410	816	84.50
441	336	HARLINGEN S.S.	94SB4090	2,292	83.67
442	382	PORTLAND	94CS9370	1,481	83.40
443	101	THREE RIVERS	94CN5190	903	83.18
444	465	EAGLE PASS CITY	94LA2510	584	83.08
445	457	ARANSAS PASS	94CS8270	606	82.97
446	191	ODEM	94CS385	408	82.90
447	297	SHARYLAND	94SB5105	1,558	82.89
448	342	POLK AVENUE	94SB4180	1,209	82.79
449	484	EAST HARRISON	94SB3190	1,467	81.68
450	398	VICTORIA POWER PLANT	94CN8170	776	81.38
451	582	SAN DIEGO	94LA1980	592	81.26
452	247	UVALDE	94LA9770	1,473	80.08
453	219	DEL RIO CITY	94LA420	2,236	80.04
454	316	WESMER	94SB4050	1,913	79.95
455	425	FREER	94LA6320	156	79.48
456	149	PRAIRIE PUMP	94CN1940	70	79.07
457	351	MORRIS STREET	94CS8715	1,603	78.93
458	352	ANNA STREET	94LA900	2,918	77.82
459	64	PLACEDO	94CN7980	410	77.61
460	366	COTULLA	94LA110	1,587	77.56
461	272	WEST HARLINGEN	94SB3800	1,337	77.43
462	3	JOURDANTON	94LA250	763	77.23
463	new station	BIG OAK	94CN420	131	77.20
464	162	MAGRUDER	94CN6680	698	77.13
465	301	SOUTH EAST EDINBURG	94SB4015	424	76.50
466	470	MCCOLL ROAD	94SB1655	1,308	76.38
467	495	EL CAMPO	94CN5745	886	76.13
468	197	PORT ISABEL S.S.	94SB9295	654	76.11
469	83	BROOKHOLLOW	94CN8950	873	75.47
470	431	EAGLE PASS CITY	94LA2770	2,950	75.42
471	71	KENEDY	94CN1970	678	75.41
472	134	WESLACO UNIT	94SB7630	2,522	75.37

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
473	5	SAN YGNACIO	94LA16060	484	75.33
474	68	NORTH VICTORIA	94CN7430	1,754	75.32
475	55	SOUTH PADRE ISLAND	94SB4675	151	74.72
476	513	LOLITA	94CN6330	27	74.52
477	224	CAMPWOOD	94LA2610	946	74.07
478	476	CLARKWOOD	94CS9570	1,144	72.87
479	422	SHARYLAND	94SB2035	2,289	71.67
480	359	GATEWAY	94LA350	1,731	71.34
481	57	MAGRUDER	94CN245	1,103	71.24
482	475	ANNA STREET	94LA780	469	70.84
483	573	PALACIOS	94CN6840	1,524	69.70
484	722	BEEVILLE	94CN2380	208	69.68
485	157	ESCONDIDO	94LA2035	2,604	68.93
486	430	YORKTOWN	94CN8380	824	68.67
487	87	NORDHEIM	94CN470	257	67.88
488	572	NORTH VICTORIA	94CN1580	1,037	67.05
489	544	BAY CITY	94CN6450	924	66.75
490	300	MATHIS	94CS2870	870	66.64
491	427	GATEWAY	94LA5055	2,123	66.60
492	367	KENEDY S.S.	94CN6750	899	66.11
493	122	FULTON	94CS6070	3,273	65.52
494	30	O_CONNER	94CN390	211	65.35
495	614	REFUGIO	94CN1210	207	64.93
496	577	NORTH MCALLEN	94SB5055	3,179	63.83
497	267	NIXON	94CN5990	815	63.67
498	528	BEEVILLE	94CN2200	762	63.22
499	312	NORTH MCALLEN	94SB9640	1,425	62.73
500	605	PALMVIEW	94SB6790	3,009	62.66
501	629	COLUMBUS	94CN9060	365	62.39
502	130	TAFT	94CS1260	178	62.19
503	510	NORTH VICTORIA	94CN7770	810	62.12
504	671	PALMHURST	94SB2530	1,818	60.87
505	239	ARCADIA	94CS1450	1,925	60.80
506	159	GREGORY	94CS5920	597	60.29
507	675	MATHIS	94CS1410	460	60.06
508	119	NORTH VICTORIA	94CN7440	1,623	59.85
509	338	HALL ACRES ROAD	94SB3670	881	59.57
510	355	NORTH WESLACO	94SB4830	499	59.03
511	284	SAN DIEGO	94LA2880	1,279	58.89
512	49	BRUNI	94LA1120	275	57.69
513	677	CLARKWOOD	94CS2170	12	57.50
514	173	MINES ROAD	94LA3745	1,686	57.43
515	668	REFUGIO	94CN1170	869	56.77
516	519	SOUTH MISSION	94SB3620	1,887	56.19
517	597	PALMVIEW	94SB7595	2,671	56.19
518	411	GATEWAY	94LA390	1,944	55.78
519	418	DEL RIO CITY	94LA430	2,490	54.04
520	413	KINGSVILLE	94CS1660	1,644	53.90
521	723	EL GATO	94SB910	2,424	53.59
522	181	PALMHURST	94SB1300	1,949	53.51
523	194	GANADO	94CN5815	601	53.11
524	309	PEARSALL	94LA5580	1,618	52.89
525	439	EL CAMPO	94CN2800	1,332	52.87

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
526	646	HEARN ROAD	94CS2220	1,522	52.60
527	363	EDROY	94CS6990	269	51.91
528	649	DEL MAR	94LA10	1,927	51.51
529	189	SOUTHSIDE	94CS8005	743	51.43
530	428	KLEBERG	94CS9395	1,313	51.35
531	550	WESLACO UNIT	94SB9805	1,788	51.30
532	508	WEST OSO	94CS9090	1,671	50.93
533	400	SEAWALL	94CS9325	1,463	50.74
534	454	DEVINE	94LA7100	964	50.61
535	682	LAREDO PLANT	94LA8565	1,405	50.53
536	642	HOLLY	94CS7740	1,987	50.44
537	206	OLMITO	94SB4275	765	50.10
538	526	EAST HARRISON	94SB3030	705	50.08
539	289	LIVE OAK	94CS1080	813	49.88
540	581	HARLINGEN	94SB370	1,176	49.88
541	258	SAN DIEGO	94LA2930	599	49.55
542	253	POLK AVENUE	94SB4740	1,905	49.43
543	346	ESCONDIDO	94LA3350	1,123	49.10
544	144	WEST OSO	94CS9095	1,589	48.40
545	234	FALFURRIAS	94LA1070	1,040	48.17
546	559	SINTON	94CS180	939	47.91
547	419	SOUTH MISSION	94SB3590	682	47.54
548	673	DEL MAR	94LA3440	1,411	47.52
549	432	GOODWIN	94SB4390	405	47.44
550	640	MATHIS	94CS1420	936	47.26
551	639	THREE RIVERS	94CN5100	36	47.06
552	654	ARCADIA	94CS5020	1,533	46.65
553	41	SABINAL	94LA200	428	46.39
554	163	SOUTH PADRE ISLAND	94SB6440	2,500	46.34
555	727	HAIN DRIVE	94SB9240	41	46.29
556	74	MUSTANG ISLAND	94CS8510	409	46.13
557	563	LIVE OAK	94CS1070	2,857	46.10
558	527	SINTON	94CS360	295	46.09
559	214	LEARY LANE	94CN7530	2,079	45.70
560	339	AIRLINE	94CS7390	1,462	45.02
561	389	INGLESIDE CITY	94CS8060	1,818	44.62
562	635	PALMHURST	94SB3890	2,391	44.37
563	262	SOUTH EAST EDINBURG	94SB4550	2,114	43.04
564	695	CABANISS	94CS75	2,112	42.96
565	195	AIRLINE	94CS9030	420	42.85
566	549	POLK AVENUE	94SB4600	2,714	42.47
567	251	WOOLRIDGE	94CS1170	757	42.43
568	259	KLEBERG	94CS6000	1,476	42.23
569	218	PORT ARANSAS	94CS6940	1,634	42.00
570	627	FULTON	94CS2020	1,795	41.96
571	588	GARCENO	94SB2130	3,091	41.80
572	494	RIO GRANDE CITY	94SB3740	2,259	41.77
573	79	HAMILTON ROAD	94LA9655	1,222	41.48
574	442	HARLINGEN	94SB360	2,470	41.35
575	461	BAY CITY	94CN2050	512	41.14
576	287	BANQUETTE	94CS130	224	40.87
577	96	NORTH ALAMO	94SB4370	1,475	40.60
578	539	RIO GRANDE CITY	94SB3230	2,532	40.52

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
579	656	NORTH EDINBURG	94SB3810	908	40.40
580	699	AIRLINE	94CS8260	1,502	40.32
581	237	LEARY LANE	94CN1430	1,595	40.28
582	669	ARANSAS PASS	94CS660	741	40.23
583	288	ARCADIA	94CS5030	1,575	40.09
584	571	LAREDO HEIGHTS	94LA9080	682	38.78
585	304	ARCADIA	94CS8570	1,437	38.07
586	503	LEARY LANE	94CN1890	1,617	38.02
587	604	EDROY	94CS6980	195	37.72
588	117	PHARAOH	94CS5175	988	37.72
589	660	EAGLE PASS CITY	94LA7060	850	37.36
590	147	ZAPATA	94LA8290	2,087	37.18
591	564	MCCOLL ROAD	94SB4400	1,228	37.14
592	569	MCCOLL ROAD	94SB4780	2,160	36.68
593	390	LAREDO HEIGHTS	94LA9400	1,428	36.60
594	626	NORTH VICTORIA	94CN7860	1,487	36.36
595	169	MUSTANG ISLAND	94CS9470	665	36.31
596	708	HALL ACRES ROAD	94SB9595	1,140	36.31
597	586	SUNCHASE	94SB1150	1,276	36.05
598	556	DEL RIO CITY	94LA440	1,083	36.03
599	435	SANTO NINO	94LA515	1,983	35.61
600	260	HALL ACRES ROAD	94SB3460	3,377	35.59
601	696	WASHINGTON STREET	94LA2470	188	35.59
602	493	HIGHWAY 9	94CS6730	531	34.95
603	52	CHASE FIELD	94CN460	10	34.30
604	678	LEARY LANE	94CN6175	1,676	34.26
605	478	BAY CITY	94CN5960	1,787	33.72
606	555	ROCKPORT	94CS5950	544	33.65
607	674	PALMVIEW	94SB9685	2,800	33.45
608	530	SAN DIEGO	94LA2890	1,073	33.16
609	693	WASHINGTON STREET	94LA6355	1,068	33.11
610	561	VICTORIA POWER PLANT	94CN8070	617	32.70
611	248	GEORGE WEST	94CN730	978	32.49
612	177	MARKHAM	94CN6440	427	32.48
613	334	SHARYLAND	94SB6745	1,999	32.04
614	328	ALICE	94LA1780	256	31.39
615	507	BRACKETTVILLE	94LA8460	1,137	31.13
616	599	MILO	94LA5020	1,314	30.95
617	333	CLARKWOOD	94CS7610	185	30.77
618	608	NORTH MCALLEN	94SB9660	1,977	30.77
619	643	MCKENZIE ROAD	94CS330	2,271	30.38
620	449	UVALDE	94LA480	1,321	30.37
621	506	SIERRA VISTA	94LA7360	2,675	29.72
622	715	EL GATO	94SB890	2,815	29.61
623	271	DEVINE	94LA7090	957	29.50
624	294	ARANSAS PASS	94CS650	745	29.34
625	275	BROOKHOLLOW	94CN7190	264	29.06
626	156	NORTH VICTORIA	94CN1470	450	28.68
627	320	RIO BRAVO	94LA1130	963	28.48
628	353	TAFT	94CS5230	833	28.18
629	111	SANTO NINO	94LA70	1,154	28.15
630	88	PORT ARANSAS	94CS990	1,453	27.55
631	225	EL CAMPO	94CN7710	1,063	27.55

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
632	new circuit	GREGORY	94CS2420	622	26.61
633	190	HALL ACRES ROAD	94SB4895	826	26.57
634	33	CRESTONIO	94LA260	1,808	24.90
635	467	ASPHALT MINES	94LA500	41	24.71
636	9	CAMPWOOD	94LA3430	82	24.66
637	285	GANADO	94CN5795	467	24.33
638	516	WEAVER ROAD	94CN1910	353	23.64
639	261	UVALDE	94LA540	1,210	23.21
640	407	ROCKPORT	94CS5930	1,135	23.21
641	new circuit	COTULLA	94LA460	638	23.03
642	340	SOUTH PADRE ISLAND	94SB5850	1,295	22.39
643	137	ARCADIA	94CS1460	2,142	22.14
644	222	LAREDO HEIGHTS	94LA2450	2,549	21.95
645	687	BUENA VISTA	94LA8965	929	21.50
646	417	LAREDO PLANT	94LA8705	220	21.41
647	620	THOMASTON	94CN9580	47	21.17
648	482	ODEM	94CS375	1,021	20.90
649	664	SHARYLAND	94SB5635	1,987	20.85
650	143	MAGRUDER	94CN6690	558	20.80
651	451	PHARR	94SB1620	2,394	20.78
652	617	POLK AVENUE	94SB4190	1,715	20.55
653	637	LAREDO PLANT	94LA8695	1,074	20.55
654	529	CABANISS	94CS240	1,490	19.96
655	525	DEL RIO CITY	94LA9790	2,319	19.86
656	183	BUENA VISTA	94LA9035	1,465	19.75
657	625	RODD FIELD	94CS205	1,678	19.51
658	151	MORRIS STREET	94CS8850	479	19.23
659	383	SINTON	94CS6860	1,634	18.91
660	447	SHARYLAND	94SB2150	1,185	18.54
661	686	KLEBERG	94CS280	1,284	18.49
662	100	UNIVERSITY	94LA950	3,124	18.27
663	601	HOLLY	94CS1220	3,409	18.19
664	622	ARANSAS PASS	94CS590	425	18.13
665	325	REFUGIO	94CN5120	704	18.04
666	235	LEARY LANE	94CN6005	2,066	17.51
667	123	UNIVERSITY	94LA920	301	16.85
668	158	ROMA	94SB3070	1,272	16.70
669	554	WESLACO UNIT	94SB2195	1,086	16.42
670	543	LEARY LANE	94CN1540	798	16.35
671	579	WASHINGTON STREET	94LA7015	1,527	16.31
672	545	PHARR	94SB1640	1,218	16.18
673	282	ESCONDIDO	94LA1510	716	16.17
674	618	AIRLINE	94CS6970	1,238	16.07
675	34	KNIPPA	94LA6535	22	16.00
676	504	SANTO NINO	94LA645	1,152	15.82
677	448	INGLESIDE CITY	94CS2495	261	15.69
678	511	MCCOLL ROAD	94SB4790	1,936	15.50
679	270	SANTO NINO	94LA80	1,785	15.47
680	109	MAGRUDER	94CN6700	1,333	15.27
681	404	WEST MCALLEN	94SB4505	1,774	15.22
682	490	KLEBERG	94CS6410	213	15.13
683	227	RAYMONDVILLE #2	94SB1280	1,059	14.93
684	399	HOMEPORT	94CS4665	445	13.63

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
685	628	SOUTH EAST EDINBURG	94SB4570	1,353	13.50
686	13	JOURDANTON	94LA5685	586	13.22
687	329	LAREDO PLANT	94LA9305	984	13.21
688	97	MCKENZIE ROAD	94CS150	26	13.19
689	238	PHARAOH	94CS1185	1,564	13.11
690	236	WOOLRIDGE	94CS1120	2,576	12.91
691	356	GREGORY	94CS420	383	12.89
692	403	LAREDO HEIGHTS	94LA6810	2,073	12.84
693	386	PORT LAVACA	94CN6850	680	12.71
694	416	WOOLRIDGE	94CS1110	1,600	12.67
695	720	WASHINGTON STREET	94LA2360	196	12.67
696	314	WEST MCALLEN	94SB4965	699	12.58
697	692	LAREDO HEIGHTS	94LA2390	1,701	12.48
698	456	SEAWALL	94CS9420	832	12.40
699	223	GARWOOD CITY	94CN2570	135	12.00
700	694	RODD FIELD	94CS1730	2,155	11.86
701	612	ZACATE CREEK	94LA2675	1,188	11.53
702	531	NAVAL BASE	94CS8440	1,597	11.53
703	710	EL CAMPO	94CN7260	530	11.21
704	651	EDNA	94CN5775	505	10.48
705	380	RAYMONDVILLE #2	94SB4160	346	10.23
706	714	RODD FIELD	94CS3010	1,962	9.60
707	576	SOUTH MISSION	94SB4650	1,003	9.13
708	672	PALMVIEW	94SB9680	980	8.92
709	711	RODD FIELD	94CS245	2,560	8.89
710	690	ZACATE CREEK	94LA2635	241	8.75
711	566	EL CAMPO	94CN6370	736	8.60
712	630	DEL RIO CITY	94LA9850	1,015	8.36
713	203	WEST MCALLEN	94SB4595	1,181	6.73
714	502	ROCKPORT	94CS5940	42	6.69
715	681	AIRLINE	94CS8370	263	5.71
716	471	ZACATE CREEK	94LA2665	1,681	5.69
717	697	AIRLINE	94CS9390	1,878	5.13
718	140	SANTO NINO	94LA695	1,563	5.03
719	new circuit	FASHING	94CN360	39	4.44
720	491	HAMILTON ROAD	94LA9645	291	4.30
721	281	KENEDY	94CN1960	67	4.18
722	688	WEST MCALLEN	94SB4815	699	4.01
723	716	EAST HARRISON	94SB3000	521	3.94
724	713	SOUTH MCALLEN	94SB3640	302	3.83
725	701	CLARKWOOD	94CS7220	427	3.64
726	102	WEAVER ROAD	94CN1900	60	3.23
727	505	WASHINGTON STREET	94LA2350	2,955	2.77
728	207	MILO	94LA3060	111	1.44
729	186	SIERRA VISTA	94LA9900	2,368	1.19
730	719	MCCOLL ROAD	94SB4910	327	0.91
731	141	GILA	94CS7840	733	0.79
732	717	SIERRA VISTA	94LA3540	341	0.73
733	522	MINES ROAD	94LA4275	17	-
734	728	VICTORIA POWER PLANT	94CNNETVIC	59	-
735	729	MORRIS STREET	94CSNET CC	334	-
736	730	WASHINGTON STREET	94LANETLAR	126	-
737	new circuit	COTULLA	94LA610	56	-

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
---------------------------	---------------------------	----------------------------------	------------------------------	----------------------------	-------------------------

Feeders from last year that are not in this year's list

2012 Ranking	Substation Identification	Feeder ID	Reason not in 2013
---------------------	----------------------------------	------------------	---------------------------

374	BRUNI	94LA5160	Retired, customers moved to 94LA1120
652	FASHING	94CN8160	Retired, customers moved to 94CN360
124	PEARSALL	94LA9905	Retired, customers moved to 94LA3675

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2013 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	13.15%
Vegetation	15.00%
Animals and Birds	7.28%
People (Including cars and farm equip)	2.64%
Utility-owned Equipment	51.53%
Other	0.04%
Unknown	10.36%