



Control Number: 42146



Item Number: 8

Addendum StartPage: 0

RECEIVED
14 FEB 14 PM 1:15
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2013 Reporting Year

Oncor Electric Delivery

Project 42146

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2013	0.96	0.07	0.07	0.08	0.07	0.09	0.09	0.14	0.08	0.08	0.09	0.05	0.05
Scheduled 2013	0.06	0.00	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.01	0.01	0.00	0.00
Outside Causes 2013	0.06	0.00	0.01	0.01	0.01	0.01	0.01	0.00	0.00	0.00	0.01	0.00	0.00
Major Events 2013	0.49	0.00	0.00	0.00	0.02	0.09	0.04	0.00	0.04	0.03	0.00	0.06	0.21

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2013	99.30	6.21	7.71	8.01	6.46	10.64	9.96	13.63	8.52	8.37	10.30	4.25	5.24
Scheduled													
2013	5.91	0.46	0.58	0.62	0.51	0.52	0.33	0.46	0.51	0.50	0.66	0.39	0.37
Outside Causes													
2013	3.88	0.18	0.53	0.28	0.57	0.39	0.61	0.35	0.25	0.06	0.43	0.01	0.22
Major Events													
2013	168.52	0.00	0.00	0.00	2.85	16.02	5.78	0.00	4.39	3.56	0.00	14.10	121.82

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2921

Add or Delete Rows as Necessary

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1	1145	UPTON	0721	110	15.42
2	10	GRDNC	1211	452	10.06
3	85	COHMA	1132	54	8.50
4	83	PLDAV	4221	235	8.31
5	222	MASON	3421	122	8.16
6	27	CSHNG	1202	61	8.07
7	N/A	BARNW	4511	52	8.06
8	456	GLSCK	2411	225	7.99
9	1	BARNW	4521	87	7.55
10	495	WCITY	2402	679	7.51
11	30	HOWRD	3921	72	7.50
12	827	DHIDE	2811	101	7.22
13	904	SCURY	1911	166	7.05
14	202	PLSTN	1002	1201	7.04
15	411	OTTOJ	3059	1096	6.96
16	2585	CRLTN	1454	335	6.93
17	157	BAYLC	1201	107	6.72
18	2421	LAVON	1454	2779	6.69
19	N/A	GYVLM	8611	11	6.64
20	302	DHIDE	2821	107	6.58
21	1416	CHALK	0911	145	6.50
22	126	CRLTN	1453	271	6.39
23	340	SBEAN	6011	149	5.99
24	N/A	MASON	3431	36	5.81
25	86	PTENN	2357	1276	5.80
26	1901	SCHRD	0001	1439	5.80
27	2382	MRSES	3015	569	5.78
28	370	ECTHM	3311	1458	5.66
29	1978	TRNTY	7541	679	5.52
30	1039	JEWET	1204	1305	5.40
31	36	RKCRK	6112	2013	5.38
32	2287	BNMAG	1201	192	5.38
33	104	COPEL	3056	2509	5.37
34	2593	SCYEN	0002	1869	5.28
35	1982	PARIS	1206	1005	5.27
36	2138	SCHRD	0007	1375	5.25
37	N/A	CWIND	6311	23	5.22
38	110	FRMBG	1753	1341	5.21
39	1138	INAIR	1413	2021	5.17
40	324	WALST	0005	246	5.15
41	308	ENTOH	0004	1514	5.14
42	173	CRKET	2403	2781	5.02
43	1962	BLMED	1617	315	5.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
44	982	MNWLE	1701	664	4.98
45	309	BLKRV	8321	38	4.95
46	223	PMBRK	1821	68	4.90
47	765	BRKTN	1202	116	4.84
48	1219	RENSW	3124	1692	4.80
49	328	EZACH	0001	984	4.79
50	640	RDLML	2571	363	4.70
51	2792	NMAIN	0262	409	4.66
52	135	HDWLK	3003	942	4.63
53	2690	EZACH	0005	536	4.58
54	266	HNTNG	1301	1346	4.53
55	1650	COHMA	1111	711	4.50
56	1646	ALPHA	0003	867	4.44
57	1353	KNOTT	5221	53	4.43
58	1608	SCYEN	0001	1966	4.34
59	514	SHAMP	0004	1133	4.34
60	18	IRLBJ	3212	2558	4.33
61	1797	KYSTN	1031	21	4.33
62	989	HKBRY	1101	184	4.28
63	2386	POYNR	1201	336	4.27
64	1208	MNRVA	1301	726	4.26
65	1987	ALLEN	2406	2634	4.26
66	585	IRVNG	1404	1424	4.18
67	2545	PKRVL	1051	4328	4.16
68	1517	RECCR	0004	70	4.16
69	1512	PLGRV	0002	2264	4.14
70	184	BRKRG	0223	271	4.13
71	1272	CLKVL	1201	448	4.12
72	185	GRLND	1604	1977	4.10
73	53	PLDAV	4231	118	4.08
74	2609	GVODS	3041	1476	4.06
75	593	TEGMN	3040	780	4.01
76	2204	VESTS	3111	55	3.96
77	48	MEXIA	4023	608	3.96
78	2101	CRSWS	1403	1834	3.92
79	428	BEAST	4082	518	3.91
80	290	UPTON	0711	143	3.89
81	2426	ODESA	0261	1470	3.87
82	102	HNTNG	1307	1458	3.82
83	2424	EGFRD	0004	1837	3.78
84	1703	CLCTY	1011	1093	3.73
85	9	TRPMN	4001	782	3.72
86	2266	PKRMX	4703	2864	3.66
87	1011	DFWSW	2202	41	3.63
88	913	PRCTR	1602	226	3.63
89	1514	NLNVL	2002	1421	3.62
90	26	TRPMN	4094	562	3.59
91	63	MYPRL	1803	577	3.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
92	1807	OAKHL	3072	2408	3.57
93	675	ABRRD	0004	826	3.55
94	2488	BLSRA	1602	151	3.55
95	1763	DCVSO	1106	1183	3.55
96	817	MSTNG	2611	168	3.55
97	1371	ALPHA	0009	57	3.54
98	6	DENDR	0005	400	3.54
99	1587	MIDWY	0612	430	3.54
100	775	PRCRK	0004	1437	3.53
101	14	CRNAT	4121	62	3.53
102	912	FRNKS	1201	375	3.53
103	759	CPLND	1101	976	3.50
104	N/A	ANDNR	2252	223	3.49
105	1564	BNTDR	0001	1276	3.47
106	2244	GRDPR	0881	2080	3.46
107	690	EDWDS	5921	1166	3.43
108	28	DIALV	3911	1067	3.42
109	2050	KLNPS	1104	1359	3.42
110	634	TYEST	1507	1196	3.41
111	1186	MSHLN	0004	1293	3.41
112	2375	TRLWD	7722	3939	3.39
113	320	GVGLF	9601	46	3.39
114	404	BAGWL	1202	47	3.38
115	1537	GVODS	3011	2293	3.37
116	1902	DAVST	0005	1812	3.37
117	721	GRLND	1605	1394	3.34
118	148	CNI45	2401	586	3.33
119	1209	ENSSO	2004	1181	3.32
120	1332	TMSTH	1406	1148	3.32
121	1746	TRLSW	1201	1159	3.31
122	429	NCDCH	1205	1061	3.31
123	932	MKNSW	2601	3028	3.30
124	1519	CRNES	2711	143	3.30
125	2777	HKBRY	1103	74	3.30
126	681	DESPR	1402	1284	3.30
127	911	COPEL	3053	2042	3.30
128	983	SHLMT	1801	300	3.27
129	1580	PKRVL	1052	2152	3.26
130	1663	MRDCK	0003	1254	3.26
131	673	CRNRD	0007	739	3.25
132	141	CRKET	1201	325	3.25
133	214	CLLVL	0003	711	3.24
134	567	BBTWN	1502	1700	3.24
135	17	TYLNE	1605	1122	3.24
136	815	CDMIL	2401	650	3.23
137	498	JUDCT	0007	600	3.22
138	2300	LKMNT	0002	985	3.22
139	1651	DEALY	0003	1157	3.21

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
140	2387	HRSMD	1951	4455	3.19
141	726	COPEL	3055	2135	3.18
142	2186	LAVON	1452	1793	3.18
143	155	TRIRA	6222	621	3.18
144	1748	TYRSW	1701	2328	3.17
145	1043	EDGWD	1101	699	3.14
146	1440	LKHLD	0008	1141	3.14
147	1003	WMRLD	0002	1559	3.14
148	533	ARPMN	4147	584	3.14
149	1361	RCLNS	1405	634	3.13
150	13	BBTWN	1501	1971	3.12
151	129	TYOMN	1409	1536	3.12
152	22	DGLAS	2401	722	3.12
153	2	LOVNG	2511	81	3.11
154	1423	DESHR	1202	1587	3.10
155	408	CSHNG	1201	916	3.10
156	781	ALNSW	2653	3382	3.09
157	789	FLMSO	3714	557	3.09
158	2260	CURIE	7212	13	3.08
159	1414	ALLEN	2408	3091	3.07
160	2397	MSLSW	0005	731	3.06
161	598	MDFRM	2111	49	3.06
162	1563	EMPCT	0001	33	3.06
163	49	SMOUR	0721	19	3.05
164	24	KNLTR	0003	608	3.04
165	1099	PCOIT	1024	2291	3.04
166	2238	IVANS	1612	1053	3.03
167	103	HRSMD	1907	2469	3.03
168	236	CKRHL	0008	1644	3.03
169	2806	SCHRD	0006	470	3.02
170	263	CNI45	2402	813	3.02
171	1299	DUVAL	0434	2430	2.99
172	1592	KLNPS	1101	2274	2.98
173	1479	DAVST	0006	1051	2.97
174	1080	ANDRD	0921	95	2.97
175	191	RSKMN	3046	1077	2.97
176	1949	WHITE	3522	1763	2.96
177	782	PLSTN	1004	1575	2.94
178	661	TYLNW	1910	1881	2.93
179	1127	SWDTN	1611	1642	2.93
180	2495	NHNSW	0003	524	2.91
181	1804	SNYDR	1822	1622	2.91
182	323	MDLNE	0112	818	2.90
183	368	FKLCY	5111	113	2.90
184	1937	PLGRV	0004	1654	2.88
185	2895	SHDYG	7821	96	2.88
186	1225	STANT	1322	155	2.86
187	1315	WHTRK	0007	1240	2.86

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
188	1301	ALPHA	0010	508	2.86
189	975	LKBRN	2402	1163	2.86
190	1317	DCATR	1202	1684	2.85
191	1985	MSTLT	1084	636	2.81
192	2409	LIPAN	1301	504	2.81
193	301	JREST	2101	1141	2.78
194	2161	CHALK	0951	72	2.78
195	884	TROYS	1013	763	2.77
196	401	BSPSW	0851	1257	2.76
197	2591	CMPST	0002	626	2.76
198	259	BLSRA	1601	1342	2.75
199	1818	KLNTF	1805	1211	2.74
200	1777	WSTHL	3652	3158	2.74
201	108	GRLRD	0004	1541	2.73
202	1435	RSKMN	3078	131	2.72
203	2528	MESQN	1508	1785	2.71
204	2254	CKRHL	0006	252	2.69
205	89	WHOUS	4122	2064	2.68
206	1052	LFEST	1905	1743	2.68
207	1274	WDGWD	1541	1119	2.68
208	335	FRNKS	1202	94	2.67
209	1201	KLNPS	1103	2049	2.67
210	683	LKHLA	0005	1125	2.67
211	500	WMRLD	0007	1694	2.65
212	2255	WDGWD	1591	1152	2.65
213	2296	GNSVL	1205	876	2.65
214	1467	PLSTH	1305	848	2.65
215	81	MDFRM	2131	17	2.65
216	1879	HUTTO	2742	3392	2.65
217	2763	KYSTN	1011	59	2.64
218	142	CRANE	0311	778	2.64
219	186	CHROW	0002	109	2.63
220	1730	INDIA	2501	333	2.63
221	2728	MSLSW	0002	1024	2.62
222	923	MESQN	1507	678	2.59
223	249	COLNY	2404	1949	2.57
224	318	JEWET	1202	748	2.57
225	2372	MSHLN	0007	722	2.57
226	2121	OAKHL	3021	1934	2.57
227	2250	IOWPK	0821	756	2.57
228	1981	NVARO	1502	201	2.55
229	44	NCDCH	1201	788	2.55
230	2855	DFWSW	2209	11	2.55
231	1991	GLNHV	3973	1356	2.54
232	233	PLDAV	4211	74	2.54
233	583	COMSO	1405	754	2.54
234	840	MTLDA	0003	1482	2.54
235	1866	DNINR	1403	1185	2.54

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
236	64	OKCLS	0003	1480	2.52
237	359	SHMNE	1409	891	2.52
238	1275	KEENE	1503	826	2.52
239	1025	NYLDV	1201	610	2.51
240	413	MSLSW	0004	373	2.50
241	1075	WOVER	6142	1667	2.50
242	771	LWRDR	0001	1140	2.50
243	1413	FSCRK	6732	3347	2.50
244	970	PAYSW	1223	120	2.50
245	750	SNYDR	1852	1373	2.50
246	1753	SNYDR	1813	293	2.49
247	1417	MLKF2	1201	1746	2.49
248	275	DIBOL	1506	622	2.49
249	459	CRSCN	1204	607	2.49
250	1074	GSMTH	1732	45	2.49
251	2091	DGNST	0002	546	2.48
252	1081	FLRTN	3721	25	2.48
253	469	QNLAN	1202	371	2.47
254	735	DALLW	0002	71	2.46
255	1322	LIPAN	1303	274	2.46
256	1271	WGROB	8411	2944	2.46
257	57	WCITY	2401	915	2.45
258	1952	FARON	4082	1569	2.45
259	1548	KLNTF	1804	1004	2.45
260	207	WATCO	2605	2617	2.44
261	450	NCSTH	1501	822	2.44
262	1493	WLWSP	1201	493	2.44
263	2184	PLKST	0004	1082	2.44
264	1933	ELCTR	1211	291	2.44
265	461	LIGSW	1608	363	2.43
266	N/A	MDAIR	2931	820	2.42
267	2718	FRMNT	0010	1937	2.42
268	2197	RHOME	2402	1231	2.41
269	1942	SCYEN	0004	1222	2.41
270	901	DALLW	0001	1102	2.40
271	2799	KNLTR	0005	2436	2.40
272	725	SSPNG	1202	1215	2.39
273	2459	HRSMD	1953	398	2.39
274	2080	NOLNW	2111	26	2.38
275	1641	KLNTF	1806	1157	2.38
276	1482	PWEST	1310	257	2.37
277	1226	IOWPK	0811	779	2.37
278	342	MNWLW	1403	923	2.37
279	647	TYEST	1511	891	2.36
280	2491	BLTLN	0004	640	2.36
281	1891	FROKS	0008	1497	2.36
282	1653	MDLNW	1532	2193	2.36
283	1941	KNLTR	0008	897	2.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
284	1786	DUVAL	0441	1000	2.35
285	592	KILEN	1202	1767	2.35
286	1316	WITTS	1705	1305	2.35
287	776	MDTHS	1002	989	2.35
288	1950	BRHLW	7651	1129	2.34
289	714	BLTLN	0003	587	2.34
290	32	BRTL	1402	121	2.34
291	2023	PRSTN	0008	773	2.33
292	1170	HSKAV	0001	1069	2.33
293	279	GRSMN	3071	337	2.32
294	1223	JUDCT	0008	135	2.31
295	52	KLBRG	0002	1633	2.31
296	1112	MSTLT	1042	496	2.31
297	371	KILEN	1201	1818	2.31
298	365	MKNSW	1602	703	2.30
299	1215	PTENN	2353	944	2.30
300	1040	KLNCC	1704	2174	2.29
301	2120	THRNE	0004	835	2.29
302	2247	CDHIL	1802	813	2.29
303	2325	KYSTN	1021	41	2.29
304	2285	PPARK	1803	1055	2.29
305	1350	FRFWS	3004	852	2.28
306	2588	DNINR	1401	81	2.28
307	1411	SNDHL	3821	68	2.28
308	537	ELGIN	1001	516	2.28
309	1087	RICES	0208	695	2.27
310	336	CRSGL	1306	599	2.27
311	1427	KLNPS	1102	1861	2.27
312	1494	NHNSW	0007	581	2.27
313	2338	MTLDA	0005	1548	2.27
314	763	GVODS	3072	2260	2.25
315	452	HDWLK	3005	986	2.24
316	1815	SANSM	3922	1730	2.23
317	2695	HNYGR	2403	136	2.22
318	1974	RDLML	2552	279	2.21
319	409	MKNNY	1251	1473	2.21
320	2628	LNDAL	2202	1210	2.19
321	2756	CRLTR	2006	52	2.19
322	2725	DGNST	0005	146	2.18
323	1021	IRVNR	1505	1297	2.18
324	136	KILEN	1205	1313	2.18
325	2548	KLNTF	1802	843	2.18
326	1296	RSKMN	3057	1162	2.17
327	2351	ITALY	2101	546	2.17
328	1276	CRNTH	2402	1594	2.17
329	995	TAYLR	1201	1763	2.16
330	1366	RDRSE	2604	2392	2.16
331	374	DNCNV	1901	890	2.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
332	1584	DGNST	0008	507	2.16
333	658	WBOSE	1102	340	2.16
334	35	HRSMD	1955	1637	2.15
335	2427	HORNE	1932	1110	2.15
336	833	HKBRY	1115	14	2.14
337	541	ANDRD	0931	170	2.14
338	2060	GVODS	3031	1372	2.13
339	210	STHRL	0004	1215	2.13
340	270	IRVNR	1508	1966	2.13
341	2174	OKLND	0003	1316	2.13
342	2216	RSPCK	2104	1797	2.12
343	1449	OVRTN	4015	634	2.12
344	1385	MSHLN	0003	531	2.11
345	167	SMPST	0003	1118	2.11
346	698	HLSBR	1203	1139	2.11
347	2133	RTHGB	1421	1650	2.10
348	2719	SYCRK	4531	2336	2.10
349	1363	CLBWS	8111	1508	2.09
350	274	LAVON	1451	985	2.09
351	1097	TYLER	1005	1992	2.09
352	5	LUFKN	1208	2135	2.09
353	2117	RRNES	2403	4665	2.09
354	2536	KNLTR	0011	334	2.08
355	1248	CRLTN	1406	1192	2.08
356	325	REAST	1502	1313	2.08
357	2144	FRNKF	0002	936	2.07
358	2362	HNYGR	2402	163	2.06
359	1364	DGNST	0007	304	2.05
360	1339	CLYVL	9313	1912	2.05
361	1006	REYST	4118	732	2.05
362	82	GLNHV	3983	1464	2.05
363	1424	CLKVL	1202	1283	2.04
364	774	MAYFD	5524	2568	2.04
365	2082	KNEDL	6332	2164	2.04
366	1020	RRSTH	1707	580	2.04
367	1377	BRYAN	0002	214	2.04
368	1358	MEANS	4411	128	2.04
369	666	RDLML	2512	1180	2.04
370	2059	WBROK	3021	56	2.04
371	595	ROLTR	2921	2508	2.03
372	1613	RECCR	0006	549	2.03
373	1749	BONHM	1206	2080	2.03
374	88	MSHLN	0001	1044	2.03
375	605	GLNHV	3953	1505	2.03
376	1165	RDOAK	1301	2341	2.02
377	74	DEALY	0004	2051	2.02
378	97	SMPST	0004	1638	2.02
379	114	ACRLY	1721	60	2.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
380	1555	BRLSN	2052	2925	2.01
381	2403	LKHL	0003	1347	2.01
382	699	BNTDR	0003	427	2.01
383	2826	HKBRY	1113	425	2.01
384	2356	RYSSW	2801	2012	2.01
385	1179	JSHUA	1301	929	2.00
386	39	AMLIA	0006	88	2.00
387	2104	GVOVS	3021	957	2.00
388	2670	NCSTH	1504	66	2.00
389	1497	OAKCK	2211	42	2.00
390	2473	SWTWR	1362	10	2.00
391	1212	MESQW	1808	1311	2.00
392	N/A	FORSN	5632	222	2.00
393	420	DCVSO	1105	1639	2.00
394	305	LNCST	1605	790	1.99
395	2278	RWDHV	1908	2173	1.99
396	1795	PLKST	0003	1940	1.99
397	67	BKWVF	0521	463	1.99
398	2227	WMRNR	0002	430	1.99
399	1325	MEXIA	4007	471	1.99
400	69	TRIRA	6221	995	1.98
401	1344	GVOVS	3062	1971	1.98
402	2787	BKWST	0007	1724	1.97
403	1585	WELRD	0004	798	1.97
404	1247	MAYFD	5522	2936	1.97
405	2680	FRMBG	1752	473	1.97
406	2768	SHAMP	0002	1726	1.97
407	1245	SCSES	1201	281	1.96
408	2554	LEMON	0008	800	1.95
409	1441	TYLNE	1613	435	1.95
410	1028	SYCRK	4532	4015	1.94
411	1767	CRLFR	2157	2413	1.94
412	606	SHDYG	7811	348	1.93
413	1614	KLNCC	1702	3656	1.93
414	1814	GSTHW	1623	2472	1.93
415	1530	CNTRD	0002	1459	1.92
416	1156	CRLUD	1304	1410	1.92
417	1491	MDLNE	0141	659	1.92
418	1893	WDGWD	1513	846	1.92
419	1108	FRMBR	1802	1111	1.92
420	160	ATHNW	1405	905	1.91
421	1801	ALLEN	2410	2323	1.91
422	45	JKWST	4035	78	1.91
423	851	QNLAN	1201	829	1.91
424	678	FARON	4062	1145	1.90
425	2127	HOLDY	0921	612	1.90
426	768	FRSTN	1604	325	1.90
427	2394	PCOIT	1022	2127	1.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
428	1308	WEAST	0617	1398	1.90
429	996	CRSCN	1203	1972	1.89
430	1262	SCYEN	0003	1242	1.89
431	2419	DESHR	1208	405	1.88
432	94	JKWST	4178	408	1.88
433	2410	GMINI	5812	764	1.86
434	638	SHDYG	7822	512	1.86
435	557	SWTWR	1341	245	1.86
436	1251	ALDTU	9421	1541	1.86
437	1057	LNDAL	2201	1831	1.86
438	1912	ROSCO	2921	221	1.86
439	1865	HURST	1822	1475	1.85
440	1792	FARON	4041	1008	1.85
441	46	PLKST	0002	1521	1.85
442	693	IRVND	1202	1484	1.85
443	734	EDDYS	0712	1098	1.85
444	425	LNDAL	2203	2213	1.85
445	519	PGSTH	7011	127	1.84
446	816	CAMRN	1203	1217	1.84
447	16	FRMBG	1750	1455	1.84
448	710	BRNSY	1211	126	1.83
449	125	NCWDN	1111	828	1.83
450	31	TSLVL	4001	1221	1.83
451	2068	BNTDR	0002	1711	1.83
452	740	THRNE	0008	2207	1.83
453	N/A	COVEE	3405	784	1.82
454	1304	VANSB	1501	790	1.82
455	1125	BNMAG	1202	388	1.81
456	2534	WXHNW	2901	178	1.81
457	N/A	ODESW	5912	295	1.80
458	590	MABNK	2403	1747	1.80
459	1490	CRKET	2401	147	1.80
460	389	BAKKE	6911	135	1.79
461	1204	MESQT	1308	1851	1.79
462	2178	SANSM	3912	4991	1.79
463	2235	MKNSW	2602	3532	1.79
464	2156	FRFWS	3002	835	1.78
465	2605	GORMN	0411	532	1.78
466	1836	RRNES	2404	4447	1.77
467	321	TMNTH	1606	220	1.76
468	1100	WHTRK	0001	2714	1.76
469	832	PLSTN	1003	1423	1.76
470	144	EULSO	9111	1867	1.76
471	1469	BRKRG	0213	426	1.75
472	1426	MIDWY	0621	113	1.75
473	333	CHRNO	1201	510	1.75
474	854	HNTNG	1305	1172	1.74
475	2707	RRNES	2407	3034	1.74

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
476	2206	COPER	1201	324	1.74
477	77	NHNSW	0006	951	1.74
478	2125	RHOME	2401	1126	1.74
479	261	TYSTH	1206	1268	1.73
480	662	WTHRF	2002	1642	1.73
481	1816	WCOLO	1316	2075	1.73
482	145	DUBLN	2214	699	1.73
483	1515	CLBRN	1202	974	1.72
484	667	DUVAL	0421	1240	1.72
485	1513	ODNTH	2014	1239	1.72
486	1101	TYSTH	1203	422	1.72
487	1253	ATHNS	1203	1034	1.72
488	806	GODRD	8151	791	1.72
489	940	TNSCL	1104	186	1.71
490	1203	IRVNR	1501	1104	1.71
491	870	WMRLD	0006	584	1.71
492	2861	FRMNT	0002	682	1.71
493	78	REAST	1503	564	1.71
494	1607	GRHWY	5522	2237	1.70
495	2165	EULES	8713	2000	1.70
496	1788	BSPRW	2532	1646	1.70
497	1232	SGOVL	1403	2148	1.70
498	1340	CPRCV	1407	2684	1.70
499	121	ODESW	5221	1169	1.69
500	260	TYSTH	1202	1047	1.69
501	1000	TYSTH	1209	820	1.69
502	1690	LFSTH	1404	489	1.69
503	751	CNTRY	2824	3120	1.69
504	181	ENSSO	2003	504	1.68
505	168	PREST	1603	1525	1.68
506	71	CRKET	2402	1709	1.68
507	1762	ODNTH	2033	667	1.68
508	376	WHTRK	0003	1258	1.67
509	218	WHOUS	4128	350	1.67
510	73	ODESW	5211	1019	1.67
511	2651	IRLBJ	3211	2590	1.67
512	87	NCSTH	1503	919	1.67
513	513	WSTHL	3631	3693	1.67
514	838	DUVAL	0483	1548	1.66
515	1976	AYERS	4431	1646	1.66
516	1187	HMTRD	0002	1030	1.66
517	526	LFKHL	2103	1925	1.66
518	2438	WDGWD	1561	1496	1.65
519	61	JKSES	3029	1175	1.65
520	416	MRSES	4005	739	1.65
521	773	PLSTH	1301	710	1.65
522	143	BDFRD	8821	876	1.65
523	1014	KLBRG	0001	331	1.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
524	196	DIBOL	1505	1426	1.64
525	1932	CKRHL	0005	1217	1.64
526	1049	DNCNV	1904	1469	1.64
527	464	MSHLN	0006	1098	1.64
528	853	CDHIL	1804	1169	1.64
529	N/A	TIODE	9632	1013	1.64
530	2272	TERSO	2503	1043	1.63
531	1147	ARLNG	1292	1544	1.63
532	2306	CRNRD	0001	722	1.63
533	1571	SALSW	3001	1362	1.63
534	2220	MAPLE	0001	834	1.62
535	1067	TRLWD	7712	3203	1.62
536	711	THRDN	1901	1672	1.62
537	2511	MSTLT	1011	65	1.62
538	1164	CADDO	0911	452	1.62
539	1525	MKNGB	5322	871	1.61
540	589	RKDLE	1302	1092	1.61
541	1541	GRPVN	8212	4011	1.61
542	925	REYST	4129	529	1.61
543	1409	EDDYS	0710	637	1.60
544	486	ARPMN	4149	308	1.60
545	98	DEALY	0002	1321	1.60
546	820	WDCR	0232	644	1.60
547	846	CHROW	0003	150	1.60
548	617	BNBOR	1203	312	1.60
549	2749	GMINI	5821	1403	1.59
550	2811	CKRHL	0001	414	1.59
551	1883	WCOLO	1319	2037	1.59
552	2467	RDOAK	1303	1969	1.59
553	1572	IRVNE	1306	1500	1.58
554	1805	PWEST	1304	1242	1.58
555	700	MESQW	1806	1655	1.58
556	193	GRNGR	1801	898	1.58
557	1747	TYLGE	1308	1556	1.58
558	1975	CRLUD	1305	1357	1.58
559	1532	HURST	1831	1361	1.58
560	979	FERIS	1101	1134	1.58
561	15	NCNTH	1806	871	1.58
562	1066	IRVGS	1902	1499	1.58
563	988	WMRLD	0005	1607	1.58
564	2131	CRNSO	3911	300	1.58
565	1939	CRYVE	3021	1277	1.57
566	1633	PSHIL	1608	1938	1.57
567	60	JREST	2102	997	1.57
568	N/A	BRTRD	7322	606	1.57
569	867	TATSP	4323	2478	1.57
570	1013	RCHRD	1208	1064	1.56
571	2024	BRCRK	6524	782	1.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
572	1205	HKHTS	1604	850	1.56
573	1207	HUTCH	1503	537	1.56
574	293	TYLGE	1311	784	1.56
575	N/A	MOSSW	4621	3058	1.55
576	2767	HMTRD	0003	396	1.55
577	1640	JSHUA	1302	1297	1.55
578	572	PMBRK	1811	20	1.55
579	2230	CTYVW	2212	146	1.55
580	2332	RDLML	2581	1229	1.55
581	2361	EDDYS	0425	403	1.55
582	287	TIODE	9621	292	1.54
583	1705	PSHIL	1604	1155	1.54
584	1735	TEGMN	3038	1679	1.54
585	1635	RWALL	1203	3264	1.54
586	1507	CRSSN	7911	758	1.54
587	958	IRVNR	1555	3776	1.53
588	1330	LNGLK	1602	756	1.53
589	603	WCOLO	1315	1562	1.53
590	532	SYCRK	4522	1353	1.53
591	1874	CNSES	3054	2020	1.52
592	1235	BLTLN	0005	842	1.51
593	1704	EULSO	9131	1973	1.51
594	2228	TRLSW	1204	579	1.51
595	72	COMSO	1402	928	1.51
596	2110	MNWLL	1207	2013	1.51
597	1983	BSPRG	1905	1586	1.51
598	1728	ITSCA	1701	727	1.50
599	251	RYLTY	1421	431	1.50
600	1732	MESQN	1502	1092	1.50
601	2837	ALLEN	2405	22	1.50
602	695	SWAN2	1803	1106	1.50
603	946	FRFWS	3001	1772	1.50
604	1583	WNTHW	1119	1312	1.50
605	1556	TXHRV	1621	79	1.49
606	1882	MESQW	1807	1493	1.49
607	1609	ALLNC	6412	2359	1.49
608	1534	RDLML	2532	1614	1.49
609	2175	TMPTV	2404	1404	1.49
610	1031	ELZCK	4911	94	1.49
611	2853	DFWSW	2203	41	1.49
612	1518	MLDR2	1605	843	1.49
613	1380	PRNTH	1405	970	1.48
614	N/A	GSMTH	1711	62	1.48
615	1945	PTENN	2351	1546	1.48
616	131	GLNHV	3922	713	1.48
617	1570	EZACH	0007	1589	1.48
618	1880	KILEN	1203	710	1.48
619	1076	ANDNR	2211	2390	1.48

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
620	980	CNTRY	2831	1589	1.48
621	1473	STNVL	1201	2237	1.48
622	1486	MESFR	2101	2016	1.48
623	2054	LVOAK	1601	833	1.48
624	29	BSPRW	2542	737	1.48
625	2143	HKBRY	1102	1364	1.48
626	1725	RWALE	3324	1656	1.48
627	2208	CRLJL	1506	1937	1.48
628	1628	PAYSW	1205	717	1.47
629	1511	WEAST	0629	1792	1.47
630	784	DNCNV	1902	1066	1.47
631	1671	JKREA	1201	30	1.47
632	N/A	MKNGB	5352	678	1.47
633	2827	ARMST	0012	1058	1.47
634	510	VENSW	2601	1262	1.46
635	1642	PLSTH	1303	572	1.46
636	1098	ARTHR	0431	461	1.46
637	1685	FSHSW	2111	304	1.46
638	584	CLBNR	1404	1310	1.45
639	1460	WWDWY	2020	1229	1.45
640	1701	IRVNE	1303	1671	1.45
641	1438	GNSVL	1203	1616	1.45
642	629	DNISN	1203	1647	1.45
643	348	REYST	4051	1077	1.44
644	1283	MRDCK	0001	2127	1.44
645	2449	SYCRK	4511	1957	1.44
646	2379	HSKAV	0004	1264	1.44
647	2433	MRDCK	0002	1422	1.43
648	7	TIODE	9611	273	1.43
649	1961	DAVIS	3752	498	1.43
650	1659	DNIWS	1602	1412	1.43
651	458	BRNWD	1205	1152	1.43
652	1884	WKATY	1718	2151	1.43
653	2276	REAST	1504	1312	1.43
654	1115	RDOAK	1302	1222	1.43
655	1461	BRLSN	2033	1674	1.42
656	1752	GNSVL	1223	1015	1.42
657	543	ARLNG	1282	836	1.42
658	2017	WXNTH	2301	1298	1.42
659	1773	TRNTH	1504	758	1.42
660	1971	RCHHL	0332	1638	1.42
661	856	ADISN	1605	1093	1.42
662	707	ODNTH	2053	2379	1.42
663	718	FARON	4072	1531	1.42
664	2150	DUBLN	1360	1103	1.42
665	659	EDGCF	2282	1043	1.42
666	2468	PROAD	0002	832	1.42
667	1139	RCLNS	1406	507	1.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
668	120	GRDPR	0842	1336	1.41
669	639	BELLS	1201	562	1.41
670	1928	CURIE	7221	820	1.41
671	1523	ECTHP	4921	213	1.41
672	1560	TYLER	1004	191	1.41
673	631	KLBRG	0004	1081	1.41
674	1285	BLTON	1802	1406	1.41
675	1160	HOWRD	3911	37	1.41
676	2365	OAKHL	3082	1389	1.40
677	530	CNTRY	2833	2342	1.39
678	795	TYLNE	1607	744	1.39
679	298	MYPTX	2401	287	1.39
680	882	ALNTH	2851	2093	1.39
681	528	LVBRD	0002	473	1.39
682	1643	DESHR	1204	1135	1.39
683	1917	GRSMN	4029	969	1.38
684	1243	OVRTN	4019	670	1.38
685	794	LIGSW	1621	29	1.38
686	802	MESQW	1803	1658	1.38
687	1834	HLSES	0561	1787	1.38
688	1019	DNIWS	1601	874	1.38
689	2010	GODRD	8132	2668	1.38
690	2851	DFWNW	2602	32	1.38
691	1620	GPLND	1201	656	1.37
692	1965	ALVDO	1902	882	1.37
693	1370	EMPCT	0003	1424	1.37
694	152	WOVER	6131	2095	1.37
695	943	DAVST	0007	617	1.37
696	2669	PROAD	0008	1150	1.37
697	620	MKNSW	2604	4147	1.37
698	472	CRISP	1501	887	1.37
699	1731	LKHLD	0004	1255	1.36
700	1194	TYBLR	2811	1048	1.36
701	1446	DENAV	0611	848	1.36
702	538	PCUST	2004	1056	1.36
703	8	PLKST	0008	1706	1.35
704	1855	OAKHL	3052	746	1.35
705	2112	MNHNS	1921	1808	1.35
706	124	FSTVW	0008	1769	1.35
707	1058	PRKWY	1511	1289	1.35
708	292	WEBBS	8623	2757	1.35
709	40	HSKAV	0008	781	1.35
710	2318	MEXIA	3016	275	1.34
711	21	PLSTH	1302	1007	1.34
712	1273	SNYDR	1823	1497	1.34
713	1908	HLSBR	1202	1232	1.34
714	2568	FRNKF	0005	1659	1.34
715	1191	KILEN	1204	1461	1.34

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
716	551	MDLNW	1552	1360	1.34
717	1072	NCDCH	1202	1044	1.34
718	1397	WSTHL	3613	3315	1.33
719	1946	CRTLD	4734	788	1.33
720	381	MNHNS	1912	1767	1.33
721	76	KIMBL	5011	766	1.33
722	258	STAUG	0004	1152	1.33
723	1591	PRCRK	0002	2166	1.33
724	1351	SHRSW	6622	1598	1.33
725	1594	BLKST	1781	1917	1.33
726	1936	MESQN	1503	1873	1.33
727	225	ECTHP	4911	992	1.33
728	1510	WXNTH	2304	854	1.33
729	N/A	FORSN	5642	40	1.33
730	2440	CMPWI	0004	1624	1.32
731	123	BEAST	4090	929	1.32
732	618	RSNHT	1171	2282	1.32
733	1238	MDLNW	1522	1349	1.32
734	1524	MNWLL	1203	830	1.32
735	2544	NHNSW	0001	456	1.32
736	2396	HKBRY	1111	25	1.32
737	353	MRTSP	1501	649	1.32
738	1711	LKMNT	0005	607	1.32
739	2225	KRUMS	1203	771	1.32
740	190	ALDTU	9411	2084	1.32
741	1649	RDLML	2561	828	1.32
742	1345	BNBOR	1202	718	1.32
743	163	GLNHV	3992	348	1.32
744	866	NCSTH	1506	89	1.31
745	1465	HMPHL	2733	118	1.31
746	1408	RYSSW	2802	3577	1.31
747	418	RRSTH	1706	3316	1.31
748	891	BRKRG	0232	1746	1.31
749	2062	SPRDL	4812	1218	1.31
750	1159	TYLNE	1623	473	1.31
751	N/A	DALLW	0007	420	1.30
752	111	SSPNG	1205	1118	1.30
753	783	DNCNV	1906	405	1.30
754	127	GRDPR	0871	1554	1.30
755	2181	BKWST	0002	1639	1.30
756	1260	FSTVW	0006	1229	1.30
757	378	ELKTN	2506	1792	1.30
758	N/A	CMTSW	0922	1360	1.30
759	100	WALNT	0008	911	1.30
760	1375	FSTVW	0007	1584	1.29
761	1094	CRLCC	2704	534	1.29
762	2095	TMPLE	1201	362	1.29
763	1647	KIMBL	5012	1736	1.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
764	1143	ALVDO	1901	1396	1.29
765	159	NHNSW	0002	394	1.29
766	128	CMEXP	1601	227	1.29
767	317	GSTHW	1611	765	1.29
768	438	ELMAR	3211	145	1.29
769	679	MEXIA	3015	111	1.29
770	600	MRSES	4006	543	1.29
771	1400	ENSSO	2002	1098	1.29
772	2508	KLBRG	0003	1276	1.28
773	322	MNFLD	2672	2208	1.28
774	890	SHSTH	1303	721	1.28
775	809	TRNTY	7511	1305	1.28
776	2654	GRLWS	1706	267	1.28
777	188	ODNTH	2034	2857	1.28
778	1758	ALPHA	0014	499	1.27
779	516	HLTOM	2431	1303	1.27
780	822	KERNS	2401	565	1.27
781	407	CHROW	0004	196	1.27
782	893	AMLIA	0007	89	1.27
783	347	CDCSW	0006	1325	1.27
784	385	STNVL	1203	2207	1.27
785	1250	THRNE	0002	1409	1.27
786	119	NCRST	2203	990	1.27
787	680	IRVVV	2851	2958	1.27
788	2301	WALST	0011	725	1.26
789	529	CRLTN	1403	129	1.26
790	1432	ALLEN	2403	1367	1.26
791	963	CRLUD	1307	301	1.26
792	2303	PFLGV	2005	3642	1.26
793	1136	CHICW	1302	199	1.26
794	2780	CMTSW	0914	513	1.26
795	2066	ENNIS	1904	1272	1.26
796	843	MESTE	1207	946	1.26
797	1595	MCGRG	1902	472	1.26
798	1593	GSTHW	1631	2218	1.26
799	375	THSES	2402	1356	1.26
800	476	COYAN	6321	304	1.26
801	2242	WXHCH	1204	1709	1.26
802	1062	MCKMY	0811	2061	1.25
803	2805	RSPCK	2105	309	1.25
804	2282	KFMNW	1201	1023	1.25
805	2295	GSTHW	1633	968	1.25
806	1450	IRVNR	1506	1390	1.25
807	1356	MKNSW	2603	1220	1.25
808	926	SACRC	5521	129	1.25
809	444	PARIS	1202	1264	1.25
810	11	CDCSW	0004	1314	1.25
811	720	ANDNR	2231	1083	1.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
812	1760	ACRLY	1711	168	1.24
813	1793	GSMTH	1742	37	1.24
814	860	ODNTH	2073	679	1.24
815	1333	HORNE	1911	997	1.24
816	1625	GNSVE	1603	1683	1.24
817	1722	DEALY	0001	395	1.24
818	2158	KLNTF	1801	1187	1.24
819	907	GRLND	1603	312	1.24
820	1843	ODNTH	2024	2681	1.24
821	1084	PEGAS	2311	119	1.24
822	449	COMRC	1203	670	1.23
823	1601	RBNSN	2502	1189	1.23
824	831	BSPSW	0822	362	1.23
825	652	LWSNR	2221	1185	1.23
826	1706	CPLSO	4312	1619	1.23
827	1378	TYOMN	1410	1515	1.23
828	754	HMTRD	0004	1038	1.23
829	967	TRPMN	4023	424	1.22
830	246	BRKNR	1221	1176	1.22
831	1892	DAVST	0002	552	1.22
832	2641	ANARN	1911	18	1.22
833	1218	KEENE	1501	1538	1.22
834	1501	HKHTS	1603	1014	1.22
835	2497	LWSNR	2211	1415	1.22
836	2115	GRHWY	5511	1876	1.22
837	2261	DAVST	0008	14	1.21
838	80	ELGIN	1002	2506	1.21
839	467	ARLNG	1232	1268	1.21
840	2205	KLNPS	1105	1554	1.21
841	746	THRNE	0001	1768	1.21
842	1454	RNDRK	1503	4566	1.21
843	1437	LKBRN	2401	706	1.21
844	2795	HMPHL	2742	470	1.20
845	2074	MRSDO	9611	1689	1.20
846	689	HNYGR	2401	460	1.20
847	521	WLSPT	1001	595	1.20
848	540	ATHNW	1403	2213	1.20
849	2694	FROKS	0001	1340	1.20
850	993	SWDTN	1621	756	1.19
851	568	PCUST	2005	1716	1.19
852	2014	MRVLY	2311	390	1.19
853	43	CLNSE	4201	923	1.19
854	1365	IRVVV	2802	1047	1.19
855	281	TMPTV	2402	3039	1.19
856	1528	BLTSW	3201	2566	1.19
857	808	ALLNC	6411	43	1.19
858	523	RCHHL	0311	964	1.18
859	2444	CRLTR	2001	2441	1.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
860	1615	ROWLT	1102	795	1.18
861	1131	CDHCR	2051	2101	1.18
862	1288	IRVGS	1904	958	1.18
863	1063	WFALS	0143	173	1.18
864	373	LEMON	0011	1347	1.18
865	2183	WNDWD	3611	1111	1.17
866	1015	SUNNY	2303	417	1.17
867	1582	TMPNW	1104	1946	1.17
868	844	CLLVL	0002	497	1.17
869	481	FERIS	1103	895	1.17
870	570	REGST	0003	945	1.17
871	1637	ELGIN	1003	1893	1.17
872	2335	ECTHM	3331	24	1.17
873	1845	ODESA	0272	1649	1.17
874	1140	BLVUE	1111	369	1.16
875	1240	BLTSW	3203	1232	1.16
876	N/A	MOSSW	4611	2591	1.16
877	2371	WBROK	3011	207	1.16
878	2317	PKRMX	4701	1738	1.16
879	2326	CNTRD	0001	2122	1.16
880	1957	MLFRD	2103	995	1.16
881	2789	FRMBR	1853	359	1.16
882	608	RYLTY	1411	127	1.16
883	172	CNANG	1806	2433	1.16
884	1885	TRLWD	7711	2598	1.16
885	1124	DCDAM	2003	1260	1.16
886	2358	KLNTF	1803	1054	1.16
887	1459	RYLTY	1431	71	1.15
888	527	RWALS	1851	1500	1.15
889	2327	GRAHM	0713	418	1.15
890	355	MKNGB	5321	561	1.15
891	1979	MDDTN	4321	926	1.15
892	902	CRWLY	7011	428	1.15
893	2352	ODESA	0231	2174	1.15
894	1718	CURIE	7231	1076	1.15
895	171	WLSPT	1002	1920	1.15
896	1496	DNISN	1205	1518	1.15
897	575	LFSTH	1406	2068	1.15
898	1256	HLSBR	1204	534	1.14
899	116	JUDCT	0001	1452	1.14
900	2726	MRSES	4012	395	1.14
901	303	KRUMS	1201	241	1.14
902	1293	LAVON	1453	641	1.14
903	1872	WFALS	0153	1147	1.14
904	239	RSNHT	1142	906	1.14
905	1142	FSTVW	0001	806	1.14
906	701	LVBRD	0004	1035	1.14
907	2583	HKBRY	1105	168	1.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
908	2207	MEXIA	4024	351	1.14
909	50	PGSTH	7031	139	1.14
910	66	ELMAR	3212	81	1.14
911	2656	EGFRD	0001	1761	1.14
912	656	CNEXP	0001	200	1.14
913	586	WESTS	1602	878	1.13
914	2193	LIGSW	1603	2496	1.13
915	2279	PRFTW	4222	3242	1.13
916	62	CNSES	0370	883	1.13
917	2798	ENTOH	0006	1600	1.13
918	931	PROAD	0003	1093	1.13
919	252	BEAST	4084	875	1.13
920	1717	LKHLA	0006	738	1.13
921	852	MSLSW	0003	188	1.13
922	863	TAYLR	1202	1508	1.13
923	2644	BKWST	0005	863	1.13
924	59	PLSTN	1001	1734	1.13
925	2201	LMESA	1512	1841	1.12
926	1589	MDTHN	1703	604	1.12
927	1008	CPRCV	1404	1594	1.12
928	1686	CNI45	1202	811	1.12
929	243	CHROW	0005	181	1.12
930	2385	PCOIT	1005	1096	1.12
931	468	IRVNR	1510	335	1.12
932	1876	CNTRY	2851	1438	1.12
933	N/A	MKNGB	5342	1262	1.12
934	118	MESTE	1204	1812	1.12
935	1771	STANT	1311	1474	1.12
936	1185	TYEST	1508	627	1.12
937	1036	WITTS	1703	1578	1.12
938	1071	MRTNS	1502	504	1.12
939	686	RRWES	1601	548	1.11
940	445	CHYNE	9121	87	1.11
941	1041	ELKTN	2501	1933	1.11
942	2320	LMESA	1531	637	1.11
943	2051	TERSO	2501	184	1.11
944	2418	LKHLA	0002	1455	1.11
945	549	HORNE	1992	211	1.11
946	1425	BNMNW	1101	197	1.11
947	1830	WSOTH	1018	1303	1.11
948	924	OTTOJ	3060	18	1.11
949	177	MDLNW	1582	1531	1.11
950	708	ARLNG	1251	534	1.11
951	2706	WMMMR	2708	245	1.11
952	646	CUMBY	1201	734	1.11
953	1481	STAUG	0006	1908	1.11
954	1053	PCUST	2011	2226	1.11
955	2869	JNKNS	0008	19	1.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
956	900	WMRNR	0001	171	1.11
957	1305	PFLGV	2001	5028	1.10
958	2420	DCATR	1204	641	1.10
959	1103	CHRNO	1203	421	1.10
960	1972	PRNTH	1406	1057	1.10
961	313	WESTS	1601	969	1.10
962	2857	ENSSE	3011	10	1.10
963	2892	RNKSW	5413	30	1.10
964	842	MESTE	1203	171	1.10
965	2096	MKNNY	1253	104	1.10
966	1661	FRNKF	0006	1717	1.10
967	2689	CLBWS	8112	254	1.09
968	1529	MKNGB	5331	1546	1.09
969	2391	BSPSW	0841	2104	1.09
970	372	EULTB	5711	1458	1.09
971	2527	IRVNR	1553	1326	1.09
972	2141	PFFRD	3492	297	1.09
973	1237	COLNY	2401	755	1.09
974	730	CNEXP	0007	455	1.09
975	2519	EMMAS	4021	59	1.08
976	2129	RSPCK	2131	59	1.08
977	2304	ANDNR	2242	2068	1.08
978	2274	RRSTH	1701	2809	1.08
979	1282	PREST	1604	1337	1.08
980	780	LKMNT	0004	2160	1.08
981	212	LOMAL	0011	1124	1.08
982	1033	PAYSW	1203	868	1.08
983	2535	GRFRD	1002	376	1.08
984	1672	HSKAV	0006	631	1.07
985	517	PCUST	2008	686	1.07
986	994	MESQN	1505	1407	1.07
987	1114	EMMAS	4011	73	1.07
988	1709	GORMN	0421	353	1.07
989	1297	FHLSW	1361	963	1.07
990	2613	MDWCK	0008	881	1.07
991	2642	SMFLD	2391	289	1.07
992	1246	CRTLD	4731	2903	1.07
993	1922	FRMBR	1805	754	1.06
994	1452	EZACH	0006	1094	1.06
995	1838	BRNWD	1204	1772	1.06
996	477	MKNSW	1601	1590	1.06
997	748	RWALE	3322	1839	1.06
998	1255	BDFRD	8812	763	1.06
999	47	MDAIR	2911	382	1.06
1000	1573	VGCRK	8021	209	1.06
1001	788	OKCLS	0001	698	1.06
1002	2639	ODESA	0221	283	1.06
1003	964	CRNRD	0005	231	1.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1004	950	CNEXP	0005	36	1.06
1005	107	MASON	3411	18	1.06
1006	1947	PALRD	2205	319	1.05
1007	2640	TRNTY	7551	1417	1.05
1008	743	CMTSW	0983	855	1.05
1009	2889	RECCR	0002	103	1.05
1010	2537	PRCRK	0001	189	1.05
1011	247	WELRD	0002	727	1.05
1012	2760	LVBRD	0005	1321	1.05
1013	1035	TSLVL	4008	1971	1.04
1014	837	WALST	0001	192	1.04
1015	2180	CLBRN	1201	1766	1.04
1016	312	LFEST	1902	1006	1.04
1017	489	ALPHA	0015	823	1.04
1018	316	DALWT	2992	330	1.04
1019	1415	VLYRN	2951	2203	1.04
1020	436	BLKST	1771	1233	1.04
1021	2293	BRCRK	6513	1152	1.04
1022	424	NCDCH	1206	1091	1.03
1023	1959	DALRK	1309	845	1.03
1024	2832	SANSM	3921	1290	1.03
1025	1567	HDWLK	3001	953	1.03
1026	715	SSPNG	1204	959	1.03
1027	2701	STERT	2701	32	1.03
1028	1090	MYPRL	1801	135	1.03
1029	504	TYSTH	1201	994	1.03
1030	2309	ELKTN	2503	833	1.03
1031	N/A	CRLFR	2159	1304	1.03
1032	1745	CRLJL	1505	919	1.03
1033	1955	PRSTN	0003	2959	1.02
1034	1638	PAYSW	1213	1398	1.02
1035	2771	FRMNT	0012	512	1.02
1036	2824	BKWST	0001	383	1.02
1037	2038	MNWLW	1402	1541	1.02
1038	1639	CPLSO	4322	256	1.02
1039	2755	CMPST	0003	210	1.02
1040	390	TYRSW	1703	1289	1.02
1041	2577	DLEON	0111	844	1.02
1042	242	GDPRW	9611	1220	1.01
1043	876	CHROW	0006	83	1.01
1044	899	STERT	2706	171	1.01
1045	796	TYOMN	1408	1334	1.01
1046	2234	MRTNS	1503	361	1.01
1047	310	MRTSP	1504	697	1.01
1048	1442	PRNTH	1401	1334	1.01
1049	2807	RECCR	0001	165	1.01
1050	2835	INAIR	1411	920	1.00
1051	644	ODESA	0251	1794	1.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1052	1286	DGNST	0003	26	1.00
1053	1269	HKBRY	1109	97	1.00
1054	976	LSCOL	2114	47	1.00
1055	2532	LSCOL	2142	12	1.00
1056	546	NWARD	3511	59	1.00
1057	1410	RGLRW	0006	34	1.00
1058	2191	BRTRD	7311	991	1.00
1059	2607	BRIRV	6922	3295	1.00
1060	859	IRVVV	2853	2821	1.00
1061	2629	EULES	8732	630	1.00
1062	430	KIMBL	5021	2346	1.00
1063	75	ALLEN	2402	3226	0.99
1064	3	MDAIR	2921	332	0.99
1065	954	CRLJL	1507	925	0.99
1066	2631	MSLSW	0008	172	0.99
1067	341	PTENN	2352	2128	0.99
1068	1721	GVFTW	1801	639	0.99
1069	1122	RCHRD	1204	1136	0.99
1070	1048	ALPHA	0005	133	0.98
1071	150	CDCRK	1201	1244	0.98
1072	1617	SGOVL	1401	1748	0.98
1073	929	IRVRS	4411	1056	0.98
1074	2217	TMPLE	1206	733	0.98
1075	855	WNDCR	0252	918	0.98
1076	879	TRNTH	1502	543	0.98
1077	2557	GRMES	0511	1195	0.98
1078	1083	IRVGS	1901	1374	0.98
1079	1284	WTAUG	4621	440	0.98
1080	1562	IRVNE	1309	1127	0.98
1081	665	WSTHL	3642	3706	0.97
1082	240	DALWT	2931	1540	0.97
1083	626	SYCRK	4512	3764	0.97
1084	2870	LOMAL	0004	135	0.97
1085	2448	BRGPR	1101	640	0.97
1086	2671	AMLIA	0008	139	0.96
1087	400	LUFKN	1205	1311	0.96
1088	1376	EDGCF	2223	3137	0.96
1089	2430	WALST	0007	26	0.96
1090	873	DAVST	0004	1711	0.96
1091	206	FLMSO	3711	2409	0.96
1092	1171	BONHM	1204	827	0.96
1093	847	DCATR	1201	1242	0.96
1094	1969	KLNCC	1703	3289	0.96
1095	1144	DCVSO	1101	1467	0.96
1096	273	TYLNE	1624	253	0.96
1097	2715	RECCR	0003	205	0.96
1098	1844	MNWLL	1204	283	0.95
1099	2328	CRNSO	3913	1504	0.95

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1100	105	CLBNR	1407	261	0.95
1101	1222	EZACH	0002	1412	0.94
1102	382	WXHCH	1202	1708	0.94
1103	2668	WALST	0012	352	0.94
1104	1462	SMFLD	2381	843	0.94
1105	182	MSLMN	4131	122	0.93
1106	1032	PCOMM	3313	468	0.93
1107	830	TYWST	2003	1514	0.93
1108	153	NCSFA	1704	1429	0.93
1109	1060	WMRLD	0004	1561	0.93
1110	2042	CRTLD	4714	2307	0.92
1111	1835	TMNTH	1602	498	0.92
1112	1104	COLNY	2403	2446	0.92
1113	2623	ATNRN	3411	3003	0.92
1114	1476	MDWPK	9221	741	0.92
1115	1102	WEAST	0626	251	0.92
1116	1905	TYWST	2004	1010	0.92
1117	949	PLSTH	1304	1293	0.92
1118	2703	WALNT	0002	1206	0.92
1119	285	MABNK	2404	2496	0.91
1120	1605	PLGRV	0003	592	0.91
1121	1154	SHSTH	1305	450	0.91
1122	441	ROANW	9511	1210	0.91
1123	299	PFFRD	3462	1710	0.91
1124	291	OVRTN	4037	121	0.91
1125	1503	WEBBS	8614	2424	0.91
1126	1042	MESQN	1504	1152	0.91
1127	903	MDWCK	0004	1748	0.91
1128	1434	HSKAV	0007	1864	0.91
1129	616	LUFKN	1201	1322	0.90
1130	627	HUDSN	1603	1723	0.90
1131	55	CDCSW	0003	685	0.90
1132	1618	IRVBL	2505	494	0.90
1133	179	FORSN	5611	10	0.90
1134	56	VANSB	1502	1666	0.90
1135	1683	ECTHM	3321	2621	0.90
1136	2170	ROLTR	2922	2390	0.90
1137	422	ENSSO	2001	222	0.90
1138	2742	FSCRK	6713	2066	0.90
1139	1533	PFLGV	2007	2818	0.89
1140	1907	NYLDV	1202	130	0.89
1141	2815	FRMNT	0007	607	0.89
1142	175	FLINT	3212	2745	0.89
1143	2648	GVFTW	1802	853	0.89
1144	812	FINKS	1801	1547	0.89
1145	1096	HMTRD	0001	963	0.88
1146	338	LRENA	2901	982	0.88
1147	92	TYEST	1501	1706	0.88

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1148	625	FKLCY	5121	105	0.88
1149	1463	MSHLN	0008	683	0.88
1150	933	EGFRD	0005	609	0.88
1151	1652	GAVSW	0008	104	0.88
1152	1055	WWDWY	2024	1413	0.87
1153	2202	HKHTS	1606	1711	0.87
1154	756	CDHIL	1801	1010	0.87
1155	364	RSNHT	1162	1471	0.87
1156	576	RWDHV	1905	1212	0.87
1157	1077	FSCRK	6721	3604	0.87
1158	1600	ANDNR	2222	110	0.86
1159	466	DCVSO	1107	1089	0.86
1160	1695	STAUG	0008	2021	0.86
1161	985	CLBWS	8121	1388	0.86
1162	2514	STHRL	0007	243	0.86
1163	1421	MAYFD	5511	4118	0.86
1164	330	JKSNR	4105	319	0.86
1165	1133	FLRTN	3711	106	0.86
1166	217	BNBOR	1201	727	0.86
1167	253	JKSBR	1401	967	0.85
1168	1549	PFFRD	3482	1095	0.85
1169	2258	PCOIT	1002	671	0.85
1170	346	PREST	1602	1365	0.85
1171	2265	KLELM	2202	1895	0.85
1172	1347	BLMED	1619	1022	0.84
1173	997	CLBSN	8821	51	0.84
1174	1130	SHRSW	6611	1237	0.84
1175	451	TYOMN	1401	1544	0.84
1176	702	TYEST	1503	1063	0.84
1177	1310	AZLES	2121	2684	0.84
1178	412	RBNSN	2501	1948	0.84
1179	1931	PLANO	1103	1574	0.84
1180	1832	DUVAL	0462	1005	0.84
1181	132	BOWEN	3171	1712	0.83
1182	1544	DALRK	1307	1128	0.83
1183	487	SSPNE	1403	1078	0.83
1184	895	MSTLT	1073	202	0.83
1185	1110	CDHIL	1803	1777	0.83
1186	908	PPARK	1808	582	0.83
1187	552	FINKS	1802	719	0.83
1188	1105	BLKST	1762	1030	0.83
1189	1894	SNYDR	1833	1445	0.83
1190	1407	BRNAV	0711	1600	0.83
1191	N/A	NPKWY	0010	3022	0.82
1192	187	FLMSO	3716	2066	0.82
1193	1329	NCNTH	1801	2502	0.82
1194	490	GAVSW	0010	479	0.82
1195	1373	KLRPR	9021	1988	0.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1196	265	LFEST	1904	1310	0.82
1197	1152	ODESA	0242	622	0.82
1198	139	TMPLE	1203	1473	0.82
1199	2231	WSTHL	3621	4717	0.81
1200	2321	ITSCA	1702	204	0.81
1201	1850	CPRCV	1405	1501	0.81
1202	1627	NHNSW	0008	573	0.81
1203	1455	PAYSW	1202	1642	0.81
1204	151	MEXIA	4008	709	0.81
1205	2341	COPER	0402	170	0.81
1206	2843	CHICC	1701	53	0.81
1207	1980	ATHNW	1404	1623	0.81
1208	1227	MESTE	1201	21	0.81
1209	848	WNTHW	1120	1012	0.81
1210	2135	FRMBG	1707	427	0.81
1211	1842	BRNAV	0762	2368	0.81
1212	349	RCHHL	0321	1691	0.80
1213	234	BRNAV	0741	2023	0.80
1214	156	DALLW	0004	821	0.80
1215	226	MDLNW	1541	2258	0.80
1216	1289	HKHTS	1602	1011	0.80
1217	1386	FSCRK	6712	3292	0.80
1218	2218	BRYAN	0005	3261	0.80
1219	1241	WTAUG	4631	1127	0.80
1220	1520	FRMBR	1804	293	0.79
1221	1198	SMPST	0001	2287	0.79
1222	612	BRKTN	1201	490	0.79
1223	555	LTLRV	1701	1063	0.79
1224	254	GRMES	0521	536	0.79
1225	1292	TYWST	2013	1548	0.79
1226	1604	FHLSW	1311	1306	0.79
1227	1699	MNFLD	2621	2239	0.79
1228	345	CGDEL	5411	32	0.78
1229	1484	TATSP	4313	1606	0.78
1230	1093	TYLGE	1306	2207	0.78
1231	1445	CRLTN	1405	1245	0.78
1232	491	GRPVN	8222	707	0.78
1233	1588	TROYS	1014	1214	0.77
1234	974	MDWCK	0007	1082	0.77
1235	1474	ODNTH	2013	1629	0.77
1236	922	MAREA	1201	143	0.77
1237	1116	SHDYG	7842	664	0.77
1238	1173	CRLJL	1504	1291	0.77
1239	1277	DENAV	0662	585	0.77
1240	1998	ELCTR	1221	129	0.77
1241	1249	JKSBR	1402	1209	0.77
1242	596	JKSNR	4109	660	0.77
1243	2028	HORNE	1921	851	0.76

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1244	358	RSKMN	3053	497	0.76
1245	501	AYERS	4411	1169	0.76
1246	2363	SALSW	3004	1276	0.76
1247	1303	TMSTH	1402	1655	0.76
1248	2818	FRMNT	0003	464	0.76
1249	417	CAMRN	1202	1478	0.76
1250	1318	TAYLR	1204	1982	0.76
1251	161	OKCLS	0006	1660	0.76
1252	216	TNPON	0001	66	0.76
1253	366	IRVBL	2503	1394	0.76
1254	682	RWDHV	1907	851	0.75
1255	2494	ROLTR	2912	3839	0.75
1256	2546	ARMST	0001	271	0.75
1257	1045	CRTLD	4742	913	0.75
1258	2299	CMTSW	0941	1032	0.75
1259	1808	GAVSW	0005	1335	0.75
1260	334	FLMSO	3712	808	0.75
1261	238	FLINT	3211	2076	0.75
1262	2333	TMPSE	1503	626	0.75
1263	2027	CMPWI	0001	1808	0.75
1264	888	BRLSN	2051	1513	0.74
1265	331	GRDPR	0862	1015	0.74
1266	435	WDGWD	1531	1492	0.74
1267	484	CLBRN	1203	1450	0.74
1268	2431	CLLVL	0006	1047	0.74
1269	728	EUSTC	2401	1671	0.74
1270	1394	PFLGV	2004	3757	0.74
1271	1553	ROWLT	1107	365	0.74
1272	1034	WTAUG	4613	1806	0.74
1273	1412	HURST	1872	2235	0.74
1274	1466	CHNDL	1201	1932	0.73
1275	377	CNTRY	2842	1130	0.73
1276	169	EDGWD	1102	934	0.73
1277	33	GRPVN	8231	377	0.73
1278	460	INAIR	1423	201	0.73
1279	2578	NPKWY	0011	4175	0.73
1280	189	EULTB	5721	1750	0.73
1281	2291	ARLNG	1261	1389	0.73
1282	387	BDFRD	8832	954	0.73
1283	1320	GRDPR	0852	1414	0.72
1284	2081	IRVGS	1908	942	0.72
1285	1579	GRSMN	4028	704	0.72
1286	1723	ENNIS	1906	1984	0.72
1287	648	ELKHR	1201	954	0.72
1288	767	DLEON	0131	728	0.72
1289	1993	KFMNW	1202	854	0.72
1290	1306	BLKST	1711	1908	0.72
1291	1169	HSKAV	0003	1352	0.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1292	1334	KLNCC	1701	2241	0.71
1293	1485	TYOMN	1402	1615	0.71
1294	2858	EXPKY	8112	14	0.71
1295	1387	FRMBR	1801	1250	0.71
1296	471	MMLMN	4007	132	0.71
1297	149	NECSP	2401	537	0.71
1298	1107	ARCTY	1311	426	0.71
1299	1016	IRVNE	1310	1565	0.71
1300	115	TYBLR	2808	944	0.71
1301	1575	CANTN	1302	1385	0.71
1302	1391	GAVSW	0012	864	0.70
1303	865	NPKWY	0012	2231	0.70
1304	1586	CDHCR	2050	809	0.70
1305	1009	CLBRN	1206	1427	0.70
1306	1737	IRVGS	1905	752	0.70
1307	20	JKWST	4033	738	0.70
1308	1180	FRMBG	1702	60	0.70
1309	1029	BDFRD	8822	1053	0.70
1310	561	DALWT	2991	1225	0.70
1311	2003	TYBLR	2802	994	0.70
1312	1192	CLBRN	1204	1096	0.70
1313	N/A	ODESW	5922	2352	0.70
1314	1196	PLANO	1105	141	0.70
1315	2724	MKNNY	1204	36	0.69
1316	1545	GNSVE	1602	1710	0.69
1317	2469	RANGR	4321	867	0.69
1318	1803	MKNNY	1201	1337	0.69
1319	1782	MCKMY	0821	1584	0.69
1320	397	COLDG	4047	428	0.69
1321	2678	ATNRN	3421	588	0.69
1322	1220	TYLGE	1316	2657	0.69
1323	2737	TMNTH	1603	130	0.68
1324	1360	GAVSW	0002	1001	0.68
1325	2429	RGFTW	6813	19	0.68
1326	1626	WTAUG	4643	984	0.68
1327	992	WXHCH	1201	1619	0.68
1328	1433	GAVSW	0004	815	0.68
1329	1174	BRKNR	1211	113	0.68
1330	326	WATCO	2602	2143	0.68
1331	1233	LUFKN	1206	1192	0.68
1332	1349	SHAMP	0001	1350	0.68
1333	565	DAVIS	3713	845	0.68
1334	688	TRLSW	1202	59	0.68
1335	2442	PCOIT	1008	1243	0.68
1336	1566	RNDRK	1505	1165	0.68
1337	1399	WNDKR	0221	579	0.68
1338	414	LWSNR	2242	1178	0.67
1339	2790	IRVNE	1304	622	0.67

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1340	1001	KLNSO	4502	2552	0.67
1341	1064	BMTWN	1611	1825	0.67
1342	2048	DCATR	1203	858	0.67
1343	1085	CNSES	0750	1228	0.66
1344	122	ADMDS	6511	903	0.66
1345	1069	REAST	1509	125	0.66
1346	2058	PRKRW	3331	119	0.66
1347	162	WXHCH	1203	1239	0.66
1348	1833	LWRDR	0004	788	0.66
1349	1714	WCOLO	1318	1632	0.66
1350	2136	PRKRW	3352	1435	0.66
1351	1877	RCHRD	1203	836	0.66
1352	1189	RDRSE	2602	3128	0.66
1353	1492	DALRK	1305	1191	0.66
1354	2627	MAYFD	5521	3199	0.65
1355	1061	NCRST	2201	1934	0.65
1356	2055	WALNT	0001	1498	0.65
1357	1887	LMESA	2813	121	0.65
1358	897	ABRRD	0002	1357	0.65
1359	1616	DCVSO	1103	1819	0.65
1360	633	BDFWD	8921	704	0.65
1361	1755	WEBBS	8624	2187	0.65
1362	2188	EULSO	9132	1934	0.65
1363	2603	SMFLD	2313	2147	0.65
1364	1211	MESQW	1801	2108	0.65
1365	2360	ECTOR	1201	387	0.65
1366	405	TYLER	1012	1724	0.65
1367	2499	FHLSW	1332	298	0.64
1368	1026	BKBNT	1832	191	0.64
1369	462	MNWLL	1206	1142	0.64
1370	37	EZACH	0008	1507	0.64
1371	289	BSPRW	2521	1165	0.64
1372	1294	BDFRD	8841	815	0.64
1373	427	LUFKN	1203	759	0.64
1374	1740	PSHIL	1602	1030	0.64
1375	84	LFSTH	1407	1670	0.64
1376	1010	IRVBL	2507	798	0.64
1377	2093	TYEST	1509	375	0.64
1378	2873	MNWLL	1201	11	0.64
1379	1228	RRWES	1603	11	0.64
1380	987	CSHNG	1204	318	0.64
1381	2245	WNRTH	1419	302	0.63
1382	475	CNTRY	2823	1857	0.63
1383	2466	GAVSW	0006	524	0.63
1384	1324	MESQN	1501	1788	0.63
1385	810	RBNSN	2503	1092	0.63
1386	1175	PFFRD	3431	576	0.63
1387	1405	TYLER	1002	851	0.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1388	2277	LKTMS	2411	107	0.63
1389	547	BRIRV	6921	2382	0.63
1390	1536	CRNDL	2403	930	0.62
1391	93	NCDCH	1203	1798	0.62
1392	1578	PCUST	2009	2268	0.62
1393	1666	FORSW	2051	2766	0.62
1394	1359	MEXIA	4012	1142	0.62
1395	1738	MDLNW	1511	2413	0.62
1396	2078	MEANS	4421	60	0.62
1397	1431	RCHRD	1205	1037	0.61
1398	1920	TMSTH	1408	757	0.61
1399	823	BOWEN	3192	1248	0.61
1400	1929	WALST	0014	836	0.61
1401	505	PFFRD	3441	1182	0.61
1402	380	FINKS	1803	1300	0.61
1403	1352	DESHR	1201	960	0.61
1404	1183	WDGWD	1592	1160	0.61
1405	1739	WNDCR	0211	1220	0.61
1406	1047	TMPNW	1102	665	0.61
1407	352	HMPHL	2752	286	0.61
1408	872	IRVNE	1305	232	0.61
1409	2541	FARON	4031	1141	0.61
1410	1997	CRLTR	2003	1345	0.61
1411	1744	CRNTH	2401	2341	0.61
1412	307	RCHLD	2101	633	0.61
1413	1267	GLNHV	3911	1357	0.60
1414	1851	CRLTN	1401	804	0.60
1415	1951	WWEST	1219	929	0.60
1416	1168	TMPLE	1205	2463	0.60
1417	1230	AZLES	2122	2177	0.60
1418	1776	DALRK	1358	1811	0.60
1419	350	HSKAV	0002	1661	0.60
1420	2402	GNSVL	1204	505	0.60
1421	1383	HUDSN	1604	1688	0.60
1422	2152	RSPVY	1706	1335	0.60
1423	2477	CRSCN	1205	787	0.60
1424	1357	MKNGB	5312	376	0.60
1425	2357	FSHSW	2121	1697	0.60
1426	1368	LKMNT	0007	1543	0.59
1427	1810	WHITE	3521	1076	0.59
1428	164	CNANG	1804	192	0.59
1429	990	MNFLD	2682	2237	0.59
1430	344	SSPNE	1401	1222	0.59
1431	399	ALNSW	2651	1747	0.59
1432	2555	THRNE	0005	1313	0.59
1433	1477	PGSTH	7021	44	0.59
1434	235	EZACH	0003	1285	0.59
1435	237	HMPHL	2762	1120	0.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1436	1346	BRCRK	6523	868	0.59
1437	2465	BOWEN	3181	756	0.59
1438	204	GLNHV	3942	1457	0.59
1439	1018	GODRD	8142	1029	0.59
1440	1270	HKHTS	1601	1493	0.58
1441	2063	WRTHM	5012	320	0.58
1442	2324	CRLJL	1503	748	0.58
1443	1619	EULES	8711	2039	0.58
1444	1916	HRSMD	1957	2452	0.58
1445	1787	CLMET	0001	1562	0.58
1446	68	WRBND	2312	1454	0.58
1447	91	MDLNW	1594	1650	0.58
1448	2098	TYWST	2001	155	0.58
1449	1565	HORNE	1952	1008	0.58
1450	2820	MESFR	2105	1045	0.58
1451	2316	PRKWY	1552	533	0.58
1452	1023	IRVBL	2502	183	0.58
1453	367	RKDLE	1301	1200	0.58
1454	1719	PTENN	2358	1434	0.58
1455	1229	CRSWS	1402	928	0.58
1456	671	AZLES	2112	1540	0.58
1457	485	HLTOM	2452	1803	0.58
1458	2147	WSOTH	1017	1746	0.58
1459	1430	BLTLN	0007	773	0.57
1460	2280	PCUST	2012	1813	0.57
1461	1313	GRLND	1606	918	0.57
1462	1999	LWSNR	2241	1076	0.57
1463	1682	RCHRD	1206	671	0.57
1464	998	IRVGS	1906	729	0.57
1465	2294	DUVAL	0452	1850	0.57
1466	691	DUVAL	0414	615	0.57
1467	2618	VLYRN	2953	2823	0.57
1468	1111	CDHIL	1623	1966	0.57
1469	2189	BOWEN	3122	1270	0.57
1470	1539	REYST	4040	541	0.57
1471	2114	SWDTN	1631	1526	0.57
1472	276	OAKHL	3031	608	0.57
1473	2016	FROKS	0006	987	0.57
1474	2312	SBEND	0611	161	0.57
1475	2185	SPRTN	1801	1748	0.57
1476	2029	PRCTR	1601	200	0.57
1477	1870	MSHLN	0002	611	0.56
1478	130	ODESA	0212	799	0.56
1479	1680	DAVIS	3711	673	0.56
1480	1418	WSOTH	1020	1115	0.56
1481	392	HNTNG	1306	1059	0.56
1482	1135	BLTLN	0006	919	0.56
1483	1535	KMASB	1721	106	0.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1484	1783	HLSES	0553	1866	0.56
1485	1151	HUDSN	1602	1708	0.56
1486	862	WFALS	0193	2289	0.55
1487	1216	DCVSO	1104	1343	0.55
1488	1559	DALRK	1301	1237	0.55
1489	1395	PERIN	1511	638	0.55
1490	2037	BRNWD	1203	804	0.55
1491	2395	DNISN	1201	1424	0.55
1492	1176	PCUST	2007	1387	0.55
1493	2083	SHLMT	1802	527	0.55
1494	2209	ROBNW	1503	1608	0.55
1495	857	WALST	0013	340	0.55
1496	841	NCDSW	3811	1442	0.55
1497	146	CRSGL	1302	1452	0.55
1498	797	FRSTN	1602	1194	0.55
1499	1921	MESFR	2102	665	0.55
1500	696	CRANE	0331	1180	0.55
1501	447	BAKKE	6912	1652	0.55
1502	2636	MCDMT	2553	1196	0.55
1503	1900	TMSTH	1401	1813	0.54
1504	574	OKCLS	0004	1467	0.54
1505	1853	TMNTH	1605	1760	0.54
1506	1393	GRMES	0512	1195	0.54
1507	1826	CRTLD	4721	3026	0.54
1508	651	DNIWS	1603	1356	0.54
1509	1398	DNCNV	1905	1323	0.54
1510	971	MKNNY	1205	493	0.54
1511	1966	PNTGO	7112	735	0.54
1512	545	BOWIE	0621	13	0.54
1513	1655	LGVST	8521	1651	0.54
1514	1278	FHLSW	1351	1344	0.54
1515	542	HUDSN	1601	957	0.54
1516	1857	IRVNR	1507	1482	0.54
1517	2675	RRNES	2405	2054	0.54
1518	1059	TYWST	2012	1984	0.53
1519	752	BOWEN	3151	1913	0.53
1520	N/A	EDWDS	5911	32	0.53
1521	23	CRNDL	2401	516	0.53
1522	2408	KMPSO	2400	910	0.53
1523	1258	ADISN	1607	1248	0.53
1524	966	MESQT	1307	591	0.53
1525	1899	LVOAK	1602	882	0.53
1526	1309	KNEDL	6312	2983	0.53
1527	457	BOWEN	3161	1490	0.53
1528	1622	HSKAV	0005	1374	0.53
1529	959	EULES	8723	5154	0.53
1530	311	BONHM	1210	1166	0.53
1531	930	TATSP	4311	1861	0.53

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1532	1362	WXNTH	2302	1284	0.53
1533	2192	PEGAS	2321	122	0.52
1534	807	DCDAM	2002	808	0.52
1535	2486	RWALE	3321	1387	0.52
1536	601	BSPSW	0832	414	0.52
1537	814	CRANE	0321	23	0.52
1538	1516	EULSO	9112	721	0.52
1539	2007	WDGWD	1581	656	0.52
1540	668	COMRC	1202	48	0.52
1541	1692	GRHWY	5512	2533	0.52
1542	1402	SSPSW	1604	1141	0.52
1543	1710	ROWLT	1104	1001	0.52
1544	803	COLNY	2402	2401	0.52
1545	158	MDDTN	4311	209	0.52
1546	1700	SPRDL	4831	1257	0.51
1547	1367	CANTN	1301	2084	0.51
1548	1146	BLMED	1622	969	0.51
1549	2392	HNRTA	0311	1048	0.51
1550	1898	WWDWY	2022	1013	0.51
1551	2040	BRNWD	1201	1544	0.51
1552	12	TMPTV	2405	496	0.51
1553	602	STNVL	1206	2246	0.51
1554	2679	RANGR	4311	911	0.51
1555	2393	HKHTS	1607	937	0.51
1556	1128	WDGWD	1522	1440	0.51
1557	2106	CPRCV	1403	1414	0.51
1558	1868	WNDWD	3641	1486	0.51
1559	1338	PROAD	0009	109	0.50
1560	2031	IRVBL	2504	1580	0.50
1561	1148	BLMND	3231	1174	0.50
1562	2289	SMFLD	2311	1026	0.50
1563	2752	HUTCH	1502	185	0.50
1564	1547	BRNWD	1202	444	0.50
1565	2308	AMMFG	5611	803	0.50
1566	1897	RDLML	2521	1001	0.50
1567	2428	INAIR	1421	20	0.50
1568	1914	KNAPP	4021	38	0.50
1569	2699	SMBMG	1701	28	0.50
1570	2085	SMFLD	2362	60	0.50
1571	1300	WINKS	0531	78	0.50
1572	906	MRDCK	0004	816	0.50
1573	1295	MABNK	2402	946	0.50
1574	2506	HURST	1882	1883	0.50
1575	984	FSCRK	6711	3748	0.50
1576	1590	CMBTP	1201	254	0.50
1577	885	WHOUS	4121	1311	0.50
1578	1602	WNRTH	1417	1375	0.49
1579	1558	ROANW	9512	1904	0.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1580	1823	CDMIL	1201	587	0.49
1581	1658	TYSTH	1208	301	0.49
1582	1693	SHNRW	1614	853	0.49
1583	2457	BRKRG	0221	702	0.49
1584	1078	FRNKS	4168	961	0.49
1585	1569	PPARK	1804	249	0.49
1586	440	JDKNS	0821	35	0.49
1587	1382	MESQW	1804	1320	0.49
1588	2198	RDLML	2591	1354	0.49
1589	2047	LOMAL	0009	981	0.49
1590	579	CDHIL	1613	2712	0.48
1591	2199	WTAUG	4641	561	0.48
1592	1500	WMMMR	2707	1538	0.48
1593	2004	ARTHR	0422	1051	0.48
1594	1670	SMFLD	2333	1045	0.48
1595	1505	PRSTN	0005	1188	0.48
1596	1106	RSPVY	1704	1365	0.48
1597	138	IRVNG	1403	515	0.48
1598	2817	DGNST	0006	907	0.48
1599	1355	TLRWT	2201	1692	0.48
1600	824	IRVND	1201	962	0.48
1601	1863	CRNTH	2405	3767	0.48
1602	1806	ALNTH	2854	649	0.48
1603	443	MTLDA	0001	2523	0.48
1604	1290	BRLSN	2023	1808	0.48
1605	1480	HKBRY	1106	1643	0.48
1606	2709	BRCRK	6521	1427	0.48
1607	1428	EULES	8712	1052	0.48
1608	1499	SHSTH	1301	2174	0.48
1609	1798	HHSTH	1502	3380	0.47
1610	2263	WSANG	2801	1328	0.47
1611	1123	EULES	8722	2130	0.47
1612	1948	TYOMN	1405	1664	0.47
1613	1406	BRNSO	1808	764	0.47
1614	2414	EMPCT	0008	36	0.47
1615	2378	RBNSN	2504	1615	0.47
1616	871	AIRPK	8421	1086	0.47
1617	1938	DAVIS	3741	1280	0.47
1618	1483	DESPR	1403	1783	0.47
1619	2020	MLKF2	1202	461	0.47
1620	34	CRLTN	1402	509	0.47
1621	2533	TMSTH	1405	520	0.47
1622	1956	WALNT	0004	1464	0.47
1623	1648	DALRK	1303	1298	0.47
1624	2011	BRHLW	7612	694	0.47
1625	1644	KFMSO	1301	896	0.46
1626	65	NCWDN	1121	56	0.46
1627	764	BRCRK	6512	1766	0.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1628	1381	MURPH	2754	2038	0.46
1629	1923	WRBND	2311	1365	0.46
1630	2597	PRKRW	3362	1086	0.46
1631	2182	BLKST	1721	1009	0.46
1632	2849	CRLUD	1306	26	0.46
1633	619	PFLGV	2002	2126	0.46
1634	2043	PFFRD	3472	1273	0.46
1635	2200	MNWLE	1702	1251	0.46
1636	654	HURST	1861	1832	0.46
1637	1502	FORSW	2025	811	0.46
1638	434	DESPR	1406	942	0.46
1639	1724	ADMDS	6521	1564	0.46
1640	1677	LWSNR	2232	2384	0.46
1641	544	IRVGS	1907	790	0.46
1642	362	CDCSW	0001	262	0.46
1643	1158	WMRLD	0001	215	0.46
1644	2576	ARTHR	0452	687	0.46
1645	573	WNTHW	1121	747	0.46
1646	2330	DUVAL	0473	1555	0.45
1647	1522	GODRD	8171	840	0.45
1648	1369	CNTRY	2813	3045	0.45
1649	1082	PCUST	2006	1601	0.45
1650	641	CNTRY	2862	407	0.45
1651	166	LFSTH	1408	2117	0.45
1652	741	MNWLL	1202	706	0.45
1653	1051	COMRC	1201	1022	0.45
1654	799	RCHHL	0374	533	0.45
1655	2146	SWDTN	1641	1571	0.45
1656	1396	MEXIA	4011	1031	0.45
1657	785	WCOLO	1317	1256	0.45
1658	473	EDGCF	2262	833	0.45
1659	2602	WEAST	0616	568	0.45
1660	388	DWSON	3121	29	0.45
1661	1825	PCOIT	1006	1032	0.45
1662	1372	BRCRK	6543	1567	0.45
1663	757	SPRDL	4811	1125	0.45
1664	577	LOMAL	0012	663	0.45
1665	928	CRLCC	2703	635	0.45
1666	1696	BLKST	1752	1191	0.45
1667	1875	NMAIN	0272	444	0.44
1668	2452	WELRD	0006	737	0.44
1669	1624	OAKHL	3062	2144	0.44
1670	1910	MURPH	2751	2287	0.44
1671	1684	CPRCV	1402	1869	0.44
1672	2657	PRKRW	3341	509	0.44
1673	1697	RYSSW	2804	1832	0.44
1674	858	HRSMD	1905	2766	0.44
1675	2103	AMMFG	5631	1363	0.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1676	1163	WTHRE	2101	1223	0.44
1677	1073	SHNRW	1609	1518	0.44
1678	1789	TATSP	4312	2478	0.44
1679	228	LORAN	9711	387	0.44
1680	1729	MDLNW	1564	1274	0.44
1681	1698	TLRWT	2203	791	0.44
1682	2002	WELRD	0008	1122	0.44
1683	2686	SPRTN	1802	867	0.44
1684	1134	CLMET	0003	911	0.44
1685	1153	MESWE	3621	796	0.44
1686	2492	IRVGS	1903	862	0.44
1687	437	COPER	1202	985	0.43
1688	894	CDHCR	2053	274	0.43
1689	2099	BRGPR	1102	1316	0.43
1690	591	BRNSO	1807	545	0.43
1691	19	MKNNY	1252	2255	0.43
1692	2251	CLKVL	1203	617	0.43
1693	96	EDGCF	2241	916	0.43
1694	947	IRVNG	1406	1272	0.43
1695	1935	CNTRY	2811	2518	0.43
1696	1871	PCOIT	1001	1222	0.43
1697	1181	PNTGO	7121	1495	0.43
1698	2750	LUFKN	1207	49	0.43
1699	2589	BNMNV	1102	404	0.43
1700	1953	MCHSN	1201	236	0.43
1701	1137	CLMET	0004	1143	0.43
1702	801	BONHM	1202	732	0.43
1703	2314	PCOIT	1007	846	0.43
1704	1837	WSOTH	1021	2079	0.42
1705	1234	MRTSP	1502	477	0.42
1706	506	CMTSW	0934	1560	0.42
1707	630	EZACH	0004	1168	0.42
1708	1775	WNTHW	1116	652	0.42
1709	559	HUTCH	1501	901	0.42
1710	1606	PRFTW	4221	1365	0.42
1711	343	HKBRY	1107	385	0.42
1712	1328	VGCRK	8041	1041	0.42
1713	109	JKSNR	4111	433	0.42
1714	1687	DALLW	0003	619	0.42
1715	1840	HORNE	1913	1610	0.42
1716	1645	BBTWN	1504	2078	0.42
1717	1681	BDFRD	8842	1461	0.42
1718	2383	MESTE	1215	1504	0.42
1719	2447	ROSCO	2911	612	0.42
1720	1354	SHRSW	6621	1813	0.42
1721	482	TYBLR	2803	781	0.42
1722	1447	WTAUG	4623	726	0.42
1723	1660	WHTRK	0004	1162	0.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1724	560	MDDTN	4312	2202	0.42
1725	2566	CRLJL	1502	376	0.41
1726	991	CRLTR	2002	1467	0.41
1727	1743	CRLJL	1501	1461	0.41
1728	2682	WNRTH	1418	1752	0.41
1729	1742	CPRCV	1406	1622	0.41
1730	2487	SUNNY	2301	595	0.41
1731	1990	BRNSO	1806	1729	0.41
1732	1849	TAYLR	1203	1357	0.41
1733	2343	BSPRG	1902	2370	0.41
1734	1577	WMRLD	0008	1570	0.41
1735	2587	ZEPHR	2404	182	0.41
1736	1847	WNRTH	1420	1144	0.41
1737	1904	LAVON	1406	1385	0.41
1738	361	SANSM	3923	3418	0.41
1739	1149	PPARK	1805	987	0.41
1740	493	CDHCR	2052	1251	0.41
1741	1050	HLTOM	2482	1138	0.41
1742	717	THRNE	0003	1234	0.41
1743	1796	WTAUG	4611	1397	0.41
1744	1314	PRFTW	4211	3352	0.41
1745	1712	HLSES	0542	765	0.41
1746	835	KERNS	2402	383	0.41
1747	1800	OKLND	0002	1208	0.41
1748	2219	DESHR	1203	1334	0.41
1749	256	BSPSW	0812	834	0.41
1750	713	RCHRD	1201	1434	0.41
1751	N/A	CMTSW	0966	116	0.41
1752	2032	HUTTO	2711	3292	0.40
1753	2753	LENSW	0321	47	0.40
1754	2084	MSLSW	0001	1148	0.40
1755	2347	ESTLD	3621	1478	0.40
1756	1401	HKHTS	1605	1464	0.40
1757	1822	BLTLN	0002	879	0.40
1758	1852	MTLDA	0004	746	0.40
1759	1657	HORNE	1972	761	0.40
1760	2283	KLELM	2205	3083	0.40
1761	N/A	KEYSB	2621	10	0.40
1762	766	PWEST	1301	1236	0.40
1763	727	DALWT	2982	1017	0.40
1764	805	TATSP	4321	1448	0.40
1765	198	HLSES	0511	1651	0.40
1766	2579	DENAV	0621	1671	0.40
1767	1821	PPARK	1806	836	0.40
1768	2070	ARTHR	0481	1271	0.40
1769	1612	CLYVL	9311	1732	0.40
1770	2148	MDWPK	9241	1354	0.40
1771	2166	FARON	4052	1073	0.40

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1772	1166	EULSO	9122	1304	0.39
1773	165	OKLND	0004	1460	0.39
1774	1791	SALSW	3003	671	0.39
1775	1694	MCGHR	2003	1261	0.39
1776	2476	ARTHR	0462	206	0.39
1777	731	TRNTH	1501	1622	0.39
1778	953	FINKS	1804	2289	0.39
1779	1543	TYBLR	2806	215	0.39
1780	2570	IRVNE	1302	282	0.39
1781	614	DCVSO	1102	700	0.39
1782	1934	DNISN	1206	891	0.39
1783	2439	PWEST	1311	953	0.39
1784	51	WICKT	0411	214	0.39
1785	2417	CNEXP	0002	866	0.39
1786	2643	KLELM	2201	2379	0.39
1787	1504	CDHCR	2054	1388	0.39
1788	1141	RSPCK	2102	1583	0.39
1789	2162	RSPVY	1708	976	0.39
1790	1888	LAVON	1401	1757	0.38
1791	232	NCSTH	1505	13	0.38
1792	1702	BNBRK	4121	4792	0.38
1793	79	CRSGL	1301	86	0.38
1794	2505	MESQT	1305	1147	0.38
1795	1453	NCDSW	3813	386	0.38
1796	1214	LKMNT	0003	574	0.38
1797	395	IRVND	1205	222	0.38
1798	1631	LOMAL	0001	672	0.38
1799	709	CLBNR	1402	2415	0.38
1800	314	RWDHV	1901	908	0.38
1801	178	ENTOH	0005	1066	0.38
1802	2126	RCHRD	1207	1538	0.38
1803	1436	WWDWY	2015	1161	0.38
1804	1404	CNTRY	2822	2845	0.38
1805	1824	MDLNW	1513	2005	0.38
1806	1927	STAUG	0001	699	0.38
1807	511	PARIS	1203	947	0.38
1808	1188	EUSTC	2402	729	0.38
1809	973	CRSCN	1206	1553	0.38
1810	1839	TRNTH	1503	1747	0.38
1811	2633	ARMST	0010	876	0.37
1812	1903	PSHIL	1603	1527	0.37
1813	117	COYAN	6311	99	0.37
1814	845	FRMBR	1807	859	0.37
1815	1252	LOMAL	0015	174	0.37
1816	1986	MSLMN	4009	228	0.37
1817	508	HLTOM	2472	1792	0.37
1818	383	KRUMS	1202	644	0.37
1819	643	BDFRD	8831	878	0.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1820	937	REAST	1506	1207	0.37
1821	777	ALPHA	0002	1084	0.37
1822	1199	PPARK	1801	1283	0.37
1823	2475	BLTON	1803	434	0.37
1824	1540	RKDLN	1401	942	0.37
1825	564	MKNNY	1202	1888	0.37
1826	1741	WATCO	2603	2812	0.37
1827	968	RWALS	1853	2845	0.37
1828	1167	CRLTN	1407	1559	0.37
1829	1150	TSLVL	4002	2528	0.37
1830	294	FHLSW	1382	111	0.37
1831	1489	WHITE	3531	1887	0.37
1832	2046	RWALL	1204	1137	0.37
1833	106	RSNHT	1122	1971	0.37
1834	1388	BNDRA	0011	400	0.37
1835	615	MEXIA	4040	880	0.37
1836	2142	CMTSW	0973	1158	0.37
1837	2461	RRNES	2401	3515	0.37
1838	1065	LOMAL	0003	1113	0.37
1839	112	DALLW	0006	1926	0.37
1840	154	CMPWI	0003	1247	0.37
1841	2297	MESFR	2103	363	0.37
1842	1319	KMASB	1711	303	0.37
1843	183	ATHNW	1402	478	0.37
1844	1210	BRLSN	2062	2869	0.36
1845	2169	ENTOH	0003	11	0.36
1846	1389	CPRCV	1401	1825	0.36
1847	645	ARMST	0009	1045	0.36
1848	1688	LKHLN	0001	1658	0.36
1849	386	WHITE	3512	1498	0.36
1850	203	PLGRV	0001	1188	0.36
1851	2168	PKRVL	1053	1018	0.36
1852	677	MRKLY	0811	120	0.36
1853	2484	VLYRN	2955	4491	0.36
1854	609	LNCST	1604	633	0.36
1855	2517	LOMAL	0010	1572	0.35
1856	1488	ORANS	1501	830	0.35
1857	2523	BRHLW	7622	1138	0.35
1858	1336	IRVNG	1407	1461	0.35
1859	745	BOWEN	3112	903	0.35
1860	2710	FRNKF	0004	996	0.35
1861	2664	MDWPK	9211	1229	0.35
1862	737	LMBLN	0001	2011	0.35
1863	271	REGST	0002	171	0.35
1864	1178	GRDPR	0891	879	0.35
1865	1665	EDGCF	2213	3089	0.35
1866	1444	ARTHR	0411	737	0.35
1867	1751	TYBLR	2805	2138	0.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1868	2875	NCRST	2202	26	0.35
1869	1217	AYERS	4421	1459	0.35
1870	483	CMPST	0004	1550	0.35
1871	446	NCRST	2204	437	0.35
1872	2290	TMPSE	1501	1500	0.35
1873	1756	EULSO	9141	58	0.34
1874	719	BARRY	1802	276	0.34
1875	1676	AZLES	2111	2984	0.34
1876	1119	CURIE	7211	516	0.34
1877	1995	INAIR	1414	767	0.34
1878	38	CLMET	0002	1387	0.34
1879	213	PLANO	1104	996	0.34
1880	496	RCHHL	0344	1210	0.34
1881	582	NCNTH	1808	760	0.34
1882	1889	WMRLD	0003	491	0.34
1883	569	SMFLD	2341	938	0.34
1884	211	CDCSW	0002	2336	0.34
1885	2132	WFALS	0133	1642	0.34
1886	2226	SPRDL	4821	1338	0.34
1887	952	TMPNW	1105	794	0.34
1888	2149	BRNAV	0723	1289	0.34
1889	1420	VLYRN	2954	2739	0.34
1890	610	RICES	0206	618	0.34
1891	2337	GLNHV	3931	1331	0.34
1892	2140	SPRDL	4841	941	0.34
1893	607	LOT69	3023	907	0.34
1894	1761	BMTWN	1621	1421	0.33
1895	1911	CANTN	1303	861	0.33
1896	2560	MRSES	3019	12	0.33
1897	2000	WSANG	2802	631	0.33
1898	2001	DESPR	1408	1884	0.33
1899	1996	RWDHV	1904	513	0.33
1900	556	CHSPG	2401	3348	0.33
1901	2788	WALST	0010	388	0.33
1902	2553	ENNIS	1901	364	0.33
1903	2367	PWEST	1307	953	0.33
1904	1070	EULES	8724	2292	0.33
1905	1895	PPARK	1807	887	0.33
1906	2092	RCHHL	0342	999	0.33
1907	2269	MDWPK	9231	2417	0.33
1908	1779	HHSTH	1504	2154	0.33
1909	1390	IOWPK	0831	1059	0.33
1910	1268	FSTVW	0002	150	0.33
1911	1713	TYBLR	2804	2430	0.33
1912	1621	SSPNG	1201	1291	0.33
1913	99	ATHNW	1401	892	0.33
1914	2249	WHTRK	0008	1509	0.32
1915	669	WHITE	3542	1629	0.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1916	2745	TMPNW	1106	497	0.32
1917	524	RDRSE	2601	1518	0.32
1918	2033	MESQW	1802	807	0.32
1919	981	MCKMY	0812	130	0.32
1920	2137	GPLND	1202	406	0.32
1921	650	ABRRD	0005	1083	0.32
1922	1280	DNCNV	1903	1197	0.32
1923	697	PCUST	2001	582	0.32
1924	1213	ARTHR	0441	1907	0.32
1925	N/A	WEAST	0619	1270	0.32
1926	509	ENTOH	0001	808	0.32
1927	351	MNHNS	1911	1353	0.32
1928	410	IRVVV	2801	2395	0.32
1929	1873	MDTHN	1701	1468	0.32
1930	1266	SGOVL	1402	937	0.32
1931	423	SGOVL	1404	2126	0.32
1932	2160	BRHLW	7621	2759	0.32
1933	1964	LKHLD	0007	1211	0.32
1934	2666	SCHRD	0004	1885	0.32
1935	2400	SHNRW	1612	818	0.32
1936	1323	CMNCH	1401	1128	0.32
1937	874	MLFRD	2101	899	0.32
1938	531	TYEST	1506	475	0.32
1939	262	WATSN	5352	1888	0.32
1940	2100	SSPNG	1203	1365	0.32
1941	2109	BLMED	1621	2017	0.31
1942	2113	WALST	0009	745	0.31
1943	1636	CHICG	1402	513	0.31
1944	1464	ODNTH	2044	2144	0.31
1945	2348	IVANS	1621	58	0.31
1946	1195	CRSWS	1401	1347	0.31
1947	655	HLSBR	1201	1659	0.31
1948	724	RCLNS	1404	291	0.31
1949	587	CRLFR	2155	1329	0.31
1950	1526	ARCTY	1321	890	0.31
1951	918	BLTON	1806	719	0.31
1952	1768	TMSTH	1404	1319	0.31
1953	790	COMSO	1401	619	0.31
1954	478	DESPR	1407	928	0.31
1955	2531	KRGRV	2401	13	0.31
1956	875	MESWE	3611	1690	0.31
1957	1291	ADISN	1601	631	0.31
1958	2697	MESTE	1213	851	0.31
1959	1848	BNDRA	0009	715	0.31
1960	219	LFSTH	1402	1186	0.31
1961	712	NHNSW	0004	556	0.31
1962	2354	MURPH	2755	2710	0.31
1963	2286	ALNTH	2844	1555	0.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
1964	2503	ALVRD	1504	154	0.31
1965	961	PRNTH	1404	1434	0.30
1966	1854	PCUST	2010	2249	0.30
1967	2006	GRLRD	0001	1768	0.30
1968	1403	LUFKN	1202	1080	0.30
1969	2005	BLMED	1620	1965	0.30
1970	1960	CRNTH	2404	2160	0.30
1971	1509	BLMGR	1902	185	0.30
1972	2580	GNSVL	1213	722	0.30
1973	393	RRSTH	1703	3332	0.30
1974	1574	AIRPK	8411	805	0.30
1975	1726	BRNSO	1805	805	0.30
1976	2069	DENAV	0642	912	0.30
1977	1780	MDLNW	1573	1053	0.30
1978	550	REAST	1505	996	0.30
1979	1994	PRKRW	3392	1627	0.30
1980	1909	IRVND	1204	1345	0.30
1981	147	BRNAV	0753	1306	0.30
1982	635	PFLGV	2003	2795	0.30
1983	398	ARLNG	1213	1315	0.30
1984	1472	MDLNW	1531	1371	0.30
1985	95	ELKTN	2508	1314	0.30
1986	628	IRVNG	1408	1056	0.30
1987	2350	ROWLT	1106	1305	0.30
1988	1754	STAUG	0002	1366	0.30
1989	295	BDFRD	8811	1683	0.30
1990	2717	PALRD	2204	680	0.30
1991	2246	RNDRK	1508	3981	0.30
1992	1784	IRVNG	1401	1559	0.30
1993	2061	BRLSN	2041	4722	0.30
1994	2155	SHNRW	1608	1414	0.29
1995	2124	LKBLT	2105	1870	0.29
1996	354	CDCSW	0005	1775	0.29
1997	356	CNEXP	0004	891	0.29
1998	2211	ARLNG	1241	629	0.29
1999	880	BRHLW	7631	708	0.29
2000	1471	PWEST	1308	602	0.29
2001	329	PTENN	2355	178	0.29
2002	2435	BRLSN	2013	1099	0.29
2003	828	RWALL	1202	2374	0.29
2004	738	BEAST	4088	120	0.29
2005	2572	GSTHW	1692	813	0.29
2006	2415	MESFR	2104	158	0.29
2007	1968	HMPHL	2743	739	0.29
2008	N/A	JDKNS	0822	55	0.29
2009	520	NCNTH	1802	1276	0.29
2010	2446	SWTWR	1321	131	0.29
2011	1508	ATHNS	1202	766	0.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
2012	1988	ROANW	9521	1436	0.29
2013	4	MCWHT	3511	2932	0.29
2014	1716	SHRSW	6612	1759	0.29
2015	2731	ALPHA	0001	424	0.29
2016	2698	EXPKY	8142	28	0.29
2017	2229	RSNHT	1181	1685	0.29
2018	1610	PLSTN	1005	1902	0.28
2019	1341	HNRTA	0321	853	0.28
2020	2118	BRCRK	6522	2202	0.28
2021	2305	MDLNE	0122	268	0.28
2022	999	WXNTH	2306	1959	0.28
2023	2608	WRBND	2322	866	0.28
2024	224	BLKST	1732	1252	0.28
2025	1970	MABNK	2401	2085	0.28
2026	1392	IRVHF	2302	1405	0.28
2027	494	PCOIT	1023	2253	0.28
2028	2077	GRAHM	0711	1652	0.28
2029	264	PCUST	2002	820	0.28
2030	1046	RWDHV	1903	1224	0.28
2031	1487	MURPH	2752	2130	0.28
2032	1925	RDOAK	1304	3161	0.28
2033	779	RTHGB	1411	2318	0.28
2034	1750	FRMBR	1803	2398	0.28
2035	2240	MNWLW	1401	1554	0.28
2036	1221	MDTHS	1003	1069	0.28
2037	818	OKCLS	0007	486	0.28
2038	1689	CLCRK	1011	191	0.28
2039	1538	WHITE	3541	947	0.28
2040	2571	IRVBL	2501	394	0.28
2041	1554	GRDPR	0831	1215	0.28
2042	604	PLKST	0005	1483	0.28
2043	1550	KNEDL	6321	2367	0.28
2044	1759	CRTLD	4711	3163	0.28
2045	1890	KNEDL	6342	2095	0.28
2046	2075	MAPLE	0006	1555	0.28
2047	2311	BSPRW	2511	759	0.28
2048	1869	CRLTR	2052	1569	0.28
2049	2518	PALRD	2208	1076	0.28
2050	1831	BSPRG	1903	1644	0.27
2051	2581	HHSTH	1503	1255	0.27
2052	384	LMESA	1561	1457	0.27
2053	2592	JNKNS	0003	1008	0.27
2054	2090	LWSNR	2231	785	0.27
2055	670	BSPRW	2552	910	0.27
2056	470	TXHRV	1611	158	0.27
2057	357	JUDCT	0002	1360	0.27
2058	1770	WXNTH	2303	1907	0.27
2059	286	CRNRD	0004	446	0.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
2060	2730	WRTHM	5004	222	0.27
2061	563	PARIS	1201	1174	0.27
2062	1254	TYWST	2002	63	0.27
2063	339	RWALS	1852	1927	0.27
2064	1224	PLKST	0007	2260	0.27
2065	1862	MESQT	1301	1431	0.27
2066	2271	PRKWY	1532	2091	0.27
2067	192	MESTE	1206	1275	0.27
2068	1311	BRCRK	6511	1224	0.27
2069	2411	HMPHL	2721	519	0.27
2070	747	WHTRK	0005	728	0.27
2071	195	LFEST	1901	1505	0.27
2072	1846	RWDHV	1906	636	0.27
2073	1766	SHMNE	1401	1192	0.27
2074	2056	RCLNS	1407	1378	0.26
2075	1984	CLYVL	9322	2138	0.26
2076	2594	ELZCK	4922	34	0.26
2077	2380	HUDSN	1605	136	0.26
2078	2480	BRNAV	0732	772	0.26
2079	723	NCSFA	1706	1129	0.26
2080	363	WNTHW	1118	1502	0.26
2081	1451	RSPCK	2108	946	0.26
2082	465	HURST	1811	1106	0.26
2083	2558	MURPH	2753	678	0.26
2084	2167	DAVIS	3721	1322	0.26
2085	2814	WALNT	0005	1003	0.26
2086	1343	MCKMY	0822	1484	0.26
2087	621	ENNIS	1902	1226	0.26
2088	2747	BLMND	3221	92	0.26
2089	1155	WINKS	0521	46	0.26
2090	1812	BLTON	1801	898	0.26
2091	230	RGLRW	0008	54	0.26
2092	2399	WHITE	3511	1358	0.26
2093	1630	DNISN	1204	1216	0.26
2094	1820	KNEDL	6311	2572	0.26
2095	2516	DGNST	0004	724	0.26
2096	594	DNISN	1202	786	0.26
2097	2458	EDGCF	2231	790	0.26
2098	396	RCHRD	1202	798	0.26
2099	2221	LOMAL	0013	1044	0.26
2100	2134	PARIS	1204	1146	0.26
2101	2088	SMFLD	2372	611	0.26
2102	1384	BRNSY	1221	78	0.26
2103	1772	CMNCH	1402	1158	0.26
2104	300	WDGWD	1512	831	0.26
2105	2891	RNDRK	1509	149	0.26
2106	1184	MDTHN	1702	1834	0.25
2107	2529	JUDCT	0004	220	0.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
2108	597	BRNWD	1206	1391	0.25
2109	502	MDWCK	0001	830	0.25
2110	197	PCOIT	1003	1511	0.25
2111	250	COPEL	3051	1575	0.25
2112	1337	WTAUG	4612	1230	0.25
2113	2804	ALPHA	0006	293	0.25
2114	269	WSOTH	1019	800	0.25
2115	2195	GRPVN	8223	2024	0.25
2116	2802	MCDMT	2554	1349	0.25
2117	360	CRLTR	2053	1743	0.25
2118	2772	FRMBG	1751	804	0.25
2119	657	WTHRF	2001	633	0.25
2120	402	JUDCT	0003	1741	0.25
2121	2015	SORCY	0004	591	0.25
2122	2145	SHRSW	6641	991	0.25
2123	379	GODRD	8131	1535	0.25
2124	2232	EDGCF	2211	2101	0.25
2125	1335	WELRD	0001	1213	0.25
2126	2214	GRDPR	0811	1197	0.25
2127	778	DESPR	1405	917	0.25
2128	2575	WEAST	0615	346	0.25
2129	229	WFALS	0184	1273	0.25
2130	1656	SMPST	0002	1392	0.25
2131	705	ESTLD	3611	1522	0.25
2132	288	FRMBG	1701	97	0.25
2133	672	HLTOM	2461	794	0.25
2134	1765	FHLSW	1342	1894	0.25
2135	558	BANGS	1201	1473	0.25
2136	2025	PRSTN	0004	670	0.25
2137	1736	DAVIS	3772	1734	0.25
2138	622	GLNHV	3963	1596	0.25
2139	2450	LOMAL	0008	463	0.25
2140	623	STNVL	1207	983	0.25
2141	1162	GRDPR	0892	1329	0.25
2142	2123	FRMBG	1708	45	0.24
2143	611	BNBRK	4111	2866	0.24
2144	868	BNBRK	4122	2316	0.24
2145	849	HUTTO	2721	3344	0.24
2146	2441	CLCTY	1031	1244	0.24
2147	406	SCURY	1921	103	0.24
2148	1678	CRLTR	2005	673	0.24
2149	742	RDRSE	2607	5064	0.24
2150	755	MSTLT	1063	961	0.24
2151	455	WTAUG	4652	785	0.24
2152	2342	ELMGV	3651	1947	0.24
2153	951	CNEXP	0006	1140	0.24
2154	962	RSPCK	2142	928	0.24
2155	535	PALRD	2206	1490	0.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIFI Ranking	2012 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIFI Value
2156	2434	PWEST	1303	925	0.24
2157	1468	CAMRN	1201	1013	0.24
2158	1679	WELRD	0003	516	0.24
2159	1774	NMAIN	0211	1913	0.24
2160	2388	ROWLT	1101	1256	0.24
2161	2355	CNTRD	0004	1109	0.24
2162	2502	CURIE	7222	392	0.24
2163	282	PLANO	1102	135	0.24
2164	887	LTVSB	5461	781	0.24
2165	2268	MKNSO	3613	3206	0.24
2166	836	LTVSB	5451	1204	0.24
2167	1734	ALNSW	2652	2611	0.24
2168	421	STHRL	0001	601	0.24
2169	1007	DAVIS	3743	483	0.24
2170	2766	SHAMP	0007	712	0.24
2171	2057	IRVND	1206	106	0.24
2172	1817	TYOMN	1411	272	0.24
2173	2212	ROWLT	1105	1068	0.24
2174	2485	SWTWR	1382	447	0.23
2175	391	WCOLO	1320	661	0.23
2176	319	RNDRK	1504	969	0.23
2177	1092	TRLWD	7721	1524	0.23
2178	826	ENTOH	0007	867	0.23
2179	1859	PRKWY	1561	1734	0.23
2180	170	MDLNE	0172	1253	0.23
2181	431	RCHHL	0384	704	0.23
2182	1662	ALVRD	1501	1170	0.23
2183	2691	WMMMR	2702	1421	0.23
2184	753	FSTVW	0005	1754	0.23
2185	1954	ELMGV	3653	1865	0.23
2186	419	CHYNE	9111	26	0.23
2187	199	DALWT	2962	468	0.23
2188	507	TYBLR	2801	1240	0.23
2189	1531	ARLNG	1271	2068	0.23
2190	2009	ARLNG	1212	132	0.23
2191	284	LNCST	1602	1787	0.23
2192	2574	LAVON	1404	951	0.23
2193	1664	HUBRD	1401	877	0.23
2194	1881	IRVNG	1402	1129	0.23
2195	2008	LGVST	8522	349	0.23
2196	2319	BNTDR	0004	1727	0.23
2197	522	ARLNG	1223	1796	0.23
2198	1374	CDHIL	1805	613	0.23
2199	2194	NLNVL	2001	361	0.22
2200	1551	SMFLD	2323	517	0.22
2201	2187	GAVSW	0001	1308	0.22
2202	2455	BLMED	1618	36	0.22
2203	739	IRVNR	1559	2612	0.22