

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1676	202	RRSTH	1702	3240	53.70
1677	528	COPEL	3052	1307	53.64
1678	998	FRMBG	1702	60	53.59
1679	2033	HURST	1882	1883	53.53
1680	1445	CAMRN	1201	1013	53.53
1681	1910	DAVST	0008	14	53.40
1682	269	PCUST	2002	820	53.29
1683	2030	HMPHL	2743	739	53.28
1684	1257	EDGCF	2213	3089	53.27
1685	1424	TSLVL	4002	2528	53.26
1686	2459	EULES	8732	630	53.26
1687	668	JUDCT	0003	1741	53.23
1688	2673	FROKS	0001	1340	53.22
1689	1821	MESQT	1303	825	53.20
1690	453	DCVSO	1102	700	53.12
1691	169	ARLNG	1213	1315	53.10
1692	892	SMPST	0002	1392	53.08
1693	2471	MSTLT	1011	65	53.08
1694	2480	BLMND	3282	82	53.00
1695	2298	TRSES	1202	497	52.95
1696	252	SANSM	3923	3418	52.84
1697	2401	SWDTN	1641	1571	52.76
1698	782	SHRSW	6622	1598	52.54
1699	1270	CRLJL	1507	925	52.53
1700	1060	ALNSW	2651	1747	52.46
1701	1012	RRSTH	1706	3316	52.44
1702	1907	MESQT	1302	659	52.43
1703	1154	TLRWT	2201	1692	52.42
1704	2685	WRTHM	5004	222	52.39
1705	2334	IRVBL	2501	394	52.27
1706	1833	GPLND	1202	406	52.26
1707	1008	PRKWY	1511	1289	52.24
1708	1357	EULSO	9112	721	52.22
1709	2006	MEXIA	4012	1142	52.13
1710	1195	GLNHV	3911	1357	52.13
1711	513	CRSGL	1301	86	52.11
1712	681	SMFLD	2341	938	52.11
1713	1378	EULES	8712	1052	52.08
1714	2267	LKBLT	2105	1870	52.04
1715	2548	WEBBS	8611	2596	52.03
1716	2385	MDWPK	9231	2417	52.03
1717	2775	LVBRD	0005	1321	51.88
1718	670	RSPCK	2108	946	51.72
1719	735	REYST	4051	1077	51.52
1720	796	MESTE	1206	1275	51.50
1721	2126	MDWPK	9241	1354	51.47
1722	1080	FINKS	1801	1547	51.46
1723	2634	PJPTR	3211	113	51.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1724	747	WNTHW	1121	747	51.42
1725	2273	MEXIA	3016	275	51.40
1726	2180	PALRD	2208	1076	51.39
1727	1977	HUTTO	2711	3292	51.31
1728	2230	MESQW	1802	807	51.29
1729	724	ELKTN	2501	1933	51.24
1730	814	GODRD	8142	1029	51.20
1731	227	KRUMS	1202	644	51.16
1732	2326	MEANS	4421	60	51.15
1733	807	MTLDA	0001	2523	51.12
1734	1160	AYERS	4421	1459	51.07
1735	876	COLDG	4047	428	51.01
1736	2387	SUNNY	2301	595	50.99
1737	1485	WATSN	5382	653	50.96
1738	2666	LKBLT	2107	1043	50.95
1739	1009	PCUST	2001	582	50.94
1740	2264	SPRDL	4841	941	50.93
1741	1286	BLTON	1806	719	50.93
1742	447	RWALS	1852	1927	50.86
1743	779	PCUST	2003	1025	50.81
1744	2310	CLKVL	1203	617	50.71
1745	2245	BRYAN	0002	214	50.69
1746	2196	FRNKF	0005	1659	50.69
1747	336	CDCSW	0005	1775	50.63
1748	769	HLTOM	2452	1803	50.61
1749	1927	SORCY	0004	591	50.61
1750	1164	MAYFD	5531	1107	50.57
1751	2582	RANGR	4321	867	50.54
1752	2787	FRNKF	0004	996	50.50
1753	570	TYEST	1506	475	50.46
1754	602	DESPR	1406	942	50.44
1755	1149	INAIR	1423	201	50.25
1756	785	LWRDR	0002	988	50.20
1757	1666	HKHTS	1604	850	50.14
1758	521	PCUST	2005	1716	50.13
1759	2404	HORNE	1942	1315	50.09
1760	2584	DENAV	0621	1671	49.92
1761	1527	LWSNR	2212	1355	49.85
1762	2294	BLTON	1801	898	49.76
1763	205	SCURY	1921	103	49.57
1764	1961	AMMFG	5611	803	49.53
1765	2695	GRLWS	1706	267	49.53
1766	2419	PWEST	1303	925	49.42
1767	585	PCOIT	1025	2897	49.36
1768	372	MNWLL	1206	1142	49.33
1769	795	PPARK	1805	987	49.31
1770	1552	BRLSN	2041	4722	49.14
1771	1241	HKHTS	1601	1493	49.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1772	964	TATSP	4321	1448	49.01
1773	2109	BRHLW	7631	708	49.01
1774	1024	BONHM	1202	732	48.99
1775	2734	FRMNT	0004	1781	48.93
1776	1902	BRGPR	1102	1316	48.90
1777	2423	MRTNS	1503	361	48.70
1778	1775	BLTON	1805	1524	48.68
1779	2586	KLNTF	1803	1054	48.67
1780	1110	CMTSW	0934	1560	48.66
1781	1251	RYSSW	2804	1832	48.65
1782	233	CRNRD	0004	446	48.56
1783	1564	PCOMM	3313	468	48.50
1784	1901	ROWLT	1105	1068	48.36
1785	1750	RCHHL	0374	533	48.25
1786	140	HUTCH	1501	901	48.22
1787	2351	WALST	0007	26	48.21
1788	2303	MSTLT	1042	496	48.17
1789	555	FRMBR	1807	859	48.16
1790	2225	GLNHV	3931	1331	48.10
1791	1637	BNDRA	0004	719	48.09
1792	2073	TMSTH	1401	1813	48.01
1793	1319	WTHRE	2101	1223	47.99
1794	1371	DAVST	0002	552	47.98
1795	2097	GRSMN	4028	704	47.91
1796	568	CMBTP	1201	254	47.91
1797	47	JDKNS	0821	35	47.90
1798	1520	BDFRD	8841	815	47.87
1799	1765	ALVRD	1501	1170	47.86
1800	376	PLSTH	1302	1007	47.86
1801	2665	ADISN	1608	372	47.67
1802	878	PLKST	0005	1483	47.66
1803	345	MDDTN	4311	209	47.65
1804	1221	WATSN	5352	1888	47.62
1805	177	CLMET	0002	1387	47.57
1806	809	FSCRK	6723	2846	47.51
1807	511	COPEL	3051	1575	47.47
1808	2248	PKRVL	1054	2345	47.45
1809	1369	DENAV	0662	585	47.33
1810	803	RENSW	3121	1940	47.24
1811	486	ARLNG	1232	1268	47.23
1812	1579	PAYSW	1202	1642	47.15
1813	208	TYBLR	2808	944	47.13
1814	822	WHOUS	4121	1311	47.13
1815	1895	CLYVL	9322	2138	47.08
1816	2315	MURPH	2755	2710	47.06
1817	2061	GNSVL	1203	1616	46.91
1818	978	MDTHN	1701	1468	46.83
1819	915	TYBLR	2801	1240	46.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1820	561	BDFRD	8831	878	46.58
1821	666	HLSBR	1201	1659	46.55
1822	1120	BNDRA	0009	715	46.42
1823	1826	SHNRW	1614	853	46.42
1824	1880	MDWCK	0005	1391	46.29
1825	1997	BRCRK	6533	1791	46.27
1826	1604	DAVIS	3731	765	46.15
1827	147	CNEXP	0004	891	46.15
1828	910	TMPNW	1105	794	46.11
1829	1566	HMPHL	2752	286	46.10
1830	1452	BRCRK	6511	1224	46.04
1831	2258	BSPRW	2511	759	46.04
1832	2435	WNRTH	1419	302	45.94
1833	1348	SHLMT	1802	527	45.94
1834	1295	CRNTH	2403	2438	45.84
1835	1178	CLYVL	9311	1732	45.83
1836	649	IRVVV	2853	2821	45.82
1837	504	ENTOH	0005	1066	45.74
1838	2147	PKRMX	4701	1738	45.73
1839	2197	SMFLD	2311	1026	45.71
1840	1380	WXNTH	2303	1907	45.69
1841	1403	MNWLL	1202	706	45.69
1842	841	HLTOM	2421	1631	45.62
1843	2494	GMINI	5812	764	45.58
1844	1184	MSLMN	4009	228	45.57
1845	2814	INAIR	1411	920	45.53
1846	1250	CRTLD	4742	913	45.36
1847	1545	NMAIN	0272	444	45.35
1848	1435	BRCRK	6543	1567	45.27
1849	454	HLSES	0511	1651	45.06
1850	2511	HMPHL	2721	519	45.02
1851	2044	TYBLR	2805	2138	44.97
1852	2288	PRFTW	4222	3242	44.94
1853	2610	SPRTN	1802	867	44.91
1854	1187	SPPSW	1604	1141	44.89
1855	1316	TATSP	4312	2478	44.88
1856	2544	BRKRG	0221	702	44.83
1857	2395	THRNE	0004	835	44.80
1858	2213	TMNTH	1602	498	44.74
1859	545	MKNSW	2603	1220	44.66
1860	948	WELRD	0001	1213	44.63
1861	465	PFLGV	2001	5028	44.58
1862	1121	MRTSP	1504	697	44.54
1863	2383	PCOIT	1007	846	44.53
1864	1965	KLNCC	1703	3289	44.45
1865	2271	WDGWD	1523	308	44.44
1866	2013	DGNST	0003	26	44.35
1867	184	PWEST	1308	602	44.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1868	1390	MKNSO	3611	776	44.25
1869	1650	MEXIA	4011	1031	44.24
1870	1837	BMTWN	1621	1421	44.18
1871	2129	PCUST	2010	2249	44.14
1872	2333	CRLJL	1508	338	43.94
1873	1491	GRHWY	5512	2533	43.92
1874	455	CDHIL	1613	2712	43.91
1875	1228	FSCRK	6712	3292	43.84
1876	853	PLKST	0007	2260	43.82
1877	983	FINKS	1802	719	43.72
1878	509	NHNSW	0004	556	43.62
1879	923	TYWST	2012	1984	43.60
1880	1069	LKHLD	0001	1658	43.59
1881	1056	WEAST	0618	706	43.55
1882	1510	IRVNG	1408	1056	43.43
1883	1652	PNTGO	7112	735	43.31
1884	1283	GSMTH	1742	37	43.22
1885	1516	ODNTH	2044	2144	43.16
1886	1713	PCOIT	1002	671	43.11
1887	1655	FARON	4052	1073	43.10
1888	1707	EULES	8731	1427	43.10
1889	2514	ROLTR	2912	3839	43.02
1890	121	ENNIS	1902	1226	42.98
1891	834	IRVNE	1305	232	42.88
1892	2027	FORSW	2053	3070	42.78
1893	1215	CNEXP	0006	1140	42.78
1894	1789	DENAV	0642	912	42.75
1895	1323	SHAMP	0005	1680	42.75
1896	199	CRLTN	1402	509	42.71
1897	373	PCOIT	1003	1511	42.70
1898	1896	WTAUG	4622	982	42.66
1899	1263	CANTN	1301	2084	42.65
1900	2223	RSPVY	1702	528	42.64
1901	2354	LOMAL	0016	644	42.63
1902	624	SGOVL	1404	2126	42.57
1903	2617	LOMAL	0010	1572	42.52
1904	2105	WWDWY	2022	1013	42.48
1905	148	IRVGS	1907	790	42.47
1906	2503	RNDRK	1508	3981	42.47
1907	94	ATHNW	1401	892	42.46
1908	1136	ALPHA	0013	452	42.29
1909	1887	MESQT	1301	1431	42.27
1910	671	BRNAV	0711	1600	42.06
1911	N/A	NPKWY	0010	3022	42.01
1912	1980	MDLNW	1513	2005	41.99
1913	1104	EULSO	9122	1304	41.96
1914	1825	CPRCV	1406	1622	41.89
1915	707	PRNTH	1404	1434	41.87

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1916	2178	WFALS	0133	1642	41.87
1917	1524	IRVNE	1309	1127	41.84
1918	1936	WNRTH	1421	1465	41.82
1919	1372	OKCLS	0001	698	41.72
1920	1993	RGFTW	6813	19	41.68
1921	294	IRVNG	1403	515	41.64
1922	330	RCLNS	1408	113	41.41
1923	1842	CRLTR	2007	1384	41.40
1924	1188	TRLWD	7711	2598	41.30
1925	1466	ELMGV	3653	1865	41.28
1926	1119	MRTSP	1502	477	41.27
1927	1679	PLANO	1105	141	41.26
1928	2525	LWRDR	0003	1692	41.17
1929	1856	DESPR	1408	1884	41.08
1930	2592	WHITE	3511	1358	40.95
1931	333	WGROB	8422	2514	40.92
1932	2281	WDGWD	1572	1466	40.77
1933	1276	BNDRA	0011	400	40.74
1934	927	LIGSW	1604	628	40.67
1935	1144	EULSO	9141	58	40.52
1936	211	DALWT	2982	1017	40.44
1937	2051	BNTDR	0004	1727	40.41
1938	2625	ELKTN	2503	833	40.39
1939	2238	HNYGR	2402	163	40.39
1940	1282	BNBRK	4121	4792	40.31
1941	N/A	WEAST	0619	1270	40.31
1942	1663	RGLRW	0006	34	40.27
1943	2564	ESTLD	3621	1478	40.22
1944	2623	KLNCC	1704	2174	40.20
1945	1352	KNEDL	6311	2572	40.12
1946	1223	SMFLD	2372	611	40.07
1947	945	WATSN	5331	1090	40.01
1948	1915	LKHLD	0006	738	39.98
1949	1647	PCOIT	1006	1032	39.94
1950	1893	CMNCH	1401	1128	39.91
1951	1495	FRMBR	1803	2398	39.90
1952	1020	IRVNG	1406	1272	39.85
1953	1354	BRYAN	0006	734	39.76
1954	2170	BLMND	3262	128	39.70
1955	2498	FRMBG	1708	45	39.69
1956	432	ARLNG	1223	1796	39.62
1957	861	CURIE	7211	516	39.58
1958	2551	SHNRW	1612	818	39.57
1959	181	RSNHT	1131	2714	39.52
1960	2302	NLNVL	2001	361	39.52
1961	2083	ROWLT	1106	1305	39.49
1962	355	FHLSW	1382	111	39.47
1963	2350	GNSVL	1213	722	39.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
1964	1641	TMSTH	1404	1319	39.46
1965	1124	FHLSW	1372	1310	39.40
1966	2412	KLELM	2205	3083	39.39
1967	1569	SGOVL	1402	937	39.23
1968	1984	WXHNW	2901	178	39.07
1969	1212	CRLTR	2005	673	39.03
1970	83	MCWHT	3511	2932	38.97
1971	1610	MESQT	1304	607	38.84
1972	2060	BOWEN	3112	903	38.78
1973	2022	MCGHR	2003	1261	38.72
1974	2819	FARON	4021	287	38.69
1975	2227	PRKRW	3331	119	38.64
1976	238	NCNTH	1808	760	38.64
1977	2427	PSHIL	1607	451	38.61
1978	1665	PLKST	0006	801	38.35
1979	972	WCOLO	1317	1256	38.26
1980	762	WHITE	3531	1887	38.09
1981	2522	CRLJL	1502	376	38.00
1982	2211	RWDHV	1906	636	37.99
1983	804	HLTOM	2461	794	37.96
1984	274	FINKS	1803	1300	37.94
1985	2891	RNDRK	1509	149	37.88
1986	1151	HUTTO	2721	3344	37.88
1987	2203	HKBRY	1109	97	37.82
1988	1246	VLYRN	2954	2739	37.80
1989	1897	BRIRV	6911	3247	37.79
1990	67	OKLND	0001	1113	37.77
1991	1792	IRVNG	1402	1129	37.60
1992	986	DNCNV	1903	1197	37.58
1993	1092	MDLNW	1573	1053	37.57
1994	691	ADISN	1601	631	37.57
1995	2432	CURIE	7222	392	37.56
1996	2158	RWALL	1204	1137	37.47
1997	2293	GAVSW	0008	104	37.41
1998	2005	SCHRD	0004	1885	37.37
1999	2811	HMPHL	2742	470	37.21
2000	1764	GODRD	8171	840	37.17
2001	536	PCUST	2011	2226	37.16
2002	1734	NPKWY	0005	840	37.13
2003	2705	BRNAV	0774	159	37.12
2004	1769	WWDWY	2015	1161	37.07
2005	3	CHYNE	9111	26	36.99
2006	1146	FHLSW	1342	1894	36.95
2007	2218	IRVND	1204	1345	36.94
2008	1093	RDRSE	2607	5064	36.90
2009	2543	WSANG	2801	1328	36.86
2010	2483	KLELM	2202	1895	36.68
2011	2646	WALNT	0002	1206	36.63

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2012	1492	MKNNY	1202	1888	36.61
2013	1029	CRLTN	1407	1559	36.61
2014	2080	AMMFG	5631	1363	36.59
2015	1047	BNBRK	4122	2316	36.57
2016	1153	IRVHF	2302	1405	36.47
2017	1506	FROKS	0004	117	36.41
2018	1592	MSLSW	0001	1148	36.40
2019	518	MURPH	2752	2130	36.17
2020	891	HNRTA	0321	853	36.16
2021	833	HLTOM	2472	1792	36.10
2022	2493	WNRTH	1416	726	36.10
2023	1532	CPRCV	1401	1825	36.03
2024	2456	ALNTH	2844	1555	35.85
2025	2643	BNMNW	1102	404	35.74
2026	495	BDFRD	8811	1683	35.66
2027	1397	ALVDO	1901	1396	35.66
2028	937	MTLDA	0002	1737	35.64
2029	2672	NHNSW	0001	456	35.62
2030	2311	PARIS	1204	1146	35.61
2031	198	CNEXP	0007	455	35.58
2032	263	MRKLY	0811	120	35.55
2033	1238	MSTLT	1021	1244	35.54
2034	2098	RTHGB	1411	2318	35.48
2035	2718	RANGR	4311	911	35.31
2036	2365	PPARK	1804	249	35.30
2037	1064	KEENE	1501	1538	35.29
2038	8	KERNS	2402	383	35.28
2039	1209	ATHNS	1201	960	35.22
2040	1131	SHNRW	1609	1518	35.19
2041	2653	GNSVL	1204	505	35.06
2042	1979	SPRDL	4821	1338	34.95
2043	1540	IOWPK	0831	1059	34.92
2044	1758	WHTRK	0008	1509	34.92
2045	1482	KFMSSO	1301	896	34.92
2046	1547	DNISN	1203	1647	34.88
2047	924	GODRD	8131	1535	34.86
2048	2740	MESTE	1213	851	34.84
2049	1722	IRVNG	1401	1559	34.81
2050	1005	WTAUG	4623	726	34.73
2051	2364	PCOIT	1005	1096	34.72
2052	1816	MESQW	1804	1320	34.63
2053	1779	GLNHV	3963	1596	34.63
2054	133	SPRDL	4811	1125	34.54
2055	1493	FSTVW	0002	150	34.48
2056	613	FROKS	0005	1402	34.45
2057	2016	MESFR	2104	158	34.38
2058	2779	MKNNY	1204	36	34.25
2059	640	PFLGV	2003	2795	34.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2060	907	LAVON	1402	64	34.20
2061	893	FORSW	2015	2102	34.19
2062	2535	BRLSN	2013	1099	34.17
2063	816	BRNAV	0753	1306	34.17
2064	2609	WFALS	0114	417	34.09
2065	1264	MDWCK	0001	830	34.07
2066	2308	WEBBS	8621	2665	34.00
2067	1011	COLNY	2406	753	33.94
2068	2440	SIKES	2421	1195	33.94
2069	2552	PALRD	2204	680	33.94
2070	2527	CLLVL	0006	1047	33.81
2071	544	MESWE	3611	1690	33.71
2072	2356	TMPSE	1501	1500	33.70
2073	258	STHRL	0001	601	33.63
2074	1925	MAPLE	0001	834	33.60
2075	1475	ARTHR	0441	1907	33.60
2076	558	DNISN	1202	786	33.57
2077	883	STNVL	1206	2246	33.51
2078	1451	GODRD	8122	1066	33.50
2079	1941	ROWLT	1101	1256	33.46
2080	1038	CDHCR	2051	2101	33.46
2081	881	SHRSW	6612	1759	33.43
2082	1401	HHSTH	1504	2154	33.37
2083	1868	AIRPK	8411	805	33.36
2084	1296	RCHHL	0344	1210	33.33
2085	821	RWALL	1202	2374	33.30
2086	2110	MABNK	2401	2085	33.27
2087	1384	PROAD	0004	988	33.24
2088	622	PRKRW	3311	1094	33.24
2089	247	ALPHA	0002	1084	33.16
2090	1478	ROWLT	1102	795	33.09
2091	590	PCOIT	1023	2253	32.91
2092	2239	GRLRD	0001	1768	32.91
2093	156	RNDRK	1504	969	32.87
2094	2378	LKHLD	0002	1455	32.86
2095	1127	CRLFR	2152	3343	32.79
2096	746	BSPSW	0812	834	32.70
2097	416	MDTHN	1702	1834	32.63
2098	1366	PRCRK	0003	1737	32.59
2099	2072	LMESA	1512	1841	32.59
2100	313	IRVHF	2305	1436	32.58
2101	2116	WNTHW	1116	652	32.54
2102	1917	LGVST	8522	349	32.53
2103	2014	GAVSW	0012	864	32.53
2104	1562	KNEDL	6342	2095	32.41
2105	810	HURST	1811	1106	32.39
2106	1308	RDRSE	2601	1518	32.38
2107	2546	CRSCN	1205	787	32.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2108	1068	LMESA	1522	1355	32.33
2109	2056	ALVDO	1902	882	32.33
2110	488	NCNTH	1802	1276	32.32
2111	1430	IRVNG	1405	1155	32.27
2112	1703	WELCH	4911	24	32.26
2113	2353	BRNWD	1201	1544	32.14
2114	1594	RKDLN	1401	942	32.09
2115	1780	MESQT	1306	969	32.04
2116	1591	BOWEN	3132	1772	32.03
2117	1919	TYSTH	1208	301	32.00
2118	2678	PALRD	2203	1090	31.99
2119	1391	WMRNR	0001	171	31.93
2120	2161	WMMMR	2707	1538	31.88
2121	660	DESPR	1401	1667	31.86
2122	1975	GAVSW	0004	815	31.64
2123	1818	RRWES	1603	11	31.64
2124	463	PFFRD	3421	849	31.60
2125	344	DAVIS	3733	482	31.57
2126	1033	ENTOH	0001	808	31.52
2127	611	GAVSW	0007	1523	31.50
2128	2408	ELMGV	3651	1947	31.48
2129	1798	HKBRY	1107	385	31.38
2130	928	ALPHA	0015	823	31.35
2131	1300	ALNSW	2652	2611	31.30
2132	1299	REAST	1505	996	31.26
2133	1810	PRCTR	1601	200	31.21
2134	2783	MCDMT	2553	1196	31.19
2135	2632	HHSTH	1503	1255	31.16
2136	969	PARIS	1201	1174	31.12
2137	1918	RNDRK	1501	803	31.12
2138	431	WXNTH	2305	951	31.06
2139	1528	DALRK	1354	1440	31.06
2140	2463	EMPCT	0008	36	31.06
2141	1182	DALWT	2921	285	31.05
2142	950	RCHRD	1201	1434	30.99
2143	482	RNDRK	1506	1653	30.96
2144	586	CRLFR	2153	58	30.96
2145	2286	BRYAN	0005	3261	30.95
2146	1609	BRNAV	0784	1881	30.95
2147	2035	HUDSN	1605	136	30.91
2148	2216	RCHRD	1207	1538	30.89
2149	980	BLKST	1732	1252	30.86
2150	550	MKNSW	2604	4147	30.80
2151	1836	CRNSO	3913	1504	30.78
2152	2316	ENNIS	1901	364	30.75
2153	1429	WELRD	0003	516	30.61
2154	1729	TYBLR	2806	215	30.56
2155	2476	BLMED	1620	1965	30.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2156	2300	BRHLW	7622	1138	30.41
2157	2519	SSPNG	1203	1365	30.39
2158	888	EULES	8723	5154	30.39
2159	2639	TRNTY	7551	1417	30.36
2160	1972	FORSW	2025	811	30.29
2161	837	LNCST	1602	1787	30.26
2162	1805	DAVIS	3772	1734	30.10
2163	1079	DAVIS	3782	978	30.08
2164	2229	GRPVN	8223	2024	30.04
2165	2122	SLAKE	8321	3656	29.89
2166	1797	SALSW	3003	671	29.88
2167	1848	IRVND	1206	106	29.81
2168	2403	WNDWD	3621	2311	29.75
2169	1085	MTLDA	0004	746	29.66
2170	1561	GODRD	8112	1424	29.66
2171	2139	WSANG	2802	631	29.56
2172	1674	WHTRK	0006	1257	29.50
2173	312	MDTHS	1003	1069	29.50
2174	783	LVBRD	0004	1035	29.49
2175	2507	ELZCK	4922	34	29.47
2176	845	LTVSB	5461	781	29.42
2177	1040	MDLNW	1521	1793	29.36
2178	254	BLVUE	1111	369	29.34
2179	2532	IRVNE	1302	282	29.34
2180	1519	MDLNE	0151	299	29.27
2181	283	DAVIS	3743	483	29.26
2182	855	BRNSO	1807	545	29.24
2183	1748	TRSES	1201	508	29.24
2184	2761	SORCY	0003	833	29.23
2185	1338	RWDHV	1904	513	29.21
2186	2425	GRPVN	8213	2155	29.16
2187	1058	WCOLO	1320	661	29.13
2188	1558	TRNTY	7521	1118	29.04
2189	2002	MRSDO	9621	1658	29.02
2190	411	GRPVN	8211	387	28.98
2191	1358	PALRD	2207	1099	28.98
2192	288	BNDRA	0001	832	28.97
2193	2215	CRSCN	1202	621	28.91
2194	2242	SWTWR	1321	131	28.86
2195	1301	NPKWY	0014	6086	28.85
2196	1694	MESTE	1209	1442	28.81
2197	1081	PLANO	1104	996	28.80
2198	2106	CRTLD	4724	3171	28.72
2199	1670	ATHNS	1202	766	28.57
2200	1499	LTVSB	5451	1204	28.56
2201	1985	SHNRW	1608	1414	28.48
2202	581	MSTLT	1063	961	28.45
2203	2047	ALPHA	0007	1442	28.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2204	1866	BRLSN	2062	2869	28.43
2205	176	FROKS	0003	632	28.42
2206	1590	CANTN	1303	861	28.41
2207	2345	DUVAL	0452	1850	28.38
2208	952	COLNY	2405	2324	28.38
2209	1931	COMSO	1401	619	28.35
2210	1018	WHITE	3541	947	28.26
2211	1284	CRSCN	1206	1553	28.16
2212	1089	FSTVW	0004	2206	28.13
2213	2335	MKNNY	1203	1059	28.12
2214	1438	WDGWD	1512	831	28.04
2215	1929	BRKRG	0242	23	27.99
2216	2593	DENDR	0009	59	27.88
2217	2810	IRLBJ	3222	580	27.87
2218	1724	CPLSO	4322	256	27.81
2219	705	CDCSW	0007	918	27.80
2220	2362	MTLDA	0006	1949	27.70
2221	2081	MESTE	1211	1184	27.63
2222	2025	GAVSW	0002	1001	27.60
2223	2069	PRSTN	0006	673	27.60
2224	1924	HLSES	0522	1644	27.59
2225	1413	COMRC	1201	1022	27.50
2226	2113	SHRSW	6641	991	27.36
2227	1715	HORNE	1961	1437	27.34
2228	543	KRGRV	2403	3401	27.32
2229	2659	HMPHL	2781	227	27.25
2230	108	WICKT	0431	16	27.24
2231	N/A	CMTSW	0966	116	27.22
2232	1761	LOT69	3023	907	27.21
2233	477	CDHIL	1805	613	27.17
2234	2768	CRLUD	1302	148	27.15
2235	1698	SSPNG	1201	1291	27.12
2236	1542	LFEST	1901	1505	27.01
2237	849	BNBRK	4111	2866	27.01
2238	2771	SHAMP	0007	712	26.99
2239	867	CRSWS	1401	1347	26.98
2240	685	NCSFA	1706	1129	26.94
2241	1022	SYCRK	4512	3764	26.85
2242	1066	DALWT	2962	468	26.83
2243	1693	DNISN	1204	1216	26.82
2244	1465	BRNAV	0762	2368	26.77
2245	774	WNTHW	1118	1502	26.64
2246	1211	PARIS	1203	947	26.57
2247	1255	CRLTR	2052	1569	26.54
2248	2730	WHITE	3532	1358	26.46
2249	1876	CHROW	0008	86	26.40
2250	812	LMBLN	0005	682	26.12
2251	1706	KLNSO	4501	3192	26.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2252	1162	TATSP	4322	2493	25.98
2253	2749	ALPHA	0001	424	25.92
2254	2202	BRNAV	0732	772	25.91
2255	2530	HOLDY	0911	1148	25.88
2256	2658	ZEPHR	2404	182	25.75
2257	933	ARCTY	1321	890	25.71
2258	2312	WTAUG	4633	1005	25.65
2259	2299	WTAUG	4642	1288	25.65
2260	727	BRGPR	1103	850	25.63
2261	2461	IRVNR	1552	64	25.60
2262	N/A	CMTSW	0927	547	25.60
2263	413	MRLNS	4003	961	25.59
2264	1573	RDOAK	1304	3161	25.52
2265	988	BARRY	1802	276	25.47
2266	126	NCDCH	1204	1255	25.44
2267	1346	MDLNE	0172	1253	25.42
2268	2566	HKHTS	1608	1290	25.42
2269	1237	ESKSW	2711	106	25.41
2270	1971	TAYLR	1203	1357	25.41
2271	2715	HURST	1852	1451	25.37
2272	2024	GAVSW	0001	1308	25.34
2273	1871	EDGCF	2211	2101	25.31
2274	2371	SHMNE	1407	779	25.22
2275	1043	RCHHL	0384	704	25.19
2276	2099	CMTSW	0973	1158	25.14
2277	2274	NCSFA	1702	1309	25.11
2278	2662	LKWOD	7442	703	25.08
2279	2189	BRNWD	1202	444	25.02
2280	827	GRDPR	0892	1329	24.90
2281	71	WTAUG	4652	785	24.88
2282	1252	WTAUG	4612	1230	24.76
2283	717	BLKST	1742	1668	24.73
2284	2251	PNTGO	7122	1093	24.70
2285	2619	ADISN	1603	193	24.68
2286	1326	PNTGO	7111	713	24.67
2287	2397	CRTLD	4722	3278	24.64
2288	352	BRHLW	7642	936	24.60
2289	1568	PRKRW	3372	1253	24.41
2290	2509	ARLNG	1212	132	24.30
2291	2296	BRNSO	1806	1729	24.19
2292	2266	BNDRA	0005	1197	24.18
2293	2028	CMNCH	1402	1158	24.05
2294	2235	PTENN	2354	2577	24.04
2295	2062	BRNSO	1808	764	23.99
2296	977	WELRD	0007	432	23.97
2297	2451	BKBNT	1842	519	23.95
2298	2465	KLNCC	1701	2241	23.72
2299	437	COMRC	1202	48	23.65

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2300	1028	MCDMT	2552	1993	23.63
2301	80	TNPON	0001	66	23.62
2302	2591	LAVON	1404	951	23.59
2303	2477	CRLTN	1404	99	23.45
2304	1464	DENAV	0683	866	23.44
2305	1113	RRNES	2402	3295	23.37
2306	879	SMFLD	2323	517	23.36
2307	1763	FROKS	0002	1307	23.35
2308	1636	BDFWD	8912	993	23.35
2309	530	RGLRW	0008	54	23.33
2310	179	PALRD	2206	1490	23.33
2311	2039	HLTOM	2411	1421	23.31
2312	2667	BDFWD	8932	1680	23.27
2313	207	ALLEN	2404	2040	23.25
2314	281	AMMFG	5621	552	23.24
2315	997	MNFLD	2611	1766	23.15
2316	2032	FRMNT	0009	1787	23.03
2317	2580	DGNST	0004	724	23.02
2318	1969	CLCRK	1011	191	22.96
2319	1757	NMAIN	0211	1913	22.94
2320	267	CNTRY	2814	923	22.91
2321	2426	FSCRK	6724	4453	22.90
2322	1817	GRDPR	0811	1197	22.87
2323	510	ELZCK	4921	1564	22.84
2324	79	SHDYG	7841	344	22.69
2325	2687	NPKWY	0011	4175	22.65
2326	2629	GAVSW	0006	524	22.62
2327	406	WINKS	0511	546	22.58
2328	2137	PWEST	1307	953	22.55
2329	2875	NCRST	2202	26	22.51
2330	650	VLYRN	2952	3415	22.48
2331	569	RCHRD	1202	798	22.47
2332	966	NPKWY	0012	2231	22.46
2333	1888	MDLNW	1531	1371	22.45
2334	2765	CMPST	0003	210	22.45
2335	1294	BNDRA	0002	536	22.44
2336	1281	PLSTN	1005	1902	22.43
2337	1229	BANGS	1201	1473	22.41
2338	2402	BDFWD	8941	1213	22.37
2339	2803	WALNT	0005	1003	22.33
2340	2766	CDHCR	2055	1273	22.30
2341	2553	MKNNY	1253	104	22.18
2342	2318	IVANS	1621	58	22.17
2343	786	GODRD	8161	2222	22.02
2344	2276	RDRSE	2603	3667	22.00
2345	956	SPRDL	4822	1327	21.84
2346	1906	TMPLE	1202	1385	21.83
2347	445	DESPR	1405	917	21.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2348	1169	ROGRS	1301	777	21.75
2349	2485	BSPRG	1904	1647	21.66
2350	2581	MNWLW	1401	1554	21.66
2351	98	ATHNW	1402	478	21.57
2352	766	WFALS	0184	1273	21.53
2353	2065	LGVST	8511	752	21.44
2354	1274	DAVIS	3723	347	21.39
2355	2207	MDLNE	0122	268	21.36
2356	1709	LKMNT	0008	989	21.34
2357	2381	TMPNW	1101	2485	21.34
2358	2434	LVBRD	0001	38	21.32
2359	2048	VLYRN	2957	501	21.32
2360	1034	MSHLN	0005	1591	21.25
2361	2558	FROKS	0007	1458	21.23
2362	2156	WSOTH	1021	2079	21.16
2363	2250	LOMAL	0006	1421	21.12
2364	2114	MKNSO	3613	3206	21.07
2365	1367	OAKHL	3011	2055	21.03
2366	1530	SHMNE	1401	1192	21.02
2367	2107	LKWOD	7432	1597	21.01
2368	337	GRDPR	0822	621	20.98
2369	2589	CNTRD	0003	1331	20.97
2370	1549	RSPCK	2142	928	20.86
2371	1449	ENNIS	1905	43	20.79
2372	2699	CRLTR	2051	3928	20.78
2373	1304	ENTOH	0007	867	20.73
2374	120	KNLTR	0001	2111	20.72
2375	1954	SYCRK	4521	3774	20.69
2376	1444	THRNE	0002	1409	20.64
2377	1010	FARON	4011	636	20.63
2378	183	ROWLT	1103	1078	20.60
2379	328	AIRPK	8421	1086	20.56
2380	854	ALPHA	0016	1798	20.56
2381	643	JUDCT	0002	1360	20.55
2382	1822	RWDHV	1903	1224	20.51
2383	2684	ADISN	1604	1147	20.47
2384	2508	FRNKF	0003	497	20.46
2385	2181	RRNES	2401	3515	20.44
2386	1701	LOMAL	0015	174	20.28
2387	2055	PRKWY	1561	1734	20.26
2388	2420	RSPCK	2106	349	20.24
2389	2325	CRSCN	1201	813	20.23
2390	2457	BLMED	1621	2017	20.19
2391	323	OKCLS	0008	1513	20.19
2392	1048	LMBLN	0001	2011	20.18
2393	2624	TYLER	1010	54	20.10
2394	1809	HUBRD	1401	877	20.05
2395	1861	CRNTH	2406	1217	20.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2396	2372	PRKWY	1532	2091	19.99
2397	2399	BLMED	1618	36	19.98
2398	2786	TMPNW	1106	497	19.96
2399	2570	HNYGR	0402	450	19.96
2400	301	JKSES	3028	384	19.96
2401	2621	LNCST	1603	1484	19.87
2402	1742	PALRD	2201	788	19.65
2403	2487	LFKHL	2101	121	19.51
2404	2781	CRTLD	4712	1158	19.47
2405	793	PALMR	2202	991	19.47
2406	2295	PRFTW	4212	1986	19.45
2407	2547	WOVER	6122	374	19.44
2408	1409	LEMON	0009	1740	19.43
2409	2598	BNBRK	4112	2182	19.42
2410	2782	WALST	0010	388	19.41
2411	1571	GODLY	1601	609	19.41
2412	900	BLMND	3252	977	19.41
2413	918	PTENN	2355	178	19.40
2414	1161	CLYVL	9321	805	19.27
2415	1537	NLNVL	2003	647	19.13
2416	2124	VGCRK	8011	1516	19.02
2417	2301	HLTOM	2442	1080	18.99
2418	618	WATSN	5361	2495	18.88
2419	1518	PWEST	1302	337	18.87
2420	698	DNINR	1402	556	18.84
2421	1172	WHTRK	0005	728	18.78
2422	836	MTLDA	0007	1602	18.78
2423	2796	MCDMT	2554	1349	18.74
2424	1502	BDFWD	8931	1731	18.60
2425	818	FRMBG	1701	97	18.57
2426	1772	PCOIT	1004	734	18.41
2427	2557	INAIR	1432	2504	18.40
2428	218	WXOCF	1402	12	18.39
2429	2797	MESQN	1506	62	18.38
2430	1827	EDGCF	2272	1043	18.28
2431	1627	BDFWD	8922	2166	18.23
2432	1766	CLCTY	1021	696	18.22
2433	517	LMESA	2833	24	18.15
2434	1432	ABRRD	0001	994	18.15
2435	2554	STERT	2702	17	18.11
2436	2681	EDGCF	2231	790	18.11
2437	1457	CMPWI	0002	1569	18.09
2438	N/A	CMTSW	0987	388	17.98
2439	2708	WMMMR	2702	1421	17.95
2440	1998	LOMAL	0002	501	17.90
2441	2795	LOMAL	0014	586	17.90
2442	2398	GRAHM	0711	1652	17.75
2443	2204	SHMNE	1405	780	17.61

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2444	913	ARLNG	1251	534	17.59
2445	1360	HUBRD	1402	990	17.53
2446	2793	FRMNT	0003	464	17.47
2447	2850	DENAV	0673	57	17.43
2448	1695	ENNIS	1903	1363	17.43
2449	1660	FINKS	1804	2289	17.30
2450	2743	CKRHL	0007	80	17.28
2451	1083	STNVL	1207	983	17.27
2452	906	RGLRW	0001	33	17.26
2453	1957	RCHHL	0353	1727	17.25
2454	2466	FRMBR	1808	677	17.24
2455	931	LIGSW	1602	1072	17.22
2456	1055	FRMNT	0008	1853	17.19
2457	2347	HHSTH	1501	3114	17.12
2458	2190	RCHHL	0342	999	17.12
2459	2807	ALPHA	0006	293	16.98
2460	2169	KLELM	2204	2988	16.95
2461	1244	DAVST	0003	1643	16.87
2462	890	MESTE	1208	992	16.87
2463	2391	MLSLW	0006	96	16.82
2464	1387	BRCRK	6514	588	16.82
2465	2531	CTYVW	2221	1868	16.80
2466	1474	STAUG	0003	1842	16.75
2467	2234	LOMAL	0005	391	16.67
2468	1262	RCHHL	0363	573	16.66
2469	471	BNDRA	0003	802	16.59
2470	1546	ARTHR	0472	1230	16.59
2471	2393	ARTHR	0462	206	16.56
2472	2637	WMMMR	2708	245	16.48
2473	718	HORNE	1981	1601	16.43
2474	2087	WEBBS	8622	1582	16.42
2475	1185	BRNWD	1206	1391	16.33
2476	2406	WRBND	2322	866	16.32
2477	1599	EULTB	5731	474	16.31
2478	2050	MCDMT	2531	2434	16.28
2479	2441	PRKWY	1521	2290	16.28
2480	2453	SANSM	3911	1272	16.28
2481	1036	GRSMN	3027	341	16.26
2482	714	BRYAN	0004	1233	16.26
2483	1361	TMPLE	1204	1042	16.19
2484	1501	KNEDL	6322	3767	16.15
2485	N/A	CMTSW	0916	536	16.15
2486	2287	JNKNS	0003	1008	16.14
2487	308	RWDHV	1902	964	16.13
2488	1625	MESTE	1205	1637	16.09
2489	2577	WXHCH	1205	942	16.08
2490	2291	IRVNR	1553	1326	15.93
2491	2748	WSOTH	1022	1526	15.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2492	2706	MRTNS	1501	485	15.89
2493	2693	PFFRD	3411	319	15.85
2494	1831	BRTRD	7312	3014	15.84
2495	2314	DNISN	1206	891	15.81
2496	2772	MCWHT	3522	2927	15.72
2497	2622	CKRHL	0003	359	15.65
2498	1692	WDCR	0241	694	15.65
2499	2510	WEAST	0615	346	15.61
2500	2594	CMPST	0001	420	15.52
2501	2305	GAVSW	0009	1022	15.44
2502	1668	MURPH	2753	678	15.33
2503	709	ADISN	1602	215	15.33
2504	1523	WMMMR	2706	17	15.32
2505	2549	HORNE	1991	1452	15.18
2506	1624	COMSO	1403	477	15.11
2507	580	GMINI	5811	2920	15.09
2508	1042	COPEL	3054	247	15.00
2509	178	GRLRD	0003	631	14.91
2510	2567	MCDMT	2551	4347	14.69
2511	1892	CRLFR	2154	3447	14.68
2512	1044	WRBND	2321	1559	14.68
2513	311	NHNSW	0005	410	14.67
2514	2677	MNSTR	1202	268	14.64
2515	2515	LSCOL	2142	12	14.63
2516	2472	LVBRD	0008	1739	14.53
2517	1806	DALRK	1326	2703	14.52
2518	76	HOLND	1901	1078	14.46
2519	154	TRLSW	1203	674	14.38
2520	2260	SMFLD	2343	726	14.30
2521	1065	BKBNT	1821	1166	14.12
2522	1712	ESTLD	3611	1522	14.11
2523	2654	CMHBL	8121	46	14.05
2524	1355	BRNSO	1801	1579	14.02
2525	862	DALLW	0005	125	13.99
2526	2848	CRLUD	1301	16	13.97
2527	315	GSTHW	1641	84	13.89
2528	1617	CRYVE	3011	279	13.88
2529	1122	PROAD	0007	412	13.85
2530	498	PREST	1601	1126	13.84
2531	1898	PPARK	1802	604	13.83
2532	2348	PLKST	0001	692	13.82
2533	813	BOWEN	3142	1057	13.74
2534	1684	VANAL	2412	2817	13.72
2535	2495	RWALE	3326	2718	13.69
2536	2468	MKNSW	1603	1317	13.66
2537	616	SHNRW	1601	543	13.65
2538	1260	DAVST	0001	571	13.60
2539	2447	LKMNT	0001	187	13.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2540	1138	TYWST	2002	63	13.44
2541	2894	RSPCK	2132	67	13.44
2542	2578	ALNSW	2654	1856	13.41
2543	430	DALWT	2941	300	13.39
2544	1377	MCWHT	3512	2001	13.36
2545	2576	BLNKT	0701	287	13.33
2546	1788	EULSO	9121	120	13.31
2547	609	WTHRF	2001	633	13.09
2548	1870	CRLUD	1303	859	13.09
2549	1593	DFWNW	2601	61	13.08
2550	2349	MDTHS	1001	1500	13.07
2551	1677	PALRD	2205	319	13.05
2552	2438	CRTLD	4732	2775	12.97
2553	1793	MNSTR	1201	670	12.95
2554	105	MCGRG	0776	216	12.71
2555	2145	MDLNE	0133	2557	12.70
2556	1054	PRSTN	0001	880	12.60
2557	1834	BRNSO	1805	805	12.60
2558	1041	BARRY	1801	82	12.59
2559	2575	ABRRD	0008	1423	12.53
2560	647	PFFRD	3452	877	12.46
2561	1385	BNDRA	0007	488	12.42
2562	1749	CLYVL	9312	1275	12.42
2563	2058	WWEST	1218	994	12.41
2564	527	SWAN2	1801	400	12.40
2565	2136	WFALS	0174	1248	12.40
2566	2719	GDNVL	1201	61	12.34
2567	2444	EDGCF	2221	763	12.28
2568	2488	MSLSW	0007	393	12.27
2569	1140	NMAIN	0241	709	12.13
2570	2052	TYOMN	1411	272	12.12
2571	2445	FRMBG	1706	62	12.00
2572	2711	IRVRS	4413	1044	11.99
2573	5	KRUMS	1204	1408	11.95
2574	1905	WFALS	0124	126	11.85
2575	2479	ABBOT	1902	119	11.84
2576	1877	LMBLN	0003	173	11.84
2577	2690	ALPHA	0008	1259	11.82
2578	1735	PLANO	1101	394	11.80
2579	2887	RCLNS	1402	656	11.78
2580	2352	RWALL	1201	1176	11.73
2581	239	RSNHT	1152	1025	11.69
2582	2652	DESPR	1404	581	11.67
2583	242	WSOTH	1019	800	11.67
2584	424	LEMON	0001	2111	11.56
2585	2194	ABRRD	0003	331	11.48
2586	2467	RRSTH	1708	4075	11.46
2587	546	BLMND	3241	226	11.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2588	863	BNDRA	0006	500	11.18
2589	2063	COMRC	1204	596	11.04
2590	389	DALWT	2911	340	11.03
2591	2727	GSTHW	1682	147	11.02
2592	1738	LOT69	3024	950	10.91
2593	929	GRAHM	0721	1271	10.77
2594	2703	ENTOH	0002	812	10.74
2595	1389	ALNTH	2853	2968	10.67
2596	139	IRASB	3211	262	10.64
2597	2214	WTAUG	4632	1276	10.55
2598	2499	NPKWY	0006	4893	10.43
2599	2289	SIKES	2411	2066	10.39
2600	1496	BEAST	4088	120	10.32
2601	2443	NMAIN	0282	1195	10.32
2602	1796	GODRD	8141	862	10.26
2603	2517	ARLNG	1222	100	10.26
2604	1173	WNDWD	3631	311	10.23
2605	621	CLLVL	0001	23	10.21
2606	2777	LFSTH	1405	217	10.20
2607	2701	PRHLL	2402	65	10.16
2608	2647	HORNE	1923	1568	10.13
2609	2597	BLMGR	1901	260	10.09
2610	1889	MDLNE	0163	1044	10.07
2611	1841	SORCY	0001	2542	10.05
2612	2815	BNDRA	0013	175	10.05
2613	1030	WGROB	8412	3235	9.92
2614	1611	RCHHL	0394	237	9.84
2615	1578	CTYVW	2211	1492	9.83
2616	2101	RGLRW	0004	78	9.75
2617	1484	RGLRW	0003	96	9.73
2618	916	CKRHL	0002	400	9.69
2619	2282	MRLNS	4002	417	9.60
2620	2750	DCATR	1205	121	9.55
2621	1586	RRSTH	1704	2931	9.50
2622	221	DCDAM	2001	747	9.37
2623	2882	PROAD	0006	126	9.30
2624	2054	NSTAR	2011	522	9.30
2625	2152	WITTS	1701	1923	9.29
2626	2616	DENAV	0652	40	9.25
2627	2285	SHMNE	1403	999	9.19
2628	1913	MURPH	2756	3213	9.18
2629	790	MDWCK	0003	1882	9.18
2630	722	CRSGL	1303	89	9.13
2631	2341	GNSVN	1401	25	9.13
2632	2865	HMPHL	2713	65	9.05
2633	2876	PARIS	1205	25	9.05
2634	2606	BKBNT	1811	687	9.02
2635	1289	RNKSW	5412	30	8.91

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2636	2881	PLHWY	3703	14	8.88
2637	157	CNEXP	0008	433	8.79
2638	1268	SHDYG	7831	95	8.76
2639	1063	NPKWY	0008	883	8.76
2640	2417	LKBLT	2103	1798	8.67
2641	35	LEMON	0006	725	8.59
2642	2228	FRNKF	0007	1167	8.52
2643	1170	STNVL	1204	920	8.50
2644	1002	FHLSW	1321	363	8.50
2645	44	MCGRG	0775	535	8.46
2646	1688	IRVNR	1557	3019	8.38
2647	2031	SMFLD	2392	1025	8.38
2648	2579	IRVHF	2303	85	8.38
2649	1603	REAST	1501	288	8.35
2650	2179	MNWLL	1205	440	8.29
2651	1554	WATSN	5342	1997	8.28
2652	2898	WALST	0006	11	8.22
2653	2562	WEBBS	8612	3348	8.21
2654	1236	NPKWY	0009	1300	8.20
2655	1932	FSTVW	0003	1908	8.19
2656	2421	WMMMR	2703	1106	8.16
2657	2555	WDCR	0262	248	8.10
2658	2210	SHAMP	0003	1725	8.08
2659	2864	GSTHW	1672	42	8.07
2660	2244	GNSVN	1403	277	8.06
2661	2792	BRIRV	6912	817	8.00
2662	2091	RRSTH	1705	601	7.97
2663	2209	JUDCT	0006	1167	7.87
2664	1234	WALST	0002	30	7.82
2665	701	RSPCK	2103	159	7.81
2666	310	ARPCM	4169	11	7.77
2667	2655	GSTHW	1622	29	7.74
2668	1891	OAKHL	3041	894	7.71
2669	2809	FRMNT	0012	512	7.70
2670	1948	SHSTH	1302	21	7.69
2671	1511	ALPHA	0004	21	7.69
2672	930	DENDR	0004	2169	7.64
2673	2731	SORCY	0002	66	7.62
2674	1942	HKBRY	1117	138	7.57
2675	1739	SLBLF	1201	136	7.57
2676	2134	PRKWY	1542	488	7.49
2677	2630	RGFTW	6822	23	7.49
2678	1001	DENDR	0006	47	7.44
2679	2883	PSHIL	1605	124	7.40
2680	1254	SANSM	3913	3449	7.36
2681	2763	ARMST	0004	1179	7.26
2682	1629	DESHR	1206	2170	7.24
2683	2789	BLTLN	0001	646	7.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2684	598	CMTSW	0952	221	7.15
2685	2644	CRLTN	1408	133	7.12
2686	103	SCHRD	0003	368	7.11
2687	2656	NMAIN	0231	328	7.09
2688	1003	RNDRK	1507	1419	7.08
2689	2862	FRMNT	0006	11	7.08
2690	2636	PRNTH	1403	20	7.07
2691	2297	WDGWD	1552	310	7.06
2692	387	LKWOD	7411	632	7.02
2693	605	BLTON	1804	471	6.98
2694	2021	CHROW	0007	84	6.90
2695	2620	SHDYG	7812	124	6.83
2696	960	CPLSO	4321	120	6.83
2697	2804	WEAST	0628	234	6.71
2698	2728	HMPHL	2711	480	6.69
2699	2521	CRLTN	1451	207	6.63
2700	2337	WOVER	6111	486	6.63
2701	1306	SMPST	0006	811	6.55
2702	2767	LKWOD	7421	42	6.53
2703	2754	COPER	0401	123	6.48
2704	1265	LNCST	1601	679	6.45
2705	1096	CLYVL	9323	1424	6.41
2706	2437	MCDMT	2532	1979	6.39
2707	2588	POWEL	2706	240	6.37
2708	292	GRLWS	1704	172	6.26
2709	904	CTYVW	2222	1394	6.22
2710	2778	STNVL	1202	89	6.15
2711	2709	WWEST	1217	95	6.04
2712	2358	SMFLD	2352	591	6.03
2713	2874	MRSES	4014	18	5.98
2714	161	CNSES	3056	2168	5.95
2715	993	HKBRY	1104	118	5.94
2716	2877	PJPTR	3221	45	5.90
2717	1803	DALWT	2972	238	5.90
2718	2537	BRKRG	0211	307	5.88
2719	1543	PRKRW	3382	283	5.78
2720	2556	TMSTH	1407	72	5.74
2721	478	EDGCF	2252	394	5.64
2722	2642	VENSW	2603	26	5.56
2723	2776	PROAD	0001	125	5.54
2724	2142	FRMBR	1806	149	5.53
2725	2201	WBOSE	1103	870	5.38
2726	2482	BRYAN	0001	15	5.37
2727	N/A	COVEE	3403	1356	5.27
2728	1807	CLBNR	1406	109	5.26
2729	2199	SSPNE	1402	67	5.23
2730	529	ABRRD	0006	206	5.10
2731	1327	WXNTH	2308	737	5.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2732	2744	DENDR	0008	86	4.95
2733	361	RDRSE	2605	651	4.73
2734	2569	KNLTR	0006	537	4.72
2735	1099	EMPCT	0004	348	4.65
2736	2867	IRVVV	2803	148	4.62
2737	2747	RGLRW	0005	53	4.61
2738	2094	DAVIS	3762	41	4.60
2739	651	WEBBS	8631	2723	4.55
2740	880	SHNRW	1611	958	4.50
2741	2833	BRHLW	7611	1616	4.50
2742	2565	MSTLT	1054	597	4.48
2743	496	SCHRD	0008	71	4.47
2744	780	PROAD	0005	119	4.45
2745	2713	WRTHM	5017	164	4.42
2746	2746	FRMBG	1705	275	4.41
2747	2858	EXPKY	8112	14	4.40
2748	1521	IRVND	1203	416	4.30
2749	2007	GRHWY	5521	876	4.26
2750	1744	LIGSW	1607	1396	4.20
2751	2413	MESQW	1805	79	4.18
2752	1365	HMPHL	2792	437	4.13
2753	1427	BDFWD	8911	934	4.08
2754	2368	ATNRN	3412	3750	4.00
2755	2261	CRNRD	0006	315	3.98
2756	885	WEBBS	8613	631	3.96
2757	2852	DFWNW	2606	22	3.95
2758	2886	RCLNS	1401	105	3.89
2759	2470	LMBLN	0008	118	3.85
2760	1539	CLLVL	0004	45	3.85
2761	1935	ARMST	0011	881	3.84
2762	200	CNEXP	0003	1387	3.82
2763	2859	EXPKY	8141	19	3.65
2764	2422	WWEST	1220	195	3.57
2765	2676	JNKNS	0004	126	3.57
2766	1753	FRNKF	0001	953	3.52
2767	2724	WFALS	0163	344	3.50
2768	1790	ROLTR	2911	1811	3.50
2769	870	VGCRK	8031	1804	3.43
2770	1654	RKCRK	6111	2239	3.39
2771	2649	PWEST	1312	1357	3.38
2772	2542	ABBOT	1901	114	3.33
2773	1992	CHROW	0001	130	3.30
2774	2868	JNKNS	0002	170	3.30
2775	2458	CRNRD	0002	373	3.28
2776	1823	TMNTH	1604	53	3.18
2777	875	WALST	0004	41	3.18
2778	2331	JNKNS	0005	536	3.18
2779	2827	CURIE	7241	713	3.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2780	1973	WATSN	5372	1337	3.11
2781	1658	SMFLD	2322	41	3.02
2782	175	PALMR	2201	52	2.95
2783	2206	TYLGE	1314	843	2.93
2784	2732	SHRSW	6631	1322	2.80
2785	2692	ROBNW	1501	678	2.78
2786	2897	WALST	0003	129	2.69
2787	2756	PLANO	1106	488	2.65
2788	2835	EULES	8714	793	2.50
2789	2836	ALLEN	2401	398	2.47
2790	2707	VALVW	1802	422	2.46
2791	2626	CRLTR	2004	222	2.44
2792	2505	STNVL	1205	433	2.42
2793	1463	HMPHL	2791	22	2.40
2794	2455	VANAL	1201	569	2.38
2795	2561	WEBBS	8633	2190	2.35
2796	2806	SHDYG	7832	1848	2.33
2797	2177	ALPHA	0011	1157	2.32
2798	2700	HORNE	1933	2002	2.30
2799	2764	WWEST	1222	165	2.26
2800	1292	SHAMP	0006	1142	2.24
2801	2389	KLRPR	9011	2748	2.20
2802	756	LSCOL	2116	32	2.17
2803	2753	CRLTN	1452	577	2.15
2804	2840	ARTHR	0492	50	2.11
2805	663	STERT	2703	330	2.06
2806	2523	CPLSO	4311	82	2.04
2807	1751	WWEST	1216	256	2.01
2808	2633	LOMAL	0007	158	2.00
2809	2270	SHNRW	1610	421	1.98
2810	2587	HURST	1841	979	1.94
2811	38	NAVCO	0001	26	1.92
2812	1014	HUTCH	1505	26	1.89
2813	2478	TMNTH	1601	28	1.86
2814	2526	REAST	1507	112	1.83
2815	2871	LSCOL	2138	730	1.78
2816	N/A	PCOMM	3311	23	1.77
2817	N/A	NMAIN	0252	10	1.77
2818	134	RGLRW	0002	216	1.72
2819	886	MSTLT	1032	30	1.71
2820	2390	MKNNY	1254	806	1.66
2821	2808	WEAST	0627	127	1.64
2822	2759	MRSES	3016	42	1.59
2823	2798	LKBLT	2101	1470	1.51
2824	2826	WMRNR	0003	791	1.50
2825	2794	ARLNG	1291	86	1.33
2826	2516	DFWNW	2610	56	1.33
2827	N/A	RVRFT	0003	169	1.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2828	237	FRNKF	0008	1255	1.23
2829	2057	IRLBJ	3231	2366	1.19
2830	1754	ALNTH	2832	946	1.11
2831	2773	WEBBS	8634	684	1.07
2832	1656	ARMST	0003	364	1.06
2833	1675	EMPCT	0005	67	1.04
2834	620	RENSW	3122	573	1.04
2835	652	NIPAK	1001	128	0.99
2836	764	LEMON	0002	957	0.99
2837	2737	GSTHW	1613	92	0.94
2838	2604	KIMBL	5022	876	0.93
2839	2424	MDWCK	0006	890	0.90
2840	2236	WTAUG	4651	517	0.83
2841	2186	HMPHL	2772	286	0.74
2842	2745	MAPLE	0002	527	0.71
2843	2813	JNKNS	0006	505	0.69
2844	2528	ARMST	0006	574	0.68
2845	2698	ARMST	0002	1186	0.67
2846	2722	CKRHL	0004	414	0.65
2847	2834	IRLBJ	3221	715	0.60
2848	2863	GAVSW	0011	109	0.60
2849	2436	ALNTH	2842	1677	0.57
2850	2602	GRLRD	0002	990	0.54
2851	2845	COTRD	0005	225	0.52
2852	1339	WGROB	8421	1693	0.51
2853	1618	REGST	0004	974	0.43
2854	2675	WMMMR	2705	579	0.40
2855	2702	ARMST	0007	114	0.33
2856	2641	LEMON	0004	383	0.31
2857	2631	TMPNW	1103	614	0.26
2858	2841	BKWST	0006	804	0.25
2859	2816	LSCOL	2137	623	0.24
2860	2832	FRMNT	0001	845	0.24
2861	791	IRVVV	2804	925	0.24
2862	11	WICKT	0421	118	0.17
2863	326	DALWT	2952	662	0.16
2864	2769	PSHIL	1606	654	0.09
2865	2846	COTRD	0008	1037	0.09
2866	2812	BKWST	0004	1077	0.08
2867	2799	LSCOL	2148	1049	0.05
2868	327	KNLTR	0004	1923	0.02
2869	866	AIRPK	8431	20	0.00
2870	2838	AMLIA	0003	21	0.00
2871	2018	ARMST	0008	238	0.00
2872	2842	BRHLW	7641	24	0.00
2873	2738	BRYAN	0007	269	0.00
2874	2668	CLBNR	1401	21	0.00
2875	2844	COLDG	4048	10	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2013 SAIDI Ranking	2012 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2013 SAIDI Value
2876	1859	COTRD	0003	30	0.00
2877	2847	CRLTR	2054	101	0.00
2878	2491	DFWSW	2204	22	0.00
2879	1968	DFWSW	2207	23	0.00
2880	2854	DFWSW	2208	19	0.00
2881	2856	DGNST	0001	232	0.00
2882	2683	FRMBG	1703	36	0.00
2883	2860	FRMBG	1704	36	0.00
2884	2688	FRMNT	0005	266	0.00
2885	2825	FRMNT	0011	514	0.00
2886	2560	GSTHW	1651	12	0.00
2887	1717	GSTHW	1662	12	0.00
2888	2670	HMPHL	2723	51	0.00
2889	2720	HNTNG	1302	39	0.00
2890	2866	INAIR	1442	114	0.00
2891	2640	JKSNR	4107	19	0.00
2892	2710	JNKNS	0001	14	0.00
2893	2034	LMBLN	0004	46	0.00
2894	2817	LSCOL	2135	554	0.00
2895	2872	LSCOL	2140	297	0.00
2896	2660	LUFKN	1204	34	0.00
2897	1219	MAPLE	0004	115	0.00
2898	2736	MAPLE	0008	214	0.00
2899	2739	MCGHR	2004	19	0.00
2900	1690	MDDTN	4322	26	0.00
2901	487	NPKWY	0007	157	0.00
2902	1353	PJPTR	3212	22	0.00
2903	2878	PJPTR	3222	169	0.00
2904	2879	PJPTR	3231	26	0.00
2905	N/A	PJPTR	3242	10	0.00
2906	2880	PLHWY	3701	493	0.00
2907	2884	PWEST	1306	281	0.00
2908	2885	PWEST	1309	58	0.00
2909	2415	RECCR	0005	158	0.00
2910	2890	REGST	0007	10	0.00
2911	2822	RGFTW	6841	19	0.00
2912	2893	ROANW	9522	31	0.00
2913	2712	RSPCK	2133	49	0.00
2914	1443	RSPCK	2141	19	0.00
2915	2680	SHNRW	1607	64	0.00
2916	2896	TRLSW	2401	22	0.00
2917	2899	WALST	0008	13	0.00
2918	2823	WEAST	0621	31	0.00
2919	2900	WMMMR	2704	14	0.00
2920	2901	WMRLD	0009	31	0.00
2921	2563	WWEST	1221	27	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2013 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	12.4%
Vegetation	16.2%
Animals and Birds	17.4%
People (Including cars and farm equip)	5.0%
Utility-owned Equipment	40.4%
Other	2.9%
Unknown	5.7%