

Control Number: 43175



Item Number: 2

Addendum StartPage: 0

House Bill (HB) 1600 and Senate Bill (SB) 567 83<sup>rd</sup> Legislature, Regular Session, transferred the functions relating to the economic regulation of water and sewer utilities from the TCEQ to the PUC effective September 1, 2014.

Bryan W. Shaw, Ph.D., Chairman Carlos Rubinstein, Commissioner Toby Baker, Commissioner Mark R. Vickery, P.G., Executive Director



RECEIVED 2014 SEP 18 PM 12: 03

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Toxas In Part.

Protecting Texas by Reducing and Preventing Pollution

April 30, 2012

Ms. Bonnie Frame, General Manager Community Water Service, Inc. P.O. Box 850155 Mesquite, Texas 75185

Comprehensive Compliance Investigation at:

Red Oak Community Water, 100 Block Carson St., Red Oak, Ellis County, Texas

RN101282762, TCEQ ID No. 0700056, Investigation #989603

Dear Ms. Frame,

On March 26, 2012, Ms. Brittany Pettitt of the Texas Commission on Environmental Quality (TCEQ) Dallas/ Fort Worth Region Office conducted an investigation of the above-referenced facility to evaluate compliance with applicable requirements for public water systems. No violations are being alleged as a result of the investigation, however, please see the enclosed Additional Issue.

The TCEQ appreciates your assistance in this matter and your compliance efforts to ensure protection of the State's environment. If you or members of your staff have any questions regarding these matters, please feel free to contact Ms. Brittany Pettitt in the Dallas/Fort Worth Region Office at (817)-588-5820.

Charles Marshall PWS Team Leader

Dallas/Fort Worth Region Office

CM/bfp

Enclosure: Summary of Investigation Findings

## Summary of investigation Emdings

RED OAK COMMUNITY WATER SERVICE

Investigation #989603

Investigation Date: 03/26/2012

, ELLIS COUNTY,

Additional ID(s): 0700056

ADDITIONAL ISSUES

Description

WATER TREATMENT: Meets applicable

No Violatrons Assectated to this Investigation

290.42 standards?

**Additional Comments** 

On the day of the investigation, the water system was utilizing a brand of bleach with an unknown NS Standard 60 status. Using any brand of bleach not manufactured to NSF Standards for public water systems is a violation of the Public Drinking Water Rules, 30 TAC 290.42(i). Please note, if the label does not indicate that the bleach meets NSF Standard 60, contact the manufacturer to confirm whether the bleach is manufactured to standards. NSF-certified bleaches are marked as follows: The label will read, "meets NSF Standard 60", the label will show the NSF symbol, or both.