



Control Number: 43452



Item Number: 60

Addendum StartPage: 0



T.B.P.E. #F-8632

700 Highlander Blvd., Suite 210
Arlington, TX 76015

817.522.1000 PHONE
www.TRCSolutions.com

RECEIVED

2016 OCT 20 AM 11:03

PUBLIC UTILITY COMMISSION
FILING CLERK

October 19, 2016

Public Utility Commission of Texas
Central Records
1701 N. Congress, Suite 8-100
Austin, TX 78701

RE: Town of Little Elm, Denton County
Application to Amend Certificates of Convenience and Necessity
Docket No. 43452
Additional Documentation – Ability to Service Additional Areas

On October 4, 2016, Debbie Reyes-Tamayo of the Water Utility Division submitted an email requesting additional documentation on the above mentioned application. The applicant has timely addressed your request regarding the application as follows:

1. PUC Comment – *Please state how many connections are currently being served by Terra Southwest, and if the transfer of the facilities has been completed.*

Applicant Response – Terra Southwest, Inc. was removed from this application and filed under a separate STM application, Docket No. 44870.

2. PUC Comment – *Provide documentation that the 2 MG water storage tank, referenced on Attachment 13 of the original application, has been approved by TCEQ. If the tank has not been approved, please provide a statement as to why this capacity is not necessary for providing service to the proposed area.*

Applicant Response – The 2 MG elevated storage tank has been constructed and was placed into service in 2014. This tank provides adequate storage capacity for the areas requested in the applications.

3. PUC Comment – *State the extent of system upgrades and extensions, including distribution and collection lines that will be necessary to serve the additional area. If applicable, provide TCEQ approvals.*

Applicant Response – The additional areas will be served as follows:

Water Tracts 1, 3-5 – The areas are currently being served by the Town and no upgrades or extensions are necessary at this time.

60

October 18, 2016

Page 2 of 2

Water Tracts 2, 6 – These areas are largely undeveloped. Additional water lines will be constructed as housing development begins in this area.

Sewer Tracts 1, 7 – These areas will be served by the Town's West Side Utility Project, including 5,400 linear feet of 8" sanitary sewer collection lines. Project was completed in April 2016.


Sewer Tract 2 – Homes in this area are currently treating sanitary sewer by on-site sewage facilities as permitted by TCEQ. The Town plans to provide sanitary sewer service to this area in the future.

Sewer Tracts 4, 6 – These areas are currently being served by the Town and no upgrades or extensions are necessary at this time.

Sewer Tracts 3, 5 – These areas are largely undeveloped. Additional sewer collection lines and lift stations will be constructed as housing development begins in this area.

Please contact this office if you need additional information or have any other questions regarding this application.

Sincerely,



Justin L. Thomas, P.E.

Arlington CES Practice Leader

cc: Doug Peach, Deputy Town Manager, Town of Little Elm

Jason Laumer, Director of Development Services, Town of Little Elm

Kimberly Brawner, Town Engineer, Town of Little Elm

