

Project Sizing and Expansion Options

Two project phasing options were developed to provide adequate capacity for the initial contracted deliveries as well as the future phase capacity anticipated by projected water demands in the area.

The first phasing option for project sizing involves the base case design with an expected single construction phase with a capacity to deliver initial contracted deliveries of 10 mgd. Evaluation for pipe sizes, pressure class, and preferred delivery scheme was conducted for the base case.

Potential expansion of project facilities was evaluated using a phased approach with an initial phase to deliver initial contract deliveries, and a future phase to deliver water that may be made available. This option was evaluated for the most feasible alternatives resulting from evaluation of the base case delivery scheme.

System Demand Distribution

The project demands used for detailed study of the hydraulic alternatives were derived from information obtained from meetings with the potential customers of the system in November and December of 1999.

The requested delivery quantities for both initial conditions (start of project operation in year 2002) and ultimate conditions (year 2012 project operations) are tabulated in Table 1, *Requested Delivery Quantities – Base Project*. The table clearly shows the additional (returnable) deliveries not used in-district during initial operation as distributed to the out-of-district customers. Similarly, the table indicates the full in-district use of those deliveries during ultimate operation.

Hydraulic Criteria and Constraints

The primary hydraulic parameters set for project constraints include the following:

- Minimum internal pressure of 10 psig above any expected local external hydrostatic pressure under all normal conditions in the pipeline. This internal pressure is slightly higher than Texas Natural Resource Conservation Commission (TNRCC) guidelines for potable water transfer lines to account for uncertainties in actual operational conditions.
- Maximum internal pressure of 300 psi in the transfer pipeline. This pressure was selected based on standards in engineering design practice and consideration for feasible pipeline construction and maintenance.
- Minimum velocity of approximately 2 feet per second (fps). This minimum velocity is required for maintaining adequate scour of potential filter sediment entering the transfer system.

Table 1 – Requested Delivery Quantities –Base Project

Entity	Requested Delivery	
	Ultimate	Initial

	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)
IN-DISTRICT				
City of Boerne	1,861	1.74	500	0.47
City of Fair Oaks	1,400	1.31	800	0.75
Comal Independent School District	150	0.14	150	0.14
Apex Water Services	200	0.19	100	0.09
Bulverde Utility Corp. (absorbed by Bexar Met.)	202	0.19	202	0.19
Murcia Development Co.	220	0.21	100	0.09
Lost Owl (Comal Water Co.)	44	0.04	5	0.00
Clyde Johnson	400	0.37	100	0.09
Double J. Ranch	250	0.23	100	0.09
Cordillera	1,000	0.94	400	0.37
Tapatio Springs/Kendall Co. Utility Co.	500	0.47	150	0.14
Others	300	0.28	0	0.00
SUBTOTAL	6,527	6.12	2,607	2.44
OUT-OF-DISTRICT				
San Antonio River Authority	50	0.05	50	0.05
San Antonio Water System	1,813	1.70	4,654	4.36
<i>(commitment)</i>	<i>(1,813)</i>	<i>(1.70)</i>	<i>(1,813)</i>	<i>(1.70)</i>
<i>(returnable)</i>	<i>(0)</i>	<i>(0.00)</i>	<i>(2,842)</i>	<i>(2.66)</i>
Bexar Metropolitan Water District	2,138	2.00	3,216	3.01
<i>(commitment)</i>	<i>(2,138)</i>	<i>(2.00)</i>	<i>(2,138)</i>	<i>(2.00)</i>
<i>(returnable)</i>	<i>(0)</i>	<i>(0.00)</i>	<i>(1,079)</i>	<i>(1.01)</i>
SUBTOTAL	4,000	3.7	7,920	7.4
TOTAL IN AND OUT OF DISTRICT	10,527	9.9	10,527	9.9

Notes:

⁽¹⁾ Demand values reported in mgd include additional consideration for 5% system losses expected.

Established Decision Criteria

Decision criteria were established for selection of the most feasible hydraulic design alternative for the project. The decision criteria are comprised of both cost and non-cost factors and are characterized by inherent concerns or trade-offs affecting that affect the decision process. The factors and associated concerns are listed below in Table 2, *Decision Criteria*.

TABLE 2 – Decision Criteria

Cost Factors	Concern
Pipe Pressure Class	Trade-off between pipe size and pump head
Pipe Size	
Pump Energy Cost	Trade-off with capital cost of pipeline
System Storage	More storage required for remote pump station
Power Connection for Electrical Feed	Less costly for single electrical feed at WTP
Non-Cost Factors	
WTP Location (Elev.)	Affects feasibility of gravity conveyance to system. Affects number of suitable sites.
O&M Staffing Location	Convenience for O&M if single facility
Control Complexity	Complexity of system control increases with off-site facilities.

Additional non-cost concerns that are of less importance to the actual feasibility of the project include system delivery to the customer's preferred hydraulic grade line elevation and electrical feed considerations (facilities within single service area vs. multiple, potential for dual feed vs. generator for backup).

Pipeline and Pump Station Design Alternatives and Hydraulics

The relative elevations of the preliminary location for the water treatment plant site and the customer delivery points provide the opportunity for several different delivery schemes. These include pumped delivery to all customers as well as gravity flow to the customers at lower elevations with pumped delivery to the customers at higher elevations. The most likely options have been identified as follows:

- Alternative 1 – This alternative provides pumped delivery to all customers via a high service pump station at the water treatment plant.
- Alternative 2 – This alternative provides gravity delivery to a remote pump station located west of Road 281 along Road 46, with pumped delivery to Boerne and BMWD.
- Alternative 3 – This alternative provides gravity delivery to Bexar Metropolitan Water District (BMWD) in Bexar County and requires a remote pump station in the vicinity of the Boerne/BMWD junction for pumped delivery to Boerne. To allow for gravity to BMWD,

the pipeline route was reconfigured along Smithson Valley Road between the water treatment plant and the junction to Boerne.

Refer to Figures 2-4 for system map for each alternative.

Results of Hydraulic Analysis – Base Project

The three hydraulic design alternatives to meet current contract delivery quantities were evaluated for resulting hydraulic grade line, required pipe size and pressure class, pumping facilities, and the required storage facilities at those pumping facilities.

A summary of hydraulic results pertinent to the established project hydraulic constraints is tabulated for each alternative in Table 3, *Summary of Hydraulic Results – Phased Project Delivery*. Violation of any project criteria is noted within the comment column of the table.

TABLE 3 – Summary of Hydraulic Results – Base Project Delivery

		HYDRAULIC RESULTS - MAINLINE DELIVERY ⁽¹⁾				Comments
Flow Condition		Minimum Velocity (fps)	Maximum Velocity (fps)	Minimum Press. (psi)	Maximum Press. (psi)	
Initial Demand	ALT. 1	3.0	4.7	12.4	242.8	
	ALT.2	3.0	4.7	11.8	234.9	
	ALT.3	1.2	7.0	10.1	234.9	violates min. velocity criteria
Ultimate Demand	ALT. 1	2.8	3.8	26.6	243.1	
	ALT.2	2.8	3.8	12.4	237.1	
	ALT.3	0.8	7.3	12.6	237.1	violates min. velocity criteria

⁽¹⁾ Includes those areas of the mainline deemed subject to hydraulic criteria constraints (exceptions include less significant portions of the line such as branches).


Hydraulic Grade Line (HGL)

Determination of the desired HGL elevation at the furthest termination point, SAWS delivery, was made based on the design criteria that the minimum working pressure be at least 10 psi for the entire pipeline. The Hazen-Williams equation was used to compute the headloss in each segment of pipe. Both spreadsheet models and the hydraulic distribution model, KY Pipe, were used to evaluate the alternatives.


The resulting hydraulic profiles for each alternative from; 1) Canyon Lake to the furthest point of the pipeline at the SAWS delivery location and 2) Boerne/BMWD junction to BMWD are shown in Figures 5 and 6, respectively.

The HGL for Alternative 1 shows that the single high-head boost at the WTP. Profiles for Alternatives 2 and 3 indicate gravity from the WTP to the respective remote pump stations where deliveries further down the line are supplied a boost in HGL.

Alternative 1 Profile - High Service Pump Station at WTP



Alternative 2 Profile Gravity from WTP to Remote Pump Station, Pump to Boerne and BMWD



Alternative 3 Profile- Gravity to Bulverde Junction, Remote Pump to Boerne Only







Figure 6 – Hydraulic Profiles, Boerne Junction to BMWD



Pipe Size and Pressure Class Determination

For the determination of pipe pressure classifications, a Hazen-Williams roughness coefficient of 120 was used as a safety factor to account for the possibility of increased pipe deterioration. The working pressures within the pipe were calculated considering the difference between HGL elevation and relative ground elevation, converted to pressure. Based on the calculated working pressure, a pressure class was assigned to each segment of pipe. Pressure class increments of 50 psi with a minimum pressure class of 100 psi were used.

The pipe sizes, pressure class and corresponding length required for each hydraulic alternative are summarized in Table 4, *Summary of Pipe Size and Pressure Class – Base Project*.

TABLE 4 – Summary of Pipe Size and Pressure Class – Base Project

Dia.(in.)	Pressure Class	LENGTH OF PIPING (ft)		
		ALT.1	ALT.2	ALT.3
36	150	-	-	45003
	100	-	-	21777
30	250	46647	16693	-
	200	26506	3292	-
	100	-	53168	-
27	150	-	-	21002
	100	-	-	3018
24	250	11407	11407	11407
	200	31323	31323	31323
	150	5937	5937	5937
20	150	33579	33579	33579
	100	5038	5038	5038
18	100	2961	2961	2961
16	150	-	-	6423
14	300	-	-	-
	250	27425	27425	-
	200	3018	3018	-
10	100	-	-	20265
8	100	-	-	4133
Totals		193841	193841	211868

Required Pumping Facilities

The required pumping facilities for each hydraulic design alternative were evaluated as a component contributing to both the capital cost and O&M costs for each alternative. The resulting pumping requirements associated with each alternative is summarized in Table 5, *Summary of Pumping Requirements – Base Project*.

TABLE 5 – Summary of Pumping Requirements – Base Project⁽¹⁾

	ALT.1	ALT.2	ALT.3
Pump Head (ft)	370	399	503
Flow (mgd)	9.9	9.1	6.4
Required hp	910	910	810

⁽¹⁾Reported values represent average conditions between initial and ultimate demand distributions.

Required System Storage

Because it is a unique component of some hydraulic design alternatives evaluated, the additional storage that may be required at remote pumping facilities was considered. For all practical purposes, the minimum storage needed at a remote pumping facility was assumed as 0.25 million gallons.

Relative Cost Comparison of Alternatives

Costs for facilities and O&M required for each alternative were evaluated to provide a cost comparison between alternatives.

Cost Basis

For the purpose of this comparison, only unique components were evaluated for cost, not including all common components. The resulting cost value is useful for determining the relative difference between alternatives and should in no way be construed as total for any alternative.

The cost comparison included consideration for the following unique components:

- Transmission pipelines
- WTP/Remote Booster Pump Stations
- System Storage
- Electrical Feed
- Additional Land Acquisition (Remote PS and Storage Tank)
- Pumping Costs
- Operation and Maintenance for Pump Stations, Transmission and Storage Facilities

The cost comparison does not include the following common components:

- Intake
- WTP
- RW Pipeline
- Interconnects
- Equilization Tank
- Environmental Studies and Mitigation
- Land ROW Cost

- Engineering and Financing Costs

Base Project Relative Cost Comparison

The cost comparison for the base project hydraulic alternatives is tabulated in Table 6, *Delivery System – Relative Cost Comparison, Base Project – 10,527 acft/yr (10 mgd Capacity)*. The non-cost factors relevant to the established project decision criteria are also included.

As indicated in the relative cost comparison table, Alternative 3 is the most expensive of the alternatives. This fact, in combination with violation of the minimum velocity requirements during ultimate demand distribution (year 2012 demands when out-of-district is reduced) makes Alternative 3 the most infeasible. The Alternative has thus been eliminated from further evaluation.

TABLE 6 – Delivery System – Relative Cost Comparison, Base Project - 10,527 acft/yr (10 mgd) Capacity

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alternative 1	Alternative 2	Alternative 3
Capital Costs			
Transmission Pipelines	\$ 16,621,000	\$ 15,589,000	\$ 16,866,000
	-	-	\$ 968,000
WTP Pump Station	\$ 1,263,000	-	-
Booster Pump Station	-	\$ 1,299,000	\$ 1,168,000
System Storage	-	\$ 282,000	\$ 282,000
Electrical Feed	\$ 114,000	\$ 118,000	\$ 104,000
Total Capital Cost ⁽²⁾	\$ 17,998,000	\$ 17,288,000	\$ 19,388,000
Add'l Land Acquisition (PS and Storage Tank)	-	\$ 6,800	\$ 6,800
Total Project Cost ⁽²⁾	\$ 17,998,000	\$ 17,295,000	\$ 19,395,000
Annual O&M Costs			
Annual Debt Service	\$ 1,476,000	\$ 1,418,000	\$ 1,590,000
(Assuming 25 years, effective interest rate of 6.5%)			
Pumping Costs (Initial Demands)	\$ 478,000	\$ 494,000	\$ 412,000
(Ultimate Demands)	\$ 478,000	\$ 458,000	\$ 434,000
(ave)	\$ 478,000	\$ 476,000	\$ 423,000
Operation and Maintenance ⁽³⁾			
Pump Station	\$ 28,000	\$ 32,000	\$ 29,000
Transmission Facilities	\$ 166,000	\$ 156,000	\$ 169,000
Storage Facilities	-	\$ 2,800	\$ 2,800
Total Annual Cost ⁽⁴⁾	\$ 2,148,000	\$ 2,085,000	\$ 2,214,000
Non-Cost Factors			
WTP Location (Elev.)	+	-	-
O&M Staffing Location	+	-	-
Control Complexity	+	-	-

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative.

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equilization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks; 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations

Phasing Options for Future Capacity Expansion

Hydraulic design Alternatives 1 and 2 were evaluated further to investigate the potential for expansion of the project facilities to deliver water that may be made available by maximizing capacity of the system.

Two expansion options for each alternative were evaluated. A description of the mode of expansion is as follows:

Alternative 1 - Phased

- **ALT 1P-A.** Increase capacity and head of high service pump station at WTP and pressure class of pipelines.
- **ALT 1P-B.** Increase pipe size to west of junction to Boerne by relaxing minimum velocity criteria. Increase pumping capacity at WTP.

Alternative 2 - Phased

- **ALT 2P-A.** Increase pipe size in gravity line from WTP to remote PS, increase capacity of remote PS.
- **ALT 2P-B.** Increase pressure class of pipelines, add booster pump station at WTP, increase capacity of remote pump station.

Refer to Figures 2-4 for system map for changes required by each phasing alternative.

Results of Hydraulic Analysis – Phased Project

The phased project hydraulic alternatives to provide expansion were evaluated for resulting hydraulic grade line, required pipe size and pressure class, pumping facilities, and the required storage facilities at those pumping facilities. For comparison purposes, a Phased Project capacity of 15,683 acft/yr -the maximum capacity of Alternative 1- was evaluated.

A summary of hydraulic results pertinent to the established project hydraulic constraints is tabulated for each alternative in Table 7, *Summary of Hydraulic Results – Phased Project Delivery*. Violation of any project criteria is noted within the comment column of the table.

TABLE 7 – Summary of Hydraulic Results – Phased Project Delivery

HYDRAULIC RESULTS - MAINLINE DELIVERY ⁽¹⁾						Comments
Base Project	Phased Project	Minimum Velocity (fps)	Maximum Velocity (fps)	Minimum Press. (psi)	Maximum Press. (psi)	
ALT. 1	ALT 1P-A	2.9	5.2	11.0	243.1	violates min. velocity criteria under base demands
	ALT. 1P-B	2.2	4.4	13.8	225.3	
ALT. 2	ALT. 2P-A	2.4	5.2	11.0	281.4	
	ALT. 2P-B	2.4	5.2	11.0	281.4	

⁽¹⁾ Includes those areas of the mainline deemed subject to hydraulic criteria constraints (exceptions include less significant portions of the line such as branches).

⁽²⁾ Flow condition for phased project alternatives consider ultimate base project demand distribution with even distribution of additional demands assuming 75% west and 25% east of the junction to Boerne

Hydraulic Grade Line (HGL)

The procedure for determination of the desired HGL elevation for the phased project is the same as described for the base project. The HGL is modified from the base project by adding elevation where head at a pump station is increased or by change in slope (flattening) of the HGL where the diameter of pipe was increased. Fundamentally, the general characteristics of the HGL are the same as for the base project, where adequate head to provide a minimum of 10 psi either at the next pump lift location or the furthest termination point is provided. Thus, the hydraulic profiles are not presented. Refer to the phased project *Required Pumping Facilities* section for an indication of additional head required at pumping facilities.

Pipe Size and Pressure Class Determination

Determination of pipe pressure classifications for the phased project was done in accordance with the procedure described previously for Base Project determinations.

The pipe sizes, pressure class and corresponding length required for the phasing of each hydraulic alternative are summarized in Table 8, *Summary of Pipe Size and Pressure Class – Phased Project*.

TABLE 8 – Summary of Pipe Size and Pressure Class – Phased Project

Dia. (in.)	Pressure Class	LENGTH OF PIPING (ft)			
		ALT.1P-A	ALT.1P-B	ALT.2P-A	ALT.2P-B
36	100	-	-	26506	-
33	100	-	-	15536	-
30	300	62893	-	16693	16693
	250	10259	14418	3292	3292
	200	-	58734	-	-
	100	-	-	11126	53168
27	250	-	2523	-	-
	200	-	16373	-	-
	150	-	45281	-	-
	100	-	18070	-	-
24	300	11407	-	2523	2523
	250	7488	-	8884	8884
	200	23835	-	24166	24166
	150	5937	-	13094	13094
	100	-	5038	-	-
20	150	33579	-	15509	15509
	100	5038	-	23108	23108
18	100	2961	2961	2961	2961
14	300	27425	-	11277	11277
	250	3018	27425	16149	16149
	200	-	-	3018	3018
	150	-	3018	-	-
Totals		193841	193841	193841	193841

Required Pumping Facilities

The required pumping facilities for each phased project hydraulic design alternative were evaluated. The resulting pumping requirements associated with each phased alternative is summarized in Table 5, *Summary of Pumping Requirements – Phased Project*.

TABLE 9 – Summary of Pumping Requirements – Phased Project⁽¹⁾

	ALT.1P-A	ALT.1P-B	ALT.2P-A	ALT.2P-B	
				WTP PS	Remote PS
Pump Head (ft)	545	375	522	45	522
Flow (mgd)	14.00	14.00	12.0	14.0	12.0
Required hp	1910	1320	1570	160	1570

⁽¹⁾Reported values represent ultimate demand distributions (year 2012 operation) and are based on a phased project capacity of 15,683 acft/yr –the maximum capacity of Alternative 1.

Required System Storage

Because it is a unique component of some hydraulic design alternatives evaluated, the additional storage that may be required at remote pumping facilities was considered. As a result of project expansion, the assumption for minimum storage required at a remote pumping facility was increased from 0.25 million gallons to 0.50 million gallons.

Phased Project Relative Cost Comparison

In accordance with the *Cost Basis* for comparison of the hydraulic alternatives, the phased project hydraulic alternatives were evaluated. The cost comparison is tabulated in Table 10, *Delivery System – Relative Cost Comparison, Phased Project Capacity*. The non-cost factors relevant to the established project decision criteria are also included.

TABLE 10 – Delivery System – Relative Cost Comparison, Phased Project Capacity

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alt. 1P-A	Alt. 1P-B	Alt. 2P-A	Alt. 2P-B
Capital Costs				
Transmission Pipelines	\$ 18,368,000	\$ 18,639,000	\$ 16,914,000	\$ 15,941,000
WTP Pump Station	\$ 2,385,000	\$ 1,727,000	-	\$ 558,000
Booster Pump Station	-	-	\$ 2,044,000	\$ 2,044,000
System Storage	-	-	\$ 399,000	\$ 399,000
Electrical Feed	\$ 239,000	\$ 165,000	\$ 196,000	\$ 216,000
Total Capital Cost ⁽²⁾	\$ 20,992,000	\$ 20,531,000	\$ 19,553,000	\$ 19,158,000
Add'l Land Acquisition (PS and Storage Tank)	-	-	\$ 7,000	\$ 7,000
Total Project Cost ⁽²⁾	\$ 20,992,000	\$ 20,531,000	\$ 19,560,000	\$ 19,165,000
Annual O&M Costs				
Annual Debt Service (Assuming 25 years, effective interest rate of 6.5%)	\$ 1,721,000	\$ 1,684,000	\$ 1,604,000	\$ 1,572,000
Pumping Costs	\$ 999,000	\$ 688,000	\$ 821,000	\$ 903,000
Operation and Maintenance ⁽³⁾				
Pump Station	\$ 54,000	\$ 39,000	\$ 489,000	\$ 65,000
Transmission Facilities	\$ 184,000	\$ 186,000	\$ 196,000	\$ 159,000
Storage Facilities	-	-	\$ 195,600	\$ 4,000
Total Annual Cost ⁽⁴⁾	\$ 2,958,000	\$ 2,597,000	\$ 3,305,600	\$ 2,703,000
Non-Cost Factors				
WTP Location (Elev.)	+	+	-	NA
O&M Staffing Location	+	+	-	-
Control Complexity	+	+	-	-

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative. For comparison purposes, costs are based on a Phased Project production of 15,683 acft/yr - the maximum capacity of Alternative 1 (Alt. 1P-A and Alt. 1P-B).

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include: Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction.

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks; 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations.

Although Alternative 1P-B is the least expensive alternative, it should be noted that it significantly violates hydraulic constraints established for the project during base project operation. It is therefore not recommended as a feasible design alternative for the GBRA Regional System.

Conclusion and Recommendations

Based on both cost and non-cost factors established and a maximum system pressure of 300 psi as the project decision criteria, we recommend Alternative 1P-A. This alternative would entail a single high service pump station at the WTP, and allow phasing to full expansion by increasing the pump head. Installation of higher pressure class pipe would be required to permit phasing. Alternative 1P-A was recommended for the following reasons:

- The relative cost comparison has shown Alternative 1P-A to be comparable to the other alternatives, within less than 10% of the least expensive feasible alternative for phased expansion.
- Pumping to all delivery points allows flexibility in location of the WTP.
- The single pump station located on the WTP site allows convenience for O&M staffing and decreases the complexity of control required for the overall system.
- All established hydraulic criteria and constraints are satisfied for both the base and phased project conditions.

It should be noted that the reported additional cost for phased expansion, Alternative 1P-A, incorporates capital pump and O&M costs during expanded operation. This value is not the cost incurred initially since much of the expanded facilities would not be needed until expansion occurs. The initial project costs would incorporate only the capital costs of the increased pressure class of the pipelines. The required increase in pressure class piping between the base and phased projects has been tabulated for comparative reference in Table 11, *Increase in Pressure Class Piping for Alt. 1P-A*. The estimated cost for the increased pressure class of the transmission pipeline is approximately \$1.7 Million.

TABLE 11 – Increase in Pressure Class Piping for Alt. 1P-A

Dia. (in.)	Pressure Class	LENGTH OF PIPING (ft)	
		ALT.1	ALT.1P-A
30	300	-	62893
	250	46647	10259
	200	26506	-
24	300	-	11407
	250	11407	7488
	200	31323	23835
	150	5937	5937
20	150	33579	33579
	100	5038	5038
18	100	2961	2961
14	300	-	27425
	250	27425	3018
	200	3018	-
Totals		193841	193841


It should be noted that this recommendation is specifically based on the 300 psi maximum pressure assumption, synonymous with reduced operation, maintenance, and control issues associated with a single pumping facility located at the WTP. Re-evaluation of the system is warranted if multiple pumping facilities is preferable to higher system pressures.

ALTERNATIVE 1

Single High Service Pump Station at WTP Pump to All Delivery Points


Base & Alt 1P-A Diameter

Alt 1P-B Diameter



ALTERNATIVE 3

Gravity from WTP to BMWWD
Remote Pump Station at Junction to Boerne
Pump to Boerne



GBRA Regional Water System



SYSTEM MAP

Transmission Line
Alignment (Alternate Route)

JOHNSON RANCH
DOUBLE J RANCH
LOST CREEK

TAPATIO SPRINGS
FERRILL CO. UTILITY


THE OLSON RANCH

BERNARD TRACT OF WEST CO.

SAVINGS WELL



GBRA Regional Water System



TM No. 1 Appendix

Background and Working Information

GBRA REGIONAL WATER SYSTEM

ALTERNATIVES FOR CONVEYANCE OF POTABLE WATER FROM THE WTP TO GBRA PROJECT CUSTOMERS

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alternative 1	Alternative 2	Alternative 3
Capital Costs			
Transmission Pipelines	\$ 16,621,000	\$ 15,589,000	\$ 16,866,000
WTP Pump Station	\$ -	\$ -	\$ 968,000
Booster Pump Station	\$ 1,263,000	\$ -	\$ -
System Storage	\$ -	\$ 1,299,000	\$ 1,168,000
Electrical Feed	\$ -	\$ 282,000	\$ 282,000
	\$ 114,000	\$ 118,000	\$ 104,000
Total Capital Cost ⁽²⁾	\$ 17,998,000	\$ 17,288,000	\$ 19,388,000
Add'l Land Acquisition (PS and Storage Tank)	\$ -	\$ 6,800	\$ 6,800
Total Project Cost ⁽²⁾	\$ 17,998,000	\$ 17,295,000	\$ 19,395,000
Annual O&M Costs			
Annual Debt Service	\$ 1,476,000	\$ 1,418,000	\$ 1,590,000
(Assuming 25 years, effective interest rate of 6.5%)			
Pumping Costs (Initial Demands)	\$ 478,000	\$ 494,000	\$ 412,000
(Ultimate Demands)	\$ 478,000	\$ 458,000	\$ 434,000
(ave)	\$ 478,000	\$ 476,000	\$ 423,000
Operation and Maintenance ⁽³⁾			
Pump Station	\$ 28,000	\$ 32,000	\$ 29,000
Transmission Facilities	\$ 166,000	\$ 156,000	\$ 169,000
Storage Facilities	\$ -	\$ 2,800	\$ 2,800
Total Annual Cost ⁽⁴⁾	\$ 2,148,000	\$ 2,085,000	\$ 2,214,000
Non-Cost Factors			
WTP Location (Elev.)	+	-	-
O&M Staffing Location	+	-	-
Control Complexity	+	-	-

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction.

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks, 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations

Description of Alternatives

Alt. 1 - Single high service pump station at WTP (route along Rd 46).

Alt. 2 - Gravity from WTP to west of Hwy 281 along Rd 46 to remote pump station, pump to Boerne and BMWWD.


Alt. 3 - Gravity from WTP to BMWWD (route along Smithson Valley Rd), including gravity branch to Rd s 281/46 customers. Remote pump station at/near junction to Boerne, pump to Boerne

5/23/00,alts.xls
r:\07081033\hyd

DESCRIPTION OF ALTERNATIVES

BASE PROJECT (Meet Current Contracts)

PHASED PROJECT (Provide for Expansion)



Pumping Costs

Equation for pumping/energy costs (assumes continuous operation)

$$\left(\frac{Q(\text{mgd}) \times 694.4 \times \frac{gpm}{mgd} \times H(f)}{3960 \times 0.70} \right) \times 0.746 \frac{kw}{hp} \times 8760 \frac{hrs}{yr} \times 0.08 \frac{\$}{kWh} = \text{Cost } \$/yr$$

where
overall efficiency = 0.7
energy rate (\$/kWh) = 0.08

ALTERNATIVE 1

-Involves a single high service pumping station to Boerne

	Initial Demand	Ultimate Demand
Pump Head (ft)=	370	370
Flow, Q (mgd)=	9.87	9.87
Pump hp =	910	910
Est PS Capital Cost (mil \$)=	1.26	1.26
O&M Energy Cost (\$/yr)=	\$ 478,119	\$ 478,119
Power Connection Cost (\$)=	\$ 113,750	\$ 113,750

ALTERNATIVE 2

-Involves a remote pumping station located near west of Rd 281 along Rd. 46, pumping to Boerne and BMW

	Initial Demand	Ultimate Demand
Pump Head (ft)=	398	400
Flow, Q (mgd)=	9.49	8.75
Pump hp =	940	880
Est PS Capital Cost (mil \$)=	1.30	1.23
O&M Energy Cost (\$/yr)=	\$ 493,921	\$ 457,965
Power Connection Cost (\$)=	\$ 117,500	\$ 110,000

ALTERNATIVE 3

-Involves a remote pumping station located near the junction to Boerne, pumping to Boerne only

	Initial Demand	Ultimate Demand
Pump Head (ft)=	500	506
Flow, Q (mgd)=	6.28	6.56
Pump hp =	790	830
Est PS Capital Cost (mil \$)=	1.12	1.17
O&M Energy Cost (\$/yr)=	\$ 411,733	\$ 434,020
Power Connection Cost (\$)=	\$ 98,750	\$ 103,750

HDR ENGINEERING, INC

ENR= 6039 6127
Values from 2nd quarter, 1999
Values from last quarter, 1999

Pumping Station Costs

(hp)	(mil\$)	(mil\$)
<400	0.55	0.56
400	0.65	0.66
1000	1.35	1.37
2000	2.45	2.49
3000	3.38	3.43
4000	4.08	4.14
5000	4.61	4.68
6000	5.04	5.11
7000	5.47	5.55
8000	5.76	5.84
9000	6.04	6.13
10000	6.3	6.39
15000	7.28	7.39
3000	9.23	9.36
60000	12.01	12.19
80000	13.05	13.24
100000	13.98	14.18

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report

Costs for pumping stations include costs for pumps, housing, motors, electrical control, site work, and all materials needed.

$$\text{PowerConn } (\$50,000/\text{min}) = \frac{\$125}{1hp} \times \text{Stationhp}$$

Costs for electrical power connection include the distance to the nearest power source and the electrical demand of the pumping station. The following equation was developed to estimate power connection costs.

	ALT. 1	ALT. 2	ALT. 3
Pump Head (ft)	370	399	503
Flow (mgd)	9.87	9.12	6.42
Required hp	910	910	810

5/23/00,alts.xls
r 107081033hyd

Pipe Material/Installation Costs

ALTERNATIVE 1

Dia. (in.)	Pressure Class	Length (ft.)	\$/LF	Cost, \$
30	250	46647	117	5438782
	200	26506	103	2734908
24	250	11407	91	1034469
	200	31323	80	2513755
	150	5937	71	421663
20	150	33579	63	2112267
	100	5038	63	316888
18	100	2961	60	177233
14	300	0	70	0
	250	27425	62	1705426
	200	3018	55	166086
checks		193841		

TOTAL= \$ 16,621,477

ALTERNATIVE 2

Dia. (in.)	Pressure Class	Length (ft.)	\$/LF	Cost, \$
30	250	16693	117	1946288
	200	3292	103	339650
	100	53168	91	4854832
24	250	11407	91	1034469
	200	31323	80	2513755
	150	5937	71	421663
20	150	33579	63	2112267
	100	5038	63	316888
18	100	2961	60	177233
14	300	0	70	0
	250	27425	62	1705426
	200	3018	55	166086
	150	0	49	0
checks		193841		

TOTAL= \$ 15,588,557

ALTERNATIVE 3

Dia. (in.)	Pressure Class	Length (ft.)	\$/LF	Cost, \$
36	150	45003	120	5387788
	100	21777	120	2607099
27	150	21002	81	1704635
	100	3018	81	244965
24	250	11407	91	1034469
	200	31323	80	2513755
	150	5937	71	421663
20	150	33579	63	2112267
	100	5038	63	316888
18	100	2961	60	177233
16	150	6423	54	345403
10	100	20265	40	810618
8	100	4133	38	157057
checks		211868		

TOTAL= \$ 17,833,839

(gravity branch to 281/46 alone)= \$ 967,675

(All w/o gravity branch)= \$ 16,866,164

length (ft)

211868

24399

181046

Assumes 13% increase per 50 psi pressure class above 150 psi.

ENR= 6039 (June 1999)

Pipeline Costs for Rock in Rural Areas					
	100 psi	150 psi	200 psi	250 psi	300 psi
Pipe Dia (in.)	\$/ft	\$/ft	\$/ft	\$/ft	\$/ft
12	42	42	47	54	61
14	48	48	54	61	69
16	53	53	60	68	76
18	59	59	67	75	85
20	62	62	70	79	89
24	70	70	79	89	101
27	80	80	90	102	115
30	90	90	102	115	130
33	104	104	118	133	150
36	118	118	133	151	170

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

Costs for piping are for installed piping and appurtenances, including markers, valves, thrust restraint systems, corrosion monitoring and control equipment, air vacuum valves, blow-off valves, erosion control, revegetation of ROW, fencing, and gates. Costs do not include crossings.

ENR= 6127 (Dec. 1999)

Pipeline Costs for Rock in Rural Areas					
	100 psi	150 psi	200 psi	250 psi	300 psi
Pipe Dia (in.)	\$/ft	\$/ft	\$/ft	\$/ft	\$/ft
12	43	43	48	54	61
14	49	49	55	62	70
16	54	54	61	69	78
18	60	60	68	76	86
20	63	63	71	80	91
24	71	71	80	91	102
27	81	81	92	104	117
30	91	91	103	117	132
33	106	106	119	135	152
36	120	120	135	153	173

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

Storage Costs

Look at storage costs in addition to tank used for equilization (Equilization tank is same for all alternatives and is not included in cost comparison)

ALTERNATIVE 1

-Involves a single high service pumping station to Boerne
No additional system storage is required.

ALTERNATIVE 2

-Involves a remote pumping station located near west of Rd. 281 along Rd. 46, pumping to Boerne and BMW.D.

Assume required system storage at booster PS(MG)= 0.25
Ground Storage Tank (\$) = \$ 282,470
Req'd Land Acquisition (acres)= 4 (pump station and tank)
Land value (\$/acre)= \$ 1,700 (1999 value)
Req'd Land Acquisition Cost (\$) = \$ 6,800

ALTERNATIVE 3

-Involves a remote pumping station located near the junction to Boerne, pumping to Boerne only

Assume required system storage at booster PS(MG)= 0.25
Ground Storage Tank (\$) = \$ 282,470
Req'd Land Acquisition (acres)= 4 (pump station and tank)
Land value (\$/acre)= \$ 1,700 (1999 value)
Req'd Land Acquisition Cost (\$) = \$ 6,800

	Values from 2nd quarter, 1999	Values from last quarter, 1999
ENR=	6039	6127
Ground Storage Tank Costs		
(MG)	(\$)	(\$)
0.01	86400	87659
0.05	146400	148533
0.1	209300	212350
0.5	393600	399336
1	679100	688996
2	1129300	1145756
4	1768600	1794372
6	2408000	2443089
7.5	2926600	2969246
9	329920	334728

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

MODEL OUTPUT -High Service Pump Station at WTP

Location	Model Node	Model Piping	Node El (ft)	Pipe Dia (in)	Pipe Length (ft)	Sum Length (ft)	Initial			Ultimate			Max Pipe Pressure Class	
							ΔQ (mgd)	v(fps)	HGL (ft)	Press Head (psi)	ΔQ (mgd)	v(fps)		HGL (ft)
Reservoir (WTP)	R-1		1380		0	0			1750			1750		
Reservoir (WTP)	J-1	P-1	1380	30	139.3	139	9.87	3.1	1749.8	160.1	9.87	3.1	1749.8	160.1
Reservoir (WTP)	RV-1	P-5	1380	30	142.9	282	0.00	0.0	1750	0.0	0.00	0.0	1750	0.0
Flow Control Element	J-5	P-4	1380	30	100.5	383	-9.87	0.0	1749.8	160.1	-9.87	0.0	1749.8	160.1
High Point	J-16	P-25	1398	30	208.0	591	0.00	3.1	1749.6	152.2	0.00	3.1	1749.6	152.2
High Point	J-25	P-16	1385	30	2804.6	3395	0.00	3.1	1746.2	156.4	0.00	3.1	1746.2	156.4
High Point	J-7	P-26	1310	30	8877.0	12272	0.00	3.1	1735.6	184.3	0.09	3.1	1735.6	184.3
Curtis Bremer Feed	J-26	P-7	1321	30	7369.4	19642	0.00	3.1	1726.8	175.7	0.00	3.1	1726.8	175.7
High Point	J-9	P-27	1299	30	4657.5	24299	0.05	3.1	1721.2	182.8	0.05	3.1	1721.4	182.9
CISD School Feed	J-27	P-9	1320	30	2206.4	26506	0.00	3.1	1718.5	172.6	0.00	3.1	1718.9	172.7
High Point	J-8	P-28	1205	30	15536.1	42042	0.09	3.1	1700.1	214.4	0.19	3.1	1700.7	214.6
Apex Feed	J-10	P-8	1137	30	2059.6	44101	0.19	3.1	1697.7	242.8	0.74	3.0	1698.4	243.1
Craig Elbel, Double J Ranch, (C J-10)	J-11	P-10	1160	30	2073.4	46175	0.05	3.0	1695.4	231.8	0.05	2.8	1696.4	232.3
CISD School Feed	J-12	P-11	1321	30	10284.8	56460	0.00	3.0	1683.9	157.1	0.00	2.8	1686.6	158.3
High Point	J-3	P-12	1165	30	16692.6	73152	0.05	3.0	1665.3	216.6	0.05	2.8	1670.5	218.9
CISD School Feed	J-28	P-2	2523.0	24	8884.3	75675	0.00	3.0	1661.5	234.9	0.00	3.2	1666.5	237.1
Low Point	J-13	P-29	1177	24	8884.3	84559	0.00	3.0	1648.2	204.0	0.00	3.2	1652.1	205.7
Low Point	J-14	P-13	1279	24	7488.4	92048	0.00	3.0	1637	155.0	0.00	3.2	1639.9	156.3
High Point	J-15	P-14	1247	24	16677.7	108725	0.09	3.0	1612	158.0	0.21	3.2	1612.9	158.4
Murcia Feed (low point)	J-6	P-15	1329	24	7157.0	115882	0.00	3.0	1601.6	118.0	0.00	3.1	1601.9	118.2
High Point	J-17	P-6	1280	24	5937.2	121820	0.38	3.0	1592.9	135.5	0.94	3.1	1592.9	135.5
Cordillera Feed (low point)	J-18	P-17	1260	20	15509.4	137329	0.75	4.1	1544.1	123.0	1.31	3.8	1550.3	125.7
Fair Oaks Feed	J-19	P-18	1416	20	18070.1	155399	0.00	3.5	1500.3	36.5	0.09	2.8	1520.9	45.4
High Point	J-20	P-19	1405	20	5037.7	160437	0.47	3.5	1488.1	36.0	1.74	2.8	1513.1	46.8
Boerne Feed	J-21	P-20	1405	18	134.0	160571	0.14	3.9	1487.6	35.8	0.47	1.9	1512.9	46.7
Tapator/Kendall Co Utility Co	J-2	P-21	1450	18	2826.8	163398	4.36	3.8	1478.7	12.4	1.70	1.5	1511.4	26.6
SAWS Feed	J-22	P-3	1080	14	6423.4	169821	0.19	4.7	1625	236.0	0.19	3.2	1650.3	246.9
Bulverde Hills	J-23	P-22	1061	14	4853.1	174674	0.00	4.4	1597.8	232.4	0.00	3.0	1637.4	249.6
Low Point	J-24	P-23	1185	14	16148.8	190823	0.05	4.4	1507.2	139.5	0.05	3.0	1594.2	177.2
SARA Feed	J-4	P-24	1320	14	3018.1	193841	3.01	4.4	1490.7	73.9	2.00	2.9	1586.5	115.4
Bexar MWD Feed														
		</												

distance from high pt (El 1321) to Boerne junct

53510 ft

10.1 mi

Location	Model Node	Model Piping	Node El (ft)	Pipe Dia (in)	Pipe Length (ft)	Sum Length (ft)	ΔQ (mgd)	v(fps)	HGL (ft)	Press Head (psi)
CISD School Feed	J-3	P-12	1165	30	1665.3	0	0.047	3	1665.3	216.63
Bulverde Hills	J-22	P-3	1080	14	6423.433	6423.4	0.189	4.7	1625	235.985
Low Point	J-23	P-22	1061	14	4853.106	11276.5	0	4.4	1597.8	232.434
SARA Feed	J-24	P-23	1185	14	16148.8	27425.3	0.047	4.4	1507.2	139.513
Bexar MWD Feed	J-4	P-24	1320	14	3018.077	30443.4	3.014	4.4	1490.7	73.9131

GRAVITY CONVEYANCE FROM WTP TO WEST OF RD 281 ALONG RD 46 TO REMOTE PUMP STATION, PUMP TO BOERNE AND BMWWD

Assume required system storage at booster PS(MG)= 0.25
C= 120

Mainline (Gravity)

Junct	EL (ft)	Dia (in.)	Pipe Length (ft)	Sum Length (ft)	Initial Q (mgd)	Initial v (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate v (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
Reservoir (WTP)	1380			0	9.87			1380		9.87					
High Point	1398	30	591	591	9.867	3.12	0.71	1379.3	-8.1	9.867	3.12	0.71	1379.3	-8.1	100
High Point	1385	30	2805	3395	9.867	3.12	3.38	1375.9	-3.9	9.867	3.12	3.38	1375.9	-3.9	100
Curtis Bremer Feed	1310	30	8877	12272	9.867	3.12	10.71	1365.2	23.9	9.773	3.09	10.52	1365.4	24.0	100
High Point	1321	30	7369	19642	9.867	3.12	8.89	1356.3	15.3	9.773	3.09	8.74	1356.6	15.4	100
CISD School Feed	1299	30	4658	24299	9.820	3.10	5.57	1350.7	22.4	9.726	3.07	5.47	1351.2	22.6	100
High Point	1320	30	2206	26506	9.820	3.10	2.64	1348.1	12.2	9.726	3.07	2.59	1348.6	12.4	100
Apex Feed	1205	30	15536	42042	9.726	3.07	18.26	1329.8	54.1	9.539	3.01	17.61	1331.0	54.5	100
Craig Elbel Double J	1137	30	2060	44101	9.533	3.01	2.33	1327.5	82.5	8.795	2.78	2.01	1329.0	83.1	100
CISD School Feed	1160	30	2073	46175	9.486	3.00	2.33	1325.2	71.5	8.748	2.76	2.00	1327.0	72.3	100
Remote Pump Sta	1290	30	6993	53168	9.486	3.00	7.85	1317.3	11.8	8.748	2.76	6.75	1320.2	13.1	100

53168 ft
10.1 mi

Pump from remote pump station to BMWWD and Boerne (same as Alt. 1 from remote pump station to Boerne and BMWWD)

Junct	EL (ft)	Dia (in.)	Pipe Length (ft)	Sum Length (ft)	Initial ΔQ (mgd)	Initial v (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate ΔQ (mgd)	Ultimate v (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
Remote Pump Sta	1290			53168				1687.6		0.000					
High Point	1321	30	3292	56460	0.000	3.0	3.7	1683.9	157.1	0.000	2.8		1686.6	158.3	200
CISD School Feed	1165	30	16693	73152	0.047	3.0	18.6	1665.3	216.6	0.047	2.8	16.1	1670.5	218.9	250
Low Point	1119	24	2523	75675	0.000	3.0	3.8	1661.5	234.9	0.000	3.2	4.0	1666.5	237.1	250
Low Point	1177	24	8884	84559	0.000	3.0	13.3	1648.2	204.0	0.000	3.2	14.4	1652.1	205.7	250
High Point	1279	24	7488	92048	0.000	3.0	11.2	1637.0	155.0	0.000	3.2	12.2	1639.9	156.3	200
Murcia Feed (low poin	1247	24	16678	108725	0.094	3.0	25.0	1612.0	158.0	0.206	3.2	27.0	1612.9	158.4	200
High Point	1329	24	7157	115882	0.000	3.0	10.4	1601.6	118.0	0.000	3.1	11.0	1601.9	118.2	200
Cordillera Feed (low p	1280	24	5937	121820	0.375	3.0	8.7	1592.9	135.5	0.937	3.1	9.0	1592.9	135.5	150
Fair Oaks Feed	1260	20	15509	137329	0.750	4.1	48.8	1544.1	123.0	1.312	3.8	42.6	1550.3	125.7	150
High Point	1416	20	18070	155399	0.000	3.5	43.8	1500.3	36.5	0.094	2.8	29.4	1520.9	45.4	150
Boerne Feed	1405	20	5038	160437	0.469	3.5	12.2	1488.1	36.0	1.744	2.8	7.8	1513.1	46.8	100
Tapatio/Kendall Co U	1405	18	134	160571	0.141	3.9	0.5	1487.6	35.8	0.469	1.9	0.2	1512.9	46.7	100
SAWS Feed	1450	18	2827	163398	4.362	3.8	8.9	1478.7	12.4	1.699	1.5	1.5	1511.4	26.6	100
Bulverde Hills	1080	14	6423	169821	0.189	4.7	40.3	1625.0	236.0	0.189	3.2	20.2	1650.3	246.9	250
Low Point	1061	14	4853	174674	0.000	4.4	27.2	1597.8	232.4	0.000	3.0	12.9	1637.4	249.6	250
SARA Feed	1185	14	16149	190823	0.047	4.4	90.6	1507.2	139.5	0.047	3.0	43.2	1594.2	177.2	250
Bexar MWD Feed	1320	14	3018	193841	3.014	4.4	16.5	1490.7	73.9	2.004	2.9	7.7	1586.5	115.4	200

140673 ft
26.6 mi

193841 ft
36.7 mi

Junct	EL (ft)	Dia (in.)	Pipe Length (ft)	Sum Length (ft)	Initial ΔQ (mgd)	Initial v (fps)	HL (ft)	HGL (ft)	Press Head (psi)
CISD School Feed	1165	30		0	0.047	3.0	18.6	1665.3	216.6
Bulverde Hills	1080	14	6423	6423	0.189	4.7	40.3	1625.0	236.0
Low Point	1061	14	4853	11277	0.000	4.4	27.2	1597.8	232.4
SARA Feed	1185	14	16149	27425	0.047	4.4	90.6	1507.2	139.5
Bexar MWD Feed	1320	14	3018	30443	3.014	4.4	16.5	1490.7	73.9

GRAVITY CONVEYANCE FROM WTP TO BMWWD, ALONG SMITHSON VALLEY ROAD

Assume required system storage at booster PS(MG)= 0.25
C= 120

Mainline (Gravity)

Junct	Pipe	El (ft)	Dia (in)	Length (ft)	Length from WTP (ft)	Initial Q (mgd)	Initial V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
WTP	P-16	1380	36	3395	3395	9.87	2.16	1.69	1380	-2.9	9.87	2.16	1.69	1380	-2.9	100
High point	P-26	1385	36	8877	12272	9.87	2.16	4.41	1378.3	27.7	9.87	2.16	4.33	1378.0	27.7	100
Cutts Brenner	P-7	1321	36	7369	19642	9.87	2.16	3.66	1370.2	21.4	9.87	2.14	3.60	1370.4	21.4	100
low point	P-27	1267	36	2135	21777	9.87	2.16	1.06	1369.2	44.2	9.87	2.14	1.04	1369.3	44.3	100
Bulverde junct.	P-31	1080	36	45003	66780	9.39	2.06	20.42	1348.8	116.4	8.85	1.90	17.55	1351.8	117.7	150
low point	P-22	1081	27	4853	71633	3.06	1.19	1.12	1347.6	124.1	2.05	0.80	0.53	1351.3	125.7	150
SABA Feed	P-23	1185	27	16149	87782	3.06	1.19	3.73	1343.9	68.8	2.05	0.80	1.78	1348.5	71.2	100
BMWWD	P-24	1320	27	3018	90800	3.01	1.17	0.68	1343.2	10.1	2.00	0.78	0.32	1349.2	12.6	100

Velocity criteria (2 fps min) is not satisfied within
69023 ft
13.1 mi

Line to Customers near Rd 281 and 46 Intersection (Gravity)

Junct	Pipe	El (ft)	Dia (in)	Length (ft)	Length from WTP (ft)	Initial Q (mgd)	Initial V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
CISD	P-10	1289	10	2523	22165	0.48	1.35	2.33	1366.8	29.4	1.12	3.18	11.38	1358.0	25.5	100
high point	P-10	1320	10	2206	24371	0.38	1.08	1.36	1365.5	19.7	1.03	2.91	8.46	1349.5	12.8	100
Apex	P-10	1205	10	15536	39907	0.38	1.08	9.55	1355.9	65.4	1.03	2.91	59.56	1289.9	36.8	100
Elbet Double J	P-10	1137	8	2060	41967	0.29	1.27	2.22	1353.7	93.8	0.84	3.72	16.11	1273.8	59.2	100
Johnson, Lost Owl	P-10	1160	8	2073	44040	0.09	0.42	0.28	1353.4	83.8	0.09	0.42	0.28	1273.5	49.2	100
CISD	P-10	1165	8	24398	68438	0.09	0.42	15.74	1348.8	116.4	0.09	0.42	15.74	1273.3	46.9	150

From Bulverde Junction to Boerne Junction (Gravity)

Junct	Pipe	El (ft)	Dia (in)	Length (ft)	Length from WTP (ft)	Initial Q (mgd)	Initial V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
Bulverde junct	P-31	1080	36	6423	73204	6.33	7.03	72.64	1276.1	48.1	6.60	7.33	78.51	1273.3	46.9	150
Boerne junct.	P-31	1165	16	6423	79627	6.33	7.03	72.64	1276.1	48.1	6.60	7.33	78.51	1273.3	46.9	150

From Bulverde Junction to Boerne (same as Alt. 1 from Junction to Boerne) (Pumped)

Junct	Pipe	El (ft)	Dia (in)	Length (ft)	Length from WTP (ft)	Initial Q (mgd)	Initial V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
CISD School Feed	P-12	1165	12	73204	73204	0.05	3.00	3.8	1663.3	218.6	0.05	3.20	4.0	1666.5	218.9	250
Low Point	P-2	1119	24	2523	75727	0.00	3.00	3.8	1663.3	218.6	0.00	3.20	4.0	1666.5	218.9	250
High Point	P-29	1177	24	8884	84611	0.00	3.00	13.3	1648.2	204.0	0.00	3.20	14.4	1652.1	205.7	250
Murcia Feed (low point)	P-13	1279	24	7488	92099	0.00	3.00	11.2	1637	155.0	0.00	3.20	12.2	1639.9	156.3	200
High Point	P-14	1247	24	16678	108777	0.09	3.00	25.0	1612	158.0	0.21	3.20	22.0	1612.9	158.4	200
Cordillera Feed (low point)	P-15	1329	24	7157	115934	0.00	3.00	10.4	1601.6	118.0	0.00	3.10	11.0	1601.9	118.2	200
Fair Oaks Feed	P-6	1280	24	5937	121871	0.38	3.00	8.7	1592.9	135.5	0.94	3.10	9.0	1592.9	135.5	150
High Point	P-17	1260	20	15509	137381	0.75	4.10	46.8	1544.1	123.0	1.31	3.80	42.6	1550.3	125.7	150
Boerne Feed	P-18	1416	20	18070	155451	0.00	3.50	43.8	1500.3	36.5	0.09	2.80	29.4	1520.9	45.4	150
Tapato/Kendall Co Utility Co.	P-19	1405	20	5038	160489	0.47	3.50	12.2	1488.1	36.0	1.74	2.80	7.8	1513.1	46.8	100
SAWS Feed	P-20	1405	18	134	160822	0.14	3.90	0.5	1487.6	35.8	0.47	1.90	0.2	1512.9	46.7	100
	P-21	1450	18	2827	163449	4.36	3.80	8.9	1478.7	12.4	1.70	1.50	1.5	1511.4	26.6	100

distance from high pt (El 1321) to Boerne junct
53562 ft
10.1 mi
211868 ft (project total)
40.1 mi
187489 ft (project total without approach main to 281/46)
35.5 mi

Junct	Pipe	El (ft)	Dia (in)	Length (ft)	Length from WTP (ft)	Initial Q (mgd)	Initial V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Ultimate Q (mgd)	Ultimate V (fps)	HL (ft)	HGL (ft)	Press Head (psi)	Max Pipe Pressure Class
Boerne junct.	P-31	1080	36	6423	6423	9.392	2.05479	20.41583	1349	116.3735	9.392	2.05479	20.41583	1349	116.3735	150
Bulverde junct.	P-22	1061	27	4853	106	11277	3.061	1193274	1121697	1348	11277	3.061	1193274	1121697	1348	124.1148
low point	P-23	1185	27	16148	8	27425	3.061	1193274	3732465	1344	27425	3.061	1193274	3732465	1344	68.80866
SABA Feed	P-24	1320	27	3018	077	30443	3.014	1174952	0.677882	1343	30443	3.014	1174952	0.677882	1343	10.05814

HYDRAULIC MODEL

Base Condition

Piping	Node 1	Node 2	Length (ft)	Dia (in)	HW C-value	Initial		Ultimate		Pipe Pressure Class	
						Vel (fps)	Flow (mgd)	HL/1000 (ft/ft)	Vel (fps)	Flow (mgd)	HL/1000 (ft/ft)
P-1	R-1	J-1	139	30	120	3.1	9.9	1.20	3.1	9.9	1.2
P-10	J-10	J-11	2073	30	120	3	9.5	1.10	2.8	8.8	1
P-11	J-11	J-12	10285	30	120	3	9.5	1.1	2.8	8.7	1
P-12	J-12	J-3	16693	30	120	3	9.5	1.1	2.8	8.7	1
P-13	J-13	J-14	7488	24	120	3	6.2	1.5	3.2	6.5	1.6
P-14	J-14	J-15	16678	24	120	3	6.2	1.5	3.2	6.5	1.6
P-15	J-15	J-6	7157	24	120	3	6.1	1.5	3.1	6.3	1.5
P-16	J-16	J-25	2805	30	120	3.1	9.9	1.2	3.1	9.9	1.2
P-17	J-17	J-18	15509	20	120	4.1	5.7	3.1	3.8	5.3	2.7
P-18	J-18	J-19	18070	20	120	3.5	5	2.4	2.8	4	1.6
P-19	J-19	J-20	5038	20	120	3.5	5	2.4	2.8	3.9	1.6
P-2	J-3	J-28	2523	24	120	3	6.2	1.5	3.2	6.5	1.6
P-20	J-20	J-21	134	1	120	3.9	4.5	3.4	1.9	2.2	0.9
P-21	J-21	J-2	2827	120	120	3.8	4.4	3.2	1.5	1.7	0.6
P-22	J-22	J-23	4853	14	120	4.4	3.1	5.6	3	2.1	2.7
P-23	J-23	J-24	16149	14	120	4.4	3.1	5.6	3	2.1	2.7
P-24	J-24	J-4	3018	14	120	4.4	3	5.5	2.9	2	2.6
P-25	J-5	J-16	208	30	120	3.1	9.9	1.2	3.1	9.9	1.2
P-26	J-25	J-7	8877	30	120	3.1	9.9	1.2	3.1	9.9	1.2
P-27	J-26	J-9	4658	30	120	3.1	9.9	1.2	3.1	9.8	1.2
P-28	J-27	J-8	15536	30	120	3.1	9.8	1.2	3.1	9.7	1.2
P-29	J-28	J-13	8884	24	120	3	6.2	1.5	3.2	6.5	1.6
P-3	J-3	J-22	6423	14	120	4.7	3.3	6.3	3.2	2.2	3.1
P-4	RV-1	J-5	100	30	120	0	0	0	0	0	0
P-5	J-1	RV-1	143	30	120	0	0	0	0	0	0
P-6	J-6	J-17	5937	24	120	3	6.1	1.5	3.1	6.3	1.5
P-7	J-7	J-26	7369	30	120	3.1	9.9	1.2	3.1	9.8	1.2
P-8	J-8	J-10	2060	30	120	3.1	9.7	1.2	3	9.5	1.1
P-9	J-9	J-27	2206	30	120	3.1	9.8	1.2	3.1	9.7	1.2
Total			193841 ft 36.7 mi								

Variable System Characteristics

Node	Reference Pt.	EI (ft.)	Initial		Ultimate			
			Demand	Pressure	Demand	Pressure		
			(mgd)	HGL (ft)	(mgd)	HGL (ft)	(psi)	
J-1	Reservoir (WTP)	1380	9.867	1749.8	160.1	9.867	1749.8	160.1
J-10	Craig Elbel, Double J. Ranch, Clyde Johnson, Lost Owl	1137	0.193	1697.7	242.8	0.744	1698.4	243.1
J-11	CISD School Feed	1160	0.047	1695.4	231.8	0.047	1696.4	232.3
J-12	High Point	1321	0	1683.9	157.1	0	1686.6	158.3
J-13	Low Point	1177	0	1648.2	204.0	0	1652.1	205.7
J-14	High Point	1279	0	1637	155.0	0	1639.9	156.3
J-15	Murcia Feed (low point)	1247	0.094	1612	158.0	0.206	1612.9	158.4
J-16	High Point	1398	0	1749.6	152.2	0	1749.6	152.2
J-17	Cordillera Feed (low point)	1280	0.375	1592.9	135.5	0.937	1592.9	135.5
J-18	Fair Oaks Feed	1260	0.75	1544.1	123.0	1.312	1550.3	125.7
J-19	High Point	1416	0	1500.3	36.5	0.094	1520.9	45.4
J-2	SAWS Feed	1450	4.362	1478.7	12.4	1.699	1511.4	26.6
J-20	Boerne Feed	1405	0.469	1488.1	36.0	1.744	1513.1	46.8
J-21	Tapatio/Kendall Co. Utility Co	1405	0.141	1487.6	35.8	0.469	1512.9	46.7
J-22	Bulverde Hills	1080	0.189	1625	236.0	0.189	1650.3	246.9
J-23	Low Point	1061	0	1597.8	232.4	0	1637.4	249.6
J-24	SARA Feed	1185	0.047	1507.2	139.5	0.047	1594.2	177.2
J-25	High Point	1385	0	1746.2	156.4	0	1746.2	156.4
J-26	High Point	1321	0	1726.8	175.7	0	1726.9	175.8
J-27	High Point	1320	0	1718.5	172.6	0	1718.9	172.7
J-28	Low Point	1119	0	1661.5	234.9	0	1666.5	237.1
J-3	CISD School Feed	1165	0.047	1665.3	216.6	0.047	1670.5	218.9
J-4	Bexar MWD Feed	1320	3.014	1490.7	73.9	2.004	1586.5	115.4
J-5	Flow Control Element	1380	-9.867	1749.8	160.1	-9.867	1749.8	160.1
J-6	High Point	1329	0	1601.6	118.0	0	1601.9	118.2
J-7	Curtis Bremer Feed	1310	0	1735.6	184.3	0.094	1735.6	184.3
J-8	Apex Feed	1205	0.094	1700.1	214.4	0.187	1700.7	214.6
J-9	CISD School Feed	1299	0.047	1721.2	182.8	0.047	1721.4	182.9
R-1	Reservoir (WTP)	1380	9.87	1750		9.87	1750	
Total								

SIZE RW LINE FROM CANYON LAKE INTAKE PS TO WTP

Canyon Lake
Normal Pool Elev (ft)= 908
Min Pool Elev. (ft)= 808

C= 120
PS @ Intake, Head (ft)= 668

PS @ Intake, Head (ft)= 640

Future Phase, Q = 14 MGD										Initial Phase, Q = 9.9 MGD				
Junct.	Node El (ft)	Dia (in.)	Pipe Length (ft)	Profile Length (ft)	Sum Length (ft)	Full Q (mgd)	Full v(fps)	HL (ft)	HGL (ft)	Press.				
										Head (psi)				
				-25758	0	14.0			908					
Canyon Lake	921		0	-25758	0	14.0			1476					
High Point	1049	30	498	-25260	498	14.0	4.42	1.15	1474.9	184.3	9.87			
Low Point	970	30	1078	-24182	1576	14.0	4.42	2.48	1472.4	217.4	9.87			
High Point	983	30	1020	-23162	2596	14.0	4.42	2.35	1470.0	210.8	9.87			
Low Point	957	30	1559	-21603	4155	14.0	4.42	3.59	1466.4	220.6	9.87			
High Point	994	30	1965	-19638	6119	14.0	4.42	4.53	1461.9	202.8	9.87			
Low Point	967	30	2076	-17562	8196	14.0	4.42	4.79	1457.1	212.4	9.87			
High Point	1072	30	2331	-15231	10527	14.0	4.42	5.37	1451.7	164.6	9.87			
Low Point	1037	30	626	-14604	11153	14.0	4.42	1.44	1450.3	179.0	9.87			
High Point	1071	30	557	-14048	11710	14.0	4.42	1.28	1449.0	163.7	9.87			
Low Point	991	30	1921	-12126	13631	14.0	4.42	4.43	1444.6	196.5	9.87			
High Point	1393	30	12042	-84	25674	14.0	4.42	27.76	1416.8	10.1	9.87			
WTP	1391	30	84	0	25758	14.0	4.42	0.19	1416.6	11.2	9.87			
				0				59.38	1750					

GBRA REGIONAL WATER SYSTEM
ALTERNATIVES FOR PHASED DELIVERY FROM PROPOSED WTP TO GBRA PROJECT CUSTOMERS

Comparison of Alternatives 1P and 2P

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alt. 1P-A	Alt. 1P-B	Alt. 2P-A	Alt. 2P-B
Capital Costs				
Transmission Pipelines	\$ 18,368,000	\$ 18,639,000	\$ 16,914,000	\$ 15,941,000
WTP Pump Station	\$ 2,385,000	\$ 1,727,000	-	\$ 558,000
Booster Pump Station	-	-	\$ 2,044,000	\$ 2,044,000
System Storage	-	-	\$ 399,000	\$ 399,000
Electrical Feed	\$ 239,000	\$ 165,000	\$ 196,000	\$ 216,000
Total Capital Cost ⁽²⁾	\$ 20,992,000	\$ 20,531,000	\$ 19,553,000	\$ 19,158,000
Add'l Land Acquisition (PS and Storage Tank)	-	-	\$ 7,000	\$ 7,000
Total Project Cost ⁽²⁾	\$ 20,992,000	\$ 20,531,000	\$ 19,560,000	\$ 19,165,000
Annual O&M Costs				
Annual Debt Service (Assuming 25 years, effective interest rate of 6.5%)	\$ 1,721,000	\$ 1,684,000	\$ 1,604,000	\$ 1,572,000
Pumping Costs	\$ 999,000	\$ 688,000	\$ 821,000	\$ 903,000
Operation and Maintenance ⁽³⁾				
Pump Station	\$ 54,000	\$ 39,000	\$ 489,000	\$ 65,000
Transmission Facilities	\$ 184,000	\$ 186,000	\$ 196,000	\$ 159,000
Storage Facilities	-	-	\$ 195,600	\$ 4,000
Total Annual Cost ⁽⁴⁾	\$ 2,958,000	\$ 2,597,000	\$ 3,305,600	\$ 2,703,000
Non-Cost Factors				
WTP Location (Elev.)	+	+	-	NA
O&M Staffing Location	+	+	-	-
Control Complexity	+	+	-	-

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative. For comparison purposes, costs are based on a Phased Project production of 15,683 acft/yr - the maximum capacity of Alternative 1.

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include. Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks; 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations.

Description of Alternatives

Alt. 1: Single high service pump station at WTP (route along Rd 46)

Alt 1P-A. Add'l head to high service pump station at WTP (route along Rd 46)

Alt 1P-B Upsize diameters at west end of transmission line (furthest delivery points) by relaxing minimum velocity criteria

Alt 2 Gravity from WTP to west of Rd 281 along Rd 46 to remote pump station, pump to Boerne and BMWWD

Alt 2P-A Increase pipe size in gravity line to provide Max capacity of 14 mgd

Alt 2P-B Addition of booster pump station at WTP to provide Max capacity of 14 mgd

GBRA REGIONAL WATER SYSTEM
PHASED DELIVERY 9.9 MGD AND 14 MGD FROM PROPOSED WTP TO GBRA PROJECT CUSTOMERS

Alternative 1 - Single high service pump station at WTP.

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alt. 1		Alt. 1P-A		Alt. 1P-B	
	Initial Case, 9.9 MGD		Build Out, 14 MGD	Incremental Cost	Build Out, 14 MGD	Incremental Cost
Capital Costs						
Transmission Pipelines	\$ 16,621,000		\$ 18,368,000	\$ 1,747,000	\$ 18,639,000	\$ 2,018,000
WTP Booster Pump Station	\$ 1,263,000		\$ 2,385,000	\$ 1,122,000	\$ 1,727,000	\$ 464,000
Booster Pump Station	-		-	-	-	-
System Storage	-		-	-	-	-
Electrical Feed	\$ 114,000		\$ 239,000	\$ 125,000	\$ 165,000	\$ 51,000
Total Capital Cost ⁽²⁾	\$ 17,998,000		\$ 20,992,000	\$ 2,994,000	\$ 20,531,000	\$ 2,533,000
Annual O&M Costs						
Annual Debt Service <i>(Assuming 25 years, elective interest rate of 6.5%)</i>	\$ 1,476,000		\$ 1,721,000	\$ 245,000	\$ 1,684,000	\$ 208,000
Pumping Costs	\$ 478,000		\$ 999,000	\$ 521,000	\$ 688,000	\$ 210,000
Operation and Maintenance ⁽³⁾						
Pump Station	\$ 28,000		\$ 54,000	\$ 26,000	\$ 39,000	\$ 11,000
Transmission Facilities	\$ 166,000		\$ 184,000	\$ 18,000	\$ 186,000	\$ 20,000
Total Annual Cost ⁽²⁾	\$ 2,148,000		\$ 2,958,000	\$ 810,000	\$ 2,597,000	\$ 449,000

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative.

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include: Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction.

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks; 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations.

Description of Alternative/Options

Alt. 1. Single high service pump station at WTP (route along Rd 46).
 Alt 1P-A. Add'l head to high service pump station at WTP (route along Rd 46).
 Alt 1P-B. Upsize diameters at west end of transmission line (furthest delivery points) by relaxing minimum velocity criteria.

GBRA REGIONAL WATER SYSTEM

PHASED DELIVERY 9.9 MGD AND 14 MGD FROM PROPOSED WTP TO GBRA PROJECT CUSTOMERS

ALTERNATIVE 2 - Gravity from WTP to remote pump station at/near junction to Boerne, pump to Boerne.

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	Alt. 2		Alt. 2P-A		Alt. 2P-B	
	Initial Case, 9.9 MGD		Build Out, 14 MGD	Incremental Cost	Build Out, 14 MGD	Incremental Cost
Capital Costs						
Transmission Pipelines	\$ 15,589,000		\$ 16,914,000	\$ 1,325,000	\$ 15,941,000	\$ 352,000
WTP Booster Pump Station	0		0	\$ -	\$ 558,000	\$ 558,000
Booster Pump Station	\$ 1,322,000		\$ 2,044,000	\$ 722,000	\$ 2,044,000	\$ 722,000
System Storage	\$ 282,000		\$ 399,000	\$ 117,000	\$ 399,000	\$ 117,000
Electrical Feed	\$ 110,000		\$ 196,000	\$ 86,000	\$ 216,000	\$ 106,000
Total Capital Cost ⁽²⁾	\$ 17,303,000		\$ 19,553,000	\$ 2,250,000	\$ 19,158,000	\$ 1,855,000
Add'l Land Acquisition (PS and Storage Tank)	\$ 6,800		\$ 6,800	\$ -	\$ 6,800	\$ -
Total Project Cost ⁽²⁾	\$ 17,309,800		\$ 19,559,800	\$ 2,250,000	\$ 19,164,800	\$ 1,855,000
Annual O&M Costs						
Annual Debt Service <i>(Assuming 25 years, effective interest rate of 6.5%)</i>	\$ 1,419,000		\$ 1,604,000	\$ 185,000	\$ 1,572,000	\$ 153,000
Pumping Costs	\$ 458,000		\$ 821,000	\$ 363,000	\$ 903,000	\$ 445,000
Operation and Maintenance ⁽³⁾						
Pump Station	\$ 33,000		\$ 51,000	\$ 18,000	\$ 65,000	\$ 32,000
Transmission Facilities	\$ 156,000		\$ 169,000	\$ 13,000	\$ 159,000	\$ 3,000
Storage Facilities	\$ 2,800		\$ 4,000	\$ 1,200	\$ 4,000	\$ 1,200
Total Annual Cost ⁽²⁾	\$ 2,068,800		\$ 2,649,000	\$ 580,200	\$ 2,703,000	\$ 634,200

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative.

⁽²⁾ Items not included for cost comparison due to equivalence between alternatives include Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies and Mitigation, Land Acquisition for WTP and Transmission Line, Reserve Account, Financing Costs, and Interest During Construction.

⁽³⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks, 2.5% of the total capital cost of remote pump stations and 2.25% of the total capital cost of on-site pump stations.

Description of Alternative/Options

Alternative 2 - Gravity from WTP to remote pump station at/near junction to Boerne, pump to Boerne

Alt. 2P-A Increase pipe size in gravity line to provide Max capacity of 14 mgd

Alt. 2P-B Addition of booster pump station at WTP to provide Max capacity of 14 mgd

Pumping Costs

Phasing

Equation for pumping/energy costs (assumes continuous operation)

$$\left(Q_{mgd} \times 694 \frac{4 \text{ gpm}}{\text{mgd}} \times H_{ft} \right) \times 0.746 \frac{\text{kW}}{\text{hp}} \times 8.760 \frac{\text{hrs}}{\text{yr}} \times 0.08 \frac{\$}{\text{kWh}} = \text{Cost } \$/\text{yr}$$

where
 3960×0.70 overall efficiency = 0.7
 energy rate (\$/kWh) = 0.08

Alt. 1 - Base Case, Q= 9.9 MGD

-Involves a single high service pumping station to Boerne
 -Ultimate Demand Scenario

Pump Head (ft)=	370
Flow, Q (mgd)=	9.87
Pump hp =	910
Est PS Capital Cost (\$)=	1.26
O&M Energy Cost (\$/yr)=	\$ 478,119
Power Connection Cost (\$)=	\$ 113,750

Alt. 2 - Base Case, Q= 9.9 MGD

	Initial Demand	Ultimate Demand
Pump Head (ft)=	473	400
Flow, Q (mgd)=	9.49	8.75
Pump hp =	969	880
Est PS Capital Cost (\$)=	1.22	1.23
O&M Energy Cost (\$/yr)=	\$500,133	\$ 457,965
Power Connection Cost (\$)=	\$120,000	\$ 110,000
	(from alt 1s, 113,000)	

Alt. 1P-A - Full Capacity, Q= 14 MGD

-Involves a single high service pumping station to Boerne

Pump Head (ft)=	545
Flow, Q (mgd)=	14.00
Pump hp =	1910
Est PS Capital Cost (\$)=	2.39
O&M Energy Cost (\$/yr)=	\$ 999,250
Power Connection Cost (\$)=	\$ 238,750

Alt. 1P-B - Full Capacity, Q= 14 MGD

-Involves a single high service pumping station to Boerne

Pump Head (ft)=	375
Flow, Q (mgd)=	14.0
Pump hp =	1320
Est PS Capital Cost (\$)=	1.73
O&M Energy Cost (\$/yr)=	\$ 687,557
Power Connection Cost (\$)=	\$ 165,000

Alt. 2P-B - Add Booster PS at WTP, Q= 14 MGD

WTP Booster PS

Pump Head (ft)=	45
Flow, Q (mgd)=	14.0
Pump hp =	160
Est PS Capital Cost (\$)=	0.56
O&M Energy Cost (\$/yr)=	\$ 82,507
Power Connection Cost (\$)=	\$ 20,000

Remote PS

Pump Head (ft)=	522
Flow, Q (mgd)=	12.01
Pump hp =	1570
Est PS Capital Cost (\$)=	2.04
O&M Energy Cost (\$/yr)=	\$ 820,736
Power Connection Cost (\$)=	\$ 196,250

ENR= 6039 6127
 2nd quarter, last quarter,
 1989 1999

Pumping Station Costs

(hp)	(mil\$)	(mil\$)
<400	0.55	0.56
400	0.65	0.66
1000	1.35	1.37
2000	2.45	2.49
3000	3.38	3.43
4000	4.08	4.14
5000	4.61	4.68
6000	5.04	5.11
7000	5.47	5.55
8000	5.76	5.84
9000	6.04	6.13
10000	6.3	6.39
15000	7.28	7.39
3000	9.23	9.36
60000	12.01	12.19
80000	13.05	13.24
100000	13.98	14.18

Reference HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

Costs for pumping stations include costs for pumps, housing, motors, electrical control, site work, and all materials needed

$$\text{PowerConn } (\$50,000/\text{min}) = \frac{\$125}{1/\text{hp}} \times \text{Stationhp}$$

Costs for electrical power connection include the distance to the nearest power source and the electrical demand of the pumping station. The following equation was developed to estimate power connection costs

Description of Alternatives

Alt 1 - Single high service pump station at WTP (route along Rd 46)

Alt 1P-A Add head to high service pump station at WTP

Alt 1P-B Upsize diameters at west end of transmission line (furthest delivery points) by relaxing minimum velocity criteria

Alt 2 - Gravity from WTP to west of Rd 281 along Rd 46 to remote pump station, pump to Boerne

Alt 2P-A Increase pipe size in gravity line to provide Max capacity of 14 mgd

Alt 2P-B Addition of booster pump station at WTP to provide Max capacity of 14 mgd

Pipe Material/Installation Costs Phasing

Alt 1 - Base Case, Q= 9.9 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
30	250	46647	117	5438782
24	250	26506	103	2734908
20	250	11407	91	1034469
18	250	31323	80	2513755
16	250	5937	71	421663
14	250	33579	63	2112267
12	250	5038	63	316888
10	250	2961	60	177233
8	250	27425	62	1705426
6	250	3018	55	166086
TOTAL		193841		

TOTAL = \$ 16,621,477

Alt 1P-A - Full Capacity, Q= 14 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
30	300	62893	132	8286336
24	300	10259	117	1196187
20	300	11407	102	1168950
18	300	7488	91	679087
16	300	23835	80	1912793
14	300	5937	71	421663
12	300	33579	63	2112267
10	300	5038	63	316888
8	300	2961	60	177233
6	300	27425	62	1705426
TOTAL		193841		

TOTAL = \$ 18,368,189

Alt 1P-B - Full Capacity, Q= 14 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
30	250	14416	117	1681057
24	250	5937	103	6060328
20	250	2323	91	261461
18	250	3373	80	268554
16	250	4251	71	3015292
14	250	19070	63	1466670
12	250	5038	63	316888
10	250	2961	60	177233
8	250	27425	62	1705426
6	250	3018	55	166086
TOTAL		193841		

TOTAL = \$ 16,638,856

Alt 2 - Base Case, Q= 9.9 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
30	250	16693	117	1946288
24	250	3292	103	339650
20	250	53168	91	4854832
18	250	11407	80	9134469
16	250	31323	71	2513755
14	250	5937	63	421663
12	250	33579	63	2112267
10	250	5038	63	316888
8	250	2961	60	177233
6	250	27425	62	1705426
TOTAL		193841		

TOTAL = \$ 15,588,557

Alt 2P-A - Upsize Dia in Gravity Line, Q= 14 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
36	100	26506	120	3173246
30	100	15536	106	1639295
24	300	16693	132	2199306
20	300	3292	117	383904
18	300	11126	91	1015940
16	300	2523	102	259540
14	300	8884	91	805673
12	300	24166	80	1939388
10	300	13094	71	929952
8	300	15509	63	975597
6	300	23108	63	1453558
4	300	11277	60	677233
3	300	16149	62	1004202
TOTAL		193841		

TOTAL = \$ 16,914,202

Alt 2P-B - Add Booster PS at WTP, Q= 14 MGD

Dia (in.)	Pressure Class	Length (ft.)	\$/LF	Cost \$
30	300	16693	132	2199306
24	300	3292	117	383904
20	300	53168	91	4854832
18	300	2523	102	259540
16	300	8884	91	805673
14	300	24166	80	1939388
12	300	13094	71	929952
10	300	15509	63	975597
8	300	23108	63	1453558
6	300	11277	60	677233
4	300	16149	62	1004202
3	300	3018	55	166086
TOTAL		193841		

TOTAL = \$ 15,940,554

Pipe Material/Installation Costs Assumes 13% Increase per 50 psi pressure class above 150 psi.

ENR- 6/29 (June 1999)									
Pipeline Costs for Rock in Rural Areas									
Pipe Dia (in.)	100 psi	150 psi	200 psi	250 psi	300 psi				
12	\$/ft	\$/ft	\$/ft	\$/ft	\$/ft				
14	42	42	47	54	61				
16	48	48	54	61	69				
18	53	53	60	68	76				
20	59	59	67	75	85				
24	62	62	70	79	89				
27	70	70	79	89	101				
30	80	80	90	102	115				
33	104	104	118	133	150				
36	118	118	133	151	170				

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

Costs for piping are for installed piping and appurtenances, including markers, valves, thrust restraint systems, corrosion monitoring and control equipment, air pressure valves, blow-off valves, erosion control, revegetation of ROW, fencing, and gates. Costs do not include crossings.

ENR- 6/27 (Dec. 1999)									
Pipeline Costs for Rock in Rural Areas									
Pipe Dia (in.)	100 psi	150 psi	200 psi	250 psi	300 psi				
12	\$/ft	\$/ft	\$/ft	\$/ft	\$/ft				
14	43	43	48	54	61				
16	46	46	53	62	70				
18	54	54	61	69	78				
20	60	60	68	76	86				
24	63	63	71	80	91				
27	71	71	80	91	102				
30	81	81	92	103	117				
33	106	106	119	135	152				
36	120	120	135	153	173				

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing Methodology, Senate Bill 1 Report.

SUMMARY

Dia	Class	Length of Piping (ft)										Totals	
		ALT 1P-A	ALT 1P-B	ALT 2P-A	ALT 2P-B	ALT 1	ALT 2	ALT 1P-A	ALT 1P-B	ALT 2P-A	ALT 2P-B		
36	100	-	-	26306	-	-	-	-	-	-	-	193841	193841
33	100	-	-	15536	-	-	-	-	-	-	-	193841	193841
30	300	62893	-	16693	16693	-	-	-	-	-	-	193841	193841
250	200	10259	14418	3292	3292	46646.5	16692.6	-	-	-	-	193841	193841
200	250	56734	-	-	-	26505.7	3291.8	-	-	-	-	193841	193841
100	100	-	-	11126	53168	-	-	-	-	-	-	193841	193841
250	250	-	2523	-	-	-	-	-	-	-	-	193841	193841
200	200	-	16373	-	-	-	-	-	-	-	-	193841	193841
150	150	-	45281	-	-	-	-	-	-	-	-	193841	193841
100	100	-	18070	-	-	-	-	-	-	-	-	193841	193841
300	300	11407	-	2523	2523	-	-	-	-	-	-	193841	193841
250	250	7488	-	8884	8884	-	-	-	-	-	-	193841	193841
200	200	23835	-	24166	24166	31323.0	31323.0	-	-	-	-	193841	193841
150	150	5937	-	13094	13094	5937.2	5937.2	-	-	-	-	193841	193841
100	100	-	5038	-	-	-	-	-	-	-	-	193841	193841
150	150	33579	-	15509	15509	33579.5	33579.5	-	-	-	-	193841	193841
20	100	5038	-	23108	23108	5037.7	5037.7	-	-	-	-	193841	193841
18	300	2961	2961	2961	2961	2960.8	2960.8	-	-	-	-	193841	193841
14	300	27425	-	11277	11277	-	-	-	-	-	-	193841	193841
250	250	3018	27425	16149	16149	27425.3	27425.3	-	-	-	-	193841	193841
200	200	-	-	3018	3018	3018.1	3018.1	-	-	-	-	193841	193841
150	150	-	3018	-	-	-	-	-	-	-	-	193841	193841

Storage Costs -Phasing

Look at storage costs in addition to tank used for equalization (Equalization tank is same for all alternatives and is not included in cost comparison)

ALTERNATIVE 1

- Involves a single high service pumping station to Boerne
- No additional system storage is required.

ALTERNATIVE 2

- Involves a remote pumping station located near west of Rd. 281 along Rd. 46, pumping to Boerne and BMWWD.

Max, Q=14 MGD

Assume required system storage at booster PS(MG)= 0.5
Ground Storage Tank (\$) = \$ 399,336
Req'd Land Acquisition (acres)= 4 (pump station and tank)
Land value (\$/acre)= \$ 1,700 (1999 value)
Req'd Land Acquisition Cost (\$) = \$ 6,800

Base, Q=9.9 MGD

0.25
\$ 282,470
4 (pump station and tank)
\$ 1,700 (1999 value)
\$ 6,800

Ground Storage Tank Costs (MG)	Values from	
	2nd quarter, 1999	Values from last quarter, 1999
	ENR= 6039	6127
0.01	86400	87659
0.05	146400	148533
0.1	209300	212350
0.5	393600	399336
1	679100	688996
2	1129300	1145756
4	1768600	1794372
6	2408000	2443089
7.5	2926600	2969246
9	329920	334728

Reference: HDR Cost Estimating, Section 5 of Studies Level Engineering and Costing
Methodology, Senate Bill 1 Report.

ALT 1P-A HIGH SERVICE PUMP STATION AT WTP MAX CAPACITY Same Size Piping as Base Condition

MODEL OUTPUT

Vary Ground Profile for Pressure Class Categories									
Location	Model Node	Model Piping	Node EI (ft)	Pipe Dia (in.)	Node EI (ft)	200 psi Node EI (ft)	250 psi Node EI (ft)	300 psi Node EI (ft)	Pipe Length (ft)
Reservoir (WTP)	R-1	P-1	1380	30	1727	1842	1958	2073	139.3
Reservoir (WTP)	J-1	P-1	1380	30	1727	1842	1958	2073	142.9
Reservoir (WTP)	RV-1	P-5	1380	30	1727	1842	1958	2073	282
Flow Control Element	J-5	P-4	1380	30	1727	1842	1958	2073	363
High Point	J-16	P-25	1380	30	1745	1860	1976	2091	208.0
High Point	J-25	P-16	1385	30	1732	1847	1963	2078	280.4
Curtis Bremer Feed	J-7	P-26	1310	30	1657	1772	1888	2003	887.0
High Point	J-26	P-7	1321	30	1668	1783	1899	2014	736.9
CISD School Feed	J-9	P-27	1299	30	1646	1761	1877	1992	465.7
High Point	J-27	P-9	1320	30	1667	1782	1898	2013	220.6
Apex Feed	J-8	P-28	1205	30	1552	1667	1783	1898	155.36
Craig Ebel Double J Ranch	J-10	P-8	1137	30	1484	1599	1715	1830	205.9
CISD School Feed	J-11	P-10	1160	30	1507	1622	1738	1853	207.3
High Point	J-12	P-11	1321	30	1668	1783	1899	2014	1028.4
CISD School Feed	J-3	P-12	1165	30	1512	1627	1743	1858	1669.2
Low Point	J-28	P-2	1119	24	1466	1581	1697	1812	252.3
High Point	J-13	P-29	1177	24	1524	1639	1755	1870	888.4
High Point	J-14	P-13	1279	24	1626	1741	1857	1972	748.8
Murcia Feed (low point)	J-15	P-14	1247	24	1594	1709	1825	1940	1667.7
High Point	J-6	P-15	1329	24	1676	1791	1907	2022	715.7
Conillera Feed (low point)	J-17	P-6	1280	24	1627	1742	1858	1973	593.2
Far Oaks Feed	J-18	P-17	1260	20	1607	1722	1838	1953	1550.9
High Point (Kendall Prop)	J-19	P-18	1416	20	1763	1878	1994	2109	1807.0
Boerne Feed	J-20	P-19	1405	20	1752	1867	1983	2098	503.7
Tapiato/Kendall Co Utility Co	J-21	P-20	1405	18	1752	1867	1983	2098	134.0
SAWS Feed	J-2	P-21	1450	18	1797	1912	2028	2143	2826.8
Buwerde Hills	J-22	P-3	1080	14	1427	1542	1658	1773	642.3
Low Point	J-23	P-22	1061	14	1408	1523	1639	1754	485.3
SARA Feed	J-24	P-23	1185	14	1532	1647	1763	1878	1614.8
Bear MWD Feed	J-4	P-24	1320	14	1667	1782	1898	2013	3018.1

ALT 1 - Base Condition

MODEL OUTPUT

Location	Model Node	Model Piping	Node EI (ft)	Pipe Dia (in.)	Node EI (ft)	200 psi Node EI (ft)	250 psi Node EI (ft)	300 psi Node EI (ft)	Pipe Length (ft)
Reservoir (WTP)	R-1	P-1	1380	30	1727	1842	1958	2073	139.3
Reservoir (WTP)	J-1	P-1	1380	30	1727	1842	1958	2073	142.9
Flow Control Element	RV-1	P-5	1380	30	1727	1842	1958	2073	282
High Point	J-5	P-4	1380	30	1727	1842	1958	2073	363
High Point	J-16	P-25	1385	30	1745	1860	1976	2091	208.0
Curtis Bremer Feed	J-7	P-26	1310	30	1657	1772	1888	2003	887.0
High Point	J-26	P-7	1321	30	1668	1783	1899	2014	736.9
CISD School Feed	J-9	P-27	1299	30	1646	1761	1877	1992	465.7
High Point	J-27	P-9	1320	30	1667	1782	1898	2013	220.6
Apex Feed	J-8	P-28	1205	30	1552	1667	1783	1898	155.36
Craig Ebel Double J Ranch	J-10	P-8	1137	30	1484	1599	1715	1830	205.9
CISD School Feed	J-11	P-10	1160	30	1507	1622	1738	1853	207.3
High Point	J-12	P-11	1321	30	1668	1783	1899	2014	1028.4
CISD School Feed	J-3	P-12	1165	30	1512	1627	1743	1858	1669.2
Low Point	J-28	P-2	1119	24	1466	1581	1697	1812	252.3
High Point	J-13	P-29	1177	24	1524	1639	1755	1870	888.4
High Point	J-14	P-13	1279	24	1626	1741	1857	1972	748.8
Murcia Feed (low point)	J-15	P-14	1247	24	1594	1709	1825	1940	1667.7
High Point	J-6	P-15	1329	24	1676	1791	1907	2022	715.7
Conillera Feed (low point)	J-17	P-6	1280	24	1627	1742	1858	1973	593.2
Far Oaks Feed	J-18	P-17	1260	20	1607	1722	1838	1953	1550.9
High Point (Kendall Prop)	J-19	P-18	1416	20	1763	1878	1994	2109	1807.0
Boerne Feed	J-20	P-19	1405	20	1752	1867	1983	2098	503.7
Tapiato/Kendall Co Utility Co	J-21	P-20	1405	18	1752	1867	1983	2098	134.0
SAWS Feed	J-2	P-21	1450	18	1797	1912	2028	2143	2826.8
Buwerde Hills	J-22	P-3	1080	14	1427	1542	1658	1773	642.3
Low Point	J-23	P-22	1061	14	1408	1523	1639	1754	485.3
SARA Feed	J-24	P-23	1185	14	1532	1647	1763	1878	1614.8
Bear MWD Feed	J-4	P-24	1320	14	1667	1782	1898	2013	3018.1

HYDRAULIC MODEL (Based on computer output from ALPAC)

HYDRAULIC MODEL										AL TIF A									
Flow Based Capacity in MGd, ft/sec, ft/s with Same Size										Flow Based Capacity in MGd, ft/sec, ft/s with Same Size									
Piping										Piping									
Node 1										Node 2									
Node 2										Node 1									
Length (ft)										Length (ft)									
Dia (in)										Dia (in)									
C-value										C-value									
P-1										P-1									
R-1										R-1									
J-1										J-1									
J-11										J-11									
J-12										J-12									
J-13										J-13									
J-14										J-14									
J-15										J-15									
J-16										J-16									
J-25										J-25									
J-28										J-28									
J-13										J-13									
J-22										J-22									
RV-1										RV-1									
RV-1										RV-1									
J-1										J-1									
J-6										J-6									
J-7										J-7									
J-10										J-10									
J-9										J-9									
Total										Total									
193841.1 ft										193841.1 ft									
36.71 mi										36.71 mi									

HYDRAULIC MODEL

Node	Reference Pt	EI (ft)	Full Capacity			Base (Ultimate)		
			Demand (mgd)	HGL (ft)	Pressure (psi)	Demand (mgd)	HGL (ft)	Pressure (psi)
J-1	Reservoir (WTP)	1380	14	1924.7	235.9	9.867	1749.8	160.1
J-10	Craig Elbel, Double J Ranch, Clyde Johnson, Lost Owl	1137	1.262	1827.4	298.9	0.744	1698.4	243.1
J-11	CISD School Feed	1160	0.091	1823.8	287.4	0.047	1696.4	232.3
J-12	High Point	1321	0	1806.1	210.0	0	1686.6	158.3
J-13	Low Point	1177	0	1739.1	243.4	0	1652.1	205.7
J-14	High Point	1279	0	1714.1	188.4	0	1639.9	156.3
J-15	Murcia Feed (low point)	1247	0.749	1658.3	178.1	0.206	1612.9	158.4
J-16	High Point	1398	0	1924.2	227.8	0	1749.6	152.2
J-17	Cordillera Feed (low point)	1280	1.446	1620.7	147.5	0.937	1592.9	135.5
J-18	Fair Oaks Feed	1260	1.803	1542.9	122.5	1.312	1550.3	125.7
J-19	High Point (Kendall Prop)	1416	0.642	1489.1	31.7	0.084	1520.9	45.4
J-2	SAWS Feed	1450	1.699	1475.4	11.0	1.699	1511.4	26.6
J-20	Boerne Feed	1405	2.214	1477.2	31.3	1.744	1513.1	46.8
J-21	Tapatio/Kendall Co Utility Co	1405	0.999	1477	31.2	0.469	1512.9	46.7
J-22	Bulverde Hills	1080	0.319	1754.8	292.2	0.189	1650.3	246.9
J-23	Low Point	1061	0	1741.9	294.8	0	1637.4	249.6
J-24	SARA Feed	1185	0.047	1698.7	222.4	0.047	1594.2	177.2
J-25	High Point	1385	0	1917.8	230.7	0	1746.2	156.4
J-26	High Point	1321	0	1881.1	242.5	0	1726.9	175.8
J-27	High Point	1320	0	1865.9	236.4	0	1718.9	172.7
J-28	Low Point	1119	0	1768.8	281.4	0	1666.5	237.1
J-3	CISD School Feed	1165	0.091	1777.3	265.1	0.047	1670.5	218.9
J-4	Bexar MWD Feed	1320	2.004	1691	160.6	2.004	1586.5	115.4
J-5	Flow Control Element	1380	-14	1924.7	235.9	-9.867	1749.8	160.1
J-6	High Point	1329	0	1637.7	133.7	0	1601.9	118.2
J-7	Curtis Brenner Feed	1310	0.228	1897.4	254.3	0.094	1735.6	184.3
J-8	Apex Feed	1205	0.317	1831.8	271.4	0.187	1700.7	214.6
J-9	CISD School Feed	1299	0.091	1870.7	247.5	0.047	1721.4	182.9
R-1	Reservoir (WTP)	1380	14.00	1925			1750	
Total						9.87		

ALT 1P-B HIGH SERVICE PUMP STATION AT WTP
MAX CAPACITY- Increase Size of Base Condition Piping

MODEL OUTPUT

MODEL OUTPUT											ALT 1P-B, Full Capacity				Alt 1, Ultimate Demands				Full Capacity
Location		Model Node	Model Piping	Node El (ft)	Pipe Length (ft)	Sum Length (ft)	Pipe Length (ft)	Press Head (ft)	HGL (ft)	v(fps)	Q (mgd)	Pipe Dia (in)	Press Head (ft)	HGL (ft)	v(fps)	Q (mgd)	Pipe Dia (in)	Press Head (ft)	Pipe Pressure Class
Reservoir (WTP)		R-1		1380		0			1755					1625					
Reservoir (WTP)		J-1	P-1	1380	139	139		162.2	1754.7	4.4	14.00	30	106.0	1624.8	3.1	9.87	30	106.0	200
Reservoir (WTP)		RV-1	P-5	1380	143	282		0.0	1755	0.0	0.00	30	0.0	1625	0.0	0.00	30	0.0	200
Flow Control Element		J-5	P-4	1380	100	383		162.2	1754.7	0.0	-14.00	30	106.0	1624.8	0.0	-9.87	30	106.0	200
High Point		J-16	P-25	1398	208	591		154.2	1754.2	4.4	0.00	30	98.1	1624.6	3.1	0.00	30	98.1	200
High Point		J-25	P-16	1385	2805	3395		157.1	1747.8	4.4	0.00	30	102.3	1621.2	3.1	0.00	30	102.3	200
Curtis Bremer Feed		J-7	P-26	1310	8877	12272		180.7	1727.4	4.4	0.23	30	130.2	1610.6	3.1	0.09	30	130.2	200
High Point		J-26	P-7	1321	7369	19642		168.9	1711.1	4.3	0.00	30	121.6	1601.9	3.1	0.00	30	121.6	200
CISD School Feed		J-9	P-27	1299	4658	24299		173.9	1700.7	4.3	0.09	30	118.6	1596.4	3.1	0.05	30	118.6	200
High Point		J-27	P-9	1320	2206	26506		197.8	1661.8	4.3	0.00	30	160.5	1575.7	3.1	0.19	30	160.5	200
Apex Feed		J-8	P-28	1205	15536	42042		225.3	1657.4	4.2	0.32	30	178.1	1573.4	3.1	0.74	30	178.1	200
Craig Ebel, Double J Ranch, (J-10)		J-10	P-8	1137	2060	44101		213.8	1653.8	3.8	0.09	30	189.0	1571.4	2.8	0.05	30	189.0	250
CISD School Feed		J-11	P-10	1160	2073	46175		136.4	1636.1	3.8	0.00	30	104.2	1561.6	2.8	0.00	30	104.2	250
High Point		J-12	P-11	1321	10285	56460		191.5	1607.3	3.8	0.00	30	164.8	1545.5	2.8	0.05	30	164.8	200
CISD School Feed		J-3	P-12	1165	16693	73152		209.4	1602.5	3.7	0.00	27	250	1543.2	2.5	0.00	27	250	250
Low Point		J-28	P-2	1119	2523	75675		177.0	1585.8	3.7	0.00	27	155.1	1535.1	2.5	0.00	27	155.1	200
Low Point		J-13	P-29	1177	8884	84559		126.7	1571.7	3.7	0.00	27	107.9	1528.3	2.5	0.00	27	107.9	200
High Point		J-14	P-13	1279	7488	92048		127.0	1540.2	3.7	0.00	27	115.2	1513	2.5	0.21	27	115.2	150
Murcia Feed (low point)		J-15	P-14	1247	16678	108725		86.4	1528.6	3.4	0.00	27	77.0	1506.9	2.4	0.00	27	77.0	150
High Point		J-6	P-15	1329	7157	115882		103.5	1519	3.4	0.00	27	96.0	1501.8	2.4	0.94	27	96.0	150
Cordillera Feed (low point)		J-17	P-6	1280	5937	121820		104.4	1501	2.9	1.45	27	100.4	1491.9	2.1	1.31	27	100.4	150
Fair Oaks Feed		J-18	P-17	1260	15509	137329		31.4	1488.5	2.2	0.64	27	29.9	1485.1	1.6	0.09	27	29.9	100
High Point (Kendall Prop)		J-19	P-18	1416	18070	155399		34.0	1483.6	2.4	2.21	24	33.3	1481.9	1.9	1.74	24	33.3	100
Boerne Feed		J-20	P-19	1405	5038	160437		33.9	1483.4	2.4	1.00	18	33.2	1481.7	1.9	0.47	18	33.2	100
Tapator/Kendall Co Utility Co		J-21	P-20	1405	134	160571		13.8	1481.9	1.5	1.70	18	13.1	1480.2	1.5	1.70	18	13.1	100
SAWS Feed		J-2	P-21	1450	2827	163398		218.6	1584.8	3.4	1.70	14	192.8	1525.3	3.2	0.19	14	192.8	250
Bulverde Hills		J-22	P-3	1080	6423	169821		221.2	1571.9	3.0	0.32	14	195.5	1512.4	3.0	0.00	14	195.5	250
Low Point		J-23	P-22	1061	4853	174674		148.8	1528.7	3.0	0.00	14	123.1	1469.2	3.0	0.05	14	123.1	250
SARA Feed		J-24	P-23	1185	16149	190823		87.0	1521	2.9	0.05	14	61.3	1461.5	2.9	2.00	14	61.3	150
Bexar MWD Feed		J-4	P-24	1320	3018	193841					2.00	14					14		150

193841 ft

36.7 mi

Velocity criteria (2 fps min) is not satisfied with
26069 ft
4.9 mi

ALT 2P-A GRAVITY CONVEYANCE FROM WTP TO WEST OF RD 281 ALONG RD 46 TO REMOTE PUMP STATION, PUMP TO BOERNE AND BMWWD

MAX CAPACITY - Increase pipe diameters (gravity). Increase HGL at Remote PS

Assume required system storage at booster PS(MG)= 0.5
C= 120

Mainline (Gravity)

Mainline (Gravity)		Vary Ground Profile for Pressure Class Categories								Max Capacity, Q = 14 MGD					Initial Phase, Q = 9.9 MGD							
		150 psi Node El (ft)	200 psi Node El (ft)	250 psi Node El (ft)	300 psi Node El (ft)	Sum Length (ft)	Full ΔQ (mgd)	Full Q (mgd)	Full v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Base ΔQ (mgd)	Base (Ultimate) Q (mgd)	Base (Ult) v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Pipe Pressure Class			
Can reroute around hills	Junct	El (ft)	Dia (in)	Length (ft)	Pipe Length (ft)																	
	Reservoir (WTP)	1380			1727	1842	1958	2073	0	14.00	3.07	0.56	1379.4	-8.0	0.000	9.867	2.16	0.71	1379.29	-8.10	100	
	High Point	1398	36	591	1745	1860	1976	2091	591	0.00	14.00	3.07	2.66	1376.8	-3.6	0.000	9.867	2.16	3.38	1375.90	-3.94	100
	High Point	1385	36	2805	1732	1847	1963	2078	3395	0.00	14.00	3.07	2.66	1376.8	-3.6	0.000	9.867	2.16	10.52	1365.38	23.98	100
	Curtis Brenner Feed	1310	36	8877	1657	1772	1888	2003	12272	0.23	13.77	3.02	8.18	1368.6	25.4	0.094	9.773	2.14	8.74	1356.64	15.43	100
	High Point	1321	36	7369	1668	1783	1899	2014	19642	0.00	13.77	3.02	6.79	1361.8	17.7	0.000	9.773	2.14	5.47	1351.17	22.59	100
	CUSD School Feed	1299	36	4658	1646	1761	1877	1992	24299	0.09	13.68	3.00	4.24	1357.6	25.4	0.047	9.726	2.13	2.59	1348.58	12.37	100
	High Point	1320	36	2206	1667	1782	1898	2013	26506	0.00	13.68	3.00	2.01	1355.6	15.4	0.000	9.726	2.13	17.61	1330.96	54.54	100
	Apex Feed	1205	33	15536	1552	1667	1783	1898	42042	0.32	13.36	3.49	20.67	1334.9	56.2	0.187	9.539	2.49	2.01	1328.96	83.12	100
	Craig Ebel, Double J	1137	30	2060	1484	1599	1715	1830	44101	1.26	12.10	3.82	3.63	1331.3	84.1	0.047	8.795	2.78	2.00	1326.95	72.29	100
Can easily reroute to EL 1280	CUSD School Feed	1160	30	2073	1507	1622	1738	1853	46175	0.09	12.01	3.79	3.60	1327.7	72.6	0.047	8.748	2.76	2.00	1326.95	72.29	100
	Remote Pump Sta	1290	30	6983	1637	1752	1868	1983	53168	0.00	12.01	3.79	12.14	1315.5	11.1	0.000	8.748	2.76	6.75	1320.20	13.08	100
		ft																				
		mi																				
		10.1																				

Pump from remote pump station to BMWWD and Boerne (same as Alt. 1 from remote pump station to Boerne and BMWWD)

Pump from remote pump station to BMWWD and Boerne (same as Alt. 1 from remote pump station to Boerne and BMWWD)																						
Max Capacity, Q = 14 MGD											Initial Phase, Q = 9.9 MGD											
Junct	El (ft)	Dia (in)	Pipe Length (ft)	150 psi Node El (ft)	200 psi Node El (ft)	250 psi Node El (ft)	300 psi Node El (ft)	Sum Length (ft)	Full ΔQ (mgd)	Full Q (mgd)	Full v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Base ΔQ (mgd)	Base (Ultimate) Q (mgd)	Base (Ult) (Ult)	Base v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Pipe Pressure Class
Remote Pump Sta	1290			1637	1752	1868	1983	53168	0.00	12.01	3.79	0.00	1806.1	210.0	0.000	8.75	2.80	8.75	1686.6	158.3	250	
High Point	1321	30	3292	1668	1783	1899	2014	56460	0.00	12.01	3.79	28.8	1777.3	265.1	0.047	8.75	2.80	16.1	1670.5	218.9	300	
CUSD School Feed	1165	30	16693	1512	1627	1743	1858	73152	0.09	12.01	3.79	8.5	1768.8	281.4	0.000	6.33	3.20	4.0	1666.5	237.1	300	
Low Point	1119	24	2523	1466	1581	1697	1812	75675	0.00	9.55	4.71	29.7	1739.1	243.4	0.000	6.33	3.20	14.4	1652.1	205.7	250	
Low Point	1177	24	8884	1524	1639	1755	1870	84559	0.00	9.55	4.71	25.0	1714.1	188.4	0.000	6.33	3.20	12.2	1639.9	156.3	200	
High Point	1279	24	7488	1626	1741	1857	1972	92048	0.00	9.55	4.71	55.8	1658.3	178.1	0.006	6.33	3.20	27.0	1612.9	158.4	200	
Murcia Feed (low point	1247	24	16678	1594	1709	1825	1940	108725	0.75	9.55	4.71	20.6	1637.7	133.7	0.000	6.13	3.10	11.0	1601.9	118.2	150	
High Point	1329	24	7157	1676	1791	1907	2022	115882	0.00	8.80	4.34	17.0	1620.7	147.5	0.000	6.13	3.10	9.0	1592.9	135.5	150	
Cordillera Feed (low p	1280	24	5937	1627	1742	1858	1973	121820	1.45	8.80	4.34	77.8	1542.9	122.5	1.312	5.19	3.80	42.6	1550.3	125.7	150	
Fair Oaks Feed	1260	20	15509	1607	1722	1838	1953	137329	1.80	7.36	5.23	53.8	1489.1	31.7	0.094	3.88	2.80	29.4	1520.9	45.4	100	
High Point	1416	20	18070	1763	1878	1994	2109	155399	0.64	5.55	3.94	11.9	1477.2	31.3	1.744	3.78	2.80	7.8	1513.1	46.8	100	
Boerne Feed	1405	20	5038	1752	1867	1983	2098	160437	2.21	4.91	3.49	0.2	1477.0	31.2	0.469	2.04	1.90	0.2	1512.9	46.7	100	
Tapatio/Kendall Co U	1405	18	134	1752	1867	1983	2098	160571	1.00	2.70	2.36	0.2	1477.0	31.2	0.469	2.04	1.90	0.2	1512.9	46.7	100	
SAWS Feed	1450	18	2827	1797	1912	2028	2143	163398	1.70	1.70	1.49	1.6	1475.4	11.0	1.699	1.57	1.50	1.5	1511.4	26.6	100	
SAWS	1450	18	2827	1797	1912	2028	2143	163398	1.70	1.70	1.49	1.6	1475.4	11.0	1.699	1.57	1.50	1.5	1511.4	26.6	100	
Buwerde Hills	1080	14	6423	1427	1542	1658	1773	169821	0.32	2.37	3.44	22.5	1754.8	292.2	0.189	2.37	3.20	20.2	1650.3	246.9	300	
Low Point	1061	14	4853	1408	1523	1639	1754	174674	0.00	2.05	2.97	12.9	1741.9	294.8	0.000	2.18	3.00	12.9	1637.4	249.6	300	
SARA Feed	1185	14	16149	1532	1647	1763	1878	190823	0.05	2.05	2.97	43.2	1698.7	222.4	0.047	2.18	3.00	43.2	1594.2	177.2	250	
Bexar MWD Feed	1320	14	3018	1667	1782	1898	2013	193841	2.00	2.00	2.91	7.7	1691.0	160.6	2.004	2.13	2.90	7.7	1586.5	115.4	200	
BMWWD	1320	14	3018	1667	1782	1898	2013	193841	2.00	2.00	2.91	7.7	1691.0	160.6	2.004	2.13	2.90	7.7	1586.5	115.4	200	
												417.0							259.2			

ALT 2P-8

GRAVITY CONVEYANCE FROM WTP TO WEST OF RD 281 ALONG RD 46 TO REMOTE PUMP STATION, PUMP TO BOERNE AND BMWWD

Assume required system storage at booster PS(MG)= 0.5
C= 120
Adding Booster PS @ WTP, Add'l Head (ft)= 45

Mainline (Gravity)

Max Capacity, Q = 14 MGD										Initial Phase, Q = 9.9 MGD							
Junct	El (ft)	Dia (in)	Pipe Length (ft)	Sum Length (ft)	Full ΔQ (mgd)	Full Q (mgd)	Full v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Base ΔQ (mgd)	Base (Ult.) (mgd)	Base v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Full Capacity Pipe Pressure Class
Reservoir (WTFP)	1380			0		14.00											
High Point	1398	30	591	591	0.00	14.00	4.42	1.36	1423.6	11.1	0.000	9.867	3.12	0.71	1379.29	-8.10	100
High Point	1385	30	2805	3395	0.00	14.00	4.42	6.47	1417.2	13.9	0.000	9.867	3.12	3.38	1375.90	-3.94	100
Curtis Bremer Feed	1310	30	8877	12272	0.23	13.77	4.35	19.85	1397.3	37.8	0.094	9.773	3.09	10.52	1365.38	23.98	100
High Point	1321	30	7369	19642	0.00	13.77	4.35	16.48	1380.8	25.9	0.000	9.773	3.09	8.74	1356.64	15.43	100
CISD School Feed	1299	30	4658	24299	0.09	13.68	4.32	10.29	1370.6	31.0	0.047	9.726	3.07	5.47	1351.17	22.59	100
High Point	1320	30	2206	26506	0.00	13.68	4.32	4.87	1365.7	19.8	0.000	9.726	3.07	2.59	1348.58	12.37	100
Apex Feed	1205	30	15536	42042	0.32	13.36	4.22	32.86	1332.8	55.3	0.187	9.539	3.01	17.61	1330.96	54.54	100
Craig Elbel, Double J	1137	30	2060	44101	1.26	12.10	3.82	3.63	1329.2	83.2	0.744	8.795	2.78	2.01	1328.96	83.12	100
CISD School Feed	1160	30	2073	46175	0.09	12.01	3.79	3.60	1325.6	71.7	0.047	8.748	2.76	2.00	1326.95	72.29	100
Remote Pump Sta	1290	30	6993	53168	0.00	12.01	3.79	12.14	1313.5	10.2	0.000	8.748	2.76	6.75	1320.20	13.08	100
53168 ft 10.1 mi																	

Can reroute around hills

Can easily reroute to EL1280

Can reroute around hills

Can easily reroute to EL 1280

Pump from remote pump station to BMWWD and Boerne (same as Alt. 1 from remote pump station to Boerne and BMWWD)

Max Capacity, Q = 14 MGD										Initial Phase, Q = 9.9 MGD							Full Capacity
Junct	El (ft)	Dia (in)	Pipe Length (ft)	Sum Length (ft)	Full ΔQ (mgd)	Full Q (mgd)	Full v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Base ΔQ (mgd)	Base (Ult.) (mgd)	Base v(fps)	HL (ft)	HGL (ft)	Press Head (psi)	Pipe Pressure Class
Remote Pump Sta	1290			53168	12.01	12.01					8.75				1689.7		
High Point	1321	30	3292	56460	0.00	12.01	3.79	0.00	1806.1	210.0	0.000	8.75	2.80	16.1	1686.6	158.3	250
CISD School Feed	1165	30	16693	73152	0.09	12.01	3.79	28.8	1777.3	265.1	0.047	8.75	2.80	16.1	1670.5	218.9	300
Low Point	1119	24	2523	75675	0.00	9.55	4.71	8.5	1768.8	281.4	0.000	6.33	3.20	4.0	1666.5	237.1	300
Low Point	1177	24	8884	84559	0.00	9.55	4.71	29.7	1739.1	243.4	0.000	6.33	3.20	14.4	1652.1	205.7	250
High Point	1279	24	7488	92048	0.00	9.55	4.71	25.0	1714.1	188.4	0.000	6.33	3.20	12.2	1639.9	156.3	200
Murcia Feed (low point)	1247	24	16678	108725	0.75	9.55	4.71	55.8	1658.3	178.1	0.206	6.33	3.20	27.0	1612.9	158.4	200
High Point	1329	24	7157	115882	0.00	8.80	4.34	20.6	1637.7	133.7	0.000	6.13	3.10	11.0	1601.9	118.2	150
Cordillera Feed (low point)	1280	24	5937	121820	1.45	8.80	4.34	17.0	1620.7	147.5	0.937	6.13	3.10	9.0	1592.9	135.5	150
Fair Oaks Feed	1260	20	15509	137329	1.80	7.36	5.23	77.8	1542.9	122.5	1.312	5.19	3.80	42.6	1550.3	125.7	150
High Point	1416	20	18070	155399	0.64	5.55	3.94	53.8	1489.1	31.7	0.094	3.88	2.80	29.4	1520.9	45.4	100
Boerne Feed	1405	20	5038	160437	2.21	4.91	3.49	11.9	1477.2	31.3	1.744	3.78	2.80	7.8	1513.1	46.8	100
Tapator/Kendall Co U	1405	18	134	160571	1.00	2.70	2.36	0.2	1477.0	31.2	0.469	2.04	1.90	0.2	1512.9	46.7	100
SAWS Feed	1450	18	2827	163398	1.70	1.70	1.49	1.6	1475.4	11.0	1.699	1.57	1.50	1.5	1511.4	26.6	100
Bulverde Hills	1080	14	6423	169821	0.32	2.37	3.44	22.5	1754.8	292.2	0.189	2.37	3.20	20.2	1650.3	246.9	300
Low Point	1061	14	4853	174674	0.00	2.05	2.97	12.9	1741.9	294.8	0.000	2.18	3.00	12.9	1637.4	249.6	300
SARA Feed	1185	14	16149	190823	0.05	2.05	2.97	43.2	1698.7	222.4	0.047	2.18	3.00	43.2	1594.2	177.2	250
Bexar MWD Feed	1320	14	3018	193841	2.00	2.00	2.91	7.7	1691.0	160.6	2.004	2.13	2.90	7.7	1586.5	115.4	200
140673 ft 26.6 mi										259.2							

SAWS

BMWWD

GBRA REGIONAL WATER SUPPLY SYSTEM REQUESTED WATER SUPPLY AND AMOUNT AVAILABLE

Phasing Scenario - Max Capacity of Base Condition

15,683 14.00 mgd

VALUES INPUT TO MODEL

Entity	Build Out Delivery				Node	Reference Pt	Demand (mgd)
	Build Out		Phase 1-'Ultimate' Demand				
	Annual Ave (acft/yr)	Ave (mgd)	Annual Ave (acft/yr)	Max (mgd)			
IN-DISTRICT							
City of Boerne	2,481	2.21	1,954	1.74	J-1	Reservoir (WTP)	14 000
City of Fair Oaks	2,020	1.80	1,470	1.31	J-10	Craig Elbel, Double J Ranch, Clyde Johnson, Lost Owl	1.262
Comal Independent School District	305	0.27	158	0.14	J-11	CISD School Feed	0.091
					J-12	High Point	0.000
Apex Water Services	355	0.32	210	0.19	J-13	Low Point	0.000
Bulverde Utility Corporation (absorbed by Bexar Met.)	357	0.32	212	0.19	J-14	High Point	0.000
Murcia Development Co.	840	0.75	231	0.21	J-15	Murcia Feed (low point)	0.749
Lost Owl (Comal Water Co.)	199	0.18	46	0.04	J-16	High Point	0.000
Clyde Johnson	555	0.50	420	0.37	J-17	Cordillera Feed (low point)	1.446
Double J. Ranch	405	0.36	263	0.23	J-18	Fair Oaks Feed	1.803
					J-19	High Point (Kendall Prop)	0.642
Cordillera	1,620	1.45	1,050	0.94	J-2	SAWS Feed	1.699
Tapatio Springs/Kendall Co. Utility Co.	1,120	1.00	525	0.47	J-20	Boerne Feed	2.214
Curtis Bremer	255	0.23	105	0.09	J-21	Tapatio/Kendall Co Utility Co	0.999
Kendall Properties	720	0.64	105	0.09	J-22	Bulverde Hills	0.319
Inland Estates ⁽¹⁾	53	0.05	53	0.05	J-23	Low Point	0.000
Craig Elbel	255	0.23	105	0.09	J-24	SARA Feed	0.047
Blanco, City of	-	-	-	-	J-25	High Point	0.000
Dominion Advisory Group, Inc.	-	-	-	-	J-26	High Point	0.000
SUBTOTAL (transmission pipeline)	11,483	10.25	6,853	6.12	J-27	High Point	0.000
					J-28	Low Point	0.000
OUT-OF-DISTRICT					J-3	CISD School Feed	0.091
San Antonio River Authority	53	0.05	53	0.05	J-4	Bexar MWD Feed	2.004
San Antonio Water System	1,903	1.70	1,903	1.70	J-5	Flow Control Element	-14.000
Bexar Metropolitan Water District	2,244	2.00	2,244	2.00	J-6	High Point	0.000
SUBTOTAL (transmission pipeline)	4,200	3.75	4,200	3.75	J-7	Curtis Bremer Feed	0.228
					J-8	Apex Feed	0.317
TOTAL IN AND OUT OF DISTRICT (transmission pipeline)	15,683	14.00	11,053	9.87	J-9	CISD School Feed	0.091
							14.000

14.000

Notes
* Demands in addition to the base case ultimate demand scenario were distributed by proportioning feed locations west of the junction to Boerne by 75% and east of the junction by 25%.
(1) Inland Estates water would probably not be delivered through high svc PS or transmission pipeline due to close proximity to treatment plant. Thus, the delivery quantity is not include

**GBRA REGIONAL WATER SUPPLY SYSTEM
REQUESTED WATER SUPPLY AND AMOUNT AVAILABLE**

Entity	Requested Commitment Delivery				Design Condition			
	Ultimate		Initial		Initial		Ultimate	
	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)	Annual Ave (acft/yr)	Ave ⁽¹⁾ (mgd)
IN-DISTRICT								
City of Boerne	1,861	1.74	500	0.47	500	0.47	1,861	1.74
City of Fair Oaks	1,400	1.31	800	0.75	800	0.75	1,400	1.31
Comal Independent School District	150	0.14	150	0.14	150	0.14	150	0.14
Apex Water Services	200	0.19	100	0.09	100	0.09	200	0.19
Bulverde Utility Corporation (absorbed by Bexar Met.)	202	0.19	202	0.19	202	0.19	202	0.19
Murcia Development Co.	220	0.21	100	0.09	100	0.09	220	0.21
Lost Owl (Comal Water Co.)	44	0.04	5	0.00	5	0.00	44	0.04
Clyde Johnson	400	0.37	100	0.09	100	0.09	400	0.37
Double J. Ranch	250	0.23	100	0.09	100	0.09	250	0.23
Cordillera	1,000	0.94	400	0.37	400	0.37	1,000	0.94
Tapatio Springs/Kendall Co. Utility Co.	500	0.47	150	0.14	150	0.14	500	0.47
Curtis Bremer	100	0.09	0	0.00	0	0.00	100	0.09
Kendall Properties	100	0.09	0	0.00	0	0.00	100	0.09
Inland Estates ⁽²⁾	50	0.05	50	0.05	50	0.05	50	0.05
Craig Elbel	100	0.09	0	0.00	0	0.00	100	0.09
Blanco, City of	-	-	0	0.00	0	0.00	-	-
Dominion Advisory Group, Inc.	-	-	0	0.00	0	0.00	-	-
SUBTOTAL (transmission pipeline)	6,527	6.12	2,607	2.44	2,607	2.44	6,527	6.12
OUT-OF-DISTRICT								
San Antonio River Authority	50	0.05	50	0.05	50	0.05	50	0.05
San Antonio Water System	1,813	1.70	1,813	1.70	4,654	4.36	1,813	1.70
Bexar Metropolitan Water District	2,138	2.00	2,138	2.00	3,216	3.01	2,138	2.00
SUBTOTAL (transmission pipeline)	4,000	3.75	4,000	3.75	7,920	7.42	4,000	3.75
TOTAL IN AND OUT OF DISTRICT (transmission pipeline)	10,527	9.87	6,607	6.19	10,527	9.87	10,527	9.87

Notes

⁽¹⁾ Demand values reported in mgd include additional consideration for 5% system losses expected

Appendix B
Technical Memorandum No. 2

To: File: 07081-033-036

From: Christianne Gaylord
(Registered in California, C57977)

Date: February 3, 2000 (Revised May 23, 2000)

Subject: **Guadalupe-Blanco River Authority Regional Water System
For Portions of Comal, Kendall, and Bexar Counties**
HDR Project No. 07081-033-036
Technical Memorandum No. 2
Determination of Maximum Pipe Pressure Class



Purpose

The purpose of this technical memorandum (TM) is to supplement previous hydraulic analysis of design alternatives evaluated for the Guadalupe-Blanco River Authority (GBRA) Regional Water System for portions of Comal, Kendall, and Bexar Counties. In response to concerns raised during Milestone Meeting No. 1, the maximum pipe pressure class criteria for the mainline of the system has been evaluated further to establish the optimum pressure class for the hydraulic design alternatives. Evaluation includes a comparison of the differential probable costs for the alternative pipeline and pumping station scenarios presented in TM No. 1, *Water Delivery System Hydraulic Design and Expansion Alternatives*, for a phased project expansion.

Basis of Analysis

This analysis is intended to supplement previous analyses presented in TM No. 1 and utilizes the following basic information:

- Preliminary Pipeline Route
- Ground Profile
- System Demand Distribution and Phasing Distribution
- Basic Hydraulic Design Alternatives
 - Alternative 1* – Pump to all delivery points.
 - Alternative 2* – Pressurized gravity from WTP to remote pump station. Pump to downstream delivery points.
- Phased Project Equivalent Pipe Sizing
- Hazen-Williams Friction Coefficient of 120.

Refer to TM No. 1 for a detailed description of the above information. TM No. 2 serves to further evaluate the hydraulic criteria presented in TM No.1, specifically the set maximum pressure within the transfer piping. The maximum value was previously set at 300 psi. The analysis described herein evaluates piping and pumping options for reduced maximum pressures, and details the additional facilities required to accomplish phased project capacity expansion.

Phasing Options for Future Capacity Expansion

In TM No. 1, hydraulic design Alternatives 1 and 2 were evaluated to investigate the potential for expansion of the project facilities to deliver water that may be made available by maximizing capacity of the system. The most feasible expansion options have been evaluated further for the purposes of this TM and include the following:

Alternative 1 - Phased

- **ALT 1P-A.** Increase capacity and head of high service pump station at WTP and pressure class of pipelines.

Alternative 2 - Phased

- **ALT 2P-A.** Increase pipe size in gravity line from WTP to remote PS, increase capacity of remote PS.

Methodology for Evaluation of Preferred Maximum Pipe Pressure Class

The methodology for determination of the preferred maximum pipe pressure class consisted of utilizing the hydraulic grade lines (HGLs) developed in the previous analysis. Since the piping diameters and flows for each phased alternative remain unchanged, the slope of the HGL also remains the same. For simplicity, graphical analysis using the resulting HGLs was conducted to provide a quick, yet reasonable, comparison between the alternatives for varying maximum pipe pressure classes.

The HGL required for each maximum pipe pressure class condition was mapped to provide a minimum working pressure of 10 psi at any point in the line, requiring addition of a booster pump station once the minimum pressure is reached midway through the pipeline. The maximum pipe pressure class values evaluated include the following:

- 300 psi maximum pressure,
- 250 psi maximum pressure,
- 200 psi maximum pressure, and
- Maximum pressures equal or less than 150 psi.

The resulting HGL profiles for the 150 psi, 200 psi, and 250 psi maximum pressure class requirements have been graphed with the resulting 300 psi HGL from TM No. 1 for reference in Figures 1-6 from the WTP to SAWS and in Figures 7-12 from the Boerne junction to BMWD.

Required Piping Lengths

The required piping lengths for each maximum pressure class requirement were evaluated directly from the HGL profiles. Since this graphic methodology varies distinctly from the spreadsheet calculation methodology used in TM No.1, the resulting distances are not equivalent. In fact, since only the extreme high and low ground points were used to create the HGL profiles, estimation of required pressure class by graphical methods results in an averaged value, rather than the maximum estimated value predicted from TM No. 1 spreadsheet calculations. However, for the purposes of this comparison, the 300 psi pressure class maximum originally evaluated in TM No. 1 was estimated graphically to produce an averaged value comparable to the remaining

analyses. The resulting measured lengths are tabulated for each size of pipe and corresponding pressure class in Table 1, *Summary of Required Piping – Maximum Pressure Class Evaluation*.

TABLE 1 – Summary of Required Piping – Maximum Pressure Class Evaluation

	ALT 1P-A				ALT 2P-A			
	Max. Pressure Class ¹ (psi)				Max. Pressure Class ¹ (psi)			
	150 psi	200 psi	250 psi	300 psi	150 psi	200 psi	250 psi	300 psi
Pipe length, ft (p<150psi)	193841	137689	75841	50898	193841	147341	125841	103398
Pipe length, ft (150<p<200psi)	0	56152	73000	23943	0	38500	35500	24443
Pipe length, ft (200<p<250psi)	0	0	45000	57500	0	8000	24500	28500
Pipe length, ft (250<p<300psi)	0	0	0	61500	0	0	8000	37500

¹ Represents maximum pressure class in main pipeline and does not include branch to BMW.D.

Required Pumping Facilities

The required pumping facilities for each phased hydraulic design alternative were evaluated. The resulting pumping requirements associated with each maximum pressure class requirement for each alternative is summarized in Table 2, *Summary of Pumping Requirements – Maximum Pressure Class Evaluation*.

TABLE 2 – Summary of Pumping Requirements – Maximum Pressure Class Evaluation

	ALT 1P-A				ALT 2P-A			
	Max. Pressure Class ¹ (psi)				Max. Pressure Class ¹ (psi)			
	150 psi	200 psi	250 psi	300 psi	150 psi	200 psi	250 psi	300 psi
No. of Req'd PS	3	2	2	1	3	2	2	1
PS ₁ hp	680	1050	1440	1910	630	990	1350	1570
PS ₂ hp	840	490	290	-	900	480	250	-
PS ₃ hp	20	-	-	-	100	-	-	-

¹ Represents maximum pressure class in main pipeline and does not include branch to BMW.D.

Required System Storage

Because it is a unique component of some hydraulic design alternatives evaluated, the additional storage that may be required at remote pumping facilities was considered. For all practical purposes, the minimum storage needed at a remote pumping facility was assumed as 0.5 million gallons.

Relative Cost Comparison of Alternatives

Costs for facilities and O&M required for each alternative were evaluated to provide a cost comparison between alternatives.

Cost Basis

For the purpose of this comparison, only unique components were evaluated for cost, not including all common components. The resulting cost value is useful for determining the relative difference between alternatives and should in no way be construed as total for any alternative.

The cost comparison included consideration for the following unique components:

- Transmission pipelines
- WTP/Remote Booster Pump Stations
- System Storage
- Electrical Feed
- Additional Land Acquisition (Remote PS and Storage Tank)
- Pumping Costs
- Operation and Maintenance for Pump Stations, Transmission and Storage Facilities

The cost comparison does not include the following common components:

- Intake
- WTP
- RW Pipeline
- Interconnects
- Equilization Tank
- Environmental Studies and Mitigation
- Land ROW Cost
- Engineering and Financing Costs

The resulting costs for each maximum pressure class requirement for each evaluated alternative is listed in Table 3, *Preliminary Estimate of Costs – Maximum Pressure Class Evaluation*.

TABLE 3 – Preliminary Estimate of Costs – Maximum Pressure Class Evaluation

PRELIMINARY ESTIMATE OF COSTS ⁽¹⁾

Basis of Comparison	ALT 1P-A				ALT 2P-A			
	150 psi Max	200 psi Max	250 psi Max	300 psi Max	150 psi Max	200 psi Max	250 psi Max	300 psi Max
Capital Costs								
Transmission Pipelines ⁽²⁾	\$ 14,225,000	\$ 14,746,000	\$ 15,889,000	\$ 17,754,000	\$ 15,199,000	\$ 15,641,000	\$ 16,184,000	\$ 17,031,000
WTP Pump Station	\$ 991,000	\$ 1,425,000	\$ 1,861,000	\$ 2,385,000	-	-	-	-
Booster Pump Station 1	\$ 1,180,000	\$ 766,000	\$ 558,000	-	\$ 932,000	\$ 1,358,000	\$ 1,760,000	\$ 2,006,000
Booster Pump Station 2	\$ 558,000	-	-	-	\$ 1,251,000	\$ 754,000	\$ 558,000	-
Booster Pump Station 3	-	-	-	-	\$ 558,000	-	-	-
System Storage	\$ 799,000	\$ 399,000	\$ 399,000	\$ -	\$ 1,198,000	\$ 799,000	\$ 799,000	\$ 399,000
Electrical Feed	\$ 193,000	\$ 193,000	\$ 216,000	\$ 239,000	\$ 204,000	\$ 184,000	\$ 200,000	\$ 196,000
Total Capital Cost ⁽³⁾	\$ 17,946,000	\$ 17,529,000	\$ 18,923,000	\$ 20,378,000	\$ 19,342,000	\$ 18,736,000	\$ 19,501,000	\$ 19,632,000
Add'l Land Acquisition (PS and Storage Tank)	\$ 14,000	\$ 7,000	\$ 7,000	\$ -	\$ 20,000	\$ 14,000	\$ 14,000	\$ 7,000
Total Project Cost ⁽³⁾	\$ 17,960,000	\$ 17,536,000	\$ 18,930,000	\$ 20,378,000	\$ 19,362,000	\$ 18,750,000	\$ 19,515,000	\$ 19,639,000
Annual O&M Costs								
Annual Debt Service (Assuming 25 years, effective interest rate of 6.5%)	\$ 1,473,000	\$ 1,438,000	\$ 1,552,000	\$ 1,671,000	\$ 1,588,000	\$ 1,538,000	\$ 1,600,000	\$ 1,610,000
Pumping Costs	\$ 808,000	\$ 809,000	\$ 902,000	\$ 999,000	\$ 849,000	\$ 772,000	\$ 837,000	\$ 820,000
Operation and Maintenance ⁽⁴⁾								
Pump Station	\$ 68,000	\$ 55,000	\$ 60,000	\$ 60,000	\$ 69,000	\$ 53,000	\$ 58,000	\$ 50,000
Transmission Facilities	\$ 142,000	\$ 147,000	\$ 159,000	\$ 178,000	\$ 152,000	\$ 156,000	\$ 162,000	\$ 170,000
Storage Facilities	\$ 8,000	\$ 4,000	\$ 4,000	\$ -	\$ 12,000	\$ 8,000	\$ 8,000	\$ 4,000
	\$ 1,026,000	\$ 1,015,000	\$ 1,125,000	\$ 1,237,000	\$ 1,082,000	\$ 989,000	\$ 1,065,000	\$ 1,044,000
Total Annual Cost ⁽³⁾	\$ 2,499,000	\$ 2,453,000	\$ 2,677,000	\$ 2,908,000	\$ 2,670,000	\$ 2,527,000	\$ 2,665,000	\$ 2,654,000

⁽¹⁾ Costs are developed for purposes of preliminary evaluation and include only those costs that vary between the alternatives. Thus, the costs should not be taken as final estimates for any alternative. Maximum pressures represent max pressures in main pipeline, not including branch to BMWD. For comparison purposes, costs are based on a Phased Project production of 15,683 acft/yr (14 mgd) - the maximum capacity of Alternative 1.

⁽²⁾ Lengths obtained by graphical analysis of hydraulic profile using only a limited number of ground points for reference. This methodology was applied for comparative analysis only. Actual piping lengths will vary in design.

⁽³⁾ Items not included for cost comparison due to equivalence between alternatives include: Intake, Intake Pump Station and Water Treatment Plant, Interconnects to all participants, Equalization Tank near Boerne/SAWS Delivery Point, Environmental Studies

⁽⁴⁾ O&M costs assume 1% of the total capital costs of pipelines and tanks; 2.5% of the total capital cost of pump stations.

Conclusion

The results of this analysis indicate that there exists an optimum maximum pressure class at which both piping and pumping requirements are optimized for cost savings. For both hydraulic design alternatives, under full capacity expansion, the maximum pressure class requirement of 200 psi proves to be preferable on a cost basis.

Comparing the 200 psi maximum pressure class of both alternatives, ALT 1P-A and ALT 2P-A, indicates ALT 1P-A – pumped delivery to all customers- to be most preferable. Although the O&M costs for ALT 1P-A exceed those associated with partial pressurized gravity conveyance of ALT 2P-A, the cost savings is obtained from the capital cost of transmission facilities for the smaller diameter piping required for ALT 1P-A.