





Control Number: 43895



Item Number: 15

Addendum StartPage: 0



Bleyl & Associates
Planning • Engineering • Management

318 W. Highland
San Angelo, Texas 76903
Tex. Reg. No. F-678

May 29, 2015

2015 JUN -1 AM 10:53

PUBLIC UTILITY COMMISSION
FILING CLERK

Public Utility Commission of Texas
Ms. Elisabeth English
Engineering Specialist
Water Utilities Division
1701 N. Congress Avenue
Austin, Texas 78711-3326

Reference: Concho Rural Water Corporation – CCN No. 11361
CCN Amendment/Expansion
B&A Project No. 11203

Dear Ms. English:

On behalf of our client, Concho Rural Water Corporation (“CRWC”), we request approval of the proposed Certificate of Convenience and Necessity (“CCN”) to cover the proposed Arden Road Public Water System (the “PWS”). In reference to the Commission Staff’s response, Docket No. 43895, we have cured the mapping related deficiencies and provided the following documents attached to this letter:

- Detailed map delineating the proposed service area
- Copy of the Corporation’s Certificate of Account Status from the Texas Comptroller of Public Accounts
- Complete list of neighboring entities within the 2-mile buffer of the proposed water service area
- Copy of the Plans and Specifications Approval Letter from the Texas Commission on Environmental Quality (TCEQ)
- Digital Copy of detailed map including DWG. file and text file with coordinate system used
- Statement identifying the effect of granting the CCCN amendment

Effect of granting the CCN Amendment:

Commercial properties along the north and south side of Arden Road are beginning to be developed and potential water customers have requested water supply from the City and CRWC, the proposed CCN Amendment will allow CRWC to bill existing and future water customers for water delivered by the new PWS.

If you have any questions or need additional information please contact me at (325) 262-4082 or by e-mail at dfentress@bleylengineering.com.

Sincerely,

Darrin Fentress, P.E.

Enclosures

cc: Concho Rural Water Corporation

Mr. Ben Wiese, Owner

San Angelo
(325) 262-4082
(325) 480-0451

Bryan
(979) 268-1125
(979) 260-3849 Fax

Austin
(512) 328-7878
(512) 328-7884 Fax

Conroe
(936) 441-7833
(936) 760-3833 Fax

15


Effect of Granting CCN Amendment

Reference: Concho Rural Water Corporation – CCN No. 11361
CCN Amendment/Expansion
B&A Project No. 11203

Statement:

Commercial properties along the north and south side of Arden Road are beginning to be developed and potential water customers have requested water supply from the City and CRWC, the proposed CCN Amendment will allow CRWC to bill existing and future water customers for water delivered by the new PWS.

Engineer:



Darrin Fentress, P.E.

Bryan W. Shaw, Ph.D., P.E., *Chairman*
Toby Baker, *Commissioner*
Zak Covar, *Commissioner*
Richard A. Hyde, P.E., *Executive Director*

PWS_2260008_CO_20150212_PlanLtr
contappr.doc

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

February 12, 2015

Mr. Darrin Fentress, P.E.
Bleyl and Associates
318 W. Highland Blvd.
San Angelo, TX 76903

Re: Concho Rural Water Grape Creek - Public Water System ID No. 2260008
Waterline Extension – Arden Road (Ref P-12042014-030)
Engineer Contact Telephone: (325) 262-4082
Plan Review Log No.: P-02032015-006
Tom Green County, Texas

CN600656995; RN101218840

Dear Mr. Fentress:

On December 4, 2014 and February 3, 2015, the Texas Commission on Environmental Quality (TCEQ) received planning material for the above referenced waterline extension. Based on our review, the project generally meets the minimum requirements of the Title 30 Texas Administrative Code (TAC) Chapter 290 - Rules and Regulations for Public Water Systems (Rules) and is **conditionally approved for construction if the project meets the following requirement(s)**:

- Waterline locations shall comply with Chapter 290.44(e) of the Rules with regard to separation distances from sources of potential contamination.
- Retail water service shall not be provided prior to obtaining a Certificate of Convenience and Necessity (CCN) for all areas served by the proposed waterline extension.

The submittal consisted of 6 sheets of engineering drawings, technical specifications, engineering report and executed water purchase agreements between Concho Rural Water Corporation (CRWC), the Upper Colorado River Authority (the Authority) and the City of San Angelo (COSA). **The approved project consists of:**

- 320 linear feet (lf) of 16-inch American Water Works Association (AWWA) C905 DR25 polyvinyl chloride (PVC) pipe;
- 4,960 lf of 8-inch AWWA C900 DR18 PVC pipe;
- Master meter with backflow preventer; and
- Various valves and fittings.

Mr. Darrin Fentress, P.E.
Page 2
February 12, 2015

This approval is for the construction of the above listed items only. Any wastewater components contained in this design were not considered.

The Concho Rural Water Grape Creek public water system provides water treatment for the system.

An appointed engineer must notify the TCEQ's Region Office 8 in San Angelo at (325) 481-8061 when construction will start. Please keep in mind that upon completion of the water works project, the engineer or owner will notify the commission's Water Supply Division, in writing, as to its completion and attest to the fact that the work has been completed essentially according to the plans and change orders on file with the commission as required in Title 30 TAC §290.39(h)(3).

Please refer to the Utilities Technical Review Team's Log No. P-02032015-006 in all correspondence for this project. This will help complete our review and prevent it from being considered a new project.

Please complete a copy of the most current Public Water System Plan Review Submittal form for any future submittal to TCEQ. Every blank on the form must be completed to minimize any delays in the review of your project. The document is available on our website at the address shown below.

<http://www.tceq.texas.gov/utilities/planrev.html>

For future reference, you can review part of the Utilities Technical Review Team's database to see if we have received your project. This is available on the TCEQ's homepage on the Internet at the following address:

<http://www.tceq.texas.gov/utilities/planrev.html#status>

You can download most of the well construction checklists and the latest revision of Chapter 290 "Rules and Regulations for Public Water Systems" from this site.

Mr. Darrin Fentress, P.E.


Page 3

February 12, 2015

If you have any questions please contact John Lock at (512)239-4710 or by email at "john.lock@tceq.texas.gov" or by correspondence at the following address:

Utilities Technical Review Team, MC-159
Texas Commission on Environmental Quality
P.O. Box 13087
Austin, Texas 78711-3087

Sincerely,



John Lock, P.E.
Utilities Technical Review Team, MC-159
Water Supply Division
Texas Commission on Environmental Quality



Vera Poe, P.E., Team Leader
Utilities Technical Review Team
Plan and Technical Review Section
Water Supply Division
Texas Commission on Environmental Quality

JL/AN

cc: CRWC, 8174 US 87 N., San Angelo, TX 76901



Franchise Tax Account Status

As of 05/29/2015 08:27:44 AM

This Page is Not Sufficient for Filings with the Secretary of State

CONCHO RURAL WATER CORPORATION	
--------------------------------	--

Texas Taxpayer Number	17520171905
-----------------------	-------------

Mailing Address	PO BOX 388 CARLSBAD, TX 76934-0388
-----------------	---------------------------------------

Right to Transact Business in	ACTIVE
Texas	

State of Formation	TX
--------------------	----

Effective SOS Registration	06/03/1983
Date	

Texas SOS File Number	0065831000
-----------------------	------------

Registered Agent Name	BENJAMIN F WIESE IV
-----------------------	---------------------

Registered Office Street	8174 HWY 87N
Address	SAN ANGELO, TX 76901

Survey 1
A.B. & M Survey 3

PROPOSED CCN
11361 AMENDMENT
BOUNDARY

S 89°45'31" E
5061.35

S 66°18'46" W
571.21

N 71°40'32" E
322.02

A.B. & M Survey 3
B.S. & F Survey 5

N 88°32'22" E
512.36

P.O.B.
Y=10490863.5
X=2238111.3

F.M. 2288
R.O.W.

N 0°14'29" E
210.00

AT 7.98 PASS %
I.R. SET IN 2010

N 89°45'31" W
5095.68

F.M. 853
ASPHALT ROAD

S 71°40'32" W
325.21

TXDOT ALUM. DISK
SW "20.695" AC.

TXDOT ALUM. DISK
at 168.67

S 88°32'22" W
410.63

S 17°07'19" W
221.55

NEIGHBORING ENTITIES WITHIN 2 MILE BUFFER	
NAME	TYPE
CITY OF SAN ANGELO ETJ	CITY ETJ
CONCHO RURAL WATER CORP. CCN NO. 11361	CCN
CITY OF SAN ANGELO CCN NO. 20097	CCN
TOM GREEN COUNTY	COUNTY



Bleyl & Associates
318 W. HIGHLAND
SAN ANGELO, TX 76903
TEL: 325-480-0451 FAX: 325-480-0451
www.bleylassociates.com

PROPOSED SERVICE AREA

SCALE: AS SHOWN
DATE: 05/27/2015
DRAWN BY: MRC
CHECKED BY: DMF
PREPARED FOR:
CONCHO RURAL WATER CORP.
8174 N. US HWY 87
SAN ANGELO, TEXAS 76901
(325) 658-2961