



2017

LANDUSE	
	COMMERCIAL/INDUSTRIAL
	SINGLE FAMILY RESIDENTIAL
	RURAL SINGLE FAMILY
	RESIDENTIAL >2 ACRES
	PARKLAND
	PUBLIC WATER SUPPLY
	AGRICULTURAL/RANCH
	SCHOOL

U.S. HWY. 183

U.S. HWY. 183

STATE

WILLIAMSON COUNTY
TRAVIS COUNTY



2022

LANDUSE	
	COMMERCIAL/INDUSTRIAL
	SINGLE FAMILY RESIDENTIAL
	RURAL SINGLE FAMILY
	RESIDENTIAL > 2 ACRES
	PARKLAND
	PUBLIC WATER SUPPLY
	AGRICULTURAL/RANCH
	SCHOOL

U.S. HWY. 183

U.S. HWY. 183

STATE

WILLAMSON COUNTY
TRAVIS COUNTY

APPENDIX 2

GRAVITY COLLECTION SYSTEM LAYOUT / PRELIMINARY PLAN & PROFILE DRAWINGS

APPENDIX 3

LOW PRESSURE SEWER SYSTEM



July 11, 2002

David Allen
Baker-Aicklen & Associates, Inc.
405 Brushy Creek Rd.
Cedar Park, TX 78613

Dear David,

This design analysis examines the use of a low pressure sewer system using Environment One grinder pumps for Liberty Hill. The low pressure sewer approach provides not only a technical solution, but also an economic advantage to be realized with low up front costs.

System Analysis

Using the drawings and data you supplied, I ran the enclosed preliminary pressure sewer pipe sizing and branch analysis. This was run through our computer design program that employs our latest Flow Velocity and Friction Head Loss vs. Pumps in Simultaneous Operation Spreadsheet.

The design criteria for the software calculation program is based on the *Hazen-Williams* formulas for determining pipe sizes (calculations for Cross Sectional Area, Velocity and Friction Loss) to create flow velocities of 2.00 fps or higher. At these velocities scouring is assured. Pipe sizes are based on the ID of the pipe type selected. A "C" factor of 150, SDR 21 PVC pipe, and daily flow per home of 200 gpd are used in this analysis.

There are 156 simplex grinder pump stations in this analysis, 1 duplex station (for the rest home), and a conventional pump station for the school. Two sets of hydraulic data are included, indicating the system characteristics when the school pump station is "on" and when it is "off". The highest Total Dynamic Head generated in the system is 133 feet. This is below our continuous-run rating of 138 feet. Flow velocity, when the school pump station is off, is low in zones 1 and 12, but is not a problem provided that it runs regularly. During vacation periods when this station is inactive, it is recommended that zones 1 and 12 are periodically flushed.

General recommendations for valve placement are as follows: flushing connections at 1,500' to 2,000' intervals and at branch ends and junctions; isolation valves at all branch junctions; and air release valves at peaks of 25 feet or more and/or at intervals of 2,000 to 2,500 feet.

Quantities of grinder pumps, pipe, and appurtenances are indicated on the cost page. Costs of these items and their installation are best obtained from sources in your region.

I am looking forward to working with you on this and future projects. If you any questions or require additional information please call me at extension 3022.

Sincerely,

A handwritten signature in cursive script, appearing to read "Bruce Richardson", followed by a horizontal line.

Bruce Richardson
LPS System Designer



Environment One Corporation

**Pressure Sewer Preliminary
Cost and Design Analysis
For
Liberty Hill, TX**

Prepared For:
Baker-Aicklen & Associates, Inc. - Cedar Creek Office
405 Brushy Creek Rd.
Cedar Park TX 78613
Tel: 512 260-3700
Fax: 512 260-3701
Prepared By: Bruce Richardson
July 11, 2002

Zone Number	Pumps to Zone	Number of Cores in Zone	Accum Cores in Zone	Gal/Day per Core	Max Flow per Core	Max Sim Ops	Max Flow (GPM)	Pipe Size (Inches)	Max Velocity (FPS)	Length of Main this Zone	Friction Loss Factor (ft/100ft)	Friction Loss this Zone	Accumulated Friction Loss (Feet)	Max Main Elevation	Minimum Pump Elevation	Static Head (Feet)	Total Dynamic Head (ft)
1.00	6.00	3	3	200.00	11.00	2	67.00	3.00	2.73	550.00	0.87	4.78	75.36	1,025.00	1,000.00	25.00	100.36
PS 1.00 GPD: 20000.00 GPM: 45.00 Desc: School Pump Station																	
2.00	6.00	3	3	200.00	11.00	2	22.00	1.50	3.04	382.00	2.15	8.22	78.80	1,025.00	1,000.00	25.00	103.80
3.00	4.00	3	3	200.00	11.00	2	22.00	1.50	3.04	365.00	2.15	7.85	94.24	1,025.00	1,000.00	25.00	119.24
4.00	5.00	6	9	200.00	11.00	3	33.00	2.00	2.92	573.00	1.54	8.84	86.39	1,025.00	1,000.00	25.00	111.39
5.00	6.00	3	12	200.00	11.00	4	44.00	2.00	3.89	265.00	2.63	6.97	77.54	1,025.00	1,000.00	25.00	102.54
6.00	12.00	1	19	200.00	11.00	5	100.00	3.00	4.07	340.00	1.83	6.21	70.58	1,025.00	1,000.00	25.00	95.58
7.00	8.00	3	3	200.00	11.00	2	22.00	1.50	3.04	200.00	2.15	4.30	78.60	1,025.00	1,000.00	25.00	103.60
8.00	12.00	4	7	200.00	11.00	3	33.00	2.00	2.92	643.00	1.54	9.92	74.29	1,025.00	1,000.00	25.00	99.29
9.00	10.00	3	3	200.00	11.00	2	22.00	1.50	3.04	286.00	2.15	6.15	92.02	1,025.00	1,000.00	25.00	117.02
10.00	11.00	6	9	200.00	11.00	3	33.00	2.00	2.92	521.00	1.54	8.04	85.87	1,025.00	1,000.00	25.00	110.87
11.00	12.00	6	15	200.00	11.00	4	44.00	2.00	3.89	512.00	2.63	13.46	77.83	1,025.00	1,000.00	25.00	102.83
12.00	20.00	5	46	200.00	11.00	6	111.00	4.00	2.73	269.00	0.65	1.75	64.37	1,025.00	1,000.00	25.00	89.37
13.00	14.00	3	3	200.00	11.00	2	22.00	1.50	3.04	208.00	2.15	4.48	76.74	1,025.00	1,000.00	25.00	101.74
14.00	16.00	2	5	200.00	11.00	3	33.00	2.00	2.92	121.00	1.54	1.87	72.26	1,025.00	1,000.00	25.00	97.26
15.00	16.00	2	2	200.00	11.00	2	22.00	1.50	3.04	243.00	2.15	5.23	75.63	1,025.00	1,000.00	25.00	100.63
16.00	20.00	1	8	200.00	11.00	3	33.00	2.00	2.92	504.00	1.54	7.78	70.40	1,025.00	1,000.00	25.00	95.40
17.00	18.00	3	3	200.00	11.00	2	22.00	1.50	3.04	330.00	2.15	7.10	86.30	1,025.00	1,000.00	25.00	111.30
18.00	19.00	6	9	200.00	11.00	3	33.00	2.00	2.92	512.00	1.54	7.90	79.20	1,025.00	1,000.00	25.00	104.20
19.00	20.00	5	14	200.00	11.00	4	44.00	2.00	3.89	330.00	2.63	8.67	71.30	1,025.00	1,000.00	25.00	96.30
20.00	26.00	9	77	200.00	11.00	7	122.00	4.00	3.01	280.00	0.78	2.17	62.62	1,025.00	1,000.00	25.00	87.62
21.00	22.00	3	3	200.00	11.00	2	22.00	1.50	3.04	313.00	2.15	6.73	73.20	1,025.00	1,000.00	25.00	98.20
22.00	26.00	2	5	200.00	11.00	3	33.00	2.00	2.92	390.00	1.54	6.02	66.47	1,025.00	1,000.00	25.00	91.47
23.00	24.00	3	3	200.00	11.00	2	22.00	1.50	3.04	234.00	2.15	5.03	79.46	1,025.00	1,000.00	25.00	104.46
24.00	25.00	6	9	200.00	11.00	3	33.00	2.00	2.92	565.00	1.54	8.72	74.43	1,025.00	1,000.00	25.00	99.43
25.00	26.00	2	11	200.00	11.00	4	44.00	2.00	3.89	200.00	2.63	5.26	65.71	1,025.00	1,000.00	25.00	90.71
26.00	42.00	3	96	200.00	11.00	8	133.00	4.00	3.28	217.00	0.91	1.97	60.45	1,025.00	1,000.00	25.00	85.45
27.00	29.00	3	3	200.00	11.00	2	22.00	1.50	3.04	340.00	2.15	7.32	76.03	1,025.00	1,000.00	25.00	101.03
28.00	29.00	2	2	200.00	11.00	2	22.00	1.50	3.04	234.00	2.15	5.03	73.75	1,025.00	1,000.00	25.00	98.75
29.00	32.00	3	8	200.00	11.00	3	33.00	2.00	2.92	217.00	1.54	3.35	68.72	1,025.00	1,000.00	25.00	93.72
30.00	31.00	3	3	200.00	11.00	2	22.00	1.50	3.04	373.00	2.15	8.03	80.23	1,025.00	1,000.00	25.00	105.23
31.00	32.00	1	4	200.00	11.00	3	33.00	2.00	2.92	443.00	1.54	6.84	72.20	1,025.00	1,000.00	25.00	97.20
32.00	39.00	2	14	200.00	11.00	4	44.00	2.00	3.89	156.00	2.63	4.10	65.37	1,025.00	1,000.00	25.00	90.37
33.00	35.00	3	3	200.00	11.00	2	22.00	1.50	3.04	521.00	2.15	11.21	107.90	1,025.00	1,000.00	25.00	132.90
34.00	35.00	2	2	200.00	11.00	2	22.00	1.50	3.04	217.00	2.15	4.67	101.36	1,025.00	1,000.00	25.00	126.36
35.00	38.00	6	11	200.00	11.00	4	44.00	2.00	3.89	625.00	2.63	16.43	96.69	1,025.00	1,000.00	25.00	121.69
36.00	37.00	3	3	200.00	11.00	2	22.00	1.50	3.04	113.00	2.15	2.43	85.90	1,025.00	1,000.00	25.00	110.90

Zone Number	Pumps to Zone	Number of Cores in Zone	Accum Cores in Zone	Gal/Day per Core	Max Flow per Core	Max Sim Ops	Max Flow (GPM)	Pipe Size (Inches)	Max Velocity (FPS)	Length of Main this Zone	Friction Loss Factor (ft/100ft)	Friction Loss this Zone	Accumulated Friction Loss (Feet)	Max Main Elevation	Minimum Pump Elevation	Static Head (Feet)	Total Dynamic Head (ft)
its spreadsheet was calculated using pipe diameters for: SDR21PVC																	
37.00	38.00	5	8	200.00	11.00	3	33.00	2.00	2.92	208.00	1.54	3.21	83.47	1,025.00	1,000.00	25.00	108.47
38.00	39.00	4	23	200.00	11.00	5	55.00	2.00	4.86	478.00	3.97	19.00	80.26	1,025.00	1,000.00	25.00	105.26
39.00	42.00	3	40	200.00	11.00	6	66.00	3.00	2.69	330.00	0.85	2.79	61.27	1,025.00	1,000.00	25.00	86.27
40.00	41.00	3	3	200.00	11.00	2	22.00	1.50	3.04	347.00	2.15	7.47	75.86	1,025.00	1,000.00	25.00	100.86
41.00	42.00	4	7	200.00	11.00	3	33.00	2.00	2.92	643.00	1.54	9.92	68.40	1,025.00	1,000.00	25.00	93.40
42.00	44.00	10	153	200.00	11.00	10	155.00	4.00	3.82	947.00	1.21	11.44	58.48	1,025.00	1,000.00	25.00	83.48
43.00	44.00	3	3	200.00	11.00	2	22.00	1.50	3.04	313.00	2.15	6.73	53.77	1,025.00	1,000.00	25.00	78.77
44.00	44.00	1	157	200.00	11.00	10	155.00	4.00	3.82	3,894.00	1.21	47.04	47.04	1,025.00	1,000.00	25.00	72.04

Zone Number	Pumps to Zone	Accumulated Total of Cores this Zone	Existing Pipe Size	Gallons per 100 Lineal Feet	Length of Zone	Capacity of Zone	Average Daily Flow	Average Fluid Changes per Day	Average Retention Time (Hr)	Accumulated Retention Time (Hr)
this spreadsheet was calculated using pipe diameters for: SDR21PVC										
1.00	6.00	3	3.00	40.90	550.00	224.93	20,600	91.58	0.26	2.30
2.00	6.00	3	1.50	12.07	382.00	46.11	600	13.01	1.84	3.89
3.00	4.00	3	1.50	12.07	365.00	44.06	600	13.62	1.76	5.74
4.00	5.00	9	2.00	18.84	573.00	107.97	1,800	16.67	1.44	3.98
5.00	6.00	12	2.00	18.84	265.00	49.93	2,400	48.07	0.50	2.54
6.00	12.00	19	3.00	40.90	340.00	139.05	23,800	171.17	0.14	2.04
7.00	8.00	3	1.50	12.07	200.00	24.14	600	24.85	0.97	4.94
8.00	12.00	7	2.00	18.84	643.00	121.16	1,400	11.56	2.08	3.98
9.00	10.00	3	1.50	12.07	286.00	34.52	600	17.38	1.38	5.36
10.00	11.00	9	2.00	18.84	521.00	98.17	1,800	18.34	1.31	3.98
11.00	12.00	15	2.00	18.84	512.00	96.47	3,000	31.10	0.77	2.67
12.00	20.00	46	4.00	67.65	269.00	181.98	29,200	160.46	0.15	1.90
13.00	14.00	3	1.50	12.07	208.00	25.11	600	23.90	1.00	4.73
14.00	16.00	5	2.00	18.84	121.00	22.80	1,000	43.86	0.55	3.72
15.00	16.00	2	1.50	12.07	243.00	29.33	400	13.64	1.76	4.94
16.00	20.00	8	2.00	18.84	504.00	94.96	1,600	16.85	1.42	3.18
17.00	18.00	3	1.50	12.07	330.00	39.83	600	15.06	1.59	5.16
18.00	19.00	9	2.00	18.84	512.00	96.47	1,800	18.66	1.29	3.57
19.00	20.00	14	2.00	18.84	330.00	62.18	2,800	45.03	0.53	2.29
20.00	26.00	77	4.00	67.65	280.00	189.42	35,400	186.88	0.13	1.75
21.00	22.00	3	1.50	12.07	313.00	37.78	600	15.88	1.51	4.90
22.00	26.00	5	2.00	18.84	390.00	73.48	1,000	13.61	1.76	3.39
23.00	24.00	3	1.50	12.07	234.00	28.24	600	21.24	1.13	4.58
24.00	25.00	9	2.00	18.84	565.00	106.46	1,800	16.91	1.42	3.45
25.00	26.00	11	2.00	18.84	200.00	37.68	2,200	58.38	0.41	2.03
26.00	42.00	96	4.00	67.65	217.00	146.80	39,200	267.02	0.09	1.62
27.00	29.00	3	1.50	12.07	340.00	41.04	600	14.62	1.64	4.45
28.00	29.00	2	1.50	12.07	234.00	28.24	400	14.16	1.69	4.50
29.00	32.00	8	2.00	18.84	217.00	40.89	1,600	39.13	0.61	2.80
30.00	31.00	3	1.50	12.07	373.00	45.02	600	13.33	1.80	6.50
31.00	32.00	4	2.00	18.84	443.00	83.47	800	9.58	2.50	4.69
32.00	39.00	14	2.00	18.84	156.00	29.39	2,800	95.26	0.25	2.19
33.00	35.00	3	1.50	12.07	521.00	62.89	600	9.54	2.52	6.21
34.00	35.00	2	1.50	12.07	217.00	26.19	400	15.27	1.57	5.26
35.00	38.00	11	2.00	18.84	625.00	117.76	2,200	18.68	1.28	3.69
36.00	37.00	3	1.50	12.07	113.00	13.64	600	43.99	0.55	3.54
37.00	38.00	8	2.00	18.84	208.00	39.19	1,600	40.82	0.59	3.00
38.00	39.00	23	2.00	18.84	478.00	90.07	4,600	51.07	0.47	2.41
39.00	42.00	40	3.00	40.90	330.00	134.96	8,000	59.28	0.40	1.94

Zone Number	Pumps to Zone	Accumulated Total of Cores this Zone	Existing Pipe Size	Gallons per 100 Lineal Feet	Length of Zone	Capacity of Zone	Average Daily Flow	Average Fluid Changes per Day	Average Retention Time (Hr)	Accumulated Retention Time (Hr)
this spreadsheet was calculated using pipe diameters for: SDR21PVC										
40.00	41.00	3	1.50	12.07	347.00	41.88	600	14.33	1.68	5.29
41.00	42.00	7	2.00	18.84	643.00	121.16	1,400	11.56	2.08	3.61
42.00	44.00	153	4.00	67.65	947.00	640.66	50,600	78.98	0.30	1.53
43.00	44.00	3	1.50	12.07	313.00	37.78	600	15.88	1.51	2.74
44.00	44.00	157	4.00	67.65	3,894.00	2,634.33	51,400	19.51	1.23	1.23

Zone Number	Pumps to Zone	Number of Cores in Zone	Accum Cores in Zone	Gal/Day per Core	Max Flow per Core	Max Sim Ops	Max Flow (GPM)	Pipe Size (Inches)	Max Velocity (FPS)	Length of Main this Zone	Friction Loss Factor (ft/100ft)	Friction Loss this Zone	Accumulated Friction Loss (Feet)	Max Main Elevation	Minimum Pump Elevation	Static Head (Feet)	Total Dynamic Head (ft)
1.00	6.00	3	3	200.00	11.00	2	22.00	3.00	0.90	550.00	0.11	0.61	36.16	1,025.00	1,000.00	25.00	61.16
Friction loss calculations were based on a Constant for inside roughness = 150																	
2.00	6.00	3	3	200.00	11.00	2	22.00	1.50	3.04	382.00	2.15	8.22	43.77	1,025.00	1,000.00	25.00	68.77
3.00	4.00	3	3	200.00	11.00	2	22.00	1.50	3.04	365.00	2.15	7.85	59.21	1,025.00	1,000.00	25.00	84.21
4.00	5.00	6	9	200.00	11.00	3	33.00	2.00	2.92	573.00	1.54	8.84	51.36	1,025.00	1,000.00	25.00	76.36
5.00	6.00	3	12	200.00	11.00	4	44.00	2.00	3.89	265.00	2.63	6.97	42.51	1,025.00	1,000.00	25.00	67.51
6.00	12.00	1	19	200.00	11.00	5	55.00	3.00	2.24	340.00	0.60	2.05	35.55	1,025.00	1,000.00	25.00	60.55
7.00	8.00	3	3	200.00	11.00	2	22.00	1.50	3.04	200.00	2.15	4.30	47.72	1,025.00	1,000.00	25.00	72.72
8.00	12.00	4	7	200.00	11.00	3	33.00	2.00	2.92	643.00	1.54	9.92	43.42	1,025.00	1,000.00	25.00	68.42
9.00	10.00	3	3	200.00	11.00	2	22.00	1.50	3.04	286.00	2.15	6.15	61.15	1,025.00	1,000.00	25.00	86.15
10.00	11.00	6	9	200.00	11.00	3	33.00	2.00	2.92	521.00	1.54	8.04	55.00	1,025.00	1,000.00	25.00	80.00
11.00	12.00	6	15	200.00	11.00	4	44.00	2.00	3.89	512.00	2.63	13.46	46.96	1,025.00	1,000.00	25.00	71.96
12.00	20.00	5	46	200.00	11.00	6	66.00	4.00	1.63	269.00	0.25	0.67	33.50	1,025.00	1,000.00	25.00	58.50
13.00	14.00	3	3	200.00	11.00	2	22.00	1.50	3.04	208.00	2.15	4.48	46.95	1,025.00	1,000.00	25.00	71.95
14.00	16.00	2	5	200.00	11.00	3	33.00	2.00	2.92	121.00	1.54	1.87	42.47	1,025.00	1,000.00	25.00	67.47
15.00	16.00	2	2	200.00	11.00	2	22.00	1.50	3.04	243.00	2.15	5.23	45.83	1,025.00	1,000.00	25.00	70.83
16.00	20.00	1	8	200.00	11.00	3	33.00	2.00	2.92	504.00	1.54	7.78	40.61	1,025.00	1,000.00	25.00	65.61
17.00	18.00	3	3	200.00	11.00	2	22.00	1.50	3.04	330.00	2.15	7.10	56.50	1,025.00	1,000.00	25.00	81.50
18.00	19.00	6	9	200.00	11.00	3	33.00	2.00	2.92	512.00	1.54	7.90	49.40	1,025.00	1,000.00	25.00	74.40
19.00	20.00	5	14	200.00	11.00	4	44.00	2.00	3.89	330.00	2.63	8.67	41.50	1,025.00	1,000.00	25.00	66.50
20.00	26.00	9	77	200.00	11.00	7	77.00	4.00	1.90	280.00	0.33	0.93	32.83	1,025.00	1,000.00	25.00	57.83
21.00	22.00	3	3	200.00	11.00	2	22.00	1.50	3.04	313.00	2.15	6.73	44.66	1,025.00	1,000.00	25.00	69.66
22.00	26.00	2	5	200.00	11.00	3	33.00	2.00	2.92	390.00	1.54	6.02	37.92	1,025.00	1,000.00	25.00	62.92
23.00	24.00	3	3	200.00	11.00	2	22.00	1.50	3.04	234.00	2.15	5.03	50.91	1,025.00	1,000.00	25.00	75.91
24.00	25.00	6	9	200.00	11.00	3	33.00	2.00	2.92	565.00	1.54	8.72	45.88	1,025.00	1,000.00	25.00	70.88
25.00	26.00	2	11	200.00	11.00	4	44.00	2.00	3.89	200.00	2.63	5.26	37.16	1,025.00	1,000.00	25.00	62.16
26.00	42.00	3	96	200.00	11.00	8	88.00	4.00	2.17	217.00	0.42	0.92	31.90	1,025.00	1,000.00	25.00	56.90
27.00	29.00	3	3	200.00	11.00	2	22.00	1.50	3.04	340.00	2.15	7.32	48.54	1,025.00	1,000.00	25.00	73.54
28.00	29.00	2	2	200.00	11.00	2	22.00	1.50	3.04	234.00	2.15	5.03	46.26	1,025.00	1,000.00	25.00	71.26
29.00	32.00	3	8	200.00	11.00	3	33.00	2.00	2.92	217.00	1.54	3.35	41.22	1,025.00	1,000.00	25.00	66.22
30.00	31.00	3	3	200.00	11.00	2	22.00	1.50	3.04	373.00	2.15	8.03	52.74	1,025.00	1,000.00	25.00	77.74
31.00	32.00	1	4	200.00	11.00	3	33.00	2.00	2.92	443.00	1.54	6.84	44.71	1,025.00	1,000.00	25.00	69.71
32.00	39.00	2	14	200.00	11.00	4	44.00	2.00	3.89	156.00	2.63	4.10	37.88	1,025.00	1,000.00	25.00	62.88
33.00	35.00	3	3	200.00	11.00	2	22.00	1.50	3.04	521.00	2.15	11.21	80.41	1,025.00	1,000.00	25.00	105.41
34.00	35.00	2	2	200.00	11.00	2	22.00	1.50	3.04	217.00	2.15	4.67	73.87	1,025.00	1,000.00	25.00	98.87
35.00	38.00	6	11	200.00	11.00	4	44.00	2.00	3.89	625.00	2.63	16.43	69.20	1,025.00	1,000.00	25.00	94.20
36.00	37.00	3	3	200.00	11.00	2	22.00	1.50	3.04	113.00	2.15	2.43	58.41	1,025.00	1,000.00	25.00	83.41

Zone Number	Pumps to Zone	Number of Cores in Zone	Accum Cores in Zone	Gal/Day per Core	Max Flow per Core	Max Sim Ops	Max Flow (GPM)	Pipe Size (Inches)	Max Velocity (FPS)	Length of Main this Zone	Friction Loss Factor (ft/100ft)	Friction Loss this Zone	Accumulated Friction Loss (Feet)	Max Main Elevation	Minimum Pump Elevation	Static Head (Feet)	Total Dynamic Head (ft)
is spreadsheet was calculated using pipe diameters for: SDR21 PVC																	
37.00	38.00	5	8	200.00	11.00	3	33.00	2.00	2.92	208.00	1.54	3.21	55.98	1,025.00	1,000.00	25.00	80.98
38.00	39.00	4	23	200.00	11.00	5	55.00	2.00	4.86	478.00	3.97	19.00	52.77	1,025.00	1,000.00	25.00	77.77
39.00	42.00	3	40	200.00	11.00	6	66.00	3.00	2.69	330.00	0.85	2.79	33.77	1,025.00	1,000.00	25.00	58.77
40.00	41.00	3	3	200.00	11.00	2	22.00	1.50	3.04	347.00	2.15	7.47	48.37	1,025.00	1,000.00	25.00	73.37
41.00	42.00	4	7	200.00	11.00	3	33.00	2.00	2.92	643.00	1.54	9.92	40.91	1,025.00	1,000.00	25.00	65.91
42.00	44.00	10	153	200.00	11.00	10	110.00	4.00	2.71	947.00	0.64	6.06	30.98	1,025.00	1,000.00	25.00	55.98
43.00	44.00	3	3	200.00	11.00	2	22.00	1.50	3.04	313.00	2.15	6.73	31.66	1,025.00	1,000.00	25.00	56.66
44.00	44.00	1	157	200.00	11.00	10	110.00	4.00	2.71	3,894.00	0.64	24.92	24.92	1,025.00	1,000.00	25.00	49.92

Zone Number	Pumps to Zone	Accumulated Total of Cores this Zone	Existing Pipe Size	Gallons per 100 Lineal Feet	Length of Zone	Capacity of Zone	Average Daily Flow	Average Fluid Changes per Day	Average Retention Time (Hr)	Accumulated Retention Time (Hr)
this spreadsheet was calculated using pipe diameters for: SDR21 PVC										
1.00	6.00	3	3.00	40.90	550.00	224.93	600	2.67	9.00	13.34
2.00	6.00	3	1.50	12.07	382.00	46.11	600	13.01	1.84	6.19
3.00	4.00	3	1.50	12.07	365.00	44.06	600	13.62	1.76	8.05
4.00	5.00	9	2.00	18.84	573.00	107.97	1,800	16.67	1.44	6.29
5.00	6.00	12	2.00	18.84	265.00	49.93	2,400	48.07	0.50	4.85
6.00	12.00	19	3.00	40.90	340.00	139.05	3,800	27.33	0.88	4.35
7.00	8.00	3	1.50	12.07	200.00	24.14	600	24.85	0.97	6.51
8.00	12.00	7	2.00	18.84	643.00	121.16	1,400	11.56	2.08	5.55
9.00	10.00	3	1.50	12.07	286.00	34.52	600	17.38	1.38	6.93
10.00	11.00	9	2.00	18.84	521.00	98.17	1,800	18.34	1.31	5.55
11.00	12.00	15	2.00	18.84	512.00	96.47	3,000	31.10	0.77	4.24
12.00	20.00	46	4.00	67.65	269.00	181.98	9,200	50.55	0.47	3.47
13.00	14.00	3	1.50	12.07	208.00	25.11	600	23.90	1.00	5.97
14.00	16.00	5	2.00	18.84	121.00	22.80	1,000	43.86	0.55	4.97
15.00	16.00	2	1.50	12.07	243.00	29.33	400	13.64	1.76	6.18
16.00	20.00	8	2.00	18.84	504.00	94.96	1,600	16.85	1.42	4.42
17.00	18.00	3	1.50	12.07	330.00	39.83	600	15.06	1.59	6.41
18.00	19.00	9	2.00	18.84	512.00	96.47	1,800	18.66	1.29	4.81
19.00	20.00	14	2.00	18.84	330.00	62.18	2,800	45.03	0.53	3.53
20.00	26.00	77	4.00	67.65	280.00	189.42	15,400	81.30	0.30	2.99
21.00	22.00	3	1.50	12.07	313.00	37.78	600	15.88	1.51	5.97
22.00	26.00	5	2.00	18.84	390.00	73.48	1,000	13.61	1.76	4.46
23.00	24.00	3	1.50	12.07	234.00	28.24	600	21.24	1.13	5.66
24.00	25.00	9	2.00	18.84	565.00	106.46	1,800	16.91	1.42	4.53
25.00	26.00	11	2.00	18.84	200.00	37.68	2,200	58.38	0.41	3.11
26.00	42.00	96	4.00	67.65	217.00	146.80	19,200	130.79	0.18	2.70
27.00	29.00	3	1.50	12.07	340.00	41.04	600	14.62	1.64	5.43
28.00	29.00	2	1.50	12.07	234.00	28.24	400	14.16	1.69	5.48
29.00	32.00	8	2.00	18.84	217.00	40.89	1,600	39.13	0.61	3.79
30.00	31.00	3	1.50	12.07	373.00	45.02	600	13.33	1.80	7.48
31.00	32.00	4	2.00	18.84	443.00	83.47	800	9.58	2.50	5.68
32.00	39.00	14	2.00	18.84	156.00	29.39	2,800	95.26	0.25	3.17
33.00	35.00	3	1.50	12.07	521.00	62.89	600	9.54	2.52	7.19
34.00	35.00	2	1.50	12.07	217.00	26.19	400	15.27	1.57	6.25
35.00	38.00	11	2.00	18.84	625.00	117.76	2,200	18.68	1.28	4.68
36.00	37.00	3	1.50	12.07	113.00	13.64	600	43.99	0.55	4.52
37.00	38.00	8	2.00	18.84	208.00	39.19	1,600	40.82	0.59	3.98
38.00	39.00	23	2.00	18.84	478.00	90.07	4,600	51.07	0.47	3.39
39.00	42.00	40	3.00	40.90	330.00	134.96	8,000	59.28	0.40	2.92

APPENDIX 4

COLLECTION SYSTEM OPINION OF PROBABLE COSTS

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM W/ LIBERTY HILL LIFT STATION

Item	Description	Unit	Quantity	Unit Price	Amount
Gravity Collection System					
1	Mobilization @ 5%	LS	1	41600	\$41,600
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	4582	25	\$114,550
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	4415	27	\$119,205
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	4052	30	\$121,560
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	1619	37	\$59,903
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	540	45	\$24,300
7	Manholes	EA	53	3000	\$159,000
8	6-inch SDR 35 Service	EA	162	1000	\$162,000
9	Decommission Septic Tank	Ea	162	200	\$32,400
10	Erosion Sedimentation Controls	LS	1	39000	\$39,000
11	Trench Protection	LF	15208	2	\$30,416
12	Traffic Control	LS	1	15000	\$15,000

Construction Total Gravity Collection System **\$918,934**

LIFT STATION AND FORCE MAIN

1	Wet Well Excavation	LS	1	2000	\$2,500
2	Wet Well	Ea	1.00	10000	\$10,000
3	Duplex Lift Station 200 gpm @ 102 ft TDH	LS	1	50000	\$50,000
4	Electrical and Controls	LS	1	25000	\$25,000
5	12" Bore and Encasement	LF	250	250	\$62,500
6	Force Main - 6" PVC	LF	12000	12	\$144,000

Construction Total Wastewater Lift Station and Force Main **\$294,000**

Subtotal **\$1,212,900**
Contingencies @ 20 % **\$242,600**
Construction Total **\$1,455,500**

Engineering & Surveying @ 15 % **\$218,325**

TOTAL **\$1,673,825**

HIGH SCHOOL LIFT STATION AND FORCE MAIN

1	Wet Well Excavation	LS	1	2000	\$2,000
2	Wet Well	Ea	1.00	7500	\$7,500
3	Duplex Lift Station 60 gpm @ 74 ft TDH	LS	1	25000	\$25,000
4	Electrical and Controls	LS	1	17000	\$17,000
5	Force Main - 3" PVC	LF	1600	8	\$12,800

Construction Total Wastewater Lift Station and Force Main **\$64,300**

Subtotal **\$64,300**
Contingencies @ 20 % **\$12,900**
Construction Total **\$77,200**

Engineering & Surveying @ 20 % **\$15,440**

TOTAL **\$92,640**

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM W/ LIBERTY HILL LIFT STATION
Yearly Operation and Maintenance Costs

	Description	Unit	Quantity	Unit Price	Cost
1	Gravity Collection System	mile	2.88	2000	\$5,761
2	Lift Station and Force Main				
	Electrical	KW/hr	9812	0.08	\$785
	Labor (assumed to be 15 % electrical costs)				\$118
Total Annual Cost					\$6,663

ALTERNATIVE II - GRAVITY SEWER W/ LHHS LIFT STATION
LINE COST VERSUS SERVICES

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM W/ LIBERTY HILL LIFT STATION

Description	West of CR 279		East of CR 279		Total	
	Cost*	Services Cost/Service**	Cost*	Services Cost/Service**	Cost*	Services Cost/Service**
Line A	\$151,496	18 \$8,400	\$251,551	43 \$5,900	\$403,048	61 \$6,607
Line B	\$72,234	13 \$5,600	\$101,770	19 \$5,400	\$174,004	32 \$5,438
Line C	\$66,934	10 \$6,700			\$66,934	10 \$6,693
Line D	\$102,293	10 \$10,200	\$56,238	10 \$5,600	\$158,531	20 \$7,927
Line E	\$99,932	9 \$11,100	\$90,071	15 \$6,000	\$190,003	24 \$7,917
Line G	\$79,746	9 \$8,900	\$25,594	6 \$4,300	\$105,340	15 \$7,023
Subtotal	\$572,635	69 \$8,483	\$525,223	93 \$5,440	\$1,097,858	162 \$6,777
LIFT STATION & FORCE MAIN					\$352,800	162 \$2,178
TOTAL					\$1,450,658	\$8,955

* - Costs Include 20 % Contingency, Costs do not Include Engineering

** - Gravity Line Only

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE A

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	5600	\$5,600
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	280	25	\$7,000
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	240	27	\$6,480
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	1104	29	\$32,016
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	337	37	\$12,469
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	280	45	\$12,600
7	Manholes	EA	7	3000	\$21,000
8	6-inch SDR 35 Service	EA	18	1000	\$18,000
9	Decommission Septic Tank	Ea	18	200	\$3,600
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	2241	2	\$4,482
Subtotal Line A West of 279					\$126,247
Contingencies @ 20 Percent					\$25,249
Subtotal Line A West of 279					\$151,496
East of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	5100	\$5,100
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	0	25	\$0
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	349	27	\$9,423
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	605	29	\$17,545
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	374	37	\$13,838
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	5	3000	\$15,000
8	6-inch SDR 35 Service	EA	16	1000	\$16,000
9	Decommission Septic Tank	Ea	16	200	\$3,200
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1328	2	\$2,656
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line A East of 279					\$88,262
Contingencies @ 20 Percent					\$17,652
Subtotal Line A East of 279					\$105,914
East of CR279 Lines A-1 thru A-5					
1	Insurance, Bonds, Move In @ 5 %	LS	1	5400	\$5,400
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	545	25	\$13,625
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	709	27	\$19,143
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	576	29	\$16,704
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	88	37	\$3,256
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	8	3000	\$24,000
8	6-inch SDR 35 Service	EA	27	1000	\$27,000
9	Decommission Septic Tank	Ea	27	200	\$5,400
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1918	2	\$3,836
Subtotal Line A Sublines East of 279					\$121,364
Contingencies @ 20 Percent					\$24,273
Total Branch Lines A					\$145,637
Total Line A					\$403,048

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE B

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	2600	\$2,600
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	0	25	\$0
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	435	27	\$11,745
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	480	29	\$13,920
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	0	37	\$0
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	2	3000	\$6,000
8	6-inch SDR 35 Service	EA	13	1000	\$13,000
9	Decommission Septic Tank	Ea	13	200	\$2,600
10	Erosion Sedimentation Controls	LS	2	3000	\$6,000
11	Trench Protection	LF	915	2	\$1,830
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line B West of 279					\$60,195
Contingencies @ 20 Percent					\$12,039
Subtotal Line B West of 279					\$72,234
East of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	3900	\$3,900
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	789	25	\$19,725
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	545	27	\$14,715
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	0	29	\$0
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	0	37	\$0
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	6	3000	\$18,000
8	6-inch SDR 35 Service	EA	19	1000	\$19,000
9	Decommission Septic Tank	Ea	19	200	\$3,800
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1334	2	\$2,668
Subtotal Line B East of 279					\$84,808
Contingencies @ 20 Percent					\$16,962
Subtotal Line B East of 279					\$101,770
Total Line B					\$174,004

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE C

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	2300	\$2,300
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	114	25	\$2,850
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	200	27	\$5,400
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	580	29	\$16,820
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	80	37	\$2,960
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	2	3000	\$6,000
8	6-inch SDR 35 Service	EA	10	1000	\$10,000
9	Decommission Septic Tank	Ea	10	200	\$2,000
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	974	2	\$1,948
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line C West of 279					\$55,778
Contingencies @ 20 Percent					\$11,156
Total Line C West of 279					\$66,934

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE D

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	3700	\$3,700
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	380	25	\$9,500
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	356	27	\$9,612
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	440	29	\$12,760
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	380	37	\$14,060
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	5	3000	\$15,000
8	6-inch SDR 35 Service	EA	10	1000	\$10,000
9	Decommission Septic Tank	Ea	10	200	\$2,000
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1556	2	\$3,112
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line D West of 279					\$85,244
Contingencies @ 20 Percent					\$17,049
Subtotal Line D West of 279					\$102,293
East of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	2100	\$2,100
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	159	25	\$3,975
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	568	27	\$15,336
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	0	29	\$0
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	0	37	\$0
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	3	3000	\$9,000
8	6-inch SDR 35 Service	EA	10	1000	\$10,000
9	Decommission Septic Tank	Ea	10	200	\$2,000
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	727	2	\$1,454
Subtotal Line D East of 279					\$46,865
Contingencies @ 20 Percent					\$9,373
Total Line D East of 279					\$56,238
Total Line D					\$158,531

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE E

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	3800	3800
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	800	25	\$20,000
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	813	27	\$21,951
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	0	29	\$0
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	0	37	\$0
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	6	3000	\$18,000
8	6-inch SDR 35 Service	EA	9	1000	\$9,000
9	Decommission Septic Tank	Ea	9	200	\$1,800
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1613	2	\$3,226
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line E West of 279					83277
Contingencies @ 20 Percent					\$16,655
Subtotal Line E West of 279					99932.4
East of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	3200	\$3,200
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	466	25	\$11,650
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	60	27	\$1,620
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	167	29	\$4,843
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	260	37	\$9,620
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	260	45	\$11,700
7	Manholes	EA	3	3000	\$9,000
8	6-inch SDR 35 Service	EA	15	1000	\$15,000
9	Decommission Septic Tank	Ea	15	200	\$3,000
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1213	2	\$2,426
Subtotal Line E East of 279					75059
Contingencies @ 20 Percent					\$15,012
Total Line E East of 279					\$90,071
Total Line E					\$190,003

ALTERNATIVE 1
GRAVITY COLLECTION SYSTEM LINE G

Item	Description	Unit	Quantity	Unit Price	Amount
West of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	2900	\$2,900
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	785	25	\$19,625
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	140	27	\$3,780
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	100	29	\$2,900
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	100	37	\$3,700
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	5	3000	\$15,000
8	6-inch SDR 35 Service	EA	9	1000	\$9,000
9	Decommission Septic Tank	Ea	9	200	\$1,800
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	1125	2	\$2,250
12	Traffic Control	LS	1	1	\$2,500
Subtotal Line G West of 279					\$66,455
Contingencies @ 20 Percent					\$13,291
Subtotal Line E W of 279					\$79,746
East of CR 279					
1	Insurance, Bonds, Move In @ 5 %	LS	1	1000	\$1,000
2	8-inch SDR 35 Sewer Line 0-8 ft	LF	264	25	\$6,600
3	8-inch SDR 35 Sewer Line 8-10 ft	LF	0	27	\$0
4	8-inch SDR 35 Sewer Line 10-12 ft	LF	0	29	\$0
5	8-inch SDR 35 Sewer Line 12-14 ft	LF	0	37	\$0
6	8-inch SDR 35 Sewer Line 14-16 ft	LF	0	45	\$0
7	Manholes	EA	1	3000	\$3,000
8	6-inch SDR 35 Service	EA	6	1000	\$6,000
9	Decommission Septic Tank	Ea	6	200	\$1,200
10	Erosion Sedimentation Controls	LS	1	3000	\$3,000
11	Trench Protection	LF	264	2	\$528
Subtotal Line G East of 279					\$21,328
Contingencies @ 20 Percent					\$4,266
Total Line G East of 279					\$25,594
Total Line G					\$105,340

ALTERNATIVE 1 **HIGH SCHOOL LIFT STATION PRELIMINARY DESIGN**

1 Wet Well Minimum Working Volume

$$\text{Volume} = Q \cdot T / 4$$

Where: Q= Pump Flow = 40 gpm
T=Minimum Cycle Time = 10 min

Working Volume = 100 gallons

2 Working Level

Assume 8 ft diameter wet well

Working Level= 0.3 ft

3 Depth

Assume 12 ft depth

4 Static Head

Floor Elevation 983 ft msl
Elevation @ SH 29 WWTP 1025 ft msl

Static Head = 42 ft

24
43
Excavation = 35

Concrete
Walls = 10.28
Foundation = 5.70
Total 16.00

5 Friction Head = $H_f = .2083 \cdot (100/C)^{1.85} \cdot Q^{1.85} / D_i^{4.86}$

C= 120
Q= 60 gpm
D_i= 3 in

H_f= 1.39 ft/100 ft
Velocity 2.72 fps

Force Main Length= 1600 ft

H_f= 22 ft

6 Minor Losses

Allow 7 ft minor losses

7 Total Head = 71 ft TDH

8 Required Power = $Q \cdot TDH \cdot \text{GAMMA} / 550 / E =$
3 hp Drawn
2.0 KW

ALTERNATIVE 2**LOW PRESSURE SEWER SYSTEM AND FORCE MAIN FROM HIGH SCHOOL**

Item	Description	Unit	Quantity	Unit Price	Amount
Low Pressure Sewer System					
1	2.0-inch SDR 21 Pressure Pipe	LF	5019	6	\$30,114
2	3.0-inch SDR 21 Pressure Pipe	LF	7906	8	\$63,248
3	4.0-inch SDR 21 Pressure Pipe	LF	1220	10	\$12,200
4	6.0-inch SDR 21 Pressure Pipe	LF	5607	12	\$67,284
5	Gator Grinder Pump	Ea	161	1900	\$305,900
6	45 GPM Elementary/Middle School	Ea	1	32500	\$32,500
7	1-1/2" Pipe lateral Services	LF	7850	3	\$23,550
8	Lateral Shut Off Valves and Appurtenances	Ea	163	200	\$32,600
9	Flush Valves and Appurtenances	LF	19752	2.5	\$49,380
10	Septic Tank Decommissioning	Ea	161	200	\$32,200
11	Erosion Sedimentation Controls	LS	1	20000	\$20,000
12	Trench Protection	LF	0		\$0
13	Traffic Control	LS	1	10000	\$10,000

Construction Total Low Pressure Sewer System**\$678,976****LIFT STATION AND FORCE MAIN**

1	Wet Well Excavation	LS	1	2500	\$2,500
2	Wet Well	Ea	1.00	10000	\$10,000
3	Duplex Lift Station 200 gpm @ 62 ft TDH	LS	1	50000	\$50,000
4	Electrical and Controls	LS	1	25000	\$25,000
5	12" Bore and Encasement	LF	250	250	\$62,500
6	Force Main - 6" PVC	LF	7040	12	\$84,480

Construction Total Wastewater Lift Station and Force Main**\$234,480****Subtotal****\$913,500****Contingencies @ 20 %****\$182,700****Construction Total****\$1,096,200****Engineering & Surveying @ 15 %****\$164,430****TOTAL****\$1,260,630**

ALTERNATIVE 2

LOW PRESSURE SEWER SYSTEM AND FORCE MAIN FROM HIGH SCHOOL LIFT STATION DESIGN

1 Wet Well Minimum Working Volume

$$\text{Volume} = Q \cdot T / 4$$

Where: Q= Pump Flow = 200 gpm
T=Minimum Cycle Time = 10 min

Working Volume = 500 gallons

24.1
42.8

2 Working Level

Assume 6 ft diameter wet well

Excavation = 19

Working Level= 2.4 ft

3 Depth

Assume 10 ft depth

Concrete

4 Static Elevation

Floor Elevation 995 ft msl

Walls = 6.63

Foundation = 4.19

Elevation @ SH 29 WWTP 1025 ft msl

Total 11.00

Static Head = 30 ft

5 Friction Head = $H_f = .2083 \cdot (100/C)^{1.85} \cdot Q^{1.85} / D_i^{4.86}$

C= 120

Q= 200 gpm

Di= 6 in

Hf= 0.44 ft/100 ft

Velocity 2.27 fps

Force Main Length= 7040 ft

Hf= 31 ft

Allow 7 ft minor losses

Total Head = 68 ft TDH

6 Required Power = $Q \cdot TDH \cdot \text{GAMMA} / 550 / E =$ 6 hp Drawn
4.7 KW

7 Total Operating Hours @ ADF = 32 gpm 6551 KW/hr

ALTERNATIVE 2**LOW PRESSURE SEWER SYSTEM AND FORCE MAIN FROM HIGH SCHOOL****Yearly Operation and Maintenance Costs**

	Description	Unit	Quantity	Unit Price	Cost
1	Grinder Pumps	Ea	162.00	52	\$8,424
2	Lift Station and Force Main				
	Electrical	KW/hr	6651	0.08	\$532
	Labor (assumed to be 15 % electrical costs)				\$80
Total Annual Cost					\$9,036

APPENDIX 5

PRELIMINARY DESIGN SUMMARIES CONCEPTUAL LEVEL SITE PLANS

LIBERTY HILL REGIONAL WASTEWATER STUDY
 300,000 GPD Oxidation Ditch
 Opinion of Probable Costs

Item	Description	No. Units	Units	Unit Cost	Total Cost
WW-1	Bonds and Insurance	1	LS	\$52,000	\$52,000
WW-2	Mobilization	1	LS	\$50,000	\$50,000
WW-3	Site Work and Excavation	1	LS	\$120,000	\$120,000
WW-4	Lift Station	1	LS	\$115,000	\$115,000
WW-5	Oxidation Ditch	1	LS	\$210,000	\$210,000
WW-6	Clarifier	1	LS	\$260,000	\$260,000
WW-7	Brush or Disk Aerators	1	LS	\$44,000	\$44,000
WW-8	Return Sludge Pumps	1	LS	\$90,000	\$90,000
WW-9	Filter Equipment	1	LS	\$120,000	\$120,000
WW-10	Ultraviolet Disinfection	1	LS	\$42,000	\$42,000
WW-11	Sludge Holding Tank	1	LS	\$35,000	\$35,000
WW-12	Yard Piping	1	LS	\$80,000	\$80,000
WW-13	Electrical	1	LS	\$175,000	\$175,000
WW-14	Phos. Removal Pumps, Pipe, & Storage	1	LS	\$25,000	\$25,000
WW-15	Storage Building	1	LS	\$10,000	\$10,000
WW-16	Chain Link Fence	1	LS	\$18,000	\$18,000
WW-17	Start up	1	LS	\$6,000	\$6,000
	Subtotal				\$1,452,000
	Contingencies @ 20 %				\$290,400
	Total Construction Cost				\$1,742,400
	Engineering & Surveying @ 15 %				\$261,360
	Total Cost				\$2,003,760

5/22/90

6/22/90

LIBERTY HILL REGIONAL WASTEWATER STUDY
300,000 GPD Extended Aeration Treatment Plant Construction Costs
Opinion of Probable Costs

Item	Description	No. Units	Units	Unit Cost	Total Cost
WW-1	Bonds and Insurance	1	LS	\$52,000	\$52,000
WW-2	Mobilization	1	LS	\$50,000	\$50,000
WW-3	Site Work and Excavation	1	LS	\$63,000	\$63,000
WW-4	Lift Station (Concrete)	1	LS	\$60,000	\$60,000
WW-5	WWTP Foundation (Concrete)	1	LS	\$125,000	\$125,000
WW-6	Filter (Concrete)	1	LS	\$21,000	\$21,000
WW-7	Blower Building (Concrete)	1	LS	\$15,000	\$15,000
WW-8	WWTP	1	LS	\$425,000	\$425,000
WW-9	Clarifier Equipment	1	LS	\$45,000	\$45,000
WW-10	Filter Equipment	1	LS	\$120,000	\$120,000
WW-11	Blower Equipment	1	LS	\$75,000	\$75,000
WW-12	Lift Station Equipment	1	LS	\$69,000	\$69,000
WW-13	Ultraviolet Disinfection	1	LS	\$42,000	\$42,000
WW-14	Yard Piping	1	LS	\$80,000	\$80,000
WW-15	Electrical	1	LS	\$175,000	\$175,000
WW-16	Phos. Removal Pumps, Pipe, & Storage	1	LS	\$25,000	\$25,000
WW-17	Storage Building	1	LS	\$10,000	\$10,000
WW-18	Chain Link Fence	1	LS	\$10,000	\$10,000
WW-19	Start up	1	LS	\$6,000	\$6,000
Subtotal					\$1,468,000
Contingencies @ 20 %					\$293,600
Total Construction Cost					\$1,761,600
Engineering & Surveying @ 15 %					\$264,240
Total Cost					\$2,025,840

** - Costs were extrapolated from a similar facility constructed in 1995 and adjusted to today's dollars with the ENR Construction Cost Index

LIBERTY HILL REGIONAL WASTEWATER STUDY

Phase 1 Design Calculations

Average Dry Flow	250,000			
Wet Weather Maximum 30 Day (gpd)	300,000			
Peaking Factor	1.99	Peak Factor = $[(18+(0.0206 \cdot F)^{.5})/(4+(0.0206 \cdot F)^{.5})]$		
Peak Flow (gpd)	1,248,260	Includes 750 gpd/acre I&I		
Overall Peak Factor	4.2			

Influent BOD5				
Average Day	200	mg/l	417	lb/day
Maximum Month	250	mg/l	521	lb/day
Influent TSS				
Average Day	200	mg/l	417	lb/day
Maximum Month	250	mg/l	521	lb/day
Influent Ammonia				
Average Day	15	mg/l		
Maximum Month	20	mg/l		
Influent Phosphorus				
Average Day	7	mg/l	15	lb/day
Maximum Month	10	mg/l	21	lb/day

Design Criteria - Extended Aeration/Oxidation Ditch

Aeration Basin Organic Load	15	lb BOD5/Day/1000 Cuft
Aeration System Design		
Extended Aeration	2850	SCF/lb BOD 5
Oxidation Ditch	2.2	lb O2/lb BOD5
Clarification		
Max. Surface Loading @ Peak Flow	1000	gpd/ft^2
Min. Detention Time @ Peak Flow	1.8	hrs
Max. Surface Loading @ Design Flow	500	gpd/ft^2
Min. Detention Time @ Design Flow	3.6	hrs
Filtration		
@ Design Flow	4	gpm/ft @ Design Flow
@ Peak Flow	8	gpm/ft @ Peak Flow (one unit out of service)
Chlorine Contact Basin	20	min HRT @ Peak Flow

Design

Sizing Calculations

Aeration Basin

Basin Volume Extended Air	27800	cubic feet	207944	gallons
Oxidation Ditch	27852	cubic feet	208333	gallons
Aeration				
Extended Aeration	1032	scfm	1153	lb O2/day
Oxidation Ditch	1147	lb O2/day		

LIBERTY HILL REGIONAL WASTEWATER STUDY

Phase 1 Design Calculations

Clarification

Required Surface Area @ Peak Flow	1248	ft ²
Required Surface Area @ Avg. Flow	600	ft ²
Required Volume @ Peak Flow	93620	gal
Required Volume @ Avg. Flow	37500	gal
Required SWD @ Peak Flow	10	ft
Required SWD @ Avg. Flow	8	ft

Filtration

Reqd. Area @ Design Flow	52	ft ²
Reqd. Area @ Peak Flow	108	ft ²
Provide 4 Filters @	26	ft ² Ea

Chlorine Contact Tank

Required Volume =	17337	gal
Required Dosage @ 10 mg/L	25	lb/day
Dosage Rate @ 1.00%	300	gal/day
Provide 15 days storage	4500	gallons Use 5000 gallons

Ferric Chloride Feed

Dosage =	1.8	lb Fe per lb P
FeSO ₄ Required @ 0.5 #/gal FeCl ₃	26	lb/day
Provide 30 days storage	53	gpd
	1576	gallons Use 1600 gallons

Dimensioning Calculations

Aeration Basin Extended Air Concentric Tanks

Volume =	27800	cu ft
Use 10 SWD depth		
Surface Area =	2780	ft ²
Required Total Surface Area =	4717	ft ² (AB + Sludge Holding Tank+Clarifier)
Goal Seek Incremental Diameter = 28.7	4717	ft
Overall Diameter =	69	ft

Aeration Basin Oxidation Ditch

Volume =	27852	cu ft
Use 6 SWD ft		
Assume Side Slope = 1		
Assume Bottom Width = 10 ft		
Assume End Radius = 20 ft		
Goal Seek Tot. Length 317 ft	27852	cu ft
Overall St Channel	159	ft Note: Two channels provided.
End To End Length	231	ft

LIBERTY HILL REGIONAL WASTEWATER STUDY

Phase 1 Design Calculations

Clarifier

Required Area =	1248	ft ²			
Diameter =	40	ft	Use	40	ft
Area =	1257	ft ²			

Filtration

Required Area =	108	ft ²			
Provide 4 filters	36	ft ² ea			
Dimensions =	6.0	x	6.0	ft	

Chlorine Contact Chamber

Required Volume =	17337	gallons			
Surface Area @ 6 ft SWD	386	ft ²			
Overall L:W 3					
Length =	11.3	ft			
Width =	3.8	ft	Use	11.0	x 4.0 Channel
Overall Width =	8.8	ft			

Sludge Holding Tank

Provide 10 days holding					
Sludge Production =	0.8	lb/lb BODr			
	297	lb Solids/day			
Clarifier Underflow 0.70%	5089	gal/day			
Tank Volume =	50893	gal/day			
SWD = 10 ft					
Required Surface Area =	680	ft ²			
Oxidation Ditch Need External Tank					
Diameter =	29	ft			

APPENDIX 6

PRELIMINARY PLAN & PROFILE DRAWINGS / OPINION OF PROBABLE COSTS EFFLUENT LINE

LIBERTY HILL REGIONAL WASTEWATER STUDY
GRAVITY EFFLUENT LINE

Item	Description	Unit	Quantity	Unit Price	Amount
1	Insurance, Bonds, Move In @ 5 %	LS	1	24000	\$24,000
2	18-inch F 679, T-1 Wall Sewer Line 0-8 ft	LF	4325	40	\$173,000
3	18-inch F 679, T-1 Wall Sewer Line 8-10 ft	LF	1460	43	\$62,780
4	18-inch F 679, T-1 Wall Sewer Line 10-12 ft	LF	1040	46	\$47,840
5	18-inch F 679, T-1 Wall Sewer Line 12-14 ft	LF	760	50	\$38,000
6	18-inch F 679, T-1 Wall Sewer Line 14-16 ft	LF	200	54	\$10,800
7	18-inch F 679, T-1 Wall Sewer Line 16-18 ft	LF	240	60	\$14,400
8	28-inch Bore and Encasement	LF	120	350	\$42,000
9	Manholes	EA	21	3000	\$63,000
10	Outfall Structure South Fork San Gabriel	EA	1	12000	\$12,000
11	Erosion Sedimentation Controls	LS	1	10000	\$10,000
12	Trench Protection	LF	8025	2	\$16,050

Subtotal \$513,870
Contingencies @ 20 Percent \$102,774
Construction Total \$616,644

Engineering and Surveying @ 15 % \$92,497

TOTAL \$709,141

PRESSURE EFFLUENT LINE

Item	Description	Unit	Quantity	Unit Price	Amount
1	Insurance, Bonds, Move In @ 5 %	LS	1	20000	\$20,000
2	16-inch Class 100	LF	8025	35	\$280,875
3	28-inch Bore and Encasement	LF	120	350	\$42,000
4	Appurtenances	LS	1	8500	\$8,500
5	Outfall Structure South Fork San Gabriel	Ea	1	12000	\$12,000
6	Erosion Sedimentation Controls	LS	1	8000	\$8,000
7	Trench Protection	LF	8025	2	\$16,050

Subtotal \$387,425
Contingencies @ 20 Percent \$77,485
Construction Total \$464,910

Engineering and Surveying @ 15 % \$69,737

TOTAL \$534,647