




Control Number: 44809



Item Number: 131

Addendum StartPage: 0

SOAH DOCKET NO. 473-16-1848.WS
DOCKET NO. 44809

RECEIVED

2016 MAY 18 PM 4:41
PUBLIC UTILITY COMMISSION
PUBLIC UTILITY COMMISSION
FILING CLERK

APPLICATION OF QUADVEST, L.P. FOR
RATE/TARIFF CHANGE

§
§
§
§
§
§
§

PUBLIC UTILITY COMMISSION

OF

TEXAS

**QUADVEST L.P.'S SUPPLEMENTAL RESPONSES TO OFFICE OF
PUBLIC UTILITY COUNSEL'S RFI 4-9**

To: Office of Public Utility Counsel by and through their attorneys of record, Tonya Baer, Christiaan Siano, Office of Public Utility Counsel, 1701 N. Congress Avenue, Suite 9-180, P.O. Box 12397, Austin, Texas 78711-2397.

COMES NOW, Quadvest, L.P. ("Quadvest"), by and through their attorney of record, file this supplemental response to Office of Public Utility Counsel's RFI 4-9. Quadvest stipulates pursuant to PUC Procedural Rule 22.144(c)(F) that the following responses to requests for information may be treated by all parties as if the answers were filed under oath.

Respectfully submitted,

COZEN O'CONNOR

By: Tammy Wavle Shea
Tammy Wavle Shea
State Bar No. 24008908
1221 McKinney, Suite 2900
Houston, Texas 77010
Phone: (713) 750-3148
Fax: (832) 214-3905
Email: tshea@cozen.com
by permission Debra Ellis

ATTORNEYS FOR QUADVEST, L.P.

CERTIFICATE OF SERVICE

I hereby certify that a true and correct copy of Quadvest L.P.'s Responses to OPUC's Third RFIs was served on all parties of record in this proceeding on this the 18th day of May, 2016, by facsimile, electronic mail, U.S. first-class mail, postage prepaid, or by hand delivery.

Tammy Travle Shea
Tammy Wavle-Shea
by permission
Debra Ellis

OFFICE OF PUBLIC UTILITY COUNSEL

SOAH DOCKET NO. 473-16-1848.WS

Docket No. 44809

SUPPLEMENTAL RESPONSE TO REQUEST NUMBER: OPUC 4-9

COMPANY NAME: Quadvest, L.P.

DATE DUE: 04/04/16

EXTENSION DATE:

INFORMATION REQUESTED:

4-9 Please provide any analyses reviewed by Quadvest staff or prepared for Quadvest regarding the increased accuracy of AMR meters over non-AMRs?

REQUESTED BY: Office of Public Utility Counsel

RESPONSE: Upon a complete new AMR to use non-ARM conversion, a system could see improvements (water loss reductions) of between 3% and 7%.

SUPPORTING WITNESS:

Jeff Eastman

The foregoing response to the above information request is accurate and complete, and contains no material misrepresentations or omissions based upon present facts known to the undersigned. The undersigned agrees to immediately inform the Requestor if any matters are discovered which would materially affect the accuracy or completeness of the information provided in response to the above information request.

Signature of Company Representative

/s/ Jeff Eastman

Date Supplement Provided: 05/18/16