




Control Number: 45516



Item Number: 12

Addendum StartPage: 0

2015 FEB 12 PM 2:57

FILED IN THE PUBLIC UTILITY COMMISSION
FILE NO. 02015-00000000000000000000

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2015 Reporting Year

AEP Texas Central Company

Project 45516

12

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2015	1.40	0.07	0.04	0.09	0.15	0.18	0.14	0.13	0.10	0.14	0.16	0.09	0.11
Scheduled													
2015	0.08	0.01	0.00	0.00	0.01	0.01	0.01	0.00	0.01	0.01	0.01	0.01	0.01
Outside Causes													
2015	0.24	0.00	0.01	0.01	0.02	0.01	0.01	0.06	0.02	0.08	0.01	0.00	0.02
Major Events													
2015	0.30				0.11	0.11	0.01		0.06		0.01		

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced													
2015	162.98	9.04	4.25	8.49	21.70	27.38	15.45	14.40	11.59	14.34	16.37	9.25	10.72
Scheduled													
2015	6.83	0.44	0.37	0.53	0.32	0.70	0.46	0.52	1.02	0.48	0.85	0.50	0.63
Outside Causes													
2015	12.33	0.01	0.69	0.50	0.88	1.17	0.73	2.94	1.13	2.89	0.13	0.10	1.16
Major Events													
2015	78.77				26.45	27.91	5.06		17.14		2.22		

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or more Customers

Total Number of Feeders

763

Add or Delete Rows as Necessary

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
1	313	CARRIZO SPRINGS	94LA860	74	23 554
2	179	CONTINENTAL	94SB4880	68	9 000
3	127	MARKHAM	94CN6440	456	8 132
4	80	WEST OSO	94CS9085	841	7.554
5	4	LOS FRESNOS	94SB4315	1,008	6.768
6	74	MAVERICK	94LA9680	740	6.673
7	443	PRAIRIE PUMP	94CN1940	80	6 513
8	11	GANADO	94CN5795	473	6.442
9	42	CAUSEWAY	94SB4795	1,206	6.113
10	76	NIXON	94CN6630	643	6.086
11	28	BONNIEVIEW	94CS8020	529	5 692
12	609	BEEVILLE	94CN1760	1,819	5.673
13	460	EDROY	94CS6990	278	5.460
14	181	NORTH PADRE ISLAND	94CS720	1,174	5 422
15	411	CONTINENTAL	94SB3650	21	5.333
16	132	RAYMONDVILLE #2	94SB3250	41	5.244
17	166	DEL RIO CITY	94LA1930	1,050	5 234
18	101	LA PRYOR	94LA570	142	5 049
19	new	CHOKE CANYON	94CN5390	429	5 009
20	124	BLESSING	94CN8790	750	4.977
21	102	BIG WELLS	94LA2630	29	4 862
22	133	RAYMONDVILLE #2	94SB3170	715	4.849
23	143	GOVERNMENT WELLS	94LA7240	215	4 767
24	233	LULING - LCRA	94CN10	386	4 741
25	168	LULING - LCRA	94CN20	289	4.740
26	366	CABANISS	94CS75	2,186	4 618
27	353	GREGORY	94CS5900	118	4 593
28	67	SOUTH EAST EDINBURG	94SB5045	2,071	4.552
29	93	FOSTER FIELD	94CN2550	222	4.495
30	1	CHARLOTTE	94LA2780	52	4.423
31	39	MAYO	94CS625	208	4 380
32	10	MARKHAM	94CN5550	116	4 345
33	461	ARANSAS PASS	94CS660	771	4 252
34	528	RANDADO	94LA8360	164	4.250
35	204	NAVAL BASE	94CS8440	1,619	4.243
36	301	RIO RICO	94SB8290	389	4.154
37	346	CLARKWOOD	94CS5525	1,064	4.142
38	184	LAGUNA	94CS9590	2,221	4.071
39	391	PORTLAND	94CS9370	1,510	4.064
40	455	ARCADIA	94CS1460	2,164	3.983
41	147	SABINAL	94LA200	437	3.979
42	476	BRACKETTVILLE	94LA8460	1,160	3.951
43	213	GREGORY	94CS8560	256	3.879
44	158	JOURDANTON	94LA250	789	3 852
45	270	PEARSALL	94LA3675	1,403	3.846
46	466	RUNGE	94CN4465	650	3.832
47	325	BRUNI	94LA1120	289	3.827
48	29	O_CONNER	94CN390	208	3.726
49	284	HIGHWAY 9	94CS6730	533	3 722
50	72	PUEBLO	94LA95	2,310	3 684
51	100	BEEVILLE	94CN300	1,670	3.675
52	625	ZAPATA	94LA7330	1,350	3.653

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
53	310	HEARN ROAD	94CS8990	1,232	3.583
54	149	CATARINA	94LA2380	210	3.581
55	734	SOUTH MCALLEN	94SB5065	129	3.550
56	576	NORTH MCALLEN	94SB2750	3,367	3.523
57	512	SINTON	94CS360	310	3.510
58	85	RANGERVILLE	94SB4060	898	3.494
59	700	LAREDO HEIGHTS	94LA9400	1,438	3.486
60	64	BRUNI	94LA1100	621	3.478
61	294	BEEVILLE	94CN8510	842	3.476
62	163	PALACIOS	94CN8550	45	3.467
63	613	TAFT	94CS1180	1,037	3.414
64	219	TAFT	94CS1260	196	3.413
65	584	PORTLAND	94CS6505	1,688	3.382
66	354	BANQUETTE	94CS9000	439	3.355
67	290	EDNA	94CN5765	1,120	3.317
68	669	SINTON	94CS1750	502	3.317
69	261	MALONE	94CN7550	177	3.299
70	599	DEL RIO CITY	94LA9790	2,321	3.278
71	311	CRYSTAL CITY	94LA330	1,308	3.246
72	729	GOODWIN	94SB7380	2,200	3.246
73	402	RANGERVILLE	94SB3410	852	3.222
74	316	HIGHWAY 9	94CS6780	832	3.206
75	69	PREMONT	94LA2730	173	3.173
76	167	CONTINENTAL	94SB4080	65	3.138
77	502	MINES ROAD	94LA3680	1,026	3.134
78	670	THOMASTON	94CN9580	46	3.130
79	269	BAY CITY	94CN6670	1,835	3.123
80	654	LAREDO HEIGHTS	94LA6820	2,103	3.102
81	105	GILA	94CS350	152	3.092
82	296	NORTH ALAMO	94SB3610	1,815	3.060
83	352	BANQUETTE	94CS130	226	3.053
84	656	HARLINGEN S.S	94SB4230	1,334	3.013
85	121	WESMER	94SB6900	1,621	3.006
86	702	CAUSEWAY	94SB4775	1,058	2.998
87	338	PALMHURST	94SB1300	1,994	2.991
88	183	OLMITO	94SB715	565	2.984
89	614	DEL RIO CITY	94LA9850	1,003	2.970
90	523	COFFEE PORT	94SB1090	1,149	2.964
91	470	WOOLRIDGE	94CS1170	1,647	2.945
92	253	PETTUS	94CN8210	338	2.932
93	505	MORRIS STREET	94CS2515	1,087	2.925
94	449	DEL RIO CITY	94LA430	2,534	2.918
95	78	GILA	94CS345	58	2.914
96	704	SOUTHSIDE	94CS5335	1,214	2.890
97	262	UVALDE	94LA540	1,220	2.879
98	291	NORDHEIM	94CN3380	172	2.878
99	286	GREENLAKE	94CN2760	577	2.860
100	309	NIXON	94CN3300	580	2.859
101	431	GILA	94CS7840	758	2.854
102	698	KINGSVILLE	94CS1350	384	2.841
103	9	LA GRULLA	94SB5005	2,051	2.828
104	212	DARST	94CN790	245	2.824
105	130	FALFURRIAS	94LA1070	1,020	2.821
106	50	PORT ISABEL S.S.	94SB3820	215	2.819
107	148	ARANSAS PASS	94CS9130	386	2.795
108	129	SAN BENITO	94SB4135	1,261	2.780
109	596	LAREDO PLANT	94LA8505	778	2.765

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
110	99	RIO RICO	94SB8330	409	2.751
111	82	BROWNSVILLE	94SB4280	309	2.715
112	489	CRESTONIO	94LA260	1,768	2.709
113	144	NORTH MERCEDES	94SB3770	1,707	2.702
114	22	STAFFORD HILL	94CN1550	222	2.689
115	445	BIG WELLS	94LA1570	457	2.670
116	677	ASPHALT MINES	94LA500	42	2.667
117	499	FALFURRIAS	94LA2830	1,455	2.667
118	687	DEVINE	94LA7100	963	2.642
119	645	EAST HARRISON	94SB4360	1,745	2.633
120	285	SAN DIEGO	94LA2930	578	2.630
121	251	ALICE	94LA2540	992	2.601
122	16	ARMSTRONG	94CS6050	76	2.592
123	77	SUNCHASE	94SB1150	1,376	2.591
124	199	PREMONT	94LA6570	735	2.582
125	111	UVALDE	94LA6620	2,741	2.575
126	34	WOODSBORO	94CS8330	1,108	2.573
127	705	HEARN ROAD	94CS8980	1,229	2.571
128	224	THREE RIVERS	94CN2580	127	2.567
129	659	MOORE FIELD	94SB3960	1,970	2.557
130	265	CLARKWOOD	94CS7610	171	2.556
131	543	BERCLAIR	94CN990	210	2.548
132	21	GANADO	94CN5815	604	2.548
133	530	AIRLINE	94CS8260	1,518	2.533
134	331	CARRIZO SPRINGS	94LA370	551	2.526
135	266	RIO RICO	94SB5050	1,745	2.524
136	451	KLEBERG	94CS1560	1,384	2.520
137	118	WEST HARLINGEN	94SB3720	2,005	2.516
138	611	HAMILTON ROAD	94LA9665	955	2.516
139	new	MOCKINGBIRD	94CN400	408	2.515
140	708	AIRLINE	94CS7390	1,781	2.494
141	544	NORTH EDINBURG	94SB3810	925	2.474
142	578	NORTH VICTORIA	94CN7440	1,622	2.459
143	68	WEST MCALLEN	94SB4535	2,843	2.457
144	591	HARLINGEN	94SB380	2,387	2.456
145	31	OLMITO	94SB905	1,547	2.452
146	173	WEST MCALLEN	94SB4815	708	2.451
147	519	VICTORIA POWER PLANT	94CN1390	1,139	2.442
148	315	VILLA CAVAZOS	94SB7615	1,027	2.438
149	351	SIERRA VISTA	94LA9900	2,699	2.432
150	382	GATEWAY	94LA350	1,763	2.428
151	440	NORTH MCALLEN	94SB4995	2,029	2.410
152	423	PHARAOH	94CS5175	998	2.398
153	15	NAVAL BASE	94CS6330	333	2.393
154	666	SAN YGNACIO	94LA16060	509	2.393
155	196	DEL RIO CITY	94LA420	2,229	2.391
156	97	EDNA	94CN5785	1,258	2.387
157	637	CRYSTAL CITY	94LA140	924	2.380
158	504	NORTH MCALLEN	94SB2980	1,714	2.372
159	264	MORRIS STREET	94CS8715	1,597	2.344
160	84	PORT ARANSAS	94CS1000	1,767	2.340
161	535	CAUSEWAY	94SB4765	972	2.338
162	374	WEST OSO	94CS9090	1,686	2.335
163	90	SAN BENITO	94SB4030	2,592	2.332
164	280	LA PRYOR	94LA580	217	2.318
165	235	SAN DIEGO	94LA1980	592	2.311
166	247	MAGRUDER	94CN245	1,231	2.310

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
167	594	BISHOP	94CS7180	933	2.309
168	439	CHASE FIELD	94CN460	10	2.300
169	446	FALFURRIAS	94LA5210	1,124	2.295
170	155	ARANSAS PASS	94CS8280	577	2.293
171	70	FOSTER FIELD	94CN8880	110	2.291
172	579	SOUTH MISSION	94SB5215	1,254	2.281
173	565	MAGRUDER	94CN7870	1,291	2.280
174	326	ARANSAS PASS	94CS1250	416	2.279
175	404	HIGHWAY 9	94CS6720	1,307	2.278
176	463	MORRIS STREET	94CS8830	1,579	2.276
177	477	RANDADO	94LA8350	139	2.273
178	385	PLACEDO	94CN7970	471	2.270
179	396	WESMER	94SB1850	1,281	2.269
180	713	REFUGIO	94CN1170	892	2.263
181	372	EAST HARRISON	94SB4310	1,204	2.262
182	193	PORT LAVACA	94CN2490	1,071	2.261
183	394	MUSTANG ISLAND	94CS8510	437	2.256
184	300	EL GATO	94SB720	2,368	2.255
185	678	AIRLINE	94CS6970	1,246	2.242
186	154	UVALDE	94LA550	687	2.224
187	218	GARCENO	94SB2135	2,224	2.219
188	379	TATTON	94CN8490	132	2.212
189	104	SOUTH PADRE ISLAND	94SB6440	2,452	2.190
190	119	PHARAOH	94CS1285	1,785	2.188
191	367	LAGUNA	94CS9065	2,205	2.188
192	368	HOLLY	94CS1370	1,892	2.183
193	113	JOURDANTON	94LA5685	1,185	2.179
194	202	FREER	94LA2900	161	2.174
195	317	UVALDE	94LA5060	1,339	2.168
196	603	DEL RIO CITY	94LA440	1,099	2.156
197	120	FREER	94LA1500	221	2.154
198	668	NORTH MCALLEN	94SB3830	1,305	2.132
199	475	LOLITA	94CN6330	27	2.111
200	12	BRUNI	94LA5440	124	2.097
201	674	PALMHURST	94SB2820	1,724	2.097
202	610	MORRIS STREET	94CS8820	1,263	2.096
203	5	CARANCAHUA	94CN5870	468	2.094
204	18	RANGERVILLE	94SB3420	777	2.093
205	344	HALL ACRES ROAD	94SB5465	1,755	2.088
206	137	COMSTOCK	94LA230	183	2.087
207	389	CLARKWOOD	94CS7220	461	2.072
208	619	MORRIS STREET	94CS7465	813	2.064
209	7	PORT ISABEL S.S.	94SB3760	675	2.053
210	707	WEST HARLINGEN	94SB3700	1,730	2.050
211	661	EAST HARRISON	94SB3080	384	2.044
212	444	MATHIS	94CS340	1,491	2.008
213	479	HOLLY	94CS5820	939	2.004
214	452	MOORE FIELD	94SB3110	650	2.000
215	236	MCKENZIE ROAD	94CS140	267	2.000
216	380	PARKER	94CN9260	108	2.000
217	242	HARLINGEN S.S.	94SB320	1,508	1.997
218	589	VICTORIA POWER PLANT	94CN7600	165	1.994
219	142	MCCOLL ROAD	94SB2810	2,284	1.991
220	237	SOUTHSIDE	94CS8025	1,057	1.981
221	162	ODEM	94CS385	411	1.981
222	717	EAST HARRISON	94SB3000	531	1.949
223	424	UVALDE	94LA480	1,300	1.945

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
224	606	POLK AVENUE	94SB4600	2,816	1.941
225	547	HARLINGEN S.S	94SB4090	2,324	1.937
226	501	SOUTHSIDE	94CS7905	1,836	1.937
227	83	PORT LAVACA	94CN8310	326	1.933
228	211	MAGRUDER	94CN7690	569	1.921
229	548	GREGORY	94CS5920	613	1.914
230	699	AIRLINE	94CS8890	550	1.913
231	467	POLK AVENUE	94SB4170	1,745	1.889
232	508	ARCADIA	94CS1450	1,900	1.888
233	522	LYTLE	94LA2850	633	1.888
234	231	HAIN DRIVE	94SB9700	845	1.851
235	743	YORKTOWN	94CN3130	455	1.846
236	110	NIXON	94CN2025	544	1.840
237	243	CRESTONIO	94LA270	628	1.838
238	260	ARCADIA	94CS6930	1,499	1.833
239	283	FASHING	94CN360	53	1.830
240	560	CAMPWOOD	94LA3430	89	1.820
241	239	PLEASANTON	94LA9505	1,628	1.819
242	384	LA GRULLA	94SB4120	1,481	1.811
243	61	EL GATO	94SB910	2,426	1.810
244	88	GOODWIN	94SB4380	1,494	1.810
245	324	SAN DIEGO	94LA2890	1,060	1.807
246	558	EL CAMPO	94CN2800	1,404	1.786
247	693	MORRIS STREET	94CS5655	984	1.785
248	686	SOUTH MISSION	94SB3980	946	1.768
249	414	PLEASANTON	94LA9475	1,332	1.768
250	14	JOURDANTON	94LA5695	712	1.746
251	278	SAN BENITO	94SB3910	1,798	1.745
252	312	LOS FRESNOS	94SB2160	1,169	1.722
253	44	THREE RIVERS	94CN5190	495	1.717
254	125	COLUMBUS	94CN9060	368	1.717
255	274	SINTON	94CS180	946	1.716
256	430	CASA BLANCA	94CS1300	1,285	1.715
257	405	BEEVILLE	94CN490	952	1.706
258	165	ARANSAS PASS	94CS8270	643	1.697
259	709	ZACATE CREEK	94LA2635	324	1.694
260	369	NORTH EDINBURG	94SB3570	2,007	1.694
261	631	GOVERNMENT WELLS	94LA6800	228	1.684
262	281	DEVINE	94LA7090	956	1.681
263	95	CONOCO-CHITTAM RANCH	94LA8580	28	1.679
264	195	GREENLAKE	94CN2740	31	1.677
265	420	HAIN DRIVE	94SB3490	1,107	1.677
266	112	REFUGIO	94CN1040	184	1.674
267	33	CARRIZO SPRINGS	94LA910	874	1.672
268	549	SAN BENITO	94SB4945	1,742	1.669
269	474	WESMER	94SB4050	1,945	1.663
270	697	HALL ACRES ROAD	94SB4895	837	1.662
271	new	TYNAN	94CS4000	26	1.654
272	191	TAFT	94CS5230	846	1.652
273	506	SINTON	94CS6860	1,631	1.647
274	117	INGLESIDE CITY	94CS2495	279	1.645
275	159	NORTH ALAMO	94SB3580	856	1.645
276	2	YORKTOWN	94CN8420	653	1.637
277	739	ZAPATA	94LA2710	58	1.621
278	252	SOUTH SANTA ROSA	94SB1225	848	1.620
279	87	EAST HARRISON	94SB3950	581	1.608
280	268	MAGRUDER	94CN6680	701	1.606

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
281	491	NORTH MERCEDES	94SB3840	645	1.605
282	615	INGLESIDE CITY	94CS8050	1,263	1.599
283	108	RIO BRAVO	94LA1130	994	1.598
284	568	NORTH EDINBURG	94SB560	1,015	1.594
285	was <10 cust	BLACK BAYOU	94CN1120	325	1.591
286	201	NORTH MERCEDES	94SB4860	1,414	1.591
287	386	ODEM	94CS375	1,031	1.589
288	197	SOUTH PADRE ISLAND	94SB5850	1,302	1.584
289	575	CAMPWOOD	94LA2610	953	1.578
290	128	NORTH VICTORIA	94CN1580	1,032	1.576
291	484	PORTLAND	94CS9290	1,726	1.574
292	232	HALL ACRES ROAD	94SB3460	3,375	1.574
293	26	BROWNSVILLE	94SB3050	1,965	1.569
294	650	KLEBERG	94CS280	1,254	1.563
295	601	UVALDE	94LA9770	1,493	1.560
296	55	LOS FRESNOS	94SB5335	2,290	1.556
297	399	MOCKINGBIRD	94CN370	47	1.553
298	25	STADIUM	94LA7490	1,303	1.538
299	667	MCKENZIE ROAD	94CS150	26	1.538
300	35	CRYSTAL CITY	94LA190	1,421	1.527
301	415	ELSA	94SB3520	448	1.525
302	new	CARRIZO SPRINGS	94LA4405	630	1.517
303	52	ALICE	94LA1770	1,634	1.517
304	357	POLK AVENUE	94SB4520	921	1.517
305	673	ALICE	94LA1780	272	1.507
306	486	CLARKWOOD	94CS9570	1,144	1.506
307	465	LEARY LANE	94CN1430	1,727	1.504
308	521	ARCADIA	94CS8570	1,460	1.504
309	288	HALL ACRES ROAD	94SB5585	739	1.498
310	51	DILLEY	94LA510	605	1.489
311	123	PLACEDO	94CN7980	411	1.479
312	593	BEEVILLE	94CN2200	763	1.478
313	207	SOUTH SANTA ROSA	94SB1240	1,581	1.474
314	564	ARCADIA	94CS5030	1,589	1.463
315	469	SOUTH MISSION	94SB3620	1,944	1.459
316	685	HARLINGEN S.S	94SB5350	802	1.456
317	454	CITRUS CITY	94SB3470	1,511	1.450
318	176	LA PRYOR	94LA2440	697	1.440
319	536	GREGORY	94CS420	432	1.431
320	621	TATTON	94CS8200	1,061	1.425
321	462	BROWNSVILLE	94SB4290	414	1.423
322	272	FULTON	94CS6070	3,396	1.421
323	585	NORTH VICTORIA	94CN2240	776	1.421
324	429	PALMHURST	94SB2535	1,325	1.417
325	662	DEL MAR	94LA3440	1,421	1.417
326	608	HOLLY	94CS9675	1,781	1.415
327	330	BROOKHOLLOW	94CN7580	484	1.415
328	617	ARCADIA	94CS5020	1,543	1.412
329	583	KINGSVILLE	94CS1130	2,298	1.412
330	210	ENCINAL	94LA2160	982	1.408
331	529	SOUTHSIDE	94CS8005	754	1.402
332	115	HAINE DRIVE	94SB9240	40	1.400
333	43	GRETA	94CN7890	281	1.399
334	538	WESLACO UNIT	94SB5970	2,330	1.396
335	448	DEL MAR	94LA7930	1,420	1.394
336	109	ELSA	94SB710	1,917	1.390
337	322	SOUTHSIDE	94CS7925	1,298	1.390

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
338	407	PORT ISABEL S.S	94SB9295	2,167	1.390
339	302	LAREDO PLANT	94LA8695	1,064	1.390
340	532	EAST HARRISON	94SB3190	1,481	1.379
341	671	HIGHWAY 9	94CS6770	1,228	1.373
342	493	PETTUS	94CN1020	441	1.367
343	209	HALL ACRES ROAD	94SB3670	952	1.367
344	556	SOUTHSIDE	94CS8045	1,022	1.364
345	393	PALMVIEW	94SB6790	3,086	1.360
346	550	ARANSAS PASS	94CS650	754	1.357
347	256	GOLIAD	94CN8220	1,030	1.356
348	216	BAY CITY	94CN6450	959	1.355
349	482	SOUTH SANTA ROSA	94SB1235	640	1.355
350	569	SOUTH EAST EDINBURG	94SB4570	1,353	1.351
351	275	EL CAMPO	94CN5745	897	1.351
352	520	LAREDO HEIGHTS	94LA2450	2,540	1.350
353	567	RODD FIELD	94CS225	1,926	1.347
354	98	VICTORIA POWER PLANT	94CN8170	789	1.346
355	57	MOORE FIELD	94SB3120	144	1.340
356	new	MAYBERRY	94SB3160	557	1.339
357	89	NORTH PADRE ISLAND	94CS7900	2,031	1.333
358	298	WEIL TRACT (138/12KV)	94CS2520	555	1.333
359	436	PREMONT	94LA6610	820	1.327
360	277	ROCKPORT	94CS5930	1,216	1.326
361	664	EAST HARRISON	94SB3030	720	1.322
362	208	NORTH MCALLEN	94SB9660	1,994	1.320
363	157	SAN BENITO	94SB3860	237	1.316
364	626	MOCKINGBIRD	94CN305	307	1.316
365	332	NORTH WESLACO	94SB4810	1,370	1.311
366	435	SAN BENITO	94SB3920	2,476	1.307
367	540	WASHINGTON STREET	94LA6525	2,134	1.303
368	598	TATTON	94CS950	567	1.296
369	630	WASHINGTON STREET	94LA7015	1,551	1.295
370	59	EL GATO	94SB780	1,690	1.286
371	408	ALAZAN	94CS2740	36	1.278
372	273	SANTO NINO	94LA515	2,025	1.278
373	412	AIRLINE	94CS7280	653	1.277
374	514	EAGLE LAKE	94CN9455	592	1.277
375	730	WEST MCALLEN	94SB4965	1,029	1.273
376	295	LA GRULLA	94SB6150	746	1.271
377	66	DILLEY	94LA3795	821	1.262
378	690	BUENA VISTA	94LA8965	917	1.258
379	545	RAYMONDVILLE #2	94SB1280	1,052	1.257
380	238	CABANISS	94CS240	1,514	1.253
381	359	WEST MCALLEN	94SB4505	1,785	1.252
382	198	PALACIOS	94CN6840	1,541	1.248
383	395	PARKER	94CN9010	21	1.238
384	604	CITRUS CITY	94SB6000	2,047	1.236
385	138	ALAZAN	94CS620	171	1.234
386	249	GATEWAY	94LA3595	1,500	1.229
387	230	DEVINE	94LA8100	1,552	1.227
388	500	CITRUS CITY	94SB7985	1,099	1.218
389	542	HOLLY	94CS7740	2,016	1.214
390	75	EAGLE LAKE	94CN320	644	1.213
391	350	NORTH VICTORIA	94CN1470	469	1.211
392	96	CHARLOTTE	94LA8120	202	1.208
393	327	HALL ACRES ROAD	94SB8870	1,936	1.208
394	712	AIRLINE	94CS9390	2,096	1.206

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
395	13	PHARAOH	94CS1185	1,591	1.204
396	341	COFFEE PORT	94SB1095	959	1.204
397	390	STADIUM	94LA6950	530	1.189
398	703	MORRIS STREET	94CS8840	587	1.187
399	546	CABANISS	94CS80	1,225	1.186
400	377	NORTH MCALLEN	94SB9640	1,440	1.175
401	478	ANNA STREET	94LA850	1,589	1.172
402	37	ROBSTOWN	94CS1650	362	1.171
403	679	HEARN ROAD	94CS9665	594	1.170
404	634	EL CAMPO	94CN6370	743	1.167
405	175	GARWOOD CITY	94CN2560	206	1.160
406	234	BANDERA ELECTRIC (LEAKEY)	94LAL30	256	1.160
407	571	HIGHWAY 9	94CS7200	671	1.159
408	413	PHARR	94SB1625	2,181	1.159
409	30	KENEDY	94CN1970	741	1.155
410	416	HALL ACRES ROAD	94SB9595	1,160	1.142
411	376	WADSWORTH	94CN8630	671	1.133
412	321	ELSA	94SB690	2,318	1.132
413	276	MAYBERRY	94SB3010	94	1.128
414	65	KENEDY S.S	94CN8340	1,231	1.127
415	190	PEARSALL	94LA7050	937	1.122
416	94	PHARAOH	94CS5185	2,213	1.117
417	49	JOURDANTON	94LA880	297	1.114
418	370	SANTO NINO	94LA645	1,313	1.108
419	257	EDNA	94CN5775	501	1.106
420	406	DEL MAR	94LA490	795	1.099
421	373	SOUTH MCALLEN	94SB3640	317	1.091
422	164	LIVE OAK	94CS1080	871	1.088
423	676	HARLINGEN S.S.	94SB4110	835	1.086
424	180	HOMEPORT	94CS4665	465	1.082
425	582	NORTH VICTORIA	94CN6390	1,645	1.072
426	136	KARNES CITY	94CN2325	1,260	1.071
427	684	RAYMONDVILLE #1	94SB620	632	1.068
428	223	GOLIAD	94CN6540	1,187	1.067
429	187	UNIVERSITY	94LA950	2,172	1.064
430	562	SOUTH MCALLEN	94SB3935	941	1.063
431	715	ZACATE CREEK	94LA2665	1,689	1.059
432	356	LA GRULLA	94SB5110	1,448	1.055
433	375	RIO BRAVO	94LA300	800	1.050
434	45	POINT COMFORT	94CN6060	58	1.034
435	3	KENEDY S.S	94CN6750	60	1.033
436	186	BAY CITY	94CN2700	1,074	1.031
437	719	BEEVILLE	94CN2380	207	1.019
438	642	LIVE OAK	94CS1090	304	1.010
439	437	ARCADIA	94CS1400	438	1.002
440	189	SANTO NINO	94LA695	1,599	1.000
441	723	SOUTHSIDE	94CS5345	405	0.998
442	6	KENEDY S S	94CN8320	145	0.993
443	347	DEL MAR	94LA220	2,195	0.988
444	665	SIERRA VISTA	94LA3540	352	0.983
445	258	WASHINGTON STREET	94LA2470	211	0.981
446	456	OLMITO	94SB4275	778	0.978
447	40	RAYMONDVILLE #1	94SB630	786	0.969
448	629	BROOKHOLLOW	94CN7190	280	0.964
449	735	GREGORY	94CS2420	732	0.952
450	259	HOLLY	94CS1950	833	0.947
451	464	WEST HARLINGEN	94SB4870	1,046	0.928

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
452	383	PORT LAVACA	94CN2480	1,518	0.924
453	555	ASHERTON	94LA2670	89	0.921
454	716	KNIPPA	94LA6535	23	0.913
455	635	DEL MAR	94LA10	1,960	0.902
456	409	PALMHURST	94SB2525	1,978	0.901
457	480	NORTH MCALLEN	94SB5055	3,222	0.901
458	534	AIRLINE	94CS8370	303	0.888
459	652	SHARYLAND	94SB2035	1,419	0.882
460	314	SOUTH SANTA ROSA	94SB7485	1,038	0.873
461	527	NORTH VICTORIA	94CN7430	1,760	0.872
462	161	ESCONDIDO	94LA2035	2,771	0.867
463	46	HOLLY	94CS1480	1,742	0.865
464	36	NORTH PADRE ISLAND	94CS1010	2,022	0.864
465	289	WEST HARLINGEN	94SB3800	1,346	0.863
466	561	RIO GRANDE CITY	94SB3220	1,775	0.859
467	336	HEARN ROAD	94CS870	1,168	0.858
468	170	BIG OAK	94CN420	140	0.857
469	638	SOUTH EAST EDINBURG	94SB4550	2,113	0.856
470	32	VILLA CAVAZOS	94SB1980	1,604	0.829
471	559	ROCKPORT	94CS5950	559	0.828
472	607	AIRLINE	94CS9605	715	0.827
473	572	GOODWIN	94SB3530	1,773	0.827
474	453	WASHINGTON STREET	94LA2350	2,945	0.826
475	651	WESLACO UNIT	94SB2195	1,098	0.817
476	23	THREE RIVERS	94CN8430	186	0.812
477	58	ARCADIA	94CS1440	1,703	0.810
478	203	PLEASANTON	94LA2080	1,623	0.810
479	398	CITRUS CITY	94SB9775	1,500	0.804
480	171	BROOKHOLLOW	94CN8950	882	0.800
481	225	GARCENO	94SB2130	3,127	0.790
482	524	SAN DIEGO	94LA2880	1,315	0.789
483	488	POINT COMFORT	94CN2460	344	0.785
484	595	SEAWALL	94CS9420	820	0.783
485	107	EAGLE PASS CITY	94LA2770	2,987	0.783
486	188	CHARLOTTE	94LA2790	192	0.781
487	371	PALMVIEW	94SB9685	2,830	0.777
488	483	KNIPPA	94LA6365	315	0.775
489	194	KLEBERG	94CS6000	1,497	0.774
490	81	RIO GRANDE CITY	94SB3230	2,572	0.769
491	86	FULTON	94CS9050	1,685	0.753
492	363	MILO	94LA6940	346	0.749
493	421	CRESTONIO	94LA6660	769	0.740
494	287	MORRIS STREET	94CS7625	571	0.739
495	498	SHARYLAND	94SB5105	1,560	0.738
496	217	MATHIS	94CS1420	924	0.736
497	648	LOS FRESNOS	94SB7270	2,130	0.731
498	577	COLUMBUS	94CN6180	473	0.727
499	73	SOUTH SANTA ROSA	94SB1215	1,636	0.724
500	146	BLESSING	94CN1030	269	0.721
501	541	SOUTH MISSION	94SB3590	546	0.720
502	200	SEAWALL	94CS9325	1,487	0.716
503	38	FREER	94LA6320	156	0.712
504	748	MINES ROAD	94LA4275	37	0.703
505	349	LEARY LANE	94CN7530	2,941	0.702
506	507	EAGLE PASS CITY	94LA2650	1,349	0.696
507	675	MATHIS	94CS1410	459	0.691
508	632	WADSWORTH	94CN7660	1,355	0.689

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
509	54	NORTH PADRE ISLAND	94CS5170	1,211	0.685
510	649	MALONE	94CN7560	108	0.685
511	641	WESLACO UNIT	94SB8195	1,676	0.683
512	303	GARWOOD CITY	94CN2570	138	0.674
513	403	LEARY LANE	94CN1890	1,609	0.670
514	135	WEAVER ROAD	94CN1910	23	0.652
515	660	EL CAMPO	94CN7710	1,066	0.645
516	586	MAGRUDER	94CN6700	1,365	0.642
517	151	MATHIS	94CS2870	876	0.638
518	692	WASHINGTON STREET	94LA6355	1,005	0.634
519	220	PEARSALL	94LA5580	1,616	0.629
520	156	KINGSVILLE	94CS1140	1,017	0.626
521	725	CHOKO CANYON	94CN9255	377	0.618
522	297	EL GATO	94SB890	2,825	0.617
523	240	FALFURRIAS	94LA1080	450	0.616
524	417	PUEBLO	94LA130	1,381	0.605
525	510	AMISTAD DAM	94LA5450	1,182	0.605
526	48	VILLA CAVAZOS	94SB5680	1,703	0.593
527	79	NAVAL BASE	94CS1380	2,410	0.590
528	531	RIO GRANDE CITY	94SB3210	1,831	0.587
529	738	EAGLE PASS CITY	94LA2745	911	0.586
530	612	PHARR	94SB1620	2,586	0.579
531	145	HAINE DRIVE	94SB9690	814	0.577
532	307	SOUTHSIDE	94CS8055	868	0.576
533	320	ZAPATA	94LA8290	2,097	0.574
534	492	NORTH MCALLEN	94SB5060	2,387	0.573
535	333	POLK AVENUE	94SB4900	2,698	0.566
536	362	ANNA STREET	94LA2250	1,579	0.565
537	122	INGLESIDE CITY	94CS8060	1,826	0.554
538	458	RIO BRAVO	94LA5	725	0.553
539	655	BUENA VISTA	94LA9385	2,229	0.553
540	447	PALMVIEW	94SB7595	2,691	0.552
541	457	SOUTHSIDE	94CS7995	1,551	0.546
542	152	PORT ISABEL S S.	94SB4070	306	0.546
543	468	GOODWIN	94SB4390	781	0.543
544	426	RACHAL	94LA8145	339	0.540
545	590	HAMILTON ROAD	94LA9655	1,246	0.540
546	427	MATTHEWS	94CN1740	165	0.539
547	570	COTULLA	94LA610	1,590	0.536
548	206	NORTH WESLACO	94SB4830	504	0.534
549	490	FULTON	94CS2020	1,805	0.532
550	526	MINES ROAD	94LA3745	1,918	0.526
551	516	KLEBERG	94CS9395	1,311	0.526
552	174	RAYMONDVILLE #2	94SB4160	355	0.524
553	566	BROOKHOLLOW	94CN8960	573	0.522
554	27	ASHERTON	94LA2660	656	0.521
555	342	PUEBLO	94LA275	2,855	0.518
556	418	SABINAL	94LA485	497	0.515
557	553	LIVE OAK	94CS1070	2,894	0.513
558	551	HAINE DRIVE	94SB270	1,031	0.510
559	172	SOUTHSIDE	94CS7955	1,074	0.510
560	new	TYNAN	94CS1855	126	0.508
561	343	ROMA	94SB3070	1,271	0.506
562	509	GEORGE WEST	94CN730	969	0.504
563	185	REFUGIO	94CN1210	191	0.503
564	623	INGLESIDE CITY	94CS6040	357	0.501
565	450	AIRLINE	94CS9030	436	0.500

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
566	588	STADIUM	94LA8540	1,585	0.493
567	525	WESLACO UNIT	94SB7630	2,538	0.493
568	459	GEORGE WEST	94CN1320	746	0.492
569	714	ODEM	94CS5575	63	0.492
570	657	RIO GRANDE CITY	94SB3740	2,295	0.492
571	425	PALMHURST	94SB2530	1,816	0.481
572	364	PALMHURST	94SB3890	2,496	0.481
573	438	COLUMBUS	94CN930	913	0.480
574	17	SOUTH MCALLEN	94SB3850	680	0.475
575	222	THREE RIVERS	94CN2010	306	0.474
576	539	ANNA STREET	94LA900	2,840	0.468
577	487	EDROY	94CS6980	190	0.468
578	432	PALMVIEW	94SB3930	1,094	0.468
579	53	NORTH EDINBURG	94SB4240	2,373	0.464
580	711	HEARN ROAD	94CS2220	1,533	0.464
581	537	HIGHWAY 9	94CS9830	152	0.461
582	355	ROCKSPRINGS	94LA2600	369	0.461
583	581	ELSA	94SB3500	1,180	0.459
584	24	ALICE	94LA2530	1,455	0.457
585	205	DILLEY	94LA6400	178	0.455
586	358	PALACIOS	94CN6830	802	0.454
587	226	PLEASANTON	94LA120	1,262	0.441
588	92	SHARYLAND	94SB2150	1,074	0.438
589	160	RODD FIELD	94CS2190	2,700	0.436
590	41	CLARKWOOD	94CS7230	607	0.430
591	658	MILO	94LA8365	1,785	0.424
592	114	WEIL TRACT (138/12KV)	94CS1990	1,385	0.422
593	387	HARLINGEN	94SB360	2,479	0.421
594	106	HAINE DRIVE	94SB8065	1,321	0.420
595	323	WESLACO UNIT	94SB9805	1,851	0.419
596	62	HOLLY	94CS7620	2,693	0.418
597	552	BLESSING	94CN8780	66	0.409
598	8	YORKTOWN	94CN8380	813	0.401
599	695	WEST OSO	94CS9095	1,603	0.399
600	63	PORTLAND	94CS9270	1,461	0.398
601	653	COTULLA	94LA90	214	0.397
602	47	ZAPATA	94LA8300	1,734	0.394
603	442	BAY CITY	94CN1110	1,304	0.394
604	496	GOVERNMENT WELLS	94LA7250	569	0.390
605	618	RODD FIELD	94CS205	1,800	0.387
606	335	BISHOP	94CS2690	557	0.386
607	345	LAREDO HEIGHTS	94LA9080	706	0.384
608	348	LEARY LANE	94CN6175	2,471	0.378
609	400	MCCOLL ROAD	94SB4400	1,270	0.377
610	139	ELSA	94SB700	1,410	0.374
611	633	KINGSVILLE	94CS1670	428	0.374
612	722	MCCOLL ROAD	94SB4790	1,973	0.373
613	308	GREENLAKE	94CN2750	1,147	0.371
614	517	FREER	94LA5200	1,026	0.371
615	627	SHARYLAND	94SB2020	2,369	0.371
616	new	DIMIT	94LA4120	1,336	0.370
617	334	BAY CITY	94CN7480	2,071	0.365
618	318	WEST MCALLEN	94SB4555	1,502	0.364
619	246	SKIDMORE	94CS600	373	0.362
620	71	VICTORIA POWER PLANT	94CN8070	608	0.357
621	91	WESMER	94SB9705	1,108	0.356
622	471	LEARY LANE	94CN6005	1,399	0.355

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
623	533	EAGLE PASS CITY	94LA7060	853	0.353
624	248	SKIDMORE	94CS380	154	0.351
625	620	WESLACO UNIT	94SB8610	1,179	0.347
626	639	PALMVIEW	94SB9680	998	0.345
627	227	BEEVILLE	94CN8090	1,359	0.341
628	279	BAY CITY	94CN5960	1,853	0.340
629	153	REFUGIO	94CN5120	717	0.340
630	495	HARLINGEN	94SB660	1,906	0.339
631	319	FULTON	94CS440	2,100	0.338
632	178	WESMER	94SB4480	1,090	0.337
633	263	KENEDY	94CN6270	557	0.334
634	557	PREMONT	94LA2720	765	0.333
635	192	CHARLOTTE	94LA1960	498	0.331
636	518	KLEBERG	94CS8140	656	0.331
637	640	POLK AVENUE	94SB4610	1,378	0.329
638	647	WEAVER ROAD	94CN1900	61	0.328
639	388	HIGHWAY 9	94CS6760	679	0.325
640	473	MAGRUDER	94CN6690	673	0.321
641	682	RAYMONDVILLE #1	94SB3130	290	0.321
642	221	CASA BLANCA	94CS55	846	0.320
643	126	NORTH VICTORIA	94CN7770	807	0.316
644	361	ALICE	94LA1790	463	0.315
645	182	HIGHWAY 9	94CS7210	344	0.314
646	131	SANTO NINO	94LA80	1,849	0.314
647	340	RAYMONDVILLE #2	94SB3240	960	0.313
648	134	EAGLE PASS CITY	94LA450	747	0.313
649	245	NORTH ALAMO	94SB4370	1,473	0.308
650	141	FULTON	94CS3070	1,630	0.307
651	720	RAYMONDVILLE #1	94SB800	671	0.306
652	250	COTULLA	94LA460	628	0.304
653	306	KLEBERG	94CS6410	255	0.302
654	150	GATEWAY	94LA390	2,008	0.300
655	481	MCCOLL ROAD	94SB1655	1,310	0.300
656	177	RODD FIELD	94CS1730	2,116	0.299
657	597	SOUTH PADRE ISLAND	94SB4675	153	0.288
658	241	BAY CITY	94CN2050	515	0.287
659	229	EL CAMPO	94CN2860	836	0.283
660	401	MUSTANG ISLAND	94CS9470	681	0.280
661	554	ROMA	94SB3060	1,584	0.279
662	60	HIDALGO	94SB4845	1,158	0.277
663	392	EAGLE PASS CITY	94LA2510	588	0.276
664	292	HIDALGO	94SB3680	331	0.275
665	694	PORT LAVACA	94CN6850	681	0.275
666	271	KINGSVILLE	94CS1660	1,724	0.273
667	600	MCCOLL ROAD	94SB4780	2,166	0.271
668	503	PORT ARANSAS	94CS990	1,513	0.271
669	511	LAREDO PLANT	94LA9305	962	0.270
670	497	SOUTHSIDE	94CS8035	1,101	0.268
671	293	NORTH VICTORIA	94CN7860	1,497	0.268
672	103	STADIUM	94LA7810	1,627	0.264
673	378	HOLLY	94CS1220	3,451	0.264
674	228	WESMER	94SB7760	2,407	0.262
675	646	ARANSAS PASS	94CS590	446	0.251
676	628	WEST MCALLEN	94SB4595	1,181	0.251
677	587	SANTO NINO	94LA75	1,522	0.249
678	365	SOUTH EAST EDINBURG	94SB6580	1,372	0.249
679	255	BUENA VISTA	94LA9035	1,486	0.247

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
680	485	SOUTH MCALLEN	94SB3790	2,120	0.247
681	727	SOUTH MISSION	94SB4650	1,015	0.245
682	20	WEIL TRACT (138/12KV)	94CS5405	170	0.241
683	580	LAREDO PLANT	94LA8745	725	0.241
684	616	SHARYLAND	94SB6745	2,048	0.239
685	254	MCKENZIE ROAD	94CS330	2,308	0.237
686	397	LAREDO PLANT	94LA8565	1,432	0.237
687	624	HARLINGEN	94SB370	1,172	0.236
688	622	HIDALGO	94SB3400	867	0.234
689	710	ESCONDIDO	94LA1510	714	0.232
690	513	PORT ARANSAS	94CS6940	1,641	0.227
691	299	THREE RIVERS	94CN5100	53	0.226
692	728	ANNA STREET	94LA780	478	0.224
693	573	POLK AVENUE	94SB4190	1,712	0.221
694	282	ROCKPORT	94CS5940	50	0.220
695	169	PORT ARANSAS	94CS3030	852	0.218
696	731	ROCKSPRINGS	94LA8040	319	0.216
697	663	LAREDO HEIGHTS	94LA2100	2,099	0.215
698	215	WEST MCALLEN	94SB4515	823	0.215
699	305	SOUTH PADRE ISLAND	94SB4695	1,371	0.209
700	636	ARCADIA	94CS1360	1,583	0.206
701	746	TYNAN	94CS4010	49	0.204
702	706	SHARYLAND	94SB5635	2,100	0.203
703	337	WOOLRIDGE	94CS1120	2,384	0.202
704	574	MILO	94LA3070	2,675	0.201
705	644	STADIUM	94LA7800	680	0.200
706	472	EAST HARRISON	94SB4620	758	0.198
707	563	POLK AVENUE	94SB4180	1,243	0.198
708	726	WEST MCALLEN	94SB6385	220	0.195
709	718	PHARR	94SB1640	1,272	0.193
710	19	EAGLE LAKE	94CN310	724	0.181
711	494	SEAWALL	94CS9450	296	0.179
712	724	LAREDO HEIGHTS	94LA2390	1,712	0.176
713	244	LAREDO HEIGHTS	94LA6810	2,059	0.176
714	736	GOODWIN	94SB4625	357	0.171
715	419	RACHAL	94LA6595	313	0.163
716	433	CITRUS CITY	94SB5070	888	0.163
717	422	PHARR	94SB1645	2,627	0.159
718	360	SHARYLAND	94SB2010	1,155	0.155
719	328	SOUTH EAST EDINBURG	94SB4015	446	0.141
720	304	EL CAMPO	94CN7260	531	0.139
721	643	HAMILTON ROAD	94LA9645	298	0.138
722	602	WASHINGTON STREET	94LA2360	215	0.135
723	721	LEARY LANE	94CN1540	792	0.135
724	701	ESCONDIDO	94LA3350	1,332	0.130
725	683	MILO	94LA5020	1,953	0.126
726	410	KARNES CITY	94CN2315	472	0.125
727	new	KITTIE WEST	94CN3760	178	0.124
728	339	LAREDO PLANT	94LA8705	235	0.123
729	672	SOUTH MISSION	94SB3940	816	0.121
730	new	MAYBERRY	94SB5340	35	0.114
731	733	PHARAOH	94CS1365	598	0.109
732	214	POLK AVENUE	94SB4740	1,899	0.109
733	742	UNIVERSITY	94LA305	2,104	0.105
734	592	MORRIS STREET	94CS8850	513	0.097
735	737	UNIVERSITY	94LA920	317	0.095
736	140	GATEWAY	94LA5055	2,426	0.092

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
737	688	RODD FIELD	94CS3010	2,005	0.084
738	689	SUNCHASE	94SB1155	1,459	0.082
739	329	WESLACO UNIT	94SB7455	1,227	0.070
740	691	RODD FIELD	94CS245	2,781	0.066
741	new	NORDHEIM	94CN4275	76	0.066
742	56	COTULLA	94LA110	31	0.065
743	267	MILO	94LA3065	202	0.064
744	696	AIRLINE	94CS7270	933	0.064
745	740	WOOLRIDGE	94CS1110	1,696	0.051
746	741	MILO	94LA3060	131	0.046
747	605	SANTO NINO	94LA70	2,583	0.046
748	681	ANNA STREET	94LA5780	706	0.035
749	new	UNIVERSITY	94LA465	813	0.033
750	441	SIERRA VISTA	94LA7360	1,390	0.024
751	680	AIRLINE	94CS5870	936	0.019
752	732	ZACATE CREEK	94LA2675	1,195	0.016
753	381	MCCOLL ROAD	94SB4910	337	0.012
754	new	DIMMIT	94LA5545	563	0.011
755	434	UNIVERSITY	94LA930	103	0.010
756	new	KITTIE WEST	94CN3765	368	0.003
757	428	WASHINGTON STREET	94LANETLAR	190	-
758	744	MAGNOLIA	94CN315	15	-
759	745	VICTORIA POWER PLANT	94CNNETVIC	60	-
760	747	MORRIS STREET	94CSNET CC	303	-
761	new	MAYBERRY	94SB1790	732	-
762	new	MAYBERRY	94SB5770	413	-
763	new	MAYBERRY	94SB6450	20	-

Feeders from last year that are not in this year's list

2014 Ranking	Substation Identification	Feeder ID	Reason not in 2015
515	CASA BLANCA	94CS5115	merged into 94CS1300
66	DILLEY	94LA2885	now 94LA3795
116	KENEDY	94CN1960	merged into 94CN1970
309	NIXON	94CN2620	now 94CN3300
76	NIXON	94CN5990	now 94CN6630

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

With 10 or more Customers

Total Number of Feeders

763

Add or Delete Rows as Necessary

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1	397	RANDADO	94LA8360	164	1,557.75
2	26	GOVERNMENT WELLS	94LA7240	215	1,446.82
3	25	CONTINENTAL	94SB4080	65	1,438.69
4	565	CARRIZO SPRINGS	94LA860	74	1,437.86
5	123	CONTINENTAL	94SB4880	68	1,284.82
6	130	BONNIEVIEW	94CS8020	529	1,260.67
7	251	CONTINENTAL	94SB3650	21	1,225.10
8	72	LA PRYOR	94LA570	142	1,206.54
9	485	GREGORY	94CS5900	118	1,191.54
10	48	RAYMONDVILLE #2	94SB3250	41	1,139.80
11	14	MAYO	94CS625	208	1,016.38
12	89	GILA	94CS350	152	951.49
13	106	MAVERICK	94LA9680	740	928.83
14	153	PRAIRIE PUMP	94CN1940	80	856.34
15	327	MINES ROAD	94LA3680	1,026	851.64
16	6	LOS FRESNOS	94SB4315	1,008	849.75
17	161	NIXON	94CN6630	643	838.83
18	3	BRUNI	94LA5440	124	837.90
19	28	BIG WELLS	94LA2630	29	834.21
20	19	GILA	94CS345	58	819.10
21	332	CLARKWOOD	94CS5525	1,064	815.78
22	173	WEST OSO	94CS9085	841	811.40
23	609	LOLITA	94CN6330	27	764.19
24	343	BIG WELLS	94LA1570	457	754.25
25	482	EDROY	94CS6990	278	707.96
26	55	FOSTER FIELD	94CN2550	222	700.85
27	335	SAN DIEGO	94LA2930	578	683.06
28	443	BRACKETTVILLE	94LA8460	1,160	683.05
29	7	GANADO	94CN5795	473	681.43
30	104	RAYMONDVILLE #2	94SB3170	715	677.45
31	22	ARMSTRONG	94CS6050	76	677.16
32	677	ASPHALT MINES	94LA500	42	675.12
33	408	GOVERNMENT WELLS	94LA6800	228	671.39
34	139	PREMONT	94LA2730	173	670.73
35	614	DEL RIO CITY	94LA430	2,534	655.96
36	148	MALONE	94CN7550	177	628.12
37	330	RIO RICO	94SB8290	389	620.23
38	208	DEL RIO CITY	94LA1930	1,050	618.29
39	186	LULING - LCRA	94CN10	386	612.30
40	24	MARKHAM	94CN5550	116	610.21
41	291	TAFT	94CS1260	196	601.46
42	1	CHARLOTTE	94LA2780	52	585.06
43	16	FREER	94LA2900	161	584.34
44	108	SABINAL	94LA200	437	579.84
45	131	LULING - LCRA	94CN20	289	578.79
46	386	HIGHWAY 9	94CS6730	533	572.68
47	117	CATARINA	94LA2380	210	568.79
48	35	BRUNI	94LA1100	621	565.66
49	538	ARCADIA	94CS1460	2,164	560.13
50	266	RANDADO	94LA8350	139	557.45
51	45	O_CONNER	94CN390	208	550.56
52	180	MARKHAM	94CN6440	456	546.55

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
53	395	CASA BLANCA	94CS1300	1,285	539.75
54	736	ZAPATA	94LA2710	58	539.36
55	692	KINGSVILLE	94CS1350	384	539.29
56	120	PALACIOS	94CN8550	45	530.13
57	195	HIGHWAY 9	94CS6780	832	528.39
58	102	COMSTOCK	94LA230	183	524.55
59	610	PORTLAND	94CS6505	1,688	522.87
60	65	DARST	94CN790	245	517.51
61	169	BRUNI	94LA1120	289	516.79
62	628	BEEVILLE	94CN1760	1,819	514.25
63	79	SOUTH EAST EDINBURG	94SB5045	2,071	512.17
64	67	RANGERVILLE	94SB4060	898	508.76
65	454	ARANSAS PASS	94CS1250	416	500.03
66	273	DEVINE	94LA7090	956	496.26
67	644	ARCADIA	94CS5020	1,543	492.15
68	109	NAVAL BASE	94CS6330	333	490.05
69	479	NORTH PADRE ISLAND	94CS720	1,174	486.95
70	676	MOORE FIELD	94SB3960	1,970	482.86
71	286	UVALDE	94LA540	1,220	477.65
72	30	FREER	94LA1500	221	476.99
73	261	GILA	94CS7840	758	474.09
74	440	LAGUNA	94CS9590	2,221	469.72
75	703	DEL RIO CITY	94LA9790	2,321	465.83
76	191	RANGERVILLE	94SB3410	852	464.15
77	618	MORRIS STREET	94CS8820	1,263	462.90
78	21	PORT ISABEL S.S.	94SB3820	215	459.63
79	606	WOOLRIDGE	94CS1170	1,647	451.91
80	38	CONOCO-CHITTAM RANCH	94LA8580	28	441.61
81	49	PREMONT	94LA6570	735	432.94
82	461	PALMHURST	94SB1300	1,994	429.07
83	475	MORRIS STREET	94CS2515	1,087	428.28
84	62	JOURDANTON	94LA250	789	425.83
85	452	PHARAOH	94CS5175	998	425.68
86	551	BEEVILLE	94CN2200	763	424.44
87	new	CHOKE CANYON	94CN5390	429	422.22
88	83	BLESSING	94CN8790	750	421.85
89	209	TATTON	94CN8490	132	420.30
90	78	CAUSEWAY	94SB4795	1,206	417.86
91	146	BEEVILLE	94CN300	1,670	417.45
92	671	DEL RIO CITY	94LA9850	1,003	414.89
93	64	BROWNSVILLE	94SB4280	309	413.18
94	80	GREENLAKE	94CN2760	577	411.71
95	192	DEL RIO CITY	94LA420	2,229	411.28
96	207	CABANISS	94CS75	2,186	407.88
97	607	BISHOP	94CS7180	933	403.58
98	73	SIERRA VISTA	94LA9900	2,699	401.10
99	318	PLACEDO	94CN7970	471	393.47
100	94	RIO RICO	94SB8330	409	393.16
101	458	NAVAL BASE	94CS8440	1,619	387.90
102	39	CRESTONIO	94LA270	628	387.80
103	572	THOMASTON	94CN9580	46	385.33
104	748	MINES ROAD	94LA4275	37	382.27
105	545	ARCADIA	94CS1450	1,900	381.02
106	194	WEST HARLINGEN	94SB3720	2,005	374.34
107	422	ARANSAS PASS	94CS660	771	372.87
108	178	ARANSAS PASS	94CS9130	386	371.04
109	597	HARLINGEN	94SB380	2,387	370.39

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
110	301	BEEVILLE	94CN8510	842	365.56
111	71	UVALDE	94LA6620	2,741	362.82
112	630	TAFT	94CS1180	1,037	362.57
113	215	PORT ARANSAS	94CS1000	1,767	362.31
114	157	LA PRYOR	94LA580	217	361.30
115	698	DEVINE	94LA7100	963	358.83
116	513	BERCLAIR	94CN990	210	358.46
117	43	EAST HARRISON	94SB3950	581	356.75
118	359	MOORE FIELD	94SB3110	650	353.03
119	23	CARANCAHUA	94CN5870	468	350.51
120	175	BAY CITY	94CN6670	1,835	350.41
121	681	HAMILTON ROAD	94LA9665	955	348.34
122	216	SAN DIEGO	94LA1980	592	346.54
123	96	CRYSTAL CITY	94LA330	1,308	346.36
124	608	DEL RIO CITY	94LA440	1,099	345.23
125	61	REFUGIO	94CN1040	184	340.19
126	235	ELSA	94SB3520	448	334.65
127	455	NORTH ALAMO	94SB3610	1,815	333.70
128	658	AIRLINE	94CS6970	1,246	332.21
129	100	GREENLAKE	94CN2740	31	329.87
130	172	FOSTER FIELD	94CN8880	110	329.00
131	8	NIXON	94CN2025	544	328.77
132	672	KLEBERG	94CS280	1,254	326.03
133	436	RUNGE	94CN4465	650	325.77
134	37	RANGERVILLE	94SB3420	777	324.38
135	227	MAGRUDER	94CN245	1,231	322.39
136	453	HARLINGEN S S	94SB4090	2,324	321.17
137	735	GOODWIN	94SB7380	2,200	320.78
138	244	WEST OSO	94CS9090	1,686	320.38
139	580	ZAPATA	94LA7330	1,350	319.00
140	115	NORTH MERCEDES	94SB3770	1,707	318.25
141	401	LOS FRESNOS	94SB2160	1,169	317.20
142	275	FALFURRIAS	94LA1070	1,020	315.19
143	255	PETTUS	94CN8210	338	314.67
144	478	ALAZAN	94CS2740	36	314.19
145	414	CRESTONIO	94LA260	1,768	313.52
146	210	GARCENO	94SB2135	2,224	311.34
147	402	KLEBERG	94CS1560	1,384	310.36
148	336	THREE RIVERS	94CN2580	127	310.02
149	170	INGLESIDE CITY	94CS2495	279	306.92
150	158	UVALDE	94LA550	687	304.64
151	112	PLACEDO	94CN7980	411	302.11
152	477	PORTLAND	94CS9370	1,510	297.80
153	46	ELSA	94SB710	1,917	295.14
154	174	CARRIZO SPRINGS	94LA910	874	293.85
155	was <10 cust	BLACK BAYOU	94CN1120	325	293.82
156	259	ALICE	94LA2540	992	292.90
157	162	GRETA	94CN7890	281	289.49
158	469	HEARN ROAD	94CS8990	1,232	289.03
159	687	SOUTHSIDE	94CS5335	1,214	289.02
160	624	UVALDE	94LA9770	1,493	288.15
161	728	SOUTH MCALLEN	94SB5065	129	286.20
162	333	WESMER	94SB1850	1,281	285.42
163	319	RIO RICO	94SB5050	1,745	285.29
164	32	LA GRULLA	94SB5005	2,051	284.99
165	542	BANQUETTE	94CS9000	439	284.57
166	640	VICTORIA POWER PLANT	94CN7600	165	283.40

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
167	358	FALFURRIAS	94LA5210	1,124	282.89
168	254	PEARSALL	94LA3675	1,403	282.03
169	670	HEARN ROAD	94CS8980	1,229	281.89
170	5	PHARAOH	94CS1185	1,591	281.58
171	743	YORKTOWN	94CN3130	455	280.87
172	297	UVALDE	94LA5060	1,339	280.32
173	60	MOORE FIELD	94SB3120	144	279.21
174	237	SOUTHSIDE	94CS7925	1,298	277.45
175	134	NORDHEIM	94CN3380	172	275.92
176	150	WOODSBORO	94CS8330	1,108	275.13
177	553	CAMPWOOD	94LA3430	89	274.91
178	337	ARANSAS PASS	94CS8280	577	273.12
179	56	EL GATO	94SB910	2,426	271.98
180	470	PORTLAND	94CS9290	1,726	271.97
181	448	AIRLINE	94CS9605	715	269.43
182	74	ENCINAL	94LA2160	982	269.12
183	314	COFFEE PORT	94SB1090	1,149	269.07
184	558	LYTLE	94LA2850	633	265.79
185	649	CRYSTAL CITY	94LA140	924	265.64
186	199	NORTH ALAMO	94SB3580	856	261.51
187	346	BANQUETTE	94CS130	226	261.19
188	601	NORTH MCALLEN	94SB2750	3,367	260.19
189	697	LAREDO HEIGHTS	94LA9400	1,438	258.66
190	249	WESMER	94SB6900	1,621	256.90
191	518	CABANISS	94CS80	1,225	256.89
192	441	SOUTHSIDE	94CS8025	1,057	256.70
193	472	GREGORY	94CS5920	613	256.13
194	416	GATEWAY	94LA350	1,763	255.02
195	241	MOCKINGBIRD	94CN370	47	254.83
196	181	PUEBLO	94LA95	2,310	254.17
197	661	LAREDO HEIGHTS	94LA6820	2,103	251.32
198	525	NORTH EDINBURG	94SB560	1,015	249.51
199	445	UVALDE	94LA480	1,300	247.93
200	new	CARRIZO SPRINGS	94LA4405	630	247.68
201	571	NORTH MCALLEN	94SB4995	2,029	247.56
202	9	PORT ISABEL S.S.	94SB3760	675	246.57
203	377	FALFURRIAS	94LA2830	1,455	246.53
204	151	VILLA CAVAZOS	94SB7615	1,027	246.00
205	70	SAN BENITO	94SB4030	2,592	245.78
206	124	RIO BRAVO	94LA1130	994	245.29
207	15	FREER	94LA6320	156	245.05
208	645	MUSTANG ISLAND	94CS8510	437	244.89
209	390	HIGHWAY 9	94CS6720	1,307	243.92
210	363	MCKENZIE ROAD	94CS140	267	241.99
211	345	EAST HARRISON	94SB4310	1,204	240.44
212	107	ALAZAN	94CS620	171	240.10
213	54	EDNA	94CN5785	1,258	239.59
214	268	MAGRUDER	94CN7690	569	233.96
215	536	ARCADIA	94CS5030	1,589	232.62
216	204	SAN BENITO	94SB3910	1,798	231.50
217	324	MATHIS	94CS340	1,491	230.51
218	425	SOUTHSIDE	94CS7905	1,836	230.06
219	93	STADIUM	94LA7490	1,303	230.01
220	362	LEARY LANE	94CN1430	1,727	229.07
221	592	SINTON	94CS360	310	228.83
222	18	PARKER	94CN9260	108	227.58
223	663	PALMHURST	94SB2820	1,724	226.65

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
224	217	OLMITO	94SB715	565	225.63
225	198	EDNA	94CN5765	1,120	225.61
226	47	ALICE	94LA1770	1,634	224.69
227	284	ELSA	94SB690	2,318	224.15
228	427	RIO BRAVO	94LA300	800	223.28
229	548	MAGRUDER	94CN7870	1,291	223.18
230	250	NORTH MERCEDES	94SB4860	1,414	222.97
231	233	ARCADIA	94CS6930	1,499	222.93
232	new	MOCKINGBIRD	94CN400	408	222.71
233	302	GREGORY	94CS8560	256	222.55
234	665	HARLINGEN S S	94SB4110	835	222.27
235	121	PORT LAVACA	94CN2490	1,071	221.73
236	585	CAUSEWAY	94SB4775	1,058	220.30
237	214	COFFEE PORT	94SB1095	959	216.68
238	599	RAYMONDVILLE #2	94SB1280	1,052	216.39
239	257	PORT LAVACA	94CN8310	326	215.17
240	604	SAN YGNACIO	94LA16060	509	214.58
241	163	FASHING	94CN360	53	213.28
242	520	CAMPWOOD	94LA2610	953	212.45
243	489	ASHERTON	94LA2670	89	209.18
244	368	PALMVIEW	94SB6790	3,086	207.78
245	95	NIXON	94CN3300	580	207.74
246	550	SOUTH MISSION	94SB5215	1,254	207.10
247	20	BROWNSVILLE	94SB3050	1,965	206.61
248	707	SINTON	94CS1750	502	206.52
249	152	SUNCHASE	94SB1150	1,376	205.53
250	378	CLARKWOOD	94CS7610	171	205.19
251	236	NORTH PADRE ISLAND	94CS7900	2,031	202.41
252	531	ARANSAS PASS	94CS650	754	201.49
253	245	PORT ISABEL S.S	94SB9295	2,167	201.36
254	111	THREE RIVERS	94CN5190	495	200.61
255	421	ARCADIA	94CS8570	1,460	199.69
256	347	POLK AVENUE	94SB4520	921	199.49
257	187	NORTH PADRE ISLAND	94CS1010	2,022	198.87
258	657	AIRLINE	94CS8260	1,518	198.80
259	300	ODEM	94CS385	411	198.73
260	126	SOUTH SANTA ROSA	94SB1225	848	198.24
261	581	WESLACO UNIT	94SB5970	2,330	198.24
262	511	GREGORY	94CS420	432	196.76
263	702	MORRIS STREET	94CS5655	984	195.10
264	654	HARLINGEN S.S.	94SB4230	1,334	193.47
265	190	TAFT	94CS5230	846	193.02
266	58	NORTH PADRE ISLAND	94CS5170	1,211	191.63
267	138	PHARAOH	94CS1285	1,785	189.03
268	655	HIGHWAY 9	94CS6770	1,228	188.51
269	232	LA PRYOR	94LA2440	697	186.60
270	656	MCKENZIE ROAD	94CS150	26	184.85
271	700	WEST HARLINGEN	94SB3700	1,730	184.55
272	583	CARRIZO SPRINGS	94LA370	551	182.99
273	317	PALMVIEW	94SB9685	2,830	182.95
274	506	NORTH EDINBURG	94SB3810	925	182.88
275	544	CLARKWOOD	94CS9570	1,144	182.67
276	27	JOURDANTON	94LA5695	712	182.63
277	310	MORRIS STREET	94CS8715	1,597	181.76
278	451	HOLLY	94CS5820	939	181.42
279	633	MORRIS STREET	94CS8830	1,579	180.53
280	605	POLK AVENUE	94SB4600	2,816	180.36

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
281	734	KNIPPA	94LA6535	23	179.70
282	224	HOLLY	94CS1950	833	179.53
283	462	WEST MCALLEN	94SB4815	708	178.09
284	611	LAREDO PLANT	94LA8505	778	177.66
285	588	MORRIS STREET	94CS7465	813	176.17
286	678	SOUTH MISSION	94SB3980	946	174.82
287	12	STAFFORD HILL	94CN1550	222	174.26
288	144	WEIL TRACT (138/12KV)	94CS1990	1,385	173.48
289	282	LAREDO PLANT	94LA8695	1,064	173.11
290	398	HALL ACRES ROAD	94SB5465	1,755	171.86
291	578	NORTH VICTORIA	94CN7440	1,622	171.57
292	184	ARCADIA	94CS1440	1,703	171.35
293	706	AIRLINE	94CS8890	550	171.32
294	85	EL GATO	94SB720	2,368	171.08
295	166	DEVINE	94LA8100	1,552	170.89
296	201	PLEASANTON	94LA9505	1,628	168.93
297	350	SOUTHSIDE	94CS8005	754	168.02
298	331	LAGUNA	94CS9065	2,205	167.32
299	481	POLK AVENUE	94SB4170	1,745	166.40
300	446	CLARKWOOD	94CS7220	461	165.92
301	263	MCCOLL ROAD	94SB2810	2,284	165.89
302	498	WESMER	94SB4050	1,945	164.43
303	272	HOLLY	94CS1370	1,892	164.25
304	113	HAIN DRIVE	94SB9240	40	164.15
305	265	GATEWAY	94LA3595	1,500	161.75
306	68	SOUTH PADRE ISLAND	94SB6440	2,452	161.71
307	159	PALACIOS	94CN6840	1,541	161.71
308	44	GANADO	94CN5815	604	160.89
309	460	WESLACO UNIT	94SB8195	1,676	159.58
310	122	GOODWIN	94SB4380	1,494	159.45
311	556	SOUTH EAST EDINBURG	94SB4570	1,353	159.20
312	29	OLMITO	94SB905	1,547	159.18
313	66	EL GATO	94SB780	1,690	156.48
314	684	BUENA VISTA	94LA8965	917	154.06
315	40	COLUMBUS	94CN9060	368	154.00
316	81	JOURDANTON	94LA5685	1,185	153.59
317	404	SOUTHSIDE	94CS8045	1,022	152.94
318	492	NORTH MCALLEN	94SB2980	1,714	152.87
319	97	SAN BENITO	94SB4135	1,261	152.50
320	288	BEEVILLE	94CN490	952	151.95
321	447	CITRUS CITY	94SB3470	1,511	151.90
322	10	THREE RIVERS	94CN8430	186	151.74
323	384	AIRLINE	94CS7280	653	151.25
324	410	HAIN DRIVE	94SB270	1,031	151.16
325	276	SINTON	94CS180	946	150.74
326	228	ARANSAS PASS	94CS8270	643	150.72
327	252	SAN DIEGO	94LA2890	1,060	150.16
328	679	LIVE OAK	94CS1090	304	148.49
329	156	LOS FRESNOS	94SB5335	2,290	148.32
330	673	RAYMONDVILLE #1	94SB620	632	147.16
331	177	SAN BENITO	94SB3860	237	146.88
332	355	PLEASANTON	94LA9475	1,332	145.77
333	116	SOUTH PADRE ISLAND	94SB5850	1,302	144.67
334	727	REFUGIO	94CN1170	892	144.52
335	274	HARLINGEN S.S.	94SB320	1,508	143.82
336	668	ALICE	94LA1780	272	143.57
337	370	KNIPPA	94LA6365	315	143.35

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
338	484	CABANISS	94CS240	1,514	143.28
339	466	CITRUS CITY	94SB7985	1,099	142.77
340	50	CHARLOTTE	94LA2790	192	142.77
341	651	EAST HARRISON	94SB3080	384	142.46
342	260	SOUTHSIDE	94CS7995	1,551	142.25
343	203	SAN BENITO	94SB3920	2,476	142.07
344	new	TYNAN	94CS4000	26	141.58
345	325	CITRUS CITY	94SB9775	1,500	141.41
346	562	TATTON	94CS950	567	141.32
347	503	PETTUS	94CN1020	441	141.30
348	270	MAGRUDER	94CN6680	701	140.95
349	603	SOUTH MCALLEN	94SB3935	941	139.25
350	699	ZACATE CREEK	94LA2665	1,689	139.03
351	4	YORKTOWN	94CN8420	653	137.79
352	147	WEST MCALLEN	94SB4535	2,843	136.98
353	375	KENEDY S S.	94CN6750	60	136.85
354	205	SANTO NINO	94LA515	2,025	136.65
355	563	SAN BENITO	94SB4945	1,742	136.54
356	722	EAST HARRISON	94SB3000	531	136.44
357	305	PREMONT	94LA6610	820	136.32
358	423	HAINE DRIVE	94SB3490	1,107	136.18
359	34	CHARLOTTE	94LA8120	202	135.83
360	383	NAVAL BASE	94CS1380	2,410	134.98
361	57	ASHERTON	94LA2660	656	133.96
362	508	CAUSEWAY	94SB4765	972	131.97
363	42	ALICE	94LA2530	1,455	131.79
364	632	MILO	94LA8365	1,785	131.72
365	737	WEST MCALLEN	94SB4965	1,029	131.66
366	689	HARLINGEN S.S.	94SB5350	802	131.38
367	new	MAYBERRY	94SB3160	557	130.76
368	389	RACHAL	94LA8145	339	130.75
369	412	EAGLE LAKE	94CN9455	592	130.67
370	582	ELSA	94SB3500	1,180	130.50
371	429	HEARN ROAD	94CS870	1,168	129.82
372	573	NORTH VICTORIA	94CN6390	1,645	129.75
373	636	EAST HARRISON	94SB4360	1,745	129.54
374	283	BAY CITY	94CN6450	959	129.23
375	409	PORT LAVACA	94CN2480	1,518	128.76
376	561	CITRUS CITY	94SB6000	2,047	128.38
377	307	RIO BRAVO	94LA5	725	128.26
378	457	SOUTH SANTA ROSA	94SB7485	1,038	127.76
379	516	SAN DIEGO	94LA2880	1,315	127.54
380	471	LAREDO HEIGHTS	94LA2450	2,540	127.28
381	367	SOUTHSIDE	94CS8055	868	126.39
382	316	PALMVIEW	94SB7595	2,691	125.44
383	392	PALMHURST	94SB2535	1,325	125.07
384	615	TATTON	94CS8200	1,061	125.01
385	725	MORRIS STREET	94CS8840	587	124.63
386	625	WADSWORTH	94CN7660	1,355	124.59
387	450	WEST HARLINGEN	94SB4870	1,046	124.58
388	674	EAST HARRISON	94SB3030	720	124.24
389	226	BAY CITY	94CN2700	1,074	124.15
390	278	PARKER	94CN9010	21	123.86
391	620	EL CAMPO	94CN2800	1,404	123.58
392	125	VILLA CAVAZOS	94SB1980	1,604	123.41
393	666	MALONE	94CN7560	108	122.98
394	338	EL CAMPO	94CN5745	897	122.24

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
395	483	VICTORIA POWER PLANT	94CN1390	1,139	121.93
396	313	FULTON	94CS9050	1,685	121.34
397	229	LIVE OAK	94CS1080	871	120.77
398	200	GARWOOD CITY	94CN2560	206	120.45
399	381	HALL ACRES ROAD	94SB5585	739	119.08
400	171	LA GRULLA	94SB6150	746	117.62
401	295	MORRIS STREET	94CS7625	571	117.60
402	296	WEIL TRACT (138/12KV)	94CS2520	555	117.19
403	530	CHASE FIELD	94CN460	10	116.60
404	621	RODD FIELD	94CS205	1,800	116.57
405	600	INGLESIDE CITY	94CS8050	1,263	115.78
406	616	SOUTH MISSION	94SB3590	546	115.47
407	105	VILLA CAVAZOS	94SB5680	1,703	115.27
408	496	HOLLY	94CS9675	1,781	115.02
409	546	KINGSVILLE	94CS1130	2,298	114.88
410	487	BISHOP	94CS2690	557	114.57
411	535	POINT COMFORT	94CN2460	344	113.88
412	365	PALMHURST	94SB2525	1,978	113.39
413	306	ROCKPORT	94CS5930	1,216	113.38
414	82	PLEASANTON	94LA2080	1,623	112.80
415	613	ROCKPORT	94CS5950	559	111.53
416	183	KENEDY S S	94CN8340	1,231	111.12
417	197	BANDERA ELECTRIC (LEAKEY)	94LAL30	256	110.74
418	464	DEL MAR	94LA3440	1,421	110.55
419	334	GATEWAY	94LA390	2,008	109.40
420	731	EAGLE PASS CITY	94LA2745	911	108.69
421	419	WASHINGTON STREET	94LA2350	2,945	108.52
422	320	NORTH VICTORIA	94CN1580	1,032	108.38
423	617	SOUTH EAST EDINBURG	94SB4550	2,113	108.33
424	646	WASHINGTON STREET	94LA7015	1,551	106.94
425	309	ODEM	94CS375	1,031	106.37
426	322	MAYBERRY	94SB3010	94	106.14
427	519	RIO GRANDE CITY	94SB3220	1,775	105.33
428	341	WEST HARLINGEN	94SB3800	1,346	104.86
429	193	BLESSING	94CN1030	269	104.68
430	189	ESCONDIDO	94LA2035	2,771	104.18
431	202	WEAVER ROAD	94CN1910	23	103.48
432	512	HIGHWAY 9	94CS9830	152	102.74
433	298	SOUTH SANTA ROSA	94SB1215	1,636	102.32
434	724	ZACATE CREEK	94LA2635	324	101.84
435	132	SOUTH SANTA ROSA	94SB1240	1,581	100.83
436	311	WADSWORTH	94CN8630	671	99.54
437	424	STADIUM	94LA6950	530	98.53
438	63	VICTORIA POWER PLANT	94CN8170	789	98.28
439	467	SOUTH MISSION	94SB3620	1,944	98.13
440	428	SOUTHSIDE	94CS7955	1,074	97.22
441	622	NORTH MCALLEN	94SB3830	1,305	96.56
442	279	DILLEY	94LA510	605	96.14
443	701	AIRLINE	94CS9390	2,096	95.97
444	642	WESLACO UNIT	94SB2195	1,098	95.89
445	75	HOLLY	94CS1480	1,742	95.87
446	567	GOODWIN	94SB4390	781	95.79
447	543	GOODWIN	94SB3530	1,773	95.21
448	352	UNIVERSITY	94LA950	2,172	94.92
449	119	CRYSTAL CITY	94LA190	1,421	94.54
450	682	EL CAMPO	94CN6370	743	94.50
451	77	EAGLE LAKE	94CN320	644	93.15

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
452	87	ROBSTOWN	94CS1650	362	92.73
453	529	FULTON	94CS2020	1,805	92.71
454	394	NORTH MCALLEN	94SB9660	1,994	92.65
455	206	ZAPATA	94LA8290	2,097	92.00
456	281	RODD FIELD	94CS2190	2,700	91.99
457	356	SOUTH MCALLEN	94SB3640	317	91.94
458	405	NORTH WESLACO	94SB4810	1,370	91.83
459	264	HALL ACRES ROAD	94SB3460	3,375	91.56
460	715	AIRLINE	94CS7390	1,781	90.55
461	505	COLUMBUS	94CN6180	473	90.38
462	589	STADIUM	94LA8540	1,585	89.34
463	142	GARWOOD CITY	94CN2570	138	88.60
464	406	GEORGE WEST	94CN1320	746	88.59
465	88	GOLIAD	94CN8220	1,030	88.50
466	304	WEST MCALLEN	94SB4505	1,785	87.83
467	587	HOLLY	94CS7740	2,016	87.46
468	688	MATHIS	94CS1410	459	86.46
469	554	WASHINGTON STREET	94LA6525	2,134	86.26
470	527	ANNA STREET	94LA850	1,589	85.82
471	590	LOS FRESNOS	94SB7270	2,130	85.73
472	239	SEAWALL	94CS9325	1,487	85.23
473	420	BROOKHOLLOW	94CN7580	484	84.88
474	494	NORTH MCALLEN	94SB9640	1,440	84.65
475	269	DEL MAR	94LA490	795	84.51
476	285	GARCENO	94SB2130	3,127	84.25
477	528	SINTON	94CS6860	1,631	84.19
478	231	FALFURRIAS	94LA1080	450	84.04
479	523	BLESSING	94CN8780	66	83.77
480	502	SHARYLAND	94SB5105	1,560	83.67
481	329	OLMITO	94SB4275	778	83.44
482	167	GOLIAD	94CN6540	1,187	82.77
483	391	HALL ACRES ROAD	94SB8870	1,936	82.65
484	718	BEEVILLE	94CN2380	207	82.04
485	476	ANNA STREET	94LA2250	1,579	81.51
486	91	POINT COMFORT	94CN6060	58	81.43
487	431	HIGHWAY 9	94CS6760	679	81.29
488	339	LEARY LANE	94CN7530	2,941	81.23
489	532	PREMONT	94LA2720	765	81.08
490	379	NORTH WESLACO	94SB4830	504	80.97
491	501	PUEBLO	94LA130	1,381	80.94
492	637	SEAWALL	94CS9420	820	80.68
493	51	SANTO NINO	94LA695	1,599	80.12
494	437	NORTH VICTORIA	94CN1470	469	79.52
495	629	HIGHWAY 9	94CS7200	671	79.42
496	128	RIO GRANDE CITY	94SB3230	2,572	79.32
497	566	MINES ROAD	94LA3745	1,918	78.58
498	729	GREGORY	94CS2420	732	78.55
499	328	PALACIOS	94CN6830	802	78.38
500	541	AIRLINE	94CS8370	303	78.02
501	246	LAREDO HEIGHTS	94LA9080	706	77.25
502	353	SANTO NINO	94LA645	1,313	76.96
503	691	HALL ACRES ROAD	94SB4895	837	76.95
504	576	RODD FIELD	94CS225	1,926	76.44
505	685	RAYMONDVILLE #1	94SB800	671	76.03
506	196	ELSA	94SB700	1,410	76.01
507	176	INGLESIDE CITY	94CS8060	1,826	75.94
508	449	BROWNSVILLE	94SB4290	414	75.93

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
509	129	PEARSALL	94LA7050	937	75.86
510	140	RAYMONDVILLE #2	94SB4160	355	75.70
511	136	MATHIS	94CS2870	876	74.92
512	348	DILLEY	94LA3795	821	74.25
513	413	NORTH VICTORIA	94CN7430	1,760	73.92
514	36	JOURDANTON	94LA880	297	73.91
515	31	BROOKHOLLOW	94CN8950	882	73.89
516	219	CRESTONIO	94LA6660	769	73.82
517	417	PHARR	94SB1625	2,181	73.73
518	160	KARNES CITY	94CN2325	1,260	73.06
519	432	GOVERNMENT WELLS	94LA7250	569	72.97
520	371	WASHINGTON STREET	94LA2470	211	72.67
521	586	ANNA STREET	94LA900	2,840	72.39
522	308	DEL MAR	94LA220	2,195	72.03
523	364	EL GATO	94SB890	2,825	71.99
524	488	HALL ACRES ROAD	94SB9595	1,160	71.81
525	155	MATHIS	94CS1420	924	71.80
526	667	MOCKINGBIRD	94CN305	307	71.18
527	396	NORTH EDINBURG	94SB3570	2,007	71.14
528	598	SHARYLAND	94SB2035	1,419	71.01
529	164	HOMEPORT	94CS4665	465	70.99
530	517	AMISTAD DAM	94LA5450	1,182	69.93
531	634	MUSTANG ISLAND	94CS9470	681	69.92
532	225	KINGSVILLE	94CS1140	1,017	69.90
533	570	RIO GRANDE CITY	94SB3210	1,831	69.89
534	459	NORTH MCALLEN	94SB5055	3,222	69.60
535	59	BIG OAK	94CN420	140	69.04
536	662	BUENA VISTA	94LA9385	2,229	68.17
537	664	EL CAMPO	94CN7710	1,066	67.59
538	575	WEAVER ROAD	94CN1900	61	66.69
539	388	LEARY LANE	94CN1890	1,609	66.53
540	238	FULTON	94CS6070	3,396	65.37
541	434	BROOKHOLLOW	94CN8960	573	65.31
542	110	NORTH EDINBURG	94SB4240	2,373	65.08
543	619	NORTH VICTORIA	94CN2240	776	64.74
544	415	NORTH MERCEDES	94SB3840	645	64.35
545	382	DEL MAR	94LA7930	1,420	63.81
546	53	KENEDY	94CN1970	741	63.15
547	652	SIERRA VISTA	94LA3540	352	62.88
548	593	MAGRUDER	94CN6700	1,365	62.70
549	127	BAY CITY	94CN2050	515	62.66
550	118	MATTHEWS	94CN1740	165	62.57
551	321	LA GRULLA	94SB4120	1,481	61.71
552	351	HAIN DRIVE	94SB9700	845	61.66
553	369	PALMHURST	94SB2530	1,816	61.66
554	256	ROCKSPRINGS	94LA2600	369	61.66
555	267	REFUGIO	94CN1210	191	61.60
556	84	CLARKWOOD	94CS7230	607	61.43
557	711	ODEM	94CS5575	63	61.25
558	660	INGLESIDE CITY	94CS6040	357	61.18
559	399	MILO	94LA6940	346	60.27
560	218	THREE RIVERS	94CN5100	53	59.98
561	374	SABINAL	94LA485	497	59.94
562	730	CHOKY CANYON	94CN9255	377	59.58
563	312	GREENLAKE	94CN2750	1,147	59.47
564	500	GEORGE WEST	94CN730	969	59.40
565	315	RACHAL	94LA6595	313	58.93

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
566	277	HAIN DRIVE	94SB8065	1,321	58.55
567	564	LIVE OAK	94CS1070	2,894	58.45
568	new	TYNAN	94CS1855	126	57.81
569	533	FREER	94LA5200	1,026	57.26
570	271	KLEBERG	94CS6000	1,497	57.13
571	103	HIDALGO	94SB4845	1,158	56.95
572	101	PORT ISABEL S S	94SB4070	306	56.76
573	69	EAGLE PASS CITY	94LA2770	2,987	56.54
574	659	KINGSVILLE	94CS1670	428	56.22
575	287	ROMA	94SB3070	1,271	56.14
576	509	HIDALGO	94SB3400	867	56.12
577	584	RIO GRANDE CITY	94SB3740	2,295	55.78
578	380	HARLINGEN	94SB360	2,479	55.73
579	442	SOUTH SANTA ROSA	94SB1235	640	55.57
580	400	SOUTHSIDE	94CS8035	1,101	55.38
581	299	WESLACO UNIT	94SB9805	1,851	54.68
582	540	PUEBLO	94LA275	2,855	54.41
583	709	MCCOLL ROAD	94SB4790	1,973	53.76
584	17	KENEDY S.S.	94CN8320	145	53.15
585	507	SEAWALL	94CS9450	296	53.13
586	669	HEARN ROAD	94CS9665	594	53.01
587	555	COTULLA	94LA610	1,590	52.30
588	41	SOUTH MCALLEN	94SB3850	680	52.24
589	574	KLEBERG	94CS9395	1,311	51.59
590	143	THREE RIVERS	94CN2010	306	51.52
591	559	EAGLE PASS CITY	94LA2650	1,349	50.95
592	385	POLK AVENUE	94SB4900	2,698	50.64
593	86	ZAPATA	94LA8300	1,734	50.31
594	179	FULTON	94CS3070	1,630	50.02
595	474	EAST HARRISON	94SB3190	1,481	49.14
596	182	SHARYLAND	94SB2150	1,074	49.04
597	716	HEARN ROAD	94CS2220	1,533	48.86
598	612	HAMILTON ROAD	94LA9655	1,246	48.51
599	340	KLEBERG	94CS6410	255	48.47
600	357	HIGHWAY 9	94CS7210	344	48.33
601	514	SOUTH PADRE ISLAND	94SB4675	153	48.08
602	366	ALICE	94LA1790	463	47.70
603	188	COLUMBUS	94CN930	913	47.56
604	594	ARCADIA	94CS1360	1,583	47.37
605	133	HAIN DRIVE	94SB9690	814	47.33
606	705	WEST OSO	94CS9095	1,603	47.32
607	289	PEARSALL	94LA5580	1,616	47.08
608	680	HAMILTON ROAD	94LA9645	298	47.00
609	521	AIRLINE	94CS9030	436	46.96
610	376	PORTLAND	94CS9270	1,461	46.86
611	537	WESLACO UNIT	94SB7630	2,538	46.42
612	344	RAYMONDVILLE #2	94SB3240	960	46.26
613	694	ARANSAS PASS	94CS590	446	45.73
614	new	DIMMIT	94LA4120	1,336	45.40
615	433	BAY CITY	94CN7480	2,071	45.18
616	292	WESMER	94SB7760	2,407	44.98
617	579	SHARYLAND	94SB2020	2,369	44.82
618	591	NORTH MCALLEN	94SB5060	2,387	44.77
619	243	BEEVILLE	94CN8090	1,359	44.22
620	526	EDROY	94CS6980	190	44.05
621	262	CHARLOTTE	94LA1960	498	43.75
622	495	HARLINGEN	94SB660	1,906	43.31

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
623	13	YORKTOWN	94CN8380	813	43.06
624	168	SANTO NINO	94LA80	1,849	43.04
625	342	EAGLE PASS CITY	94LA2510	588	42.93
626	552	MCCOLL ROAD	94SB4780	2,166	42.79
627	631	PALMVIEW	94SB9680	998	42.73
628	650	POLK AVENUE	94SB4610	1,378	42.36
629	141	NORTH VICTORIA	94CN7770	807	42.36
630	185	PLEASANTON	94LA120	1,262	41.47
631	486	LAREDO PLANT	94LA9305	962	41.38
632	602	HARLINGEN	94SB370	1,172	41.38
633	293	WESMER	94SB9705	1,108	41.14
634	145	HALL ACRES ROAD	94SB3670	952	41.11
635	577	MAGRUDER	94CN6690	673	40.78
636	354	EDNA	94CN5775	501	40.74
637	430	PALMVIEW	94SB3930	1,094	40.37
638	710	PHARAOH	94CS1365	598	40.28
639	76	VICTORIA POWER PLANT	94CN8070	608	40.21
640	723	ROCKSPRINGS	94LA8040	319	40.19
641	222	DILLEY	94LA6400	178	39.91
642	92	RAYMONDVILLE #1	94SB630	786	39.53
643	247	PORT ARANSAS	94CS3030	852	39.41
644	253	KINGSVILLE	94CS1660	1,724	39.17
645	504	MORRIS STREET	94CS8850	513	38.88
646	349	MCKENZIE ROAD	94CS330	2,308	38.73
647	361	LEARY LANE	94CN6005	1,399	38.70
648	280	CASA BLANCA	94CS55	846	38.43
649	547	ROMA	94SB3060	1,584	38.18
650	234	PHARAOH	94CS5185	2,213	37.15
651	468	MCCOLL ROAD	94SB1655	1,310	37.07
652	223	HOLLY	94CS7620	2,693	36.96
653	212	HIDALGO	94SB3680	331	36.90
654	98	WESMER	94SB4480	1,090	36.82
655	221	STADIUM	94LA7810	1,627	36.73
656	407	BAY CITY	94CN1110	1,304	36.65
657	439	HOLLY	94CS1220	3,451	35.77
658	323	SHARYLAND	94SB2010	1,155	35.42
659	493	DEL MAR	94LA10	1,960	35.08
660	248	SKIDMORE	94CS380	154	34.86
661	569	SANTO NINO	94LA75	1,522	34.68
662	717	WASHINGTON STREET	94LA6355	1,005	34.60
663	230	COTULLA	94LA460	628	34.59
664	438	PORT ARANSAS	94CS990	1,513	34.49
665	522	FULTON	94CS440	2,100	34.46
666	675	COTULLA	94LA90	214	34.26
667	393	SOUTH EAST EDINBURG	94SB4015	446	33.85
668	560	SHARYLAND	94SB6745	2,048	33.27
669	373	EAST HARRISON	94SB4620	758	33.27
670	641	BROOKHOLLOW	94CN7190	280	33.08
671	220	NORTH ALAMO	94SB4370	1,473	32.86
672	290	ROCKPORT	94CS5940	50	32.30
673	473	WEST MCALLEN	94SB4555	1,502	31.66
674	211	NORTH VICTORIA	94CN7860	1,497	31.64
675	639	PHARR	94SB1620	2,586	31.63
676	372	RODD FIELD	94CS1730	2,116	31.57
677	387	BAY CITY	94CN5960	1,853	31.50
678	33	WEIL TRACT (138/12KV)	94CS5405	170	31.47
679	539	SOUTH PADRE ISLAND	94SB4695	1,371	30.87

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
680	648	STADIUM	94LA7800	680	30.55
681	463	PORT ARANSAS	94CS6940	1,641	30.02
682	746	TYNAN	94CS4010	49	29.73
683	213	KENEDY	94CN6270	557	29.32
684	693	PORT LAVACA	94CN6850	681	27.94
685	444	MILO	94LA3070	2,675	27.57
686	242	REFUGIO	94CN5120	717	27.41
687	696	RAYMONDVILLE #1	94SB3130	290	27.40
688	258	SKIDMORE	94CS600	373	26.66
689	360	BUENA VISTA	94LA9035	1,486	26.35
690	99	POLK AVENUE	94SB4740	1,899	26.09
691	708	PHARR	94SB1640	1,272	25.49
692	712	LAREDO HEIGHTS	94LA2390	1,712	25.47
693	549	LAREDO PLANT	94LA8565	1,432	25.43
694	635	WEST MCALLEN	94SB4595	1,181	25.11
695	326	WOOLRIDGE	94CS1120	2,384	25.10
696	149	EL CAMPO	94CN2860	836	24.93
697	490	LAREDO PLANT	94LA8745	725	24.87
698	52	EAGLE LAKE	94CN310	724	24.71
699	638	WASHINGTON STREET	94LA2360	215	24.12
700	596	WESLACO UNIT	94SB8610	1,179	23.83
701	491	LEARY LANE	94CN6175	2,471	23.28
702	557	EAGLE PASS CITY	94LA7060	853	23.03
703	741	GOODWIN	94SB4625	357	22.52
704	418	PALMHURST	94SB3890	2,496	22.39
705	499	SOUTH MCALLEN	94SB3790	2,120	22.06
706	695	SHARYLAND	94SB5635	2,100	21.96
707	497	SOUTH EAST EDINBURG	94SB6580	1,372	21.94
708	726	ANNA STREET	94LA780	478	21.82
709	480	PHARR	94SB1645	2,627	21.44
710	435	MCCOLL ROAD	94SB4400	1,270	21.43
711	303	CITRUS CITY	94SB5070	888	21.39
712	686	MILO	94LA5020	1,953	20.54
713	515	KLEBERG	94CS8140	656	19.83
714	721	SOUTH MISSION	94SB4650	1,015	19.71
715	627	LAREDO HEIGHTS	94LA2100	2,099	19.60
716	154	LAREDO HEIGHTS	94LA6810	2,059	19.01
717	240	WEST MCALLEN	94SB4515	823	18.95
718	114	EAGLE PASS CITY	94LA450	747	17.99
719	411	LA GRULLA	94SB5110	1,448	17.51
720	732	SOUTHSIDE	94CS5345	405	17.39
721	524	POLK AVENUE	94SB4180	1,243	17.30
722	719	LEARY LANE	94CN1540	792	17.10
723	714	WEST MCALLEN	94SB6385	220	15.67
724	294	ARCADIA	94CS1400	438	15.63
725	623	POLK AVENUE	94SB4190	1,712	15.34
726	742	UNIVERSITY	94LA305	2,104	13.95
727	426	KARNES CITY	94CN2315	472	13.84
728	683	SOUTH MISSION	94SB3940	816	13.68
729	465	EL CAMPO	94CN7260	531	13.08
730	new	KITTIE WEST	94CN3760	178	12.48
731	165	GATEWAY	94LA5055	2,426	12.23
732	137	LAREDO PLANT	94LA8705	235	11.72
733	720	ESCONDIDO	94LA1510	714	11.31
734	new	MAYBERRY	94SB5340	35	10.74
735	653	RODD FIELD	94CS3010	2,005	10.38
736	690	SUNCHASE	94SB1155	1,459	9.93

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
737	704	ESCONDIDO	94LA3350	1,332	9.74
738	new	UNIVERSITY	94LA465	813	7.37
739	510	WESLACO UNIT	94SB7455	1,227	7.21
740	11	MILO	94LA3065	202	6.30
741	713	RODD FIELD	94CS245	2,781	5.70
742	647	ANNA STREET	94LA5780	706	5.70
743	739	MILO	94LA3060	131	4.74
744	740	WOOLRIDGE	94CS1110	1,696	4.39
745	568	SANTO NINO	94LA70	2,583	4.21
746	new	NORDHEIM	94CN4275	76	4.14
747	595	AIRLINE	94CS7270	933	3.79
748	403	SIERRA VISTA	94LA7360	1,390	3.31
749	135	COTULLA	94LA110	31	3.13
750	738	UNIVERSITY	94LA920	317	2.27
751	733	ZACATE CREEK	94LA2675	1,195	1.48
752	534	UNIVERSITY	94LA930	103	1.44
753	643	MCCOLL ROAD	94SB4910	337	1.34
754	626	AIRLINE	94CS5870	936	1.14
755	new	DIMITT	94LA5545	563	0.61
756	new	KITTIE WEST	94CN3765	368	0.11
757	2	WASHINGTON STREET	94LANETLAR	190	-
758	744	MAGNOLIA	94CN315	15	-
759	745	VICTORIA POWER PLANT	94CNNETVIC	60	-
760	747	MORRIS STREET	94CSNET CC	303	-
761	new	MAYBERRY	94SB1790	732	-
762	new	MAYBERRY	94SB5770	413	-
763	new	MAYBERRY	94SB6450	20	-

Feeders from last year that are not in this year's list

2014 Ranking	Substation Identification	Feeder ID	Reason not in 2015
456	CASA BLANCA	94CS5115	merged into 94CS1300
348	DILLEY	94LA2885	now 94LA3795
90	KENEDY	94CN1960	merged into 94CN1970
95	NIXON	94CN2620	now 94CN3300
161	NIXON	94CN5990	now 94CN6630

Service Quality Report to the Public Utility Commission of Texas

AEP Texas Central Company

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2015 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	18.56%
Vegetation	17.98%
Animals and Birds	5.50%
People (Including cars and farm equip)	2.63%
Utility-owned Equipment	45.70%
Other	0.07%
Unknown	9.56%