



Control Number: 45516



Item Number: 5

Addendum StartPage: 0

RECEIVED

2016 FEB 12 AM 10:51

PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2015 Reporting Year

Entergy Texas, Inc.

Project 45516

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

System SAIFI	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2015	1.514	0.104	0.048	0.066	0.147	0.276	0.147	0.137	0.088	0.148	0.097	0.142
Scheduled 2015	0.049	0.006	0.004	0.001	0.003	0.006	0.005	0.003	0.004	0.005	0.003	0.007
Outside Causes 2015	0.265	0.032	0.010	0.000	0.000	0.065	0.031	0.050	0.020	0.028	0.003	0.010
Major Events 2015	0.264	0.000	0.000	0.000	0.146	0.000	0.000	0.118	0.000	0.000	0.000	0.000

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
System SAIDI	207.6	12.6	5.1	6.9	22.4	52.9	16.9	14.3	13.6	10.6	20.0	14.2	18.1
Forced 2015	2.9	0.3	0.3	0.1	0.1	0.4	0.2	0.1	0.3	0.4	0.3	0.2	0.2
Scheduled 2015	25.5	5.8	0.4	0.0	0.0	4.4	2.4	3.1	3.2	1.6	0.4	0.8	3.3
Outside Causes 2015	101.5	0.0	0.0	0.0	83.7	0.0	0.0	0.0	17.8	0.0	0.0	0.0	0.0
Major Events 2015													

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

389

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
1	15	WARREN	592WR	2,136	6.341
2	271	LACON	540LA	995	5.916
3	63	CLEVELAND (TX)	425CV	2,281	5.789
4	293	HAMPTON	158HA	1,137	5.487
5	4	FORT WORTH	567FT	483	5.354
6	101	GRIMES	982GR	743	5.114
7	64	NECHES	197NE	152	5.046
8	69	OAK RIDGE (TX)	743OK	3,940	4.744
9	8	HUNTSVILLE	611HU	1,591	4.678
10	1	GOREE	681GR	707	4.655
11	219	APRIL	590AP	1,572	4.644
12	279	HANKS	22HKS	1,151	4.573
13	21	CRYSTAL	566CR	1,431	4.556
14	317	GROVES-EGSI	59GRO	1,717	4.421
15	282	ELIZABETH	122EL	982	4.274
16	225	KOLBS	34KOL	1,211	4.262
17	327	YANKEE DOODLE	24YAN	254	4.217
18	58	Alden Bridge	769AL	1,245	4.211
19	205	HIMEX	223HI	4,363	4.155
20	147	PEE DEE	809PD	1,591	4.128
21	202	TEMCO	628TE	381	3.992
22	17	ECHO	71ECH	736	3.978
23	74	VIWAY	682VI	1,801	3.606
24	231	DOUCETTE	569DC	192	3.469
25	6	TAMINA	316TA	316	3.446
26	139	BRIDGE CITY	361BD	1,087	3.396
27	3	DAYTON BULK	725DY	1,485	3.378
28	134	STOWELL	233ST	650	3.363
29	261	EGYPT	552EP	710	3.304
30	112	CHINA	92CHI	643	3.303
31	209	HUNTSVILLE	600HU	2,012	3.302
32	121	DOUCETTE	570DC	1,128	3.256
33	65	WINSHIRE	241WS	1,062	3.183
34	186	CROCKETT	61CRK	98	3.173
35	264	TYRRELL	37TYR	512	3.145
36	88	DAYTON BULK	726DY	1,541	3.143
37	46	GOREE	682GR	1,184	3.121
38	141	RIVTRIN	268RV	2,597	3.099
39	50	METRO	719ME	1,839	3.061
40	47	CLEVELAND (TX)	405CV	1,887	3.034
41	20	MAYHAW	671MA	1,851	3.018
42	72	HUNTSVILLE	607HU	3,308	2.978
43	160	CENTRAL	133CE	1,599	2.971
44	81	FRONT STREET	307FR	501	2.934
45	55	DOBBIN	519DO	1,648	2.899
46	299	CONAIR	513CN	1,603	2.837

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
47	228	NEW CANEY	304NC	1,652	2.813
48	174	ROSEDALE (TX)	153RS	763	2.811
49	68	DOBBIN	920DO	1,768	2.800
50	91	NAVASOTA	969NA	881	2.788
51	275	VIWAY	681VI	958	2.787
52	328	CHEEK	166CH	579	2.758
53	128	MCLEWIS	381MC	1,222	2.685
54	353	FRONT STREET	310FR	569	2.657
55	22	TEMCO	627TE	1,065	2.618
56	146	LACON	539LA	1,959	2.617
57	33	LINDBERGH	40LNB	1,612	2.606
58	311	LAKEVIEW	81LAV	1,293	2.577
59	221	MCDONALD	477MD	1,570	2.572
60	262	LONGMIRE	583LM	1,266	2.570
61	274	KOLBS	37KOL	705	2.540
62	304	BENTWATER	521BW	2,020	2.529
63	176	NAVASOTA	905NA	2,140	2.520
64	67	CLEVELAND (TX)	426CV	2,975	2.504
65	255	Alden Bridge	767AL	2,575	2.498
66	84	SPURLOCK	99SPU	715	2.462
67	79	BAYSHORE	213BA	1,727	2.461
68	7	DAYTON BULK	723DY	967	2.427
69	340	WEST ORANGE	393WO	671	2.423
70	165	CORDREY	324CO	1,578	2.413
71	27	MAPLE	91MPL	248	2.411
72	111	NAVASOTA	904NA	1,457	2.373
73	144	RAYWOOD	74RAY	1,084	2.361
74	9	CHINA	93CHI	1,286	2.345
75	83	MERLIN	374MR	535	2.307
76	120	GRIMES	883GR	870	2.303
77	87	OAK RIDGE (TX)	740OK	1,242	2.291
78	204	MCLEWIS	380MC	2,406	2.289
79	154	SOUTH LIBERTY	714SL	123	2.285
80	206	HEARNE	29HRN	320	2.259
81	296	CONAIR	512CN	1,275	2.246
82	257	PORT ACRES BULK	70PAS	828	2.221
83	273	HUNTSVILLE	610HU	1,918	2.199
84	244	WYNTEX	634WT	1,299	2.194
85	105	DAYTON BULK	724DY	2,193	2.171
86	307	MAPLE	90MPL	342	2.161
87	329	LAKEVIEW	80LAV	703	2.151
88	31	RIVTRIN	269RV	3,005	2.146
89	51	MAGNOLIA AMES	711MG	780	2.138
90	368	WESTSIDE	113WS	294	2.122
91	213	CROCKETT	65CRK	565	2.122
92	252	GOSLIN	708GL	2,221	2.118
93	210	AMELIA BULK	180AM	1,379	2.104
94	310	LINDBERGH	42LNB	311	2.087
95	99	CORDREY	327CO	972	2.086
96	358	CHEEK	160CH	461	2.061
97	157	JIROU	77JRU	319	2.000

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
98	96	VIDOR	163VD	1,689	1.998
99	336	LINCOLN	16LCN	298	1.997
100	26	SARATOGA	761SA	433	1.975
101	110	CEDAR	698CE	23	1.957
102	117	CONAIR	514CN	1,439	1.936
103	36	TAMINA	317TA	921	1.912
104	57	HIMEX	221HI	109	1.908
105	253	BAYOU FANNETT	250BY	292	1.894
106	56	SPLENDORA	307SP	1,534	1.891
107	290	BRIARCLIFF	31BRC	876	1.857
108	12	Alden Bridge	764AL	1,252	1.854
109	189	PEE DEE	806PD	2,553	1.839
110	119	ECHO	70ECH	1,668	1.819
111	93	NORTH SILSBEE	472NS	338	1.811
112	103	DAISETTA	743DA	353	1.773
113	200	CRYSTAL	567CR	1,282	1.761
114	71	BATSON	53BAT	903	1.751
115	182	KOLBS	36KOL	1,352	1.726
116	New	METRO	724ME	507	1.722
117	258	SOMERVILLE	127SO	470	1.719
118	16	JOHNSTOWN	343JT	1,543	1.713
119	34	CORDREY	326CO	1,225	1.671
120	109	LINDBERGH	43LNB	784	1.659
121	127	KOUNTZE BULK	435KT	49	1.653
122	44	CLEVELAND (TX)	404CV	1,767	1.650
123	233	FORT WORTH	99FTW	367	1.646
124	77	MCHALE	113MC	626	1.631
125	70	Alden Bridge	765AL	896	1.631
126	159	TAMINA	599TA	449	1.579
127	14	CORRIGAN BULK	239CR	489	1.575
128	126	MCHALE	111MC	673	1.563
129	268	BRIARCLIFF	30BRC	2,385	1.551
130	269	PORT ACRES SUB	67PTA	585	1.538
131	281	SILSBEE	463SI	755	1.522
132	150	NEW CANEY	337NC	568	1.514
133	132	FRONT STREET	308FR	370	1.495
134	240	NEW CANEY	335NC	2,012	1.479
135	277	NECHES	193NE	1,498	1.453
136	211	Alden Bridge	762AL	5,411	1.452
137	191	WYNTEX	633WT	611	1.435
138	354	TYRRELL	38TYR	42	1.429
139	35	VIDOR	162VD	1,899	1.420
140	162	VIDOR	164VD	883	1.419
141	41	APOLLO	320AP	1,916	1.410
142	337	PORT ACRES SUB	69PTA	573	1.401
143	248	NECHES	194NE	10	1.400
144	73	STOWELL	231ST	992	1.393
145	249	BEVIL	156BE	671	1.392
146	49	MCDONALD	478MD	640	1.384
147	140	GEORGIA	670GE	498	1.384
148	92	WARREN	506WR	1,427	1.364

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
149	95	ELIZABETH	121EL	1,172	1.352
150	37	OAK RIDGE (TX)	745OK	1,861	1.334
151	323	PANSY	185PS	1,302	1.326
152	322	ELIZABETH	120EL	1,376	1.306
153	308	CENTRAL	130CE	718	1.305
154	289	NEW CANEY	333NC	5,191	1.290
155	24	MCHALE	110MC	1,041	1.272
156	349	CROCKETT	60CRK	199	1.271
157	100	SPLENDORA	308SP	2,398	1.261
158	89	CRYSTAL	570CR	959	1.260
159	177	LACON	537LA	2,085	1.244
160	318	JOHNSTOWN	342JT	687	1.239
161	188	ORANGE	352ON	914	1.224
162	355	WESTSIDE	111WS	347	1.196
163	247	DAISETTA	744DA	772	1.193
164	356	STONEGATE	93STG	2,063	1.192
165	263	PORT NECHES	45PTN	906	1.175
166	230	ELIZABETH	123EL	2,595	1.170
167	163	SPLENDORA	309SP	1,323	1.169
168	94	CLEVELAND (TX)	403CV	1,543	1.168
169	180	CENTRAL	132CE	1,780	1.162
170	312	YANKEE DOODLE	23YAN	554	1.155
171	297	CONROE BULK	506CN	2,117	1.146
172	19	CROCKETT	198CR	212	1.142
173	294	GROVES-EGSI	61GRO	934	1.137
174	278	LONGMIRE	580LM	1,947	1.131
175	108	PEE DEE	808PD	912	1.123
176	23	METRO	722ME	2,529	1.117
177	345	SOMERVILLE	126SO	865	1.106
178	238	CALDWELL INDUSTRIAL	138CI	696	1.098
179	314	VIRGINIA	130VI	1,004	1.081
180	90	OAK RIDGE (TX)	744OK	2,835	1.069
181	181	TESCO	36TSC	78	1.064
182	291	NORTH END	21NOE	1,892	1.054
183	199	GOSLIN	705GL	1,278	1.049
184	365	JIROU	75JRU	61	1.049
185	195	FEDERAL	801FE	255	1.043
186	142	WALDEN	563WD	1,886	1.039
187	161	WEST END	88WED	909	1.039
188	302	PARKDALE	171PR	705	1.034
189	194	WYNTEX	632WT	891	1.034
190	321	HANKS	23HKS	1,300	1.032
191	241	BENTWATER	520BW	1,890	1.019
192	173	BRIARCLIFF	32BRC	1,259	1.018
193	102	ECHO	73ECH	777	1.015
194	348	JIROU	76JRU	168	1.012
195	208	BEVIL	155BE	4,050	1.010
196	136	GRIMES	981GR	316	1.009
197	158	NORTH SILSBEE	471NS	1,091	1.005
198	164	OAK RIDGE (TX)	742OK	236	1.000
199	192	METRO	720ME	560	0.980

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
200	152	KOUNTZE BULK	451KT	1,033	0.976
201	59	BEVIL	154BE	2,349	0.974
202	382	WEST END	87WED	33	0.970
203	384	SPEEDWAY	917SW	33	0.970
204	135	HUMPHREY (TX)	107HM	890	0.967
205	122	MCHALE	112MC	802	0.964
206	334	BENTWATER	522BW	661	0.961
207	270	OAK RIDGE (TX)	741OK	824	0.954
208	42	JOHNSTOWN	544JT	2,745	0.946
209	61	ADAMS BAYOU	332AD	557	0.944
210	330	FORT WORTH	7FTW	1,237	0.943
211	133	RAYWOOD	73RAY	521	0.939
212	54	PLANTATION (TX)	545PL	1,100	0.932
213	246	LOEB	17LOB	946	0.923
214	222	AMELIA BULK	182AM	965	0.910
215	New	PARKDALE	172PR	20	0.900
216	171	CONROE BULK	577CN	569	0.882
217	60	LACON	538LA	1,438	0.878
218	76	LUMBERTON	441LU	4,249	0.877
219	288	LONGMIRE	581LM	2,242	0.872
220	156	CLEVELAND (TX)	406CV	1,374	0.867
221	48	JOHNSTOWN	345JT	1,467	0.843
222	235	SHEAWILL	536SH	1,303	0.842
223	237	ROSEDALE (TX)	152RS	738	0.841
224	85	HAMPTON	157HA	12	0.833
225	166	OILLA	345OI	1,403	0.833
226	229	CONROE BULK	572CN	1,364	0.831
227	260	APOLLO	321AP	1,171	0.819
228	295	LOEB	18LOB	567	0.815
229	236	MERLIN	375MR	863	0.810
230	30	WOODVILLE (TX)	593WD	711	0.805
231	New	PARKWAY	350PW	927	0.800
232	115	PANORAMA	525PA	1,380	0.799
233	25	APRIL	592AP	1,094	0.799
234	254	CHEEK	159CH	538	0.796
235	11	KOUNTZE BULK	432KT	850	0.792
236	97	HANKAMER	206HA	652	0.790
237	29	LOVELLS LAKE	142LV	353	0.776
238	280	ROSEDALE (TX)	151RS	1,265	0.775
239	218	CALVERT	4CAL	2,138	0.763
240	5	PLANTATION (TX)	546PL	866	0.748
241	217	HARDIN	35HDN	811	0.746
242	305	TANGLEWOOD	136TG	618	0.743
243	138	CALVERT	6CAL	1,591	0.733
244	116	GROVES-EGSI	63GRO	1,298	0.731
245	306	TANGLEWOOD	137TG	1,525	0.729
246	216	EASTGATE	781EG	1,018	0.724
247	137	DOUCETTE	568DC	593	0.718
248	369	TANGLEWOOD	135TG	672	0.713
249	43	EGYPT	551EP	2,379	0.712
250	187	FLETCHER	457FL	1,491	0.708

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
251	175	APRIL	591AP	1,623	0.703
252	220	SOUR LAKE	105SL	1,236	0.697
253	13	KICKAPOO	251KP	1,299	0.694
254	272	PANSY	184PS	435	0.690
255	201	SILSBEE	462SI	793	0.677
256	223	ADAMS BAYOU	331AD	194	0.675
257	333	GOSLIN	706GL	1,502	0.666
258	207	CONAIR	515CN	1,679	0.655
259	10	LOVELLS LAKE	141LV	743	0.647
260	125	LONGMIRE	582LM	1,033	0.644
261	367	WEST END	86WED	480	0.640
262	28	FLETCHER	456FL	826	0.605
263	347	ORANGE	351ON	509	0.601
264	178	METRO	721ME	1,496	0.592
265	245	WINFREE	342WN	1,157	0.591
266	265	YANKEE DOODLE	22YAN	2,109	0.588
267	285	ORANGE	350ON	944	0.587
268	104	WOODVILLE (TX)	594WD	1,169	0.583
269	155	KOLBS	35KOL	1,092	0.580
270	151	HANKS	25HKS	914	0.579
271	276	ECHO	72ECH	503	0.579
272	32	HEARNE	25HRN	223	0.578
273	303	CONAIR	511CN	1,608	0.576
274	143	STONEGATE	91STG	1,368	0.576
275	224	HANKAMER	207HA	734	0.569
276	168	BRIDGE CITY	363BD	2,041	0.555
277	39	NEW CANEY	338NC	2,342	0.553
278	342	CONROE BULK	576CN	1,300	0.502
279	107	MCDONALD	476MD	983	0.494
280	266	PORT ACRES SUB	68PTA	1,263	0.492
281	149	MANCHESTER	67MAN	1,025	0.491
282	267	GOSLIN	707GL	696	0.478
283	53	CORRIGAN BULK	238CR	609	0.476
284	131	WALDEN	564WD	2,628	0.470
285	38	HUNTSVILLE	608HU	3,182	0.463
286	172	NEW CANEY	336NC	4,588	0.459
287	113	BRIDGE CITY	362BD	1,171	0.459
288	18	TAMINA	598TA	833	0.459
289	118	MCLEWIS	382MC	822	0.457
290	214	VIRGINIA	131VI	1,392	0.456
291	320	BAYSHORE	211BA	1,045	0.444
292	251	CROCKETT	195CR	981	0.439
293	324	HANKS	24HKS	841	0.430
294	215	VIDOR	161VD	608	0.426
295	259	HUMPHREY (TX)	106HM	1,119	0.425
296	184	NEW CANEY	334NC	6,327	0.422
297	148	LILLARD	490LI	303	0.422
298	346	CENTRAL	131CE	966	0.417
299	226	CONROE BULK	507CN	2,143	0.416
300	198	CORDREY	325CO	1,553	0.406
301	332	CHEEK	165CH	107	0.402

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
302	98	WINSHIRE	240WS	931	0.400
303	212	BRIDGE CITY	360BD	1,015	0.397
304	227	GOSLIN	709GL	3,642	0.396
305	300	WEST END	80WED	274	0.387
306	243	FORT WORTH	12FTW	1,466	0.384
307	153	TRANSCO	48TCO	203	0.384
308	66	WEST END	85WED	526	0.384
309	315	STONEGATE	92STG	2,013	0.382
310	145	PORT NECHES	46PTN	1,266	0.378
311	62	CROWDER	103CD	1,432	0.346
312	82	STOWELL	232ST	1,136	0.335
313	45	WINFREE	340WN	456	0.331
314	239	CROWDER	102CD	1,703	0.330
315	359	WALDEN	560WD	694	0.329
316	331	SHEAWILL	535SH	678	0.319
317	250	WEST ORANGE	392WO	630	0.311
318	183	EGYPT	550EP	963	0.307
319	167	CONROE BULK	574CN	1,598	0.288
320	New	RAYWOOD	75RAY	122	0.279
321	301	TANGLEWOOD	134TG	2,206	0.269
322	362	CROWDER	105CD	908	0.265
323	170	CROCKETT	64CRK	1,018	0.262
324	316	MANCHESTER	66MAN	2,079	0.258
325	106	METRO	723ME	699	0.258
326	124	LINDBERGH	41LNB	1,717	0.248
327	319	MCDONALD	479MD	759	0.245
328	298	BROOKS CREEK	270BC	51	0.235
329	129	ADAMS BAYOU	330AD	153	0.235
330	40	SOUR LAKE	104SL	357	0.232
331	284	WINFREE	341WN	702	0.224
332	130	SILSBEE	461SI	535	0.224
333	78	JIROU	78JRU	309	0.223
334	325	GROVES-EGSI	62GRO	1,539	0.222
335	234	VIRGINIA	129VI	593	0.218
336	335	LINCOLN	15LCN	290	0.217
337	350	CONROE BULK	505CN	1,358	0.216
338	313	VIRGINIA	132VI	605	0.203
339	371	NORTH END	29NOE	362	0.202
340	352	INDEPENDENCE (TX)	945ID	10	0.200
341	341	GOSLIN	703GL	2,152	0.197
342	123	METRO	716ME	23	0.174
343	52	DAYTON BULK	727DY	793	0.169
344	New	PARKWAY	782PW	334	0.168
345	383	TRAVIS	8TRV	14	0.143
346	80	GOSLIN	704GL	1,682	0.124
347	179	CROWDER	104CD	1,600	0.108
348	376	HEARNE	28HRN	29	0.103
349	380	CROCKETT	63CRK	32	0.094
350	364	ROSEDALE (TX)	150RS	122	0.090
351	286	BRIARCLIFF	33BRC	304	0.089
352	339	HIMEX	222HI	219	0.087

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIFI Ranking	2014 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIFI Value
353	351	Alden Bridge	766AL	1,659	0.086
354	372	NORTH END	28NOE	172	0.081
355	357	Alden Bridge	768AL	3,488	0.080
356	197	Alden Bridge	763AL	1,163	0.078
357	283	NORTH END	26NOE	308	0.075
358	373	GOSLIN	702GL	1,773	0.072
359	86	SPURLOCK	98SPU	720	0.072
360	203	METRO	717ME	146	0.068
361	363	CONROE BULK	575CN	809	0.066
362	360	LONGMIRE	584LM	1,391	0.058
363	185	YANKEE DOODLE	25YAN	172	0.052
364	292	WESTSIDE	112WS	390	0.051
365	287	AMELIA BULK	181AM	2,234	0.043
366	242	BAYSHORE	212BA	48	0.042
367	370	MEMORIAL	281ML	745	0.039
368	256	NAVASOTA	901NA	289	0.038
369	338	STONEGATE	90STG	1,041	0.036
370	75	CONAIR	516CN	278	0.025
371	196	TRAVIS	13TRV	45	0.022
372	361	GOSLIN	701GL	1,690	0.022
373	169	MEMORIAL	280ML	934	0.017
374	New	PARKWAY	351PW	560	0.014
375	309	METRO	718ME	1,314	0.008
376	366	WEST END	82WED	481	0.008
377	344	PARKDALE	176PR	535	0.006
378	2	HUMPHREY (TX)	108HM	45	0.000
379	326	TRAVIS	11TRV	24	0.000
380	374	TRAVIS	14TRV	18	0.000
381	375	NORTH END	27NOE	94	0.000
382	378	WALDEN	562WD	10	0.000
383	379	CONROE BULK	573CN	12	0.000
384	381	TRAVIS	6TRV	29	0.000
385	190	GOSLIN	710GL	960	0.000
386	114	METRO	715ME	29	0.000
387	343	DAISETTA	741DA	170	0.000
388	385	TRAVIS	9TRV	13	0.000
389	386	FAWIL	FAWIL	37	0.000

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

389

Add or Delete Rows as Necessary

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1	85	SOUTH LIBERTY	714SL	123	1270.1
2	32	WARREN	592WR	2,136	1226.5
3	113	PEE DEE	809PD	1,591	1117.8
4	5	GOREE	681GR	707	1062.4
5	235	LACON	540LA	995	1031.1
6	234	DOUCETTE	569DC	192	937.1
7	9	DOBBIN	519DO	1,648	933.6
8	285	BENTWATER	521BW	2,020	909.2
9	151	HIMEX	223HI	4,363	890.9
10	94	TEMCO	628TE	381	876.3
11	12	CRYSTAL	566CR	1,431	867.6
12	301	LINDBERGH	42LNB	311	860.2
13	303	YANKEE DOODLE	24YAN	254	806.4
14	1	HUNTSVILLE	611HU	1,591	773.1
15	51	CLEVELAND (TX)	425CV	2,281	766.1
16	13	ECHO	71ECH	736	754.9
17	89	DOUCETTE	570DC	1,128	718.2
18	122	GRIMES	982GR	743	674.8
19	127	OAK RIDGE (TX)	743OK	3,940	660.0
20	335	ROSEDALE (TX)	153RS	763	646.5
21	17	FORT WORTH	567FT	483	641.3
22	316	HANKS	22HKS	1,151	613.8
23	78	JIROU	77JRU	319	590.6
24	54	DOBBIN	920DO	1,768	589.9
25	123	HUNTSVILLE	600HU	2,012	535.9
26	80	DAYTON BULK	726DY	1,541	520.9
27	108	LACON	539LA	1,959	510.6
28	56	TAMINA	316TA	316	502.9
29	264	ELIZABETH	122EL	982	499.6
30	168	VIWAY	682VI	1,801	480.7
31	2	OAK RIDGE (TX)	740OK	1,242	460.1
32	313	HAMPTON	158HA	1,137	456.4
33	100	FRONT STREET	307FR	501	443.8
34	193	APRIL	590AP	1,572	438.5
35	326	CHEEK	166CH	579	438.4
36	8	DAYTON BULK	725DY	1,485	434.7
37	176	EGYPT	552EP	710	431.2
38	321	GROVES-EGSI	59GRO	1,717	428.2
39	115	PEE DEE	806PD	2,553	422.7
40	137	NEW CANEY	304NC	1,652	420.4
41	18	CORRIGAN BULK	239CR	489	420.1
42	76	CHINA	92CHI	643	420.1
43	357	FRONT STREET	310FR	569	415.7
44	53	MAGNOLIA AMES	711MG	780	413.5
45	248	LONGMIRE	583LM	1,266	413.4
46	11	TEMCO	627TE	1,065	409.6

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
47	384	SPEEDWAY	917SW	33	409.2
48	29	GOREE	682GR	1,184	408.4
49	22	NECHES	197NE	152	407.8
50	145	TAMINA	599TA	449	406.0
51	305	CONAIR	512CN	1,275	399.1
52	36	DAYTON BULK	723DY	967	397.0
53	42	CHINA	93CHI	1,286	393.3
54	306	MAPLE	90MPL	342	389.0
55	33	HUNTSVILLE	607HU	3,308	388.6
56	220	PORT ACRES BULK	70PAS	828	385.9
57	236	WYNTEX	634WT	1,299	366.9
58	237	CENTRAL	133CE	1,599	362.6
59	279	CONAIR	513CN	1,603	358.6
60	73	KOLBS	34KOL	1,211	357.7
61	52	PEE DEE	808PD	912	357.0
62	140	GEORGIA	670GE	498	356.7
63	60	BAYSHORE	213BA	1,727	347.4
64	107	RAYWOOD	74RAY	1,084	346.5
65	118	WINSHIRE	241WS	1,062	345.2
66	338	BENTWATER	522BW	661	343.0
67	310	CROCKETT	61CRK	98	338.8
68	62	CLEVELAND (TX)	405CV	1,887	336.9
69	117	NAVASOTA	904NA	1,457	335.5
70	154	MAPLE	91MPL	248	335.0
71	47	CLEVELAND (TX)	426CV	2,975	332.7
72	196	HEARNE	29HRN	320	331.6
73	213	GOSLIN	708GL	2,221	324.4
74	10	SARATOGA	761SA	433	323.1
75	165	GRIMES	981GR	316	322.2
76	232	BRIDGE CITY	361BD	1,087	320.0
77	276	NEW CANEY	333NC	5,191	314.3
78	96	STOWELL	231ST	992	309.4
79	55	DAISETTA	743DA	353	306.7
80	35	MAYHAW	671MA	1,851	305.9
81	195	MCLEWIS	380MC	2,406	299.3
82	3	RIVTRIN	269RV	3,005	296.5
83	340	LAKEVIEW	80LAV	703	292.5
84	233	TYRRELL	37TYR	512	290.4
85	230	HUNTSVILLE	610HU	1,918	290.3
86	304	Alden Bridge	769AL	1,245	284.9
87	309	PORT NECHES	45PTN	906	284.4
88	139	MERLIN	374MR	535	280.8
89	19	CEDAR	698CE	23	280.8
90	97	RIVTRIN	268RV	2,597	274.8
91	204	ECHO	70ECH	1,668	270.7
92	57	CLEVELAND (TX)	404CV	1,767	269.2
93	14	JOHNSTOWN	343JT	1,543	267.8
94	203	CROCKETT	65CRK	565	263.2
95	41	LACON	538LA	1,438	262.9
96	277	SILSBEE	463SI	755	253.8
97	269	NECHES	193NE	1,498	249.7

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
98	77	NAVASOTA	969NA	881	248.1
99	247	LOEB	18LOB	567	242.9
100	251	STOWELL	233ST	650	242.0
101	138	GRIMES	883GR	870	237.5
102	355	TYRRELL	38TYR	42	235.2
103	101	OAK RIDGE (TX)	745OK	1,861	228.2
104	61	VIDOR	163VD	1,689	225.9
105	184	NAVASOTA	905NA	2,140	225.4
106	252	BRIARCLIFF	30BRC	2,385	220.6
107	143	ELIZABETH	121EL	1,172	218.6
108	228	MCDONALD	477MD	1,570	216.2
109	68	CORDREY	327CO	972	213.5
110	331	ELIZABETH	120EL	1,376	210.3
111	360	CHEEK	160CH	461	206.3
112	44	METRO	719ME	1,839	204.7
113	179	CORDREY	324CO	1,578	203.1
114	27	BATSON	53BAT	903	202.3
115	372	WESTSIDE	113WS	294	200.1
116	37	WARREN	506WR	1,427	198.2
117	209	BEVIL	156BE	671	198.1
118	64	VIDOR	164VD	883	196.6
119	110	CRYSTAL	567CR	1,282	196.1
120	88	HIMEX	221HI	109	194.3
121	242	BENTWATER	520BW	1,890	193.8
122	302	KOLBS	37KOL	705	193.5
123	111	DAYTON BULK	724DY	2,193	192.8
124	58	MCHALE	113MC	626	191.1
125	83	LINDBERGH	40LNB	1,612	186.4
126	275	BRIARCLIFF	31BRC	876	182.6
127	43	CLEVELAND (TX)	403CV	1,543	180.7
128	40	SPLENDORA	307SP	1,534	180.3
129	330	PORT ACRES SUB	69PTA	573	174.4
130	46	CRYSTAL	570CR	959	173.6
131	48	SPURLOCK	99SPU	715	172.4
132	274	LAKEVIEW	81LAV	1,293	170.6
133	6	TAMINA	317TA	921	169.6
134	172	KOLBS	36KOL	1,352	167.9
135	149	OILLA	345OI	1,403	166.9
136	190	Alden Bridge	767AL	2,575	166.8
137	182	Alden Bridge	762AL	5,411	165.5
138	170	LACON	537LA	2,085	165.2
139	81	SPLENDORA	308SP	2,398	165.0
140	288	CONROE BULK	506CN	2,117	160.9
141	169	HUMPHREY (TX)	107HM	890	156.7
142	197	NEW CANEY	335NC	2,012	155.1
143	183	BEVIL	155BE	4,050	153.4
144	332	JOHNSTOWN	342JT	687	152.1
145	45	VIDOR	162VD	1,899	152.0
146	286	FORT WORTH	7FTW	1,237	151.6
147	26	LOVELLS LAKE	142LV	353	151.4
148	241	AMELIA BULK	180AM	1,379	147.4

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
149	157	RAYWOOD	73RAY	521	143.9
150	312	VIWAY	681VI	958	143.2
151	90	CONAIR	514CN	1,439	142.3
152	314	PANSY	185PS	1,302	140.9
153	185	SILSBEE	462SI	793	138.8
154	250	APOLLO	321AP	1,171	138.5
155	244	BAYOU FANNETT	250BY	292	138.2
156	174	NECHES	194NE	10	137.2
157	280	SOMERVILLE	126SO	865	136.8
158	180	FORT WORTH	99FTW	367	136.5
159	257	CONROE BULK	572CN	1,364	136.1
160	167	PANORAMA	525PA	1,380	136.0
161	86	KOUNTZE BULK	435KT	49	135.0
162	New	METRO	724ME	507	134.4
163	66	JOHNSTOWN	544JT	2,745	134.1
164	267	ROSEDALE (TX)	152RS	738	133.3
165	121	CONROE BULK	577CN	569	133.3
166	249	NORTH END	21NOE	1,892	132.9
167	106	Alden Bridge	764AL	1,252	131.1
168	207	WYNTEX	632WT	891	130.0
169	308	VIRGINIA	130VI	1,004	129.5
170	361	WESTSIDE	111WS	347	128.1
171	178	ORANGE	352ON	914	126.1
172	63	Alden Bridge	765AL	896	125.2
173	28	MCHALE	112MC	802	124.3
174	194	EASTGATE	781EG	1,018	124.2
175	102	HAMPTON	157HA	12	121.7
176	261	CHEEK	159CH	538	120.0
177	16	CORRIGAN BULK	238CR	609	119.8
178	148	BRIARCLIFF	32BRC	1,259	118.9
179	296	PORT ACRES SUB	67PTA	585	118.4
180	136	LUMBERTON	441LU	4,249	117.2
181	49	METRO	722ME	2,529	117.2
182	315	TANGLEWOOD	136TG	618	116.2
183	282	LONGMIRE	580LM	1,947	115.5
184	199	GROVES-EGSI	63GRO	1,298	115.2
185	263	OAK RIDGE (TX)	741OK	824	114.9
186	92	JOHNSTOWN	345JT	1,467	113.5
187	214	SOMERVILLE	127SO	470	113.1
188	229	HARDIN	35HDN	811	112.2
189	164	NORTH SILSBEE	472NS	338	111.9
190	104	TESCO	36TSC	78	111.2
191	231	DAISETTA	744DA	772	111.0
192	39	WALDEN	563WD	1,886	109.0
193	318	YANKEE DOODLE	23YAN	554	108.9
194	158	SPLENDORA	309SP	1,323	108.8
195	191	AMELIA BULK	182AM	965	108.4
196	79	ADAMS BAYOU	332AD	557	107.8
197	82	LINDBERGH	43LNB	784	107.8
198	238	CALDWELL INDUSTRIAL	138CI	696	107.6
199	146	MCLEWIS	381MC	1,222	106.7

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
200	353	WEST ORANGE	393WO	671	105.9
201	126	PLANTATION (TX)	545PL	1,100	104.4
202	15	KOUNTZE BULK	432KT	850	103.4
203	363	WEST END	86WED	480	103.3
204	162	NEW CANEY	337NC	568	103.2
205	25	CROCKETT	198CR	212	102.9
206	69	CLEVELAND (TX)	406CV	1,374	102.2
207	59	APOLLO	320AP	1,916	101.7
208	65	APRIL	591AP	1,623	100.4
209	74	CORDREY	326CO	1,225	100.0
210	289	PORT ACRES SUB	68PTA	1,263	99.8
211	327	WALDEN	560WD	694	99.1
212	368	TANGLEWOOD	135TG	672	98.7
213	369	JIROU	75JRU	61	98.2
214	271	ROSEDALE (TX)	151RS	1,265	98.0
215	211	MCDONALD	478MD	640	98.0
216	38	KICKAPOO	251KP	1,299	97.6
217	171	FRONT STREET	308FR	370	97.1
218	4	PLANTATION (TX)	546PL	866	97.1
219	112	OAK RIDGE (TX)	744OK	2,835	97.1
220	273	WYNTEX	633WT	611	97.0
221	222	ECHO	72ECH	503	97.0
222	291	TANGLEWOOD	137TG	1,525	96.6
223	125	LONGMIRE	582LM	1,033	95.6
224	216	NORTH SILSBEE	471NS	1,091	95.4
225	23	HUNTSVILLE	608HU	3,182	93.8
226	119	HANKS	25HKS	914	92.5
227	30	EGYPT	551EP	2,379	92.1
228	343	BAYSHORE	211BA	1,045	90.4
229	239	CALVERT	4CAL	2,138	90.1
230	New	PARKWAY	350PW	927	89.6
231	323	HANKS	23HKS	1,300	89.0
232	87	ECHO	73ECH	777	88.4
233	133	DOUCETTE	568DC	593	88.0
234	155	FLETCHER	457FL	1,491	87.8
235	205	ELIZABETH	123EL	2,595	87.3
236	259	LOEB	17LOB	946	85.8
237	130	KOLBS	35KOL	1,092	85.8
238	253	PARKDALE	171PR	705	84.3
239	341	LONGMIRE	581LM	2,242	84.3
240	219	SHEAWILL	536SH	1,303	83.9
241	246	PANSY	184PS	435	80.9
242	346	LINCOLN	16LCN	298	80.4
243	75	MCHALE	110MC	1,041	79.6
244	334	ORANGE	351ON	509	78.8
245	120	FEDERAL	801FE	255	78.0
246	218	NEW CANEY	336NC	4,588	77.8
247	365	STONEGATE	93STG	2,063	77.2
248	294	GOSLIN	706GL	1,502	76.3
249	163	SOUR LAKE	105SL	1,236	75.9
250	255	GOSLIN	707GL	696	74.6

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
251	134	MANCHESTER	67MAN	1,025	74.1
252	265	MERLIN	375MR	863	73.8
253	152	MCHALE	111MC	673	73.7
254	322	CENTRAL	130CE	718	73.4
255	103	BRIDGE CITY	362BD	1,171	73.1
256	159	BRIDGE CITY	363BD	2,041	73.1
257	93	BEVIL	154BE	2,349	71.8
258	20	NEW CANEY	338NC	2,342	70.1
259	300	METRO	720ME	560	69.8
260	114	NEW CANEY	334NC	6,327	68.3
261	227	WINFREE	342WN	1,157	66.8
262	71	HEARNE	25HRN	223	66.4
263	281	CONAIR	511CN	1,608	66.3
264	21	TAMINA	598TA	833	66.3
265	173	OAK RIDGE (TX)	742OK	236	65.9
266	147	ADAMS BAYOU	331AD	194	65.2
267	258	YANKEE DOODLE	22YAN	2,109	63.5
268	188	HANKAMER	206HA	652	63.1
269	84	CALVERT	6CAL	1,591	63.1
270	7	APRIL	592AP	1,094	63.0
271	34	LOVELLS LAKE	141LV	743	61.4
272	260	PORT NECHES	46PTN	1,266	61.2
273	290	WEST END	80WED	274	61.1
274	98	WOODVILLE (TX)	593WD	711	61.0
275	245	HANKAMER	207HA	734	60.6
276	91	KOUNTZE BULK	451KT	1,033	60.2
277	109	FLETCHER	456FL	826	59.7
278	142	MCDONALD	476MD	983	59.3
279	342	JIROU	76JRU	168	57.2
280	175	VIRGINIA	131VI	1,392	56.5
281	221	WALDEN	564WD	2,628	56.0
282	268	SHEAWILL	535SH	678	55.4
283	129	WOODVILLE (TX)	594WD	1,169	55.4
284	371	NORTH END	29NOE	362	55.3
285	254	VIDOR	161VD	608	54.5
286	208	CROCKETT	195CR	981	54.0
287	349	CROCKETT	60CRK	199	53.7
288	202	CONAIR	515CN	1,679	52.7
289	319	STONEGATE	92STG	2,013	52.7
290	270	ORANGE	350ON	944	51.3
291	153	WEST END	85WED	526	50.0
292	243	GOSLIN	709GL	3,642	49.9
293	256	CROWDER	102CD	1,703	47.8
294	358	INDEPENDENCE (TX)	945ID	10	47.8
295	350	CONROE BULK	505CN	1,358	47.6
296	292	CHEEK	165CH	107	47.2
297	225	METRO	721ME	1,496	46.9
298	141	CROWDER	103CD	1,432	46.4
299	187	CONROE BULK	507CN	2,143	46.0
300	160	STONEGATE	91STG	1,368	45.5
301	186	LILLARD	490LI	303	45.2

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
302	132	MCLEWIS	382MC	822	45.1
303	150	HUMPHREY (TX)	106HM	1,119	44.8
304	99	STOWELL	232ST	1,136	42.5
305	295	HANKS	24HKS	841	42.1
306	135	TRANSCO	48TCO	203	40.1
307	333	GROVES-EGSI	62GRO	1,539	38.8
308	217	FORT WORTH	12FTW	1,466	38.6
309	161	CORDREY	325CO	1,553	38.6
310	380	CROCKETT	63CRK	32	37.4
311	336	CONROE BULK	576CN	1,300	37.2
312	356	CENTRAL	131CE	966	36.8
313	287	WEST ORANGE	392WO	630	36.4
314	325	BROOKS CREEK	270BC	51	36.3
315	240	GROVES-EGSI	61GRO	934	34.9
316	293	GOSLIN	705GL	1,278	33.7
317	198	BRIDGE CITY	360BD	1,015	33.2
318	New	RAYWOOD	75RAY	122	32.5
319	67	CROCKETT	64CRK	1,018	31.4
320	181	LINDBERGH	41LNB	1,717	30.6
321	31	SOUR LAKE	104SL	357	30.5
322	339	GOSLIN	703GL	2,152	30.2
323	215	METRO	723ME	699	29.2
324	382	WEST END	87WED	33	29.2
325	124	WINFREE	340WN	456	29.1
326	212	VIRGINIA	129VI	593	28.5
327	128	JIROU	78JRU	309	28.5
328	266	CONROE BULK	574CN	1,598	28.4
329	284	WINFREE	341WN	702	28.2
330	351	Alden Bridge	766AL	1,659	26.9
331	297	TANGLEWOOD	134TG	2,206	26.6
332	324	MANCHESTER	66MAN	2,079	24.6
333	166	METRO	716ME	23	22.7
334	226	CENTRAL	132CE	1,780	22.6
335	116	ADAMS BAYOU	330AD	153	22.5
336	72	WINSHIRE	240WS	931	22.4
337	New	PARKDALE	172PR	20	21.7
338	224	SILSBEE	461SI	535	20.8
339	192	GOSLIN	704GL	1,682	20.7
340	352	CROWDER	105CD	908	20.4
341	337	LINCOLN	15LCN	290	18.6
342	50	DAYTON BULK	727DY	793	17.9
343	307	WESTSIDE	112WS	390	17.8
344	345	MCDONALD	479MD	759	17.3
345	373	GOSLIN	702GL	1,773	17.2
346	New	PARKWAY	782PW	334	15.3
347	320	VIRGINIA	132VI	605	13.5
348	210	EGYPT	550EP	963	13.2
349	144	SPURLOCK	98SPU	720	10.8
350	278	Alden Bridge	763AL	1,163	10.7
351	156	WEST END	88WED	909	10.6
352	328	LONGMIRE	584LM	1,391	10.4

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
353	354	Alden Bridge	768AL	3,488	10.1
354	283	STONEGATE	90STG	1,041	9.4
355	359	ROSEDALE (TX)	150RS	122	8.9
356	344	CONROE BULK	575CN	809	8.3
357	201	CROWDER	104CD	1,600	8.0
358	311	BRIARCLIFF	33BRC	304	7.3
359	370	NORTH END	28NOE	172	6.3
360	70	YANKEE DOODLE	25YAN	172	6.2
361	347	HIMEX	222HI	219	6.0
362	367	MEMORIAL	281ML	745	5.3
363	272	AMELIA BULK	181AM	2,234	5.0
364	383	TRAVIS	8TRV	14	5.0
365	298	MEMORIAL	280ML	934	4.5
366	362	TRAVIS	13TRV	45	4.0
367	376	HEARNE	28HRN	29	3.8
368	200	NAVASOTA	901NA	289	3.8
369	223	NORTH END	26NOE	308	3.5
370	364	GOSLIN	701GL	1,690	2.9
371	95	CONAIR	516CN	278	2.3
372	177	BAYSHORE	212BA	48	2.2
373	189	METRO	717ME	146	2.1
374	New	PARKWAY	351PW	560	1.8
375	348	PARKDALE	176PR	535	0.6
376	317	METRO	718ME	1,314	0.6
377	366	WEST END	82WED	481	0.5
378	24	HUMPHREY (TX)	108HM	45	0.0
379	299	TRAVIS	11TRV	24	0.0
380	374	TRAVIS	14TRV	18	0.0
381	375	NORTH END	27NOE	94	0.0
382	378	WALDEN	562WD	10	0.0
383	379	CONROE BULK	573CN	12	0.0
384	381	TRAVIS	6TRV	29	0.0
385	131	GOSLIN	710GL	960	0.0
386	206	METRO	715ME	29	0.0
387	329	DAISETTA	741DA	170	0.0
388	385	TRAVIS	9TRV	13	0.0
389	386	FAWIL	FAWIL	37	0.0

Service Quality Report to the Public Utility Commission of Texas

Entergy Texas, Inc.

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2015 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	9.30%
Vegetation	22.27%
Animals and Birds	3.39%
People (Including cars and farm equip)	16.07%
Utility-owned Equipment	35.96%
Other	2.98%
Unknown	10.03%