

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1580	2754	BSPSW	0841	2,132	55.35
1581	510	CNI45	2402	808	55.23
1582	1501	LUFKN	1201	1,340	55.22
1583	568	ANDNR	2211	2,504	55.22
1584	1782	MDWCK	0006	886	55.22
1585	897	WMMMR	2707	1,547	55.14
1586	2409	PTENN	2358	1,441	55.11
1587	813	CLBRN	1206	1,036	55.06
1588	512	NCDCH	1206	1,104	54.97
1589	2044	CLYVL	9312	1,281	54.97
1590	414	CRANE	0311	804	54.89
1591	1799	RSNHT	1171	2,299	54.88
1592	757	BRNWD	1204	1,765	54.86
1593	325	TAYLR	1202	1,550	54.80
1594	1268	DENAV	0611	849	54.71
1595	1356	PFLGV	2005	3,719	54.61
1596	1359	MESWE	3621	803	54.50
1597	1223	BOWEN	3151	1,940	54.45
1598	2525	GSTHW	1641	83	54.43
1599	1077	SYCRK	4532	4,076	54.43
1600	1882	WXNTH	2302	1,296	54.41
1601	1927	EULES	8713	2,089	54.37
1602	1942	DENAV	0621	1,698	54.30
1603	350	ESTLD	3621	1,479	54.30
1604	1494	REAST	1505	991	54.25
1605	2140	RWALE	3324	1,494	54.22
1606	1280	GRPVN	8212	4,062	53.94
1607	1827	SSPNG	1202	1,207	53.90
1608	627	BLTLN	0003	589	53.81
1609	2313	MKNGB	5342	1,255	53.69
1610	959	KNEDL	6311	2,813	53.60
1611	2459	PSHIL	1604	1,159	53.57
1612	260	CDHIL	1802	824	53.53
1613	2564	DCVSO	1106	1,202	53.44
1614	2322	KNLTR	0005	2,599	53.42
1615	640	NHNSW	0003	528	53.38
1616	2403	ARLNG	1223	1,822	53.32
1617	2891	DFWNW	2604	11	53.32
1618	2836	GAVSW	0006	525	53.30
1619	1228	LVBRD	0008	1,753	53.28
1620	1867	SMFLD	2392	1,029	53.21
1621	686	RWDHV	1903	1,241	53.18
1622	1676	DAVST	0003	1,652	53.15
1623	852	ARLNG	1292	1,545	53.14
1624	1172	MURPH	2753	1,057	53.11
1625	989	KRUMS	1204	1,418	52.95
1626	2398	EULES	8723	5,166	52.95
1627	2416	ALLEN	2406	2,626	52.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1628	1211	CRLJL	1501	1,458	52.87
1629	459	WNDCR	0211	1,183	52.83
1630	872	WXHCH	1201	1,651	52.66
1631	1967	CRLTR	2004	235	52.64
1632	2848	ALPHA	0009	63	52.63
1633	2197	GLNHV	3963	1,594	52.62
1634	1365	KIMBL	5022	892	52.57
1635	803	EDGCF	2223	3,161	52.54
1636	1610	DUBLN	1360	1,104	52.49
1637	2283	SMFLD	2343	719	52.49
1638	1954	MSLSW	0003	197	52.39
1639	2737	WWDWY	2020	1,232	52.34
1640	485	OAKHL	3072	2,462	52.32
1641	2543	BRHLW	7611	1,621	52.29
1642	1456	PRMED	4401	2,609	52.25
1643	1458	CRLJL	1503	749	52.17
1644	2693	BRNWD	1203	822	52.01
1645	442	GNSVE	1603	1,697	51.93
1646	1106	ADMDS	6521	1,592	51.82
1647	1037	CDCRK	1201	1,238	51.82
1648	1693	MEXIA	4011	1,024	51.81
1649	2279	MDLNW	1552	1,366	51.77
1650	1515	WNRTH	1421	1,475	51.71
1651	674	WTAUG	4612	1,243	51.59
1652	2831	CRLUD	1302	152	51.58
1653	2479	SYCRK	4522	2,807	51.56
1654	2223	RCHHL	0384	709	51.51
1655	1217	TRLNW	1203	683	51.50
1656	2314	GORMN	0421	354	51.47
1657	1139	RECCR	0002	100	51.46
1658	1777	WWDWY	2022	1,023	51.39
1659	2570	CMTSW	0966	125	51.34
1660	2475	FSTVW	0007	1,575	51.32
1661	1742	LKWOD	7432	1,596	51.26
1662	1766	WWDWY	2015	1,182	51.24
1663	2510	MLFRD	2101	959	51.23
1664	312	MRSES	4006	532	51.12
1665	1692	RICES	0206	618	51.07
1666	1084	MOSSW	4621	2,277	51.07
1667	2892	DFWNW	2606	22	51.06
1668	1765	TYLER	1004	182	50.94
1669	2037	FRNKF	0002	943	50.86
1670	1487	CRTLD	4711	3,180	50.82
1671	1046	WTAUG	4611	1,394	50.81
1672	171	FRNKF	0001	961	50.71
1673	2515	SHNRW	1609	1,736	50.69
1674	2373	NAVCO	0001	25	50.61
1675	1564	CRNTH	2403	2,597	50.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1676	274	FRSTN	1604	333	50.55
1677	945	MSHLN	0002	1,574	50.50
1678	2210	DESHR	1204	1,153	50.42
1679	2532	JUDCT	0002	1,399	50.35
1680	1813	WSOTH	1017	1,749	50.29
1681	1840	RCHHL	0311	978	50.26
1682	2119	LIGSW	1604	701	50.22
1683	2580	MKNSW	1603	1,343	50.18
1684	1465	ARTHR	0472	1,289	50.09
1685	2264	CMNCH	1401	1,174	50.06
1686	1811	FROKS	0003	639	50.00
1687	841	KNLTR	0008	899	49.92
1688	520	ARMST	0009	1,082	49.84
1689	1269	MCDMT	2554	1,368	49.81
1690	1092	HLSES	0511	1,757	49.77
1691	1467	TRNTH	1503	1,811	49.74
1692	1069	ABRRD	0004	819	49.59
1693	125	CLBSN	8821	11	49.48
1694	963	RCHHL	0332	1,710	49.44
1695	2442	MRDCK	0002	1,435	49.40
1696	726	ENTOH	0004	2,004	49.33
1697	575	MABNK	2404	2,527	49.32
1698	1162	FLMSO	3716	2,098	49.23
1699	2116	CMTSW	0973	1,185	49.14
1700	2487	CMTSW	0983	859	49.12
1701	780	ROLTR	2922	2,401	49.08
1702	1067	LWSNR	2232	2,243	49.08
1703	1985	FINKS	1801	1,562	49.05
1704	2810	CRLTN	1404	100	48.95
1705	888	TMPNW	1104	1,931	48.91
1706	1855	ALLEN	2404	2,047	48.89
1707	2147	SWTWR	1382	454	48.89
1708	1918	TLRWT	2201	1,740	48.88
1709	1658	DAVIS	3741	1,228	48.82
1710	2073	STAUG	0001	705	48.80
1711	2184	WXNTH	2308	827	48.69
1712	1137	PSHIL	1608	1,944	48.49
1713	2280	GRDPR	0881	2,386	48.46
1714	1475	RCLNS	1404	712	48.38
1715	528	FSCRK	6732	3,770	48.38
1716	1542	LKMNT	0003	598	48.31
1717	2317	WXHCH	1203	1,255	48.31
1718	2036	GODRD	8132	2,679	48.17
1719	2380	ELKTN	2502	1,435	48.12
1720	1843	LMESA	1522	1,351	48.08
1721	2921	PALMR	2201	54	48.07
1722	140	THRDN	1901	1,687	47.78
1723	1140	MDLNW	1541	2,290	47.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1724	496	KEENE	1501	1,561	47.72
1725	1970	VLRYN	2953	2,842	47.63
1726	1754	PRKWY	1521	2,303	47.62
1727	1871	BDFRD	8821	879	47.58
1728	1524	CDHIL	1803	1,815	47.45
1729	1299	DAVIS	3721	1,330	47.39
1730	753	KLBRG	0001	381	47.38
1731	2217	FINKS	1804	2,271	47.38
1732	2450	ALPHA	0002	1,261	47.31
1733	2465	DALWT	2972	240	47.30
1734	2018	WCOLO	1318	1,643	47.28
1735	1476	COPEL	3053	2,064	47.22
1736	1583	MCWHT	3522	2,959	47.21
1737	1594	BDFRD	8842	1,465	47.14
1738	1065	MRVLY	2311	371	47.14
1739	941	SANSM	3923	3,723	47.12
1740	283	PWEST	1303	923	47.02
1741	2151	SHNRW	1612	812	47.02
1742	257	PKRMX	4703	2,954	46.95
1743	1681	PAYSW	1205	730	46.91
1744	2143	ARMST	0001	280	46.81
1745	2222	HMPHL	2781	232	46.75
1746	1851	ROWLT	1103	1,087	46.74
1747	661	ALNTH	2854	661	46.71
1748	367	FRMBG	1707	450	46.57
1749	453	RWDHV	1907	887	46.56
1750	417	DIBOL	1506	614	46.48
1751	2877	ALPHA	0001	425	46.43
1752	2882	CLBNR	1401	22	46.38
1753	1790	BDFWD	8932	1,706	46.36
1754	231	CLKVL	1203	603	46.36
1755	1473	DUVAL	0434	2,465	46.35
1756	862	CNSES	0370	1,103	46.29
1757	2175	DNINR	1403	1,188	46.26
1758	2185	MCDMT	2532	1,980	46.22
1759	338	GRLRD	0004	1,555	46.13
1760	2339	MCKMY	0811	2,194	46.10
1761	2500	BLMED	1620	1,992	46.04
1762	469	BLKST	1762	1,015	46.01
1763	2514	DAVIS	3731	768	45.94
1764	1818	FORSW	2051	3,546	45.92
1765	1735	WEAST	0629	1,776	45.86
1766	1845	LIPAN	1301	510	45.85
1767	2583	ATHNW	1401	905	45.81
1768	1687	ROLTR	2911	1,812	45.72
1769	1489	RWALS	1851	1,538	45.71
1770	899	MDTHN	1702	1,831	45.70
1771	917	HHSTH	1502	3,649	45.48

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1772	1956	FSTVW	0008	1,797	45.48
1773	1062	RKDLN	1401	934	45.41
1774	2839	RENSW	3122	1,355	45.37
1775	1260	GRDPR	0852	1,426	45.36
1776	581	ANDNR	2231	1,101	45.36
1777	735	PFFRD	3472	1,275	45.35
1778	743	LKHLD	0007	1,215	45.10
1779	1752	NSTAR	2011	521	45.10
1780	1734	GRAHM	0711	1,644	45.09
1781	921	LVOAK	1601	843	45.05
1782	721	LEMON	0008	804	45.04
1783	1426	CRLTR	2052	1,576	45.02
1784	2615	HURST	1841	998	44.95
1785	1793	SGOVL	1401	1,818	44.93
1786	835	TYOMN	1402	1,611	44.92
1787	2224	FSTVW	0006	1,239	44.86
1788	1696	HKHTS	1604	864	44.80
1789	969	FRMBR	1801	1,246	44.80
1790	1425	WNTHW	1116	665	44.59
1791	1072	CPRCV	1404	1,595	44.59
1792	1498	CNTRY	2824	3,094	44.59
1793	2292	ROWLT	1101	1,258	44.56
1794	105	GODRD	8112	1,426	44.55
1795	383	MRTNS	1501	489	44.54
1796	2358	KLNSO	4502	2,905	44.53
1797	1720	TATSP	4322	2,498	44.34
1798	1008	WNTHW	1119	1,322	44.30
1799	1135	HORNE	1913	1,667	44.28
1800	2153	IRVBL	2502	182	44.24
1801	2357	RNKSU	5412	27	44.14
1802	400	KNLTR	0003	608	44.12
1803	881	HURST	1861	1,846	44.12
1804	1028	GODRD	8142	1,039	44.11
1805	832	DNIWS	1603	1,354	44.01
1806	N/A	TYLNU	1912	2,074	43.99
1807	776	BNBRK	4122	2,564	43.91
1808	1968	LOMAL	0005	398	43.89
1809	800	VENSW	2601	1,368	43.88
1810	2002	MESQN	1501	1,792	43.84
1811	738	KNEDL	6322	3,856	43.76
1812	1984	MDLNU	1521	1,800	43.72
1813	2445	SMFLD	2372	634	43.71
1814	1672	BRCRK	6523	873	43.65
1815	702	FRMBG	1705	281	43.65
1816	1770	DUVAL	0473	1,576	43.62
1817	1850	FORSN	5611	12	43.59
1818	1555	TYSTH	1208	242	43.56
1819	2618	OKCLS	0003	1,504	43.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1820	1796	DCVSO	1101	1,470	43.46
1821	1146	WHTRK	0008	1,508	43.40
1822	2338	EZACH	0007	1,585	43.39
1823	2670	RRNES	2402	3,707	43.37
1824	1645	EULES	8712	1,070	43.36
1825	1195	STAUG	0002	1,389	43.18
1826	1839	GODRD	8151	800	43.16
1827	2120	BLKST	1781	1,924	43.12
1828	2554	EDGCF	2262	879	43.11
1829	2190	BSPRG	1902	2,395	43.08
1830	114	CPLND	1101	1,021	43.08
1831	977	WXNTH	2304	856	43.06
1832	1419	MAYFD	5521	3,217	42.93
1833	1279	CLBNR	1404	1,337	42.93
1834	239	RDLML	2591	1,621	42.88
1835	2505	KIMBL	5032	1,692	42.80
1836	1549	MDWPK	9231	2,422	42.65
1837	1130	BRNSO	1806	1,771	42.55
1838	53	FRMBG	1704	35	42.45
1839	2634	LFSTH	1402	1,197	42.41
1840	1730	OAKHL	3021	1,981	42.39
1841	1947	DAVST	0005	1,826	42.38
1842	768	IRVBL	2503	1,402	42.34
1843	509	CRNRD	0001	732	42.34
1844	1183	LKHL	0003	1,339	42.33
1845	1751	CDHIL	1804	1,188	42.24
1846	1157	RDOAK	1302	1,232	42.21
1847	826	EZACH	0004	1,168	42.19
1848	2381	SIKES	2421	1,833	42.15
1849	2461	CHROW	0003	156	42.00
1850	1705	CRTLD	4742	918	41.97
1851	2226	WCOLO	1317	1,254	41.89
1852	1577	IRVVV	2801	2,393	41.83
1853	744	BNTDR	0004	1,786	41.82
1854	788	LOMAL	0012	686	41.79
1855	1623	TYBLR	2801	1,240	41.77
1856	1914	ALPHA	0007	1,457	41.75
1857	617	CRYVE	3011	288	41.74
1858	1439	CLBWS	8111	1,648	41.72
1859	2172	PCOIT	1002	673	41.71
1860	1569	HURST	1882	1,902	41.64
1861	2060	IRVND	1201	965	41.64
1862	633	JKSBR	1401	775	41.61
1863	914	DENAV	0683	885	41.61
1864	2469	MESTE	1215	1,511	41.47
1865	621	BRKRG	0223	287	41.45
1866	622	ELKHR	1201	958	41.32
1867	475	DALRK	1358	1,815	41.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1868	2014	WXNTH	2306	2,163	41.12
1869	746	CPLSO	4312	1,739	41.11
1870	1023	CRLTR	2003	1,354	41.09
1871	1026	IRVGS	1907	797	41.09
1872	998	MCWHT	3512	796	41.08
1873	2494	RGLRW	0005	52	41.00
1874	2079	BRCRK	6511	1,269	41.00
1875	844	WHITE	3542	1,659	40.98
1876	1335	CRLUD	1304	1,497	40.98
1877	794	THRNE	0008	2,222	40.94
1878	273	BLMED	1617	315	40.94
1879	980	PCUST	2001	580	40.87
1880	2584	WCOLO	1315	1,611	40.77
1881	2253	DFWNW	2610	59	40.76
1882	975	ODNTH	2033	677	40.70
1883	1763	LVOAK	1602	909	40.67
1884	389	DEALY	0002	1,417	40.66
1885	1728	PRKRW	3352	1,530	40.64
1886	460	CHROW	0002	112	40.60
1887	643	BDFWD	8931	1,727	40.59
1888	2517	ALLEN	2410	2,334	40.58
1889	1118	WITTS	1705	1,336	40.56
1890	1802	SSPNG	1201	1,307	40.53
1891	2432	TMPTV	2404	1,424	40.49
1892	N/A	CHNDW	1203	825	40.43
1893	487	CRLTR	2002	1,478	40.42
1894	N/A	MKNGB	5311	1,617	40.30
1895	1697	BLMED	1619	1,025	40.26
1896	624	TMSTH	1408	759	40.21
1897	2934	TMNTH	1607	10	40.14
1898	1842	FRMBR	1803	2,406	40.11
1899	1444	IRVNG	1405	1,154	40.06
1900	2103	CLLVL	0004	54	40.00
1901	2817	LEMON	0009	1,741	39.94
1902	599	ARTHR	0431	460	39.92
1903	700	MOSSW	4611	1,559	39.87
1904	2299	DESPR	1408	1,919	39.86
1905	1480	HKHTS	1601	1,505	39.84
1906	1640	SMFLD	2333	1,059	39.78
1907	747	HKHTS	1607	947	39.70
1908	1436	TRNTH	1504	775	39.66
1909	1234	ODESA	0261	1,474	39.58
1910	2038	CRNTH	2404	2,352	39.56
1911	1049	BRNSO	1807	560	39.55
1912	1175	CMNCH	1402	1,151	39.54
1913	1213	SWTWR	1321	139	39.53
1914	2464	WND CR	0262	231	39.43
1915	2369	MTLDA	0006	1,910	39.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1916	1009	MDTHS	1002	1,182	39.25
1917	2234	CNTRY	2862	400	39.22
1918	N/A	SFTLK	4021	42	39.15
1919	2587	RECCR	0006	502	39.12
1920	2828	DGNST	0006	1,093	39.11
1921	2296	RDLML	2552	280	39.09
1922	2347	LOMAL	0016	648	39.02
1923	1602	DAVIS	3711	678	38.99
1924	1322	IRVNE	1309	1,126	38.94
1925	1628	DNIWS	1602	1,419	38.90
1926	1835	WSTHL	3642	4,072	38.90
1927	1098	ELGIN	1003	2,058	38.85
1928	2359	WHITE	3521	1,119	38.82
1929	1522	GRDPR	0891	894	38.75
1930	1771	WHITE	3522	1,809	38.72
1931	1878	RECCR	0004	71	38.56
1932	1689	SBEND	0611	173	38.55
1933	1677	WTAUG	4643	996	38.52
1934	573	KRUMS	1203	789	38.52
1935	2741	PJPTR	3212	26	38.47
1936	1999	WMRLD	0005	1,605	38.41
1937	1792	PSHIL	1603	1,548	38.41
1938	2563	ELZCK	4921	1,716	38.40
1939	1105	DESHR	1203	1,381	38.37
1940	1461	LIGSW	1607	1,426	38.37
1941	412	ENSSO	2003	506	38.35
1942	1890	SHRSW	6631	1,291	38.33
1943	2167	BSPRG	1905	1,608	38.28
1944	2353	BRCRK	6533	1,806	38.25
1945	2203	FROKS	0002	1,547	38.04
1946	1688	COPER	1202	973	38.03
1947	2558	LKBLT	2107	1,070	38.03
1948	704	DEALY	0004	1,998	38.01
1949	1126	MESQN	1505	1,417	37.93
1950	2463	CLLVL	0006	1,212	37.87
1951	1358	KLNTF	1805	1,255	37.86
1952	877	RCHHL	0321	1,740	37.83
1953	1398	MESQW	1804	1,326	37.82
1954	733	HMTRD	0001	965	37.82
1955	61	WOVER	6131	2,114	37.68
1956	2418	STAUG	0004	2,079	37.53
1957	326	IRVNR	1553	1,335	37.47
1958	677	PCUST	2003	1,026	37.42
1959	886	FARON	4041	1,022	37.39
1960	315	HUTTO	2742	4,072	37.34
1961	854	BLTLN	0005	880	37.34
1962	1807	BLTSW	3203	888	37.31
1963	1017	DUVAL	0483	2,238	37.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
1964	465	COMRC	1203	675	37.25
1965	1753	GRHWY	5522	2,328	37.15
1966	2620	SMFLD	2352	602	37.02
1967	1152	WNTHW	1120	1,028	36.96
1968	390	OVRTN	4015	620	36.93
1969	2092	PRSTN	0004	673	36.89
1970	946	PFLGV	2003	3,934	36.89
1971	2717	GVGLF	9601	48	36.85
1972	2607	WWEST	1222	170	36.77
1973	839	GRHWY	5512	2,523	36.76
1974	102	COPEL	3056	2,708	36.73
1975	1160	INAIR	1423	228	36.72
1976	692	CMPWI	0001	1,877	36.68
1977	1216	MESTE	1207	951	36.66
1978	2677	LTVSB	5451	1,229	36.64
1979	1654	MDWPK	9241	1,537	36.62
1980	1376	PCUST	2005	1,717	36.60
1981	2095	PWEST	1304	1,614	36.59
1982	1922	CNTRD	0001	2,115	36.56
1983	2331	NPKWY	0008	879	36.51
1984	1435	TMSTH	1401	1,827	36.49
1985	2034	WELRD	0006	730	36.47
1986	1485	PLSTH	1305	511	36.45
1987	2024	WRTHM	5004	228	36.44
1988	997	KLRPR	9021	2,005	36.40
1989	1834	KEENE	1503	829	36.39
1990	1367	LUFKN	1205	1,343	36.39
1991	1129	MAYFD	5522	3,238	36.29
1992	1375	WNDWD	3611	294	36.25
1993	2284	DGNST	0002	477	36.24
1994	1620	WHTRK	0006	1,299	36.24
1995	71	CMTSW	0916	548	36.12
1996	2237	KLNPS	1102	1,865	36.10
1997	1270	WNDWD	3641	1,265	36.01
1998	1459	CLBRN	1203	1,572	36.00
1999	2341	LIPAN	1303	269	35.96
2000	2593	BLTON	1801	844	35.92
2001	950	BKBNT	1821	1,142	35.91
2002	2685	FRMBR	1802	1,116	35.82
2003	246	IRVNR	1505	1,317	35.74
2004	1085	NCDCH	1203	1,795	35.73
2005	916	LNCST	1601	684	35.65
2006	2901	FRMBG	1706	62	35.60
2007	1103	MSHLN	0005	503	35.56
2008	1948	WMRNR	0002	431	35.56
2009	2144	PRFTW	4212	2,001	35.55
2010	1259	CRNRD	0006	346	35.47
2011	2629	SIKES	2411	2,051	35.29

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2012	1686	MSHLN	0007	718	35.23
2013	1334	CDHCR	2050	809	35.21
2014	2585	TRNTY	7511	1,436	35.15
2015	1161	WEAST	0615	424	35.13
2016	2318	CLLVL	0001	13	35.00
2017	1745	SUNNY	2301	609	34.96
2018	2128	GRPVN	8222	2,046	34.91
2019	695	NCDCH	1202	1,033	34.89
2020	517	LOMAL	0014	588	34.88
2021	458	SCYEN	0004	1,234	34.76
2022	1303	NCSTH	1504	65	34.74
2023	2431	FSTVW	0004	2,217	34.70
2024	2204	DNINR	1402	564	34.62
2025	2541	BLMED	1621	2,045	34.61
2026	2533	LEMON	0006	718	34.59
2027	2594	ARMST	0012	1,084	34.42
2028	696	ACRLY	1711	174	34.42
2029	2405	DLEON	0131	730	34.42
2030	N/A	WNDWD	3682	989	34.41
2031	370	RSPCK	2142	931	34.33
2032	486	ALDTU	9411	2,305	34.28
2033	1482	BSPRG	1903	1,676	34.23
2034	848	DNCNV	1903	1,194	34.21
2035	825	RSNHT	1122	2,015	34.03
2036	2290	KNEDL	6342	2,119	33.98
2037	1341	BLKST	1721	1,026	33.96
2038	1529	OKCLS	0005	140	33.96
2039	1204	FROKS	0005	1,396	33.85
2040	2340	LWSNR	2241	1,083	33.83
2041	1112	PLGRV	0002	2,320	33.83
2042	1711	BOWEN	3132	1,775	33.82
2043	1355	NHNSW	0008	583	33.81
2044	785	BEAST	4088	122	33.81
2045	132	EDGCF	2241	925	33.74
2046	850	NPKWY	0014	6,098	33.73
2047	698	ATNRN	3421	1,581	33.70
2048	2157	WDGWD	1512	826	33.55
2049	1086	HSKAV	0002	1,715	33.51
2050	1440	WEBBS	8633	2,215	33.49
2051	1391	DUVAL	0414	649	33.43
2052	2852	ALLEN	2401	455	33.40
2053	2219	CRLTN	1401	803	33.33
2054	1263	ELGIN	1002	2,568	33.32
2055	1685	GPLND	1202	405	33.26
2056	2122	BSPRG	1901	584	33.20
2057	1659	WWDWY	2024	1,427	33.19
2058	2799	AMLIA	0006	77	33.18
2059	498	STAUG	0003	2,029	33.05

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2060	836	BRHLW	7632	1,481	33.03
2061	339	GRLWS	1704	171	33.02
2062	1930	RCLNS	1407	1,384	32.97
2063	1149	EDGCF	2282	1,044	32.97
2064	2715	MESFR	2105	1,046	32.94
2065	1866	SHNRW	1611	975	32.93
2066	1241	EULSO	9132	1,945	32.91
2067	364	LEMON	0004	574	32.90
2068	824	ATHNW	1405	892	32.80
2069	1585	STAUG	0008	2,049	32.76
2070	393	MSLSW	0001	1,145	32.76
2071	642	IRVBL	2501	389	32.73
2072	255	HOLDY	0921	613	32.66
2073	2530	CKRHL	0008	1,667	32.62
2074	1591	TRNTY	7551	1,502	32.60
2075	2132	GODRD	8122	1,041	32.55
2076	2802	ABRRD	0006	449	32.55
2077	1635	DUVAL	0421	1,264	32.54
2078	1714	CRNTH	2405	3,917	32.48
2079	2860	CRNRD	0005	360	32.46
2080	1371	LAVON	1454	2,895	32.45
2081	736	EZACH	0005	543	32.44
2082	1989	TYLER	1002	860	32.43
2083	472	MCGRG	0775	527	32.41
2084	715	SWDTN	1631	1,625	32.41
2085	514	MLKF2	1202	446	32.35
2086	1706	ARLNG	1232	1,271	32.30
2087	2720	TYLGE	1314	900	32.27
2088	1113	ADISN	1605	1,104	32.27
2089	2565	PCOIT	1023	639	32.25
2090	1518	ARTHR	0452	683	32.14
2091	2076	WKATY	1718	2,190	32.12
2092	682	HORNE	1992	229	32.10
2093	1903	CRSGL	1302	1,473	32.06
2094	1868	REAST	1504	1,314	32.01
2095	376	SANSM	3922	1,765	32.01
2096	1772	BLTLN	0004	634	31.94
2097	994	TATSP	4312	2,506	31.90
2098	2721	TYLER	1001	154	31.84
2099	2202	SHLMT	1801	303	31.75
2100	798	COMSO	1405	761	31.71
2101	905	TMPLE	1205	2,472	31.67
2102	2798	PWEST	1310	684	31.67
2103	424	SALSW	3001	1,381	31.66
2104	118	HLSES	0522	1,745	31.63
2105	1271	ALNTH	2844	1,966	31.60
2106	1351	WNDWD	3621	2,151	31.60
2107	1767	CLBRN	1201	1,744	31.58

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2108	1916	TMSTH	1404	1,318	31.56
2109	529	WATSN	5361	2,526	31.54
2110	2407	WEBBS	8611	2,599	31.53
2111	1701	GSTHW	1633	950	31.49
2112	943	HSKAV	0004	1,306	31.49
2113	1741	LKWOD	7411	631	31.49
2114	543	FSCRK	6712	2,538	31.42
2115	2516	WWEST	1218	1,007	31.42
2116	1277	CKRHL	0001	417	31.42
2117	828	OAKHL	3082	1,430	31.35
2118	2608	MESTE	1209	1,447	31.31
2119	2016	EULES	8711	2,048	31.27
2120	2300	CRLUD	1303	642	31.26
2121	291	BRNAV	0784	1,885	31.21
2122	2827	ROLTR	2913	1,342	31.20
2123	2440	HHSTH	1504	2,266	31.19
2124	2251	VGCRK	8011	1,527	31.18
2125	2029	MTLDA	0005	1,567	31.13
2126	97	CLBWS	8121	258	31.07
2127	1825	CRSWS	1403	1,816	31.06
2128	1238	PLKST	0003	1,303	31.03
2129	1210	WSTHL	3613	3,347	30.98
2130	2668	PLKST	0001	783	30.93
2131	1310	LOMAL	0010	1,557	30.91
2132	2233	HKHTS	1602	1,017	30.89
2133	2638	RWDHV	1908	2,179	30.82
2134	N/A	LKBLT	2102	2,207	30.82
2135	1044	RCLNS	1405	640	30.79
2136	574	MSTLT	1021	1,283	30.78
2137	701	KLBRG	0002	1,686	30.73
2138	2609	DLEON	0111	830	30.68
2139	2344	BKBNT	1842	545	30.68
2140	2610	HKHTS	1608	1,315	30.64
2141	356	CLYVL	9311	1,855	30.61
2142	1781	ARLNG	1213	1,325	30.59
2143	1648	JUDCT	0006	1,201	30.48
2144	2135	TYLGE	1308	1,562	30.48
2145	1666	SMFLD	2391	289	30.38
2146	1977	MRSES	4012	401	30.34
2147	1820	HSKAV	0003	1,416	30.26
2148	741	PLANO	1104	996	30.26
2149	60	GNSVL	1203	1,623	30.26
2150	2269	RSPCK	2141	19	30.24
2151	1958	CRLTN	1403	200	30.22
2152	N/A	WNDWD	3662	894	30.16
2153	1193	HORNE	1991	1,472	30.14
2154	2152	WDGWD	1513	861	30.09
2155	2046	ADISN	1601	637	30.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2156	2590	RGLRW	0001	34	30.04
2157	1043	FHLSW	1311	1,392	29.97
2158	1537	CRSCN	1201	830	29.94
2159	1945	KLNPS	1105	1,548	29.93
2160	995	MESFR	2101	2,018	29.91
2161	1075	RSPVY	1706	1,341	29.91
2162	2189	MESWE	3611	1,915	29.88
2163	1568	CHSPG	2401	3,578	29.84
2164	990	MCGHR	2003	1,261	29.80
2165	2023	ENNIS	1904	1,266	29.77
2166	1923	EDGCF	2231	817	29.77
2167	1177	CPRCV	1406	1,633	29.74
2168	2393	THRNE	0002	1,610	29.68
2169	1723	GSTHW	1692	813	29.66
2170	2286	PSHIL	1601	1,408	29.64
2171	1492	CLCTY	1031	1,237	29.63
2172	958	SSPSW	1604	1,205	29.62
2173	1995	PROAD	0002	841	29.61
2174	28	PGSTH	7011	134	29.40
2175	1014	GNSVL	1205	871	29.36
2176	2586	FSHSW	2111	315	29.30
2177	2794	CLBNR	1407	264	29.20
2178	1619	HLSBR	1203	1,121	29.12
2179	182	BNBRK	4111	2,883	29.08
2180	1346	LOMAL	0007	146	29.08
2181	606	ENNIS	1903	1,371	29.08
2182	1844	PCOIT	1003	1,510	29.04
2183	2126	TMPNW	1101	2,586	28.98
2184	2943	WWEST	1221	37	28.96
2185	2047	TRLNW	1204	581	28.95
2186	507	CRYVE	3021	1,274	28.94
2187	2263	SACRC	5521	120	28.88
2188	2546	ALNTH	2851	2,101	28.72
2189	2366	BLTLN	0001	675	28.71
2190	2150	DAVST	0001	573	28.69
2191	1349	WTAUG	4631	1,150	28.66
2192	2560	JNKNS	0003	1,063	28.65
2193	2415	COMRC	1201	997	28.61
2194	2106	RWDHV	1902	966	28.58
2195	1021	PNTGO	7112	740	28.46
2196	767	DCDAM	2002	868	28.42
2197	1276	MEXIA	4024	348	28.37
2198	1817	MYPRL	1803	588	28.37
2199	909	COPEL	3052	1,310	28.36
2200	610	EULSO	9122	1,311	28.35
2201	611	BDFRD	8831	870	28.32
2202	1774	GNSVN	1403	293	28.20
2203	1286	PKRVL	1051	4,564	28.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2204	1713	SALSW	3004	1,313	28.15
2205	2074	SWDTN	1641	1,588	28.09
2206	1634	MESQW	1807	1,496	28.04
2207	1430	OKCLS	0006	1,675	27.99
2208	2094	MKNNY	1201	1,311	27.99
2209	1383	DNISN	1202	802	27.89
2210	878	GAVSW	0009	1,023	27.79
2211	2722	MYPRL	1801	155	27.72
2212	1716	PRCTR	1602	229	27.69
2213	2567	DFWSW	2204	24	27.64
2214	2894	DFWSW	2209	16	27.46
2215	947	WNTHW	1118	1,519	27.44
2216	666	SHAMP	0004	1,140	27.39
2217	1331	MSTLT	1063	972	27.33
2218	1427	AIRPK	8411	806	27.32
2219	1863	WSANG	2802	637	27.29
2220	2918	MRSES	3019	13	27.29
2221	912	BDFRD	8812	776	27.27
2222	2163	FARON	4082	1,589	27.27
2223	1209	TMPNW	1105	803	27.22
2224	1987	RCHHL	0374	537	27.20
2225	944	GRDPR	0892	1,323	27.18
2226	2727	BDFWD	8911	937	27.10
2227	1443	WOVER	6122	1,692	27.05
2228	1232	INAIR	1413	2,408	27.00
2229	2171	ARMST	0005	1,516	26.96
2230	321	MNWLL	1204	279	26.88
2231	1060	KLNPS	1103	2,139	26.87
2232	778	SMFLD	2311	1,347	26.85
2233	2706	LMBLN	0003	177	26.82
2234	2881	CHROW	0007	84	26.75
2235	831	NMAIN	0211	1,922	26.74
2236	2241	CRTLD	4721	3,049	26.71
2237	1324	PALRD	2204	682	26.66
2238	1168	RCHHL	0353	1,716	26.63
2239	2652	CKRHL	0003	440	26.63
2240	2744	BRKRG	0211	313	26.62
2241	1237	RANGR	4311	916	26.57
2242	195	CRLTN	1408	116	26.56
2243	1978	MDLNW	1564	1,278	26.55
2244	2688	WATSN	5342	2,025	26.47
2245	1132	GLNHV	3911	1,357	26.42
2246	2406	COPER	0402	164	26.35
2247	2890	DFWNW	2603	12	26.33
2248	2673	DGNST	0005	147	26.21
2249	421	ODESA	0221	255	26.17
2250	1579	RSPVY	1704	1,400	26.16
2251	2764	BRKRG	0213	417	26.12

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2252	2441	TYOMN	1411	310	26.09
2253	1565	GAVSW	0007	1,522	26.08
2254	2064	RNDRK	1504	989	26.07
2255	2588	SHSTH	1301	2,190	26.04
2256	616	TYLGE	1316	2,823	25.99
2257	1434	CRLTN	1402	805	25.99
2258	2262	EDGCF	2211	2,106	25.96
2259	2457	KLNTF	1802	846	25.94
2260	1563	KLNTF	1801	1,193	25.92
2261	670	EULSO	9131	1,972	25.90
2262	1466	GSTHW	1623	2,488	25.82
2263	1570	FSHSW	2121	1,693	25.81
2264	2294	ELKTN	2501	710	25.70
2265	2606	LOMAL	0002	511	25.69
2266	2929	RRWES	1603	11	25.69
2267	1302	CRNRD	0004	475	25.62
2268	2247	CRTLD	4723	2,318	25.57
2269	2625	JKREA	1201	30	25.56
2270	1274	NCSFA	1702	1,294	25.56
2271	2020	DNISN	1201	1,449	25.53
2272	2537	PSHIL	1607	457	25.52
2273	2524	RRNES	2403	4,856	25.48
2274	2068	SMFLD	2341	947	25.41
2275	2568	CRSWS	1401	1,354	25.40
2276	561	FORSW	2015	2,298	25.39
2277	1788	TLRWT	2203	814	25.34
2278	2365	IRASB	3211	275	25.31
2279	1284	DNCNV	1905	1,323	25.28
2280	2080	WALST	0011	742	25.26
2281	802	BRLSN	2033	1,661	25.25
2282	2087	EULTB	5731	476	25.24
2283	461	JKSNR	4111	442	25.23
2284	1165	ARMST	0011	900	25.10
2285	2745	SCHRD	0004	1,916	25.09
2286	752	MDWCK	0004	1,715	24.96
2287	1314	PRKWY	1532	2,118	24.96
2288	235	PTENN	2351	1,547	24.86
2289	2270	RNDRK	1505	1,316	24.78
2290	2277	BRNWD	1201	1,567	24.77
2291	1748	CPRCV	1407	2,193	24.74
2292	1215	WITTS	1703	1,549	24.66
2293	1667	MESTE	1208	992	24.65
2294	2868	PSHIL	1606	997	24.57
2295	1951	PALRD	2207	1,119	24.57
2296	306	MESFR	2104	154	24.52
2297	1445	IRVNR	1551	1,363	24.50
2298	2267	RSPCK	2132	66	24.46
2299	2648	WND CR	0232	650	24.46

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2300	1257	CHROW	0006	80	24.44
2301	2509	BRLSN	2023	1,829	24.39
2302	2071	PLSTH	1303	572	24.29
2303	786	PLKST	0004	1,177	24.22
2304	1519	GLNHV	3983	1,668	24.21
2305	2360	EDGCF	2272	1,080	24.18
2306	2188	FROKS	0008	1,514	24.17
2307	2000	RANGR	4321	861	24.15
2308	1901	LKHL	0008	1,151	24.13
2309	2195	TATSP	4321	1,444	24.12
2310	590	SNYDR	1852	1,363	24.11
2311	2194	CMTSW	0927	560	24.11
2312	1063	THRNE	0001	1,762	24.08
2313	1950	ARLNG	1261	1,407	24.00
2314	2086	MKNGB	5331	1,442	23.98
2315	2372	WFALS	0174	1,219	23.96
2316	1664	SYCRK	4512	3,940	23.92
2317	2273	CLYVL	9323	1,417	23.89
2318	2907	HMPHL	2723	52	23.88
2319	1013	ROLTR	2921	2,583	23.72
2320	1993	DGNST	0003	711	23.67
2321	1019	BDFWD	8941	1,217	23.60
2322	2657	FORSW	2025	544	23.57
2323	2705	ARLNG	1251	545	23.56
2324	2354	FSTVW	0005	1,749	23.53
2325	1642	GNSVL	1204	506	23.52
2326	1281	SNYDR	1833	1,440	23.50
2327	2694	CRNDL	2401	509	23.48
2328	647	SSPNG	1204	970	23.46
2329	317	WTAUG	4633	1,046	23.46
2330	1904	STNVL	1204	839	23.46
2331	2446	SPRTN	1802	863	23.34
2332	2350	BLMGR	1902	178	23.31
2333	2832	ABRRD	0008	1,435	23.27
2334	1354	RNDRK	1508	3,990	23.24
2335	2272	WALNT	0002	1,217	23.23
2336	2049	ALNTH	2853	2,970	23.22
2337	2348	MESTE	1213	989	23.21
2338	106	RDLML	2532	1,779	23.20
2339	1606	RDOAK	1303	2,194	23.09
2340	887	COTRD	0003	110	23.07
2341	1856	MTLDA	0007	1,746	23.06
2342	1647	IRVNR	1555	3,794	22.89
2343	2257	WRBND	2322	884	22.88
2344	773	PROAD	0007	416	22.88
2345	2938	WALST	0006	10	22.86
2346	2529	ELMGV	3651	2,093	22.83
2347	2486	COMSO	1402	934	22.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2348	2496	ABBOT	1902	120	22.76
2349	1556	LKHL	0004	1,256	22.69
2350	1831	WNTHW	1121	745	22.58
2351	849	HORNE	1933	1,997	22.56
2352	492	HSKAV	0008	791	22.51
2353	1710	WTHRE	2101	1,221	22.47
2354	272	DUVAL	0462	1,043	22.38
2355	1399	BRNSO	1801	1,590	22.32
2356	340	CPRCV	1403	1,444	22.32
2357	409	MCKMY	0822	1,384	22.31
2358	1171	PRSTN	0003	2,957	22.30
2359	1573	MESTE	1203	175	22.24
2360	495	HORNE	1972	763	22.20
2361	2377	THSES	2402	1,378	22.20
2362	1315	IRVVV	2851	2,964	22.19
2363	307	PALMR	2202	1,029	22.13
2364	2225	NMAIN	0272	455	22.02
2365	1527	ODNTH	2053	2,367	22.02
2366	2633	WMRLD	0006	593	21.93
2367	566	LTVSB	5461	790	21.86
2368	1316	BRNSO	1805	803	21.84
2369	2573	SHSTH	1302	20	21.71
2370	N/A	GRPTT	9921	575	21.67
2371	2552	ARTHR	0422	1,065	21.63
2372	456	NMAIN	0231	316	21.62
2373	795	DEALY	0003	1,776	21.60
2374	2769	IRLBJ	3211	2,617	21.58
2375	2042	WELRD	0003	514	21.54
2376	311	ARCTY	1321	884	21.41
2377	1339	BRNSO	1808	779	21.41
2378	662	GLNHV	3992	1,104	21.40
2379	1148	MURPH	2756	3,466	21.38
2380	2243	RDRSE	2603	3,681	21.38
2381	1387	WSTHL	3631	3,751	21.37
2382	650	BRKRG	0242	24	21.31
2383	1219	GVODS	3011	2,288	21.22
2384	1847	RCHRD	1202	795	21.21
2385	2703	MESQN	1507	696	21.09
2386	2612	KNEDL	6332	2,184	21.07
2387	1858	RCHRD	1201	1,433	21.05
2388	2113	PCOIT	1005	1,093	20.90
2389	1857	BDFRD	8841	814	20.82
2390	199	RGLRW	0003	92	20.81
2391	2307	BRCRK	6512	1,771	20.77
2392	316	HUTTO	2711	3,618	20.74
2393	1969	HORNE	1961	1,766	20.71
2394	2669	BRNWD	1205	1,135	20.70
2395	1747	HLSES	0542	758	20.70

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2396	1251	HRSMD	1907	2,564	20.68
2397	2598	BLMND	3221	95	20.54
2398	1221	RDRSE	2604	2,481	20.53
2399	2456	SHRSW	6641	1,004	20.49
2400	2227	WNRTH	1419	305	20.45
2401	N/A	STERT	2704	10	20.44
2402	337	BRHLW	7621	2,885	20.38
2403	2389	ARLNG	1222	100	20.37
2404	882	OKCLS	0007	356	20.23
2405	2681	WMMMR	2708	249	20.20
2406	1202	FRNKF	0003	494	20.19
2407	2790	NCSTH	1505	16	20.18
2408	2022	PRKWY	1561	1,726	20.15
2409	1898	MSHLN	0008	682	20.14
2410	2043	RKDLE	1302	1,179	20.13
2411	1421	SHRSW	6612	1,822	20.12
2412	2410	DAVST	0007	623	20.10
2413	161	SORCY	0004	597	20.08
2414	2129	HURST	1831	1,361	20.06
2415	1311	CNEXP	0005	46	20.04
2416	2818	REGST	0004	982	20.03
2417	857	LWSNR	2212	1,384	20.02
2418	653	RWDHV	1905	1,211	20.02
2419	1364	CNTRD	0004	1,117	20.01
2420	2725	RNDRK	1501	807	20.01
2421	2755	RNKSW	5413	31	19.86
2422	2304	NCRST	2201	1,980	19.78
2423	1746	KILEN	1203	709	19.78
2424	2287	LOMAL	0006	1,401	19.78
2425	1289	WNDCR	0241	712	19.75
2426	1824	TYWST	2004	1,024	19.74
2427	1587	FRNKF	0004	1,010	19.64
2428	890	CDHCR	2055	1,314	19.62
2429	2211	KLNTF	1806	1,168	19.61
2430	1452	WTAUG	4623	731	19.54
2431	524	PARIS	1203	962	19.54
2432	2815	MCKMY	0812	131	19.50
2433	1450	PRMED	4403	3,510	19.42
2434	2775	RRSTH	1707	605	19.41
2435	2131	TATSP	4313	1,608	19.33
2436	996	TMSTH	1406	1,146	19.29
2437	1875	MDLNE	0172	377	19.27
2438	2229	ODNTH	2024	2,661	19.23
2439	1541	BRNAV	0741	2,044	19.20
2440	1350	WNDCR	0221	569	19.16
2441	2191	GRLRD	0001	1,774	19.05
2442	1655	WEAST	0617	1,395	19.03
2443	2561	FRMBR	1808	683	18.93

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2444	737	DENAV	0642	915	18.70
2445	282	OVRTN	4037	117	18.67
2446	1205	CDCSW	0004	1,354	18.65
2447	296	HSKAV	0006	649	18.63
2448	2664	BRKNR	1221	1,168	18.62
2449	2534	RCHHL	0363	579	18.60
2450	2702	JUDCT	0001	1,446	18.58
2451	2759	WALST	0001	287	18.58
2452	2056	BNDRA	0001	838	18.56
2453	N/A	KNLTR	0009	866	18.55
2454	441	TRLNW	1201	1,173	18.52
2455	1061	SNYDR	1823	1,490	18.45
2456	2337	MESQW	1805	85	18.41
2457	2898	EXPKY	8141	21	18.37
2458	1184	MCDMT	2551	2,197	18.34
2459	2483	DCATR	1205	125	18.32
2460	1957	BOWEN	3112	907	18.30
2461	2861	IRVNE	1302	283	18.26
2462	652	MCGHR	2004	26	18.26
2463	1551	BLTSW	3201	2,576	18.22
2464	2784	HKBRY	1117	136	18.17
2465	2123	RCHRD	1206	679	18.11
2466	1508	RWALE	3326	2,899	18.10
2467	2336	HKHTS	1605	1,472	18.10
2468	N/A	ALLNC	6421	67	18.10
2469	742	SHDYG	7822	526	18.04
2470	1248	GRDPR	0862	1,027	17.99
2471	1370	CRLJL	1502	388	17.92
2472	2419	BRYAN	0005	3,633	17.89
2473	1035	TMPTV	2402	3,469	17.88
2474	1512	WCOLO	1319	2,048	17.83
2475	930	DALWT	2982	1,020	17.80
2476	2719	BLMGR	1901	264	17.72
2477	2472	ALLEN	2403	1,368	17.70
2478	1379	GNSVN	1401	29	17.66
2479	1033	HORNE	1952	1,260	17.54
2480	2550	NPKWY	0012	2,228	17.53
2481	148	MDWCK	0005	1,387	17.45
2482	36	GRLWS	1706	277	17.32
2483	1548	MRTNS	1502	501	17.31
2484	N/A	STAUG	0007	1,173	17.30
2485	N/A	MDDTN	4331	1,812	17.24
2486	1768	CLMET	0004	1,151	17.24
2487	1607	NMAIN	0282	1,335	17.22
2488	2212	SHNRW	1614	915	17.20
2489	1761	WCOLO	1316	2,065	17.18
2490	1294	WGROB	8422	2,554	17.15
2491	2305	WNRTH	1418	1,753	17.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2492	2362	CRSCN	1204	608	17.03
2493	2278	IRVNR	1552	63	17.03
2494	2482	SHMNE	1403	999	17.01
2495	1124	BRHLW	7642	937	17.00
2496	2127	MDWCK	0003	1,875	16.98
2497	227	RRSTH	1702	3,255	16.94
2498	1899	BLTON	1805	1,535	16.86
2499	541	FRMNT	0012	183	16.84
2500	1733	PAYSW	1213	1,403	16.83
2501	346	WATCO	2603	2,917	16.82
2502	N/A	MDAIR	2922	366	16.78
2503	2616	RSPCK	2106	351	16.76
2504	217	BRGPR	1101	632	16.71
2505	537	COMRC	1204	584	16.70
2506	1385	SPRDL	4822	1,255	16.60
2507	1680	TMNTH	1604	55	16.59
2508	2539	PFFRD	3411	318	16.57
2509	2623	BLMED	1618	35	16.48
2510	2329	WFALS	0114	418	16.45
2511	2842	PRKWY	1542	503	16.43
2512	2310	MDLNE	0122	232	16.39
2513	1064	TMPLE	1202	1,358	16.39
2514	2779	BSPSW	0832	400	16.37
2515	2599	HUTTO	2721	3,650	16.27
2516	729	SMPST	0005	201	16.24
2517	2695	HLSBR	1202	1,216	16.16
2518	2548	CRTLD	4732	2,782	16.16
2519	2107	WEAST	0627	170	16.05
2520	2736	CMPST	0001	445	15.90
2521	745	CKRHL	0004	419	15.83
2522	2829	WDGWD	1561	1,496	15.82
2523	396	SHNRW	1610	429	15.77
2524	2058	FORSW	2053	3,123	15.72
2525	646	DGNST	0008	110	15.66
2526	2155	GRMES	0521	546	15.62
2527	1348	ARLNG	1282	839	15.61
2528	816	ROBNW	1503	1,645	15.51
2529	2776	HMPHL	2791	23	15.46
2530	1053	MDTHN	1701	1,501	15.46
2531	2870	HKBRY	1102	1,567	15.44
2532	2088	BRHLW	7641	30	15.40
2533	548	MCGRG	0776	220	15.40
2534	2422	HORNE	1942	1,413	15.37
2535	2698	TMPNW	1103	643	15.34
2536	1886	WHITE	3532	1,284	15.31
2537	1478	ARMST	0007	124	15.21
2538	1926	RSNHT	1142	938	15.20
2539	1275	HORNE	1911	999	15.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2540	2216	SNYDR	1822	1,637	15.15
2541	582	BLMND	3282	86	15.14
2542	N/A	ENTOH	0008	10	15.10
2543	2214	STAUG	0005	1,225	15.08
2544	614	ATNRN	3412	5,063	15.02
2545	70	MDDTN	4322	25	14.98
2546	2295	SORCY	0001	2,561	14.93
2547	2674	WEBBS	8621	2,668	14.90
2548	924	BRCRK	6543	1,630	14.89
2549	2661	KNLTR	0006	830	14.82
2550	2807	GAVSW	0010	482	14.77
2551	2571	HRSMD	1951	4,465	14.59
2552	1332	HKBRY	1115	15	14.59
2553	569	TRNTY	7541	685	14.49
2554	2378	BLMND	3262	124	14.49
2555	2110	GAVSW	0012	846	14.46
2556	2027	NMAIN	0241	717	14.41
2557	2391	RRSTH	1703	3,461	14.39
2558	2671	BOWEN	3181	766	14.33
2559	2072	BNDRA	0005	1,252	14.33
2560	159	REGST	0003	975	14.25
2561	842	GSTHW	1682	175	14.25
2562	1231	CTYVW	2212	149	14.09
2563	1366	DESPR	1404	630	14.09
2564	711	MDLNW	1513	2,407	14.08
2565	1029	STNVL	1201	2,529	14.03
2566	1660	DAVST	0006	1,141	14.03
2567	2520	GORMN	0411	543	13.98
2568	1288	MCDMT	2552	876	13.96
2569	2812	TYLER	1010	53	13.96
2570	1909	PARIS	1204	1,164	13.91
2571	2553	DESHR	1208	427	13.73
2572	1159	TYBLR	2808	973	13.65
2573	644	DGNST	0007	94	13.62
2574	906	BKWST	0002	1,619	13.58
2575	667	PAYSW	1203	872	13.55
2576	2367	PWEST	1312	1,360	13.54
2577	2653	IRVND	1203	437	13.51
2578	2083	ARLNG	1271	2,070	13.50
2579	2112	WHTRK	0005	728	13.49
2580	1919	BRTRD	7312	3,368	13.42
2581	1853	DESPR	1401	1,691	13.30
2582	2650	BKBNT	1811	687	13.29
2583	755	NHNSW	0001	458	13.20
2584	1972	WTAUG	4621	446	13.19
2585	1088	ARTHR	0411	737	13.18
2586	713	FLMSO	3714	1,140	13.17
2587	542	PCOIT	1024	2,285	13.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2588	1794	GODRD	8161	2,223	13.07
2589	323	FLMSO	3712	834	13.03
2590	2667	BRYAN	0001	16	13.01
2591	2235	ESTLD	3611	1,545	13.00
2592	2600	RRNES	2405	2,387	12.92
2593	2919	MSTLT	1011	64	12.89
2594	154	ADISN	1603	194	12.80
2595	2382	HNYGR	2401	449	12.78
2596	N/A	CMPWI	0005	1,638	12.75
2597	2481	ABRRD	0003	345	12.72
2598	407	FRMBG	1753	702	12.71
2599	2039	DALWT	2992	333	12.69
2600	2734	CMHBL	8121	60	12.62
2601	2052	PALRD	2203	1,089	12.57
2602	931	EZACH	0003	1,289	12.56
2603	2374	BSPRW	2511	780	12.47
2604	637	ALPHA	0008	1,252	12.45
2605	2003	ARTHR	0462	209	12.44
2606	2675	RKCRK	6111	2,552	12.43
2607	2753	STERT	2703	335	12.39
2608	1039	LKHLD	0001	1,658	12.35
2609	2575	STNVL	1205	429	12.35
2610	2770	WVWST	1217	99	12.34
2611	2099	WFALS	0193	2,243	12.32
2612	2019	LWSNR	2211	1,419	12.25
2613	554	WMMMR	2702	1,497	12.24
2614	2624	IRLBJ	3222	846	12.22
2615	2495	PCOIT	1022	2,128	12.22
2616	2547	NVARO	1502	205	12.20
2617	2577	RBNSN	2504	1,631	12.14
2618	2491	SHDYG	7832	1,843	12.14
2619	2604	CTYVW	2221	1,877	12.07
2620	2165	CLBNR	1402	2,440	12.05
2621	2363	WGROB	8411	3,280	12.00
2622	1726	STERT	2701	33	11.95
2623	2355	FRNKF	0006	1,723	11.95
2624	2906	HKBRY	1111	27	11.92
2625	1191	GLNHV	3931	1,335	11.81
2626	732	GRMES	0512	1,202	11.80
2627	198	ROANW	9522	40	11.78
2628	1860	GNSVL	1223	1,009	11.77
2629	2070	SANSM	3913	3,830	11.76
2630	2658	LKWOD	7421	43	11.74
2631	2208	DFWSW	2203	42	11.73
2632	1908	LEMON	0001	2,088	11.69
2633	2630	WFALS	0153	1,136	11.64
2634	2545	WMMMR	2703	1,112	11.58
2635	2785	LVBRD	0005	1,303	11.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2636	1785	MESFR	2103	373	11.54
2637	2932	SHNRW	1607	542	11.50
2638	2425	ADISN	1604	1,149	11.49
2639	783	MCHSN	1201	239	11.43
2640	2781	BNMNV	1102	408	11.43
2641	2352	LIGSW	1603	2,504	11.43
2642	2438	IRVVV	2804	935	11.42
2643	2665	BDFWD	8912	1,031	11.41
2644	1360	SPRDL	4812	1,215	11.37
2645	2714	SANSM	3921	1,401	11.36
2646	384	PFLGV	2002	2,244	11.34
2647	377	BRNAV	0732	786	11.32
2648	2390	GAVSW	0002	922	11.25
2649	2778	CKRHL	0007	68	11.15
2650	2591	WRTHM	5017	161	11.14
2651	749	WNDWD	3631	312	11.12
2652	2743	HURST	1852	1,499	11.07
2653	2791	CLLVL	0002	500	11.03
2654	2506	FRMNT	0010	2,122	10.94
2655	1517	PKRVL	1053	1,043	10.87
2656	2527	MSLSW	0006	96	10.84
2657	2025	SANSM	3911	1,437	10.79
2658	2726	STERT	2702	19	10.69
2659	1212	PLANO	1103	1,871	10.69
2660	2540	BRYAN	0007	259	10.69
2661	2824	HORNE	1981	1,531	10.64
2662	2939	WEAST	0621	27	10.63
2663	1526	CNTRD	0002	1,470	10.62
2664	1525	BRIRV	6921	2,411	10.57
2665	1758	ARTHR	0441	1,892	10.55
2666	292	BLKST	1771	1,186	10.54
2667	634	GAVSW	0001	1,528	10.53
2668	2089	SSPNG	1203	1,363	10.50
2669	2931	RVRFT	0001	29	10.46
2670	2321	WATCO	2605	2,625	10.43
2671	1590	PTENN	2352	2,481	10.24
2672	1208	SHDYG	7811	371	10.19
2673	341	RCLNS	1401	111	10.19
2674	2511	DENAV	0652	30	10.16
2675	N/A	BRNSO	1804	12	10.14
2676	2704	BNMNV	1101	203	10.12
2677	2009	MAPLE	0001	1,059	10.11
2678	2028	HMTRD	0003	420	10.02
2679	865	BRLSN	2062	3,711	9.95
2680	2512	NCRST	2202	29	9.83
2681	1938	PCOIT	1025	2,899	9.81
2682	1617	LMBLN	0004	50	9.78
2683	2562	TMPSE	1501	544	9.75

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2684	2443	RDRSE	2602	3,219	9.74
2685	2742	BLTON	1802	1,388	9.74
2686	1327	MRTNS	1503	349	9.71
2687	925	HHSTH	1503	1,486	9.63
2688	2582	KLELM	2204	3,060	9.58
2689	2454	MRSES	4014	21	9.57
2690	2795	WGROB	8421	2,025	9.55
2691	1554	PFFRD	3421	858	9.52
2692	521	HMPHL	2713	66	9.51
2693	2437	LEMON	0011	1,838	9.44
2694	1611	JNKNS	0001	15	9.43
2695	2228	MSTLT	1084	799	9.42
2696	2498	BLKST	1732	1,260	9.38
2697	2830	FARON	4021	289	9.37
2698	2684	WSOTH	1022	1,797	9.35
2699	2930	RSPCK	2133	49	9.32
2700	2691	WALNT	0005	994	9.22
2701	1662	WRTHM	5012	317	9.18
2702	1156	OKLND	0003	1,343	9.14
2703	2384	WALST	0002	32	9.12
2704	2342	HRSMD	1953	405	9.10
2705	224	ARMST	0010	848	8.97
2706	365	ROANW	9511	1,306	8.91
2707	2121	HLTOM	2472	1,802	8.84
2708	1699	BOWEN	3142	1,059	8.77
2709	2448	RRSTH	1701	3,168	8.75
2710	1295	RDOAK	1304	3,262	8.71
2711	2809	SHAMP	0003	1,768	8.61
2712	2765	KLELM	2201	2,398	8.50
2713	2518	HMPHL	2721	504	8.45
2714	2596	RSPVY	1708	979	8.39
2715	143	MRSES	3015	565	8.37
2716	463	HKBRY	1103	123	8.37
2717	904	EULSO	9121	119	8.36
2718	2649	BLNKT	0701	279	8.32
2719	1185	ALPHA	0015	839	8.19
2720	1235	BLKST	1752	1,170	8.15
2721	2835	PAYSW	1223	119	8.15
2722	1864	CPLSO	4311	90	8.15
2723	372	AMLIA	0008	106	8.13
2724	1381	GRPVN	8231	395	8.13
2725	2621	RDRSE	2607	4,833	8.13
2726	2662	EDGCF	2252	395	8.12
2727	2821	RVRFT	0002	321	8.08
2728	779	COMSO	1403	470	8.08
2729	1650	TMPLE	1203	127	8.07
2730	2244	PLANO	1106	493	8.05
2731	1000	SCHRD	0003	383	8.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2732	2709	DGNST	0004	720	8.01
2733	2885	CRLUD	1301	22	7.98
2734	2423	BKWST	0005	905	7.92
2735	2597	WEAST	0619	2,153	7.90
2736	348	NPKWY	0009	1,297	7.85
2737	253	RRSTH	1708	4,082	7.78
2738	2738	FRMNT	0003	907	7.78
2739	166	FSCRK	6724	1,348	7.69
2740	2849	PJPTR	3211	118	7.58
2741	2723	PCOIT	1007	847	7.57
2742	1755	DENDR	0006	45	7.50
2743	601	DCATR	1204	652	7.44
2744	2497	SHMNE	1407	789	7.43
2745	1649	PROAD	0004	990	7.43
2746	2654	EMPCT	0004	344	7.36
2747	2647	MESQN	1506	63	7.33
2748	95	TMNTH	1603	135	7.33
2749	N/A	MKNSO	3614	2,098	7.31
2750	1347	CLCRK	1011	200	7.26
2751	2093	SHDYG	7821	100	7.24
2752	2557	CRNSO	3911	300	7.20
2753	1894	DALWT	2941	305	7.15
2754	2917	MAPLE	0008	215	7.15
2755	2254	TMSTH	1407	136	7.13
2756	2772	COTRD	0008	1,351	7.12
2757	2335	PALRD	2208	1,074	6.97
2758	2822	JUDCT	0004	216	6.96
2759	2015	FRMBG	1701	97	6.86
2760	1111	HKBRY	1104	121	6.85
2761	2645	LKBLT	2101	1,720	6.69
2762	1652	PCOMM	3313	470	6.66
2763	1917	REAST	1507	116	6.65
2764	2010	OKCLS	0008	1,542	6.65
2765	2659	RWDHV	1904	513	6.54
2766	1239	CLBRN	1202	986	6.51
2767	2602	EMPCT	0002	101	6.48
2768	2686	DNINR	1401	82	6.37
2769	1186	WELRD	0007	431	6.30
2770	N/A	AIRPK	8432	949	6.30
2771	2813	FRMBG	1708	45	6.30
2772	2468	CRLTR	2051	3,934	6.22
2773	2490	HNYGR	0402	455	6.17
2774	658	SHNRW	1601	547	6.15
2775	2603	ENNIS	1901	364	6.14
2776	2371	ALNTH	2842	1,795	6.11
2777	1975	ABRRD	0001	1,422	6.04
2778	2523	WEBBS	8631	3,349	6.01
2779	2707	IRVHF	2303	86	5.93

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2780	668	VGCRK	8021	208	5.93
2781	2942	WMRLD	0009	32	5.92
2782	1104	FSTVW	0002	151	5.91
2783	2730	WGROB	8412	3,479	5.88
2784	2700	WNRTH	1416	724	5.85
2785	2748	WATSN	5372	1,340	5.82
2786	2193	CRLUD	1306	26	5.79
2787	1949	MESQN	1503	1,884	5.75
2788	2867	PTENN	2355	179	5.71
2789	1509	BLMND	3252	1,118	5.62
2790	263	LMBLN	0001	2,032	5.61
2791	286	INAIR	1414	764	5.60
2792	552	EULES	8731	718	5.51
2793	2909	INAIR	1442	113	5.49
2794	382	GLNHV	3953	1,604	5.48
2795	1963	TMPNW	1102	682	5.46
2796	853	BANGS	1201	1,481	5.46
2797	1673	DNISN	1206	917	5.45
2798	673	SHMNE	1405	791	5.42
2799	2928	RGFTW	6822	23	5.39
2800	1155	ALNSW	2651	1,900	5.35
2801	2644	CMTSW	0987	389	5.35
2802	2858	RCHHL	0394	235	5.32
2803	2911	LAVON	1402	140	5.31
2804	2325	CURIE	7212	20	5.30
2805	1629	CNEXP	0008	493	5.23
2806	2920	MSTLT	1032	31	5.22
2807	513	SHAMP	0006	1,146	5.22
2808	591	KNLTR	0001	2,128	5.22
2809	2751	HMPHL	2792	451	5.08
2810	2632	TRLSW	2401	21	5.05
2811	2872	EULES	8714	806	5.03
2812	2078	TYBLR	2806	215	4.92
2813	2825	MSLSW	0007	385	4.89
2814	840	WALST	0013	350	4.87
2815	2082	WELRD	0004	792	4.87
2816	942	DALWT	2952	654	4.85
2817	1861	TMPNW	1106	545	4.84
2818	2477	BRKRG	0221	708	4.82
2819	2701	ARLNG	1212	132	4.80
2820	2922	PCOMM	3311	25	4.77
2821	976	VANAL	1201	586	4.72
2822	2178	COVEE	3403	1,272	4.71
2823	1810	RRSTH	1704	3,112	4.63
2824	2428	MDWPK	9211	1,237	4.63
2825	2797	GAVSW	0008	107	4.63
2826	2549	MDWCK	0008	887	4.57
2827	2245	SHDYG	7841	341	4.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2828	2916	LVBRD	0001	40	4.56
2829	2589	PROAD	0003	1,134	4.56
2830	2773	ARMST	0003	363	4.53
2831	1131	WSOTH	1019	819	4.50
2832	2555	IRVNR	1510	389	4.48
2833	1528	ALPHA	0010	517	4.41
2834	2379	ZEPHR	2404	177	4.31
2835	600	CRKET	1201	318	4.31
2836	970	HORNE	1923	1,568	4.30
2837	2032	CMTSW	0952	242	4.29
2838	1897	GRHWY	5521	888	4.16
2839	538	HMPHL	2733	112	4.15
2840	210	NCSTH	1506	90	4.12
2841	2782	MNSTR	1202	269	4.09
2842	936	BKWST	0004	1,050	4.06
2843	2902	FRMBR	1806	146	4.05
2844	2642	PRHLL	2402	60	4.00
2845	2507	ADISN	1602	220	3.97
2846	962	NHNSW	0002	396	3.84
2847	2847	RWALL	1201	1,189	3.83
2848	2937	VENSW	2603	33	3.83
2849	2656	EULTB	5711	2,032	3.80
2850	2801	PROAD	0009	120	3.78
2851	440	AMLIA	0007	94	3.73
2852	N/A	BLTSW	3205	1,307	3.69
2853	N/A	SIKES	2422	1,043	3.67
2854	2774	HLTOM	2461	848	3.64
2855	489	RGLRW	0008	37	3.44
2856	506	BRHLW	7631	635	3.40
2857	2820	PWEST	1302	332	3.38
2858	2692	CMPST	0003	204	3.38
2859	2484	WATSN	5382	662	3.32
2860	1304	CRSCN	1202	623	3.31
2861	2853	JUDCT	0008	134	3.14
2862	2447	EDGCF	2221	800	3.13
2863	2622	FSCRK	6721	1,662	3.13
2864	2739	WWEST	1220	198	2.96
2865	2613	GDNVL	1201	64	2.96
2866	2933	SORCY	0002	64	2.91
2867	671	HNYGR	2403	133	2.89
2868	2740	KLELM	2202	2,151	2.87
2869	871	WMRNR	0001	169	2.84
2870	1142	SHAMP	0002	1,751	2.81
2871	2138	CRNRD	0002	365	2.74
2872	N/A	WNDWD	3672	274	2.71
2873	2485	CURIE	7222	947	2.71
2874	1816	IRLBJ	3221	794	2.52
2875	2231	GRAHM	0713	405	2.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2876	N/A	RSNHT	1111	323	2.46
2877	2480	TMNTH	1601	30	2.18
2878	418	WALST	0010	837	2.11
2879	1971	COPER	0401	122	1.95
2880	1639	PJPTR	3221	45	1.84
2881	100	BRYAN	0002	214	1.82
2882	2614	FLMSO	3711	2,430	1.75
2883	214	PRKRW	3382	280	1.73
2884	2845	SHDYG	7812	125	1.73
2885	2578	BRNAV	0774	205	1.65
2886	121	HNTNG	1302	37	1.64
2887	2850	STNVL	1202	77	1.61
2888	2750	JKSNR	4107	322	1.54
2889	2880	BNDRA	0013	163	1.45
2890	2716	WALST	0012	509	1.43
2891	2899	FHLSW	1382	112	1.42
2892	2837	GAVSW	0011	111	1.40
2893	1005	BRKTN	1202	117	1.36
2894	1896	WMMMR	2706	19	1.33
2895	2396	HKBRY	1113	426	1.31
2896	1318	ALPHA	0006	295	1.25
2897	2864	LSCOL	2137	748	0.98
2898	2888	DENDR	0009	61	0.98
2899	2749	NPKWY	0007	180	0.97
2900	478	WMMMR	2705	601	0.97
2901	2844	MCDMT	2553	1,319	0.89
2902	2855	TMSTH	1405	521	0.88
2903	2752	KLNTF	1803	1,049	0.86
2904	1513	WEBBS	8613	629	0.85
2905	1344	MSTLT	1042	513	0.84
2906	934	TERSO	2503	1,071	0.82
2907	N/A	COTRD	0004	105	0.82
2908	2230	MDWPK	9221	769	0.78
2909	869	WEAST	0620	545	0.78
2910	2786	RRSTH	1705	857	0.75
2911	2805	DGNST	0001	453	0.74
2912	814	SCHRD	0006	472	0.74
2913	137	FRMBR	1807	856	0.73
2914	N/A	MDAIR	2912	854	0.72
2915	2826	HMPHL	2752	286	0.59
2916	2811	COTRD	0005	227	0.46
2917	2566	FRMNT	0007	604	0.42
2918	2925	PLHWY	3701	492	0.42
2919	2833	WFALS	0124	128	0.41
2920	2053	ARMST	0006	618	0.40
2921	2871	ROBNW	1501	999	0.39
2922	951	JNKNS	0006	516	0.38
2923	2349	RDRSE	2605	713	0.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2924	596	RECCR	0005	158	0.29
2925	2158	SMFLD	2362	63	0.28
2926	1778	FRMBR	1853	360	0.21
2927	1717	VGCRK	8031	1,809	0.18
2928	2927	PWEST	1306	283	0.18
2929	2783	WMRNR	0003	798	0.09
2930	2803	FRMNT	0002	572	0.09
2931	1410	LEMON	0002	912	0.08
2932	1708	WTAUG	4651	516	0.02
2933	1586	ABBOT	1901	111	0.00
2934	2876	ALLEN	2405	25	0.00
2935	1719	ARLNG	1291	87	0.00
2936	2841	ARMST	0008	244	0.00
2937	N/A	BLMND	3272	10	0.00
2938	2711	COLDG	4048	10	0.00
2939	2676	COMRC	1202	48	0.00
2940	N/A	COTRD	0001	10	0.00
2941	2883	CRLTR	2006	53	0.00
2942	2889	DFWNW	2602	36	0.00
2943	2893	DFWSW	2208	24	0.00
2944	2896	ENSSE	3011	10	0.00
2945	2370	EULSO	9141	62	0.00
2946	2897	EXPKY	8112	14	0.00
2947	562	FRMBG	1703	30	0.00
2948	765	FRMNT	0006	12	0.00
2949	2851	FRMNT	0011	647	0.00
2950	2660	FRNKF	0008	1,341	0.00
2951	N/A	GMINI	5822	10	0.00
2952	N/A	GSMTH	1731	51	0.00
2953	2903	GSTHW	1613	94	0.00
2954	299	GSTHW	1651	13	0.00
2955	2905	GSTHW	1662	13	0.00
2956	2814	GSTHW	1672	41	0.00
2957	2908	INAIR	1421	17	0.00
2958	2866	JNKNS	0002	173	0.00
2959	2626	JNKNS	0008	18	0.00
2960	N/A	JREST	2103	74	0.00
2961	223	KIMBL	5011	167	0.00
2962	2910	KNLTR	0007	12	0.00
2963	449	LSCOL	2114	59	0.00
2964	2856	LSCOL	2135	599	0.00
2965	2913	LSCOL	2140	325	0.00
2966	2838	LSCOL	2148	1,571	0.00
2967	2434	MAPLE	0004	479	0.00
2968	2084	MESTE	1201	23	0.00
2969	2627	PARIS	1205	26	0.00
2970	2923	PJPTR	3222	179	0.00
2971	2924	PJPTR	3231	26	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2015 SAIDI Ranking	2014 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2015 SAIDI Value
2972	N/A	PJPTR	3241	259	0.00
2973	2708	PJPTR	3242	75	0.00
2974	2834	PLANO	1108	326	0.00
2975	1196	PLHWY	3703	14	0.00
2976	2297	PSHIL	1605	130	0.00
2977	N/A	PTENN	2356	11	0.00
2978	23	REGST	0007	10	0.00
2979	1420	RGFTW	6841	20	0.00
2980	2862	RSPCK	2105	310	0.00
2981	395	SMBMG	1701	28	0.00
2982	2758	SMFLD	2322	41	0.00
2983	2800	WALST	0007	27	0.00
2984	2462	WALST	0008	11	0.00
2985	2941	WMMMR	2704	18	0.00
2986	2944	WXOCF	1402	13	0.00

Notes:

- 1) PRMED was incorrectly referred to as PREMD in 2014. It was corrected.
- 2) LOT69-3023 was replaced by LTFRD-3021 (new substation) in 2015
- 3) LOT69-3024 was replaced by LTFRD-3011 (new substation) in 2015
- 4) CHNDL-1201 was replaced by CHNDW-1201 (new substation) in 2015

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

INTERRUPTION CAUSES

Provide the percentage of interruptions attributable to each cause.

2015 Reporting Year

Causes of Forced Interruptions	Percentage
Weather (Including Lightning)	11%
Vegetation	13%
Animals and Birds	17%
People (Including cars and farm equip)	5%
Utility-owned Equipment	45%
Other	3%
Unknown	6%