


Control Number 45624



Item Number 393

Addendum StartPage 0

PUC DOCKET NO. 45624  
SOAH DOCKET NO. 473-16-2751

RECEIVED

2016 AUG 18 PM 4:09


APPLICATION OF THE CITY OF §  
GARLAND TO AMEND A §  
CERTIFICATE OF CONVENIENCE §  
AND NECESSITY FOR THE RUSK TO §  
PANOLA DOUBLE-CIRCUIT 345-KV §  
TRANSMISSION LINE IN RUSK AND §  
PANOLA COUNTIES §

PUBLIC UTILITY COMMISSION  
PUBLIC UTILITY COMMISSION  
FILING CLERK  
OF TEXAS

**ORDER REQUESTING BRIEFING**

At its August 18, 2016 open meeting, the Commission requested briefing in this docket regarding the possibility that the Commission order that the DC tie operate below ERCOT's current most severe single contingency of 1,375 MW until ERCOT completes any required studies and implements any new standards and protocols. Parties shall submit briefs by Monday, August 22, 2016. Parties may orally reply to other parties' briefs at the August 25 open meeting.

**Signed at Austin, Texas the 18th day of August 2016.**

  
Stephen D. Journey, Director  
Commission Advising & Docket Management

393