



Control Number: 46717



Item Number: 14

Addendum StartPage: 0

RECEIVED
2017 OCT 23 PM 2:23
PUBLIC UTILITY COMMISSION
FILING CLERK

Service Quality Report
To The
Public Utility Commission of Texas
In Accordance With
Substantive Rule §25.81
2016 Reporting Year

Oncor Electric Delivery

Project 46717

Revised
October 20, 2017

14

Service Quality Report to the Public Utility Commission of Texas

System SAIFI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2016	0.89	0.05	0.05	0.06	0.05	0.07	0.08	0.09	0.12	0.10	0.08	0.07	0.06
Scheduled 2016	0.07	0.00	0.00	0.00	0.01	0.00	0.01	0.01	0.01	0.01	0.01	0.00	0.01
Outside Causes 2016	0.08	0.01	0.00	0.01	0.00	0.01	0.01	0.00	0.01	0.01	0.00	0.01	0.01
Major Events 2016	0.69	0.00	0.00	0.07	0.13	0.18	0.09	0.13	0.05	0.00	0.00	0.01	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

System SAIDI	Annual	Jan	Feb	March	April	May	June	July	Aug	Sept	Oct	Nov	Dec
Forced 2016	85.85	4.88	4.88	6.00	4.87	7.71	7.60	9.17	11.12	10.53	7.40	6.49	5.20
Scheduled 2016	4.46	0.30	0.32	0.30	0.31	0.31	0.45	0.37	0.33	0.56	0.45	0.33	0.43
Outside Causes 2016	3.72	0.48	0.12	0.34	0.03	0.47	0.46	0.32	0.18	0.57	0.13	0.49	0.13
Major Events 2016	107.32	0.00	0.00	8.44	18.89	28.03	13.61	26.31	7.47	0.00	0.00	0.65	3.92

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2998

Add or Delete Rows as Necessary

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1	238	SBEAN	6011	182	13.69
2	257	CNANG	1806	2458	7.70
3	2890	BRKTN	1202	120	7.55
4	249	NHNSW	0006	946	7.47
5	29	MSTNG	2621	72	7.06
6	41	ELMAR	3211	134	7.05
7	27	RYLTY	1411	126	6.83
8	1034	MNFLD	2672	2275	6.59
9	870	SNDHL	3821	61	6.57
10	76	PLDAV	4231	73	6.00
11	167	BRIRV	6922	3406	5.97
12	397	MDLNW	1582	2061	5.96
13	31	CRNES	2711	143	5.86
14	184	MEXIA	4008	690	5.82
15	18	MDLNW	1531	1754	5.54
16	478	TXHRV	1611	169	5.21
17	65	MSTNG	2611	145	5.14
18	37	TIODE	9632	413	5.11
19	1504	MEXIA	3016	279	5.01
20	373	UPTON	0721	121	4.97
21	1366	RYSSW	2804	2188	4.95
22	727	BRNSY	1211	135	4.93
23	2552	MCGRG	0776	222	4.88
24	2424	WMRLD	0006	593	4.82
25	702	FARON	4011	642	4.81
26	2701	OKCLS	0006	687	4.76
27	489	ADMDS	6532	466	4.75
28	220	LMBLN	0005	686	4.74
29	1023	BKWFF	0521	463	4.70
30	104	AMMFG	5611	813	4.69
31	193	NCDCH	1201	781	4.67
32	44	CLCTY	1011	1056	4.64
33	502	KNOTT	5221	60	4.60
34	208	LUFKN	1203	741	4.58
35	617	WSTHL	3621	4999	4.52
36	1136	GNSVE	1603	1687	4.50
37	5	BARNW	4511	72	4.50
38	2576	BRIRV	6921	2448	4.43

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
39	1999	PRNTH	1405	986	4.39
40	862	TMNTH	1606	232	4.35
41	115	WDGWD	1531	1516	4.35
42	1607	DAVST	0004	1721	4.31
43	784	MIDWY	0612	474	4.27
44	2606	DEALY	0003	1773	4.17
45	13	BARNW	4521	101	4.15
46	206	LKMNT	0002	987	4.12
47	1482	CHALK	0951	73	4.11
48	732	EMPCT	0008	37	4.08
49	1231	PLKST	0007	1784	4.07
50	755	CKRHL	0002	425	4.05
51	286	COYAN	6321	311	4.05
52	1126	FRNKS	4168	968	4.04
53	113	RYLTY	1421	453	4.02
54	555	RYLTY	1431	76	4.01
55	1046	MCGRG	1902	491	3.99
56	1785	CRLUD	1303	616	3.96
57	2427	FORSW	2053	3210	3.96
58	110	DGLAS	2401	754	3.95
59	194	FRFWS	3004	822	3.93
60	343	MIDWY	0621	141	3.93
61	830	MASON	3421	53	3.91
62	2591	PLKST	0001	786	3.89
63	1192	FRNKS	1201	385	3.89
64	905	PRFTW	4222	3314	3.82
65	388	GLSCK	2411	240	3.80
66	40	TYLGE	1311	809	3.78
67	103	MEXIA	4023	616	3.76
68	7	DHIDE	2811	105	3.74
69	235	WINKS	0531	48	3.71
70	520	AYERS	4421	1481	3.69
71	319	PMBRK	1821	73	3.68
72	284	MAPLE	0006	2373	3.68
73	2195	RSPCK	2131	58	3.67
74	2812	PAYSW	1223	115	3.66
75	613	FSTVW	0003	1929	3.66
76	254	MDLNE	0161	992	3.61
77	1015	NCDCH	1205	1084	3.61
78	895	HOWRD	3921	74	3.58
79	#N/A	GASLD	4211	101	3.56
80	83	STHRL	0004	1278	3.52

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
81	725	BNBRK	4122	2743	3.52
82	1869	NWARD	3511	63	3.49
83	2365	ABRRD	0008	1438	3.49
84	174	MKNSW	2601	3198	3.48
85	2820	BNDRA	0013	146	3.48
86	1569	WWDWY	2015	1200	3.48
87	1042	MRSES	4005	751	3.48
88	1318	ENNIS	1902	1260	3.47
89	2305	BRNAV	0753	1267	3.47
90	1383	PAYSW	1205	724	3.46
91	2902	ARMST	0006	613	3.44
92	16	GRLND	1604	1996	3.43
93	1975	MYPRL	1801	158	3.42
94	321	CNSES	3056	2646	3.42
95	403	BRLSN	2051	2689	3.42
96	936	MKNNY	1251	1517	3.41
97	792	DFWNW	2603	10	3.40
98	2265	NCDCH	1203	1825	3.40
99	2405	INAIR	1413	2418	3.39
100	1563	ALNTH	2854	690	3.35
101	902	PRKRW	3321	163	3.34
102	1374	GRPVN	8213	264	3.34
103	91	SSPNE	1403	1109	3.34
104	2644	WHITE	3521	1122	3.32
105	2635	BRKRG	0242	24	3.29
106	1684	CLKVL	1202	1265	3.27
107	1831	LOVNG	2521	44	3.27
108	748	WXHCH	1205	972	3.26
109	182	HNTNG	1307	1499	3.26
110	188	LTFRD	3011	945	3.26
111	2378	KLNPS	1105	1556	3.25
112	1489	IRVNE	1304	630	3.24
113	1721	BNBRK	4112	2229	3.20
114	1858	KNLTR	0011	1852	3.20
115	1741	COMRC	1203	682	3.19
116	1421	MNWLE	1702	1287	3.19
117	1416	LAVON	1401	1714	3.18
118	143	MDFRM	2111	63	3.17
119	808	SHAMP	0004	1142	3.17
120	2735	OTTOJ	3060	17	3.12
121	1001	WHITE	3531	1922	3.12
122	2056	BKBNT	1842	555	3.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
123	2787	HMTRD	0003	428	3.10
124	2726	NHNSW	0002	404	3.09
125	1876	NMAIN	0211	1928	3.08
126	1609	BRHLW	7622	1130	3.07
127	479	NCWDN	1121	59	3.07
128	2565	BANGS	1201	1498	3.04
129	1512	IRVND	1204	1353	3.03
130	78	WXHNW	2901	179	3.02
131	801	MSLSW	0001	846	3.02
132	135	BLSRA	1601	1404	3.02
133	448	TYLNE	1613	464	3.02
134	2086	WRTHM	5004	225	3.01
135	1788	FROKS	0004	118	3.01
136	320	MDFRM	2131	11	3.00
137	54	CRLTN	1454	347	2.98
138	979	WLSPT	1001	1956	2.98
139	198	EMMAS	4022	60	2.97
140	2	DHIDE	2821	116	2.95
141	1832	EZACH	0005	541	2.95
142	2310	CPLSO	4321	158	2.94
143	2510	PRSTN	0004	674	2.93
144	2557	MDWCK	0004	1750	2.93
145	2373	IRVNR	1553	1336	2.91
146	68	CWIND	6311	27	2.89
147	914	RGLRW	0001	34	2.88
148	271	ESKSW	2711	107	2.85
149	#N/A	DENDR	0003	2224	2.85
150	1732	AZLES	2121	2882	2.84
151	140	PLDAV	4221	219	2.84
152	202	JEWET	1202	759	2.83
153	1838	PLGRV	0003	594	2.79
154	756	DENAV	0683	884	2.78
155	370	SPRTN	1801	1843	2.77
156	330	HRSMD	1955	2091	2.77
157	2386	PRNTH	1406	1021	2.76
158	746	DCATR	1201	1258	2.76
159	399	FORSN	5632	237	2.76
160	2589	NMAIN	0241	712	2.75
161	1268	CNANG	1804	192	2.73
162	897	CRNTH	2401	2531	2.73
163	2192	LKMNT	0003	603	2.72
164	1404	BLMND	3241	231	2.72

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
165	2947	GSMTH	1731	49	2.71
166	1190	GRPTT	9911	697	2.71
167	2281	GRSMN	3027	362	2.70
168	2772	BSPSW	0832	406	2.68
169	175	BLKRV	8311	48	2.67
170	630	FKLCY	5121	105	2.67
171	221	RSPCK	2102	1562	2.66
172	1639	SPRDL	4841	953	2.65
173	106	AZLES	2112	1718	2.65
174	237	TYEST	1501	1757	2.65
175	493	TYLNE	1624	259	2.63
176	1552	NHNSW	0007	581	2.62
177	473	GLSCN	6211	119	2.62
178	1705	KMASB	1711	304	2.62
179	1936	EULES	8711	2049	2.61
180	1428	WFALS	0184	1263	2.61
181	423	MCWHT	3511	3132	2.60
182	2159	RANGR	4321	869	2.59
183	1928	CLKVL	1203	633	2.57
184	2367	COHMA	1132	63	2.57
185	964	CUMBY	1201	750	2.57
186	1746	LMESA	1522	1334	2.56
187	618	JKSES	3029	1183	2.55
188	2189	GLNHV	3911	1360	2.55
189	1145	KMPSO	2400	931	2.54
190	1138	NPKWY	0010	3016	2.52
191	1173	ATHNW	1402	487	2.52
192	546	CLMET	0003	909	2.52
193	1235	PCUST	2011	1639	2.51
194	1348	MNFLD	2621	2282	2.51
195	451	SMFLD	2313	2128	2.51
196	1131	LGVST	8511	754	2.51
197	1777	TYRSW	1701	2410	2.51
198	1083	WOVER	6111	1329	2.50
199	2567	ATNRN	3412	5640	2.49
200	973	FSCRK	6713	3068	2.49
201	332	DALLW	0005	128	2.48
202	1456	ANDRD	0921	91	2.48
203	1759	MABNK	2404	2541	2.47
204	2084	RWDHV	1902	967	2.46
205	1412	TYSTH	1203	430	2.46
206	1893	SHNRW	1611	975	2.45

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
207	2574	FLMSO	3714	1231	2.45
208	2069	BSPSW	0812	1076	2.44
209	2222	RKDLE	1302	1186	2.44
210	2183	HSKAV	0002	1737	2.44
211	126	SCHRD	0007	1405	2.44
212	434	NOLNW	2111	23	2.43
213	521	GYVLM	8611	14	2.43
214	38	EMPCT	0001	35	2.43
215	2137	PARIS	1203	953	2.42
216	2233	PGSTH	7011	43	2.42
217	2299	ARTHR	0462	209	2.42
218	492	PALRD	2201	797	2.41
219	1221	LNCST	1605	816	2.41
220	771	CHRNO	1203	419	2.41
221	1229	RTHGB	1411	680	2.41
222	1536	WCITY	2402	684	2.40
223	966	LFEST	1902	1044	2.39
224	1223	RDLML	2581	1238	2.39
225	1524	HRSMD	1905	2787	2.39
226	1026	SLAKE	8321	4376	2.38
227	1870	RDLML	2552	281	2.38
228	2781	WGROB	8421	2174	2.38
229	562	AYERS	4431	1667	2.37
230	2496	CHROW	0007	84	2.37
231	1697	FSCRK	6732	4208	2.37
232	2702	PJPTR	3211	118	2.36
233	278	REYST	4051	1076	2.35
234	483	RDLML	2571	365	2.35
235	1988	PPARK	1803	1063	2.35
236	180	QNLAN	1201	850	2.34
237	1140	SWAN2	1801	543	2.34
238	2668	CTYVW	2221	1829	2.34
239	1781	FORSN	5611	12	2.33
240	2865	DENDR	0009	63	2.33
241	2133	EULSO	9132	1987	2.33
242	2788	GRSMN	3071	333	2.32
243	1147	DALRK	1307	1161	2.32
244	1273	DESPR	1407	944	2.32
245	1500	WWDWY	2022	1028	2.31
246	#N/A	RYSSW	2803	2278	2.31
247	2289	BRNAV	0762	2393	2.31
248	296	SCYEN	0004	1234	2.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
249	67	HNTNG	1301	1390	2.29
250	1700	BNDRA	0002	540	2.29
251	1099	INDIA	2501	376	2.29
252	1622	PLKST	0002	837	2.29
253	1468	PTENN	2353	936	2.28
254	304	OAKHL	3011	2252	2.28
255	482	MDLNE	0131	2564	2.28
256	1588	CNEXP	0004	912	2.28
257	1793	STAUG	0002	1402	2.28
258	382	GSMTH	1732	45	2.27
259	1680	VLYRN	2953	2837	2.26
260	1646	IRVNE	1305	236	2.26
261	77	PRCRK	0001	202	2.26
262	1335	DALRK	1354	1461	2.26
263	99	GSMTH	1721	47	2.26
264	2619	MSHLN	0008	680	2.25
265	1410	HNTNG	1306	1085	2.25
266	353	ENTOH	0001	846	2.25
267	186	LUFKN	1208	1786	2.25
268	1845	SSPSW	1604	1212	2.25
269	2686	PTENN	2352	2488	2.24
270	49	JDKNS	0821	38	2.24
271	736	WRBND	2321	1545	2.23
272	834	PRMED	4401	2042	2.23
273	2535	HORNE	1911	1017	2.23
274	1129	WHITE	3541	955	2.22
275	743	PROAD	0007	422	2.22
276	89	WEBBS	8612	3384	2.22
277	267	LFEST	1905	1791	2.21
278	196	NCNTH	1806	868	2.21
279	376	FLRTN	3721	75	2.20
280	2308	MESQN	1507	696	2.20
281	513	PEGAS	2311	121	2.20
282	726	MDLNW	1522	1180	2.19
283	1779	RENSW	3122	1541	2.19
284	2861	PRHLL	2402	59	2.19
285	2673	RVRFT	0002	330	2.18
286	2147	FRMBR	1803	2408	2.18
287	429	TRIRA	6222	998	2.17
288	1060	FORSN	5642	42	2.17
289	1852	REAST	1502	1323	2.16
290	1964	KNLTR	0003	624	2.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
291	98	ENTOH	0002	808	2.15
292	940	CKRHL	0001	415	2.15
293	2025	CRNRD	0001	740	2.15
294	2855	WATSN	5372	1339	2.14
295	60	RHOME	2402	1324	2.14
296	1371	MEXIA	3015	123	2.14
297	1750	REGST	0004	980	2.14
298	568	PLSTN	1003	1454	2.13
299	823	ALDTU	9411	2505	2.13
300	1837	HSKAV	0004	1315	2.13
301	118	KNAPP	4021	31	2.13
302	2519	PCOMM	3313	473	2.13
303	178	ABRRD	0005	1461	2.13
304	1507	ANDNR	2231	1086	2.13
305	30	GVOVS	3041	1477	2.12
306	329	BLMND	3213	3272	2.12
307	201	PGSTH	7021	135	2.12
308	130	GRLND	1605	1533	2.12
309	282	ACRLY	1721	60	2.12
310	1340	FHLSW	1332	309	2.12
311	2595	BRLSN	2062	3790	2.12
312	2116	ABRRD	0006	456	2.11
313	46	COLNY	2405	2388	2.11
314	957	CRLTR	2004	235	2.11
315	6	VANSB	1501	797	2.11
316	709	MCWHT	3522	2963	2.11
317	90	BNDRA	0009	718	2.11
318	2474	WFALS	0153	1135	2.10
319	1501	GRDNC	1211	49	2.10
320	2918	RDRSE	2605	736	2.10
321	2438	BRGPR	1101	627	2.10
322	2652	HRSMD	1951	4461	2.10
323	982	JKWST	4035	81	2.10
324	537	MKNKY	1252	2649	2.10
325	2364	WBOSE	1103	906	2.10
326	1611	WWDWD	3641	1483	2.09
327	2556	ARMST	0010	880	2.08
328	261	SMPST	0003	1020	2.08
329	127	BARRY	1802	300	2.08
330	692	PRSTN	0006	758	2.07
331	2215	FLMSO	3716	2141	2.07
332	350	IRVNR	1501	1103	2.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
333	495	ENSSO	2004	1202	2.07
334	58	PRNTH	1404	1474	2.06
335	158	CSHNG	1202	66	2.06
336	2876	TERSO	2503	1097	2.05
337	2271	WBOSE	1102	347	2.05
338	2977	RGFTW	6841	20	2.05
339	2172	MOSSW	4621	1462	2.05
340	2694	CLCRK	1011	204	2.04
341	1194	ABRRD	0004	850	2.04
342	259	MKNGB	5321	590	2.03
343	552	RSPCK	2103	167	2.03
344	456	RENSW	3124	1708	2.03
345	2602	TYBLR	2808	981	2.03
346	931	GAVSW	0006	522	2.02
347	1044	UPTON	0711	170	2.02
348	2105	HKBRY	1105	185	2.02
349	1139	ELZCK	4921	1733	2.02
350	336	CRLCC	2703	635	2.02
351	2186	PKRVL	1051	4720	2.02
352	2423	ARMST	0012	1161	2.02
353	1403	TNSCL	1104	198	2.01
354	1342	SWTWR	1341	246	2.00
355	1461	WNDWD	3611	297	2.00
356	2581	DAVIS	3762	41	2.00
357	829	ALLNC	6422	15	2.00
358	2572	WALST	0006	10	2.00
359	2771	TRLNW	2401	22	2.00
360	875	FRMNT	0001	850	2.00
361	1079	SSPNE	1401	1276	1.99
362	1712	TRLWD	7722	4056	1.99
363	291	FRMNT	0004	2377	1.98
364	394	BRIRV	6912	805	1.98
365	584	TRNTY	7521	1165	1.98
366	705	SCURY	1911	172	1.98
367	2072	CNTRY	2833	2366	1.98
368	1662	FARON	4041	1032	1.98
369	1633	MDAIR	2921	71	1.97
370	1224	FERIS	1103	988	1.97
371	2744	CHICW	1302	202	1.97
372	160	MDAIR	2911	412	1.97
373	1612	THRDN	1901	1710	1.97
374	930	NCDSW	3811	1469	1.97

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
375	62	TYLNE	1605	1181	1.97
376	1017	WATCO	2602	2273	1.96
377	1704	GNSVL	1203	1622	1.96
378	1731	PWEST	1303	1008	1.96
379	2113	TYLGE	1316	2841	1.95
380	1088	MKNGB	5311	487	1.95
381	996	TYOMN	1409	1600	1.95
382	1358	SBEND	0611	171	1.95
383	2356	GLNHV	3992	1158	1.95
384	2605	GODRD	8161	2216	1.94
385	441	ATHNS	1203	1044	1.94
386	1621	GRDNE	9211	439	1.94
387	368	ALPHA	0005	128	1.94
388	508	CANTN	1301	2169	1.94
389	517	RWALL	1202	2503	1.93
390	2389	HORNE	1961	1774	1.93
391	4	LOVNG	2511	51	1.92
392	1480	LWSNR	2232	2269	1.92
393	992	JDKNS	0822	57	1.91
394	301	SCURY	1921	101	1.91
395	612	NECSP	2401	564	1.90
396	665	OAKHL	3021	1988	1.90
397	1302	AMMFG	5621	553	1.90
398	539	WESTS	1601	1047	1.89
399	704	EZACH	0007	1591	1.88
400	2722	NCSTH	1505	17	1.88
401	128	STANT	1311	1525	1.87
402	172	NCSTH	1503	916	1.86
403	974	DIBOL	1505	1446	1.86
404	511	CMEXP	1601	249	1.85
405	573	REAST	1505	999	1.85
406	1351	EMMAS	4012	86	1.85
407	832	CLNSE	4201	933	1.84
408	240	IOWPK	0821	756	1.84
409	446	RSNHT	1162	1514	1.83
410	715	SMOUR	0721	18	1.83
411	187	HURST	1872	2104	1.83
412	871	HORNE	1933	1998	1.83
413	1389	CRLTN	1453	297	1.83
414	169	PLSTN	1004	1576	1.83
415	939	PTENN	2355	179	1.82
416	1277	RWALL	1203	3587	1.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
417	2407	BLTLN	0002	880	1.82
418	1666	DALWT	2931	1563	1.82
419	116	CRSCN	1206	1518	1.82
420	550	BSPSW	0851	1426	1.81
421	1538	MTLDA	0001	2603	1.81
422	596	MRDCK	0004	824	1.80
423	538	ALVRD	1501	1172	1.80
424	575	SWDTN	1611	1488	1.80
425	1664	KMASB	1721	105	1.80
426	1791	SNYDR	1852	1347	1.80
427	390	MDLNE	0112	363	1.78
428	2035	ELCTR	1211	279	1.78
429	2216	FROKS	0003	639	1.77
430	422	PLDAV	4211	57	1.75
431	35	ANDRD	0931	191	1.75
432	1420	CRLTN	1403	211	1.75
433	1293	MNWLL	1207	2096	1.75
434	1296	ODNTH	2033	676	1.75
435	1555	ODESA	0242	640	1.75
436	2547	TYLNW	1912	2100	1.74
437	2731	PCOIT	1024	2312	1.74
438	1669	KLNPS	1102	1883	1.74
439	656	GLNHV	3922	730	1.74
440	2670	MCHSN	1201	244	1.73
441	921	CLBNR	1407	268	1.73
442	289	CRKET	2402	1672	1.73
443	988	DGNST	0006	1283	1.73
444	2959	LSCOL	2114	91	1.73
445	2400	PTENN	2358	1440	1.72
446	1740	WMRLD	0004	1584	1.72
447	400	TSLVL	4008	2029	1.72
448	1057	CRSCN	1205	766	1.72
449	1698	SNYDR	1823	1472	1.71
450	1591	LAVON	1406	1476	1.70
451	454	WBROK	3011	199	1.70
452	633	OAKHL	3052	765	1.70
453	1585	PRKWY	1521	2322	1.69
454	588	RSPCK	2108	960	1.69
455	1368	TRSES	1201	500	1.69
456	963	CRISP	1501	916	1.68
457	1053	MEXIA	4012	1112	1.68
458	72	GLNHV	3973	1525	1.68

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
459	396	HURST	1822	1588	1.67
460	1325	BDFRD	8821	889	1.67
461	1071	FHLSW	1321	414	1.67
462	503	EGFRD	0005	738	1.67
463	410	MNWLL	1206	1105	1.67
464	1989	BLTSW	3201	2607	1.66
465	#N/A	STANT	1313	162	1.66
466	1814	WXNTH	2308	869	1.66
467	411	RCLNS	1406	527	1.66
468	404	ELKTN	2508	1419	1.65
469	431	LUFKN	1206	1615	1.65
470	407	BOWEN	3171	1717	1.65
471	1707	HRSMO	1957	2457	1.65
472	2479	LKMNT	0004	2183	1.65
473	109	KRGRV	2403	3720	1.64
474	2145	LAVON	1454	2979	1.64
475	2809	SIKES	2422	1066	1.64
476	1673	PFFRD	3441	1211	1.64
477	1339	CPRCV	1404	1616	1.64
478	74	BNDRA	0006	693	1.63
479	1596	TRLNW	1203	682	1.63
480	1232	LUFKN	1201	1341	1.63
481	224	WMRLD	0007	1696	1.63
482	1274	TEGMN	3038	1664	1.63
483	117	CNTRY	2831	1592	1.63
484	1915	DNISN	1202	819	1.62
485	2336	GVGLF	9601	50	1.62
486	1337	TRLWD	7711	2341	1.62
487	772	MSLSW	0005	1023	1.62
488	2171	CRANE	0311	791	1.61
489	1406	ROLTR	2912	3609	1.60
490	168	RDLML	2561	897	1.60
491	1426	ALLNC	6412	3266	1.60
492	582	FRSTN	1602	1248	1.60
493	377	EDGWD	1101	629	1.60
494	287	LSCOL	2138	1057	1.60
495	842	ADISN	1605	1106	1.60
496	924	FRMNT	0014	629	1.59
497	2074	COHMA	1111	730	1.59
498	2905	MDAIR	2912	851	1.59
499	1400	TYBLR	2803	787	1.59
500	720	DESPR	1403	1796	1.59

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
501	1828	BRNAV	0741	2076	1.59
502	653	SCYEN	0001	2012	1.58
503	28	WEBBS	8623	2800	1.58
504	1397	HMTRD	0002	2178	1.58
505	944	FRMNT	0003	877	1.58
506	1269	ODESA	0251	1891	1.58
507	1154	WXHCH	1204	1782	1.56
508	906	BRKNR	1211	116	1.56
509	768	NCRST	2204	443	1.56
510	1466	MESQW	1808	1343	1.55
511	2640	RWALE	3326	3032	1.55
512	989	JREST	2102	1051	1.55
513	1483	DALWT	2991	1222	1.55
514	190	ECTHP	4911	1195	1.55
515	1578	LUFKN	1202	1070	1.55
516	2267	LEMON	0004	579	1.55
517	361	WELCH	4911	22	1.55
518	393	IRVND	1205	218	1.54
519	1202	OVRTN	4019	660	1.54
520	2163	TMPLE	1205	2488	1.54
521	1620	ARTHR	0452	680	1.53
522	1055	DNCNV	1904	1471	1.53
523	894	GNSVL	1213	737	1.53
524	96	MKNSO	3611	1944	1.53
525	1024	RHOME	2401	1183	1.53
526	300	MNHNS	1912	1899	1.52
527	1008	MSHLN	0001	1043	1.52
528	1728	BRNSO	1805	798	1.52
529	2687	HSKAV	0006	756	1.52
530	1939	HLSBR	1202	1224	1.52
531	1918	RDLML	2591	1626	1.52
532	1004	LFSTH	1407	1730	1.52
533	548	SHMNE	1409	900	1.52
534	1730	DENAV	0611	852	1.51
535	2700	GLNHV	3931	1338	1.51
536	1676	ROLTR	2922	2467	1.51
537	1811	CMPWI	0002	1660	1.50
538	1816	BLMED	1621	2067	1.50
539	1739	LVOAK	1601	863	1.50
540	57	COYAN	6311	105	1.50
541	1615	PCUST	2004	1204	1.50
542	1437	BSPRW	2532	1604	1.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
543	375	IRVHF	2305	1455	1.49
544	2871	MDDTN	4331	1835	1.49
545	1260	BRHLW	7612	710	1.48
546	1940	SALSW	3001	1484	1.48
547	48	ATHNS	1202	775	1.48
548	1568	CPRCV	1406	1640	1.48
549	2165	PKRMX	4703	3034	1.48
550	1373	NAVCO	0001	23	1.48
551	1018	CRLJL	1505	925	1.48
552	2008	REAST	1504	1294	1.47
553	1708	ALLEN	2408	3213	1.47
554	150	EZACH	0008	1534	1.47
555	2938	DFWSW	2208	17	1.47
556	670	MKNNY	1203	1083	1.47
557	1010	LAVON	1451	1020	1.47
558	2058	AIRPK	8411	782	1.47
559	576	WICKT	0411	250	1.47
560	2917	MCDMT	2553	1926	1.47
561	297	TRPMN	4001	784	1.46
562	1264	MABNK	2401	2132	1.46
563	946	LNGLK	1602	637	1.46
564	516	BOWIE	0621	11	1.45
565	1297	PPARK	1805	996	1.45
566	1529	HLSES	0561	1825	1.45
567	2586	MRSES	4014	18	1.44
568	1760	BLKST	1781	1928	1.44
569	1962	BLMED	1622	955	1.44
570	2068	ARCTY	1321	890	1.44
571	1299	CDHCR	2051	2128	1.44
572	458	MAYFD	5524	2594	1.44
573	603	ATHNS	1201	971	1.44
574	1164	BRKRG	0232	1718	1.44
575	1072	GSTHW	1631	2205	1.44
576	722	RECCR	0001	163	1.44
577	1859	MDLNW	1552	1365	1.43
578	1649	BNDRA	0003	820	1.43
579	1197	KLELM	2205	3200	1.42
580	2127	NCRST	2201	1934	1.42
581	684	BLTLN	0006	926	1.42
582	1782	HOWRD	3911	38	1.42
583	2806	TMPNW	1102	680	1.42
584	2026	DAVST	0005	1828	1.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
585	2886	JKSNR	4107	330	1.42
586	1041	SMFLD	2352	602	1.42
587	306	KLBRG	0003	1404	1.42
588	2409	DAVIS	3733	294	1.41
589	695	CRLJL	1504	1285	1.41
590	2757	TMNTH	1603	138	1.41
591	524	WDGWD	1523	308	1.41
592	1943	MESQW	1804	1344	1.41
593	2063	IRVNE	1302	282	1.41
594	1151	STNVL	1207	971	1.41
595	2089	BRHLW	7632	1487	1.41
596	1399	CPRCV	1405	1530	1.41
597	2311	HUTTO	2721	2702	1.40
598	433	PLSTN	1005	1901	1.40
599	2202	CLYVL	9311	2011	1.40
600	2205	MESTE	1209	1448	1.40
601	683	WNDWD	3652	979	1.40
602	148	STHRL	0001	602	1.40
603	2845	ALNSW	2651	2054	1.39
604	1651	LAVON	1452	1816	1.39
605	1256	TYLNE	1623	510	1.39
606	425	COLNY	2403	2631	1.39
607	215	WEBBS	8614	2507	1.39
608	1773	EZACH	0004	1171	1.39
609	1927	TRLSW	1204	581	1.39
610	559	TIODE	9611	359	1.39
611	1603	KIMBL	5032	1741	1.39
612	1796	NHNSW	0003	527	1.38
613	972	HUTCH	1503	551	1.38
614	543	EULES	8722	2131	1.38
615	2575	PROAD	0004	991	1.38
616	1364	FARON	4062	1149	1.38
617	2721	BRYAN	0001	16	1.38
618	173	GODLY	1601	662	1.37
619	22	BRNAV	0723	1330	1.37
620	969	ALNTH	2832	974	1.37
621	1902	CRSCN	1204	618	1.37
622	778	PCUST	2006	1611	1.37
623	877	RYSSW	2802	4193	1.37
624	1312	HUDSN	1601	971	1.37
625	427	PCUST	2007	1393	1.37
626	864	TMPLE	1206	720	1.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
627	1214	ELMAR	3222	87	1.37
628	911	GAVSW	0005	1500	1.37
629	1111	NCSFA	1706	1185	1.37
630	1813	HSKAV	0005	1373	1.37
631	2421	RRSTH	1703	3573	1.37
632	1960	DEALY	0002	1465	1.37
633	1291	RKDLE	1301	1226	1.36
634	419	TYEST	1508	631	1.36
635	1653	WOVER	6131	2113	1.36
636	1533	RDLML	2521	1025	1.36
637	222	MKNSO	3613	3322	1.36
638	1914	JKSBR	1401	742	1.36
639	571	SMFLD	2381	849	1.36
640	1923	CPLSO	4312	1789	1.36
641	1237	GDPRW	9611	1261	1.35
642	2003	HSKAV	0003	1420	1.35
643	1280	RENSW	3121	1942	1.35
644	1016	DNISN	1204	1213	1.35
645	1007	JKWST	4033	748	1.35
646	1076	CNTRY	2811	2659	1.35
647	2316	WCOLO	1319	2072	1.34
648	476	WDGWD	1581	604	1.34
649	23	ELMAR	3212	38	1.34
650	918	PRFTW	4221	1383	1.34
651	1541	BRHLW	7611	1628	1.34
652	192	EUSTC	2401	1705	1.34
653	87	CSHNG	1201	918	1.33
654	563	LKTMS	2412	12	1.33
655	2455	SSPNE	1402	69	1.33
656	1095	PAYSW	1202	1652	1.33
657	1283	SMPST	0001	2088	1.33
658	880	DCDAM	2003	1322	1.33
659	2924	FRMNT	0002	575	1.33
660	280	BLMND	3231	1227	1.33
661	2182	SMFLD	2333	1063	1.33
662	1776	ITALY	2101	568	1.33
663	2464	TMPLE	1202	1362	1.33
664	1251	SYCRK	4532	4150	1.32
665	1905	GNSVN	1403	299	1.32
666	1441	LNCST	1602	1870	1.32
667	121	ECTHM	3341	2415	1.32
668	2944	FRMNT	0011	993	1.32

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
669	2198	RDRSE	2603	3880	1.32
670	2218	RDRSE	2604	3786	1.32
671	1557	GORMN	0421	353	1.31
672	689	NPKWY	0006	4874	1.31
673	413	GODRD	8131	1533	1.31
674	583	ALVDO	1902	928	1.30
675	69	CDHIL	1623	2153	1.30
676	270	PARIS	1201	1137	1.30
677	213	IRVNR	1557	3120	1.30
678	1514	MESQN	1505	1429	1.30
679	713	ARPMN	4149	313	1.30
680	672	BKWST	0007	1839	1.30
681	92	MNWLW	1402	1531	1.30
682	1077	SGOVL	1403	2376	1.30
683	1900	CHROW	0003	155	1.30
684	820	PRCRK	0003	1836	1.29
685	1929	SYCRK	4512	4161	1.29
686	2292	CMPWI	0005	1645	1.29
687	679	FARON	4072	1541	1.29
688	1913	FINKS	1804	2306	1.29
689	369	WCITY	2401	917	1.29
690	621	BRNSY	1221	79	1.29
691	530	CNTRY	2842	1148	1.29
692	345	CHICC	1701	55	1.29
693	1056	ARLNG	1241	657	1.29
694	855	WALST	0003	131	1.29
695	558	BRKTN	1201	493	1.29
696	850	FROKS	0007	1497	1.29
697	953	MCDMT	2552	876	1.29
698	312	DENDR	0005	404	1.29
699	256	PRCRK	0002	2234	1.29
700	1853	WXHCH	1203	1288	1.29
701	760	ALNSW	2652	2600	1.29
702	1855	DAVIS	3782	983	1.28
703	1979	WNDWD	3662	883	1.28
704	570	WNDCR	0252	912	1.28
705	900	TYLNE	1607	782	1.28
706	1613	FORSW	2015	2404	1.28
707	777	DNISN	1203	1686	1.28
708	1158	OKLND	0002	1261	1.28
709	761	LFEST	1904	1335	1.28
710	1618	ODESW	5922	2399	1.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
711	2266	LMBLN	0003	181	1.28
712	2442	ROLTR	2921	2599	1.27
713	545	SHRSW	6611	1243	1.27
714	1761	TRNTH	1503	1841	1.27
715	773	FSCRK	6712	2562	1.27
716	2548	BOWEN	3112	907	1.27
717	1809	BNDRA	0007	504	1.27
718	480	FERIS	1101	1179	1.27
719	2158	MCDMT	2532	1978	1.27
720	2235	LVBRD	0008	1761	1.27
721	2411	CLCTY	1031	1224	1.27
722	2375	GAVSW	0009	1032	1.27
723	1243	LAVON	1404	960	1.27
724	1972	PRKRW	3362	1099	1.27
725	968	OAKCK	2211	45	1.27
726	197	HSKAV	0007	1888	1.27
727	2699	AIRPK	8432	948	1.27
728	1330	CAMRN	1203	1220	1.26
729	1778	OKCLS	0001	1396	1.26
730	535	GRDPR	0842	1378	1.26
731	2351	OAKHL	3082	1449	1.26
732	742	EULES	8724	2400	1.26
733	1631	ALLNC	6411	46	1.26
734	2201	SNYDR	1822	1616	1.26
735	797	MCDMT	2531	2439	1.26
736	2501	MRTNS	1502	508	1.26
737	2184	PLANO	1104	991	1.25
738	311	MESFR	2102	676	1.25
739	1275	COPEL	3051	1588	1.25
740	2659	NLNVL	2001	420	1.25
741	2875	PRKRW	3382	309	1.25
742	1278	CLCTY	1021	680	1.25
743	2665	PWEST	1312	1361	1.25
744	2280	SSPNG	1204	972	1.25
745	2185	BNBRK	4111	2890	1.24
746	641	BBTWN	1504	2105	1.24
747	690	LKBRN	2402	1173	1.24
748	2188	MOSSW	4611	1583	1.24
749	2136	CDMIL	1201	598	1.24
750	1966	ARLNG	1223	1838	1.24
751	302	CNI45	2401	608	1.24
752	313	IRVNR	1559	2599	1.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
753	1471	OTTOJ	3059	1092	1.23
754	1169	DESPR	1405	931	1.23
755	2601	HLTOM	2472	1812	1.23
756	2314	WATSN	5342	2032	1.23
757	687	ALLEN	2402	3343	1.23
758	379	GNSVE	1602	1737	1.23
759	629	PARIS	1206	1024	1.22
760	560	CRLUD	1307	290	1.22
761	1799	ROGRS	1301	768	1.22
762	155	LNDAL	2201	1907	1.22
763	1244	WICKT	0431	18	1.22
764	2019	EXPKY	8142	27	1.22
765	595	LWRDR	0001	1166	1.22
766	783	IRVVV	2851	2972	1.22
767	2231	GSTHW	1692	999	1.22
768	1234	IRVNE	1306	1535	1.22
769	991	WEBBS	8631	3599	1.22
770	2805	RCLNS	1401	115	1.22
771	1701	WELRD	0008	1125	1.22
772	1276	TYEST	1506	479	1.22
773	790	COPEL	3056	2811	1.21
774	1672	CHSPG	2401	3722	1.21
775	688	MSHLN	0007	724	1.21
776	1659	ALPHA	0009	62	1.21
777	2294	CMPWI	0001	1889	1.21
778	1467	CNTRY	2862	401	1.21
779	2511	BRNAV	0732	798	1.21
780	1950	DCATR	1205	121	1.21
781	1805	NCDCH	1206	1098	1.21
782	138	FSCRK	6711	3788	1.21
783	2044	ELMGV	3653	1988	1.20
784	484	BDFWD	8921	688	1.20
785	908	CHYNE	9111	30	1.20
786	731	SHAMP	0007	690	1.20
787	449	FROKS	0001	1364	1.20
788	805	KLRPR	9011	2738	1.20
789	439	DUVAL	0441	1034	1.20
790	1493	CNI45	2402	811	1.20
791	544	FHLSW	1372	1314	1.19
792	1510	WND CR	0221	572	1.19
793	367	SYCRK	4531	2434	1.19
794	1432	TYLER	1004	184	1.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
795	959	MRVLY	2311	368	1.19
796	2093	LKMNT	0008	1004	1.19
797	2002	CMTSW	0966	124	1.19
798	84	REAST	1503	570	1.18
799	2486	PRSTN	0003	2960	1.18
800	2484	PFLGV	2002	2272	1.18
801	1663	FORSW	2051	4026	1.18
802	1211	LOMAL	0003	1055	1.18
803	2561	SHMNE	1407	807	1.18
804	589	CMTSW	0922	1420	1.18
805	854	MESQW	1806	1665	1.18
806	2408	RCLNS	1407	1390	1.18
807	597	RCHLD	2101	613	1.18
808	366	MKNNY	1254	2366	1.18
809	2347	STAUG	0008	2057	1.18
810	142	DENAV	0662	588	1.17
811	2252	TATSP	4322	2534	1.17
812	663	PRFTW	4211	3614	1.17
813	678	LTLRV	1701	1085	1.17
814	1152	KNEDL	6312	3080	1.17
815	2340	MDLNW	1513	2469	1.17
816	592	ECTHP	4921	311	1.17
817	1835	GLNHV	3963	1597	1.17
818	1715	HLSES	0511	1809	1.17
819	1937	WEAST	0617	1403	1.17
820	2041	WEAST	0629	1802	1.17
821	2066	PTENN	2351	1553	1.17
822	14	RBNSN	2502	1224	1.17
823	1254	SHAMP	0001	1230	1.17
824	542	JKWST	4178	421	1.17
825	1909	GODRD	8171	839	1.17
826	1422	HORNE	1932	1159	1.16
827	47	MKNSW	2602	1272	1.16
828	2372	EDGCF	2272	1079	1.16
829	1947	TYSTH	1202	1056	1.16
830	1764	WELRD	0006	732	1.16
831	364	RSKMN	3046	1085	1.16
832	1285	FSHSW	2111	315	1.16
833	1920	PAYSW	1213	1427	1.16
834	1745	BKBNT	1821	1148	1.16
835	204	ARMST	0004	1282	1.16
836	294	WALST	0009	817	1.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
837	216	BEAST	4090	937	1.15
838	1632	MCGHR	2003	1298	1.15
839	1857	ODESA	0261	1455	1.15
840	853	CLBNR	1406	106	1.15
841	2717	KLELM	2201	2428	1.15
842	1213	SYCRK	4522	2835	1.15
843	2377	HLSES	0522	1753	1.15
844	2187	CLLVL	0006	1183	1.15
845	1087	ANDNR	2252	241	1.15
846	2626	NSTAR	2011	524	1.15
847	1156	CNSES	0750	1977	1.15
848	620	MSLSW	0002	1038	1.15
849	2653	IRVNR	1552	68	1.15
850	819	BRIRV	6911	3239	1.15
851	428	JKSNR	4109	651	1.15
852	2220	TYLGE	1308	1559	1.15
853	412	BBTWN	1502	1741	1.15
854	2592	PCOIT	1005	1095	1.15
855	2492	BKWST	0005	918	1.14
856	594	PLGRV	0001	1201	1.14
857	2285	PRMED	4403	2640	1.14
858	1203	ELZCK	4911	35	1.14
859	2406	OVRTN	4037	119	1.14
860	2724	SANSM	3911	1479	1.14
861	1494	LFSTH	1402	1188	1.14
862	2465	MRLNS	4002	411	1.14
863	985	REYST	4040	545	1.14
864	2237	TMPNW	1105	829	1.14
865	2404	NHNSW	0008	587	1.14
866	1532	BOWEN	3161	1544	1.14
867	2955	KIMBL	5011	162	1.14
868	229	RICES	0208	715	1.14
869	1217	MNFLD	2611	1894	1.14
870	2337	JKREA	1201	30	1.13
871	1486	NHNSW	0004	567	1.13
872	1868	LVBRD	0001	38	1.13
873	1695	WFALS	0174	1226	1.13
874	700	CNI45	1202	820	1.13
875	2792	MSLSW	0007	385	1.13
876	2326	TMSTH	1404	1313	1.13
877	2620	OKLND	0003	1352	1.13
878	2277	WEBBS	8611	2610	1.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
879	2342	BLKST	1721	1029	1.13
880	230	TRIRA	6221	634	1.12
881	1380	SHLMT	1802	538	1.12
882	1322	MABNK	2402	979	1.12
883	1648	ALLEN	2406	2630	1.12
884	2329	IRVRS	4411	1247	1.12
885	2558	BLKST	1732	1224	1.12
886	2236	FRMBG	1707	443	1.12
887	1875	ALNTH	2853	2993	1.12
888	856	BRTRD	7311	1191	1.12
889	1770	GRLRD	0004	1556	1.12
890	408	ARMST	0002	1685	1.12
891	730	STAUG	0001	707	1.12
892	2357	DNCNV	1903	1203	1.12
893	1032	NCNTH	1802	1289	1.12
894	1610	CNTRY	2824	3090	1.12
895	1817	FRNKF	0002	943	1.11
896	799	PRSTN	0002	1345	1.11
897	2536	FRMNT	0010	2519	1.11
898	2230	SNYDR	1833	1425	1.11
899	664	BSPRG	1904	1665	1.11
900	2749	RDRSE	2602	3262	1.11
901	243	COPEL	3055	2178	1.11
902	890	MSHLN	0004	1302	1.11
903	682	TMNTH	1602	474	1.11
904	673	DEALY	0001	730	1.11
905	2096	RECCR	0006	503	1.11
906	2607	ABRRD	0001	1418	1.11
907	461	LENSW	0321	46	1.11
908	1954	PRFTW	4212	2009	1.11
909	800	HHSTH	1501	3392	1.11
910	440	PLSTH	1304	1310	1.11
911	1787	ALPHA	0014	515	1.11
912	685	HKBRY	1107	969	1.11
913	912	CRLTR	2054	105	1.10
914	660	MSHLN	0002	1584	1.10
915	2207	LOMAL	0010	1558	1.10
916	2583	BNDRA	0005	1264	1.10
917	59	MASON	3431	142	1.10
918	1737	CNEXP	0006	1213	1.10
919	785	FRMBR	1804	300	1.10
920	809	EGFRD	0001	1813	1.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
921	1959	MDLNW	1564	1275	1.09
922	2432	MESFR	2105	1049	1.09
923	494	MURPH	2754	2115	1.09
924	758	FSTVW	0004	2269	1.09
925	1284	HUDSN	1603	1799	1.09
926	2226	BSPRG	1901	586	1.09
927	2984	WALST	0008	11	1.09
928	2269	OKCLS	0007	635	1.09
929	2491	WMMMR	2708	250	1.09
930	2418	GAVSW	0012	834	1.09
931	2540	CRLJL	1502	391	1.08
932	2132	LEMON	0011	1870	1.08
933	2937	DFWNW	2604	12	1.08
934	25	ODESA	0212	885	1.08
935	1560	HLSBR	1203	1643	1.08
936	861	NCSFA	1704	1402	1.08
937	#N/A	LKBLT	2103	1915	1.08
938	406	CRLJL	1508	345	1.08
939	2240	TRNTY	7541	697	1.08
940	2149	OKLND	0001	1339	1.08
941	1303	MLDR2	1605	216	1.07
942	2936	DFWNW	2602	27	1.07
943	1439	WXNTH	2304	855	1.07
944	1509	LIGSW	1604	720	1.07
945	625	FRMNT	0013	3105	1.07
946	1945	TYBLR	2801	1238	1.07
947	#N/A	CMTSW	0936	522	1.07
948	2750	PCOIT	1025	2924	1.07
949	1880	BNTDR	0004	1844	1.07
950	978	EULES	8723	5166	1.06
951	73	CRSGL	1306	644	1.06
952	1176	HURST	1811	1242	1.06
953	2129	NMAIN	0231	318	1.06
954	1271	PRNTH	1401	1343	1.06
955	2773	MESQW	1805	83	1.06
956	151	CTYVW	2222	1385	1.06
957	2727	BRTRD	7312	3712	1.06
958	1976	WOVER	6122	833	1.06
959	1987	LEMON	0008	784	1.06
960	2958	LOMAL	0015	177	1.06
961	907	GRLRD	0002	994	1.06
962	1446	KNLTR	0004	1945	1.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
963	1654	NHNSW	0005	422	1.05
964	2168	ELZCK	4922	19	1.05
965	2909	FRMBG	1753	708	1.05
966	1117	MCKMY	0811	2605	1.05
967	2503	HRSMD	1907	2662	1.05
968	1433	PRKRW	3372	1494	1.05
969	1039	TAYLR	1202	1565	1.05
970	1382	GNSVL	1205	880	1.05
971	1623	MSTLT	1073	194	1.05
972	2609	JUDCT	0001	1906	1.05
973	107	MKNGB	5322	1587	1.05
974	2286	IRVNR	1555	2202	1.04
975	2858	SHAMP	0006	1145	1.04
976	1050	FRNKS	1202	94	1.04
977	1167	HNTNG	1305	1176	1.04
978	1910	IRVGS	1905	770	1.04
979	1735	DCVSO	1106	1210	1.04
980	2851	LMBLN	0004	50	1.04
981	2506	LEMON	0006	709	1.04
982	1215	HUTCH	1501	974	1.04
983	2362	ARTHR	0411	736	1.04
984	703	WOVER	6142	1505	1.04
985	2460	MESFR	2103	375	1.03
986	354	GMINI	5821	1422	1.03
987	2597	FSTVW	0002	146	1.03
988	1912	CHROW	0008	88	1.03
989	2532	ODESA	0221	252	1.03
990	1252	EZACH	0001	985	1.03
991	1090	INAIR	1423	233	1.03
992	277	RGLRW	0006	36	1.03
993	587	TRSES	1202	507	1.03
994	26	BAKKE	6922	1458	1.03
995	251	TRNTH	1501	1765	1.02
996	2242	ABRRD	0002	1372	1.02
997	804	WWEST	1222	178	1.02
998	#N/A	PRMED	4402	867	1.02
999	1263	HLTOM	2442	1096	1.02
1000	145	MNRVA	1301	743	1.02
1001	2392	HORNE	1942	1558	1.02
1002	395	MSTLT	1054	609	1.02
1003	1847	DALLW	0007	442	1.02
1004	1233	RWALL	1204	1064	1.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1005	2798	EMPCT	0004	340	1.02
1006	2579	MDWCK	0003	1873	1.02
1007	209	EDDYS	0712	1100	1.02
1008	2483	PROAD	0003	1140	1.02
1009	1890	FSTVW	0008	1814	1.01
1010	1522	MESQT	1306	978	1.01
1011	813	SHAMP	0005	1722	1.01
1012	474	RECCR	0002	97	1.01
1013	2784	FSCRK	6724	1397	1.01
1014	1068	WHOUS	4128	362	1.01
1015	1992	WNDWD	3682	782	1.01
1016	767	NCSTH	1501	808	1.01
1017	1036	BAKKE	6911	287	1.01
1018	943	ALPHA	0011	1173	1.01
1019	2345	FSTVW	0006	1250	1.01
1020	1160	CLBWS	8112	1626	1.01
1021	149	JUDCT	0007	895	1.00
1022	1270	ALPHA	0001	428	1.00
1023	340	STHRL	0007	134	1.00
1024	987	DFWNW	2606	18	1.00
1025	2167	WNDKR	0241	708	1.00
1026	2706	DENDR	0006	44	1.00
1027	2715	RSNHT	1111	348	1.00
1028	2859	ALPHA	0006	294	1.00
1029	2963	MAPLE	0004	480	1.00
1030	887	FRMBG	1752	464	1.00
1031	2542	SANSM	3913	4118	1.00
1032	1289	WVWST	1219	941	1.00
1033	463	NCWDN	1111	801	1.00
1034	8	BKWST	0001	386	0.99
1035	1409	MESQW	1802	827	0.99
1036	710	CDHIL	1801	1050	0.99
1037	236	MTLDA	0004	834	0.99
1038	1652	CHRNO	1201	517	0.99
1039	1990	ELKTN	2502	1564	0.99
1040	119	PTENN	2357	1294	0.99
1041	342	HORNE	1921	1348	0.99
1042	1343	RDOAK	1302	1252	0.98
1043	1216	HLSBR	1201	1128	0.98
1044	1417	KIMBL	5022	890	0.98
1045	1122	FINKS	1802	727	0.98
1046	2470	BLMND	3282	91	0.98

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1047	1407	SWTWR	1382	438	0.98
1048	1520	BRKRG	0223	286	0.98
1049	896	GSMTH	1742	37	0.97
1050	793	OAKHL	3072	2489	0.97
1051	619	EUSTC	2402	815	0.97
1052	2878	WMMMR	2705	1062	0.97
1053	157	TYSTH	1201	1132	0.97
1054	418	TXHRV	1621	89	0.97
1055	983	MEANS	4421	52	0.96
1056	1798	HLTOM	2452	1810	0.96
1057	1196	SSPNG	1201	1311	0.96
1058	1239	PALRD	2206	1511	0.96
1059	293	INAIR	1432	3279	0.96
1060	561	BNBOR	1203	310	0.95
1061	2897	FRMBG	1750	41	0.95
1062	795	KILEN	1205	1329	0.95
1063	878	CRLFR	2154	3458	0.95
1064	1025	WHOUS	4122	2062	0.95
1065	2852	BLTSW	3205	1439	0.94
1066	640	BEAST	4084	875	0.94
1067	1063	RCHRD	1208	1036	0.94
1068	661	HSKAV	0001	1077	0.94
1069	2258	SWDTN	1641	1572	0.93
1070	776	RECCR	0003	210	0.93
1071	2194	IRASB	3211	277	0.93
1072	2293	GLNHV	3983	1677	0.93
1073	1183	ARCTY	1311	431	0.93
1074	1473	COLNY	2401	734	0.93
1075	728	BRYAN	0006	928	0.92
1076	1019	CLKVL	1201	431	0.92
1077	459	FRFWS	3001	1810	0.92
1078	2759	ZEPHR	2404	181	0.92
1079	549	BSPRW	2542	751	0.92
1080	1753	OKCLS	0005	197	0.91
1081	2471	DGNST	0002	456	0.91
1082	504	WSOTH	1020	1140	0.91
1083	1511	CMPWI	0003	977	0.91
1084	2728	OKCLS	0008	1986	0.91
1085	2961	LSCOL	2140	624	0.91
1086	426	MNFLD	2682	2388	0.90
1087	95	WINKS	0521	51	0.90
1088	327	FRNKF	0007	1172	0.90

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1089	470	CNTRY	2822	2847	0.90
1090	2112	CRLTN	1401	810	0.90
1091	928	BKBNT	1832	196	0.89
1092	1393	MNWLL	1204	286	0.89
1093	308	WLSPT	1002	604	0.89
1094	211	DNISN	1205	1537	0.88
1095	288	RVRFT	0003	908	0.88
1096	754	COLDG	4047	411	0.88
1097	2563	TMPLE	1203	126	0.88
1098	42	LNDAL	2203	2424	0.88
1099	1574	MCDMT	2554	1779	0.88
1100	1691	KNLTR	0006	947	0.88
1101	2468	PAYSW	1203	857	0.88
1102	1210	DALLW	0004	1323	0.88
1103	1227	MNWLW	1401	1546	0.88
1104	481	GMINI	5812	775	0.87
1105	995	PFLGV	2004	3937	0.87
1106	1247	DCVSO	1105	1660	0.87
1107	442	MRTSP	1504	703	0.87
1108	586	LKTMS	2411	95	0.86
1109	1951	ELGIN	1002	2621	0.86
1110	318	EZACH	0002	1424	0.86
1111	567	LRENA	2901	992	0.86
1112	1411	MEXIA	4011	1015	0.86
1113	1135	FINKS	1801	1643	0.86
1114	1052	LWSNR	2221	1451	0.86
1115	556	DWSON	3121	28	0.86
1116	1094	RCHRD	1204	1141	0.86
1117	1108	MDLNW	1511	2588	0.86
1118	1178	KLNTF	1804	1007	0.86
1119	706	SHSTH	1305	488	0.85
1120	347	ENTOH	0006	1952	0.85
1121	541	TYLNW	1910	609	0.84
1122	798	MDTHN	1703	609	0.84
1123	1308	HHSTH	1502	3740	0.84
1124	2009	ARMST	0009	1140	0.84
1125	352	POWEL	2706	239	0.84
1126	233	VALVW	1802	431	0.84
1127	605	BONHM	1202	737	0.84
1128	2360	MCKMY	0822	1386	0.84
1129	1078	HUDSN	1602	1707	0.84
1130	438	MRKLY	0811	121	0.83

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1131	1	VESTS	3111	54	0.83
1132	1427	GVFTW	1802	903	0.83
1133	1818	PLANO	1101	404	0.83
1134	1174	SSPNG	1205	1130	0.83
1135	218	TSLVL	4001	1275	0.83
1136	2130	STNVL	1205	439	0.83
1137	1187	CDMIL	2401	902	0.83
1138	1970	BRCKR	6523	876	0.83
1139	749	WMRLD	0008	1595	0.83
1140	1115	NLNVL	2003	691	0.82
1141	919	CRLTR	2053	1742	0.82
1142	947	CGDEL	5411	28	0.82
1143	744	ENSSO	2002	1109	0.82
1144	248	MAREA	1201	151	0.81
1145	2100	LSCOL	2116	59	0.81
1146	1924	IRVNR	1506	2970	0.81
1147	1319	HLTOM	2411	1442	0.81
1148	1472	RKDLN	1401	934	0.81
1149	753	JREST	2101	1354	0.81
1150	1706	KLRPR	9021	2022	0.81
1151	637	RWALE	3322	1946	0.81
1152	1709	ENNIS	1906	2033	0.81
1153	1625	DLEON	0111	836	0.81
1154	757	KYSTN	1031	26	0.81
1155	1996	WXNTH	2306	2356	0.81
1156	101	TYEST	1511	881	0.81
1157	1240	WXHCH	1202	1710	0.80
1158	465	ELKTN	2506	1688	0.80
1159	1149	WRBND	2312	1443	0.80
1160	314	MDLNE	0142	884	0.80
1161	1627	NCNTH	1808	757	0.80
1162	2568	ENTOH	0008	10	0.80
1163	885	HNYGR	2402	159	0.80
1164	1460	PNTGO	7112	739	0.80
1165	1345	DNCNV	1906	406	0.80
1166	869	WHTRK	0007	1242	0.80
1167	2448	WNDWD	3631	309	0.80
1168	1786	HURST	1861	1849	0.80
1169	632	TMPSE	1503	621	0.80
1170	1006	LKBLT	2105	2003	0.79
1171	1521	DNIWS	1602	1429	0.79
1172	385	NCDCH	1204	1268	0.79

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1173	1091	CRTLD	4732	2785	0.79
1174	1434	SHLMT	1801	305	0.79
1175	1629	MNWLL	1203	885	0.79
1176	1030	MNHNS	1911	1515	0.78
1177	1790	PREST	1602	1413	0.78
1178	932	EULES	8732	629	0.78
1179	1219	HUDSN	1604	1760	0.78
1180	183	VANAL	2412	2997	0.78
1181	1127	DCATR	1202	1720	0.78
1182	909	BONHM	1210	1178	0.78
1183	2738	WHITE	3532	1366	0.77
1184	1714	BDFRD	8831	877	0.77
1185	1344	BONHM	1206	2111	0.77
1186	1722	TROYS	1013	785	0.77
1187	70	FKLCY	5111	72	0.76
1188	518	IOWPK	0831	1073	0.76
1189	1287	AIRPK	8421	1035	0.76
1190	2140	GSTHW	1633	955	0.76
1191	1768	SMPST	0002	1458	0.76
1192	1043	CRLUD	1305	1368	0.76
1193	94	HDWLK	3003	971	0.76
1194	1534	MESWE	3621	807	0.75
1195	405	BDFRD	8822	1054	0.75
1196	1022	LNCST	1604	637	0.75
1197	1544	IRVBL	2501	387	0.75
1198	997	NYLDV	1201	652	0.74
1199	2098	DALLW	0006	1950	0.74
1200	1104	ATHNW	1403	2244	0.74
1201	1925	IRVNE	1309	1130	0.74
1202	999	OAKHL	3031	624	0.74
1203	671	ROSCO	2911	616	0.74
1204	1751	MRSES	4012	395	0.74
1205	1481	RCHRD	1205	1039	0.74
1206	171	GLNHV	3942	1363	0.73
1207	453	ATHNW	1404	1366	0.73
1208	766	GODRD	8141	855	0.73
1209	163	AMMFG	5631	1225	0.73
1210	1526	RBNSN	2501	1968	0.73
1211	1253	PCUST	2008	694	0.73
1212	#N/A	DFWSE	2715	11	0.73
1213	1272	JSHUA	1301	1003	0.73
1214	2126	PRCTR	1602	230	0.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1215	662	MEXIA	4007	453	0.72
1216	1048	LFSTH	1406	2091	0.72
1217	2103	ALNTH	2844	2188	0.72
1218	913	ROSCO	2921	239	0.72
1219	466	RWALE	3324	1508	0.71
1220	1208	HNRTA	0321	850	0.71
1221	938	DNCNV	1901	891	0.71
1222	2301	WALST	0011	747	0.71
1223	565	DCVSO	1104	1352	0.71
1224	2829	WALST	0010	1083	0.71
1225	1123	LGVST	8521	1761	0.71
1226	781	FINKS	1803	1345	0.71
1227	1248	EDDYS	0425	411	0.71
1228	2341	NMAIN	0272	414	0.71
1229	1688	FHLSW	1342	1955	0.71
1230	2234	WDGWD	1512	828	0.71
1231	2911	WALST	0012	516	0.71
1232	1246	NCNTH	1801	2532	0.71
1233	554	WRBND	2311	1398	0.71
1234	2118	DNCNV	1905	1328	0.70
1235	505	CMPST	0004	1586	0.70
1236	1051	FHLSW	1351	1443	0.70
1237	681	PREST	1603	1521	0.70
1238	3	MASON	3411	30	0.70
1239	1110	DNCNV	1902	1078	0.70
1240	644	LIGSW	1608	386	0.70
1241	628	BRNAV	0711	1642	0.70
1242	460	GVODS	3021	262	0.69
1243	2704	BRHLW	7641	36	0.69
1244	1605	PLSTH	1305	500	0.69
1245	1031	TYLER	1005	2004	0.69
1246	112	HKBRY	1101	339	0.69
1247	179	KFMNW	1201	1020	0.69
1248	2758	EULES	8731	1426	0.69
1249	1414	BLVUE	1111	358	0.69
1250	416	DALLW	0001	1149	0.69
1251	2380	PLGRV	0002	2338	0.69
1252	2203	DUVAL	0414	653	0.69
1253	268	WXNTH	2303	2224	0.69
1254	840	ORANS	1501	850	0.69
1255	2335	DALWT	2982	1031	0.68
1256	1842	GRHWY	5522	1728	0.68

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1257	615	CRKET	2403	2796	0.68
1258	817	WNRTH	1417	1395	0.68
1259	207	TYBLR	2811	1124	0.68
1260	2246	EULSO	9131	1977	0.68
1261	435	CHICG	1402	508	0.68
1262	1725	IRVND	1201	976	0.68
1263	1084	RRSTH	1706	3691	0.67
1264	100	LFSTH	1404	513	0.67
1265	1516	WITTS	1705	1353	0.67
1266	2703	CTYVW	2212	145	0.67
1267	1080	TMNTH	1605	1829	0.67
1268	645	PMBRK	1811	24	0.67
1269	455	WBROK	3021	51	0.67
1270	2106	CAMRN	1201	1032	0.67
1271	1955	WNRTH	1421	1484	0.67
1272	2148	CMTSW	0973	1615	0.67
1273	1839	KILEN	1201	1851	0.66
1274	2000	RSNHT	1122	2027	0.66
1275	71	NLNVL	2002	526	0.66
1276	802	MDLNW	1573	1050	0.66
1277	50	FLRTN	3711	100	0.66
1278	2117	TMPTV	2404	1427	0.66
1279	2125	BDFRD	8812	770	0.66
1280	61	NIPAK	1001	131	0.66
1281	2776	RSPVY	1708	980	0.66
1282	1881	CMTSW	0916	555	0.66
1283	1402	FRFWS	3002	850	0.66
1284	325	GRAHM	0721	1241	0.65
1285	1580	HMPHL	2762	1014	0.65
1286	526	SCYEN	0003	1974	0.65
1287	967	HDWLK	3001	970	0.65
1288	1696	DNIWS	1603	1363	0.65
1289	2075	CRYVE	3021	1285	0.65
1290	305	MKNSW	1602	550	0.65
1291	1204	BNTDR	0003	460	0.64
1292	1956	PREST	1601	1159	0.64
1293	638	BRNWD	1202	445	0.64
1294	1101	CDHCR	2054	1435	0.64
1295	392	COLNY	2404	1947	0.64
1296	1747	TYSTH	1208	250	0.64
1297	1230	CRTLD	4711	3181	0.64
1298	1710	GRMES	0521	549	0.64

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1299	639	WTAUG	4613	1896	0.64
1300	75	WHOUS	4121	1333	0.64
1301	1012	IRVGS	1902	1496	0.63
1302	2767	PWEST	1302	339	0.63
1303	246	NCDSW	3813	396	0.63
1304	2739	CRLTR	2051	3938	0.63
1305	111	HDWLK	3005	1020	0.63
1306	1329	TYLER	1012	1706	0.63
1307	1331	STERT	2706	171	0.63
1308	310	GRDPR	0822	627	0.63
1309	1128	TYOMN	1408	1333	0.63
1310	2531	DAVIS	3772	1720	0.63
1311	697	LIGSW	1602	1109	0.63
1312	2152	CRTLD	4723	2326	0.62
1313	2274	GNSVL	1223	1015	0.62
1314	334	KRUMS	1202	701	0.62
1315	1465	CRTLD	4742	920	0.62
1316	1398	MLKF2	1201	1837	0.62
1317	1455	LVOAK	1602	936	0.62
1318	2538	WALNT	0005	992	0.62
1319	450	PWEST	1307	945	0.62
1320	1949	NPKWY	0014	6107	0.62
1321	578	BDFRD	8832	984	0.62
1322	920	PRKWY	1552	556	0.62
1323	831	BLTON	1803	441	0.61
1324	1415	CRNDL	2401	511	0.61
1325	123	THRNE	0005	1351	0.61
1326	234	WLWSP	1201	505	0.61
1327	85	VANSB	1502	1666	0.61
1328	1448	TMPLE	1201	1656	0.61
1329	1236	IRVVV	2802	1034	0.61
1330	2504	PRKWY	1542	509	0.61
1331	2181	PFFRD	3482	1087	0.61
1332	477	MKNSW	1601	1603	0.61
1333	2965	MESTE	1201	23	0.61
1334	668	WDGWD	1572	1475	0.61
1335	1309	GRAHM	0711	1616	0.61
1336	464	GVODS	3062	1978	0.61
1337	2566	RICES	0206	656	0.61
1338	1222	PRKWY	1511	1301	0.60
1339	2527	WALST	0001	509	0.60
1340	457	SMPST	0004	1991	0.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1341	159	BMTWN	1621	1432	0.60
1342	1228	GRDPR	0811	1216	0.60
1343	581	GRPVN	8223	2049	0.60
1344	1388	LUFKN	1207	47	0.60
1345	1863	COLNY	2402	2426	0.60
1346	1172	DFWSW	2209	42	0.60
1347	475	MNWLW	1403	926	0.60
1348	2332	CDHIL	1804	1221	0.59
1349	1879	RECCR	0004	71	0.59
1350	1166	TROYS	1014	1321	0.59
1351	1162	BNMAG	1202	405	0.59
1352	557	MABNK	2403	1661	0.59
1353	1617	LGVST	8522	354	0.59
1354	265	DALRK	1326	2807	0.59
1355	1033	DNIWS	1601	892	0.59
1356	154	IRVBL	2504	1585	0.59
1357	1130	BOWEN	3192	1264	0.59
1358	675	EULTB	5721	1770	0.59
1359	2300	WTHRE	2101	1215	0.59
1360	63	TRPMN	4023	426	0.58
1361	540	MRSDO	9621	1843	0.58
1362	1378	TATSP	4323	2495	0.58
1363	572	IRVNG	1407	1467	0.58
1364	1150	COVEE	3405	1431	0.58
1365	847	BLTON	1806	847	0.58
1366	228	RKCRK	6112	2322	0.58
1367	2124	DALRK	1358	2088	0.58
1368	623	BRYAN	0004	1301	0.58
1369	205	CRNAT	4121	64	0.58
1370	643	AZLES	2111	3043	0.58
1371	262	TIODE	9621	310	0.58
1372	1665	MESQN	1501	1807	0.58
1373	1106	CDHIL	1613	2979	0.58
1374	1354	LORAN	9711	391	0.58
1375	2462	JNKNS	0003	1064	0.58
1376	680	MESQT	1302	654	0.57
1377	469	RWALE	3321	1533	0.57
1378	239	WALST	0014	893	0.57
1379	652	MESQT	1308	1880	0.57
1380	2330	ODNTH	2024	2618	0.57
1381	1897	WTAUG	4643	1001	0.57
1382	531	CLBRN	1204	1094	0.57

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1383	712	DIALV	3911	1081	0.57
1384	1469	WCOLO	1315	1585	0.57
1385	409	RSKMN	3053	497	0.57
1386	82	BNBOR	1201	752	0.57
1387	657	BEAST	4082	515	0.57
1388	2379	BDFWD	8912	1008	0.57
1389	1757	RWDHV	1905	1215	0.57
1390	398	CURIE	7211	752	0.57
1391	1548	KIMBL	5012	1013	0.57
1392	1198	WMRLD	0003	489	0.57
1393	1334	HKHTS	1604	875	0.57
1394	1849	KLNPS	1103	2184	0.57
1395	955	CADDO	0911	448	0.56
1396	1305	DCVSO	1103	1828	0.56
1397	1641	IRVNG	1405	1163	0.56
1398	212	MRTSP	1501	667	0.56
1399	1054	IRVGS	1901	1388	0.56
1400	2097	GRDPR	0892	1319	0.56
1401	2414	WATCO	2603	2950	0.56
1402	2085	CMPWI	0004	1025	0.56
1403	2396	MLKF2	1202	455	0.56
1404	976	WESTS	1602	864	0.56
1405	1226	MESQN	1504	1331	0.56
1406	170	RWALS	1853	2350	0.56
1407	1802	HKHTS	1602	1019	0.56
1408	1021	GRNGR	1801	908	0.56
1409	904	CRNDL	2403	986	0.56
1410	1457	BRCKR	6521	1428	0.56
1411	718	CRLTR	2001	2501	0.55
1412	258	NPKWY	0005	856	0.55
1413	1973	LKHLD	0003	1347	0.55
1414	608	MKNGB	5312	625	0.55
1415	210	CRTLD	4724	3179	0.55
1416	961	ARTHR	0492	49	0.55
1417	564	CRNTH	2402	1461	0.55
1418	298	PFLGV	2001	4552	0.55
1419	1349	TMPTV	2405	491	0.55
1420	1756	PFFRD	3472	1279	0.55
1421	1453	CPLND	1101	1056	0.55
1422	2562	LIGSW	1607	1435	0.55
1423	865	HORNE	1972	766	0.55
1424	1797	BLTSW	3203	1000	0.55

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1425	1926	SCYEN	0002	1282	0.55
1426	1822	BMTWN	1611	1843	0.55
1427	1862	SUNNY	2303	590	0.55
1428	2160	TNPON	0001	66	0.55
1429	1795	BLMED	1619	1036	0.55
1430	1306	HKHTS	1603	1035	0.54
1431	1719	EULES	8712	1071	0.54
1432	2062	OVRTN	4015	626	0.54
1433	522	WSTHL	3652	3207	0.54
1434	125	CRLTN	1452	1158	0.54
1435	794	CDHIL	1802	754	0.54
1436	2712	ALNTH	2842	1943	0.54
1437	791	SSPNG	1202	1228	0.54
1438	1255	AYERS	4411	1210	0.54
1439	674	ALVRD	1504	158	0.54
1440	467	SPRDL	4811	1225	0.54
1441	669	MSLMN	4007	134	0.54
1442	1775	MCGRG	0775	527	0.54
1443	1546	ALDTU	9421	1764	0.54
1444	2683	IRVVV	2804	943	0.54
1445	2633	TYLER	1001	153	0.54
1446	960	IRVBL	2502	181	0.54
1447	888	KNEDL	6321	2423	0.53
1448	1093	WDGWD	1541	1133	0.53
1449	2523	WELRD	0007	442	0.53
1450	1132	KLNPS	1101	2291	0.53
1451	2420	ARTHR	0441	1891	0.53
1452	1191	ANDNR	2222	126	0.53
1453	64	RSKMN	3057	1173	0.53
1454	1245	REYST	4118	737	0.53
1455	421	TYRSW	1703	1387	0.53
1456	741	JKSBR	1402	1427	0.53
1457	1901	WITTS	1703	1583	0.53
1458	1314	PNTGO	7121	1506	0.53
1459	2346	RSPVY	1704	1406	0.52
1460	1327	NCSTH	1504	63	0.52
1461	486	TYOMN	1405	1662	0.52
1462	1888	MDWPK	9241	1566	0.52
1463	2790	BAGWL	1202	48	0.52
1464	1484	BOWEN	3151	1944	0.52
1465	1628	ARTHR	0472	1289	0.52
1466	2030	ADISN	1601	636	0.52

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1467	1717	BLKST	1762	1033	0.52
1468	487	RWDHV	1901	914	0.52
1469	1801	CRLJL	1501	1463	0.52
1470	1332	GVFTW	1801	667	0.52
1471	1513	MDTHN	1702	1899	0.52
1472	2053	ARLNG	1251	548	0.51
1473	2156	SPRTN	1802	883	0.51
1474	1485	SGOVL	1404	2184	0.51
1475	1418	ESTLD	3621	1494	0.51
1476	2070	PWEST	1301	1253	0.51
1477	1716	LMESA	1531	640	0.51
1478	2500	SHDYG	7822	529	0.51
1479	694	LNDAL	2202	1239	0.51
1480	147	MLFRD	2103	983	0.51
1481	1597	TMSTH	1408	754	0.51
1482	2650	CLBRN	1202	1002	0.51
1483	1020	CRTLD	4734	792	0.51
1484	1833	HURST	1831	1366	0.51
1485	485	ALPHA	0002	1260	0.51
1486	1519	VGCRK	8041	1041	0.50
1487	2122	DUVAL	0421	1303	0.50
1488	585	CDHCR	2052	1405	0.50
1489	2043	CPRCV	1407	2205	0.50
1490	519	TYWST	2012	2147	0.50
1491	1540	EDGWD	1102	947	0.50
1492	1195	SHDYG	7842	728	0.50
1493	812	MSHLN	0003	531	0.50
1494	1543	MESTE	1202	814	0.50
1495	1867	BSPRG	1905	1608	0.50
1496	1978	TMSTH	1406	1156	0.50
1497	120	SGOVL	1402	945	0.50
1498	1113	MNSTR	1201	662	0.50
1499	1479	BOWEN	3122	1281	0.50
1500	2178	BSPRG	1903	1700	0.50
1501	1783	OKCLS	0003	1513	0.50
1502	401	BLKST	1711	1966	0.50
1503	933	ECTHM	3311	1539	0.50
1504	2303	JKSNR	4111	442	0.50
1505	1379	HKHTS	1601	1506	0.49
1506	2718	HRSMD	1953	405	0.49
1507	241	TYOMN	1410	1535	0.49
1508	1694	RCLNS	1405	639	0.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1509	2033	CHNDW	1203	844	0.49
1510	2139	WHITE	3522	1813	0.49
1511	1261	DNINR	1403	1198	0.49
1512	266	STAUG	0006	1800	0.49
1513	2657	REAST	1507	114	0.49
1514	2217	WSTHL	3642	4162	0.49
1515	677	ODESW	5221	1484	0.49
1516	2512	BLKST	1752	1176	0.49
1517	1429	DALRK	1305	1153	0.49
1518	1985	CRLJL	1503	752	0.49
1519	303	MDDTN	4312	1173	0.49
1520	1376	IRVHF	2302	1408	0.49
1521	1352	PPARK	1804	247	0.49
1522	965	EDWDS	5931	1087	0.49
1523	165	REAST	1509	140	0.49
1524	2469	RDOAK	1303	2389	0.49
1525	1396	RBNSN	2503	1126	0.48
1526	1765	ENSSO	2001	227	0.48
1527	1898	TRNTH	1504	818	0.48
1528	1733	KRUMS	1204	1416	0.48
1529	821	WDGWD	1592	1167	0.48
1530	1766	LKWOD	7411	630	0.48
1531	355	SWAN2	1803	1161	0.48
1532	2385	FRMBG	1751	808	0.48
1533	838	MDLNW	1532	1965	0.48
1534	217	CPLSO	4322	279	0.48
1535	2131	WNDWD	3621	2154	0.48
1536	1062	CANTN	1303	860	0.48
1537	2799	HNYGR	2403	594	0.48
1538	1678	BSPRW	2521	1121	0.48
1539	79	MTLDA	0002	1783	0.48
1540	1118	KIMBL	5021	2366	0.48
1541	219	SHSTH	1303	716	0.47
1542	1887	SMFLD	2341	980	0.47
1543	2082	DAVIS	3711	678	0.47
1544	2021	WTAUG	4631	1147	0.47
1545	1826	SALSW	3003	733	0.47
1546	658	IRVNE	1310	1421	0.47
1547	1361	MDLNW	1541	2294	0.47
1548	1586	GRDPR	0871	1569	0.47
1549	1185	SIKES	2421	1843	0.47
1550	1300	HLTOM	2431	1306	0.47

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1551	2494	GSTHW	1682	179	0.47
1552	1423	EULSO	9111	1843	0.47
1553	2144	WXHCH	1201	1657	0.47
1554	275	REYST	4129	518	0.47
1555	349	PARIS	1202	1264	0.47
1556	1496	SWDTN	1621	714	0.46
1557	723	HOLDY	0911	1162	0.46
1558	770	IRVGS	1904	958	0.46
1559	2079	KNEDL	6322	3918	0.46
1560	1670	MESQT	1307	593	0.46
1561	1517	MNWLL	1205	448	0.46
1562	1047	COPER	1201	321	0.46
1563	1443	CRLTN	1406	1202	0.46
1564	380	BNBRK	4121	5015	0.46
1565	2611	CLMET	0004	1174	0.46
1566	462	RWALS	1852	2767	0.46
1567	1066	CDCSW	0008	725	0.46
1568	2797	COVEE	3403	1356	0.46
1569	1377	CMBTP	1201	261	0.46
1570	1582	DESHR	1204	1157	0.46
1571	729	SHMNE	1401	1205	0.45
1572	1630	RDOAK	1301	2475	0.45
1573	2631	BLMND	3252	1138	0.45
1574	1424	CRLTN	1407	1571	0.45
1575	272	LWSNR	2242	1374	0.45
1576	226	MNWLE	1701	672	0.45
1577	1459	PLKST	0008	1699	0.45
1578	1792	HMPHL	2781	331	0.45
1579	1390	GODRD	8142	1039	0.45
1580	2616	MRTNS	1503	359	0.45
1581	1953	TYSTH	1206	1265	0.45
1582	1558	RCHHL	0311	978	0.45
1583	1313	IRVGS	1903	882	0.45
1584	2151	TATSP	4321	1445	0.45
1585	649	DENAV	0621	1705	0.45
1586	2401	RCHHL	0374	541	0.45
1587	1355	DESPR	1406	955	0.45
1588	1539	PSHIL	1608	1941	0.44
1589	2537	CNTRD	0002	1476	0.44
1590	2831	RGLRW	0008	36	0.44
1591	2078	SGOVL	1401	1816	0.44
1592	139	PRKRW	3311	1140	0.44

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1593	1435	KYSTN	1021	43	0.44
1594	1438	PPARK	1808	598	0.44
1595	836	PFFRD	3462	1773	0.44
1596	374	CNTRY	2823	1864	0.44
1597	1860	DCVSO	1101	1478	0.44
1598	1209	NYLDV	1202	139	0.44
1599	1478	WWDWY	2020	1243	0.44
1600	848	ANDNR	2211	2528	0.44
1601	2161	SANSM	3922	1837	0.44
1602	1323	FRMBR	1805	760	0.44
1603	1180	CRANE	0321	23	0.43
1604	1812	DESHR	1201	990	0.43
1605	2088	HOLDY	0921	615	0.43
1606	20	LMESA	2813	118	0.43
1607	2250	PPARK	1801	1318	0.43
1608	1454	MDTHS	1003	1251	0.43
1609	2498	ODESA	0272	1653	0.43
1610	627	CDCSW	0007	990	0.43
1611	2444	PLKST	0004	1310	0.43
1612	2111	PALMR	2202	1051	0.43
1613	1310	FLINT	3211	2289	0.43
1614	436	HKHTS	1606	1781	0.43
1615	1991	ELKHR	1201	959	0.43
1616	1096	JSHUA	1302	1331	0.43
1617	1114	SHNRW	1608	1431	0.43
1618	1259	BRCRK	6514	572	0.43
1619	1257	WMMMR	2707	1547	0.43
1620	2481	ENNIS	1901	363	0.43
1621	1819	HNRTA	0311	1044	0.43
1622	468	COMSO	1401	655	0.43
1623	826	WMRLD	0005	1616	0.43
1624	264	TRLWD	7712	3254	0.43
1625	1470	PSHIL	1602	1077	0.43
1626	1035	CNSES	0370	1256	0.43
1627	1391	SHNRW	1609	1772	0.43
1628	1848	TMSTH	1401	1823	0.42
1629	2475	CRTLD	4721	3062	0.42
1630	1205	MURPH	2751	2315	0.42
1631	1009	IOWPK	0811	789	0.42
1632	1807	CRNTH	2404	2380	0.42
1633	950	MDLNE	0121	232	0.42
1634	1294	HLTOM	2482	1163	0.42

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1635	2175	WELRD	0001	1220	0.42
1636	1567	FARON	4052	1072	0.42
1637	514	CRANE	0331	1202	0.42
1638	1854	ALLEN	2404	2057	0.42
1639	1367	WWDWY	2024	1440	0.42
1640	2417	CLBNR	1402	2453	0.42
1641	15	SCHRD	0001	1029	0.42
1642	2313	TATSP	4312	2527	0.42
1643	1944	WNTHW	1120	1035	0.42
1644	2384	BRCRK	6512	1784	0.42
1645	1474	MESQW	1801	2102	0.42
1646	2162	SALSW	3004	1377	0.42
1647	765	HLSES	0553	1930	0.42
1648	323	EDWDS	5921	24	0.42
1649	1177	ODNTH	2014	1289	0.42
1650	601	PWEST	1308	921	0.42
1651	1359	LOMAL	0001	676	0.42
1652	2048	RRNES	2403	4953	0.42
1653	1692	COLNY	2406	811	0.41
1654	2393	SHDYG	7811	379	0.41
1655	1589	MSHLN	0006	1113	0.41
1656	2692	LIPAN	1303	268	0.41
1657	2036	ARLNG	1232	1273	0.41
1658	1561	MRDCK	0003	1267	0.41
1659	2047	MESQT	1304	635	0.41
1660	1490	MCWHT	3512	864	0.41
1661	2256	MAYFD	5522	3262	0.41
1662	642	KERNS	2401	554	0.41
1663	402	OKCLS	0004	1497	0.41
1664	2225	BDFWD	8941	1223	0.41
1665	604	BDFRD	8811	1703	0.41
1666	2290	ALLNC	6421	73	0.41
1667	2017	CHNDW	1201	1190	0.41
1668	551	RDRSE	2601	1952	0.41
1669	1932	RCHHL	0332	1713	0.41
1670	2251	SFTLK	4021	39	0.41
1671	2696	WSOTH	1019	823	0.41
1672	655	BRGPR	1102	1363	0.41
1673	1298	DALWT	2911	347	0.41
1674	1442	GRPVN	8212	4097	0.41
1675	2632	SMPST	0005	152	0.41
1676	#N/A	MOSSW	4612	2281	0.41

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1677	815	BSPSW	0822	395	0.41
1678	276	CDCSW	0002	2369	0.41
1679	1153	WNTHW	1116	675	0.41
1680	191	CLYVL	9322	2203	0.40
1681	1640	GRDPR	0852	1435	0.40
1682	2331	CRNTH	2405	3957	0.40
1683	2509	STAUG	0007	1183	0.40
1684	1836	COMSO	1402	946	0.40
1685	1903	LKWOD	7442	717	0.40
1686	553	TAYLR	1203	1331	0.40
1687	1014	EZACH	0006	1103	0.40
1688	281	MDTHS	1001	1700	0.40
1689	2278	ROWLT	1103	1090	0.40
1690	2863	CRNRD	0002	360	0.40
1691	1974	WXNTH	2301	1311	0.40
1692	102	PERIN	1511	653	0.40
1693	1362	BNDRA	0011	402	0.40
1694	253	TYEST	1507	1279	0.40
1695	2049	FSTVW	0007	1614	0.40
1696	714	MNHNS	1921	1848	0.40
1697	1029	BRNWD	1204	1779	0.39
1698	#N/A	CMTSW	0957	1175	0.39
1699	2013	SHNRW	1614	954	0.39
1700	2416	BKWST	0002	1667	0.39
1701	2119	DESHR	1203	1405	0.39
1702	2553	RCHRD	1201	1436	0.39
1703	338	RCHHL	0342	1007	0.39
1704	2197	BDFRD	8841	813	0.39
1705	2344	DNISN	1201	1468	0.39
1706	852	WXNTH	2305	1067	0.39
1707	51	ALNSW	2653	3516	0.39
1708	626	IRVVV	2803	154	0.39
1709	747	HUTCH	1502	203	0.39
1710	1675	MRDCK	0002	1699	0.39
1711	269	SLBLF	1201	139	0.39
1712	2102	BRCRK	6533	1833	0.39
1713	2051	GODRD	8132	2702	0.39
1714	634	LKMNT	0007	1553	0.39
1715	1064	IRVND	1202	1503	0.38
1716	733	EDGCF	2262	1019	0.38
1717	2530	RCHRD	1206	683	0.38
1718	822	CLYVL	9313	2010	0.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1719	#N/A	PGSTH	7012	173	0.38
1720	1794	LKHL	0007	1209	0.38
1721	1523	TATSP	4311	1873	0.38
1722	1141	DALLW	0003	663	0.38
1723	2138	WCOLO	1316	2076	0.38
1724	337	RGLRW	0004	79	0.38
1725	387	TAYLR	1204	2026	0.38
1726	162	DCDAM	2001	799	0.38
1727	2482	KLNSO	4502	3190	0.38
1728	1508	KILEN	1204	1520	0.38
1729	1102	DGNST	0007	241	0.38
1730	1065	WHTRK	0001	2750	0.38
1731	734	CMPST	0002	1060	0.38
1732	2910	LSCOL	2137	774	0.38
1733	1188	KLNTF	1805	1339	0.38
1734	1636	KFMST	1301	924	0.38
1735	1505	WNDCR	0211	1183	0.38
1736	1980	CPRCV	1403	1437	0.38
1737	616	KEYSB	2621	16	0.38
1738	430	PCOIT	1001	1233	0.37
1739	2954	JREST	2103	267	0.37
1740	884	GRLRD	0003	641	0.37
1741	2229	LOMAL	0011	1130	0.37
1742	1350	BRNSO	1806	1782	0.37
1743	818	SPRDL	4831	1268	0.37
1744	1789	MESQT	1303	830	0.37
1745	2318	TATSP	4313	1612	0.37
1746	611	PCUST	2012	1813	0.37
1747	2034	RRNES	2405	2628	0.37
1748	2678	TMSTH	1407	206	0.37
1749	759	BLKST	1742	1729	0.37
1750	223	ODNTH	2044	2091	0.37
1751	43	WDGWD	1591	1131	0.37
1752	1679	SANSM	3912	5168	0.37
1753	2693	DAVST	0007	608	0.37
1754	510	LTFRD	3021	899	0.36
1755	2382	CRNRD	0004	480	0.36
1756	490	CNTRY	2813	3070	0.36
1757	648	LNGLK	1604	448	0.36
1758	19	LMESA	2833	22	0.36
1759	2449	RSNHT	1142	946	0.36
1760	1225	AZLES	2122	2255	0.36

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1761	1395	EDGCF	2213	3188	0.36
1762	1103	MDWCK	0007	1081	0.36
1763	2306	DNINR	1402	389	0.36
1764	1593	BSPSW	0841	2117	0.36
1765	1249	BRCKR	6524	782	0.36
1766	1338	KILEN	1202	1721	0.36
1767	1000	PLSTH	1301	722	0.36
1768	2922	JNKNS	0006	525	0.36
1769	1861	BRCKR	6511	1291	0.36
1770	2676	MKNSO	3614	2401	0.36
1771	1815	SWDTN	1631	1624	0.36
1772	1711	HURST	1882	1900	0.36
1773	1644	RRNES	2404	4452	0.36
1774	1844	KNEDL	6311	2923	0.36
1775	2012	CLBRN	1203	1574	0.36
1776	599	EULSO	9112	735	0.36
1777	1564	PCOIT	1008	1243	0.36
1778	2445	WFALS	0193	2233	0.36
1779	1037	CRNTH	2406	1310	0.36
1780	806	WTAUG	4632	1313	0.36
1781	1100	TYEST	1503	1077	0.36
1782	1365	IVANS	1612	1049	0.36
1783	980	CLMET	0002	1407	0.36
1784	1279	ODESW	5912	335	0.36
1785	2108	BLTLN	0007	780	0.35
1786	2261	ESTLD	3611	1538	0.35
1787	2191	MEXIA	4024	345	0.35
1788	2323	MSTLT	1063	976	0.35
1789	472	TAYLR	1201	1774	0.35
1790	153	TEGMN	3040	798	0.35
1791	2685	BLMND	3262	122	0.35
1792	1360	SHNRW	1612	827	0.35
1793	432	HUBRD	1401	902	0.35
1794	1137	BONHM	1204	840	0.35
1795	1930	ARLNG	1213	1328	0.35
1796	214	CNTRY	2814	930	0.35
1797	1452	ATHNW	1401	902	0.35
1798	2213	ARLNG	1261	1366	0.35
1799	2349	HKHTS	1605	1473	0.35
1800	2391	BSPRW	2511	760	0.35
1801	1590	PNTGO	7111	723	0.35
1802	1405	DUVAL	0452	1274	0.35

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1803	2320	DENAV	0642	912	0.35
1804	9	CANTN	1302	1348	0.35
1805	1554	SHRSW	6621	1816	0.35
1806	2836	FLMSO	3712	865	0.35
1807	1028	ALVDO	1901	1464	0.35
1808	764	PALRD	2205	333	0.35
1809	1144	CPRCV	1402	2034	0.35
1810	231	GVOVS	3031	1371	0.35
1811	2487	PALRD	2203	1088	0.34
1812	1572	WSOTH	1017	1744	0.34
1813	2284	FSHSW	2121	1702	0.34
1814	2967	PJPTR	3222	183	0.34
1815	1656	HKBRY	1106	1671	0.34
1816	2134	WNRTH	1419	306	0.34
1817	956	RWDHV	1906	639	0.34
1818	2247	CRLTR	2002	1495	0.34
1819	2690	WELRD	0004	802	0.34
1820	849	CNTRD	0004	1081	0.34
1821	1105	CRSWS	1402	925	0.34
1822	2282	KNEDL	6342	2123	0.34
1823	1889	PLKST	0006	816	0.34
1824	199	PRKRW	3341	542	0.34
1825	1317	SUNNY	2301	611	0.34
1826	2029	ODESA	0231	2115	0.34
1827	1576	DAVST	0002	552	0.34
1828	2083	JUDCT	0002	1409	0.34
1829	331	LKHLD	0005	1137	0.34
1830	2023	CRSWS	1403	1801	0.34
1831	693	TYWST	2001	179	0.34
1832	1748	BRNSO	1801	1568	0.33
1833	1392	WDGWD	1522	1440	0.33
1834	2090	BBTWN	1501	1954	0.33
1835	2038	GPLND	1202	401	0.33
1836	738	OAKHL	3041	945	0.33
1837	1619	TMNTH	1607	12	0.33
1838	2929	ARLNG	1291	87	0.33
1839	1604	WFALS	0133	1672	0.33
1840	536	WCOLO	1320	1439	0.33
1841	53	LVBRD	0002	509	0.33
1842	1436	ROANW	9521	1944	0.33
1843	2808	CRKET	1201	323	0.33
1844	2028	KLNTF	1806	1181	0.33

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1845	1687	DUVAL	0473	1602	0.33
1846	185	BRTL	1402	122	0.33
1847	2115	DCVSO	1102	705	0.33
1848	1736	WTAUG	4652	800	0.33
1849	691	KRUMS	1201	376	0.33
1850	1780	MESQW	1807	1498	0.33
1851	1186	CNSES	3054	1580	0.33
1852	1531	WXNTH	2302	1308	0.33
1853	1906	NCDCH	1202	1027	0.33
1854	1767	MSTLT	1021	1288	0.33
1855	1647	MRTSP	1502	498	0.33
1856	1763	IRVGS	1907	966	0.33
1857	283	BRLSN	2041	3811	0.32
1858	2209	SIKES	2411	2073	0.32
1859	1120	KLNPS	1104	1344	0.32
1860	646	CRLFR	2152	3480	0.32
1861	962	BNTDR	0002	1784	0.32
1862	1592	RTHGB	1421	1661	0.32
1863	2193	PFFRD	3492	297	0.32
1864	835	CNTRY	2851	1504	0.32
1865	1401	BELLS	1201	573	0.32
1866	346	TRLNW	1202	59	0.32
1867	2802	SHNRW	1607	554	0.32
1868	1212	KLNCC	1702	3779	0.32
1869	1549	DALRK	1301	1230	0.32
1870	769	TMPLE	1204	1034	0.32
1871	1425	BLTON	1804	464	0.32
1872	1121	DESPR	1402	1305	0.32
1873	136	IRVBL	2507	904	0.32
1874	93	ECTHM	3331	22	0.32
1875	1369	RCHHL	0384	718	0.32
1876	1463	FLINT	3212	3024	0.32
1877	1049	CRTLD	4712	1172	0.32
1878	1109	GRHWY	5511	1899	0.32
1879	1535	FRMNT	0012	475	0.32
1880	1689	MKNNY	1205	507	0.32
1881	2166	ENNIS	1903	1386	0.32
1882	2260	RRSTH	1702	3289	0.32
1883	2426	MDAIR	2922	387	0.32
1884	2076	WNTHW	1118	1524	0.31
1885	1286	TMSTH	1402	1656	0.31
1886	2244	MESWE	3611	1923	0.31

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1887	1326	IRVNR	1507	1490	0.31
1888	1440	MSLMN	4131	132	0.31
1889	1553	CDCRK	1201	1253	0.31
1890	1674	MESQN	1502	1089	0.31
1891	2322	MESTE	1203	174	0.31
1892	1184	IRVGS	1906	719	0.31
1893	1011	CSHNG	1204	326	0.31
1894	415	RNDRK	1503	3919	0.31
1895	1602	CLYVL	9321	822	0.31
1896	1661	MESTE	1206	1288	0.31
1897	1262	CHYNE	9121	91	0.31
1898	1565	CRLUD	1306	26	0.31
1899	292	ALPHA	0013	449	0.31
1900	1686	BRLSN	2052	3010	0.31
1901	2228	WNTHW	1121	749	0.31
1902	1941	CLBRN	1206	1038	0.31
1903	1450	MKNGB	5352	680	0.31
1904	1258	GRSMN	4028	710	0.31
1905	892	RSPCK	2132	72	0.31
1906	#N/A	CMTSW	0977	249	0.31
1907	1315	CLBRN	1201	1750	0.31
1908	452	IRVNR	1508	2015	0.30
1909	1266	TYWST	2003	1412	0.30
1910	2577	SHRSW	6612	1826	0.30
1911	1683	BDFRD	8842	1465	0.30
1912	2352	HORNE	1991	1480	0.30
1913	1594	ODESW	5211	1262	0.30
1914	1242	TYSTH	1209	814	0.30
1915	569	IRVNE	1303	1688	0.30
1916	606	JEWET	1204	1331	0.30
1917	66	PLSTN	1001	1897	0.30
1918	1713	DAVST	0003	1691	0.30
1919	1720	ARTHR	0481	1251	0.30
1920	2524	GRLRD	0001	1773	0.30
1921	636	MKNSW	1603	1379	0.30
1922	2164	LOMAL	0016	664	0.30
1923	816	WDGWD	1513	865	0.30
1924	707	RRNES	2407	3365	0.30
1925	2174	BOWEN	3132	1779	0.30
1926	512	TSLVL	4002	2748	0.30
1927	1075	ODNTH	2013	1594	0.30
1928	1545	TMPNW	1104	1927	0.30

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1929	1002	ELGIN	1001	539	0.29
1930	2039	ODNTH	2053	2350	0.29
1931	860	HOLND	1901	1097	0.29
1932	952	RGLRW	0005	51	0.29
1933	971	KFMNW	1202	874	0.29
1934	255	ALPHA	0003	874	0.29
1935	1878	BRLSN	2033	1671	0.29
1936	341	IRVGS	1908	957	0.29
1937	1408	MESQW	1803	1691	0.29
1938	1846	DESPR	1408	1998	0.29
1939	1497	WTAUG	4611	1394	0.29
1940	998	CKRHL	0003	472	0.29
1941	2169	PCUST	2003	1028	0.29
1942	383	ECTOR	1201	388	0.29
1943	2433	WEAST	0619	2449	0.29
1944	2497	BRCKR	6543	1659	0.29
1945	299	THRNE	0008	2222	0.29
1946	1882	WNRTH	1418	1780	0.29
1947	17	EMPCT	0003	1355	0.29
1948	164	MKNNY	1253	156	0.29
1949	1931	MESTE	1215	1516	0.29
1950	2381	LOMAL	0006	1413	0.29
1951	1601	THRNE	0003	1252	0.29
1952	2801	EULTB	5711	2295	0.29
1953	1073	RSNHT	1181	1713	0.29
1954	2120	PALRD	2204	687	0.29
1955	1171	PREST	1604	1343	0.29
1956	1419	PRCTR	1601	207	0.29
1957	2625	EZACH	0003	1288	0.28
1958	1933	IRVNG	1406	1278	0.28
1959	1658	CRKET	2401	151	0.28
1960	1598	TRPMN	4094	573	0.28
1961	2430	GRDPR	0862	1564	0.28
1962	2055	MDWCK	0001	839	0.28
1963	708	SPRDL	4821	1363	0.28
1964	1451	DAVIS	3721	1323	0.28
1965	949	DFWSW	2203	39	0.28
1966	1824	WSTHL	3631	3801	0.28
1967	1963	WATSN	5331	1114	0.28
1968	501	ROANW	9512	1928	0.28
1969	447	WNRTH	1420	1165	0.28
1970	828	TRNTH	1502	544	0.28

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
1971	1311	HMPHL	2743	907	0.28
1972	2580	SPRDL	4812	1205	0.28
1973	1784	WCOLO	1318	1647	0.28
1974	2505	PCUST	2001	579	0.28
1975	2223	PLANO	1102	143	0.28
1976	2007	RNDRK	1505	1321	0.28
1977	2927	ABBOT	1901	111	0.28
1978	2813	CRNSO	3911	301	0.28
1979	666	MTLDA	0003	1550	0.28
1980	739	PWEST	1309	61	0.28
1981	1527	CDHIL	1805	621	0.28
1982	2045	MSHLN	0005	503	0.28
1983	1038	LFSTH	1408	2116	0.28
1984	926	MCKMY	0821	1783	0.28
1985	2729	RDOAK	1304	3370	0.28
1986	1762	SMFLD	2343	719	0.28
1987	577	LKBRN	2401	705	0.28
1988	1385	LOMAL	0008	449	0.28
1989	1267	CMNCH	1401	1200	0.28
1990	789	MYPTX	2401	305	0.28
1991	1218	CRNSO	3913	1541	0.28
1992	1579	PWEST	1304	1615	0.27
1993	1356	MRSES	4006	529	0.27
1994	631	FSCRK	6723	4515	0.27
1995	624	PKRMX	4701	1744	0.27
1996	2383	TYLER	1010	55	0.27
1997	#N/A	BLMND	3211	11	0.27
1998	1157	IRVNG	1402	1142	0.27
1999	152	ODNTH	2034	2782	0.27
2000	2059	GSTHW	1623	2529	0.27
2001	1803	WHITE	3542	1671	0.27
2002	1971	TMPTV	2402	3763	0.27
2003	1333	LFEST	1901	1512	0.27
2004	339	PROAD	0005	122	0.27
2005	2681	MESQN	1503	1890	0.27
2006	420	PLSTN	1002	1222	0.27
2007	647	VENSW	2601	1425	0.27
2008	1347	CRLTN	1405	1251	0.27
2009	845	GSTHW	1611	817	0.27
2010	574	BRLSN	2013	1104	0.27
2011	2077	HSKAV	0008	791	0.27
2012	1386	MESQT	1305	1146	0.27

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2013	2109	MESTE	1207	952	0.27
2014	1394	SMPST	0006	844	0.27
2015	1599	RSPCK	2104	1903	0.27
2016	1559	CRLFR	2157	2417	0.27
2017	1645	PFLGV	2005	3802	0.27
2018	1942	MURPH	2755	3282	0.27
2019	635	CRSGL	1301	146	0.27
2020	2754	ABRRD	0003	345	0.27
2021	525	IRVBL	2505	499	0.27
2022	827	GRLWS	1704	173	0.27
2023	2588	WATCO	2605	2709	0.27
2024	2135	KLBRG	0002	1716	0.27
2025	2674	BOWEN	3181	768	0.27
2026	1265	BRNSO	1807	565	0.27
2027	922	BDFWD	8931	1731	0.27
2028	986	ADISN	1607	1237	0.27
2029	1961	KRUMS	1203	791	0.26
2030	1917	ARMST	0007	125	0.26
2031	807	FRMNT	0009	945	0.26
2032	2143	MDLNE	0172	372	0.26
2033	2753	WMMMR	2706	19	0.26
2034	1201	IRVNG	1403	525	0.26
2035	2415	MAPLE	0001	1066	0.26
2036	2428	EDGCF	2211	2105	0.26
2037	1571	HKHTS	1607	943	0.26
2038	1074	GPLND	1201	676	0.26
2039	803	TMSTH	1403	1177	0.26
2040	2206	TRNTY	7551	1576	0.26
2041	1800	PCOIT	1023	639	0.26
2042	1353	CRLJL	1507	926	0.26
2043	2514	TYWST	2004	984	0.26
2044	2370	MSTLT	1084	800	0.26
2045	129	WEAST	0618	854	0.26
2046	1321	CRLCC	2704	535	0.26
2047	2071	CDHCR	2050	809	0.26
2048	1997	CRYVE	3011	289	0.26
2049	2037	EULSO	9122	1296	0.26
2050	2765	WALST	0013	386	0.26
2051	424	CRSCN	1203	1992	0.26
2052	146	ALNSW	2654	1973	0.26
2053	1515	BEAST	4088	116	0.26
2054	2493	RRSTH	1708	4237	0.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2055	1998	PARIS	1204	1161	0.26
2056	1864	FARON	4082	1599	0.26
2057	1346	PSHIL	1604	1163	0.26
2058	2268	BRLSN	2023	1844	0.26
2059	2042	CRLTR	2052	1568	0.26
2060	2441	STAUG	0005	1230	0.26
2061	2334	RNDRK	1508	4031	0.26
2062	1098	CPRCV	1401	1850	0.26
2063	2374	EDGCF	2241	929	0.26
2064	881	GRLWS	1706	289	0.26
2065	2087	KLNSO	4501	3429	0.26
2066	2843	WMRNR	0001	184	0.26
2067	2298	WMMMR	2702	1544	0.26
2068	934	ARPMN	4147	600	0.26
2069	1503	PRSTN	0001	907	0.25
2070	2363	GVODS	3011	2282	0.25
2071	579	WTAUG	4641	574	0.25
2072	2010	LTVSB	5451	1231	0.25
2073	1301	CAMRN	1202	1471	0.25
2074	811	MDLNW	1594	1648	0.25
2075	977	TERSO	2501	185	0.25
2076	2520	BLTON	1802	1410	0.25
2077	1624	RCHHL	0363	579	0.25
2078	2478	WNDCR	0232	646	0.25
2079	1069	PKRVL	1052	2361	0.25
2080	1003	TYOMN	1401	1558	0.25
2081	2459	LKHLD	0001	1662	0.25
2082	2437	LKHLD	0004	1262	0.25
2083	2107	PCOIT	1003	1511	0.25
2084	2573	WGROB	8411	3435	0.25
2085	225	JKSNR	4105	84	0.25
2086	1159	CDCSW	0003	716	0.25
2087	2877	CLLVL	0002	12	0.25
2088	1491	EDGCF	2223	3179	0.25
2089	2463	IRVND	1203	437	0.25
2090	2564	PLKST	0003	1303	0.25
2091	740	ROWLT	1107	369	0.25
2092	498	TYBLR	2805	2231	0.25
2093	1134	EDDYS	0710	648	0.25
2094	1551	WHITE	3511	1341	0.25
2095	1726	WNDCR	0262	230	0.25
2096	532	MESTE	1205	1640	0.25

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2097	2688	CMTSW	0987	396	0.25
2098	1570	ADMDS	6521	1593	0.25
2099	1922	ATHNW	1405	882	0.25
2100	1488	FSTVW	0001	793	0.25
2101	1907	TYLGE	1306	2323	0.25
2102	2179	BRNWD	1201	1583	0.25
2103	1738	HORNE	1913	1685	0.25
2104	2040	CLBWS	8111	1682	0.25
2105	2488	CRSCN	1201	833	0.25
2106	1155	WEBBS	8624	2302	0.25
2107	2060	COMSO	1405	754	0.25
2108	2679	HMPHL	2721	518	0.25
2109	2196	WKATY	1718	2215	0.25
2110	1830	HMTRD	0001	967	0.25
2111	2324	SMFLD	2311	1417	0.24
2112	45	ECTHM	3321	1012	0.24
2113	2980	SMFLD	2322	41	0.24
2114	1885	LNCST	1601	681	0.24
2115	2022	LKBLT	2107	1100	0.24
2116	2546	DNISN	1206	920	0.24
2117	602	LWRDR	0002	994	0.24
2118	1476	REAST	1506	1208	0.24
2119	610	GRDPR	0831	1226	0.24
2120	1290	ROWLT	1104	1121	0.24
2121	2291	STAUG	0003	2162	0.24
2122	1841	MDWPK	9231	2416	0.24
2123	2081	EULES	8713	2185	0.24
2124	1935	KEENE	1503	833	0.24
2125	1059	MSLSW	0004	411	0.24
2126	1969	PRKWY	1561	1737	0.24
2127	1744	MSLMN	4009	237	0.24
2128	2101	KLNTF	1802	866	0.24
2129	1146	RCHRD	1203	837	0.24
2130	941	CLLVL	0003	679	0.24
2131	598	MESQN	1508	1788	0.24
2132	1883	RCHHL	0321	1739	0.24
2133	200	LMESA	1561	1426	0.24
2134	2760	LKBLT	2101	571	0.24
2135	1375	CDCSW	0006	1369	0.24
2136	137	LFKHL	2103	1954	0.24
2137	654	CRLTR	2005	677	0.24
2138	33	BRGPR	1103	900	0.24

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2139	2783	KLNCC	1704	2556	0.24
2140	1752	SYCRK	4511	1991	0.24
2141	1820	TRLWD	7721	1620	0.24
2142	1749	LOMAL	0014	588	0.24
2143	1542	BLTLN	0003	589	0.24
2144	1608	COPER	1202	976	0.24
2145	2312	PROAD	0002	841	0.24
2146	699	PCUST	2002	821	0.24
2147	2321	HORNE	1952	1275	0.23
2148	2219	IRVBL	2503	1304	0.23
2149	1650	WELRD	0002	744	0.23
2150	1112	PKRVL	1054	2567	0.23
2151	1207	PLANO	1105	60	0.23
2152	1495	DIBOL	1506	613	0.23
2153	951	MESQN	1506	65	0.23
2154	2880	NCSTH	1506	91	0.23
2155	2288	DUVAL	0462	1062	0.23
2156	2154	BLTON	1801	850	0.23
2157	533	HUTTO	2742	4671	0.23
2158	1595	OAKHL	3062	2282	0.23
2159	2825	SHDYG	7841	340	0.23
2160	698	SHRSW	6622	1624	0.23
2161	1742	BRNAV	0784	1896	0.23
2162	737	BNBOR	1202	736	0.23
2163	716	MRDCK	0001	2203	0.23
2164	1573	ENNIS	1905	44	0.23
2165	1660	AMLIA	0003	22	0.23
2166	2092	MLFRD	2101	970	0.23
2167	1642	WICKT	0421	137	0.23
2168	2778	BRKRG	0221	699	0.23
2169	2361	THSES	2402	1407	0.23
2170	488	ELCTR	1221	129	0.22
2171	1464	RCHRD	1207	1544	0.22
2172	1600	EULTB	5731	494	0.22
2173	2560	DGNST	0004	942	0.22
2174	2238	LUFKN	1205	1335	0.22
2175	2173	MTLDA	0007	1785	0.22
2176	676	GRMES	0511	1201	0.22
2177	1547	CDHIL	1803	1903	0.22
2178	2826	WNDWD	3672	265	0.22
2179	2774	MSTLT	1011	63	0.22
2180	56	VLYRN	2954	2748	0.22

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2181	1982	ROBNW	1503	1670	0.22
2182	528	MRSDO	9611	1762	0.22
2183	1336	HMPHL	2772	299	0.22
2184	2541	HLSES	0542	766	0.22
2185	2429	MAYFD	5521	3213	0.22
2186	1116	HLSBR	1204	554	0.22
2187	515	TYBLR	2804	2442	0.22
2188	1133	GRLND	1606	965	0.22
2189	1958	LKWOD	7432	1609	0.22
2190	1581	WHITE	3512	1533	0.22
2191	1758	ROWLT	1101	1255	0.22
2192	752	CKRHL	0005	1226	0.22
2193	2596	ALLEN	2403	1366	0.22
2194	1702	ROWLT	1102	807	0.22
2195	2435	SHRSW	6641	1005	0.22
2196	2016	MDLNW	1521	1788	0.22
2197	2050	MESFR	2101	2018	0.22
2198	868	CRLTN	1451	474	0.22
2199	1866	KNLTR	0008	902	0.22
2200	189	BAKKE	6912	1842	0.22
2201	1045	IRVNG	1401	1604	0.22
2202	176	WALST	0005	249	0.22
2203	622	TYEST	1509	383	0.22
2204	2397	KNEDL	6332	2191	0.22
2205	825	LVBRD	0004	1059	0.22
2206	1387	CRLJL	1506	1940	0.22
2207	2264	SMFLD	2391	292	0.22
2208	2622	DAVIS	3752	502	0.22
2209	2253	DAVIS	3741	1288	0.21
2210	1637	PWEST	1311	958	0.21
2211	1843	CLMET	0001	1592	0.21
2212	719	IRVND	1208	164	0.21
2213	2533	GRPTT	9921	582	0.21
2214	2061	TRNTY	7511	1451	0.21
2215	2224	SMFLD	2372	634	0.21
2216	36	OKLND	0004	799	0.21
2217	1984	IRVVV	2801	2407	0.21
2218	2057	FROKS	0002	1567	0.21
2219	1884	IRVNR	1505	1319	0.21
2220	1316	CMNCH	1402	1156	0.21
2221	889	BLMND	3221	95	0.21
2222	686	PLSTH	1302	1012	0.21

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2223	1170	PFFRD	3431	580	0.21
2224	242	PCUST	2009	2273	0.21
2225	1638	DALRK	1303	1271	0.21
2226	2091	TLRWT	2201	1821	0.21
2227	2545	WELRD	0003	511	0.21
2228	1946	MESTE	1211	1171	0.21
2229	39	LKMNT	0005	680	0.21
2230	2214	MYPRL	1803	599	0.21
2231	1668	VGCRK	8011	1531	0.21
2232	2339	ADISN	1604	1152	0.21
2233	2241	CRLTN	1402	798	0.21
2234	839	GNSVL	1204	505	0.21
2235	324	MAYFD	5511	4142	0.21
2236	2868	WFALS	0124	126	0.21
2237	2005	SHDYG	7831	97	0.21
2238	2598	THRNE	0001	1771	0.21
2239	2232	MESTE	1213	995	0.21
2240	774	PRSTN	0008	748	0.21
2241	2176	ARLNG	1282	839	0.20
2242	381	MESQT	1301	1454	0.20
2243	2629	WHTRK	0005	727	0.20
2244	2791	MSLSW	0006	94	0.20
2245	2283	ALLEN	2401	744	0.20
2246	144	RRNES	2401	4972	0.20
2247	1681	DCATR	1203	929	0.20
2248	2842	IRLBJ	3221	842	0.20
2249	1148	RWDHV	1903	1261	0.20
2250	899	CRNTH	2403	2764	0.20
2251	1671	ELGIN	1003	2107	0.20
2252	2624	HMPHL	2791	30	0.20
2253	2707	HKBRY	1115	15	0.20
2254	2395	WEAST	0621	15	0.20
2255	2708	JNKNS	0001	25	0.20
2256	1626	ROWLT	1105	1066	0.20
2257	1873	RNDRK	1504	988	0.20
2258	863	GRDPR	0881	1882	0.20
2259	1993	ENNIS	1904	1264	0.20
2260	2275	GRMES	0512	1195	0.20
2261	2259	SHSTH	1301	2221	0.20
2262	2190	GRHWY	5512	3134	0.20
2263	846	RNDRK	1507	891	0.20
2264	1677	TYLER	1002	861	0.20

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2265	1182	HLTOM	2421	1592	0.20
2266	775	WMRNR	0002	431	0.20
2267	1771	ODNTH	2073	671	0.20
2268	2355	WMMMR	2703	1120	0.20
2269	2473	RBNSN	2504	1646	0.20
2270	2628	LOMAL	0009	1007	0.20
2271	1634	KEENE	1501	1611	0.20
2272	1431	LKBLT	2102	1369	0.20
2273	1606	IRVNG	1408	1067	0.19
2274	2031	BSPRG	1902	2408	0.19
2275	1655	DALWT	2962	473	0.19
2276	2410	HNYGR	2401	468	0.19
2277	1871	HUTTO	2711	3776	0.19
2278	2210	RCHRD	1202	798	0.19
2279	244	GAVSW	0004	830	0.19
2280	1040	MEXIA	4040	861	0.19
2281	363	CKRHL	0006	258	0.19
2282	1165	FHLSW	1361	983	0.19
2283	2733	BNMNW	1102	411	0.19
2284	2221	FROKS	0005	1423	0.19
2285	1729	BLMED	1620	2019	0.19
2286	1667	NCSFA	1702	1305	0.19
2287	2502	HKBRY	1117	141	0.19
2288	2328	LWSNR	2241	1085	0.19
2289	1086	PCOIT	1006	1040	0.19
2290	1834	RSNHT	1171	2317	0.19
2291	177	CRLSP	1703	263	0.19
2292	2551	CDHCR	2055	1321	0.19
2293	2200	MTLDA	0005	1559	0.19
2294	2896	KLNTF	1803	1054	0.19
2295	1384	CRLUD	1304	1498	0.19
2296	1304	WCOLO	1317	1268	0.19
2297	252	MEANS	4411	37	0.19
2298	1934	FSTVW	0005	1762	0.19
2299	1829	WNTHW	1119	1318	0.19
2300	500	ITSCA	1701	747	0.19
2301	787	BRNWD	1206	1397	0.19
2302	2458	EDGCF	2252	401	0.19
2303	2104	STAUG	0004	2075	0.19
2304	2024	COPEL	3053	2070	0.19
2305	650	CRWLY	7011	424	0.19
2306	1477	KNLTR	0005	2858	0.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2307	2121	PPARK	1806	840	0.19
2308	2518	JUDCT	0006	1213	0.19
2309	471	DAVST	0008	27	0.19
2310	1896	GSTHW	1641	81	0.19
2311	2020	LWSNR	2231	789	0.19
2312	1827	WEAST	0616	777	0.18
2313	55	WEBBS	8622	1696	0.18
2314	2211	SACRC	5521	120	0.18
2315	317	HMTRD	0004	1059	0.18
2316	659	BRCRK	6522	2213	0.18
2317	779	DAVIS	3713	869	0.18
2318	2714	LEMON	0001	2161	0.18
2319	2366	BRHLW	7621	2882	0.18
2320	2800	GRAHM	0713	401	0.18
2321	1550	SANSM	3923	3786	0.18
2322	1804	WATSN	5361	2524	0.18
2323	1872	TLRWT	2203	815	0.18
2324	1921	WTAUG	4642	1270	0.18
2325	357	STNVL	1203	2267	0.18
2326	2450	BLKST	1771	1214	0.18
2327	2064	RCHHL	0353	1731	0.18
2328	2544	PCUST	2005	1716	0.18
2329	2390	LEMON	0009	1778	0.18
2330	2490	MDWCK	0005	1379	0.18
2331	2516	RSPCK	2142	930	0.18
2332	1769	INAIR	1411	948	0.18
2333	2711	SHNRW	1601	106	0.18
2334	2327	KILEN	1203	759	0.18
2335	2740	RRSTH	1707	609	0.18
2336	2387	MCDMT	2551	2214	0.18
2337	2584	TMPSE	1501	543	0.18
2338	1444	SWTWR	1321	140	0.18
2339	141	HUDSN	1605	146	0.18
2340	580	STNVL	1206	2519	0.18
2341	2637	CMHBL	8121	62	0.18
2342	2677	HORNE	1992	254	0.18
2343	2476	CDCSW	0004	1373	0.18
2344	1904	MRLNS	4003	938	0.18
2345	2142	MKNGB	5342	1257	0.18
2346	810	THRNE	0004	811	0.18
2347	1727	PSHIL	1603	1594	0.18
2348	2453	SSPNG	1203	1373	0.18

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2349	2353	MDTHN	1701	1524	0.18
2350	2099	WTAUG	4621	445	0.18
2351	917	BRYAN	0005	3880	0.18
2352	2559	ARLNG	1271	2077	0.17
2353	2578	WTAUG	4612	1230	0.17
2354	1067	RGFTW	6813	23	0.17
2355	133	ANDNR	2242	512	0.17
2356	2646	WATSN	5382	664	0.17
2357	2141	CRLTR	2003	1355	0.17
2358	2660	BLTLN	0005	881	0.17
2359	1808	HHSTH	1504	2390	0.17
2360	762	PRCRK	0004	1497	0.17
2361	1027	WSOTH	1021	2131	0.17
2362	2011	CRSWS	1401	1380	0.17
2363	2032	FRMBR	1801	1245	0.17
2364	1206	WHTRK	0002	1428	0.17
2365	2369	PNTGO	7122	1097	0.17
2366	591	CDCSW	0005	1705	0.17
2367	1874	PLSTH	1303	573	0.17
2368	1250	DUBLN	2214	689	0.17
2369	2857	GAVSW	0008	107	0.17
2370	711	ARTHR	0431	471	0.17
2371	873	BNMAG	1201	197	0.17
2372	2515	HHSTH	1503	1620	0.17
2373	2046	DUVAL	0483	2254	0.17
2374	1458	DCVSO	1107	1102	0.17
2375	2204	PPARK	1802	606	0.17
2376	#N/A	DFWSE	2712	24	0.17
2377	2621	RRSTH	1701	3176	0.17
2378	1851	MRTNS	1501	493	0.17
2379	2157	ROWLT	1106	1312	0.17
2380	1891	COPER	0402	169	0.17
2381	2027	BRKNR	1221	1154	0.17
2382	2073	IRVNR	1551	1367	0.17
2383	2467	ARTHR	0422	1054	0.17
2384	2499	RSPVY	1706	1342	0.16
2385	1528	KLBRG	0004	1171	0.16
2386	1193	DENAV	0673	61	0.16
2387	1200	IVANS	1621	61	0.16
2388	1199	CNEXP	0007	398	0.16
2389	2297	RWDHV	1907	894	0.16
2390	2412	CLYVL	9323	1423	0.16

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2391	843	RCHHL	0344	1247	0.16
2392	701	WSANG	2801	1340	0.16
2393	2923	WTAUG	4651	541	0.16
2394	1575	CRSGL	1302	1462	0.16
2395	2779	CRSCN	1202	626	0.16
2396	970	BRCRK	6513	1198	0.16
2397	1810	PCUST	2010	2259	0.16
2398	1381	PWEST	1310	685	0.16
2399	837	CRTLD	4731	2977	0.16
2400	1734	GRPVN	8222	2043	0.16
2401	2639	KNLTR	0001	2124	0.16
2402	523	PTENN	2354	524	0.16
2403	1587	CLBNR	1404	1330	0.16
2404	2248	WSTHL	3613	3363	0.16
2405	2730	ARMST	0005	1514	0.16
2406	88	GMINI	5811	3285	0.16
2407	1938	STNVL	1201	2533	0.16
2408	496	DESHR	1206	2238	0.16
2409	2585	GAVSW	0010	486	0.16
2410	274	IRVVV	2853	2601	0.16
2411	2457	PRKWY	1532	2134	0.16
2412	2359	RSPCK	2141	19	0.16
2413	2748	MCKMY	0812	133	0.16
2414	1081	RSPVY	1702	539	0.16
2415	609	ITSCA	1702	203	0.16
2416	2304	PRKRW	3352	1532	0.16
2417	1288	ADISN	1608	369	0.16
2418	2014	GRFRD	1002	382	0.16
2419	2709	DAVST	0001	576	0.16
2420	2255	DEALY	0004	2383	0.16
2421	32	VLYRN	2952	3425	0.16
2422	872	RCLNS	1402	725	0.16
2423	1413	CMTSW	0983	1080	0.16
2424	2249	LOMAL	0013	1056	0.16
2425	1894	ELKTN	2501	735	0.16
2426	1562	GRSMN	4029	955	0.15
2427	2272	FORSW	2025	549	0.15
2428	2348	ALNTH	2851	2093	0.15
2429	232	RDLML	2512	1208	0.15
2430	2371	MRSES	3019	13	0.15
2431	260	MDDTN	4321	918	0.15
2432	2921	PLHWY	3701	495	0.15

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2433	309	FRMNT	0005	483	0.15
2434	1856	PFFRD	3452	871	0.15
2435	2534	SORCY	0001	2557	0.15
2436	2054	RANGR	4311	925	0.15
2437	590	BNDRA	0004	722	0.15
2438	1061	WTAUG	4623	730	0.15
2439	2123	BRKRG	0211	310	0.15
2440	2600	MRSES	3015	582	0.15
2441	2833	STNVL	1202	73	0.15
2442	667	JNKNS	0005	552	0.15
2443	2480	FRMBG	1701	100	0.15
2444	2795	RWDHV	1904	516	0.15
2445	2199	LTVSB	5461	795	0.15
2446	2796	FSCRK	6721	1665	0.15
2447	1643	DCDAM	2002	907	0.15
2448	1718	MURPH	2752	2147	0.15
2449	566	CHROW	0001	136	0.15
2450	2439	WSOTH	1022	1797	0.15
2451	1566	LMESA	1512	1814	0.15
2452	2263	SHMNE	1403	995	0.15
2453	2177	MDTHS	1002	1265	0.14
2454	2822	SHDYG	7821	97	0.14
2455	1143	LKHLD	0002	1528	0.14
2456	1754	DAVIS	3731	767	0.14
2457	984	MKNNY	1202	1911	0.14
2458	1983	WRBND	2322	847	0.14
2459	2522	BLMED	1618	35	0.14
2460	2972	PLHWY	3703	14	0.14
2461	1220	EDGCF	2282	1054	0.14
2462	2608	WEBBS	8621	2832	0.14
2463	2874	LAVON	1402	155	0.14
2464	2761	MTLDA	0006	2011	0.14
2465	724	MESTE	1204	1828	0.14
2466	1577	CRNRD	0006	353	0.14
2467	534	QNLAN	1202	389	0.14
2468	1690	BRNWD	1205	1151	0.14
2469	2828	GRPVN	8231	398	0.14
2470	2319	GAVSW	0007	1541	0.14
2471	1968	ATNRN	3421	1962	0.14
2472	2893	WEAST	0620	578	0.14
2473	2684	PALRD	2208	1076	0.14
2474	1475	BLSRA	1602	158	0.14

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2475	1840	LOMAL	0005	395	0.14
2476	1168	MKNSW	2603	2604	0.14
2477	2945	FRNKF	0008	1342	0.14
2478	391	JKSES	3028	376	0.14
2479	1498	TYBLR	2802	998	0.14
2480	1175	RCLNS	1404	717	0.14
2481	2645	CGRSW	9811	58	0.14
2482	2388	ACRLY	1711	174	0.14
2483	2925	LEMON	0002	979	0.14
2484	2549	PLANO	1103	1877	0.14
2485	2643	DAVST	0006	1150	0.14
2486	2614	GAVSW	0001	1712	0.14
2487	1058	KLNCC	1701	2312	0.14
2488	105	MDLNE	0151	308	0.14
2489	2004	GODRD	8122	1053	0.14
2490	1967	DUVAL	0434	2491	0.14
2491	132	WINKS	0511	636	0.14
2492	2680	SHMNE	1405	795	0.13
2493	1916	BLMED	1617	320	0.13
2494	122	HUBRD	1402	1013	0.13
2495	2128	LIPAN	1301	510	0.13
2496	2814	TMNTH	1601	30	0.13
2497	351	COPEL	3054	828	0.13
2498	1530	PPARK	1807	889	0.13
2499	1092	DUBLN	1360	1101	0.13
2500	614	DLEON	0131	737	0.13
2501	1241	RNDRK	1506	1687	0.13
2502	2001	ROLTR	2911	1809	0.13
2503	547	GVODS	3072	2256	0.13
2504	593	HMPHL	2711	524	0.13
2505	2276	BLTLN	0004	640	0.13
2506	1372	WHTRK	0004	1165	0.13
2507	2239	SPRDL	4822	1197	0.13
2508	2495	IRLBJ	3211	2614	0.13
2509	2741	HORNE	1981	1573	0.13
2510	1292	GRLND	1603	313	0.13
2511	2309	BLMGR	1902	180	0.13
2512	1755	WSANG	2802	635	0.13
2513	1537	EMPCT	0005	71	0.13
2514	796	BDFWD	8922	2170	0.13
2515	2153	COPEL	3052	1309	0.13
2516	1492	ENTOH	0007	907	0.13

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2517	882	CNTRD	0001	2132	0.13
2518	2513	SHAMP	0003	1775	0.13
2519	24	MSLSW	0008	192	0.13
2520	929	DALWT	2921	288	0.13
2521	2368	WMRLD	0009	32	0.13
2522	2543	FRNKF	0003	497	0.12
2523	2257	FRMBG	1705	281	0.12
2524	#N/A	HUTTO	2723	3621	0.12
2525	994	BRNWD	1203	829	0.12
2526	2766	HLTOM	2461	849	0.12
2527	2815	BOWEN	3142	1193	0.12
2528	2094	KLNCC	1703	4088	0.12
2529	1821	BDFWD	8932	1709	0.12
2530	2065	CTYVW	2211	1462	0.12
2531	2262	ALLEN	2410	2338	0.12
2532	2830	HNTNG	1302	41	0.12
2533	750	CRLTR	2007	1449	0.12
2534	2667	PCOIT	1022	2125	0.12
2535	1986	ARLNG	1292	1563	0.12
2536	2343	EGFRD	0004	1864	0.12
2537	497	NMAIN	0262	416	0.12
2538	2443	MKNGB	5331	1451	0.12
2539	2604	PFFRD	3411	317	0.12
2540	2454	EDGCF	2231	868	0.12
2541	203	POYNR	1201	334	0.12
2542	326	LNCST	1603	1593	0.12
2543	1281	CLYVL	9312	1295	0.12
2544	2456	DGNST	0003	1161	0.12
2545	1965	CHROW	0002	110	0.12
2546	1097	CRLTN	1408	127	0.12
2547	1357	NPKWY	0011	4165	0.12
2548	942	WTHRF	2001	645	0.12
2549	2472	FHLSW	1311	1469	0.12
2550	2854	RRSTH	1704	3261	0.12
2551	2786	PKRVL	1053	1069	0.12
2552	#N/A	MDESA	4541	310	0.12
2553	2612	HKBRY	1102	1682	0.12
2554	1430	SHRSW	6631	1287	0.11
2555	1013	TYWST	2002	87	0.11
2556	1981	BLTLN	0001	681	0.11
2557	607	SMFLD	2323	620	0.11
2558	247	ENTOH	0005	1083	0.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2559	901	KERNS	2402	378	0.11
2560	2920	VGCRK	8031	1812	0.11
2561	371	ADMDS	6511	1050	0.11
2562	1499	MNWLL	1202	693	0.11
2563	1850	PFLGV	2003	2858	0.11
2564	891	ALPHA	0008	1256	0.11
2565	2664	PCOIT	1007	849	0.11
2566	2782	VANAL	1201	603	0.11
2567	1614	PLKST	0005	1134	0.11
2568	1525	CRSSN	7911	834	0.11
2569	437	SFTLK	4011	46	0.11
2570	2067	WEAST	0615	2153	0.11
2571	2080	ABBOT	1902	120	0.11
2572	2666	SCHRD	0003	360	0.11
2573	11	WEBBS	8634	1194	0.11
2574	195	CDHCR	2053	279	0.11
2575	2350	WFALS	0114	419	0.11
2576	2810	GNSVN	1401	28	0.11
2577	2651	PCOMM	3311	28	0.11
2578	2747	IRVNR	1510	430	0.11
2579	1743	BLTON	1805	1537	0.11
2580	1899	GRDPR	0891	891	0.11
2581	1957	CMTSW	0927	565	0.11
2582	372	BRHLW	7651	1149	0.11
2583	1892	WTAUG	4633	1049	0.11
2584	1363	MDDTN	4311	192	0.10
2585	2376	CRLFR	2155	1330	0.10
2586	2661	PFFRD	3421	858	0.10
2587	80	CRLFR	2159	1449	0.10
2588	2150	KLNTF	1801	1114	0.10
2589	1005	WGROB	8422	2694	0.10
2590	1977	GODRD	8112	1421	0.10
2591	2906	FRMBR	1807	849	0.10
2592	227	WITTS	1701	2021	0.10
2593	97	LIGSW	1621	49	0.10
2594	2869	CRLFR	2153	245	0.10
2595	2634	FRNKF	0004	1608	0.10
2596	975	SNYDR	1813	324	0.10
2597	1341	LFSTH	1405	216	0.10
2598	1487	BNTDR	0001	1314	0.10
2599	2713	NMAIN	0282	1345	0.10
2600	1370	LWRDR	0003	1783	0.10

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2601	2630	LIGSW	1603	2517	0.10
2602	2732	RDRSE	2607	5011	0.10
2603	2489	BLMGR	1901	269	0.10
2604	2599	TRLNW	1201	1167	0.10
2605	2425	BKBNT	1811	679	0.10
2606	2550	ELMGV	3651	2238	0.10
2607	2973	PRNTH	1403	20	0.10
2608	1948	CLBSN	8821	10	0.10
2609	156	WMRLD	0002	1566	0.10
2610	378	TYWST	2013	916	0.10
2611	509	IRVRS	4413	1353	0.10
2612	2296	RDLML	2532	1788	0.10
2613	857	RGLRW	0003	91	0.10
2614	2793	EDGCF	2221	862	0.10
2615	2904	CNEXP	0001	213	0.10
2616	2446	WTAUG	4622	1005	0.10
2617	2895	RRSTH	1705	934	0.10
2618	2824	RWALL	1201	1301	0.10
2619	2295	RNDRK	1501	803	0.10
2620	1723	SMFLD	2392	1030	0.10
2621	2358	TYOMN	1411	307	0.10
2622	2755	MNSTR	1202	268	0.10
2623	1328	CRTLD	4722	3303	0.10
2624	1107	GRPVN	8211	135	0.10
2625	833	CRLTN	1404	104	0.10
2626	506	BARRY	1801	84	0.10
2627	2654	WRTHM	5012	315	0.10
2628	356	SYCRK	4521	3155	0.10
2629	1518	PRKRW	3392	1676	0.09
2630	1584	MDWCK	0006	887	0.09
2631	763	CNTRD	0003	1385	0.09
2632	2555	AMLIA	0008	106	0.09
2633	2451	LKHLD	0008	1464	0.09
2634	2402	PSHIL	1601	1416	0.09
2635	927	LFKHL	2101	128	0.09
2636	2821	VENSW	2603	32	0.09
2637	866	IRLBJ	3212	3299	0.09
2638	1877	ENSSO	2003	503	0.09
2639	910	KLBRG	0001	410	0.09
2640	2508	GAVSW	0002	930	0.09
2641	1295	LWRDR	0004	804	0.09
2642	916	MAYFD	5531	1185	0.09

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2643	2636	BRNSO	1804	11	0.09
2644	2649	FRMBR	1808	684	0.09
2645	#N/A	MLDR2	1603	505	0.09
2646	2170	LKMNT	0001	203	0.09
2647	2794	FRMBR	1806	147	0.09
2648	2440	SORCY	0004	603	0.09
2649	651	FROKS	0006	992	0.09
2650	1616	RSNHT	1131	2718	0.09
2651	2689	RSPCK	2106	348	0.09
2652	507	NCRST	2203	987	0.09
2653	2764	DCATR	1204	654	0.09
2654	1635	RWALS	1851	1554	0.09
2655	2734	CMPST	0003	212	0.08
2656	1886	WALNT	0004	1475	0.08
2657	2756	FARON	4021	285	0.08
2658	2663	MDWPK	9211	1274	0.08
2659	2804	BRHLW	7631	633	0.08
2660	1119	WSOTH	1018	562	0.08
2661	2710	BRHLW	7642	935	0.08
2662	2931	BLMND	3272	12	0.08
2663	2780	NPKWY	0009	1290	0.08
2664	2006	ALPHA	0007	1465	0.08
2665	2974	PSHIL	1605	135	0.08
2666	2746	WWEST	1221	37	0.08
2667	844	IRVNG	1404	1448	0.08
2668	1447	WDGWD	1552	314	0.08
2669	52	VLARN	2951	2209	0.08
2670	2180	PCOIT	1002	674	0.08
2671	2817	GDNLV	1201	64	0.08
2672	2431	WDGWD	1561	1498	0.08
2673	1806	WALNT	0002	1227	0.08
2674	499	CURIE	7221	805	0.08
2675	2638	LSCOL	2142	13	0.08
2676	717	ENTOH	0003	13	0.08
2677	2742	DGNST	0008	117	0.08
2678	2986	WXOCF	1402	13	0.08
2679	445	WEAST	0626	291	0.08
2680	2593	WRTHM	5017	159	0.08
2681	893	RWDHV	1908	2306	0.08
2682	2529	GORMN	0411	545	0.08
2683	1772	DESHR	1202	1598	0.08
2684	1895	IRVND	1206	107	0.07

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2685	2603	HKHTS	1608	1312	0.07
2686	279	LKHL D	0006	737	0.07
2687	1995	BRNSO	1808	792	0.07
2688	1908	ARMST	0001	282	0.07
2689	2926	JNKNS	0008	27	0.07
2690	2751	ARLNG	1212	122	0.07
2691	2052	PEGAS	2321	136	0.07
2692	2745	ALPHA	0010	517	0.07
2693	2887	GAVSW	0011	109	0.07
2694	2554	MESTE	1208	995	0.07
2695	2697	WNRTH	1416	728	0.07
2696	945	WTHRF	2002	1718	0.07
2697	315	FARON	4031	1142	0.07
2698	2254	MURPH	2753	1063	0.07
2699	2872	KLELM	2202	2378	0.07
2700	386	WWEST	1216	250	0.07
2701	990	ROLTR	2913	1727	0.07
2702	735	CRNRD	0007	754	0.07
2703	2466	LOMAL	0002	518	0.07
2704	2789	RKCRK	6111	2708	0.07
2705	2642	LVBRD	0005	1364	0.07
2706	751	ATNRN	3411	3007	0.07
2707	2898	SCHRD	0006	488	0.07
2708	316	FRNKF	0005	1086	0.07
2709	721	SORCY	0003	843	0.07
2710	2768	GLNHV	3953	1631	0.07
2711	903	HURST	1841	1001	0.07
2712	2669	EULSO	9121	118	0.07
2713	1703	TMPNW	1101	2633	0.07
2714	1724	CLBWS	8121	268	0.07
2715	2507	SHNRW	1610	434	0.07
2716	414	KRGRV	2401	15	0.07
2717	245	DENDR	0008	90	0.07
2718	2662	PJPTR	3212	30	0.07
2719	1825	NCRST	2202	30	0.07
2720	2818	HMPHL	2792	456	0.07
2721	1583	DALRK	1309	876	0.07
2722	86	SCSES	1201	281	0.06
2723	295	VLARN	2955	4545	0.06
2724	2461	REGST	0003	968	0.06
2725	2146	FRSTN	1604	334	0.06
2726	1911	DAVIS	3723	350	0.06

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2727	2434	MKNNY	1201	1311	0.06
2728	2769	DESPR	1404	642	0.06
2729	2287	PRSTN	0005	1191	0.06
2730	2912	MDWPK	9221	769	0.06
2731	2807	TMPNW	1106	1001	0.06
2732	2610	BLNKT	0701	280	0.06
2733	#N/A	MLDR2	1601	364	0.06
2734	1682	WHTRK	0008	1514	0.06
2735	2590	PALRD	2207	1126	0.06
2736	307	WMRLD	0001	222	0.06
2737	2883	HMPHL	2752	295	0.06
2738	2587	SANSM	3921	1381	0.06
2739	841	RCLNS	1408	107	0.06
2740	1823	RRNES	2402	3859	0.06
2741	2844	GRHWY	5521	895	0.06
2742	335	CURIE	7231	1080	0.06
2743	12	CHROW	0004	200	0.06
2744	2399	LOMAL	0012	714	0.05
2745	2743	TMNTH	1604	55	0.05
2746	2736	WGROB	8412	3894	0.05
2747	2982	STERT	2702	19	0.05
2748	263	WATSN	5352	1900	0.05
2749	2521	MURPH	2756	3603	0.05
2750	2325	ARLNG	1222	97	0.05
2751	81	IRLBJ	3231	2504	0.05
2752	2208	FRMNT	0008	1052	0.05
2753	2403	KLELM	2204	3070	0.05
2754	2671	PLANO	1106	492	0.05
2755	780	GSTHW	1622	20	0.05
2756	2951	GSTHW	1672	40	0.05
2757	2803	DNINR	1401	81	0.05
2758	814	REAST	1501	304	0.05
2759	1124	PFLGV	2007	3994	0.05
2760	1282	MRSES	3016	41	0.05
2761	2737	IRVHF	2303	86	0.05
2762	2436	HMPHL	2713	130	0.05
2763	2273	PSHIL	1607	458	0.05
2764	444	CLLVL	0001	503	0.05
2765	1179	CLBNR	1401	22	0.05
2766	1189	PCOIT	1004	735	0.04
2767	2847	FRMBG	1708	45	0.04
2768	2617	BNMNW	1101	204	0.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2769	2785	RGFTW	6822	23	0.04
2770	2655	ROANW	9511	1459	0.04
2771	290	MKNSW	2604	2101	0.04
2772	10	GVOIDS	3052	1324	0.04
2773	2777	CRLUD	1301	24	0.04
2774	2279	THRNE	0002	1705	0.04
2775	124	WFALS	0163	361	0.04
2776	1502	ARMST	0011	900	0.04
2777	2850	LOMAL	0007	151	0.04
2778	389	CRLUD	1302	152	0.04
2779	2354	FRNKF	0001	964	0.04
2780	2452	COMRC	1204	587	0.04
2781	131	CKRHL	0008	1666	0.04
2782	2647	NPKWY	0012	2231	0.04
2783	1181	HUTCH	1505	26	0.04
2784	2656	MESFR	2104	156	0.04
2785	2837	ALPHA	0015	838	0.04
2786	2835	RCHHL	0394	237	0.04
2787	384	CLLVL	0004	53	0.04
2788	2539	DALWT	2972	240	0.04
2789	898	AMLIA	0006	80	0.04
2790	134	RGLRW	0002	215	0.04
2791	981	PALMR	2201	54	0.04
2792	2243	MCGHR	2004	27	0.04
2793	2394	HKBRY	1111	27	0.04
2794	2110	MSTLT	1032	27	0.04
2795	2983	WALST	0007	27	0.04
2796	2682	HKBRY	1103	244	0.04
2797	#N/A	PRMED	4404	1154	0.04
2798	2333	HURST	1852	1508	0.04
2799	2270	RNKSW	5412	28	0.04
2800	2870	WWEST	1220	198	0.04
2801	#N/A	CMTSW	0946	865	0.03
2802	2864	COPER	0401	116	0.03
2803	2966	PARIS	1205	29	0.03
2804	2979	SMBMG	1701	29	0.03
2805	1685	BRKRG	0213	411	0.03
2806	2940	EULSO	9141	59	0.03
2807	2658	LWSNR	2211	1421	0.03
2808	1556	GODRD	8151	801	0.03
2809	491	CNEXP	0003	1396	0.03
2810	2838	HKBRY	1104	121	0.03

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2811	1082	CRSGL	1303	91	0.03
2812	1125	NPKWY	0008	882	0.03
2813	2015	WWEST	1218	1015	0.03
2814	344	WEBBS	8633	2469	0.03
2815	2705	DENAV	0652	31	0.03
2816	2723	WALST	0002	31	0.03
2817	2862	PROAD	0009	124	0.03
2818	2867	SMFLD	2362	63	0.03
2819	2419	FROKS	0008	1514	0.03
2820	2114	ALPHA	0016	1817	0.03
2821	874	JNKNS	0004	129	0.03
2822	2853	EMPCT	0002	98	0.03
2823	858	PRKRW	3331	134	0.03
2824	883	BRTRD	7322	640	0.03
2825	2981	STERT	2701	34	0.03
2826	788	BKWST	0006	804	0.03
2827	2823	JUDCT	0008	140	0.03
2828	2885	COTRD	0004	105	0.03
2829	#N/A	MDLNE	0132	35	0.03
2830	161	CHROW	0005	179	0.03
2831	333	MKNNY	1204	36	0.03
2832	1320	CRNRD	0005	361	0.03
2833	2302	CKRHL	0007	73	0.03
2834	782	WHTRK	0003	1276	0.03
2835	2839	CMPST	0001	454	0.03
2836	2960	LSCOL	2135	608	0.03
2837	2860	DALWT	2952	656	0.03
2838	2517	FRNKF	0006	1726	0.03
2839	1142	RNDRK	1509	1439	0.03
2840	2672	ROANW	9522	42	0.02
2841	2866	SHDYG	7812	126	0.02
2842	2525	BNDRA	0001	845	0.02
2843	108	KYSTN	1011	89	0.02
2844	824	FRMBR	1802	1117	0.02
2845	1445	RSKMN	3078	135	0.02
2846	1238	WALST	0004	45	0.02
2847	2848	PJPTR	3221	46	0.02
2848	2882	HORNE	1923	1572	0.02
2849	2948	GSTHW	1613	93	0.02
2850	2892	TMSTH	1405	519	0.02
2851	2315	HMPHL	2723	48	0.02
2852	2834	SHAMP	0002	1746	0.02

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2853	1085	DAVIS	3743	200	0.02
2854	1952	COMRC	1201	1018	0.02
2855	2873	LMBLN	0001	2042	0.02
2856	2307	LAVON	1453	949	0.02
2857	2935	CRLTR	2006	54	0.02
2858	2971	PLANO	1108	491	0.02
2859	2615	DESHR	1208	439	0.02
2860	2919	FRMBR	1853	55	0.02
2861	2613	HMPHL	2733	116	0.02
2862	2212	PSHIL	1606	1392	0.02
2863	2846	DALWT	2941	309	0.02
2864	1994	FRMBG	1706	62	0.02
2865	1449	PROAD	0001	126	0.02
2866	867	PLGRV	0004	384	0.02
2867	2413	ADISN	1603	192	0.02
2868	2317	MSLSW	0003	193	0.02
2869	114	HKBRY	1109	129	0.02
2870	879	RSNHT	1152	1039	0.02
2871	2775	SORCY	0002	66	0.02
2872	1865	HMPHL	2742	466	0.02
2873	993	CDCSW	0001	273	0.01
2874	2913	MSTLT	1042	500	0.01
2875	1307	WHTRK	0006	1311	0.01
2876	2245	STNVL	1204	828	0.01
2877	2908	COTRD	0005	228	0.01
2878	2618	DGNST	0005	154	0.01
2879	786	WALNT	0001	1468	0.01
2880	2720	DESPR	1401	1700	0.01
2881	1657	TYOMN	1402	1615	0.01
2882	2819	BRYAN	0007	244	0.01
2883	2891	ROBNW	1501	849	0.01
2884	925	WFALS	0143	171	0.01
2885	696	PROAD	0008	1206	0.01
2886	#N/A	DNINR	1404	177	0.01
2887	2155	VLYRN	2957	499	0.01
2888	2978	RSPCK	2105	313	0.01
2889	2889	FHLSW	1382	108	0.01
2890	2841	DALWT	2992	332	0.01
2891	2422	ADISN	1602	226	0.01
2892	2623	COMSO	1403	463	0.01
2893	273	BAYLC	1201	116	0.01
2894	2641	NHNSW	0001	469	0.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2895	1324	LMBLN	0008	119	0.01
2896	851	WEAST	0628	241	0.01
2897	#N/A	TIODE	9622	974	0.01
2898	2907	DGNST	0001	270	0.01
2899	2648	EULES	8714	811	0.01
2900	923	ELKTN	2503	839	0.01
2901	360	MAPLE	0007	143	0.01
2902	876	LOMAL	0004	145	0.01
2903	2899	RECCR	0005	157	0.01
2904	365	WALNT	0008	873	0.01
2905	2962	LSCOL	2148	1572	0.01
2906	2953	JNKNS	0002	197	0.01
2907	1070	WEAST	0627	205	0.00
2908	2719	SHDYG	7832	1854	0.00
2909	2840	CNEXP	0008	414	0.00
2910	2901	FLMSO	3711	1661	0.00
2911	2752	VGCRK	8021	211	0.00
2912	2856	BRYAN	0002	213	0.00
2913	2894	HKBRY	1113	427	0.00
2914	2594	TYBLR	2806	214	0.00
2915	2582	JUDCT	0004	216	0.00
2916	2849	CNEXP	0005	463	0.00
2917	529	ENTOH	0004	2003	0.00
2918	2914	WMRNR	0003	799	0.00
2919	2526	LWSNR	2212	1410	0.00
2920	2915	PWEST	1306	286	0.00
2921	2957	KNLTR	0009	861	0.00
2922	443	CNEXP	0002	880	0.00
2923	2571	TYLGE	1314	946	0.00
2924	2811	CURIE	7222	970	0.00
2925	954	COTRD	0008	1352	0.00
2926	2018	TMPNW	1103	682	0.00
2927	886	JUDCT	0003	1775	0.00
2928	2881	ARMST	0003	366	0.00
2929	2725	INAIR	1414	766	0.00
2930	348	CKRHL	0004	424	0.00
2931	2227	MDWCK	0008	888	0.00
2932	915	BDFWD	8911	937	0.00
2933	1161	SCHRD	0004	1924	0.00
2934	2903	WEBBS	8613	634	0.00
2935	2916	FRMNT	0007	703	0.00
2936	935	CURIE	7241	713	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2937	322	MAPLE	0002	910	0.00
2938	2763	IRLBJ	3222	1033	0.00
2939	2528	BKWST	0004	1053	0.00
2940	745	ANARN	1911	19	0.00
2941	527	FRMBG	1702	62	0.00
2942	166	DFWSW	2202	57	0.00
2943	358	AMLIA	0005	10	0.00
2944	417	ALPHA	0004	22	0.00
2945	328	DALLW	0002	62	0.00
2946	1693	SCHRD	0008	74	0.00
2947	2338	LUFKN	1204	33	0.00
2948	958	PROAD	0006	133	0.00
2949	1506	ARPCM	4169	11	0.00
2950	2827	FRMBG	1704	37	0.00
2951	359	DFWSW	2204	24	0.00
2952	1699	RRWES	1603	11	0.00
2953	2477	CHROW	0006	82	0.00
2954	1919	COTRD	0003	109	0.00
2955	2762	SHSTH	1302	20	0.00
2956	2570	STERT	2704	10	0.00
2957	2716	RNKSW	5413	37	0.00
2958	2770	EXPKY	8141	23	0.00
2959	2964	MDDTN	4322	26	0.00
2960	2888	STERT	2703	333	0.00
2961	2691	WWEST	1217	102	0.00
2962	2695	LKWOD	7421	43	0.00
2963	2698	RVRFT	0001	28	0.00
2964	2485	RSPCK	2133	778	0.00
2965	2879	CPLSO	4311	95	0.00
2966	2447	MAPLE	0008	214	0.00
2967	2832	INAIR	1442	114	0.00
2968	1163	CURIE	7212	20	0.00
2969	2816	AMLIA	0007	93	0.00
2970	2884	BRNAV	0774	205	0.00
2971	2900	NPKWY	0007	180	0.00
2972	2928	ALLEN	2405	27	0.00
2973	2930	ARMST	0008	246	0.00
2974	2932	COLDG	4048	10	0.00
2975	2933	COMRC	1202	49	0.00
2976	2934	COTRD	0001	11	0.00
2977	2941	EXPKY	8112	11	0.00
2978	2942	FRMBG	1703	31	0.00

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIFI Ranking	2015 SAIFI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIFI Value
2979	2943	FRMNT	0006	12	0.00
2980	2949	GSTHW	1651	13	0.00
2981	2950	GSTHW	1662	13	0.00
2982	2952	INAIR	1421	18	0.00
2983	2956	KNLTR	0007	12	0.00
2984	2968	PJPTR	3231	25	0.00
2985	2970	PJPTR	3242	76	0.00
2986	2975	PTENN	2356	14	0.00
2987	2976	REGST	0007	10	0.00
2988	2985	WMMMR	2704	18	0.00
2989	#N/A	ALPHA	0012	14	0.00
2990	#N/A	BLMND	3223	230	0.00
2991	#N/A	DFWSE	2710	72	0.00
2992	#N/A	DFWSE	2713	17	0.00
2993	#N/A	FBRIW	1901	305	0.00
2994	#N/A	GLSCN	6221	20	0.00
2995	#N/A	PAULN	2503	115	0.00
2996	#N/A	PWEST	1305	15	0.00
2997	#N/A	RRWES	1623	716	0.00
2998	#N/A	SCHRD	0002	297	0.00

NOTES:

EMMAS4021 was transferred to EMMAS4022 (new substation transformer and breaker)
MDLNE0163 was transferred to MDLNE0161 (new substation transformer and breaker)
MDLNE0133 was transferred to MDLNE0131 (new substation transformer and breaker)
MDLNE0141 was transferred to MDLNE0142 (new substation transformer and breaker)
MDLNE0122 was transferred to MDLNE0121 (new substation transformer and breaker)

Service Quality Report to the Public Utility Commission of Texas

Distribution Feeder Indices for Forced Interruptions

List all Distribution Feeders on Texas System

Total Number of Feeders

With 10 or more Customers

2998

Add or Delete Rows as Necessary

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
1	66	SBEAN	6011	182	2535.96
2	464	KNOTT	5221	60	2104.87
3	48	BRNSY	1211	135	1989.42
4	1020	NWARD	3511	63	1842.49
5	143	COYAN	6321	311	1689.68
6	1	CWIND	6311	27	1636.21
7	18	DHIDE	2821	116	1553.11
8	6	DHIDE	2811	105	1537.57
9	85	RYLTY	1431	76	1496.86
10	24	CRNES	2711	143	1470.98
11	543	LOVNG	2521	44	1428.34
12	15	ELMAR	3211	134	1314.10
13	112	MASON	3421	53	1313.66
14	22	MSTNG	2611	145	1235.99
15	656	WICKT	0431	18	1220.75
16	114	WINKS	0531	48	1220.46
17	7	RYLTY	1411	126	1212.03
18	11	MDFRM	2111	63	1074.73
19	108	SNDHL	3821	61	1054.56
20	625	SMOUR	0721	18	1018.49
21	41	MIDWY	0621	141	1007.73
22	2947	GSMTH	1731	49	974.85
23	40	EMMAS	4022	60	932.94
24	8	BLKRV	8311	48	910.52
25	273	NCWDN	1121	59	904.60
26	1062	CHALK	0951	73	858.25
27	2	BARNW	4511	72	838.93
28	34	MSTNG	2621	72	810.01
29	57	UPTON	0721	121	803.18
30	436	MNFLD	2672	2275	789.04
31	200	GLSCN	6211	119	785.41
32	1263	HNTNG	1306	1085	743.73
33	191	SCURY	1921	101	736.62
34	327	CNANG	1806	2458	734.11
35	1609	COHMA	1111	730	722.25
36	558	WXHCH	1205	972	711.31
37	118	CHYNE	9111	30	711.24
38	147	ESKSW	2711	107	711.04

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
39	10	PLDAV	4231	73	703.17
40	#N/A	STANT	1313	162	700.11
41	1147	FRNKS	1201	385	699.91
42	689	HOWRD	3921	74	693.02
43	2119	PGSTH	7011	43	684.18
44	115	WINKS	0521	51	679.46
45	980	SWTWR	1341	246	678.01
46	514	MKNSW	2601	3198	665.31
47	1945	NCDCH	1203	1825	658.65
48	263	PMBRK	1821	73	642.45
49	61	CLCTY	1011	1056	638.54
50	132	ELMAR	3222	87	637.61
51	1648	FSCRK	6732	4208	632.54
52	19	JDKNS	0821	38	626.46
53	838	RSPCK	2131	58	624.65
54	#N/A	GASLD	4211	101	614.86
55	407	BKWWF	0521	463	613.75
56	157	PLDAV	4211	57	603.61
57	2071	PLKST	0001	786	603.54
58	72	TYLGE	1311	809	593.44
59	373	UPTON	0711	170	586.58
60	193	EMMAS	4012	86	582.97
61	316	MDLNE	0161	992	581.87
62	2915	RDRSE	2605	736	567.29
63	626	MIDWY	0612	474	548.60
64	4	BARNW	4521	101	544.40
65	187	PLDAV	4221	219	542.12
66	1864	WHITE	3521	1122	535.99
67	23	MASON	3431	142	529.16
68	474	FARON	4011	642	520.47
69	511	GYVLM	8611	14	514.53
70	2826	PRHLL	2402	59	509.64
71	1069	GRDNC	1211	49	504.53
72	246	BOWIE	0621	11	497.69
73	2408	OKCLS	0006	687	496.62
74	17	RYLTY	1421	453	494.84
75	349	SCURY	1911	172	491.17
76	688	PEGAS	2311	121	486.02
77	1201	BSPRW	2532	1604	481.20
78	952	TMNTH	1606	232	480.96
79	21	GSMTH	1721	47	480.81
80	49	GLSCK	2411	240	480.26

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
81	1169	ELCTR	1211	279	479.03
82	2391	GRSMN	3027	362	476.08
83	856	MCGRG	1902	491	473.77
84	124	ACRLY	1721	60	472.21
85	68	MEXIA	4008	690	470.51
86	138	BRNSY	1221	79	469.22
87	1202	WCITY	2402	684	468.68
88	141	ALVRD	1501	1172	460.29
89	272	STHRL	0004	1278	455.40
90	589	LAVON	1401	1714	450.62
91	43	FORSN	5632	237	447.59
92	463	GSMTH	1742	37	447.33
93	94	DGLAS	2401	754	447.19
94	2075	CLKVL	1203	633	445.99
95	1795	DENAV	0683	884	445.92
96	14	CHICC	1701	55	444.84
97	526	TYEST	1506	479	441.92
98	86	BLSRA	1601	1404	440.86
99	854	FROKS	0004	118	439.47
100	9	PGSTH	7021	135	436.79
101	1370	FRNKS	4168	968	436.70
102	154	AMMFG	5611	813	433.85
103	2633	BRIRV	6921	2448	431.05
104	84	ARPMN	4149	313	427.47
105	59	KNAPP	4021	31	422.94
106	768	FORSN	5642	42	421.79
107	16	VANSB	1501	797	416.84
108	1748	FORSN	5611	12	412.92
109	886	RTHGB	1411	680	411.19
110	1113	KMASB	1721	105	407.89
111	350	BRIRV	6922	3406	403.34
112	830	ANDRD	0921	91	399.06
113	201	FRFWS	3004	822	394.99
114	36	TYLNE	1605	1181	392.41
115	2493	MCGRG	0776	222	387.96
116	425	NHNSW	0006	946	384.42
117	2607	MCHSN	1201	244	382.85
118	1519	CRANE	0311	791	382.77
119	592	LKTMS	2412	12	381.42
120	222	CRGCC	2703	635	380.43
121	819	SPRTN	1801	1843	379.23
122	1073	MRDCK	0004	824	378.78

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
123	872	FRNKF	0007	1172	378.14
124	1139	FKLCY	5121	105	377.99
125	1223	TYLNE	1607	782	377.55
126	2165	SHAMP	0004	1142	376.81
127	77	GSMTH	1732	45	374.74
128	2409	SNYDR	1823	1472	370.33
129	1432	BRHLW	7622	1130	367.63
130	1380	MEXIA	3016	279	364.58
131	328	NCDSW	3811	1469	363.61
132	1831	MKNGB	5311	487	362.31
133	20	ELMAR	3212	38	362.27
134	561	CNANG	1804	192	357.34
135	2648	CHICW	1302	202	356.22
136	151	TXHRV	1611	169	355.57
137	1176	GRDNE	9211	439	354.23
138	628	ADMDS	6532	466	350.40
139	271	TIODE	9632	413	349.23
140	520	MDLNE	0131	2564	344.23
141	2724	GRSMN	3071	333	342.23
142	44	NOLNW	2111	23	340.13
143	2098	RGLRW	0001	34	337.64
144	775	NCDCH	1205	1084	334.62
145	1739	BNBRK	4122	2743	334.53
146	215	NCNTH	1806	868	332.50
147	1110	BLMND	3241	231	331.40
148	295	FHLSW	1321	414	329.34
149	134	WELCH	4911	22	326.24
150	2236	MDWCK	0004	1750	326.14
151	1954	MSHLN	0007	724	324.55
152	126	MDLNW	1531	1754	322.97
153	1256	PRKRW	3321	163	317.65
154	76	LKTMS	2411	95	314.25
155	3	MASON	3411	30	313.57
156	476	NECSP	2401	564	313.45
157	306	CGDEL	5411	28	311.34
158	360	IRVNE	1305	236	310.22
159	459	LAVON	1451	1020	308.79
160	5	LOVNG	2511	51	308.06
161	258	MEXIA	4023	616	306.72
162	2344	PRNTH	1405	986	306.13
163	252	TYLNE	1624	259	304.60
164	1019	BSPSW	0812	1076	304.23

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
165	2501	SNYDR	1822	1616	302.76
166	304	NCSTH	1503	916	302.67
167	457	CRISP	1501	916	299.22
168	2765	WATSN	5372	1339	297.64
169	2573	PRNTH	1406	1021	297.12
170	2880	BRKTN	1202	120	296.84
171	810	MNWLL	1206	1105	296.46
172	424	CNI45	1202	820	296.27
173	1067	FERIS	1103	988	295.52
174	667	DCATR	1201	1258	294.35
175	2156	DNISN	1202	819	293.99
176	2393	WND CR	0221	572	293.82
177	2150	PKRVL	1051	4720	293.26
178	146	MDLNE	0112	363	293.14
179	671	ENNIS	1902	1260	292.95
180	536	AYERS	4421	1481	292.36
181	607	PLKST	0007	1784	291.69
182	1676	PAYSW	1205	724	291.26
183	583	ENSSO	2004	1202	291.00
184	1009	CHRNO	1201	517	290.84
185	#N/A	RYSSW	2803	2278	290.26
186	1125	AMMFG	5621	553	290.24
187	579	NCDCH	1201	781	290.03
188	442	RSNHT	1162	1514	290.02
189	899	IRVND	1205	218	288.12
190	492	MNWLE	1702	1287	286.34
191	1280	ROGRS	1301	768	285.69
192	1094	SMFLD	2381	849	285.68
193	568	JKSES	3029	1183	285.11
194	2261	SNYDR	1852	1347	284.39
195	2855	OTTOJ	3060	17	282.98
196	779	CLKVL	1201	431	282.25
197	260	BLVUE	1111	358	281.64
198	64	CRNAT	4121	64	280.99
199	437	TRIRA	6222	998	280.56
200	881	WLSPT	1001	1956	279.82
201	91	WBROK	3011	199	279.67
202	2791	TRL SW	2401	22	279.67
203	1858	RDLML	2552	281	277.63
204	136	WXHNW	2901	179	277.50
205	2057	CKRHL	0001	415	276.33
206	359	WDGWD	1531	1516	275.77

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
207	2646	HMTRD	0003	428	275.71
208	171	CNI45	2401	608	274.99
209	846	COPEL	3055	2178	274.57
210	418	CNSES	3056	2646	274.16
211	2102	KLNPS	1105	1556	273.24
212	1207	MNWLL	1207	2096	271.74
213	2518	NMAIN	0241	712	271.07
214	212	ODESA	0212	885	270.55
215	26	ANDRD	0931	191	269.90
216	944	RYSSW	2804	2188	269.35
217	46	NCWDN	1111	801	269.03
218	2158	MYPRL	1801	158	267.43
219	2053	HSKAV	0004	1315	267.21
220	2334	GLNHV	3992	1158	266.54
221	1423	ATHNS	1201	971	266.51
222	599	KLRPR	9011	2738	265.62
223	1820	ODNTH	2033	676	264.10
224	358	BRKNR	1211	116	263.25
225	1463	GRPTT	9911	697	262.73
226	1870	SBEND	0611	171	262.67
227	397	ECTHP	4911	1195	260.49
228	#N/A	PRMED	4402	867	259.40
229	2332	ARCTY	1321	890	258.84
230	2093	CRLTN	1403	211	258.36
231	882	TEGMN	3038	1664	258.35
232	2167	AIRPK	8411	782	257.56
233	220	TRIRA	6221	634	257.09
234	1104	WBOSE	1102	347	255.69
235	1428	DALWT	2931	1563	254.98
236	1868	CLKVL	1202	1265	254.82
237	2160	HKBRY	1105	185	252.87
238	2379	WNDCR	0241	708	252.45
239	1798	KNLTR	0011	1852	252.17
240	683	PARIS	1206	1024	252.00
241	2684	KLELM	2201	2428	251.66
242	83	TSLVL	4008	2029	251.66
243	127	WICKT	0411	250	250.27
244	907	CLCTY	1021	680	249.26
245	205	DWSON	3121	28	249.14
246	299	RDLML	2571	365	248.27
247	1235	EGFRD	0005	738	247.91
248	340	PLSTN	1004	1576	247.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
249	394	LTFRD	3011	945	246.10
250	933	INDIA	2501	376	246.06
251	2058	OAKHL	3082	1449	245.00
252	2140	RWDHV	1902	967	244.46
253	2011	STAUG	0008	2057	244.42
254	1713	LVOAK	1601	863	243.82
255	1304	PLKST	0002	837	243.22
256	202	LFEST	1905	1791	242.40
257	1164	BRHLW	7612	710	239.09
258	1758	BLKST	1781	1928	239.00
259	166	BAKKE	6922	1458	238.94
260	2984	WALST	0008	11	238.19
261	794	MRSES	4005	751	238.10
262	977	SUNNY	2303	590	237.47
263	997	PLGRV	0003	594	237.22
264	2321	WMRLD	0006	593	237.15
265	1001	CNEXP	0004	912	236.89
266	2730	CLCRK	1011	204	236.85
267	1364	LNCST	1602	1870	235.56
268	2338	BRKRG	0242	24	235.34
269	1942	BKBNT	1821	1148	235.25
270	2912	ARMST	0006	613	235.17
271	294	HNTNG	1307	1499	234.95
272	2462	BRGPR	1101	627	234.78
273	2441	MRTNS	1502	508	233.08
274	207	TYEST	1501	1757	232.78
275	2694	PAYSW	1223	115	232.52
276	801	KMASB	1711	304	232.27
277	555	LMBLN	0005	686	232.19
278	269	RCLNS	1406	527	232.17
279	1973	ALDTU	9411	2505	231.99
280	2685	BSPSW	0832	406	231.75
281	2030	ADISN	1605	1106	229.85
282	839	GVFTW	1802	903	229.40
283	560	HURST	1872	2104	228.97
284	39	TRPMN	4001	784	228.94
285	2874	BNDRA	0013	146	228.61
286	1706	ANDNR	2231	1086	228.02
287	1148	PTENN	2353	936	228.01
288	443	FLRTN	3721	75	227.71
289	919	HOWRD	3911	38	226.69
290	1226	EDDYS	0425	411	226.11

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
291	2329	DEALY	0003	1773	225.89
292	913	MDLNW	1522	1180	224.96
293	615	OAKCK	2211	45	224.78
294	181	LUFKN	1208	1786	224.41
295	461	LKMNT	0002	987	222.94
296	1963	NCSTH	1504	63	222.58
297	1496	LAVON	1406	1476	222.05
298	62	KYSTN	1031	26	221.42
299	2184	LMBLN	0003	181	221.21
300	949	CAMRN	1203	1220	220.49
301	698	ANDNR	2252	241	219.58
302	690	TNSCL	1104	198	218.99
303	50	TYLNE	1613	464	218.71
304	210	REYST	4051	1076	218.10
305	1904	COMRC	1203	682	217.84
306	1680	ALNTH	2854	690	217.65
307	2627	SANSM	3911	1479	217.26
308	156	RICES	0208	715	217.17
309	2483	FORSW	2053	3210	215.67
310	1416	HLSES	0561	1825	214.42
311	545	JKWST	4033	748	212.98
312	2505	ATNRN	3412	5640	212.61
313	413	CRLTN	1454	347	212.44
314	2583	BRNAV	0762	2393	211.45
315	111	PRNTH	1404	1474	211.45
316	412	TRNTY	7521	1165	211.38
317	862	WHITE	3531	1922	211.01
318	466	WSTHL	3621	4999	210.39
319	1319	ODESA	0242	640	210.37
320	303	VALVW	1802	431	209.99
321	981	OAKHL	3052	765	209.57
322	953	KNEDL	6312	3080	208.20
323	1212	REAST	1502	1323	208.05
324	165	BNBOR	1203	310	205.83
325	1349	BSPSW	0851	1426	205.81
326	319	CRLTN	1453	297	205.41
327	789	MKNSW	1602	550	203.04
328	796	RHOME	2401	1183	202.64
329	2780	ALNSW	2651	2054	202.40
330	198	EDGWD	1101	629	201.28
331	499	MDLNW	1582	2061	201.23
332	251	TYEST	1508	631	200.19

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
333	426	LFEST	1902	1044	199.92
334	345	LWRDR	0001	1166	199.69
335	2061	CRLUD	1303	616	199.63
336	2904	MDAIR	2912	851	199.28
337	324	ARCTY	1311	431	199.04
338	237	BNDRA	0009	718	198.82
339	544	CRLJL	1505	925	198.66
340	323	WNDCR	0252	912	198.49
341	1460	LUFKN	1207	47	198.48
342	685	EMPCT	0008	37	198.30
343	1888	MESQN	1505	1429	198.18
344	817	HMTRD	0002	2178	197.93
345	162	PMBRK	1811	24	197.72
346	642	EZACH	0001	985	197.54
347	1007	OAKHL	3011	2252	197.37
348	81	QNLAN	1201	850	197.16
349	527	CUMBY	1201	750	196.36
350	1071	FSTVW	0003	1929	195.26
351	627	SGOVL	1403	2376	194.90
352	2228	IRASB	3211	277	194.82
353	1352	HNTNG	1305	1176	194.78
354	69	STANT	1311	1525	194.58
355	2177	WOVER	6122	833	194.41
356	99	TXHRV	1621	89	194.39
357	1807	DAVIS	3782	983	194.32
358	2090	PLANO	1104	991	193.77
359	238	TYSTH	1203	430	193.45
360	1465	AZLES	2121	2882	192.29
361	261	MNHNS	1912	1899	191.43
362	771	PLSTN	1003	1454	191.07
363	2178	INAIR	1413	2418	190.62
364	2835	SIKES	2422	1066	190.60
365	353	JEWET	1202	759	190.54
366	1502	KYSTN	1021	43	190.47
367	1229	GRDPR	0842	1378	190.03
368	1448	LGVST	8522	354	189.53
369	733	LGVST	8511	754	188.62
370	1587	TRLNW	1203	682	188.56
371	253	AZLES	2112	1718	188.40
372	58	CSHNG	1201	918	187.82
373	196	GODLY	1601	662	187.55
374	277	CRKET	2402	1672	186.82

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
375	188	FLRTN	3711	100	186.78
376	857	FRSTN	1602	1248	186.58
377	1532	REAST	1505	999	186.40
378	1598	TYLER	1004	184	186.36
379	177	CRLTN	1452	1158	185.74
380	1057	RWALL	1203	3587	185.37
381	337	ELKTN	2508	1419	185.26
382	853	DESPR	1405	931	184.65
383	1089	GSTHW	1631	2205	184.63
384	364	LUFKN	1203	741	184.52
385	182	MDAIR	2911	412	184.01
386	344	CHRNO	1203	419	183.71
387	2816	CRKET	1201	323	183.67
388	559	CLMET	0003	909	183.39
389	262	GLNHV	3942	1363	183.06
390	811	SLAKE	8321	4376	182.85
391	1654	LMESA	1522	1334	182.21
392	2549	FLMSO	3714	1231	181.97
393	139	JDKNS	0822	57	181.70
394	2290	ALNTH	2853	2993	180.85
395	170	MSLMN	4007	134	180.70
396	2400	PARIS	1203	953	180.38
397	951	KMPSO	2400	931	180.00
398	494	FARON	4062	1149	180.00
399	695	PRFTW	4222	3314	179.28
400	1909	PRSTN	0004	674	179.17
401	1603	NAVCO	0001	23	178.98
402	1911	GVGLF	9601	50	178.95
403	2106	CHSPG	2401	3722	178.94
404	2502	BLMND	3282	91	178.28
405	1427	WRBND	2321	1545	178.27
406	2012	MSLSW	0001	846	178.16
407	887	FRMNT	0004	2377	178.04
408	1174	FHLSW	1332	309	177.89
409	765	MDLNW	1573	1050	177.79
410	1723	CPRCV	1404	1616	177.20
411	2743	REAST	1507	114	176.47
412	1785	BNTDR	0004	1844	176.38
413	828	ALNTH	2832	974	175.77
414	1447	CNTRY	2833	2366	175.62
415	2728	TMNTH	1603	138	175.56
416	1899	ENTOH	0001	846	175.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
417	699	WOVER	6142	1505	175.33
418	795	LNGLK	1602	637	174.60
419	121	MRKLY	0811	121	174.11
420	1620	HLSES	0511	1809	173.98
421	45	COYAN	6311	105	173.85
422	2672	OKLND	0003	1352	173.20
423	195	BSPSW	0822	395	173.12
424	97	FKLCY	5111	72	172.93
425	808	JREST	2102	1051	172.66
426	1898	FARON	4041	1032	172.34
427	408	FRFWS	3001	1810	171.65
428	2194	WATSN	5342	2032	170.72
429	1362	HURST	1811	1242	170.25
430	744	PFLGV	2004	3937	170.09
431	1734	KNLTR	0003	624	169.91
432	798	RDLML	2581	1238	169.58
433	1962	SCYEN	0004	1234	169.49
434	1317	TYRSW	1701	2410	169.41
435	2121	FSHSW	2111	315	169.18
436	1481	IRVND	1204	1353	168.24
437	961	IRVHF	2305	1455	167.55
438	2500	COHMA	1132	63	167.15
439	13	VESTS	3111	54	167.02
440	1661	PRKWY	1521	2322	166.95
441	923	JREST	2101	1354	166.81
442	194	MNRVA	1301	743	166.49
443	971	WMRLD	0004	1584	166.37
444	1259	OTTOJ	3059	1092	166.36
445	2271	LKMNT	0004	2183	166.34
446	113	SSPNE	1403	1109	166.13
447	2524	CTYVW	2212	145	166.11
448	1576	GNSVE	1603	1687	165.68
449	183	HDWLK	3003	971	165.50
450	420	ROSCO	2921	239	165.13
451	739	REYST	4118	737	164.83
452	1330	OKCLS	0001	1396	164.66
453	234	GRLND	1604	1996	164.57
454	2613	CLLVL	0006	1183	163.97
455	236	ECTHP	4921	311	163.42
456	2887	DENDR	0009	63	163.40
457	2742	PCOMM	3313	473	163.09
458	1079	WXHCH	1202	1710	163.01

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
459	2722	SHMNE	1407	807	162.56
460	1417	JKWST	4035	81	162.48
461	1194	HKBRY	1107	969	162.42
462	231	WMRLD	0007	1696	161.73
463	700	FRMBR	1804	300	161.66
464	2445	WBOSE	1103	906	161.45
465	1503	RCHRD	1205	1039	161.41
466	542	MAYFD	5524	2594	161.35
467	1445	ALLNC	6422	15	161.30
468	1874	WEAST	0629	1802	160.24
469	791	PRCRK	0003	1836	160.11
470	130	HNTNG	1301	1390	159.94
471	643	CRNTH	2401	2531	159.27
472	2185	CHROW	0007	84	158.95
473	2219	JKREA	1201	30	158.82
474	216	MEANS	4421	52	158.33
475	2715	FRMNT	0003	877	158.24
476	1088	PLSTN	1005	1901	158.07
477	1774	CRNRD	0001	740	158.05
478	1896	IRVNR	1553	1336	157.72
479	1629	MABNK	2404	2541	157.09
480	1410	MNFLD	2621	2282	157.08
481	2416	IRVNE	1302	282	156.90
482	1018	DESPR	1407	944	156.70
483	448	RCHLD	2101	613	156.43
484	1032	IRVNE	1304	630	156.24
485	858	MLDR2	1605	216	156.22
486	2341	MESQN	1507	696	155.96
487	651	MKNNY	1203	1083	154.31
488	697	DNCNV	1904	1471	154.01
489	890	GRLND	1605	1533	153.40
490	1108	CLBWS	8112	1626	153.02
491	705	CDHCR	2051	2128	152.99
492	1509	CNI45	2402	811	152.93
493	1982	PLGRV	0002	2338	152.89
494	1137	EXPKY	8142	27	152.29
495	911	IOWPK	0831	1073	152.13
496	1363	TIODE	9611	359	152.12
497	1473	ALLNC	6412	3266	152.10
498	894	LFSTH	1407	1730	151.53
499	968	CLNSE	4201	933	151.39
500	2003	BRHLW	7632	1487	151.38

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
501	2398	OVRTN	4037	119	150.67
502	1358	RKDLE	1301	1226	149.88
503	679	COLNY	2401	734	149.81
504	2045	SALSW	3001	1484	149.66
505	1036	WSOTH	1020	1140	149.31
506	440	MNFLD	2682	2388	149.25
507	398	SSPNE	1401	1276	149.15
508	347	RSPCK	2108	960	149.09
509	2281	SSPNG	1204	972	149.04
510	1305	HUTCH	1501	974	148.44
511	2043	TMPLE	1205	2488	148.40
512	1331	FHLSW	1342	1955	148.38
513	1650	WXHCH	1203	1288	148.12
514	1196	AIRPK	8421	1035	147.43
515	1735	HURST	1861	1849	147.21
516	1159	CMEXP	1601	249	146.94
517	747	TIODE	9621	310	146.92
518	479	MAPLE	0006	2373	146.79
519	2023	EZACH	0005	541	146.76
520	1781	CHROW	0003	155	146.65
521	1505	HSKAV	0005	1373	146.57
522	1779	FINKS	1804	2306	146.56
523	1253	LKWOD	7442	717	146.44
524	67	JKWST	4178	421	146.26
525	1618	ARMST	0009	1140	146.18
526	1594	WWDWY	2015	1200	146.14
527	452	TYLER	1005	2004	146.04
528	225	HRSMD	1955	2091	145.50
529	844	PCUST	2011	1639	145.36
530	133	WCITY	2401	917	145.34
531	1479	RENSW	3121	1942	145.20
532	1041	RENSW	3124	1708	144.91
533	1855	SFTLK	4021	39	144.75
534	256	KRUMS	1202	701	144.68
535	1829	TMPTV	2404	1427	144.19
536	852	FINKS	1802	727	144.18
537	98	LNDAL	2203	2424	144.02
538	342	WHITE	3541	955	143.97
539	1335	HORNE	1932	1159	143.88
540	1472	CPLSO	4321	158	143.82
541	1365	NCRST	2204	443	143.64
542	2401	HSKAV	0006	756	143.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
543	2944	FRMNT	0011	993	143.35
544	2110	CPRCV	1406	1640	143.30
545	488	DIBOL	1505	1446	143.13
546	1394	BOWEN	3161	1544	143.12
547	435	RWALL	1202	2503	143.05
548	38	RSPCK	2103	167	143.02
549	229	IOWPK	0821	756	142.50
550	2569	ARTHR	0462	209	141.92
551	174	SMPST	0003	1020	141.82
552	348	CNTRY	2842	1148	141.67
553	2018	ABRRD	0006	456	141.63
554	377	MSHLN	0001	1043	141.62
555	624	CNTRY	2811	2659	141.53
556	891	NPKWY	0010	3016	141.51
557	320	ENSSO	2002	1109	141.39
558	616	NCSTH	1501	808	141.22
559	2429	DAVIS	3733	294	141.20
560	1562	CRLTR	2004	235	141.08
561	1486	SALSW	3003	733	140.98
562	515	PRCRK	0001	202	140.81
563	93	ECTHM	3341	2415	140.47
564	161	LUFKN	1206	1615	140.31
565	1344	MNFLD	2611	1894	140.19
566	314	ALNSW	2653	3516	140.08
567	2122	CLBNR	1407	268	140.04
568	1188	TRSES	1201	500	139.84
569	1999	BSPRG	1901	586	139.80
570	518	SCYEN	0001	2012	139.77
571	2131	CRYVE	3021	1285	139.75
572	759	MKNNY	1251	1517	139.73
573	1066	MCWHT	3511	3132	139.49
574	2257	EDGCF	2272	1079	139.42
575	1950	PRFTW	4212	2009	139.23
576	176	LENSW	0321	46	138.95
577	382	BRLSN	2051	2689	138.90
578	822	DNISN	1203	1686	138.79
579	331	CNTRY	2822	2847	138.48
580	1332	MESQW	1802	827	138.23
581	28	RBNSN	2502	1224	137.92
582	823	PCUST	2008	694	137.84
583	964	LNCST	1605	816	137.70
584	1964	FSTVW	0004	2269	137.52

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
585	1906	SMFLD	2352	602	137.44
586	120	CNTRY	2831	1592	137.44
587	290	MNHNS	1911	1515	137.27
588	510	OVRTN	4019	660	137.17
589	1675	PKRMX	4703	3034	136.56
590	1441	NHNSW	0005	422	136.22
591	762	WMRLD	0008	1595	136.20
592	445	HUTCH	1503	551	136.18
593	1767	KIMBL	5032	1741	135.93
594	178	INAIR	1432	3279	135.69
595	2008	EULSO	9132	1987	135.67
596	1415	BNBRK	4112	2229	135.36
597	1497	SPRDL	4841	953	135.30
598	1375	TMPSE	1503	621	135.01
599	140	BAKKE	6911	287	134.46
600	421	FERIS	1101	1179	134.33
601	1630	FLMSO	3716	2141	134.21
602	410	TYOMN	1409	1600	134.07
603	702	WESTS	1601	1047	133.92
604	2298	PROAD	0007	422	133.77
605	2977	RGFTW	6841	20	133.64
606	1051	WOVER	6111	1329	133.62
607	829	RWALE	3321	1533	133.40
608	244	COLNY	2404	1947	133.27
609	1582	WNRTH	1421	1484	133.22
610	1457	NCNTH	1808	757	133.14
611	1634	LWSNR	2232	2269	133.11
612	1649	LKMNT	0003	603	132.97
613	1756	STAUG	0002	1402	132.82
614	591	LNDAL	2201	1907	132.72
615	763	EULES	8724	2400	132.66
616	1705	MESQW	1806	1665	132.49
617	1771	OAKHL	3021	1988	132.49
618	2250	RSPCK	2132	72	131.98
619	2438	BRNAV	0753	1267	131.97
620	704	PRKWY	1552	556	131.83
621	746	CDMIL	2401	902	131.82
622	687	LFSTH	1406	2091	131.71
623	1507	PFFRD	3441	1211	131.67
624	310	MKNNY	1252	2649	131.65
625	707	DAVST	0004	1721	131.59
626	2350	HORNE	1961	1774	131.56

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
627	1602	MDAIR	2921	71	131.33
628	975	HRSMD	1957	2457	131.27
629	2768	PTENN	2355	179	130.83
630	1802	WXNTH	2306	2356	130.74
631	871	LFEST	1904	1335	130.56
632	2205	TYLGE	1316	2841	130.51
633	1937	KLNPS	1102	1883	130.47
634	717	TYBLR	2803	787	130.32
635	922	MEXIA	4007	453	130.32
636	2660	WGROB	8421	2174	130.20
637	409	BEAST	4090	937	130.14
638	291	STHRL	0001	602	129.97
639	267	CRLUD	1307	290	129.88
640	712	GNSVL	1213	737	129.85
641	1797	BRKRG	0223	286	129.71
642	1660	VLARN	2953	2837	129.70
643	2431	WCOLO	1319	2072	129.33
644	1072	VGCRK	8041	1041	129.22
645	368	PRCRK	0002	2234	129.19
646	1026	PPARK	1805	996	128.88
647	2965	MESTE	1201	23	128.82
648	179	STHRL	0007	134	128.74
649	622	BRIRV	6911	3239	128.61
650	1854	CNTRY	2862	401	128.56
651	2239	PTENN	2351	1553	128.48
652	572	DNCNV	1902	1078	128.36
653	2425	SHDYG	7822	529	128.00
654	1861	IRVNE	1309	1130	127.78
655	1638	SWTWR	1382	438	127.68
656	2550	PCOIT	1024	2312	127.36
657	1894	WOVER	6131	2113	127.20
658	433	HNRTA	0321	850	127.13
659	1494	LORAN	9711	391	127.03
660	2551	GODRD	8161	2216	126.84
661	1373	BLMND	3213	3272	126.57
662	484	NCNTH	1802	1289	126.57
663	1560	LKMNT	0008	1004	126.38
664	666	NCNTH	1801	2532	126.33
665	1919	MDWPK	9241	1566	126.32
666	941	WWEST	1219	941	126.28
667	1689	MCDMT	2532	1978	125.96
668	233	WLSPT	1002	604	125.93

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
669	274	MKNSO	3611	1944	125.78
670	2868	PRKRW	3382	309	125.73
671	2392	BRNAV	0741	2076	125.44
672	1008	PALRD	2206	1511	125.41
673	416	CADDO	0911	448	124.84
674	1590	WWDWY	2022	1028	124.82
675	471	TYWST	2003	1412	124.71
676	1622	PPARK	1803	1063	124.56
677	1674	PWEST	1303	1008	124.52
678	1388	LUFKN	1202	1070	124.49
679	1105	DUVAL	0441	1034	124.46
680	985	WATCO	2602	2273	124.37
681	1210	DALLW	0005	128	124.34
682	2009	LEMON	0004	579	124.31
683	1616	FROKS	0003	639	124.23
684	2216	HLSES	0522	1753	124.19
685	1288	LVBRD	0004	1059	124.04
686	2081	BKBNT	1842	555	124.01
687	1678	HMPHL	2781	331	123.79
688	1064	AYERS	4431	1667	123.75
689	486	CRKET	2403	2796	123.67
690	2599	WFALS	0153	1135	123.65
691	1285	CMPWI	0002	1660	123.54
692	1391	RDLML	2521	1025	123.46
693	481	IRVNR	1501	1103	123.37
694	1992	HSKAV	0002	1737	123.15
695	2458	PAYSW	1213	1427	123.02
696	388	ANDNR	2222	126	122.99
697	1643	WXNTH	2308	869	122.77
698	2553	BRYAN	0001	16	122.60
699	25	HDWLK	3005	1020	122.46
700	153	GVODS	3041	1477	121.49
701	338	BRNAV	0723	1330	121.29
702	1701	HHSTH	1502	3740	121.23
703	1163	ATHNW	1402	487	121.12
704	1656	THRDN	1901	1710	121.09
705	2162	SHNRW	1611	975	120.95
706	809	FHLSW	1351	1443	120.82
707	1268	JSHUA	1301	1003	120.81
708	2621	WNDWD	3631	309	120.56
709	1580	MEXIA	4011	1015	120.51
710	723	DALRK	1305	1153	120.37

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
711	1109	DESPR	1403	1796	120.29
712	2086	TYLGE	1308	1559	120.24
713	1738	TYLNW	1912	2100	120.11
714	2604	MESFR	2103	375	119.99
715	1070	TERSO	2501	185	119.70
716	2394	ODNTH	2024	2618	119.63
717	1642	STAUG	0001	707	119.44
718	2959	LSCOL	2114	91	119.25
719	326	CANTN	1301	2169	119.24
720	1581	MDLNW	1552	1365	119.18
721	1556	LOMAL	0001	676	119.15
722	843	NHNSW	0007	581	119.13
723	1565	KIMBL	5022	890	119.00
724	292	WICKT	0421	137	118.78
725	649	DCDAM	2003	1322	118.54
726	204	ATHNS	1202	775	118.51
727	784	BRNAV	0711	1642	118.35
728	2591	GLNHV	3931	1338	118.30
729	2967	PJPTR	3222	183	118.13
730	522	PRSTN	0006	758	118.05
731	1621	TRNTH	1503	1841	117.85
732	1762	WXNTH	2304	855	117.83
733	63	MDLNE	0142	884	117.78
734	1498	RBNSN	2503	1126	117.71
735	602	CHYNE	9121	91	117.70
736	315	REAST	1503	570	117.65
737	635	ORANS	1501	850	117.55
738	135	CRSCN	1206	1518	117.50
739	661	EUSTC	2401	1705	117.43
740	2828	NHNSW	0002	404	117.34
741	1672	MRVLY	2311	368	117.27
742	493	BEAST	4084	875	117.24
743	619	CRNTH	2402	1461	117.18
744	2040	TYLER	1001	153	117.02
745	963	NCDCH	1204	1268	116.93
746	2371	REGST	0004	980	116.92
747	2052	GSTHW	1633	955	116.45
748	833	SWAN2	1801	543	116.31
749	87	RDLML	2561	897	116.30
750	610	RHOME	2402	1324	116.29
751	1712	MTLDA	0001	2603	116.22
752	1528	SYCRK	4532	4150	115.92

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
753	444	NCSFA	1704	1402	115.87
754	939	RECCR	0003	210	115.81
755	2049	TMSTH	1404	1313	115.79
756	1571	OAKHL	3072	2489	115.67
757	482	IRVBL	2507	904	115.65
758	1967	ARMST	0012	1161	115.53
759	751	LTLRV	1701	1085	115.48
760	403	MCDMT	2531	2439	115.45
761	1936	CMTSW	0916	555	115.44
762	1209	ENNIS	1906	2033	115.35
763	1522	TAYLR	1202	1565	115.26
764	1461	PCUST	2004	1204	115.22
765	285	COLNY	2405	2388	115.19
766	2485	GRMES	0521	549	115.15
767	1857	DGNST	0006	1283	114.94
768	586	BKBNT	1832	196	114.79
769	2492	BRHLW	7641	36	114.69
770	2451	IRVNR	1552	68	114.64
771	2256	GLNHV	3983	1677	114.60
772	920	ROLTR	2912	3609	114.28
773	1912	WWEST	1222	178	114.28
774	2265	ARLNG	1261	1366	114.23
775	943	GDPRW	9611	1261	114.04
776	2152	SWDTN	1641	1572	114.01
777	2014	HOLDY	0921	615	113.95
778	363	STAUG	0006	1800	113.90
779	430	SCHRD	0007	1405	113.88
780	449	WHOUS	4122	2062	113.67
781	570	HSKAV	0007	1888	113.17
782	534	RSKMN	3046	1085	113.10
783	772	COLNY	2403	2631	113.04
784	2640	PTENN	2352	2488	112.89
785	595	WXHCH	1204	1782	112.82
786	538	CURIE	7211	752	112.72
787	725	KLBRG	0003	1404	112.66
788	239	DIALV	3911	1081	112.51
789	172	CSHNG	1202	66	112.25
790	766	GODRD	8171	839	112.25
791	307	WDGWD	1572	1475	112.08
792	341	WEBBS	8614	2507	111.95
793	551	PRKWY	1511	1301	111.85
794	805	PAYSW	1202	1652	111.60

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
795	1651	ITALY	2101	568	111.25
796	2312	MCKMY	0822	1386	111.22
797	1518	STERT	2706	171	111.10
798	1037	RSPCK	2102	1562	111.10
799	301	TRSES	1202	507	111.03
800	1542	DCVSO	1106	1210	110.91
801	298	CDHIL	1623	2153	110.88
802	1272	RWALE	3322	1946	110.84
803	2559	CMPWI	0005	1645	110.84
804	1681	FRMBG	1707	443	110.82
805	145	GLNHV	3973	1525	110.55
806	109	KRGRV	2403	3720	110.38
807	1670	MCWHT	3522	2963	110.10
808	2961	LSCOL	2140	624	109.89
809	900	PCUST	2006	1611	109.77
810	734	NPKWY	0005	856	109.65
811	1454	REYST	4040	545	109.20
812	2279	SNYDR	1833	1425	108.79
813	2060	EULES	8711	2049	108.58
814	2120	GNSVL	1205	880	108.52
815	2170	BDFRD	8812	770	108.19
816	278	SHRSW	6611	1243	108.10
817	2809	LVBRD	0001	38	108.03
818	1187	RCHRD	1208	1036	107.87
819	2748	AIRPK	8432	948	107.54
820	374	BDFRD	8822	1054	107.44
821	1813	RDOAK	1302	1252	107.40
822	612	ARLNG	1241	657	107.28
823	1510	LUFKN	1201	1341	107.18
824	2267	WFALS	0174	1226	107.05
825	1865	DNIWS	1603	1363	106.84
826	218	ATHNS	1203	1044	106.73
827	2186	NMAIN	0211	1928	106.64
828	938	LWSNR	2221	1451	106.59
829	812	PRFTW	4221	1383	106.55
830	813	CKRHL	0002	425	106.48
831	1563	ALPHA	0009	62	106.42
832	2195	GLNHV	3911	1360	106.40
833	2264	RANGR	4321	869	106.17
834	2693	BLKST	1752	1176	106.08
835	2476	SMPST	0005	152	106.06
836	1258	CMPST	0002	1060	105.73

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
837	2159	PRCTR	1602	230	105.69
838	404	SYCRK	4531	2434	105.50
839	1186	DNISN	1204	1213	105.25
840	1523	DENAV	0611	852	105.04
841	842	DCATR	1202	1720	105.01
842	782	SHAMP	0007	690	104.99
843	2319	NMAIN	0272	414	104.84
844	895	BOWEN	3171	1717	104.83
845	836	COPEL	3051	1588	104.65
846	1488	GRLRD	0002	994	104.51
847	1750	OKCLS	0003	1513	104.28
848	1024	BNDRA	0003	820	104.08
849	525	EULES	8722	2131	103.88
850	959	HURST	1822	1588	103.87
851	2336	RDRSE	2603	3880	103.83
852	2368	DAVST	0007	608	103.58
853	289	MSLSW	0002	1038	103.54
854	884	WNDWD	3652	979	103.19
855	206	MKNSW	2602	1272	103.08
856	873	MESQT	1302	654	103.06
857	2272	ROLTR	2921	2599	103.00
858	1230	WFALS	0184	1263	102.94
859	190	ROSCO	2911	616	102.57
860	432	BRKTN	1201	493	102.21
861	1400	GRPVN	8213	264	101.83
862	386	DALRK	1307	1161	101.76
863	1995	ALLEN	2401	744	101.51
864	460	WMRLD	0003	489	101.45
865	1043	FSCRK	6713	3068	101.25
866	1545	ARLNG	1223	1838	101.22
867	1406	HLTOM	2452	1810	100.97
868	1266	ODESW	5922	2399	100.94
869	462	SLBLF	1201	139	100.94
870	799	ALNSW	2652	2600	100.92
871	2687	RSPVY	1708	980	100.85
872	2454	MDWCK	0003	1873	100.33
873	1119	BNDRA	0002	540	100.23
874	2115	SSPSW	1604	1212	100.10
875	144	RSKMN	3057	1173	100.00
876	564	BNTDR	0003	460	99.94
877	2377	NCRST	2201	1934	99.90
878	1644	PSHIL	1608	1941	99.80

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
879	1307	BLTON	1806	847	99.76
880	1323	DALLW	0006	1950	99.71
881	2112	GSTHW	1692	999	99.71
882	2851	HNYGR	2403	594	99.65
883	1378	KLELM	2205	3200	99.55
884	1753	EZACH	0007	1591	99.54
885	1516	NCDCH	1206	1098	99.40
886	2054	LKWOD	7411	630	99.34
887	1414	ELZCK	4911	35	99.33
888	978	HRSMD	1905	2787	99.30
889	927	BNMAG	1202	405	99.23
890	1215	SANSM	3912	5168	99.22
891	2718	PJPTR	3211	118	99.17
892	603	COMSO	1401	655	98.93
893	2535	TYBLR	2808	981	98.87
894	1033	ARTHR	0481	1251	98.86
895	270	WDGWD	1523	308	98.76
896	1276	CPRCV	1405	1530	98.66
897	1144	HLTOM	2431	1306	98.44
898	1871	WTAUG	4643	1001	98.34
899	797	MEXIA	3015	123	98.29
900	384	EDWDS	5931	1087	98.27
901	1336	FRMBR	1805	760	98.08
902	658	ODESW	5221	1484	97.97
903	330	JKSNR	4105	84	97.88
904	1573	PRMED	4401	2042	97.85
905	477	FSCRK	6711	3788	97.81
906	1439	LMESA	1531	640	97.62
907	33	EDWDS	5921	24	97.45
908	509	CDHIL	1801	1050	97.29
909	333	MKNGB	5322	1587	97.22
910	1396	GVODS	3021	262	97.09
911	988	TMNTH	1602	474	96.88
912	1525	MESWE	3621	807	96.88
913	1392	TRLWD	7711	2341	96.88
914	2499	HORNE	1911	1017	96.80
915	102	MKNGB	5321	590	96.70
916	152	VANAL	2412	2997	96.68
917	1138	BBTWN	1504	2105	96.65
918	618	KNLTR	0004	1945	96.51
919	630	PNTGO	7121	1506	96.50
920	867	DCVSO	1105	1660	96.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
921	869	NHNSW	0004	567	96.46
922	2885	JKSNR	4107	330	96.46
923	1728	TATSP	4322	2534	96.42
924	1156	AZLES	2111	3043	96.29
925	1165	KLNTF	1804	1007	96.17
926	1399	IRVGS	1905	770	96.08
927	686	MURPH	2754	2115	96.00
928	2365	MSHLN	0008	680	95.99
929	446	BDFWD	8921	688	95.95
930	2226	FORSW	2015	2404	95.84
931	2702	RVRFT	0002	330	95.74
932	1408	EDGWD	1102	947	95.69
933	2149	GNSVN	1403	299	95.60
934	73	MAREA	1201	151	95.59
935	137	IOWPK	0811	789	95.55
936	1327	ARTHR	0492	49	95.48
937	1584	SYCRK	4522	2835	95.48
938	565	TRNTH	1501	1765	95.45
939	1776	BLMED	1622	955	95.39
940	1170	TRLWD	7722	4056	95.38
941	2022	LAVON	1454	2979	95.32
942	552	JUDCT	0007	895	95.31
943	395	CHICG	1402	508	95.20
944	1766	RDLML	2591	1626	94.97
945	2440	GRLWS	1706	289	94.91
946	972	CTYVW	2222	1385	94.71
947	898	DCVSO	1104	1352	94.69
948	1168	LNCST	1604	637	94.62
949	1780	SIKES	2421	1843	94.50
950	1318	HLSBR	1201	1128	94.45
951	2585	CLBNR	1402	2453	94.45
952	1892	MESQW	1804	1344	94.42
953	914	CRLTR	2001	2501	94.40
954	621	LAVON	1452	1816	94.27
955	790	SHMNE	1409	900	94.16
956	1994	DUVAL	0414	653	94.02
957	385	CSHNG	1204	326	93.84
958	1056	CLBNR	1406	106	93.75
959	2366	RKDLE	1302	1186	93.70
960	#N/A	PGSTH	7012	173	93.68
961	1225	COLNY	2402	2426	93.60
962	1925	WELRD	0006	732	93.49

Service Quality Report to the Public Utility Commission of Texas

Oncor Electric Delivery

2016 SAIDI Ranking	2015 SAIDI Ranking	Substation Identification	Feeder Identification	Number of Customers	2016 SAIDI Value
963	2676	ARMST	0010	880	93.47
964	662	DALRK	1354	1461	93.46
965	936	ELMGV	3653	1988	93.33
966	998	NYLDV	1201	652	93.28
967	487	COPER	1201	321	93.27
968	2955	KIMBL	5011	162	93.25
969	1801	DALRK	1358	2088	93.20
970	600	AZLES	2122	2255	93.00
971	2564	PALRD	2203	1088	92.67
972	800	MSHLN	0003	531	92.67
973	885	CDHCR	2054	1435	92.56
974	1076	SHAMP	0001	1230	92.46
975	12	LMESA	2813	118	92.37
976	103	TRPMN	4023	426	92.36
977	703	GRAHM	0721	1241	92.22
978	451	WBROK	3021	51	91.94
979	1150	DCVSO	1103	1828	91.87
980	1333	PLANO	1101	404	91.85
981	1251	HUDSN	1603	1799	91.39
982	2523	GSTHW	1682	179	91.38
983	2923	FRMNT	0002	575	91.26
984	1040	DEALY	0001	730	91.03
985	2543	BRTRD	7312	3712	90.83
986	929	PARIS	1201	1137	90.83
987	1814	DAVIS	3772	1720	90.74
988	1877	ELZCK	4921	1733	90.67
989	#N/A	CMTSW	0936	522	90.66
990	743	BRIRV	6912	805	90.54
991	1083	PNTGO	7111	723	90.09
992	761	DAVST	0002	552	90.06
993	1557	CRLJL	1501	1463	89.83
994	1845	SMFLD	2333	1063	89.80
995	1455	BLTLN	0002	880	89.79
996	1859	LOMAL	0016	664	89.76
997	1827	WITTS	1705	1353	89.59
998	1700	MDTHN	1702	1899	89.51
999	2663	LEMON	0011	1870	89.34
1000	632	EMPCT	0001	35	89.32
1001	1970	WNDWD	3682	782	89.30
1002	648	MESQN	1504	1331	89.18
1003	1282	GAVSW	0005	1500	89.17
1004	1475	LIGSW	1602	1109	88.98